

Table 2 2010 Drinking Water Quality Report

Results of Primary Inorganics Monitoring by Well

Date Sampled 2008 - 2009

ND = not detected. When a compound is not detected in a specific well, the space is left blank.

Well name	Antimony	Arsenic	Barium	Beryllium	Cadmium	Chromium	Cyanide	Fluoride	Lead	Mercury	Nickel	Nitrate	Nitrite	Selenium	Sodium	Thallium
MCL:	6	50	2	4	5	100	200	4	15	2	100	10	1	50	160	2
Units:	ppb	ppb	ppm	ppb	ppb	ppb	ppb	ppm	ppb	ppb	ppb	ppm	ppm	ppb	ppm	ppb
Maximum:	0.0	0.0	0.1	0.0	0.5	0.0	9.0	0.7	1.1	0.1	0.0	4.2	0.0	0.0	9.2	0.0
Minimum:	ND	ND	0.01	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	2.3	ND
Hi Ann'l Avg.												2010.0				
Davis 2008			0.0					0.35	0.8			1.1			6.7	
McAllister			0.0					0.36				2.1			4.8	
Davis			0.0				5.0	0.45		0.1		1.1			4.8	
Broad Street			0.0				6.0	0.44		0.1		1.2			4.0	
Sweeney			0.0					0.55		0.1		1.3			4.7	
Olive			0.0				2.0					3.1			8.7	
Ellyson			0.0				4.0	0.41		0.1		2.1			6.4	
Ensley																
Airport North			0.0				5.0	0.51	0.6	0.1		1.1			4.2	
Dunaway			0.0				3.0			0.0		0.3			2.3	
Royce			0.0					0.03				2.0			5.3	
University			0.0		0.5		4.0	0.42		0.0		0.3			2.7	
OLF 4A			0.0				9.0	0.49		0.1		2.0			5.8	
Avondale/ Muldoon			0.0					0.42				1.9			4.8	
Carriage Hills			0.0							0.0		0.1			2.9	
Cantonment			0.0					0.43	1.1			0.3			3.1	
McCrary			0.0									1.4			3.3	
Tennant			0.0					0.04				2.1			4.8	
West			0.1					0.48				3.9			9.2	
West Pensacola			0.0				6.0	0.51		0.0		0.1U			6.7	
W & Avery			0.1					0.43				4.2			9.0	
F & Scott			0.1				4.0	0.54	0.6	0.1		1.6			5.0	
Lillian			0.0					0.34		0.0		2.8			7.6	
Hagler			0.0				2.0	0.51				0.8			7.4	
#6 Well			0.1							0.1		2.2			5.3	
Bronson			0.0				3.0	0.43				0.7			2.4	

Villa Drive			0.0					0.27				0.9			5.1	
Spanish Trail			0.0					0.54				1.0			3.0	
Nine Mile Rd.			0.0					0.53				0.8			3.0	
Kingsfield			0.0					0.65				0.4			2.8	
Watson 2009			0.0									1.1			4.0	