

Table 4
2009 Drinking Water Quality Report
Results of Secondary Contaminant Monitoring by Well
Date Sampled 2008

ND = not detected. When a compound is not detected in a specific well, the space is left blank.

<u>Well name</u>	<u>Aluminum</u>	<u>Chloride</u>	<u>Color</u>	<u>Copper</u>	<u>Foaming</u>	<u>Iron</u>	<u>Manganese</u>	<u>Odor</u>	<u>Silver</u>	<u>Zinc</u>	<u>Sulfate</u>	<u>TDS</u>
MCL	0.2	250	15	1.000	0.5	0.3	0.05	3	0.1	5	250	500
Units:	ppm	ppm	color units	ppm	ppm	ppm	ppm	odor number	ppm	ppm	ppm	ppm
Max:	0.1	13	0.0	0.007	0.1	0.28	0.036	2.0	0.0	0.1	12.0	130
Min:	ND	4	ND	ND	ND	ND	0.001	ND	ND	ND	ND	29
Humphreys	0.04	9		0.001		0.03	0.014				4	83
McAllister	0.03	7		0.001	0.03		0.007				1	58
Davis	0.03	8		0.002		0.28	0.035	2.0			3	100
Broad Street	0.03	5		0.001		0.02	0.001				1	54
Sweeney	0.04	7				0.03	0.001				5	97
Olive	0.04	10					0.017				4	83
Ellyson	0.04	8		0.002		0.02	0.015				2	70
Ensley												
Airport North	0.01	7		0.007			0.006				1	29
Dunaway	0.04	5				0.03	0.003				1	59
Royce	0.09	8		0.003	0.03	0.04	0.016			0.1	3	92
University	0.03	4		0.001		0.03	0.006				3	37
OLF 4A	0.03	7		0.001		0.03	0.005				1	68
Avondale/ Muldoon	0.03	8		0.002			0.006	2.0			1	65
Carriage Hills	0.02	5									0	47
Cantonment	0.03	5		0.002			0.005	2.0			1	63
McCrary	0.04	5				0.02	0.003				0	60
Tennant	0.04	7		0.002		0.03	0.003	2.0			1	61
West	0.06	11		0.001		0.02	0.010				4	120
West Pensacola	0.04	8				0.03	0.004				2	100
W & Avery	0.05	11			0.05		0.006	2.0			2	110
F & Scott	0.09	6		0.001		0.13	0.030				11	130
Lillian	0.06	10		0.001	0.00	0.03	0.013	2.0			6	110
Hagler	0.05	13			0.03		0.004				8	93
#6 Well	0.06	8				0.03	0.036	2.0		0.1	12	130
Bronson	0.03	4		0.001		0.02	0.011				2	67
Villa Drive	0.05	8		0.002		0.05	0.010	2.0			3	85
Spanish Trail	0.05	6					0.003				1	69
Nine Mile Rd.	0.03	4		0.001							1	49
Kingsfield	0.04	5				0.04	0.003				1	71
Watson							0.005					47


