



LIBERTY HOMES, INC.

Corporate Office

October 7, 2005

Lon Larsen (via fax: 760-744-7444)
 Oliver Technology
 562 Glenheather Dr.
 San Marcos, CA 92069

RE: Use of Oliver Foundation System

Dear Lon;

I have reviewed Oliver Technology products for installation in relationship to Liberty Homes' Installation Manual for Wind Zone I, II & III areas for the following products.

- Oliver Model 1101-L "V" All Steel Foundation – Florida Installation
- Oliver Model 1101 "V" All Steel Foundation – Florida Installation
- Oliver Adjustable Outrigger
- Oliver Model 1055 ABS Pads
- Oliver Model CB1 or CB2 Cap Boards

Accordingly, these products may be used to properly secure any Liberty home for the Wind Zone I, II & III areas.

Please call me if you have any questions.

Sincerely,

LIBERTY HOMES, INC.

Nader Tomasbi, P.E.
 Vice President of Product Development
 & Engineering Services

seh



LIBERTY HOMES, INC.

Corporate Office

April 30, 2004

To Whom It May Concern:

Liberty Homes, Inc. approves the use of the "All Steel Foundation Systems" by Oliver Technologies on new or used homes in wind zones 1 and 2 as a supplement to our existing setup procedures provided the following conditions are met.

- Instructions must be approved by a registered professional engineer or architect.
- Local jurisdiction has approved this system.
- System is to be completely installed as per manufacturer's installation instructions.
- Pier blocking and footings continue to be installed as per Liberty Homes, Inc. setup manual.

The same applies for any and all model lines (Waverlee, Badger) produced by any Liberty Homes, Inc. facility and includes the following All Steel Foundation Systems model numbers:

1100-1'V'
1100-11'V'
1100-1C'V'
1100-11C'V'

Please call if you have any questions.

Sincerely,
LIBERTY HOMES, INC.

Nader Tomasbi, P.E.
Vice President of Product Development
& Engineering Services

seh