



10-23-07

Mr. Tommy Colley, or Jim Sloan
350 South Decatur Street
Montgomery, AL 36104
Phone (334) – 242-4036
Fax (334) – 240-3178


Subject: Use of Oliver Technologies Foundation Systems

In response to your request, Live Oak Homes has approved the use of Oliver Technologies, Inc foundation systems as an alternative to the standard installation; piers, footings, and tie-down as detailed in the Live Oak Homes installation instructions. These systems are deemed acceptable for use on new and used homes produced by Live Oak Homes. Approved are the following products:

- Oliver “1100” V Series ASF systems
- Oliver Adjustable Outriggers
- Oliver ABS Pier/Foundation Pads
- Oliver CB1 and CB2 Cap Boards
- Oliver Anchors and Anchoring Components

These products may be used to properly secure any Live Oak Homes in Wind Zones I, II and III areas as long as the following requirements are met:

1. The foundation system is installed specifically per the manufacturer’s instructions.
2. A registered engineer or architect must approve the manufacturer’s instructions.
3. Local Jurisdiction has approved the item in question.



Wayne Gilmore
Director of Engineering
Live Oak Homes
2875 Fulford Rd.
Waycross, GA 31503

2875 Fulford Rd. ■ Waycross, GA 31503 ■ Office (912) 287-9015 ■ Fax (912) 287-9017