



PIONEER HOUSING SYSTEMS, INC.

June 6, 2001

Jimmy Sloan (via fax 334-240-3178)
 State of Alabama
 Manufactured Housing Commission
 305 South Decatur Street
 Montgomery, AL 36104

Subject: Oliver All Steel Foundation System

Dear Jimmy:

Thank you for helping me understand the issues with the subject system and the State of Alabama approvals. We have approved using the All Steel Foundation System by Oliver Technologies (a.k.a. Manufactured Housing Foundation Systems) as the anchoring system of a Pioneer manufactured home in Alabama with the following restrictions:

- . the manufacturer's installation instructions must be followed,
- . such instructions must be approved by a registered professional engineer or architect,
- . the maximum pier height in 32 inches,
- . four ground anchors must also be installed on any single-wide, and
- . installations must be limited to Wind Zone I.

If you have any further questions please feel free to call me.

Sincerely,

PIONEER HOUSING SYSTEM, INC.


 David Paulk, G.M.
 General Manager

cc- Jerry Moriarty, Bob Henry, Lon Larson – Oliver (via fax 760-744-7444)

"A QUALITY BUILT HOME FOR YOUR TOMORROW"

P.O. Box 250
 Fitzgerald, GA 31750

0011111111111111

2294232849

Phone (812) 423-6630
 06/19/2001 15:39