



State of Idaho

DIVISION OF BUILDING SAFETY

JAMES E. RISCH
Governor
John A. McAllister
Administrator

1090 East Watertower Street
Meridian, Idaho 83642
208-334-3950
dbs.idaho.gov

September 20, 2006

Mr. Scott Oliver
Oliver Technologies
PO Box 9
Hohenwald, TN 38462

RE: Idaho Approval of OTI ABS Wedges

Dear Mr. Oliver:

The Idaho Manufactured Housing Installation Committee has approved your company's OTI-ABS wedge product for use in Idaho in conjunction with manufactured housing foundation support systems. These ABS wedges were tested by Tri-State Testing Services and approved for a maximum working capacity of 12,000 lbs. These wedges are to be used in pairs with single stack concrete block support piers or two pairs with double stack block support piers.

This approval letter and OTI-ABS wedge installation instructions shall be made available to installers or local building code officials upon request.

Sincerely,

A handwritten signature in black ink, appearing to read "Jack Rayne".

JACK RAYNE
Building Bureau Chief

JR/eh

C: Idaho Manufactured Housing Installation Committee