



State of Idaho
DIVISION OF BUILDING SAFETY
BUILDING BUREAU

1090 East Watertower Street
Meridian, ID 83642

DIRK KEMPTHORNE

Governor

DAVE MUNROE

Administrator

(208) 334-3896 FAX (208) 855-9399

January 31, 2005

Mr. Scott Oliver
Oliver Technologies, Inc
4678 Swan Ave
Hokenwald, TN 38462

RE: Idaho Approval of Model OTSFT Swivel Frame Tie
(Radco Test Report RAD-3254)

Dear Mr. Oliver:

At a recent meeting of our Idaho Manufactured Home Installation Committee on January 26, 2005, a decision was made approving the above subject product for use in anchorage of manufactured housing.

The maximum allowable working load capacity is 3150 lbs with no more than 2% elongation and the product is limited also to a maximum ultimate load of 4725 lbs. The product identified above shall be appropriately labeled in accordance with its listings.

You should be prepared to make available copies of your test reports and this Idaho approval letter upon request.

Sincerely,

A handwritten signature in black ink, appearing to read "Jack Rayne", with a long horizontal flourish extending to the right.

JACK RAYNE
Building Bureau Chief

JR/eh

C: Idaho Manufactured Housing Committee