



**Bill Richardson**  
GOVERNOR

**Arturo L. Jaramillo**  
SUPERINTENDENT

**Marilyn L. Hill**  
DEPUTY SUPERINTENDENT

**John Alejandro, Sr.**  
DIRECTOR

**Manufactured Housing Division**  
725 St. Michael's Drive 87505  
P.O. Box 25101 Santa Fe, New Mexico 87504-5101  
(505) 827-7070

January 5, 2004

Mr. Lon Larson  
Oliver Technologies – All steel Foundation System  
562 Glen Heather Dr.  
San Marcos, California 92069

Dear Mr. Larson:

Please be advised that the State of New Mexico Manufactured Housing Division has received and reviewed your request to approve “Oliver Technologies – All Steel Foundation System Model #1100 ITV and Model #1100ILV” as a foundation system for Manufactured Homes.

Based upon our review, we hereby approve “Oliver Technologies – All Steel Foundation System” as an alternative method of installing manufactured homes on secondary sets to be considered as a permanent foundation where no home installation instruction manual is available. The system must be installed with an engineered tie down system and used as a Retrofit system on homes that have been sitting at said location for a minimum of two (2) years. Oliver Technologies – All Steel Foundation System used on NEW homes must be installed based upon the manufacturer’s DAPIA approval and must be included in the manufacturer’s installation manual.

This approval is based upon the engineering analysis performed on this product, and must be installed in accordance with the Oliver Technologies – All Steel Foundation System’s listed instructions for wind Zone I. Furthermore, if the State requires the licensed installer to perfect a section of the State regulation, the State regulation will apply, not your company’s installation instructions.

This approval is hereby granted until *January 5, 2005*, or until the Division deems it necessary to withdraw approval. The State must be notified prior to the system being installed by issuing the appropriate state permit.

If you have any questions regarding this approval or the permit process, please do not hesitate to contact me at (505) 827-7070.

Sincerely,

Pasqual Armijo III  
Bureau Chief

c: File