



## MANUFACTURED HOUSING DIVISION

Rick Perry  
GOVERNOR

Timothy K. Irvine  
EXECUTIVE DIRECTOR

**Board Members**  
*Presiding Officer:* Cary Yates  
Jack Davis  
Clement P. Moreno  
Joan Tavarez

September 2, 2003

Mr. Scott Oliver  
Oliver Technologies, Inc.  
P.O. Box 9  
Hohenwald, Tennessee 38462

RE: Certification Report Number OTI-6774-TX-090103

Dear Mr. Oliver:

The Texas Department of Housing and Community Affairs (TDHCA) approves Model 1100 I "V" All Steel Foundation System Wind Zone I and Seismic, Model 1100 I C "V" All Steel/Concrete Foundation System Wind Zone I (1.0 Uplift Factor), and Model 1100 LV Foundation/Pier Anchor System. In granting this approval, the TDHCA is relying wholly upon the certification provided by RADCO of the evidence referenced below:

*Evidence Submitted*

RADCO Certification Report Number OTI-6774-TX-090103 (Sealed September 1, 2003, by R. F. Tucker, P.E.) is the substantiating certification report.

*Description of Component/System*

The certification report describes the Model 1100 I "V" All Steel Foundation System Wind Zone I and Seismic, Model 1100 I C "V" All Steel/Concrete Foundation System Wind Zone I (1.0 Uplift Factor), and Model 1100 LV Foundation/Pier Anchor System.

*Conditions for Use of Component/System*

As noted in the installation instructions, the system is not to be used if:

- 1) Pier (system) height exceeds 48"
- 2) Roof eaves exceed 16"
- 3) Sidewall height exceeds 96"
- 4) Roof Pitch greater than 5/12 (23 degrees)
- 5) Location is within 1500 feet of coast line
- 6) Footing to surface area exceeds 3 square feet
- 7) Soil conditions less than 4B

Unless renewed, this approval letter and the TDHCA approval stamp on the enclosed certification report will expire on September 2, 2013. The Manufactured Housing Division Executive Director has the authority to withdraw approval of this component/system on an earlier date, if any of the conditions described in rule 10 TAC §80.62(g) exist.

Sincerely,

Heidi A. Maldonado  
Contract and Device Approval Administrator



## MANUFACTURED HOUSING DIVISION

Rick Perry  
GOVERNOR

Timothy K. Irvine  
EXECUTIVE DIRECTOR

**Board Members**  
*Presiding Officer*, Cary Yates  
Jack Davis  
Clement P. Moreno  
Joan Tavares

September 23, 2003

Mr. Scott Oliver  
Oliver Technologies, Inc.  
P.O. Box 9  
Hohenwald, TN 38462

RE: Certification Report Number OTI-6774-TX-091503-WZII

Dear Mr. Oliver:

The Texas Department of Housing and Community Affairs (TDHCA) approves the All Steel Foundation System Models 1100 II T "V", 1100 II L "V", and 1100 II C "V" for wind zone II. In granting this approval, the TDHCA is relying wholly upon the certification provided by RADCO of the evidence referenced below:

*Evidence Submitted*

RADCO Certification Report Number OTI-6774-TX-091503-WZII (Issued September 15, 2003, and sealed by R. F. Tucker, P.E.) is the substantiating certification report.

*Description of Component/System*

The certification report describes the All Steel Foundation System Models 1100 II T "V", 1100 II L "V", and 1100 II C "V" for wind zone II.

*Conditions for Use of Component/System*

The Installation Instructions for Wind Zone 1 & 2 Model 1100 "V" Series All Steel Foundation System revised September 2003 must be followed.

Unless renewed, this approval letter and the TDHCA approval stamp on the enclosed certification report will expire on September 15, 2013. The Manufactured Housing Division Executive Director has the authority to withdraw approval of this component/system on an earlier date, if any of the conditions described in rule 10 TAC §80.62(g) exist.

Sincerely,

Heidi A. Maldonado  
Contract and Device Approval Administrator

AD375