



TEXAS DEPARTMENT OF HOUSING AND COMMUNITY AFFAIRS

George W. Bush
GOVERNOR

Daisy A. Stiner
EXECUTIVE DIRECTOR

September 13, 1999

BOARD MEMBERS
Donald R. Bethel, *Chair*
Michael E. Jones, *Vice Chair*
Margie Lee Bingham
Robert O. Brewer
C. Kent Conine
James A. Daross
Florita Bell Griffin, Ph. D.
Lydia Saenz
Marsha L. Williams

Mr. Lon Larson, General Manager
Manufactured Housing Foundations Systems, Inc.
562 Glenheather Drive
San Marcos, CA 92069

RE: Adjustable Outrigger

Dear Mr. Larson:

The Texas Department of Housing and Community Affairs (TDHCA) approves the Adjustable Outrigger, Listing # 1055-11, for use as a supplemental floor brace. The Adjustable Outrigger is field installed, connected near the end of a floor joist, and braced against a longitudinal I-beam of a manufactured home. The Adjustable Outrigger is approved to provide localized and supplemental support at sidewall openings and under extra furniture loads near sidewalls for manufactured homes in Texas.

Evidence Submitted

Mr. Edward M. Salsbury, P.E. (California) issued two certification reports: Project #99-014-01, sealed January 20, 1999; and a supplemental Project #99-014-01, sealed August 25, 1999. Preferred Construction Inspections issued certification report, Job No. 1055, on August 17, 1999.

Description of Adjustable Outrigger

The bracket will have the following identification:

LISTING # 1055-11
TESTING CO.
PREFERRED CONST.
INSPECTIONS
SAN DIEGO, CA
PH (800)-284-7437
PATENT PENDING

Preferred Construction Inspections, Job No. 1055 describes the following parts of the adjustable outrigger:

- 0.75 inch diameter – 10 inch x 5 inch threaded rod;
- 0.75 inch - 10 hex nut;
- 1.0 inch outside diameter x 12 gauge steel pipe;
- #12 x 2 inch hex washer head screws; and
- 2.0 inch x 7.0 inch x 0.25 inch bracket with five holes, 0.25 inch diameter.

Visit us on the world wide web at: www.tdhca.state.tx.us

MANUFACTURED HOUSING DIVISION

507 SABINE - SUITE 1000 • P. O. BOX 12489 • AUSTIN, TEXAS 78711-2489 • (512) 475-2200 • (800) 500-7074