

June 21, 1995

Mr. Steven Clark
Mobile Home Safety Products
195 East Morgan
Ferris, CA 92571

RE: PIER SUPPORT INSTALLATIONS, STATE OF WASHINGTON

Dear Mr. Clark:

At your request, we have reviewed the testing data as performed by PCI (Preferred Construction Inspections). The PCI reports are dated May 15, 1995 for listing card number 1055-6 (copy enclosed).

We have found that the pier in the referenced PCI testing report and as tested by PCI are adequate to support a 6000 pound vertical load as the pier component of a typical pier and bearing pad mobile home support.

Should you have any questions regarding this report, please call.


Sincerely,

JOHNSON/COASTLINE ASSOCIATES, INC.



Michael G. Wray, P.E.
Office Manager

Attachments (1)



File: 6094AL01