


### Water Usage - Hamilton Township Fire District #9



## ELECTRIC MARKETERS LIST

The following is a listing of marketers/suppliers/brokers that have been licensed by the NJ Board of Public Utilities to sell electricity to residential, small commercial and industrial customers served by the Public Service Electric and Gas Company distribution system. **This listing is provided for informational purposes only and PSE&G makes no representations or warranties as to the competencies of the entities listed herein or to the completeness of this listing.**

American Powermet Management  
867 Berkshire Blvd, Suite 101  
Wyomissing, PA 19610  
[www.americanpowermet.com](http://www.americanpowermet.com)

Gerdau Ameristeel Energy Co.  
North Crossman Road  
Sayreville, NJ 08872

PPL EnergyPlus, LLC  
Energy Marketing Center  
Two North Ninth Street  
Allentown, PA 18101  
1-866-505-8825  
<http://www.pplenergyplus.com/>

BOC Energy Services  
575 Mountain Avenue  
Murray Hill, NJ 07974  
[www.boc-gases.com](http://www.boc-gases.com)

Gexa Energy LLC New Jersey  
20 Greenway Plaza, Suite 600  
Houston, TX 77046  
(866) 304-GEXA  
[Beth.miller@gexaenergy.com](mailto:Beth.miller@gexaenergy.com)

Sempra Energy Solutions  
The Mac-Cali Building  
581 Main Street, 8<sup>th</sup> Floor  
Woodbridge, NJ 07095  
(877) 273-6772  
[www.SempraSolutions.com](http://www.SempraSolutions.com)

Commerce Energy Inc.  
535 Route 38, Suite 138  
Cherry Hill, NJ 08002  
(888) 817-8572 or  
(858) 910-8099  
[www.commerceenergy.com](http://www.commerceenergy.com)

Glacial Energy of New Jersey  
2602 McKinney Avenue, Suite 220  
Dallas, TX 75204  
[www.glacialenergy.com](http://www.glacialenergy.com)

South Jersey Energy Company  
1 South Jersey Plaza, Route 54  
Folsom, NJ 08037  
(800) 756-3749  
[www.sjindustries.com](http://www.sjindustries.com)

ConEdison Solutions  
701 Westchester Avenue  
Suite 201 West  
White Plains, NY 10604  
(800) 316-8011  
[www.ConEdSolutions.com](http://www.ConEdSolutions.com)

Hess Corporation  
1 Hess Plaza  
Woodbridge, NJ 07095  
[www.hess.com](http://www.hess.com)

Strategic Energy, LLC  
6 East Main Street, Suite 6E  
Ramsey, NJ 07446  
(888) 925-9115  
[www.sel.com](http://www.sel.com)

Constellation NewEnergy, Inc.  
1199 Route 22 East  
Mountainside, NJ 07092  
908 228-5100  
[www.newenergy.com](http://www.newenergy.com)

Integrus Energy Services, Inc  
99 Wood Avenue, Suite 802  
Iselin, NJ 08830  
[www.integrusenergy.com](http://www.integrusenergy.com)

Suez Energy Resources NA  
333 Thomall Street FL6  
Edison, NJ 08818  
866.999.8374(toll free)  
[www.suezenergyresources.com](http://www.suezenergyresources.com)

Credit Suisse (USA), Inc.  
700 College Road East  
Princeton, NJ 08450  
[www.creditsuisse.com](http://www.creditsuisse.com)

Liberty Power Delaware, LLC  
1901 W Cypress Road, Suite 600  
Fort Lauderdale, FL 33309  
(866) Power-99  
(866) 769-3799  
[www.libertypowercorp.com](http://www.libertypowercorp.com)

UGI Energy Services, Inc.  
d/b/a POWERMARK  
1 Meridian Blvd. Suite 2C01  
Wyomissing, PA 19610  
(800) 427-8545  
[www.ugienergyservices.com](http://www.ugienergyservices.com)

Direct Energy Services, LLC  
One Gateway Center, Suite 2600  
Newark, NJ 07102  
(973) 799-8568  
[www.directenergy.com](http://www.directenergy.com)

Liberty Power Holdings, LLC  
1901 W Cypress Creek Road, Suite 600  
Fort Lauderdale, FL 33309  
(866) Power-99  
(866) 769-3799  
[www.libertypowercorp.com](http://www.libertypowercorp.com)

FirstEnergy Solutions  
395 Ghent Road Suite 407  
Akron, OH 44333  
(800) 977-0500  
[www.fes.com](http://www.fes.com)

Pepco Energy Services, Inc.  
d/b/a Power Choice  
23 S. Kinderkamack Rd Ste D  
Montvale, NJ 07645  
(800) 363-7499  
[www.pepco-services.com](http://www.pepco-services.com)

## GAS MARKETERS LIST

The following is a listing of marketers/suppliers/brokers that have been licensed by the NJ Board of Public Utilities to sell natural gas to residential, small commercial and industrial customers served by the Public Service Electric and Gas Company distribution system. **This listing is provided for informational purposes only and PSE&G makes no representations or warranties as to the competencies of the entities listed herein or to the completeness of this listing.**

Gateway Energy Services  
44 Whispering Pines Lane  
Lakewood, NJ 08701  
(800) 805-8586  
[www.gesc.com](http://www.gesc.com)

Metro Energy Group, LLC  
14 Washington Place  
Hackensack, NJ 07601  
[www.metroenergy.com](http://www.metroenergy.com)

RPL Holdings, Inc  
601 Carlson Pkwy  
Minnetonka, MN 55305

Great Eastern Energy  
3044 Coney Island Ave. PH  
Brooklyn, NY 11235  
888-651-4121  
[www.greasterngas.com](http://www.greasterngas.com)

Metromedia Energy, Inc.  
6 Industrial Way  
Eatontown, NJ 07724  
(800) 828-9427  
[www.metromediaenergy.com](http://www.metromediaenergy.com)

South Jersey Energy Company  
One South Jersey Plaza, Rte 54  
Folsom, NJ 08037  
(800) 756-3749  
[www.sjindustries.com/sje.htm](http://www.sjindustries.com/sje.htm)

Hess Corporation  
1 Hess Plaza  
Woodbridge, NJ 07095  
(800) 437-7872  
[www.hess.com](http://www.hess.com)

Mitchell- Supreme Fuel  
(NATGASCO)  
532 Freeman Street  
Orange, NJ 07050  
(800) 840-4GAS  
[www.mitchellsupreme.com](http://www.mitchellsupreme.com)

Sprague Energy Corp.  
Two International Drive, Ste 200  
Portsmouth, NH 03801  
800-225-1560  
[www.spragueenergy.com](http://www.spragueenergy.com)

Hudson Energy Services, LLC  
545 Route 17 South  
Ridgewood, NJ 07450  
(201) 251-2400  
[www.hudsonenergyservices.com](http://www.hudsonenergyservices.com)

MxEnergy Inc.  
P.O. Box 177  
Annapolis Junction, MD 20701  
800-375-1277  
[www.mxenergy.com](http://www.mxenergy.com)

Stuyvesant Energy LLC  
642 Southern Boulevard  
Bronx, NY 10455  
(718) 665-5700  
[www.stuyfuel.com](http://www.stuyfuel.com)

Intelligent Energy  
7001 SW 24<sup>th</sup> Avenue  
Gainesville, FL 32607  
Sales: 1 877 I've Got Gas  
(1 877 483-4684)  
Customer Service:  
1 800 927-9794  
[www.intelligentenergy.org](http://www.intelligentenergy.org)

Pepco Energy Services, Inc.  
23 S Kinderkamack Rd, Suite D  
Montvale, NJ 07645  
(800) 363-7499  
[www.pepco-services.com](http://www.pepco-services.com)

Tiger Natural Gas, Inc.  
1422 E. 71st Street, Suite J.  
Tulsa, OK 74136  
1-888-875-6122  
[www.tignaturalgas.com](http://www.tignaturalgas.com)

Systrum Energy  
877-SYSTRUM  
(877-797-8786)  
[www.systrumenergy.com](http://www.systrumenergy.com)

Plymouth Rock Energy, LLC  
165 Remsen Street  
Brooklyn, NJ 11201  
866-539-6450  
[www.plymouthrockenergy.com](http://www.plymouthrockenergy.com)

UGI Energy Services, Inc.  
d/b/a GASMARK  
704 E. Main Street, Suite I  
Moorestown, NJ 08057  
856-273-9995  
[www.ugienergyservices.com](http://www.ugienergyservices.com)

Macquarie Cook Energy, LLC  
10100 Santa Monica Blvd, 18<sup>th</sup>  
Fl  
Los Angeles, CA 90067

PPL EnergyPlus, LLC  
Energy Marketing Center  
Two North Ninth Street  
Allentown, PA 18101  
1-866-505-8825  
[www.pplenergyplus.com/natural+gas/](http://www.pplenergyplus.com/natural+gas/)

Woodruff Energy  
73 Water Street  
P.O. Box 777  
Bridgeton, NJ 08302  
(856) 455-1111  
[www.woodruffenergy.com](http://www.woodruffenergy.com)

## **APPENDIX B**

### **ECM-1 Install Demand Control Ventilation**



Hamilton Township  
CHA #21180  
Building: Fire District #9

ECM-1 Install Demand Control Ventilation

Meeting Room

Description:

Outside air can be significantly reduced for most of the time that the building is occupied. Savings will result from the avoided heating and cooling of excessive outside air.

Method:

The outdoor air introduced into the spaces is currently constant based on design occupancy conditions. This ECM proposes the installation of CO2 sensors in the space to allow for reduced outdoor air flows when conditions allow. Average reduction in outdoor air is based on an assumed occupancy of the space and local code requirements. The DCV system will automatically adjust the outdoor air damper position through a controller to reduce outdoor air flows based on indoor CO2 levels.

| Org. scheduled CFM*  | Total CFM | O.A. CFM | O.A. % |
|----------------------|-----------|----------|--------|
| 3,000                | 3,000     | 1,000    | 33%    |
| Derated CFM**        | 3,000     | 31       | 1%     |
| SA Enthalpy          | 26.4      | BTU/lbma |        |
| SA Set point, Winter | 68.0      | °F       |        |
| SA Set point, Summer | 73.0      | °F       |        |
| Heating "On" Point   | 60.0      | °F       |        |
| Cooling System Eff.  | 1.21      | kW/Ton   |        |
| Heating System Eff.  | 58%       |          |        |

(Includes ancillary equipment)  
(Includes distribution losses)

\*Per building drawings

\*\*Per 2006 International Mechanical Code 15 CFM/person, average 20 people, 2.5 hrs/day

CFM is average over a 24 hour period.

| A            | B    | C            | D          | E        | F            | G          | Existing                   |              |            | J         | K         | Proposed Demand Ventilation |                  |                  | Q          |                  |                  |             |                |
|--------------|------|--------------|------------|----------|--------------|------------|----------------------------|--------------|------------|-----------|-----------|-----------------------------|------------------|------------------|------------|------------------|------------------|-------------|----------------|
|              |      |              |            |          |              |            | Equipment Operating Time % | Bin HOURS    | O.A. CFM   |           |           | Cooling Load MBH            | Heating Load MBH | Derated O.A. CFM |            | Cooling Load MBH | Heating Load MBH | Cooling kWh | Heating therms |
| 102.5        | 49.1 | 0            | 100%       | 0        | 1,000        | 102        | 0                          | 0            | 0          | 31        | 3         | 0                           | 0                | 0                | 0          | 0                | 0                | 0           | 0              |
| 97.5         | 42.5 | 3            | 85%        | 3        | 1,000        | 72         | 0                          | 19           | 0          | 31        | 2         | 0                           | 0                | 0                | 18         | 0                | 0                | 0           | 0              |
| 92.5         | 39.5 | 34           | 70%        | 24       | 1,000        | 59         | 0                          | 141          | 0          | 31        | 2         | 0                           | 0                | 137              | 0          | 0                | 0                | 0           | 0              |
| 87.5         | 36.6 | 131          | 55%        | 72       | 1,000        | 46         | 0                          | 333          | 0          | 31        | 1         | 0                           | 0                | 323              | 0          | 0                | 0                | 0           | 0              |
| 82.5         | 34   | 500          | 40%        | 200      | 1,000        | 34         | 0                          | 690          | 0          | 31        | 1         | 0                           | 0                | 668              | 0          | 0                | 0                | 0           | 0              |
| 77.5         | 31.6 | 620          | 25%        | 155      | 1,000        | 23         | 0                          | 366          | 0          | 31        | 1         | 0                           | 0                | 354              | 0          | 0                | 0                | 0           | 0              |
| 72.5         | 29.2 | 664          | 10%        | 66       | 1,000        | 13         | 0                          | 84           | 0          | 31        | 0         | 0                           | 0                | 82               | 0          | 0                | 0                | 0           | 0              |
| 67.5         | 27   | 854          | 10%        | 85       | 1,000        | 3          | 0                          | 23           | 0          | 31        | 0         | 0                           | 0                | 23               | 0          | 0                | 0                | 0           | 0              |
| 62.5         | 24.5 | 1,023        | 20%        | 139      | 1,000        | 0          | 0                          | 0            | 20         | 31        | 0         | 0                           | 0                | 0                | 0          | 0                | 0                | 0           | 19             |
| 57.5         | 21.4 | 600          | 20%        | 120      | 1,000        | 0          | 11                         | 0            | 38         | 31        | 0         | 0                           | 0                | 0                | 0          | 0                | 0                | 0           | 36             |
| 52.5         | 18.7 | 610          | 25%        | 153      | 1,000        | 0          | 17                         | 0            | 60         | 31        | 0         | 0                           | 0                | 0                | 0          | 0                | 0                | 0           | 58             |
| 47.5         | 16.2 | 611          | 30%        | 183      | 1,000        | 0          | 22                         | 0            | 93         | 31        | 0         | 0                           | 0                | 0                | 0          | 0                | 0                | 0           | 90             |
| 42.5         | 14.4 | 656          | 35%        | 230      | 1,000        | 0          | 28                         | 0            | 198        | 31        | 0         | 0                           | 0                | 0                | 0          | 0                | 0                | 0           | 192            |
| 37.5         | 12.6 | 1,023        | 40%        | 409      | 1,000        | 0          | 33                         | 0            | 386        | 31        | 0         | 0                           | 0                | 0                | 0          | 0                | 0                | 0           | 180            |
| 32.5         | 10.7 | 734          | 45%        | 330      | 1,000        | 0          | 38                         | 0            | 107        | 31        | 0         | 0                           | 0                | 0                | 0          | 0                | 0                | 0           | 104            |
| 27.5         | 8.6  | 334          | 50%        | 167      | 1,000        | 0          | 44                         | 0            | 100        | 31        | 0         | 0                           | 0                | 0                | 0          | 0                | 0                | 0           | 97             |
| 22.5         | 6.8  | 252          | 55%        | 139      | 1,000        | 0          | 49                         | 0            | 60         | 31        | 0         | 0                           | 0                | 0                | 0          | 0                | 0                | 0           | 58             |
| 17.5         | 5.5  | 125          | 60%        | 75       | 1,000        | 0          | 55                         | 0            | 27         | 31        | 0         | 0                           | 0                | 0                | 0          | 0                | 0                | 0           | 26             |
| 12.5         | 4.1  | 47           | 65%        | 31       | 1,000        | 0          | 60                         | 0            | 15         | 31        | 0         | 0                           | 0                | 0                | 0          | 0                | 0                | 0           | 14             |
| 7.5          | 2.6  | 22           | 70%        | 15       | 1,000        | 0          | 65                         | 0            | 10         | 31        | 0         | 0                           | 0                | 0                | 0          | 0                | 0                | 0           | 10             |
| 2.5          | 1    | 13           | 75%        | 10       | 1,000        | 0          | 71                         | 0            | 0          | 31        | 0         | 0                           | 0                | 0                | 0          | 0                | 0                | 0           | 0              |
| -2.5         | 0    | 0            | 80%        | 0        | 1,000        | 0          | 76                         | 0            | 0          | 31        | 0         | 0                           | 0                | 0                | 0          | 0                | 0                | 0           | 0              |
| -7.5         | -1.5 | 0            | 85%        | 0        | 1,000        | 0          | 82                         | 0            | 0          | 31        | 0         | 0                           | 0                | 0                | 0          | 0                | 0                | 0           | 0              |
| <b>Total</b> |      | <b>8,760</b> | <b>30%</b> | <b>0</b> | <b>1,000</b> | <b>352</b> | <b>0</b>                   | <b>1,657</b> | <b>914</b> | <b>31</b> | <b>11</b> | <b>52</b>                   | <b>29</b>        | <b>1,605</b>     | <b>886</b> |                  |                  |             |                |

| 100% Energy Cost Savings |            |
|--------------------------|------------|
| Heating Savings          | 886 therms |
| Cooling Savings          | 1,605 kWh  |

Notes:

- Building personnel indicated that the doors to the meeting room are often left open and a fan is placed in the doorways to help cool the corridors. Therefore, the actual operating time of the equipment during cooling hours is considerably greater than that required to cool the room alone.

Hamilton Township  
CHA #21180  
Building: Fire District #9

ECM-1 Install Demand Control Ventilation Weight Room

|                     | Total CFM     | O.A. CFM | O.A. % |
|---------------------|---------------|----------|--------|
| Org. scheduled CFM* | 1,200         | 180      | 15%    |
| Derated CFM**       | 1,200         | 13       | 1%     |
| SA Enthalpy         | 26.4 BTU/lbma |          |        |
| SA Setpoint, Winter | 68.0 °F       |          |        |
| SA Setpoint, Summer | 73.0 °F       |          |        |
| Heating "On" Point  | 60.0 °F       |          |        |
| Cooling System Eff. | 1.21 kW/Ton   |          |        |
| Heating System Eff. | 68%           |          |        |

(Includes ancillary equipment)  
(Includes distribution losses)

\*Per building drawings

\*\*Per 2006 International Mechanical Code 20 CFM/person, average 4 people, 4 hrs/day

CFM is average over a 24 hour period.

**Description:**  
Outside air can be significantly reduced for most of the time that the building is occupied.  
Savings will result from the avoided heating and cooling of excessive outside air.

**Method:**  
The outdoor air introduced into the spaces is currently constant based on design occupancy conditions.  
This ECM proposes the installation of CO2 sensors in the space to allow for reduced outdoor air flows when conditions allow.  
Average reduction in outdoor air is based on an assumed occupancy of the space and local code requirements.  
The DCV system will automatically adjust the outdoor air damper position through a controller to reduce outdoor air flows based on indoor CO2 levels.

| A                   | B                  | C            | D                  | E                         | F      | Existing         |                  |             | Proposed Demand Ventilation |                  |                  | Savings          |             |             |                |                |
|---------------------|--------------------|--------------|--------------------|---------------------------|--------|------------------|------------------|-------------|-----------------------------|------------------|------------------|------------------|-------------|-------------|----------------|----------------|
|                     |                    |              |                    |                           |        | G                | H                | I           | J                           | K                | L                | M                | N           | O           | P              | Q              |
| Avg. DB Bin Temp °F | OA Enthalpy Btu/lb | Bin HOURS    | t Operating Time % | Equipment Operating HOURS | OA CFM | Cooling Load MBH | Heating Load MBH | Cooling kWh | Heating kWh                 | Derated O.A. CFM | Cooling Load MBH | Heating Load MBH | Cooling kWh | Heating kWh | Cooling therms | Heating therms |
| 102.5               | 49.1               | 0            | 70%                | 0                         | 180    | 18               | 0                | 0           | 0                           | 13               | 1                | 0                | 0           | 0           | 0              | -              |
| 97.5                | 42.5               | 3            | 60%                | 2                         | 180    | 13               | 0                | 2           | -                           | 13               | 1                | 0                | 0           | 0           | 2              | -              |
| 92.5                | 39.5               | 34           | 50%                | 17                        | 180    | 11               | 0                | 18          | -                           | 13               | 1                | 0                | 1           | 0           | 17             | -              |
| 87.5                | 36.6               | 131          | 40%                | 52                        | 180    | 8                | 0                | 44          | -                           | 13               | 1                | 0                | 3           | 0           | 40             | -              |
| 82.5                | 34                 | 500          | 30%                | 150                       | 180    | 6                | 0                | 93          | -                           | 13               | 0                | 0                | 7           | 0           | 86             | -              |
| 77.5                | 31.6               | 620          | 20%                | 124                       | 180    | 4                | 0                | 53          | -                           | 13               | 0                | 0                | 4           | 0           | 49             | -              |
| 72.5                | 29.2               | 664          | 10%                | 66                        | 180    | 2                | 0                | 15          | -                           | 13               | 0                | 0                | 1           | 0           | 14             | -              |
| 67.5                | 27                 | 854          | 10%                | 85                        | 180    | 0                | 0                | 4           | -                           | 13               | 0                | 0                | 0           | 0           | 4              | -              |
| 62.5                | 24.5               | 927          | 15%                | 139                       | 180    | 0                | 0                | 0           | -                           | 13               | 0                | 0                | 0           | 0           | 0              | 0              |
| 57.5                | 21.4               | 600          | 20%                | 120                       | 180    | 0                | 2                | 0           | 4                           | 13               | 0                | 0                | 0           | 0           | 0              | 3              |
| 52.5                | 18.7               | 610          | 25%                | 153                       | 180    | 0                | 3                | 0           | 7                           | 13               | 0                | 0                | 0           | 1           | 0              | 6              |
| 47.5                | 16.2               | 611          | 30%                | 183                       | 180    | 0                | 4                | 0           | 11                          | 13               | 0                | 0                | 0           | 0           | 0              | 10             |
| 42.5                | 14.4               | 656          | 35%                | 230                       | 180    | 0                | 5                | 0           | 17                          | 13               | 0                | 0                | 0           | 0           | 0              | 15             |
| 37.5                | 12.6               | 1,023        | 40%                | 409                       | 180    | 0                | 6                | 0           | 36                          | 13               | 0                | 0                | 0           | 0           | 0              | 33             |
| 32.5                | 10.7               | 734          | 45%                | 330                       | 180    | 0                | 7                | 0           | 34                          | 13               | 0                | 0                | 0           | 0           | 0              | 31             |
| 27.5                | 8.6                | 334          | 50%                | 167                       | 180    | 0                | 8                | 0           | 19                          | 13               | 0                | 0                | 0           | 0           | 0              | 18             |
| 22.5                | 6.8                | 252          | 55%                | 139                       | 180    | 0                | 9                | 0           | 18                          | 13               | 0                | 0                | 0           | 0           | 0              | 17             |
| 17.5                | 5.5                | 125          | 60%                | 75                        | 180    | 0                | 10               | 0           | 11                          | 13               | 0                | 0                | 0           | 0           | 0              | 10             |
| 12.5                | 4.1                | 47           | 65%                | 31                        | 180    | 0                | 11               | 0           | 5                           | 13               | 0                | 0                | 0           | 0           | 0              | 4              |
| 7.5                 | 2.6                | 22           | 70%                | 15                        | 180    | 0                | 12               | 0           | 3                           | 13               | 0                | 0                | 0           | 0           | 0              | 2              |
| 2.5                 | 1                  | 13           | 75%                | 10                        | 180    | 0                | 13               | 0           | 2                           | 13               | 0                | 0                | 0           | 0           | 0              | 2              |
| -2.5                | 0                  | 0            | 80%                | 0                         | 180    | 0                | 14               | 0           | -                           | 13               | 0                | 0                | 0           | 0           | 0              | -              |
| -7.5                | -1.5               | 0            | 85%                | 0                         | 180    | 0                | 15               | 0           | -                           | 13               | 0                | 0                | 0           | 0           | 0              | -              |
| <b>Total</b>        |                    | <b>8,760</b> | <b>29%</b>         | <b>2,497</b>              |        | <b>63</b>        |                  | <b>229</b>  | <b>165</b>                  |                  | <b>5</b>         |                  | <b>17</b>   | <b>12</b>   | <b>212</b>     | <b>152</b>     |

| 100% Energy Cost Savings |            |
|--------------------------|------------|
| Heating Savings          | 152 therms |
| Cooling Savings          | 212 kWh    |

Comments:



Hamilton Township  
 CHA #21180  
 Building: Fire District #9

ECM-1 Install Demand Control Ventilation

| Multipliers |      |
|-------------|------|
| Material:   | 0.98 |
| Labor:      | 1.21 |
| Equipment:  | 1.09 |

|                                | QTY | UNIT | UNIT COSTS |          |        | SUBTOTAL COSTS |          |        | TOTAL COST | REMARKS    |
|--------------------------------|-----|------|------------|----------|--------|----------------|----------|--------|------------|------------|
|                                |     |      | MAT.       | LABOR    | EQUIP. | MAT.           | LABOR    | EQUIP. |            |            |
| CO2 sensor                     | 3   | EA   | \$ 400     | \$ 100   | \$ -   | \$ 1,176       | \$ 363   | \$ -   | \$ 1,539   |            |
| Replace damper actuators       | 3   | EA   | \$ 300     | \$ 50    | \$ -   | \$ 882         | \$ 182   | \$ -   | \$ 1,064   |            |
| PLC Controller and Programming | 1   | LS   | \$ 1,000   | \$ 1,500 | \$ -   | \$ 980         | \$ 1,815 | \$ -   | \$ 2,795   | Common PLC |
| Electrical/wiring              | 1   | LS   | \$ 1,200   | \$ 2,400 | \$ -   | \$ 1,176       | \$ 2,904 | \$ -   | \$ 4,080   |            |
|                                |     |      |            |          |        | \$ -           | \$ -     | \$ -   | \$ -       |            |
|                                |     |      |            |          |        |                |          |        |            |            |
|                                |     |      |            |          |        |                |          |        |            |            |

|                    |           |               |
|--------------------|-----------|---------------|
| Subtotal           | \$        | 9,478         |
| 10% OH, 10% Profit | \$        | 1,896         |
| 10% Contingency    | \$        | 1,137         |
| <b>Total</b>       | <b>\$</b> | <b>12,510</b> |

## **APPENDIX C**

### **ECM-2 Boiler Replacement with Hot Water Temperature Reset**

Hamilton Township  
 CHA #21180  
 Building: Fire District #9

ECM-2 Boiler Replacement with Hot Water Temperature Reset

|               |         |   |
|---------------|---------|---|
| Existing Fuel | Nat.Gas | ▼ |
| Proposed Fuel | Nat.Gas | ▼ |

| Item                             | Value           | Units      | Formula/Comments   |
|----------------------------------|-----------------|------------|--|
| Baseline Fuel Cost               | \$ 1.10         |            |  |
| Proposed Fuel Cost               | \$ 1.10         |            |  |
| Baseline Fuel Use                | 7,360           | Therms     | Based on historical utility data                             |
| Existing Boiler Plant Efficiency | 68%             |            | Per boiler nameplate   |
| Baseline Boiler Load             | 500,480         | Mbtu/yr    | Baseline Fuel Use x Existing Efficiency x 100 Mbtu/Therms    |
| Baseline Fuel Cost               | \$ 8,118        |            |  |
| Proposed Boiler Plant Efficiency | 92.3%           |            | New Boiler Efficiency  |
| Proposed Fuel Use                | 5,422           | Therms     | Baseline Boiler Load / Proposed Efficiency / 100 Mbtu/Therms |
| Proposed Fuel Cost               | \$ 5,981        |            |  |
| Annual Savings                   | 1,938           | Therms     |  |
| <b>Annual Savings</b>            | <b>\$ 2,137</b> | <b>/yr</b> |  |

|                                   |              |        |
|-----------------------------------|--------------|--------|
| Annual NG Usage per Utility Bills | 8,500        | Therms |
| Annual NG Usage Generator         | 240          | Therms |
| Annual NG Usage DHW Heater        | 900          | Therms |
| Annual NG Usage Boiler            | <b>7,360</b> | Therms |

Hamilton Township  
 CHA #21180  
 Building: Borough Hall Municipal Building

**ECM-2 Boiler Replacement with Hot Water Temperature Reset**

**Description**

Existing heating hot water (HHW) supply setpoint is 170°F.

**Proposed:**

Vary heating hot water supply temperature as building heating load decreases in relation to outside air temperature.

|                                 |       |
|---------------------------------|-------|
| Existing Boiler Efficiency      | 68%   |
| Avg. Proposed Boiler Efficiency | 92.3% |

| A             | B     | C            | D            | E             | F                   |                   | G                                |                            | H          | I                                |                            | J |
|---------------|-------|--------------|--------------|---------------|---------------------|-------------------|----------------------------------|----------------------------|------------|----------------------------------|----------------------------|---|
|               |       |              |              |               | Avg. DB Bin Temp °F | Heating Bin Hours | Existing Heat Loss In Piping MBH | Avg. HHW Temp @ OA Temp °F |            | Proposed Heat Loss In Piping MBH | Proposed Boiler Efficiency |   |
| 100-104       | 102.0 | 0            | 0            | 0             | 0                   | 0                 | 0.0%                             | 0                          | 0          | 0                                | 0                          |   |
| 95-99         | 97.0  | 3            | 0            | 0             | 0                   | 0                 | 0.0%                             | 0                          | 0          | 0                                | 0                          |   |
| 90-94         | 92.0  | 34           | 0            | 0             | 0                   | 0                 | 0.0%                             | 0                          | 0          | 0                                | 0                          |   |
| 85-89         | 87.0  | 131          | 0            | 0             | 0                   | 0                 | 0.0%                             | 0                          | 0          | 0                                | 0                          |   |
| 80-84         | 82.0  | 500          | 0            | 0             | 0                   | 0                 | 0.0%                             | 0                          | 0          | 0                                | 0                          |   |
| 75-79         | 77.0  | 620          | 0            | 0             | 0                   | 0                 | 0.0%                             | 0                          | 0          | 0                                | 0                          |   |
| 70-74         | 72.0  | 664          | 0            | 0             | 0                   | 0                 | 0.0%                             | 0                          | 0          | 0                                | 0                          |   |
| 65-69         | 67.0  | 854          | 0            | 0             | 0                   | 0                 | 96.0%                            | 0                          | 0          | 0                                | 0                          |   |
| 60-64         | 62.0  | 927          | 927          | 13,575        | 80                  | 8,068             | 96.0%                            | 141                        | 84         | 84                               | 84                         |   |
| 55-59         | 57.0  | 600          | 600          | 8,786         | 87                  | 5,222             | 95.0%                            | 92                         | 55         | 55                               | 55                         |   |
| 50-54         | 52.0  | 610          | 610          | 8,933         | 93                  | 5,309             | 94.0%                            | 95                         | 56         | 56                               | 56                         |   |
| 45-49         | 47.0  | 611          | 611          | 8,947         | 100                 | 5,318             | 93.4%                            | 96                         | 57         | 57                               | 57                         |   |
| 40-44         | 42.0  | 656          | 656          | 9,606         | 107                 | 5,709             | 92.0%                            | 104                        | 62         | 62                               | 62                         |   |
| 35-39         | 37.0  | 1,023        | 1,023        | 14,981        | 113                 | 8,904             | 90.6%                            | 165                        | 98         | 98                               | 98                         |   |
| 30-34         | 32.0  | 734          | 734          | 10,749        | 120                 | 6,388             | 89.8%                            | 120                        | 71         | 71                               | 71                         |   |
| 25-29         | 27.0  | 334          | 334          | 4,891         | 127                 | 2,907             | 89.0%                            | 55                         | 33         | 33                               | 33                         |   |
| 20-24         | 22.0  | 252          | 252          | 3,690         | 133                 | 2,193             | 88.5%                            | 42                         | 25         | 25                               | 25                         |   |
| 15-19         | 17.0  | 125          | 125          | 1,830         | 140                 | 1,088             | 88.0%                            | 21                         | 12         | 12                               | 12                         |   |
| 10-14         | 12.0  | 47           | 47           | 688           | 147                 | 409               | 87.6%                            | 8                          | 5          | 5                                | 5                          |   |
| 5-9           | 7.0   | 22           | 22           | 322           | 153                 | 191               | 87.2%                            | 4                          | 2          | 2                                | 2                          |   |
| 0-4           | 2.0   | 13           | 13           | 190           | 160                 | 113               | 86.8%                            | 2                          | 1          | 1                                | 1                          |   |
| -5- -1        | -3.0  | 0            | 0            | 0             | 160                 | 0                 | 86.8%                            | 0                          | 0          | 0                                | 0                          |   |
| -10- -6       | -8.0  | 0            | 0            | 0             | 160                 | 0                 | 86.8%                            | 0                          | 0          | 0                                | 0                          |   |
| <b>Totals</b> |       | <b>8,760</b> | <b>5,954</b> | <b>87,190</b> |                     | <b>51,820</b>     |                                  | <b>945</b>                 | <b>562</b> | <b>562</b>                       | <b>562</b>                 |   |

|                       |    |     |           |
|-----------------------|----|-----|-----------|
| Annual Energy Savings | \$ | 384 | Therms/yr |
| Annual Cost Savings   | \$ | 458 | /yr       |

**Comments:**

- A-C Newark, NJ weather bins
- D Based on building balance points and bin data.
- E Existing heat loss in piping system based on current average HHW temperature.
- F Estimated Average HHW temperature with HW reset based on OA temperature.
- G Proposed heat loss in piping system based on estimated average HW temperature. Return HHW temp min 70 deg F
- H Proposed boiler efficiency based return water temperature and boiler efficiency curve.
- I-J Utility usage to overcome heat loss in HHW piping system based on boiler efficiency.

| Building HHW Piping System |                |
|----------------------------|----------------|
| Heating On Temperature     | 65 °F          |
| Total Length of Pipe       | 1535 LF        |
| Existing HHW Setpoint High | 170 °F         |
| Existing HHW Setpoint Low  | 150 °F         |
| Avg HHW Temp               | 160 °F         |
| Avg Pipe Size              | 1 Inches       |
| Avg Insul Thickness        | 1 1/2 Inches   |
| Existing Heat Loss         | 10.6 Btu/Hr/LF |
| Percent in Uncond. Space   | 90%            |
| Existing System Heat Loss  | 14,644 Btu/Hr  |
| Proposed Min HHW Return*   | 70 °F          |
| Avg Prop HHW Supply Temp   | 105 °F         |
| Proposed Heat Loss         | 6.3 Btu/Hr/LF  |
| Proposed System Heat Loss  | 8,703 Btu/Hr   |

\*Refer to proposed boiler capabilities

| Size (in) | Length (ft)    |
|-----------|----------------|
| 1/2       | 290            |
| 3/4       | 350            |
| 1         | 315            |
| 1 1/4     | 215            |
| 1 1/2     | 65             |
| 2         | 300            |
| 2 1/2     | 0              |
| 3         | 0              |
| 1         | <b>Average</b> |

Hamilton Township  
 CHA #21180  
 Building: Fire District #9

|             |      |
|-------------|------|
| Multipliers |      |
| Material:   | 0.98 |
| Labor:      | 1.21 |
| Equipment:  | 1.09 |

**ECM-2 Boiler Replacement with Hot Water Temperature Reset**

| Description                               | QTY | UNIT | UNIT COSTS |          |        | SUBTOTAL COSTS |          |        | TOTAL COST | REMARKS                      |
|---|-----|------|------------|----------|--------|----------------|----------|--------|------------|------------------------------|
|   |     |      | MAT.       | LABOR    | EQUIP. | MAT.           | LABOR    | EQUIP. |            |                              |
| Boiler Removal                            | 1   | EA   |            | \$ 500   |        | \$ -           | \$ 605   | \$ -   | \$ 605     |                              |
| 1,500 MBH Gas-Fired Condensing HW Boiler* | 1   | EA   | \$ 25,000  | \$ 4,000 |        | \$ 24,500      | \$ 4,840 | \$ -   | \$ 29,340  | Includes freight and startup |
| Condensate Neutralization Kit             | 1   | EA   | \$ 300     | \$ 250   |        | \$ 294         | \$ 303   | \$ -   | \$ 597     |                              |
| Flue Replacement                          | 20  | LF   | \$ 10      | \$ 8.50  |        | \$ 196         | \$ 206   | \$ -   | \$ 402     | 6" PVC Piping                |
| Miscellaneous Electrical                  | 1   | LS   | \$ 400     | \$ 300   |        | \$ 392         | \$ 363   | \$ -   | \$ 755     |                              |
| Miscellaneous HW Piping                   | 1   | LS   | \$ 250     | \$ 200   |        | \$ 245         | \$ 242   | \$ -   | \$ 487     |                              |
| Miscellaneous Gas Piping                  | 1   | LS   | \$ 250     | \$ 200   |        | \$ 245         | \$ 242   | \$ -   | \$ 487     |                              |
| Boiler Energy Management System**         | 1   | EA   | \$ 2,300   | \$ 1,500 |        | \$ 2,254       | \$ 1,815 | \$ -   | \$ 4,069   | Controls HW temp reset       |
|   |     |      |            |          |        | \$ -           | \$ -     | \$ -   | \$ -       |                              |
|   |     |      |            |          |        | \$ -           | \$ -     | \$ -   | \$ -       |                              |

\*Pricing based on Aerco Benchmark 1.5 boiler  
 \*\*Pricing based on Aerco Boiler Management System II

|    |        |                    |
|----|--------|--------------------|
| \$ | 36,741 | Subtotal           |
| \$ | 3,674  | 10% Contingency    |
| \$ | 4,042  | 10% Contractor O&P |
| \$ | -      | Engineering        |
| \$ | 44,457 | Total              |

| New Jersey Smart Start Incentive Program | QTY   | UNIT | \$ / UNIT | TOTAL SAVINGS | Cost W/O INCENTIVE | Cost w/ INCENTIVE |
|--|-------|------|-----------|---------------|--------------------|-------------------|
| NG Boilers ≥ 300 - 1500 MBH              | 1,500 | MBH  | \$1.75    | \$2,625       | \$ -               | \$ 26,715         |
|  |       |      |           |               |                    |                   |
|  |       |      |           | \$2,625       | \$29,340           | \$26,715          |

Total ECM Cost w/ Incentives **\$41,832**

**APPENDIX D**

**ECM-3 Replace Rooftop Condensing Units**



Hamilton Township  
 CHA #21180  
 Building: Fire District #9

**ECM-3 Replace Rooftop Condensing Units**

Three original cooling units in use. 4 Tons, 4 Tons, & 10 Tons; Total 18 tons capacity.

| ASSUMPTIONS                          |                  | Comments                                    |
|--------------------------------------|------------------|---|
| Electric Cost                        | \$0.163 / kWh    |   |
| Average occupied hours per Week      | 168 Hours        | Building is occupied 24 hours per day       |
| Space Balance Point                  | 60 F             |   |
| Space Temperature Setpoint           | 73 deg F         | Average cooling setpoints per T-stats       |
| BTU / Hr Rating of existing AC units | 216,000 Btu / Hr | 18 Tons total cooling per three older units |
| Derated Average EER                  | 7.5              | Average 8.9 when new. Units >20 years old.  |

| Item                           | Value  | Units | Comments  |
|--------------------------------|--------|-------|---|
| Total Number of Units          | 1      |       | Analyzing three units as one.   |
| Existing Annual Electric Usage | 18,242 | kWh   |   |
| Proposed EER                   | 12.8   |       | Average EER of three new condensing units @ existing capacities. 11.4, 11.4, 14.0 |
| Proposed Annual Electric Usage | 10,689 | kWh   | Unit will cycle on w/ temp of room. Possible operating time shown below           |

| ANNUAL SAVINGS      |           |
|---------------------|-----------|
| Annual Savings      | 7,553 kWh |
| Annual Cost Savings | \$1,231   |

| OAT - DB Bin Temp F | Annual Hours | Cooling Hrs at Temp Above setpoint | Assumed % of time of operation | Assumed hrs of Operation |
|---------------------|--------------|------------------------------------|--------------------------------|--------------------------|
| 102.5               | 0            | 0                                  | 100%                           | 0                        |
| 97.5                | 3            | 3                                  | 88%                            | 3                        |
| 92.5                | 34           | 34                                 | 76%                            | 26                       |
| 87.5                | 131          | 131                                | 65%                            | 85                       |
| 82.5                | 500          | 500                                | 53%                            | 265                      |
| 77.5                | 620          | 620                                | 41%                            | 255                      |
| 72.5                | 664          | 0                                  | 0%                             | 0                        |
| 67.5                | 854          | 0                                  | 0%                             | 0                        |
| 62.5                | 927          | 0                                  | 0%                             | 0                        |
| 57.5                | 600          | 0                                  | 0%                             | 0                        |
| 52.5                | 610          | 0                                  | 0%                             | 0                        |
| 47.5                | 611          | 0                                  | 0%                             | 0                        |
| 42.5                | 656          | 0                                  | 0%                             | 0                        |
| 37.5                | 1,023        | 0                                  | 0%                             | 0                        |
| 32.5                | 734          | 0                                  | 0%                             | 0                        |
| 27.5                | 334          | 0                                  | 0%                             | 0                        |
| 22.5                | 252          | 0                                  | 0%                             | 0                        |
| 17.5                | 125          | 0                                  | 0%                             | 0                        |
| 12.5                | 47           | 0                                  | 0%                             | 0                        |
| 7.5                 | 22           | 0                                  | 0%                             | 0                        |
| 2.5                 | 13           | 0                                  | 0%                             | 0                        |
| -2.5                | 0            | 0                                  | 0%                             | 0                        |
| -7.5                | 0            | 0                                  | 0%                             | 0                        |

|              |       |       |     |     |
|--------------|-------|-------|-----|-----|
| <b>Total</b> | 8,760 | 1,288 | 49% | 633 |
|--------------|-------|-------|-----|-----|

Hamilton Township  
 CHA #21180  
 Building: Fire District #9

| Multipliers |      |
|-------------|------|
| Material:   | 0.98 |
| Labor:      | 1.21 |
| Equipment:  | 1.09 |

**ECM-3 Replace Rooftop Condensing Units**

| Description                 | QTY | UNIT | UNIT COSTS |          |        | SUBTOTAL COSTS |          |        | TOTAL COST | REMARKS           |
|-----------------------------|-----|------|------------|----------|--------|----------------|----------|--------|------------|-------------------|
|                             |     |      | MAT.       | LABOR    | EQUIP. | MAT.           | LABOR    | EQUIP. |            |                   |
| Condensing Unit Removal     | 3   | EA   |            | \$ 600   |        | \$ -           | \$ 2,178 | \$ -   | \$ 2,178   |                   |
| 4 Ton Condensing Unit       | 2   | EA   | \$ 1,775   | \$ 830   |        | \$ 3,479       | \$ 2,009 | \$ -   | \$ 5,488   | Standard Controls |
| 10 Ton Condensing Unit      | 1   | EA   | \$ 4,750   | \$ 1,500 |        | \$ 4,655       | \$ 1,815 | \$ -   | \$ 6,470   | Standard Controls |
| Miscellaneous Electrical    | 3   | LS   | \$ 100     | \$ 100   |        | \$ 294         | \$ 363   | \$ -   | \$ 657     |                   |
| Miscellaneous Piping        | 3   | LS   | \$ 100     | \$ 100   |        | \$ 294         | \$ 363   | \$ -   | \$ 657     |                   |
| Crane/Lift Rental (Per Day) | 1   | EA   | \$ 355     | \$ 870   |        | \$ 348         | \$ 1,053 | \$ -   | \$ 1,401   | Removal / Install |
|                             |     |      |            |          |        | \$ -           | \$ -     | \$ -   | \$ -       |                   |
|                             |     |      |            |          |        | \$ -           | \$ -     | \$ -   | \$ -       |                   |
|                             |     |      |            |          |        | \$ -           | \$ -     | \$ -   | \$ -       |                   |

|                  |                    |
|------------------|--------------------|
| \$ 16,850        | Subtotal           |
| \$ 2,528         | 15% Contingency    |
| \$ 1,938         | 10% Contractor O&P |
| \$ -             | Engineering        |
| <b>\$ 21,316</b> | <b>Total</b>       |

| New Jersey Smart Start Incentive Program | QTY | UNIT | \$ / UNIT | TOTAL SAVINGS | Cost W/O INCENTIVE | Cost W/ INCENTIVE |
|--|-----|------|-----------|---------------|--------------------|-------------------|
|  |     |      |           |               | \$ -               | \$ -              |
| Split System < 5.4 Tons                  | 4   | Tons | \$92      | \$368         | \$ 2,744           | \$ 2,376          |
| Split System < 5.4 Tons                  | 4   | Tons | \$92      | \$368         | \$ 2,744           | \$ 2,376          |
| Split System ≥ 5.4 Tons < 11.25 Tons     | 10  | Tons | \$73      | \$730         | \$ 6,470           | \$ 5,740          |
|  |     |      |           | \$1,466       | \$11,958           | \$10,492          |

|                                     |                 |
|-------------------------------------|-----------------|
| <b>Total ECM Cost w/ Incentives</b> | <b>\$19,850</b> |
|-------------------------------------|-----------------|

**APPENDIX E**

**ECM-4 Install Infrared Heaters – Engine Room**





## HEAT GAIN/LOSS WORKSHEET

Project Name:   
 Location:   
 Building Name:   
 Engineer:

Project No.:   
 Site Elevation:  Feet  
 Date:  Specific Volume:  CF/#

Building/Facility Designation:

|                                      |  |                                     |  |
|--------------------------------------|--|-------------------------------------|--|
| Outdoor Winter Design DB Temperature | <input type="text" value="14"/> *F     | Indoor Winter Design DB Temperature | <input type="text" value="62"/> *F     |
| Outdoor Summer Design DB Temperature | <input type="text" value="91"/> *F     | Indoor Summer Design DB Temperature | <input type="text" value="73"/> *F     |
| Outdoor Summer Design WB Temperature | <input type="text" value="73"/> *F     | Indoor Summer Design WB Temperature | <input type="text" value="60"/> *F     |
| Outdoor Summer Humidity Ratio        | <input type="text" value="0.0121"/> ## | Indoor Air (70°F) Humidity Ratio    | <input type="text" value="0.0078"/> ## |

**ENVELOPE DESCRIPTIONS (Descriptions are from Interior to Exterior)**

**Walls (Select One - Type X)**

|   | R Value | Wall Type |
|---|---------|-----------|
| <input type="checkbox"/> Steel Siding, 4" Insulation, Steel Siding                          | 15.2    | 1         |
| <input type="checkbox"/> Plaster or Gypsum, frame construction, 5" Insulation, 1" stucco    | 18.2    | 1         |
| <input type="checkbox"/> 4" WH CMU, 1" Insulation, Finished Exterior                        | 5.2     | 2         |
| <input type="checkbox"/> Plaster or Gypsum, frame construction, 3" Insulation, 8" LW CMU    | 7.8     | 5         |
| <input type="checkbox"/> 4" Face Brick, 2" Concrete, 1" Insulation, Exterior Finish         | 5.1     | 12        |
| <input type="checkbox"/> 4" Face Brick, 4" Concrete, 1" Insulation, Exterior Finish         | 4.0     | 11        |
| <input type="checkbox"/> Interior Finish, 2" Insulation, 8" CMU, 4" Face Brick              | 10.9    | 16        |
| <input type="checkbox"/> Finished Surface, 8" LW CMU (filled), Air Space, 4" Face Brick     | 11.1    | 16        |
| <input type="checkbox"/> Stucco or Gypsum, 2.5" Insul, Face Brick                           | 14.3    | 10        |
| <input type="checkbox"/> 4" Block, 1" insulation, 8" Block                                  | 19.9    | 16        |
| <input checked="" type="checkbox"/> 12" Block, 1" Rigid Insulation, 4" Decorative Rib Block | 7.5     |           |

**Roofs (Select One)**

|  | R Value | Roof Type |
|--|---------|-----------|
| <input type="checkbox"/> Tectum Deck, 3.3" Insul., BU Roof   | 13.0    | 1         |
| <input type="checkbox"/> Steel Deck, 5" Insul., BU Roof  | 18.2    | 1         |
| <input type="checkbox"/> Attic Roof with 6" Insul.   | 25.0    | 4         |
| <input type="checkbox"/> 4" HW Concrete Deck, BU Roof  | 2.7     | 2         |
| <input type="checkbox"/> Ceiling, 3" Insulation, 4" Concrete Deck, BU Roof                           | 14.9    | 4         |
| <input type="checkbox"/> Ceiling, 4" Concrete Deck, 3" Insulation, BU Roof                           | 18.5    | 13        |
| <input type="checkbox"/> Ceiling, 4" Concrete Deck, 6" Insulation, BU Roof                           | 21.7    | 14        |
| <input type="checkbox"/> Ceiling, Wood Deck, 6" Insulation, Felt & Membrane                          | 22.7    | 10        |
| <input type="checkbox"/> Wood Deck, 6" insulation, Felt & Membrane                                   | 18.0    |           |
| <input checked="" type="checkbox"/> Steel deck, 2" Rigid Insulation, Felt & Membrane, Stone Ballasts | 11.50   |           |

**Windows (Select One)**

|  | U Value |  |
|--|---------|--|
| <input type="checkbox"/> Aluminum Frame, 1/8" SP Glazing             | 1.05    |  |
| <input type="checkbox"/> Aluminum Frame, 1/4" DP Glazing             | 0.60    |  |
| <input checked="" type="checkbox"/> Aluminum Frame, 3/16" DP Glazing | 0.62    |  |
| <input type="checkbox"/> Aluminum Frame, 1/2" DP Glazing             | 0.50    |  |
| <input type="checkbox"/> Skylights                                   | 0.90    |  |
| <input type="checkbox"/> Other                                       |         |  |

|                            | No Storm |
|----------------------------|----------|
| Flat Glass                 | 1.05     |
| Flat Glass (e=.6)          | 1.00     |
| Flat Glass (e=0.4)         | 0.90     |
| Flat Glass (e=0.2)         | 0.77     |
| Double Glaze (3/16 in air) | 0.63     |
| Double Glaze (1/4 in air)  | 0.60     |
| Double Glaze (1/2 in air)  | 0.53     |
| Double Glaze (e=.6)        | 0.50     |
| Double Glaze (e=0.4)       | 0.42     |
| Double Glaze (e=0.2)       | 0.35     |
| Triple Glaze (1/4 in air)  | 0.42     |
| Triple Glaze (1/2 in air)  | 0.35     |

**BUILDING CHARACTERISTICS**

Roof Area:  SF  
 Occupied Area:  SF  
 Return Plenum?

|                | Gross Wall Length                   | Average Wall Height                  | Ceiling Height                       | Window Area                       | Door Area                           | Net Wall Area |
|----------------|-------------------------------------|--------------------------------------|--------------------------------------|-----------------------------------|-------------------------------------|---------------|
| North Exposure | <input type="text" value="100"/> Ft | <input type="text" value="20.5"/> Ft | <input type="text" value="20.5"/> Ft | <input type="text" value="0"/> SF | <input type="text" value="42"/> SF  | 2,008 SF      |
| East Exposure  | <input type="text" value="80"/> Ft  | <input type="text" value="20.5"/> Ft | <input type="text" value="20.5"/> Ft | <input type="text" value="0"/> SF | <input type="text" value="784"/> SF | 856 SF        |
| South Exposure | <input type="text" value="100"/> Ft | <input type="text" value="9.0"/> Ft  | <input type="text" value="20.5"/> Ft | <input type="text" value="0"/> SF | <input type="text" value="0"/> SF   | 900 SF        |
| West Exposure  | <input type="text" value="40"/> Ft  | <input type="text" value="20.5"/> Ft | <input type="text" value="20.5"/> Ft | <input type="text" value="0"/> SF | <input type="text" value="196"/> SF | 624 SF        |

Forced Ventilation:  cfm

## HEAT GAIN/LOSS WORKSHEET

Project Name: Hamilton Township  
 Location: Hamilton, NJ  
 Building Name: Fire District #9  
 Engineer: CAA

Project No.: CHA #21180  
 Site Elevation: 460 Feet  
 Date: 04/12/10

Specific Volume: 13.50 CF/#

Building/Facility Designation: Engine Room

### COOLING HEAT GAINS TO THE ROOM - SENSIBLE

#### SOLAR GAINS

| WINDOWS        | AREA (SF) | SHGF         | Shade Coef | Cooling Load Factor | Glass Type   | Solar Heat Gain |
|----------------|-----------|--------------|------------|---------------------|--------------|-----------------|
| North Exposure | 0         | 38 btu/h/sf  | 0.8        | 0.75                | Glass Type C | 0 Btu/hr        |
| East Exposure  | 0         | 216 btu/h/sf | 0.8        | 0.31                | Glass Type C | 0 Btu/hr        |
| South Exposure | 0         | 109 btu/h/sf | 0.8        | 0.58                | Glass Type C | 0 Btu/hr        |
| West Exposure  | 0         | 216 btu/h/sf | 0.8        | 0.29                | Glass Type C | 0 Btu/hr        |
|                |           |              |            |                     |              | <b>0 Btu/h</b>  |

#### CONDUCTION

|                | NET AREA (SF) | U-VALUE | Cooling Load Temp. Dif. | Return Air Factor | Room Heat Gain |                     |
|----------------|---------------|---------|-------------------------|-------------------|----------------|---------------------|
| North Exposure | 2,008         | 0.13    | 20 °F                   | 1.0               | 5,355 Btu/hr   |                     |
| East Exposure  | 856           | 0.13    | 39 °F                   | 1.0               | 4,451 Btu/hr   |                     |
| South Exposure | 2,050         | 0.13    | 27 °F                   | 1.0               | 7,380 Btu/hr   |                     |
| West Exposure  | 624           | 0.13    | 22 °F                   | 1.0               | 1,830 Btu/hr   |                     |
| Roof           | 6,900         | 0.09    | 73 °F                   | 1.0               | 43,800 Btu/hr  |                     |
| Fenestration   | 0             | 0.62    | 18 °F                   |                   | 0 Btu/hr       |                     |
| Doors          | 1,022         | 0.14    | 27 °F                   |                   | 3,854 Btu/hr   |                     |
| Ceiling        | 6,900         | 0.14    | 0 °F                    |                   | 0 Btu/hr       |                     |
| Partition      |               | 0.05    | 0 °F                    |                   | 0 Btu/hr       |                     |
| Floor          | 6,900         | 0.04    | 0 °F                    |                   | 0 Btu/hr       |                     |
|                |               |         |                         |                   |                | <b>66,670 Btu/h</b> |

#### INTERNAL HEAT GAINS

|                        |             |                  |                      |           |              |                     |
|------------------------|-------------|------------------|----------------------|-----------|--------------|---------------------|
| Lights                 | 0.80 w/sf x | 6,900 Occ Area = | 5.5 kW x 3.4x        | 1.0 RAF = | 18,840 Btu/h |                     |
| Plug Load              | 0.00 w/sf x | 6,900 Occ Area = | 0.0 kW x 3.4x        | 1.0 RAF = | 0 Btu/h      |                     |
| People                 | 0 people x  | 255 btu/person x | 100% time in space = |           | 0 Btu/h      |                     |
| Computer Work Stations |             | 0 Units x        | 120 W/Unit x         | 3414 =    | 0 Btu/h      |                     |
| Equipment              | 0.0 kW x    | 3,413 =          |                      |           | 0 Btu/h      |                     |
| Misc.                  |             |                  |                      |           | 0 Btu/h      |                     |
|                        |             |                  |                      |           |              | <b>18,840 Btu/h</b> |

#### VENTILATION AND INFILTRATION

|             | Infiltration Factor | Perimeter Ratio | Coef | Temp. Diff. | Room Heat Gain |                     |
|-------------|---------------------|-----------------|------|-------------|----------------|---------------------|
| Walls       | 5,538 SF            | 0.15 CFM/SF     | 1.08 | 18 °F       | 17,477 Btu/h   |                     |
| Doors       | 1,022 SF            | 0.25 CFM/LF     | 1.08 | 18 °F       | 1,683 Btu/h    |                     |
| Windows     | 0 SF                | 0.20 CFM/LF     | 1.08 | 18 °F       | 0 Btu/h        |                     |
| Ventilation | 0 cfm               | 0.00 LF/SF      | 1.08 | 18 °F       | 0 Btu/h        |                     |
|             |                     |                 |      |             |                | <b>19,160 Btu/h</b> |

### COOLING HEAT GAINS TO THE RA PLENUM - SENSIBLE

4,950

#### CONDUCTION

|                | NET AREA (SF) | U-VALUE | Cooling Load Temp. Dif. | Return Air Factor | Room Heat Gain |                     |
|----------------|---------------|---------|-------------------------|-------------------|----------------|---------------------|
| North Exposure | 0             | 0.13    | 20                      | 1.0               | 0 Btu/hr       |                     |
| East Exposure  | 0             | 0.13    | 39                      | 1.0               | 0 Btu/hr       |                     |
| South Exposure | -1,150        | 0.13    | 27                      | 1.0               | -4,140 Btu/hr  |                     |
| West Exposure  | 0             | 0.13    | 22                      | 1.0               | 0 Btu/hr       |                     |
| Roof           | 6,900         | 0.09    | 73                      | 0.0               | 0 Btu/hr       |                     |
|                |               |         |                         |                   |                | <b>-4,140 Btu/h</b> |

#### INTERNAL HEAT GAINS

|        |             |                  |                |            |         |                |
|--------|-------------|------------------|----------------|------------|---------|----------------|
| Lights | 0.80 w/sf x | 6,900 Occ Area = | 5.5 kW x 3413x | 0.00 RAF = | 0 Btu/h |                |
| Misc.  |             |                  |                |            | 0 Btu/h |                |
|        |             |                  |                |            |         | <b>0 Btu/h</b> |

#### SENSIBLE HEAT GAINS - TEMP. DEPENDENT

|                              |        |
|------------------------------|--------|
| Solar                        | 0      |
| Conduction to Room           | 66,670 |
| Conduction to Plenum         | -4,140 |
| Ventilation and Infiltration | 19,160 |
| Sub Total                    | 81,691 |

#### SENSIBLE HEAT GAINS - TEMP. INDEPENDENT

|                          |        |
|--------------------------|--------|
| Internal Gains to Room   | 18,840 |
| Internal Gains to Plenum | 0      |
| Sub Total                | 18,840 |

## HEAT GAIN/LOSS WORKSHEET

Project Name: Hamilton Township  
 Location: Hamilton, NJ  
 Building Name: Fire District #9  
 Engineer: CAA

Project No.: CHA #21180  
 Site Elevation: 460 Feet  
 Date: 04/12/10  
 Specific Volume: 13.50 CF/#

Building/Facility Designation: Engine Room

### LATENT COOLING LOADS

| Infiltration | Infiltration Factor | Air Density        | Humidity Ratio Dif. | Room Heat Gain      |
|--------------|---------------------|--------------------|---------------------|---------------------|
| Walls        | 5,750 SF            | 0.15 CFM/SF        | 4,800               | 0.0043 ##           |
| Doors        | 1,022 SF            | 0.25 CFM/LF        | 4,800               | 0.0043 ##           |
| Windows      | 0 SF                | 0.20 CFM/LF        | 4,800               | 0.0043 ##           |
| Ventilation  | 0 cfm               |                    | 4,800               | 0.0043 ##           |
| People       | 0 people            | 1.00 time in space | 250 Btu/hr/person   |                     |
|              |                     |                    |                     | <b>19,647 Btu/h</b> |

### Cooling Load Summary

|                             | Sensible       | Latent        | Total          |      |      |
|-----------------------------|----------------|---------------|----------------|------|------|
| Temperature Dependent Gains | 81,691         | 19,647        | 101,338        |      |      |
| Temperature Indep. Gains    | 18,840         |               | 18,840         | SHR= | 0.84 |
| <b>Total</b>                | <b>100,530</b> | <b>19,647</b> | <b>120,177</b> |      |      |

Building Cooling Load: 10.0 Tons at 689 SF/Ton

Building Air Flow to Condition Space based on a 12°F Temp Rise is: 8,060 CFM  
1.17 CFM/sf

### HEATING CALCULATION

#### CONDUCTION

| NET AREA (SF)  | U-VALUE | Heating Load Temp. Dif. | Room Heat Gain     |
|----------------|---------|-------------------------|--------------------|
| North Exposure | 2,008   | 0.13                    | 48                 |
| East Exposure  | 856     | 0.13                    | 48                 |
| South Exposure | 900     | 0.13                    | 48                 |
| West Exposure  | 624     | 0.13                    | 48                 |
| Fenestration   | 0       | 0.62                    | 48                 |
| Roof           | 6,900   | 0.09                    | 48                 |
| Doors          | 1,022   | 0.14                    | 48                 |
| Ceiling        | 6,900   | 0.14                    | 0                  |
| Partition      | 0       | 0.05                    | 0                  |
| Floor          | 6,900   | 0.04                    | 15                 |
|                |         |                         | <b>4,140 Btu/h</b> |

#### Ventilation and Infiltration

| Infiltration Factor                              | Coef     | Temp. Difference | Air Flow       | Room Heat Gain      |
|--|----------|------------------|----------------|---------------------|
| Walls  | 4,388 SF | 0.15 CFM/SF      | 1.08           | 48                  |
| Doors  | 1,022 SF | 0.25 CFM/LF      | 1.08           | 48                  |
| Windows  | 0 SF     | 0.20 CFM/LF      | 1.08           | 48                  |
| Ventilation Load                                 | 0 cfm    |                  | 1.08           | 48                  |
| <b>Total Ventilation &amp; Infiltration Load</b> |          |                  | <b>738 cfm</b> | <b>38,349 Btu/h</b> |

**Building Heating Load** 106,223 **btu/h**  
 15.4 btu/sf

Hamilton Township  
 CHA #21180  
 Building: Fire District #9

Engine Room

Doors

|       | Width (ft) | Height (ft) | Quantity     | Area (SF)     | Lineal Feet  |
|-------|------------|-------------|--------------|---------------|--------------|
| North | 3.0        | 7.0         | 2            | 42.0          | 40.0         |
|       |            |             |              | 0.0           | 0.0          |
|       |            |             |              | 0.0           | 0.0          |
|       |            |             |              | 0.0           | 0.0          |
|       |            |             |              | 0.0           | 0.0          |
|       |            |             |              | 0.0           | 0.0          |
|       |            |             | Sub-total    | 42.0          | 40.0         |
| East  | 14.0       | 14.0        | 4            | 784.0         | 224.0        |
|       |            |             |              | 0.0           | 0.0          |
|       |            |             |              | 0.0           | 0.0          |
|       |            |             |              | 0.0           | 0.0          |
|       |            |             | Sub-total    | 784.0         | 224.0        |
| South |            |             |              | 0.0           | 0.0          |
|       |            |             |              | 0.0           | 0.0          |
|       |            |             |              | 0.0           | 0.0          |
|       |            |             |              | 0.0           | 0.0          |
|       |            |             |              | 0.0           | 0.0          |
|       |            |             | Sub-total    | 0.0           | 0.0          |
| West  | 14.0       | 14.0        | 1            | 196.0         | 56.0         |
|       |            |             |              | 0.0           | 0.0          |
|       |            |             |              | 0.0           | 0.0          |
|       |            |             | Sub-total    | 196.0         | 56.0         |
|       |            |             | <b>Total</b> | <b>1022.0</b> | <b>320.0</b> |

|       |
|-------|
| LF/SF |
| 0.31  |

**Walls**

|       | Width (ft) | Height (ft) | Quantity | Area (SF) | Lineal Feet |
|-------|------------|-------------|----------|-----------|-------------|
| North | 100.0      | 20.5        | 1        | 2050.0    | 241.0       |
|       |            |             |          | 0.0       | 0.0         |
|       |            |             |          | 0.0       | 0.0         |
|       |            |             |          | 0.0       | 0.0         |
|       |            |             |          | 0.0       | 0.0         |
|       | 100.0      |             |          | 2050.0    | 241.0       |

All wall quantities must remain equal to 1

Ave. height 20.5

Average height wall automatically linked to

|      |      |      |   |        |       |
|------|------|------|---|--------|-------|
| East | 80.0 | 20.5 | 1 | 1640.0 | 201.0 |
|      |      |      |   | 0.0    | 0.0   |
|      |      |      |   | 0.0    | 0.0   |
|      |      |      |   | 0.0    | 0.0   |
|      |      |      |   | 0.0    | 0.0   |
|      | 80.0 |      |   | 1640.0 | 201.0 |

Ave. height 20.5

Average height wall automatically linked to

|       |       |     |   |       |       |
|-------|-------|-----|---|-------|-------|
| South | 100.0 | 9.0 | 1 | 900.0 | 218.0 |
|       |       |     |   | 0.0   | 0.0   |
|       |       |     |   | 0.0   | 0.0   |
|       |       |     |   | 0.0   | 0.0   |
|       |       |     |   | 0.0   | 0.0   |
|       | 100.0 |     |   | 900.0 | 218.0 |

Ave. height 9.0

Average height wall automatically linked to

|      |      |      |   |       |       |
|------|------|------|---|-------|-------|
| West | 40.0 | 20.5 | 1 | 820.0 | 121.0 |
|      |      |      |   | 0.0   | 0.0   |
|      |      |      |   | 0.0   | 0.0   |
|      |      |      |   | 0.0   | 0.0   |
|      |      |      |   | 0.0   | 0.0   |
|      | 40.0 |      |   | 820.0 | 121.0 |

Ave. height 20.5

Average height auto linked to block load sheet

**Windows**

|       | Width (ft) | Height (ft) | Quantity  | Area (SF) | Lineal Feet |
|-------|------------|-------------|-----------|-----------|-------------|
| North |            |             |           | 0.0       | 0.0         |
|       |            |             |           | 0.0       | 0.0         |
|       |            |             |           | 0.0       | 0.0         |
|       |            |             |           | 0.0       | 0.0         |
|       |            |             |           | 0.0       | 0.0         |
|       |            |             |           | 0.0       | 0.0         |
|       |            |             | Sub-total | 0.0       | 0.0         |

|      |  |  |           |     |     |
|------|--|--|-----------|-----|-----|
| East |  |  |           | 0.0 | 0.0 |
|      |  |  |           | 0.0 | 0.0 |
|      |  |  |           | 0.0 | 0.0 |
|      |  |  |           | 0.0 | 0.0 |
|      |  |  |           | 0.0 | 0.0 |
|      |  |  |           | 0.0 | 0.0 |
|      |  |  | Sub-total | 0.0 | 0.0 |

|       |  |  |           |     |     |
|-------|--|--|-----------|-----|-----|
| South |  |  |           | 0.0 | 0.0 |
|       |  |  |           | 0.0 | 0.0 |
|       |  |  |           | 0.0 | 0.0 |
|       |  |  |           | 0.0 | 0.0 |
|       |  |  |           | 0.0 | 0.0 |
|       |  |  |           | 0.0 | 0.0 |
|       |  |  | Sub-total | 0.0 | 0.0 |

|      |  |  |           |     |     |
|------|--|--|-----------|-----|-----|
| West |  |  |           | 0.0 | 0.0 |
|      |  |  |           | 0.0 | 0.0 |
|      |  |  |           | 0.0 | 0.0 |
|      |  |  |           | 0.0 | 0.0 |
|      |  |  |           | 0.0 | 0.0 |
|      |  |  |           | 0.0 | 0.0 |
|      |  |  | Sub-total | 0.0 | 0.0 |

**Total** 0.0 0.0

LF/SF 0.00



**APPENDIX F**

**ECM-5 Roof Replacement**



Hamilton Township  
CHA #21180  
Building: Fire District #9

**ECM-5 Roof Replacement** Single Story Main Building Area

|                           |                     |
|---------------------------|---------------------|
| Existing Roof Area        | 8,500 sf            |
| Existing U-value          | 0.09 Btu/hr/(sf°F)  |
| Proposed Added R-value    | 19.2                |
| Proposed U-value          | 0.033 Btu/hr/(sf°F) |
| Heating System Efficiency | 68%                 |
| Cooling System Efficiency | 1.21 kW/ton         |

|                                  |               |  |
|----------------------------------|---------------|--|
| Existing Cooling                 |               |  |
| Existing Cooling Load Temp Diff. | 18 F          |  |
| Existing Max. Roof Cooling Load  | 13,304 Btu/hr |  |
| Proposed Cooling                 |               |  |
| Proposed Cooling Load            | 4,984 Btu/hr  |  |
| Occupied Cooling Setpoint        | 73 F          |  |
| Unoccupied Cooling Setpoint*     | 76 F          |  |

|                                  |               |  |
|----------------------------------|---------------|--|
| Existing Heating                 |               |  |
| Existing Heating Load Temp Diff. | 54 F          |  |
| Existing Max. Roof Heating Load  | 39,913 Btu/hr |  |
| Proposed Heating                 |               |  |
| Proposed Heating Load            | 14,951 Btu/hr |  |
| Occupied Heating Setpoint        | 68 F          |  |
| Unoccupied Heating Setpoint*     | 64 F          |  |

|                        |                    |
|------------------------|--------------------|
| Existing Heating Total | 106,352,739 Btu/yr |
| Proposed Heating Total | 39,838,974 Btu/yr  |
| Savings                | 66,513,765 Btu/yr  |
| Input                  | 978 therms         |
| Existing Cooling Total | 758 kWh/yr         |
| Proposed Cooling Total | 284 kWh/yr         |
| Savings                | 474 kWh/yr         |

\*Average between areas w/ and w/o setback

| Avg Outdoor Air Temp. Bins *F | Occupied                     |                              |                                |                             | Unoccupied                  |                             |                             |                             | Existing Heating Load (Btu/yr) | Existing Cooling Load (kWh/yr) | Existing Heating Load (Btu/yr) | Existing Cooling Load (kWh/yr) | Proposed Heating Load (Btu/yr) | Proposed Cooling Load (kWh/yr) |                             |
|-------------------------------|------------------------------|------------------------------|--------------------------------|-----------------------------|-----------------------------|-----------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|--------------------------------|--------------------------------|--------------------------------|--------------------------------|-----------------------------|
|                               | Existing Equipment Bin Hours | Occupied Equipment Bin Hours | Unoccupied Equipment Bin Hours | Existing Heat Gain (Btu/hr) | Proposed Heat Loss (Btu/hr) | Existing Heat Loss (Btu/hr) | Proposed Heat Gain (Btu/hr) | Existing Heat Loss (Btu/hr) |                                |                                |                                |                                |                                |                                | Proposed Heat Loss (Btu/hr) |
|                               | 0                            | 3                            | 0                              | 21,804                      | 8,168                       | -                           | 19,587                      | 7,337                       |                                |                                |                                |                                |                                |                                | -                           |
| 102.5                         | 0                            | 0                            | 0                              | 18,109                      | 6,783                       | -                           | 15,891                      | 5,853                       | -                              | -                              | -                              | 5                              | -                              | -                              |                             |
| 97.5                          | 3                            | 3                            | 0                              | 14,413                      | 5,399                       | -                           | 12,196                      | 4,568                       | -                              | -                              | -                              | 49                             | 19                             | -                              |                             |
| 92.5                          | 34                           | 34                           | 0                              | 10,717                      | 4,015                       | -                           | 8,500                       | 3,184                       | -                              | -                              | -                              | 142                            | 53                             | -                              |                             |
| 87.5                          | 131                          | 131                          | 0                              | 7,022                       | 2,630                       | -                           | 4,804                       | 1,800                       | -                              | -                              | -                              | 354                            | 133                            | -                              |                             |
| 82.5                          | 500                          | 500                          | 0                              | 3,326                       | 1,246                       | -                           | 1,109                       | 415                         | -                              | -                              | -                              | 208                            | 78                             | -                              |                             |
| 77.5                          | 620                          | 620                          | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 72.5                          | 664                          | 664                          | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 67.5                          | 854                          | 854                          | 0                              | -                           | -                           | 370                         | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 62.5                          | 927                          | 927                          | 0                              | -                           | -                           | 4,065                       | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 57.5                          | 600                          | 600                          | 0                              | -                           | -                           | 7,761                       | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 52.5                          | 610                          | 610                          | 0                              | -                           | -                           | 11,457                      | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 47.5                          | 611                          | 611                          | 0                              | -                           | -                           | 15,152                      | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 42.5                          | 656                          | 656                          | 0                              | -                           | -                           | 18,848                      | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 37.5                          | 1,023                        | 1,023                        | 0                              | -                           | -                           | 22,543                      | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 32.5                          | 734                          | 734                          | 0                              | -                           | -                           | 26,239                      | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 27.5                          | 334                          | 334                          | 0                              | -                           | -                           | 29,935                      | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 22.5                          | 252                          | 252                          | 0                              | -                           | -                           | 33,630                      | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 17.5                          | 125                          | 125                          | 0                              | -                           | -                           | 37,326                      | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 12.5                          | 47                           | 47                           | 0                              | -                           | -                           | 41,022                      | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 7.5                           | 22                           | 22                           | 0                              | -                           | -                           | 44,717                      | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 2.5                           | 13                           | 13                           | 0                              | -                           | -                           | 48,413                      | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| -2.5                          | 0                            | 0                            | 0                              | -                           | -                           | 52,109                      | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| -7.5                          | 0                            | 0                            | 0                              | -                           | -                           | 55,804                      | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| <b>TOTALS</b>                 | <b>8,760</b>                 | <b>8,760</b>                 | <b>0</b>                       |                             |                             |                             |                             |                             |                                |                                |                                | <b>758</b>                     | <b>284</b>                     | <b>106,352,739</b>             | <b>39,838,974</b>           |

Hamilton Township  
CHA #21180  
Building: Fire District #9

ECM-5 Roof Replacement

Two Story Engine Room Area

|                           |                     |
|---------------------------|---------------------|
| Existing Roof Area        | 8,000 sf            |
| Existing U-value          | 0.08 Btu/hr/(sf°F)  |
| Proposed Added R-value    | 19.2                |
| Proposed U-value          | 0.033 Btu/hr/(sf°F) |
| Heating System Efficiency | 68%                 |
| Cooling System Efficiency | 0.00 kW/ton         |

|                                  |               |
|----------------------------------|---------------|
| Existing Cooling                 | 73 F          |
| Existing Cooling Load Temp Diff. | 43,800 Btu/hr |
| Existing Max. Roof Cooling Load  | 16,407 Btu/hr |
| Proposed Cooling                 | 73 F          |
| Proposed Cooling Load            | 80 F          |
| Occupied Cooling Setpoint        |               |
| Unoccupied Cooling Setpoint      |               |

|                                  |               |
|----------------------------------|---------------|
| Existing Heating                 | 48 F          |
| Existing Heating Load Temp Diff. | 33,391 Btu/hr |
| Existing Max. Roof Heating Load  | 12,508 Btu/hr |
| Proposed Heating                 | 62 F          |
| Proposed Heating Load            | 62 F          |
| Occupied Heating Setpoint        |               |
| Unoccupied Heating Setpoint      |               |

|                        |                   |
|------------------------|-------------------|
| Existing Heating Total | 75,270,609 Btu/yr |
| Proposed Heating Total | 28,195,831 Btu/yr |
| Savings                | 47,074,778 Btu/yr |
| Input                  | 692 therms        |
| Existing Cooling Total | - kWh/yr          |
| Proposed Cooling Total | - kWh/yr          |
| Savings                | - kWh/yr          |

| Avg Outdoor Air Temp. Bins °F | Occupied                     |                              |                                |                             | Unoccupied                  |                             |                             |                             | Existing Heating Load (Btu/yr) | Existing Cooling Load (kWh/yr) | Proposed Heating Load (Btu/yr) | Proposed Cooling Load (kWh/yr) | Proposed Heating Load (Btu/yr) | Proposed Cooling Load (kWh/yr) |                             |                             |
|-------------------------------|------------------------------|------------------------------|--------------------------------|-----------------------------|-----------------------------|-----------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|--------------------------------|--------------------------------|--------------------------------|--------------------------------|-----------------------------|-----------------------------|
|                               | Existing Equipment Bin Hours | Occupied Equipment Bin Hours | Unoccupied Equipment Bin Hours | Existing Heat Gain (Btu/hr) | Proposed Heat Gain (Btu/hr) | Existing Heat Loss (Btu/hr) | Proposed Heat Loss (Btu/hr) | Existing Heat Gain (Btu/hr) |                                |                                |                                |                                |                                |                                | Proposed Heat Gain (Btu/hr) | Existing Heat Loss (Btu/hr) |
| 102.5                         | 0                            | 0                            | 0                              | 20,522                      | 7,687                       | -                           | -                           | 15,652                      | 5,863                          | -                              | -                              | -                              | -                              | -                              | -                           |                             |
| 97.5                          | 3                            | 3                            | 0                              | 17,043                      | 6,384                       | -                           | -                           | 12,174                      | 4,560                          | -                              | -                              | -                              | -                              | -                              | -                           |                             |
| 92.5                          | 34                           | 34                           | 0                              | 13,565                      | 5,081                       | -                           | -                           | 8,696                       | 3,257                          | -                              | -                              | -                              | -                              | -                              | -                           |                             |
| 87.5                          | 131                          | 131                          | 0                              | 10,087                      | 3,779                       | -                           | -                           | 5,217                       | 1,954                          | -                              | -                              | -                              | -                              | -                              | -                           |                             |
| 82.5                          | 500                          | 500                          | 0                              | 6,609                       | 2,476                       | -                           | -                           | 1,739                       | 651                            | -                              | -                              | -                              | -                              | -                              | -                           |                             |
| 77.5                          | 620                          | 620                          | 0                              | 3,130                       | 1,173                       | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                           |                             |
| 72.5                          | 664                          | 664                          | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                           |                             |
| 67.5                          | 854                          | 854                          | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                           |                             |
| 62.5                          | 927                          | 927                          | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                           |                             |
| 57.5                          | 600                          | 600                          | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                           |                             |
| 52.5                          | 610                          | 610                          | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                           |                             |
| 47.5                          | 611                          | 611                          | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                           |                             |
| 42.5                          | 656                          | 656                          | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                           |                             |
| 37.5                          | 1,023                        | 1,023                        | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                           |                             |
| 32.5                          | 734                          | 734                          | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                           |                             |
| 27.5                          | 334                          | 334                          | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                           |                             |
| 22.5                          | 252                          | 252                          | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                           |                             |
| 17.5                          | 125                          | 125                          | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                           |                             |
| 12.5                          | 47                           | 47                           | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                           |                             |
| 7.5                           | 22                           | 22                           | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                           |                             |
| 2.5                           | 13                           | 13                           | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                           |                             |
| -2.5                          | 0                            | 0                            | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                           |                             |
| -7.5                          | 0                            | 0                            | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                           |                             |
| <b>TOTALS</b>                 | <b>8,760</b>                 | <b>8,760</b>                 | <b>0</b>                       |                             |                             |                             |                             |                             |                                |                                |                                |                                |                                |                                |                             | <b>28,195,831</b>           |

**Hamilton Township  
CHA #21180  
Building: Fire District #9**

**ECM-5 Roof Replacement**

**Description:**

Installation of a high reflectivity, high thermal emittance roof to decrease heat island effect. The new roof covering shall be applied over new added foam insulation.

Existing Roof Area 16,500 sf  
 Heating System Efficiency 68%  
 Cooling System Efficiency 1.21 kW/ton

|                 | Roof Surface Material     | Solar Reflectance | Infrared Emittance | *Cooling Load (Btu/ft <sup>2</sup> /yr) | *Heating Load (Btu/ft <sup>2</sup> /yr) |
|-----------------|---------------------------|-------------------|--------------------|---|---|
| Existing Roof   | Stone Ballast             | 12                | 90                 | 2,010                                   | 5,012                                   |
| **Proposed Roof | White Elastomeric Coating | 82                | 91                 | 416                                     | 5,861                                   |

\*Values calculated using the DOE Cool Roof Calculator

\*\*Proposed Roof values based on the use of SWD Quick-Shield High Reflectivity Roof Coating

| Annual Savings | Load Reduction (Btu/ft <sup>2</sup> /yr) | Bldg Load Savings (Btu/yr) | Annual Utility Savings |
|----------------|--|----------------------------|------------------------|
| Cooling        | 1,594                                    | 13,549,000                 | 1,366 kWh              |
| Heating        | (849)                                    | (14,008,500)               | (21) Therms            |

Cooling in Main Building Area only (8,500 sqft).

Hamilton Township

CHA #21180

Building: Fire District #9

**ECM-5 Roof Replacement**

Additional Insulation and Highly Reflective Roof

| Multipliers |      |
|-------------|------|
| Material:   | 0.98 |
| Labor:      | 1.21 |
| Equipment:  | 1.09 |

| Description               | QTY    | UNIT | UNIT COSTS |         |         | SUBTOTAL COSTS |           |          | TOTAL COST | REMARKS          |
|---------------------------|--------|------|------------|---------|---------|----------------|-----------|----------|------------|------------------|
|                           |        |      | MAT.       | LABOR   | EQUIP.  | MAT.           | LABOR     | EQUIP.   |            |                  |
| Roof Ballast Removal      | 16,500 | SQFT |            | \$ 0.27 |         | \$ -           | \$ 5,391  | \$ -     | \$ 5,391   |                  |
| Roof Membrane Removal     | 16,500 | SQFT |            | \$ 0.18 |         | \$ -           | \$ 3,594  | \$ -     | \$ 3,594   |                  |
| Substrate Primer          | 16,500 | SQFT | \$ 0.16    | \$ 0.25 | \$ 0.13 | \$ 2,587       | \$ 4,991  | \$ 2,338 | \$ 9,917   | Only if required |
| 3" Spray Foam Insulation  | 16,500 | SQFT | \$ 1.66    | \$ 0.07 | \$ 0.06 | \$ 26,842      | \$ 1,398  | \$ 1,079 | \$ 29,319  |                  |
| White Elastomeric Coating | 16,500 | SQFT | \$ 2.04    | \$ 0.64 | \$ 0.09 | \$ 32,987      | \$ 12,778 | \$ 1,619 | \$ 47,383  |                  |
|                           |        |      |            |         |         | \$ -           | \$ -      | \$ -     | \$ -       |                  |
|                           |        |      |            |         |         | \$ -           | \$ -      | \$ -     | \$ -       |                  |
|                           |        |      |            |         |         | \$ -           | \$ -      | \$ -     | \$ -       |                  |
|                           |        |      |            |         |         | \$ -           | \$ -      | \$ -     | \$ -       |                  |

Description: Existing stone ballasts and roofing membrane to be completely removed.  
 Additional foam insulation to be applied to remaining roof substrate or rigid foam insulation.  
 Final roof coating to be applied to new foam insulation.  
 Application process is subject to manufacturer's specifications.

|    |                |                     |
|----|----------------|---------------------|
| \$ | 95,603         | Subtotal            |
| \$ | 7,170          | 7.5% Contingency    |
| \$ | 7,708          | 7.5% Contractor O&P |
| \$ | -              | 0% Engineering      |
| \$ | <b>110,481</b> | <b>Total</b>        |

Hamilton Township  
 CHA #21180  
 Building: Fire District #9

**ECM-5 Roof Replacement**

Traditional Membrane Replacement Only

|             |      |
|-------------|------|
| Multipliers |      |
| Material:   | 0.98 |
| Labor:      | 1.21 |
| Equipment:  | 1.09 |

| Description                               | QTY    | UNIT     | UNIT COSTS |         |         | SUBTOTAL COSTS |          |        | TOTAL COST | REMARKS                  |
|---|--------|----------|------------|---------|---------|----------------|----------|--------|------------|--------------------------|
|   |        |          | MAT.       | LABOR   | EQUIP.  | MAT.           | LABOR    | EQUIP. |            |                          |
| Roof Ballast Removal                      | 16,500 | SQFT     |            | \$ 0.27 |         | \$ -           | \$ 5,391 | \$ -   | \$ 5,391   |                          |
| Roof Membrane Removal                     | 16,500 | SQFT     |            | \$ 0.18 |         | \$ -           | \$ 3,594 | \$ -   | \$ 3,594   |                          |
| EPDM Membrane Roofing 60 mils, 0.4 P.S.F. | 165    | 100 SQFT | \$ 90      | \$ 25   | \$ 3.69 | \$ 14,553      | \$ 4,991 | \$ 664 | \$ 20,208  | Loose Laid and Ballasted |
|   |        |          |            |         |         | \$ -           | \$ -     | \$ -   | \$ -       |                          |
|   |        |          |            |         |         | \$ -           | \$ -     | \$ -   | \$ -       |                          |
|   |        |          |            |         |         | \$ -           | \$ -     | \$ -   | \$ -       |                          |
|   |        |          |            |         |         | \$ -           | \$ -     | \$ -   | \$ -       |                          |
|   |        |          |            |         |         | \$ -           | \$ -     | \$ -   | \$ -       |                          |
|   |        |          |            |         |         | \$ -           | \$ -     | \$ -   | \$ -       |                          |

Description: Existing stone ballasts and roofing membrane to be completely removed.  
 Additional foam insulation to be applied to remaining roof substrate or rigid foam insulation.  
 Final roof coating to be applied to new foam insulation.  
 Application process is subject to manufacturer's specifications.

|    |               |                    |
|----|---------------|--------------------|
| \$ | 29,192        | Subtotal           |
| \$ | 5,838         | 20% Contingency    |
| \$ | 7,006         | 20% Contractor O&P |
| \$ | -             | 0% Engineering     |
| \$ | <b>42,037</b> | <b>Total</b>       |

## DOE Cool Roof Calculator

### Estimates Energy and Peak Demand Savings for Flat Roofs with Non-Black Surfaces

- Developed by the U.S. Department of Energy's Oak Ridge National Laboratory (Version 2.0)
- This version of the calculator is for large facilities that purchase electricity with a demand charge based on peak monthly load. If you have a small or medium-sized facility that purchases electricity without a demand charge, run the [CoolCalcEnergy](#) version to estimate the savings in energy charges from using solar radiation control.
- What you get out of this calculator is only as good as what you put in. If you [CLICK HERE](#), you'll find help in figuring out the best input values. Some things, such as the weathering of the solar radiation control properties and the effects of a plenum, are especially important. You'll also find help in figuring out your heating and cooling system efficiencies and proper fuel prices.
- To compare two non-black roofs, print out results of separate estimates for each vs. a black roof. Manually compute the difference in savings to compare the two non-black roofs.
- If your energy costs are determined with both on-peak and off-peak rates, print out results of separate estimates with on-peak then off-peak rates. Use appropriate demand charges for the same roof in both estimates. Judge what fraction of the savings with on-peak rates is appropriate.

My State

New Jersey 

My City

Newark 

Click to see [Data for All 243 Locations](#)

#### My Proposed Roof:

|  |      |
|--|------|
| R-value (HIGH=20; AVG=10; LOW=5) [h·ft <sup>2</sup> ·°F/Btu] | 31.9 |
| Solar reflectance, SR (HIGH=80; AVG=50; LOW=10) [%]          | 12   |
| Infrared emittance, IE (HIGH=90; AVG=60; LOW=10) [%]         | 90   |

#### My Energy Costs and Equipment Efficiencies:

|   |   |
|---|---|
| Summertime cost of electricity (HIGH=0.20; AVG=0.10; LOW=0.05) [\$/KWh]           | 0.1412  |
| Air conditioner efficiency (COP) over cooling season (HIGH=2.5; AVG=2.0; LOW=1.5) | 2.9   |
| Energy source for heating (choose one)  | <input type="radio"/> Electricity <input checked="" type="radio"/> Fuel |
| If electricity, wintertime cost (HIGH=0.20; AVG=0.10; LOW=0.05) [\$/KWh]          |   |
| If fuel, cost (Natural gas: HIGH=1.00; AVG=0.70; LOW=0.50) [\$/Therm]             |   |
| (Fuel oil: 2002 East coast=0.85; 2002 Midwest=0.70) [\$/Therm]                    | 1.10  |

Heating system efficiency (Furnace or boiler: HIGH=0.8; AVG=0.7; LOW=0.5)  
 (Electric heat pump: HIGH=2.0; AVG=1.5) (Electric resistance: 1.0) 0.75

### My Electricity Demand Charges and Duration:

Demand charge during cooling season (HIGH=15.00; AVG=10.00; LOW=5.00) [\$/KW] 17.68

Months charged for peak demand (Typical = 6) [-] 4

Total Annual Energy + Demand Savings (relative to a black roof) [\$/ft<sup>2</sup> per year] 0.002

Cooling energy savings [\$/ft<sup>2</sup> per year] 0.002

Heating energy savings (heating penalty if negative) [\$/ft<sup>2</sup> per year] -0.001

Cooling season demand savings [\$/ft<sup>2</sup> per year] 0.001

### Insulation in Black Roof for Same Total Annual Energy Savings (ignores demand savings):

Upgrade from R-31.9 to R-32 [h-ft<sup>2</sup>·°F/Btu]

### Details of Energy and Demand Savings:

Heating degree days for location chosen [Annual °F-day] 5122.5

Cooling degree days for location chosen [Annual °F-day] 1061.5

Solar load for location chosen [Annual average Btu/ft<sup>2</sup> per day] 1226.5

Cooling load for black roof (SR=5%; IE=90%) [Btu/ft<sup>2</sup> per year] 2163

Heating load for black roof (SR=5%; IE=90%) [Btu/ft<sup>2</sup> per year] 4951

Cooling load for proposed roof [Btu/ft<sup>2</sup> per year] 2010

Heating load for proposed roof [Btu/ft<sup>2</sup> per year] 5012

Average heat load reduction during cooling season [Btu/ft<sup>2</sup> each month] 0.1

Maximum heat load reduction during cooling season [Btu/ft<sup>2</sup>] 0.2

## DOE Cool Roof Calculator

### Estimates Energy and Peak Demand Savings for Flat Roofs with Non-Black Surfaces

- Developed by the U.S. Department of Energy's Oak Ridge National Laboratory (Version 2.0)
- This version of the calculator is for large facilities that purchase electricity with a demand charge based on peak monthly load. If you have a small or medium-sized facility that purchases electricity without a demand charge, run the [CoolCalcEnergy](#) version to estimate the savings in energy charges from using solar radiation control.
- What you get out of this calculator is only as good as what you put in. If you [CLICK HERE](#), you'll find help in figuring out the best input values. Some things, such as the weathering of the solar radiation control properties and the effects of a plenum, are especially important. You'll also find help in figuring out your heating and cooling system efficiencies and proper fuel prices.
- To compare two non-black roofs, print out results of separate estimates for each vs. a black roof. Manually compute the difference in savings to compare the two non-black roofs.
- If your energy costs are determined with both on-peak and off-peak rates, print out results of separate estimates with on-peak then off-peak rates. Use appropriate demand charges for the same roof in both estimates. Judge what fraction of the savings with on-peak rates is appropriate.

My State

New Jersey 

My City

Newark 

Click to see [Data for All 243 Locations](#)

#### My Proposed Roof:

|  |      |
|--|------|
| R-value (HIGH=20; AVG=10; LOW=5) [h·ft <sup>2</sup> ·°F/Btu] | 31.9 |
| Solar reflectance, SR (HIGH=80; AVG=50; LOW=10) [%]          | 82   |
| Infrared emittance, IE (HIGH=90; AVG=60; LOW=10) [%]         | 91   |

#### My Energy Costs and Equipment Efficiencies:

|   |   |
|---|---|
| Summertime cost of electricity (HIGH=0.20; AVG=0.10; LOW=0.05) [\$/KWh]           | 0.1412  |
| Air conditioner efficiency (COP) over cooling season (HIGH=2.5; AVG=2.0; LOW=1.5) | 2.9   |
| Energy source for heating (choose one)  | <input type="radio"/> Electricity <input checked="" type="radio"/> Fuel |
| If electricity, wintertime cost (HIGH=0.20; AVG=0.10; LOW=0.05) [\$/KWh]          |   |
| If fuel, cost (Natural gas: HIGH=1.00; AVG=0.70; LOW=0.50) [\$/Therm]             |   |
| (Fuel oil: 2002 East coast=0.85; 2002 Midwest=0.70) [\$/Therm]                    | 1.10  |

Heating system efficiency (Furnace or boiler: HIGH=0.8; AVG=0.7; LOW=0.5)  
 (Electric heat pump: HIGH=2.0; AVG=1.5) (Electric resistance: 1.0) 0.75

### My Electricity Demand Charges and Duration:

Demand charge during cooling season (HIGH=15.00; AVG=10.00;  
 LOW=5.00) [\$/KW] 17.68

Months charged for peak demand (Typical = 6) [-] 4

Calculate My Annual Savings

Total Annual Energy + Demand Savings (relative to a black  
 roof) [\$/ft<sup>2</sup> per year] 0.028

Cooling energy savings [\$/ft<sup>2</sup> per year] 0.025

Heating energy savings (heating penalty if negative) [\$/ft<sup>2</sup> per year] -0.013

Cooling season demand savings [\$/ft<sup>2</sup> per year] 0.017

Insulation in Black Roof for Same Total Annual Energy Savings  
 (ignores demand savings):

Upgrade from R-31.9 to R-33.1 [h-ft<sup>2</sup>·°F/Btu]

### Details of Energy and Demand Savings:

Heating degree days for location chosen [Annual °F-day] 5122.5

Cooling degree days for location chosen [Annual °F-day] 1061.5

Solar load for location chosen [Annual average Btu/ft<sup>2</sup> per day] 1226.5

Cooling load for black roof (SR=5%; IE=90%) [Btu/ft<sup>2</sup> per year] 2163

Heating load for black roof (SR=5%; IE=90%) [Btu/ft<sup>2</sup> per year] 4951

Cooling load for proposed roof [Btu/ft<sup>2</sup> per year] 416

Heating load for proposed roof [Btu/ft<sup>2</sup> per year] 5861

Average heat load reduction during cooling season [Btu/ft<sup>2</sup> each month] 2.3

Maximum heat load reduction during cooling season [Btu/ft<sup>2</sup>] 2.9



# SWD Quik-Shield® | 1929F High Reflectivity Roof Coating

SWD Quik-Shield® | 1929F is a high solids, heat resistant, water based, elastomeric coating material made from 100% acrylic polymers.

It is an ideal coating for all types of roofing including:

- Spray polyurethane foam (SPF)
- Built-up
- Single-ply
- Metal
- Concrete

SWD Quik-Shield® | 1929F prevents degradation to roofing caused by normal weathering, aging and ultraviolet exposure. It includes special fire retardants, mildew retardants and rust inhibitors that help extend the service life of any roofing system.

SWD Quik-Shield® | 1929F is easy and convenient to apply. It is fast drying, odor free and environmentally safe. It is also ideal for applications to walls, tanks, silos and many other surfaces.




## SWD Quik-Shield® | 1929F an ideal cool roofing solution

A cool roof reflects and emits the sun's heat back into the sky instead of transferring it into the building.

A cool roof can:

- Increase indoor comfort by keeping a building cooler in the summer months.
- Reduce energy costs. Studies have shown that cool roof coating can lead to energy savings of 30-40%.
- Address air pollution and global warming concerns by lowering CO<sub>2</sub> and other emissions associated with fossil fuel generated electricity.
- Reduce "urban heat island effect" by reflecting heat back into the atmosphere.
- Pay for itself. The California energy commission cites cases of a 2-5 yr payback for installing a cool roof.

*Source: Cool Roof Rating Council*



### Tested & Approved

SWD Quik-Shield® | 1929F is CRRC, Energy Star & LEED compliant.

ICC, UL, FM, Miami-Dade, California Fire Marshall approved

SWD Quik-Shield® | 1929 coatings were tested by the US Navy Civil Engineering Lab (NCEL) in an on-going environmental test from 1977-1990. Rated "excellent" and "recommended for use at any and all locations."





# SWD Quik-Shield® | 1929F

## High Reflectivity Roof Coating - Specifications

### CHARACTERISTICS:

#### FLAME RETARDANT:

ICC rated Class A  
 UL 723 rated Class I  
 UL 790 rated Class A  
 Meets coating requirements for UL Roof Systems #136, 181 and 206  
 California Fire Marshall listed as a component of Class A rated roof systems and as a "general purpose fire retardant chemical coating."

#### CRRC & ENERGY STAR COMPLIANT:

Solar Reflectance Index (SRI) 103%.  
 82% Solar Reflectance  
 91% Thermal Emittance

#### ADHESION:

Rigid polyurethane roofing and insulation foam  
 Asphalt shingle roofing  
 Concrete, masonry, wood, metal

#### MOISTURE PROOF-VAPOR RETARDANT.

Perm rating of 3.5 allows the dried film to "breathe"

#### WEATHER RESISTANT:

Acrylic polymers extend durability  
 Titanium dioxide blocks ultra-violet light effects  
 Tested "Excellent" in on-going Naval Civil Engineering Laboratory study.  
 Meets ASTM D-6083 standards

#### MILDEW RESISTANT:

Contains mildew retardants to inhibit or prevent mildew growth.

#### APPROVALS/CODE COMPLIANCE:

ICC : Research Report # 3182  
 UL: File # R-8671, R-9303 Construction # 136, 181, 206

#### CALIFORNIA FIRE MARSHALL:

ID# 4175-1321:100  
 ID#2280-1321:102  
 Class A rated roof system component  
 General purpose fire retardant coating

CITY OF LOS ANGELES: Report # RR 24072

MIAMI-DADE: #06-1204.03

**SHELF LIFE:** Unopened containers @ 50°-89°F 6 months

**COLORS:** White, Buff, Santa Fe Buff, Lt. Grey, Dk. Grey

**CAUTION:** Do not take internally. Keep out of reach of children.

### PHYSICAL PROPERTIES:

#### SOLIDS CONTENT:

By Weight 70+ 5%  
 By Volume 60+ 5%

#### WEIGHT /GAL:

11.9 lbs

#### COVERAGE:

(Mils/100 sf./gal) 9.3

#### VISCOSITY: (Krebs)

96-102

#### ULTIMATE TENSILE STRENGTH:

psi @ 75°F ASTM D-412 280  
 psi @ 0°F ASTM D-2370 299

#### ELONGATION AT BREAK:

% @ 75°F ASTM D-412 355  
 % @ 0°F ASTM D-2370 255

#### SURFACE BURNING CHARACTERISTICS:

Flame Spread ASTM E-84 10  
 Smoke Developed UL 723 15

#### PERMEANCE:

(Perms @ 20 mils) ASTM E-96(Procedure B) 3.5

#### SOLAR REFLECTANCE INDEX:

ASTM E-1980 103%

#### SOLAR REFLECTANCE:

ASTM E-903 82%

#### THERMAL EMITTANCE:

ASTM E-408 91%

#### HARDNESS:

ASTM D-2240 (Shore A) 60

#### ADHESION TO POLYURETHANE FOAM:

ASTM D-413 (Cohesive Peak Failure)  
 Dry 6.1 Wet 3.5

#### LOW TEMPERATURE FLEXIBILITY:

(-150F) 1800 Bend-  
 After 3000 hrs. Pass  
 After 1 yr Outside Pass

#### WATER ABSORPTION:

ASTM D-2842 (168 hr. @ 75°F) 5%

#### INSTALLATION:

May be applied by brush, roller, or conventional airless spray equipment. Tools can be cleaned with a thorough water flush. Surface should be dry, clean and free of contaminants or oxidation. When applying over foam (SPF): to avoid damaging the skin of the foam, operator should wear soft soled shoes. The coating should be applied 2-72 hours after foam installation. It is recommended that operators wear sunglasses to avoid temporary blinding effects due to glare. Do not apply at ambient temperatures below 50°F.

This information herein is believed to be reliable, however, unknown risks may be present. SWD Urethane Company makes no warranty, expressed or implied, concerning this product's merchantability or fitness for any particular use. The only warranty SWD Urethane Company give is that the product meets the specifications herein listed, and in the event that it does not, that SWD Urethane Company will replace, at its costs SWD Urethane Company's product. The foregoing constitutes SWD Urethane Company's sole obligation with respect to damages, whether direct, incidental or consequential, resulting from the use or performance of the product.

SWD Urethane Company 222 S. Date St. Mesa, AZ 85210 swdurethane.com (800) 828-1394



# SWD Quik-Shield® | 125 Roof Foam

**SWD Quik-Shield® | 125** is a low viscosity, two component, 2.5 - 3.0 lb closed-cell, spray-applied rigid polyurethane foam . This product meets building codes for roofing and is ideal for use as an insulating air barrier and as part of an energy efficient building envelope.

**SWD Quik-Shield® | 125** creates a monolithic, water resistant barrier that stops air infiltration. It also provides excellent insulation with an R-Value of 6.8 per inch.

**SWD Quik-Shield® | 125** quickly adheres to roofing substrates to strengthen and waterproof new and existing roofs (many times without a costly tear off).

**SWD Quik-Shield® | 125** roof systems are environmentally friendly because they reduce energy use, reduce a building's carbon footprint, and reduce landfill space requirements. They also contain no CFC's, or HCFC's .



## **SWD Quik-Shield® | 125 an ideal roofing solution**

Up to 50% of all energy used in a building can be literally lost through the roof.

**SWD Quik-Shield® | 125** can significantly reduce that loss and increase the performance of your building by creating a seamless monolithic roofing system.

**SWD Quik-Shield® | 125** is able to add structural stability and increase resistance to wind uplift and hail damage.

**SWD Quik-Shield® | 125** also provides high R-value insulation, reduces air infiltration and 'bellowing' and restricts water and vapor transmission.

As a self adhering system, **SWD Quik-Shield® | 125** requires no mechanical fasteners which increases installation efficiency as well as structural waste.

### **Tested & Approved**

**SWD Quik-Shield® | 125** is ICC, UL, and California Fire Marshall approved. It is California Bureau of Home Furnishings & LEED compliant. It is also a qualifying material for an Energy Star qualified home.





# SWD Quik-Shield® | 125

## Roof Foam - Specifications

### CHARACTERISTICS:

#### INSULATION PROPERTIES:

R-Value: 6.8 per inch.  
 Noise Reduction Coefficient: 20%  
 Performs equally in hot or cold temperatures.

#### SEAMLESS INSULATION:

Stops air infiltration  
 No joints or seams to leak air or water.  
 Reduce dust, gas, odor and noise penetration

#### MONOLITHIC:

Solid, one-piece construction.  
 Increases structural stability.

#### SELF-ADHESIVE:

No fasteners needed  
 Attaches chemically to wood, metal, plastic, tile, pipe, etc.  
 No unnecessary holes in roof substrates from fasteners

#### WATER MOISTURE RESISTANT:

Undamaged, closed cell foam will not absorb water  
 Water vapor can pass through foam, allowing roof to breathe and help prevent condensation and mold.

#### LIGHT WEIGHT:

Weight Per Square (at 1"): 30 lbs  
 High strength to weight ratio.

#### SAFE TO USE:

Contains no urea formaldehyde or carcinogens.  
 Does not give off toxic fumes after application.

#### ENVIRONMENTALLY FRIENDLY:

Reduces energy and fossil fuel requirements.  
 No CFC's or HCFC's  
 Low VOC's  
 No adverse impact on ozone layer.  
 Finished product may be recycled or landfill disposed.

#### SHELF LIFE:

Six months from date of manufacture in unopened containers when stored at 50-80°F.

#### APPROVALS/ COMPLIANCE:

ICC-ES #3182  
 E-108, UL 790 Class A Roof System:  
 Construction # 136, 181, 206, UL file R-9303.  
 California Fire Marshal Listing No. 040175-1321:100  
 California Bureau of Home Furnishings: Reg#. CA – T030

### PHYSICAL PROPERTIES:

#### RELATIVE INSULATION VALUES (initial values):

| k-Factor | R Value/ in. | Thickness |
|----------|--------------|-----------|
| 0.16     | 6.8          | 1"        |

#### HANDLING PROPERTIES :

(Based on regular grade formulation at 75°F.)

|                  | "A" Compound | "B" Compound |
|------------------|--------------|--------------|
| Viscosity, cps   | 500          | 770          |
| Specific Gravity | 1.23         | 1.18         |
| Mixing Ratio     | 50           | 50           |

#### REACTIVITY PROFILE:

|                          | Winter | Inter. | Summer |
|--------------------------|--------|--------|--------|
| Cream Time (seconds)     | 1-3    | 3-4    | 4-6    |
| Tack Free Time (seconds) | 7-9    | 9-11   | 11-13  |
| Cure Time @ 75° (hours)  | 4      | 4      | 4      |
| Rise Time (seconds)      | 12-14  | 14-18  | 18-24  |

|                           | Procedure* | Values    |
|---------------------------|------------|-----------|
| Core Density, pcf nominal | D-1622     | 2.5 - 3.0 |
| Compressive Strength,psi  | D-1621     | 42        |
| Tensile Strength          | D-1623     | 75        |
| Closed Cell, content, %   | D-2856     | 95        |
| Thermal Resistance        | C-1770     | 14.8      |
| Dimensional Stability     | D-2126     | 1.07      |

\*NOTES: ASTM Test Method Reference Number

#### PROCESSING INFORMATION:

Under normal operation conditions, primary heater setting should be 120°F -140°F. Hose temperatures are dependent on weather conditions and processing equipment, with 120°F-140°F for most types of plural component 1:1 dispensing equipment to achieve proper atomization of liquid components. Hose pressure should be 800 to 1500 psi depending upon equipment. Remove bung covers with caution.

**WARNING:** Polyurethane products produced from these chemicals may present a serious fire hazard if improperly used or allowed to remain exposed or unprotected. Specific hazards will depend upon a broad range of factors, which are controlled or influenced by the manufacturing process, the mode of application or installation, and the function and usage of the particular product. Each person, firm or corporation engaged in the manufacture, production, application, installation, or use of any polyurethane product should carefully determine whether there is a fire hazard associated with such product in a specific usage, and utilize all appropriate precautionary and safety measures.

This information herein is believed to be reliable, however, unknown risks may be present. SWD Urethane Company makes no warranty, expressed or implied, concerning this product's merchantability or fitness for any particular use. The only warranty SWD Urethane Company give is that the product meets the specifications herein listed, and in the event that it does not, that SWD Urethane Company will replace, at its costs SWD Urethane Company's product. The foregoing constitutes SWD Urethane Company's sole obligation with respect to damages, whether direct, incidental or consequential, resulting from the use or performance of the product.

SWD Urethane Company 222 S. Date St. Mesa, AZ 85210 swdurethane.com (800) 828-1394

## **APPENDIX G**

### **ECM-6 Increase Wall Insulation – Engine Room**



Hamilton Township  
CHA #21180  
Building: Fire District #9

**ECM-6 Increase Wall Insulation - Engine Room**

Total Existing Wall Area 4,388 sf  
Existing U-value 0.133 Btu/hr/(sf°F)  
Proposed U-value 0.047 Btu/hr/(sf°F)  
Heating Efficiency 65%  
Cooling Efficiency 1.21 kWh/ton

W/ additional 2" Polystyrene Board Insulation (R-14)

Existing Heating  
Existing Heating Load Temp Diff 48 F  
Existing Max. Wall Heating Load 28,083 Btu/hr

Proposed Heating  
Proposed Max. Heating Load 9,899 Btu/hr

Occupied Heating Setpoint 62 F  
Unoccupied Heating Setpoint 62 F

Existing Heating Total 63,395,081 Btu/yr  
Proposed Heating Total 22,315,045 Btu/yr  
Savings 40,990,046 Btu/yr  
Input 893 therms

| Avg Outdoor Air Temp. Bins °F | Occupied                     |                              |                                |                             | Unoccupied                  |                             |                             |                             | Existing Heating Load (Btu/yr) | Existing Cooling Load (kWh/yr) | Existing Heating Load (Btu/yr) | Existing Cooling Load (kWh/yr) | Proposed Heating Load (Btu/yr) | Proposed Cooling Load (kWh/yr) | Proposed Heating Load (Btu/yr) | Proposed Cooling Load (kWh/yr) |                             |
|-------------------------------|------------------------------|------------------------------|--------------------------------|-----------------------------|-----------------------------|-----------------------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|--------------------------------|--------------------------------|--------------------------------|--------------------------------|--------------------------------|--------------------------------|-----------------------------|
|                               | Existing Equipment Bin Hours | Occupied Equipment Bin Hours | Unoccupied Equipment Bin Hours | Existing Heat Gain (Btu/yr) | Proposed Heat Gain (Btu/yr) | Existing Heat Loss (Btu/yr) | Proposed Heat Loss (Btu/yr) | Existing Heat Gain (Btu/yr) |                                |                                |                                |                                |                                |                                |                                |                                | Proposed Heat Gain (Btu/yr) |
| 97.5                          | 3                            | 3                            | 0                              | 19,016                      | 6,703                       | -                           | -                           | 19,016                      | 6,703                          | -                              | -                              | 6                              | -                              | -                              | -                              | -                              |                             |
| 92.5                          | 34                           | 34                           | 0                              | 15,135                      | 5,335                       | -                           | -                           | 15,135                      | 5,335                          | -                              | -                              | 52                             | -                              | -                              | -                              | -                              |                             |
| 87.5                          | 131                          | 131                          | 0                              | 11,255                      | 3,967                       | -                           | -                           | 11,255                      | 3,967                          | -                              | -                              | 149                            | -                              | -                              | -                              | -                              |                             |
| 82.5                          | 500                          | 500                          | 0                              | 7,374                       | 2,599                       | -                           | -                           | 7,374                       | 2,599                          | -                              | -                              | 372                            | -                              | -                              | -                              | -                              |                             |
| 77.5                          | 620                          | 620                          | 0                              | 3,493                       | 1,231                       | -                           | -                           | 3,493                       | 1,231                          | -                              | -                              | 218                            | -                              | -                              | -                              | -                              |                             |
| 72.5                          | 664                          | 664                          | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 67.5                          | 854                          | 854                          | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 62.5                          | 927                          | 927                          | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 57.5                          | 600                          | 600                          | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 52.5                          | 610                          | 610                          | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 47.5                          | 611                          | 611                          | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 42.5                          | 656                          | 656                          | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 37.5                          | 1,023                        | 1,023                        | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 32.5                          | 734                          | 734                          | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 27.5                          | 334                          | 334                          | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 22.5                          | 252                          | 252                          | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 17.5                          | 125                          | 125                          | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 12.5                          | 47                           | 47                           | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 7.5                           | 22                           | 22                           | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| 2.5                           | 13                           | 13                           | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| -2.5                          | 0                            | 0                            | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| -7.5                          | 0                            | 0                            | 0                              | -                           | -                           | -                           | -                           | -                           | -                              | -                              | -                              | -                              | -                              | -                              | -                              | -                              |                             |
| <b>TOTALS</b>                 | <b>8,760</b>                 | <b>8,760</b>                 | <b>0</b>                       |                             |                             |                             |                             |                             |                                |                                |                                | <b>796</b>                     |                                |                                | <b>63,305,091</b>              | <b>281</b>                     | <b>22,315,045</b>           |



## **APPENDIX H**

### **ECM-7 Install Door Seals**

