

**TABERNACLE TOWNSHIP  
DEPARTMENT OF PUBLIC WORKS BUILDING  
ENERGY ASSESSMENT**

**for**

**NEW JERSEY  
BUREAU OF PUBLIC UTILITIES**

**CHA PROJECT NO. 21063**

June 2010

Prepared by:

**CLOUGH HARBOUR & ASSOCIATES LLP**

6 Campus Drive  
Parsippany, NJ 07054

(973) 538-2120

---

## TABLE OF CONTENTS

|   | <u>Page</u> |
|---|-------------|
| <b>1.0 INTRODUCTION &amp; BACKGROUND.....</b>     | <b>1</b>    |
| <b>2.0 EXECUTIVE SUMMARY.....</b>                 | <b>2</b>    |
| <b>3.0 EXISTING CONDITIONS.....</b>               | <b>4</b>    |
| 3.1 Building General                              |             |
| 3.2 Utility Usage                                 |             |
| 3.3 HVAC Systems                                  |             |
| 3.4 Control Systems                               |             |
| 3.5 Lighting/Electrical Systems                   |             |
| 3.6 Plumbing Systems                              |             |
| <b>4.0 ENERGY CONSERVATION MEASURES.....</b>      | <b>6</b>    |
| 4.1 ECM-1 Furnace Replacement                     |             |
| 4.2 ECM-2 Increase Wall Insulation                |             |
| 4.3 ECM-3 Night Setback                           |             |
| 4.4 ECM-4 Install Door Seals                      |             |
| 4.5 ECM-5 Lighting Replacements                   |             |
| <b>5.0 INCENTIVES OVERVIEW.....</b>               | <b>10</b>   |
| 5.1 Incentives Overview                           |             |
| 5.2 Building Incentives                           |             |
| <b>6.0 ALTERNATIVE ENERGY EVALUATION.....</b>     | <b>12</b>   |
| 6.1 Geothermal                                    |             |
| 6.2 Solar   |             |
| 6.3 Wind  |             |
| 6.4 Combined Heat and Power Generation (CHP)      |             |
| 6.5 Biomass Power Generation                      |             |
| 6.6 Demand Response Curtailment                   |             |
| <b>7.0 EPA PORTFOLIO MANAGER.....</b>             | <b>17</b>   |
| <b>8.0 CONCLUSIONS &amp; RECOMMENDATIONS.....</b> | <b>18</b>   |

---

## **APPENDICES**

- A Utility Usage Analysis
  - B ECM-1 Furnace Replacement
  - C ECM-2 Increase Wall Insulation
  - D ECM-3 Night Setback
  - E ECM-4 Install Door Seals
  - F ECM-5 Lighting Replacement
  - G New Jersey Incentive Program
  - H Photovoltaic (PV) Rooftop Solar Power Generation
  - I Solar Thermal Domestic Hot Water Plant
  - J Wind
  - K EPA Portfolio Manager
  - L Equipment Inventory
-

## **1.0 INTRODUCTION AND BACKGROUND**

The Department of Public Works Building (DPW) was constructed in 1980. The single story, 2,290 square foot structure, located at 163 Carranza Road in Tabernacle, New Jersey, includes a two bay garage, lunchroom, storage room, and restroom.

New Jersey's Clean Energy Program, funded by the New Jersey Board of Public Utilities, supports energy efficiency and sustainability for Municipal and Local Government Energy Audits. Through the support of a utility trust fund, New Jersey is able to assist state and local authorities in reducing energy consumption while increasing comfort.

## 2.0 EXECUTIVE SUMMARY

This report summarizes the energy audit for Tabernacle, New Jersey Department of Public Works Building. The 2,290 square foot single story structure consists of a two bay garage, lunchroom, storage room, and restroom. The following areas were evaluated for energy conservation measures:

- Furnace replacement
- Insulation upgrade
- Lighting replacement
- Night setback
- Door seals

Various potential Energy Conservation Measures (ECMs) were identified for the above categories. Measures which are recommended for implementation have a payback of 10 years or less. This threshold is considered a viable return on investment. Potential annual savings of \$4,400 for the recommended ECMs may be realized with a payback of 4.9 years.

The ECMs identified in this report will allow for the building to reduce its energy usage and if pursued has the opportunity to qualify for the New Jersey SmartStart Buildings Program. A summary of the costs, savings, and paybacks for the recommended ECMs follows:

### ECM-1 Furnace Replacement

| Budgetary<br>Cost | Annual Utility Savings |     |          |         |       | ROI | Potential<br>Incentive* | Payback<br>(without<br>incentive) | Payback<br>(with<br>incentive) |
|-------------------|------------------------|-----|----------|---------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
|                   | Electricity            |     | Fuel Oil | Gas     | Total |     |                         |                                   |                                |
| \$                | kW                     | kWh | Gallons  | Therms  | \$    |     | \$                      | Years                             | Years                          |
| 6,800             | 0                      | 0   | 1,190    | (1,220) | 1,000 | 1.9 | 300                     | 6.8                               | 6.5                            |

\* Incentive shown is per the New Jersey Smart Start Program, Gas Heating Application.

### ECM-2 Increase Wall Insulation

| Budgetary<br>Cost | Annual Utility Savings |     |          |        |       | ROI | Potential<br>Incentive* | Payback<br>(without<br>incentive) | Payback<br>(with<br>incentive) |
|-------------------|------------------------|-----|----------|--------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
|                   | Electricity            |     | Fuel Oil | Gas    | Total |     |                         |                                   |                                |
| \$                | kW                     | kWh | Gallons  | Therms | \$    |     | \$                      | Years                             | Years                          |
| 10,100            | 0                      | 0   | 500      | 0      | 1,500 | 1.2 | NA                      | 6.7                               | NA                             |

\*There is currently no incentive from the New Jersey Smart Start Program.

**ECM-3 Night Setback**

| Budgetary<br>Cost | Annual Utility Savings |     |             |        |       | ROI | Potential<br>Incentive* | Payback<br>(without<br>incentive) | Payback<br>(with<br>incentive) |
|-------------------|------------------------|-----|-------------|--------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
|                   | Electricity            |     | Fuel<br>Oil | Gas    | Total |     |                         |                                   |                                |
| \$                | kW                     | kWh | Gallons     | Therms | \$    |     | \$                      | Years                             | Years                          |
| 300               | 0                      | 0   | 130         | 0      | 400   | 4.0 | NA                      | 0.8                               | NA                             |

\*There is currently no incentive from the New Jersey Smart Start Program.

**ECM-4 Install Door Seals**

| Budgetary<br>Cost | Annual Utility Savings |     |             |        |       | ROI  | Potential<br>Incentive* | Payback<br>(without<br>incentive) | Payback<br>(with<br>incentive) |
|-------------------|------------------------|-----|-------------|--------|-------|------|-------------------------|-----------------------------------|--------------------------------|
|                   | Electricity            |     | Fuel<br>Oil | Gas    | Total |      |                         |                                   |                                |
| \$                | kW                     | kWh | Gallons     | Therms | \$    |      | \$                      | Years                             | Years                          |
| 1,200             | 0                      | 680 | 90          | 0      | 200   | 0.76 | NA                      | 6.0                               | NA                             |

\*There is currently no incentive from the New Jersey Smart Start Program.

**ECM-5 Lighting Replacements**

| Budgetary<br>Cost | Annual Utility Savings |       |             |        |       | ROI | Potential<br>Incentive* | Payback<br>(without<br>incentive) | Payback<br>(with<br>incentive) |
|-------------------|------------------------|-------|-------------|--------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
|                   | Electricity            |       | Fuel<br>Oil | Gas    | Total |     |                         |                                   |                                |
| \$                | kW                     | kWh   | Gallons     | Therms | \$    |     | \$                      | Years                             | Years                          |
| 3,700             | 0                      | 4,630 | 0           | 0      | 800   | 2.3 | 400                     | 4.6                               | 4.1                            |

\* Incentive available through the New Jersey Smart Start Program.

## **3.0 EXISTING CONDITIONS**

### **3.1 Building - General**

The DPW building is a single story, 2,290 square foot structure consisting of a two bay garage, lunchroom, tool storage room, and restroom.

The DPW operates from 8:00 AM to 4:00 PM five days a week and is occupied by about three people.

Construction of the building's exterior walls consists of plaster over concrete masonry unit (CMU) block. The interior of the garage bays are unfinished with the CMU; the lunch room has finished walls. There are several windows along the building exterior. The DPW's roof has batt insulation and steel framing and a steel deck.

### **3.2 Utility Usage**

Utilities include electricity and fuel oil. Electricity is purchased from Atlantic City Electric and fuel oil is purchased from Majestic Oil Company. The building does have a well outside and does not pay for water.

From January 2009 through December 2009, electric usage was approximately 19,000 kWh at a cost of about \$3,300. Analyzing electricity bills during this period, the building was charged at an average demand unit cost of \$12 per kW; and a blended unit cost of \$0.17 per kWh. Electricity usage was highest in the summer months when the air conditioning equipment operates. In 2009 the building heat required about 1,840 gallons of oil. Based on the annual cost of about \$3,700, the blended price per gallon was about \$2.04. Fuel oil consumption is highest in the winter months to heat the building. Utility data can be found in Appendix A.

Electricity supply and delivery is presently purchased from Atlantic City Electric. The delivery component will always be the responsibility of the utility that connects the facility to the power grid; however, the supply can be purchased from a third party. The electricity commodity supply entity will require submission of one to three years of past energy bills. Contract terms can vary among suppliers. A list of approved electrical energy commodity suppliers can be found in Appendix A.

### **3.3 HVAC Systems**

#### **3.3.1 Space Heating System**

The building's primary heating system consists of two, Comfort Air Patriot 80 oil fired forced hot air furnaces. Both air handlers are located in the garage bay and hung from the roof and walls. One unit serves the lunchroom and is relatively new; the other unit handles the garage and is older and less efficient.

#### **3.3.2 Air Conditioning Systems**

The only AC system is for the lunchroom and consists of one cooling coil attached to the furnace. The coil is connected to a two ton condensing unit located outside, which is in good condition.

### 3.3.3 Building Ventilation and Exhaust Systems

Primary ventilation is provided by the operable windows throughout the building. The restroom exhaust fan operates with the light switch.

### 3.4 Control Systems

HVAC in this building is controlled by two thermostats, each scheduled for night setback. For both the lunchroom and garage areas, the occupied setpoint for heating is 70°F and the unoccupied is 62°F. The lunchroom cooling occupied setpoint is 72°F and unoccupied is 80°F. The thermostats are not programmed for weekend schedules and the same Monday through Friday schedule operates on Saturday and Sunday.

### 3.5 Lighting/Electrical Systems

The majority of lighting in the building are F34T-12 fixtures that use 80 watts per lamp. These fixtures are either 4 and 8' bulbs and various U tubes. The exit lights are incandescent.

Lighting is controlled by individual switches at the entrances to each space. Lighting remains on during normal business hours, generally, eight to nine hours daily. Some fixtures use incandescent screw-type bulbs that can be easily upgraded. There are several outdoor incandescent lighting fixtures mounted directly to the building.

### 3.6 Plumbing Systems

Domestic hot water is generated by a 6 gallon electric hot water heater with an input of 1,500 watts. This unit, located in the tool room, is in good condition.

There is one restroom and all fixtures are standard high flow type.

## 4.0 ENERGY CONSERVATION MEASURES

### 4.1 ECM-1 Furnace Replacement

Space heating is provided by two, fuel oil fired, Comfort Air Patriot 80 furnaces. This ECM evaluated replacing the furnace which serves the garage with a high efficiency, condensing furnace along with new gas service to the building. The local gas utility, South Jersey Gas, was contacted and stated that new gas service and a gas meter would be provided at no charge. Modern condensing furnaces operate at much higher efficiencies and change fan speeds resulting from part load conditions, enabling the furnace to provide heat more accurately to match the changing building load, which saves energy.

Following review of the fuel oil utility bills, both furnaces combined consume about 1,840 gallons of fuel oil annually and it is estimated the furnace serving the garage area consumes about 65% of that or 1,190 gallons. With estimated average efficiencies of 95%, the proposed new condensing furnace will require approximately 1,880 therms to meet the heat load, resulting in a savings of about \$1,500 per year. The proposed efficiency rating is based on the use of a new Rheem high efficiency 95% natural gas furnace with 60,000 Btuh input. This furnace would be used as a direct replacement for the existing furnace.

In addition to the new condensing furnace, other components of this measure include new direct vent flue system, and new gas piping.

Condensing furnaces have an expected life of 20 years, according to ASHRAE, and total energy savings over the life of the project are estimated at 23,800 gallons fuel oil and (37,600) therms, totaling \$19,400.

The implementation cost and savings related to this ECM are presented in Appendix B and summarized below:

#### ECM-1 Furnace Replacement

| Budgetary<br>Cost | Annual Utility Savings |     |          |         |       | ROI | Potential<br>Incentive* | Payback<br>(without<br>incentive) | Payback<br>(with<br>incentive) |
|-------------------|------------------------|-----|----------|---------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
|                   | Electricity            |     | Fuel Oil | Gas     | Total |     |                         |                                   |                                |
| \$                | kW                     | kWh | Gallons  | Therms  | \$    |     | \$                      | Years                             | Years                          |
| 6,800             | 0                      | 0   | 1,190    | (1,220) | 1,000 | 1.9 | 300                     | 6.8                               | 6.5                            |

\* Incentive shown is per the New Jersey Smart Start Program, Gas Heating Application.

This measure is recommended

### 4.2 ECM-2 Increase Wall Insulation

The interior walls of the garage area are not finished and have exposed CMUs. There is no insulation and this area is heated by one furnace. Significant savings can result from the installation of new rigid board insulation (R-14) attached to the interior walls of the garage.

The difference in heating BTUs between the initial and proposed calculations is taken as the savings. Following implementation of this measure, it is expected the building's annual heating consumption will be reduced by approximately 60,000 KBTU.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

**ECM-2 Increase Wall Insulation**

| Budgetary<br>Cost | Annual Utility Savings |     |             |        |       | ROI | Potential<br>Incentive* | Payback<br>(without<br>incentive) | Payback<br>(with<br>incentive) |
|-------------------|------------------------|-----|-------------|--------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
|                   | Electricity            |     | Fuel<br>Oil | Gas    | Total |     |                         |                                   |                                |
| \$                | kW                     | kWh | Gallons     | Therms | \$    |     | \$                      | Years                             | Years                          |
| 5,600             | 0                      | 0   | 500         | 0      | 900   | 2.2 | NA                      | 6.2                               | NA                             |

\*There is currently no incentive from the New Jersey Smart Start Program.

This measure is recommended.

**4.3 ECM-3 Night Setback**

HVAC system controls are based upon standard programmable thermostats for heating and cooling; some provisions have been made for temperature setback during unoccupied times. By replacing the older thermostats with seven day programmable models, thermostats can be programmed to increase the unoccupied space temperature set back timeframes to save additional heating and cooling energy. This ECM models the expected savings of adjusting the unoccupied temperature setpoints. The setbacks are 62°F heating and 80°F cooling periods. In the calculations for this measure, occupied temperature setpoints were maintained per those in use at the time of the energy audit.

To calculate the benefits of night setback, a block load building model was created to approximate the existing energy load for the building. The block load, provided in Appendix D, models the maximum overall cooling and heating load for the building, taking into account various parameters such as roof, wall, and window construction; total envelope surface area; ventilation and infiltration loads; building occupancy; internal heat generation; and other sources of heat gains and losses. By entering this calculated maximum load into a spreadsheet containing bin temperature data, the total accumulated year-round cooling and heating energy requirements were determined. The heating and cooling loads for the building were then reconciled to building utility data and HVAC equipment energy requirements to confirm the model’s accuracy. The bin temperature spreadsheets are included in Appendix D.

The difference in heating BTUs between the existing and proposed models is taken as the savings. Following implementation of this measure, it is expected the building’s annual fuel oil consumption will be reduced by approximately 420 gallons.

Programmable thermostats have an expected life of 15 years, according to ASHRAE, and total energy savings over the life of the project are estimated at 970 gallons of fuel oil totaling \$1,500.

The implementation cost and savings related to this ECM are presented in Appendix D and summarized as follows:

### ECM-3 Night Setback

| Budgetary<br>Cost | Annual Utility Savings |     |          |        |       | ROI | Potential<br>Incentive* | Payback<br>(without<br>incentive) | Payback<br>(with<br>incentive) |
|-------------------|------------------------|-----|----------|--------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
|                   | Electricity            |     | Fuel Oil | Gas    | Total |     |                         |                                   |                                |
| \$                | kW                     | kWh | Gallons  | Therms | \$    |     | \$                      | Years                             | Years                          |
| 300               | 0                      | 0   | 65       | 0      | 100   | 4.0 | NA                      | 3.0                               | NA                             |

\*There is currently no incentive from the New Jersey Smart Start Program.

This measure is recommended.

### 4.4 ECM-4 Install Door Seals

The main two main overhead doors and entrance door do not seal properly, which causes infiltration of outdoor air into the conditioned areas. Installing new door seals will minimize infiltration and reduce heating and cooling energy consumption.

For this calculation, the block load developed for the existing building conditions in section 4.1 was utilized as a baseline for building energy consumption. Per this model, the existing infiltration around the front entrance doors is about 77 CFM. Assuming the proposed door seals reduce the amount of outdoor air infiltration to about 15 CFM, it is estimated that an annual savings of about 80 gallons of fuel oil can be expected.

Door seals have an expected life of 10 years, according to the manufacturer, and total energy savings over the life of the project are estimated at 800 gallons fuel oil and \$2,000.

The implementation cost and savings related to this ECM are presented in Appendix E and summarized below:

### ECM-4 Install Door Seals

| Budgetary<br>Cost | Annual Utility Savings |     |          |        |       | ROI | Potential<br>Incentive* | Payback<br>(without<br>incentive) | Payback<br>(with<br>incentive) |
|-------------------|------------------------|-----|----------|--------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
|                   | Electricity            |     | Fuel Oil | Gas    | Total |     |                         |                                   |                                |
| \$                | kW                     | kWh | Gallons  | Therms | \$    |     | \$                      | Years                             | Years                          |
| 1,200             | 0                      | 0   | 80       | 0      | 200   | 0.7 | NA                      | 6.0                               | NA                             |

\*There is currently no incentive from the New Jersey Smart Start Program.

This measure is recommended.

### 4.5 ECM-5 Lighting Replacements

A comprehensive fixture survey was conducted of the entire building. Each switch and circuit was identified, and the number of fixtures, locations, and existing wattage established. The majority of the lighting in the facility utilizes T-12 lamps with magnetic ballasts, which are regarded as inefficient by

today's standards. In addition, the existing exit signs utilize older, incandescent technology, which can be upgraded to more efficient lighting technology.

Energy savings for this measure were calculated by applying the existing and proposed fixture wattages to the estimated time of operation. The difference resulted in an annual savings of 4,630 kWh per year. Supporting calculations, including all assumptions for lighting hours and the annual energy usage for each fixture is provided in Appendix F.

Retrofitting fixtures that utilize T-12 lamps would require replacement with electronic ballasts and T-8 lamps. Incandescent lamps would be replaced with compact fluorescent spiral lightbulbs.

Lighting has an expected life of 15 years, according to the manufacturer, and total energy savings over the life of the project are estimated at 69,430 kWh, totaling \$12,000.

The implementation cost and savings related to this ECM are presented in Appendix F and summarized below:

**ECM-5 Lighting Replacements**

| Budgetary<br>Cost | Annual Utility Savings |       |             |        |       | ROI | Potential<br>Incentive* | Payback<br>(without<br>incentive) | Payback<br>(with<br>incentive) |
|-------------------|------------------------|-------|-------------|--------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
|                   | Electricity            |       | Fuel<br>Oil | Gas    | Total |     |                         |                                   |                                |
| \$                | kW                     | kWh   | Gallons     | Therms | \$    |     | \$                      | Years                             | Years                          |
| 3,600             | 0                      | 4,630 | 0           | 0      | 800   | 2.3 | 400                     | 4.5                               | 4.1                            |

\* Incentive available through the New Jersey Smart Start Program.

This measure is recommended.

## 5.0 PROJECT INCENTIVES

### 5.1 Incentives Overview

#### 5.1.1 New Jersey Pay For Performance Program

The building will be eligible for incentives from the New Jersey Office of Clean Energy. The most significant incentives will be from the New Jersey Pay for Performance (P4P) Program. The P4P program is designed for qualified energy conservation projects in facilities whose demand in any of the preceding 12 months exceeds 200 kW. Facilities that meet this criterion must also achieve a minimum performance target of 15% energy reduction by using the EPA Portfolio Manager benchmarking tool before and after implementation of the measure(s). If the participant is a municipal electric company customer, and a customer of a regulated gas New Jersey Utility, only gas measures will be eligible under the Program. American Recovery and Reinvestment Act (ARRA) funding, when available, may allow oil, propane and municipal electric customers to be eligible for the P4P Program. Available incentives are as follows:

**Incentive #1: Energy Reduction Plan** – This incentive is designed to offset the cost of services associated with the development of the Energy Reduction Plan (ERP). The standard incentive pays \$0.10 per square foot, up to a maximum of \$50,000, not to exceed 50% of facility annual energy cost, paid after approval of application. For building audits funded by the New Jersey Board of Public Utilities, which receive an initial 75% incentive toward performance of the energy audit, facilities are only eligible for an additional \$0.05 per square foot, up to a maximum of \$25,000, rather than the standard incentive noted above.

**Incentive #2: Installation of Recommended Measures** – This incentive is based on projected energy saving and designed to pay approximately 60% of the total performance-based incentive. Base incentives deliver \$0.11/kWh and \$1.10/therm not to exceed 30% of total project cost.

**Incentive #3: Post-Construction Benchmarking Report** – This incentive is paid after acceptance of a report proving energy savings over one year utilizing the Environmental Protection Agency (EPA) Portfolio Manager benchmarking tool. Incentive #3 base incentives deliver \$0.07/kWh and \$0.70/therm not to exceed 20% of total project cost.

Combining incentives #2 and #3 will provide a total of \$0.18/ kWh and \$1.8/therm not to exceed 50% of total project cost. Additional incentives for #2 and #3 are increased by \$0.005/kWh and \$0.05/therm for each percentage increase above the 15% minimum target to 20%, calculated with the EPA Portfolio Manager benchmarking tool, not to exceed 50% of total project cost.

A new incentive structure is in place for projects exceeding 20% in energy savings, which doubles incentives #2 and #3 for a total of \$0.36/kWh and \$3.60/therm. For Incentive #1, the maximum incentive has been raised to 80% of project costs, or \$2 million per gas account and \$2 million per electric account. The 200 kW/month average minimum has been waived for buildings owned by local governments or municipalities and non-profit organizations. This new incentive structure has been extended to December 31, 2010.

#### 5.1.2 New Jersey Smart Start Program

For this program, specific incentives for energy conservation measures are calculated on an individual basis utilizing the 2010 New Jersey Smart Start incentive program. This program provides incentives

dependent upon mechanical and electrical equipment. If applicable, incentives from this program are reflected in the ECM summaries and attached appendices.

If the building qualifies and enters into the New Jersey Pay for Performance Program, all energy savings will be included in the total building energy reduction, and savings will be applied towards the Pay for Performance incentive. A project is not applicable for both New Jersey incentive programs.

## **5.2 Building Incentives**

### **5.2.1 New Jersey Pay For Performance Program**

Under incentive #1 of the New Jersey Pay for Performance Program, the 2,290 square foot building is eligible for about \$100 towards the development of an Energy Reduction Plan. When calculating the total amount under Incentives #2 and #3, all energy conservation measures are applicable as the amount received is based on building wide energy improvements. Since the overall energy reduction for the building is not estimated to exceed the 15% minimum, the facility is ineligible for Incentives #2 and #3 as previously discussed. See Appendix G for calculations.

### **5.2.2 New Jersey Smart Start Program**

The Tabernacle DPW Building is eligible for several incentives available under the New Jersey Smart Start Program. The total amount of all qualified incentives is about \$700 and includes installing energy efficient lighting and a new high efficient furnace.

Incentives cannot be accepted under multiple programs.

## 6.0 ALTERNATIVE ENERGY SCREENING EVALUATION

### 6.1 Geothermal

Geothermal heat pumps (GHP) transfer heat between the constant temperature of the earth and the building to maintain the building's interior space conditions. Below the surface of the earth throughout New Jersey the temperature remains in the low 50°F range throughout the year. This stable temperature provides a source for heat in the winter and a means to reject excess heat in the summer. With GHP systems, water is circulated between the building and the piping buried in the ground. The ground heat exchanger in a GHP system is made up of a closed or open loop pipe system. Most common is the closed loop in which high density polyethylene pipe is buried horizontally at 4-6 feet deep or vertically at 100 to 400 feet deep. These pipes are filled with an environmentally friendly antifreeze/water solution that acts as a heat exchanger. In the summer, the water picks up heat from the building and moves it to the ground. In the winter the system reverses and fluid picks up heat from the ground and moves it to the building. Heat pumps make collection and transfer of this heat to and from the building possible.

The building uses oil fired furnaces to meet the HVAC requirements. All of the existing equipment is not compatible with a geothermal energy source. Therefore, to take advantage of a GHP system, the existing mechanical equipment would have to be removed or overhauled; and either a low temperature closed loop water source heat pump system or a water to water heat pump system would have to be installed to realize the benefit of the consistent temperature of the ground.

This measure is not recommended due to the extent of HVAC system renovation needed for implementation.

### 6.2 Solar

#### 6.2.1 Photovoltaic Rooftop Solar Power Generation

The DPW was evaluated for the potential to install rooftop photovoltaic (PV) solar panels for power generation. Present technology incorporates the use of solar cell arrays that produce direct current (DC) electricity. This DC current is converted to alternating current (AC) with the use of an electrical device known as an inverter.

The PVWATTS solar power generation model was utilized to calculate PV power generation. The New Jersey Clean Power Estimator provided by the New Jersey Clean Energy Program is presently being updated; therefore, the site recommended use of the PVWATT solar grid analyzer version 1. The closest city available in the model is Philadelphia, Pennsylvania and a fixed tilt array type was utilized to calculate energy production. The PVWATT solar power generation model is provided in Appendix H.

The State of New Jersey incentives for non-residential PV applications is \$1.00/watt up to 50 kW of installed PV array. Federal tax credits are also available for renewable energy projects up to 30% of installation cost. Municipalities do not pay federal taxes; therefore, would not be able to utilize the federal tax credit incentive.

Installation of (PV) arrays in the state New Jersey will allow the owner to participate in the New Jersey solar renewable energy certificates program (SREC). This is a program that has been set up to allow entities with large amounts of environmentally unfriendly emissions to purchase credits from zero emission (PV) solar-producers. An alternative compliance penalty (ACP) is paid for by the high emission

producers and is set each year on a declining scale of 3% per year. One SREC credit is equivalent to 1000 kilowatt hours of PV electrical production; these credits can be traded for period of 15 years from the date of installation. The approximate cost of the ACP penalty for 2010 is \$700; this is the amount that must be paid per SERC by the high emission producers. The expected dollar amount that will be paid to the PV producer for 2010 is around \$600/SREC credit. Payments that will be received from the PV producer will change from year to year dependent upon supply and demand. Renewable Energy Consultants is a third party SREC broker that has been approved by the New Jersey Clean Energy Program. As stated above there is no definitive way to calculate an exact price that will be received by the PV producer per SREC over the next 15 years. Renewable Energy Consultants estimated an average of \$487/ SERC per year and this number was utilized in the cash flow for this report.

The building had a maximum electricity demand of 12 kW and a minimum of 8 kW, from January 2009 through December 2009. The monthly average over the observed 12 month period was 10 kW. The existing load does not justify the use of the maximum incentive cap of 50 kW of installed PV solar array; therefore, an 8.0 kW system was used for the calculations. The system costs for PV installations were derived from the most recent NYSERDA (New York State Energy Research and Development Agency) estimates of total cost of system installation. It should be noted that the cost of installation for a system of this size is currently estimated at \$7 per watt or \$7,000 per kW of installed system. This has increased in the past few years due to the rise in national demand for PV power generator systems. Other cost considerations will also need to be considered. PV panels have an approximate 20 year life span; however, the inverter device that converts DC electricity to AC has a life span of 10 to 12 years and will need to be replaced multiple times during the useful life of the PV system.

The implementation cost and savings related to this ECM are presented in Appendix H and summarized below:

**Photovoltaic (PV) Rooftop Solar Power Generation – 8 kW System**

| Budgetary<br>Cost | Annual Utility Savings |       |             |       | Total<br>Savings | New<br>Jersey<br>Renewable<br>Energy<br>Incentive* | New<br>Jersey<br>Renewable<br>SREC** | Payback<br>(without<br>incentive) | Payback<br>(with<br>incentives) |
|-------------------|------------------------|-------|-------------|-------|------------------|--|--------------------------------------|-----------------------------------|---------------------------------|
|                   | Electricity            |       | Natural Gas | Total |                  |  |                                      |                                   |                                 |
|                   | kW                     | kWh   | Therms      | \$    |                  |  |                                      |                                   |                                 |
| \$                | 0                      | 9,650 | 0           | 1,600 | 1,600            | 8,000  | 4,700                                | >25                               | 7.6                             |

\*Incentive based on New Jersey Renewable Energy Program for non-residential applications of \$1.00 per Watt of installed capacity

\*\* Estimated Solar Renewable Energy Certificate Program (SREC) for 15 years at \$487/1000 kWh

While the payback period justifies recommendation of the measure, further investigation of possible installation locations, required system maintenance, and local installation costs are suggested prior to implementation.

**6.2.2 Solar Thermal Hot Water Plant**

Active solar thermal systems use solar collectors to gather the sun’s energy to heat water, another fluid, or air. An absorber in the collector converts the sun’s energy into heat. The heat is then transferred by circulating water, antifreeze, or sometimes air to another location for immediate use or storage for later utilization. Applications for active solar thermal energy include providing hot water, heating swimming pools, space heating, and preheating air in residential and commercial buildings.

A standard solar hot water system is typically composed of solar collectors, heat storage vessel, piping, circulators, and controls. Systems are typically integrated to work alongside a conventional heating system that provides heat when solar resources are not sufficient. The solar collectors are usually placed on the roof of the building, oriented south, and tilted around the site's latitude, to maximize the amount of radiation collected on a yearly basis.

Several options exist for using active solar thermal systems for space heating. The most common method involves using glazed collectors to heat a liquid held in a storage tank (similar to an active solar hot water system). The most practical system would transfer the heat from the panels to thermal storage tanks and transfer solar produced thermal energy to use for domestic hot water production. DHW is presently produced by an electric water heater and overall use is very small.

Currently, an incentive is not available for installation of thermal solar systems. A Federal tax credit of 30% of installation cost for the thermal applications is available; however, the Tabernacle Township does not pay Federal taxes and, therefore, would not benefit from this program.

The implementation cost and savings related to this ECM are presented in Appendix I and summarized as follows:

**Solar Thermal Domestic Hot Water Plant**

| Budgetary<br>Cost | Annual Utility Savings |       |             | Total<br>Savings | New Jersey<br>Renewable<br>Energy<br>Incentive | Payback<br>(without<br>incentive) | Payback<br>(with incentive) |
|-------------------|------------------------|-------|-------------|------------------|--|-----------------------------------|-----------------------------|
|                   | Electricity            |       | Natural Gas |                  |  |                                   |                             |
| \$                | kW                     | kWh   | Therms      | \$               | \$   | Years                             | Years                       |
| 27,100            | 0                      | 1,250 | 0           | 200              | 200  | NA                                | >25                         |

\* No incentive is available in New Jersey at this time.

This measure is not recommended.

**6.3 Wind**

Small wind turbines use a horizontal axis propeller, or rotor, to capture the kinetic energy of the wind and convert it into rotary motion to drive a generator which usually is designed specifically for the wind turbine. The rotor consists of two or three blades, usually made from wood or fiberglass. These materials give the turbine the needed strength and flexibility, and have the added advantage of not interfering with television signals. The structural backbone of the wind turbine is the mainframe, and includes the slip-rings that connect the wind turbine, which rotates as it points into changing wind directions, and the fixed tower wiring. The tail aligns the rotor into the wind.

To avoid turbulence and capture greater wind energy, turbines are mounted on towers. Turbines should be mounted at least 30 feet above any structure or natural feature within 300 feet of the installation. Smaller turbines can utilize shorter towers. For example, a 250-watt turbine may be mounted on a 30-50 foot tower, while a 10 kW turbine will usually need a tower of 80-120 feet. Tower designs include tubular or latticed, guyed or self-supporting. Wind turbine manufacturers also provide towers.

The New Jersey Clean Energy Program for small wind installations has designated numerous pre-approved wind turbines for installation in the State of New Jersey. Incentives for wind turbine installations are based on kilowatt hours saved in the first year. Systems sized under 16,000 kWh per year

of production will receive a \$3.20 per kWh incentive. Systems producing over 16,000 kWh will receive \$51,200 for the first 16,000 kWh of production with an additional \$0.50 per kWh up to a maximum cap of 750,000 kWh per year. Federal tax credits are also available for renewable energy projects up to 30% of installation cost for systems less than 100 kW. However, as noted previously, municipalities do not pay federal taxes and is, therefore, not eligible for the tax credit incentive.

The most important part of any small wind generation project is the mean annual wind speed at the height of which the turbine will be installed. In the Tabernacle, NJ area, the map indicates a mean annual wind speed of just under 10 miles per hour. For the municipal building, there are site restrictions. Parking lots, trees and surrounding structures would greatly affect a tower location.

A wind speed map and aerial site photo are included in Appendix J.

This measure is not recommended due to the low mean annual wind speed and site restrictions.

#### **6.4 Combined Heat and Power Generation (CHP)**

Combined heat and power, cogeneration, is self-production of electricity on-site with beneficial recovery of the heat byproduct from the electrical generator. Common CHP equipment includes reciprocating engine-driven, micro turbines, steam turbines, and fuel cells. Typical CHP customers include industrial, commercial, institutional, educational institutions, and multifamily residential facilities. CHP systems that are commercially viable at the present time are sized approximately 50 kW and above, with numerous options in blocks grouped around 300 kW, 800 kW, 1,200 kW and larger. Typically, CHP systems are used to produce a portion of the electricity needed by a facility some or all of the time, with the balance of electric needs satisfied by purchase from the grid.

Any proposed CHP project will need to consider many factors, such as existing system load, use of thermal energy produced, system size, natural gas fuel availability, and proposed plant location. The municipal building does not have sufficient need for electrical generation and the ability to use most of the thermal byproduct during the winter, thermal usage during the summer months is low. Thermal energy produced by the CHP plant in the warmer months will be wasted. Purchasing this system and performing modifications to the existing HVAC and electrical systems would greatly outweigh the savings over the life of the equipment.

This measure is not recommended.

#### **6.5 Biomass Power Generation**

Biomass power generation is a process in which waste organic materials are used to produce electricity or thermal energy. These materials would otherwise be sent to the landfill or expelled to the atmosphere. To participate in NJCEP's Customer On-Site Renewable Energy program, participants must install an on-site sustainable biomass or fuel cell energy generation system. Incentives for bio-power installations are available to support up to 1MW-dc of rated capacity.

\*Class I organic residues are eligible for funding through the NJCEP CORE program. Class I wastes include the following renewable supply of organic material:

- Wood wastes not adulterated with chemicals, glues or adhesives

- Agricultural residues (corn stover, rice hulls or nut shells, manures, poultry litter, horse manure, etc) and/or methane gases from landfills
- Food wastes
- Municipal tree trimming and grass clipping wastes
- Paper and cardboard wastes
- Non adulterated construction wood wastes, pallets

The NJDEP evaluates biomass resources not identified in the RPS.

Examples of eligible facilities for a CORE incentive include:

- Digestion of sewage sludge
- Landfill gas facilities
- Combustion of wood wastes to steam turbine
- Gasification of wood wastes to reciprocating engine
- Gasification or pyrolysis of bio-solid wastes to generation equipment

\* from NJOCE Website

This measure is not recommended because of noise issues, potential zoning issues, and because the DPW building does not have a steady waste stream to fuel the power generation system. Additionally, purchasing this system and performing modifications to the existing HVAC and electrical systems would greatly outweigh the savings over the life of the equipment.

## 6.6 Demand Response Curtailment

Utility Curtailment is an agreement with the electric utility company and an approved Curtailment Service Provider (CSP) to shed electrical load by either turning major equipment off or energizing all or part of a facility utilizing an emergency generator; therefore, reducing the electrical demand on the utility grid. This program is to benefit the utility company during high demand periods and incentives are offered to the CSP to participate in this program. Enrolling in the program will require program participants to drop electrical load or turn on emergency generators during high electrical demand conditions or during emergencies. Part of the program also will require that program participants reduce their required load or run emergency generators with notice to test the system.

A pre-approved CSP will require a minimum of 100 kW of load reduction to participate in any curtailment program. The building had a maximum electricity demand of 12 kW and an average of 10 kW, in 2009.

This measure is not recommended because the facility does not have an adequate load to meet the minimum load reduction requirement.

## 7.0 EPA PORTFOLIO MANAGER

The United State Environmental Protection Agency (EPA) is a federal agency in charge of regulating environment waste and policy in the United States. The EPA has released the EPA Portfolio Manager for public use. The program is designed to allow property owners and managers to share, compare and improve upon their facility's energy consumption. Inputting such parameters as electricity, heating fuel, building characteristics and location into the website based program generates a naturalized energy rating score out of 100. Once an account is registered, monthly utility data can be entered to track the savings progress and retrieve an updated energy rating score on a monthly basis.

The DPW is considered a high energy consumer per the Portfolio Manager with a Site Energy Usage Index (EUI) of 201 kBTU/ft<sup>2</sup>/year; however; after implementing the measures discussed in this report, the building can expect to lower their EUI to 166 kBTU/ft<sup>2</sup>/year. Several factors contribute to the unfavorable EUI, including, wasted energy from poorly insulated walls, unnecessary heating during unoccupied hours, and inefficient lighting operation. The EPA Portfolio Manager did not generate an energy rating score for this building because this type of facility is not eligible.

A full EPA Energy Star Portfolio Manager Report is located in Appendix K.

The user name and password for the municipal building's EPA Portfolio Manager Account has been provided to Douglas Cramer of the Township of Tabernacle.

## 8.0 CONCLUSIONS & RECOMMENDATIONS

The energy audit conducted by CHA at the Department of Public Works, in Tabernacle, New Jersey identified potential ECMs for furnace replacement, insulation upgrade, lighting replacement, night setback, and door seals. Potential annual savings of \$4,400 may be realized for the recommended ECMs, with a summary of the costs, savings, and paybacks as follows:

### ECM-1 Furnace Replacement

| Budgetary<br>Cost | Annual Utility Savings |     |          |         |       | ROI | Potential<br>Incentive* | Payback<br>(without<br>incentive) | Payback<br>(with<br>incentive) |
|-------------------|------------------------|-----|----------|---------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
|                   | Electricity            |     | Fuel Oil | Gas     | Total |     |                         |                                   |                                |
| \$                | kW                     | kWh | Gallons  | Therms  | \$    |     | \$                      | Years                             | Years                          |
| 6,800             | 0                      | 0   | 1,190    | (1,220) | 1,000 | 1.9 | 300                     | 6.8                               | 6.5                            |

\* Incentive shown is per the New Jersey Smart Start Program, Gas Heating Application.

### ECM-2 Increase Wall Insulation

| Budgetary<br>Cost | Annual Utility Savings |     |          |        |       | ROI | Potential<br>Incentive* | Payback<br>(without<br>incentive) | Payback<br>(with<br>incentive) |
|-------------------|------------------------|-----|----------|--------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
|                   | Electricity            |     | Fuel Oil | Gas    | Total |     |                         |                                   |                                |
| \$                | kW                     | kWh | Gallons  | Therms | \$    |     | \$                      | Years                             | Years                          |
| 10,100            | 0                      | 0   | 500      | 0      | 1,500 | 1.2 | NA                      | 6.7                               | NA                             |

\*There is currently no incentive from the New Jersey Smart Start Program.

### ECM-3 Night Setback

| Budgetary<br>Cost | Annual Utility Savings |     |          |        |       | ROI | Potential<br>Incentive* | Payback<br>(without<br>incentive) | Payback<br>(with<br>incentive) |
|-------------------|------------------------|-----|----------|--------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
|                   | Electricity            |     | Fuel Oil | Gas    | Total |     |                         |                                   |                                |
| \$                | kW                     | kWh | Gallons  | Therms | \$    |     | \$                      | Years                             | Years                          |
| 300               | 0                      | 0   | 130      | 0      | 400   | 4.0 | NA                      | 0.8                               | NA                             |

\*There is currently no incentive from the New Jersey Smart Start Program.

### ECM-4 Install Door Seals

| Budgetary<br>Cost | Annual Utility Savings |     |          |        |       | ROI  | Potential<br>Incentive* | Payback<br>(without<br>incentive) | Payback<br>(with<br>incentive) |
|-------------------|------------------------|-----|----------|--------|-------|------|-------------------------|-----------------------------------|--------------------------------|
|                   | Electricity            |     | Fuel Oil | Gas    | Total |      |                         |                                   |                                |
| \$                | kW                     | kWh | Gallons  | Therms | \$    |      | \$                      | Years                             | Years                          |
| 1,200             | 0                      | 680 | 90       | 0      | 200   | 0.76 | NA                      | 6.0                               | NA                             |

\*There is currently no incentive from the New Jersey Smart Start Program.

**ECM-5 Lighting Replacements**

| Budgetary<br>Cost | Annual Utility Savings |       |             |        |       | ROI | Potential<br>Incentive* | Payback<br>(without<br>incentive) | Payback<br>(with<br>incentive) |
|-------------------|------------------------|-------|-------------|--------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
|                   | Electricity            |       | Fuel<br>Oil | Gas    | Total |     |                         |                                   |                                |
| \$                | kW                     | kWh   | Gallons     | Therms | \$    |     | \$                      | Years                             | Years                          |
| 3,700             | 0                      | 4,630 | 0           | 0      | 800   | 2.3 | 400                     | 4.6                               | 4.1                            |

\* Incentive available through the New Jersey Smart Start Program.

## **APPENDIX A**

### **Utility Usage Analysis**




New Jersey BPU Energy Audit Program  
 CHA #21063  
 Tabernacle Township  
 DPW/Garage

Account Number: 0039-6819-9996  
 Atlantic City Electric

Meter #: 60623446

| Date                  | Charges           |             |                   | Unit Costs            |                      |                |
|-----------------------|-------------------|-------------|-------------------|-----------------------|----------------------|----------------|
|                       | Consumption (kWh) | Demand (kW) | Total (\$)        | Blended Rate (\$/kWh) | Consumption (\$/kWh) | Demand (\$/kW) |
| 1/5/09                | 2434              | 12          | \$ 400            | 0.1643                | 0.1643               | -              |
| 2/2/09                | 3954              | 12          | \$ 590            | 0.1492                | 0.1411               | 2.67           |
| 3/4/09                | 2098              | 10          | \$ 333            | 0.1587                | 0.1468               | 2.50           |
| 4/2/09                | 1384              | 7.8         | \$ 225            | 0.1626                | 0.1496               | 2.31           |
| 5/5/09                | 1459              | 8           | \$ 240            | 0.1645                | 0.1515               | 2.38           |
| 6/4/09                | 1289              | 8           | \$ 212            | 0.1645                | 0.1521               | 2.00           |
| 7/6/09                | 1332              | 8           | \$ 266            | 0.1997                | 0.1997               | -              |
| 8/4/09                | 1687              | 9           | \$ 334            | 0.1980                | 0.1980               | -              |
| 9/2/09                | 1981              | 9           | \$ 399            | 0.2014                | 0.1883               | 2.89           |
| 10/2/09               | 1349              | 8           | \$ 266            | 0.1972                | 0.1972               | -              |
| 11/3/09               | 1309              | 7           | \$ 229            | 0.1749                | 0.1620               | 2.43           |
| 12/3/09               | 1344              | 9           | \$ 230            | 0.1711                | 0.1711               | -              |
| <b>Total</b>          | <b>19,186</b>     | <b>12.0</b> | <b>\$3,324.00</b> | <b>0.1733</b>         | <b>0.1653</b>        | <b>1.60</b>    |
| <b>Most Recent Yr</b> | <b>19,186</b>     | <b>12.0</b> | <b>\$3,324.00</b> | <b>0.1733</b>         | <b>0.1653</b>        | <b>1.60</b>    |

# Electric Usage - DPW/Garage




**New Jersey BPU Energy Audit Program**  
**CHA #21063**  
**Tabernacle Township**  
**DPW/Garage**

**Account Number:** 2349  
**Majestic Oil Company**

| Date    | Gallons | Cost       | (\$/Gallon) |
|---------|---------|------------|-------------|
| 1/20/09 | 300     | \$603      | 2.010       |
| 2/6/09  | 354     | \$712      | 2.011       |
| 2/6/09  | 75      | \$150      | 2.000       |
| 2/18/09 | 125     | \$230      | 1.840       |
| 2/18/09 | 29      | \$53       | 1.828       |
| 3/10/09 | 349     | \$594      | 1.702       |
| 5/7/09  | 145     | \$260      | 1.793       |
| 12/8/09 | 460     | \$1,141.00 | 2.480       |

|                |       |            |       |
|----------------|-------|------------|-------|
| Total          | 1,837 | \$3,743.00 | 2.038 |
| Most Recent Yr | 1,837 | \$3,743.00 | 2.038 |

# Oil Purchased - DPW/Garage



## ELECTRIC MARKETERS LIST

The following is a listing of marketers/suppliers/brokers that have been licensed by the NJ Board of Public Utilities to sell electricity to residential, small commercial and industrial customers served by the Public Service Electric and Gas Company distribution system. **This listing is provided for informational purposes only and PSE&G makes no representations or warranties as to the competencies of the entities listed herein or to the completeness of this listing.**

American Powernet Management  
867 Berkshire Blvd, Suite 101  
Wyomissing, PA 19610  
[www.americanpowernet.com](http://www.americanpowernet.com)

Gerda Ameristeel Energy Co.  
North Crossman Road  
Sayreville, NJ 08872

PPL EnergyPlus, LLC  
Energy Marketing Center  
Two North Ninth Street  
Allentown, PA 18101  
1-866-505-8825  
<http://www.pplenergyplus.com/>

BOC Energy Services  
575 Mountain Avenue  
Murray Hill, NJ 07974  
[www.boc-gases.com](http://www.boc-gases.com)

Gexa Energy LLC New Jersey  
20 Greenway Plaza, Suite 600  
Houston, TX 77046  
(866) 304-GEXA  
[Beth.miller@gexaenergy.com](mailto:Beth.miller@gexaenergy.com)

Sempra Energy Solutions  
The Mac-Cali Building  
581 Main Street, 8<sup>th</sup> Floor  
Woodbridge, NJ 07095  
(877) 273-6772  
[www.SempraSolutions.com](http://www.SempraSolutions.com)

Commerce Energy Inc.  
535 Route 38, Suite 138  
Cherry Hill, NJ 08002  
(888) 817-8572 or  
(858) 910-8099  
[www.commerceenergy.com](http://www.commerceenergy.com)

Glacial Energy of New Jersey  
2602 McKinney Avenue, Suite 220  
Dallas, TX 75204  
[www.glacialenergy.com](http://www.glacialenergy.com)

South Jersey Energy Company  
1 South Jersey Plaza, Route 54  
Folsom, NJ 08037  
(800) 756-3749  
[www.sjindustries.com](http://www.sjindustries.com)

ConEdison Solutions  
701 Westchester Avenue  
Suite 201 West  
White Plains, NY 10604  
(800) 316-8011  
[www.ConEdSolutions.com](http://www.ConEdSolutions.com)

Hess Corporation  
1 Hess Plaza  
Woodbridge, NJ 07095  
[www.hess.com](http://www.hess.com)

Strategic Energy, LLC  
6 East Main Street, Suite 6E  
Ramsey, NJ 07446  
(888) 925-9115  
[www.sel.com](http://www.sel.com)

Constellation NewEnergy, Inc.  
1199 Route 22 East  
Mountainside, NJ 07092  
908 228-5100  
[www.newenergy.com](http://www.newenergy.com)

Integrus Energy Services, Inc  
99 Wood Avenue, Suite 802  
Iselin, NJ 08830  
[www.integrusenergy.com](http://www.integrusenergy.com)

Suez Energy Resources NA  
333 Thornall Street FL6  
Edison, NJ 08818  
866.999.8374(toll free)  
[www.suezenergyresources.com](http://www.suezenergyresources.com)

Credit Suisse (USA), Inc.  
700 College Road East  
Princeton, NJ 08450  
[www.creditsuisse.com](http://www.creditsuisse.com)

Liberty Power Delaware, LLC  
1901 W Cypress Road, Suite 600  
Fort Lauderdale, FL 33309  
(866) Power-99  
(866) 769-3799  
[www.libertypowercorp.com](http://www.libertypowercorp.com)

UGI Energy Services, Inc.  
d/b/a POWERMARK  
1 Meridian Blvd. Suite 2C01  
Wyomissing, PA 19610  
(800) 427-8545  
[www.ugienergyservices.com](http://www.ugienergyservices.com)

Direct Energy Services, LLC  
One Gateway Center, Suite 2600  
Newark, NJ 07102  
(973) 799-8568  
[www.directenergy.com](http://www.directenergy.com)

Liberty Power Holdings, LLC  
1901 W Cypress Creek Road, Suite 600  
Fort Lauderdale, FL 33309  
(866) Power-99  
(866) 769-3799  
[www.libertypowercorp.com](http://www.libertypowercorp.com)

FirstEnergy Solutions  
395 Ghent Road Suite 407  
Akron, OH 44333  
(800) 977-0500  
[www.fes.com](http://www.fes.com)

Pepco Energy Services, Inc.  
d/b/a Power Choice  
23 S. Kinderkamack Rd Ste D  
Montvale, NJ 07645  
(800) 363-7499  
[www.pepco-services.com](http://www.pepco-services.com)

## **APPENDIX B**

### **ECM-1 Furnace Replacement**



Tabernacle Township  
 CHA #21063  
 Building: Department of Public Works Garage

ECM-1 Furnace Replacement

|          |   |
|----------|---|
| #2 Oil   | ▼ |
| Nat. Gas | ▼ |

Existing Fuel  
 Proposed Fuel

| Item                        | Value         | Units      | Formula/Comments  |
|-----------------------------|---------------|------------|---|
| Baseline Fuel Cost          | \$2.04        |            |   |
| Proposed Fuel Cost          | \$1.20        |            |   |
| Baseline Fuel Use           | 1,194         | Gals #2    | Oil usage for Garage area only                                |
| Existing Furnace Efficiency | 70%           |            | Estimated or Measured   |
| Baseline Load               | 115,930       | Mbtu/yr    | Baseline Fuel Use x Existing Efficiency x 138.7 Mbtu/Gals #2  |
| Baseline Fuel Cost          | \$ 2,433      |            |   |
| Proposed Efficiency         | 95%           |            | New Furnace Efficiency  |
| Proposed Fuel Use           | 1,220         | Therms     | Baseline Furnace Load / Proposed Efficiency / 100 Mbtu/Therms |
| Proposed Fuel Cost          | \$ 1,464      |            |   |
| Annual Savings              | 1,194         | Gals #2    |   |
|                             | (1,220)       | Therms     |   |
| <b>Annual Savings</b>       | <b>\$ 969</b> | <b>/yr</b> |   |



## **APPENDIX C**

### **ECM-2 Increase Wall Insulation**





Tabernacle  
 CHA #21063  
 Building: Department of Public Works Garage  
 ECM-2 Increase Wall Insulation

| Multipliers |      |
|-------------|------|
| Material:   | 0.98 |
| Labor:      | 1.21 |
| Equipment:  | 1.09 |

| Description  | QTY  | UNIT(Sqft) | UNIT COSTS |         |        | SUBTOTAL COSTS |          |        | TOTAL COST | REMARKS |
|--|------|------------|------------|---------|--------|----------------|----------|--------|------------|---------|
|  |      |            | MAT.       | LABOR   | EQUIP. | MAT.           | LABOR    | EQUIP. |            |         |
| New Insulation for Garage Walls                        | 1900 | sf         | \$ 1.47    | \$ 0.44 |        | \$ 2,745       | \$ 1,012 | \$ -   | \$ 3,756   |         |
| Removal and re installation of equipment and work area | 24   |            |            | \$ 30   |        | \$ -           | \$ 871   | \$ -   | \$ 871     |         |
|  |      |            |            |         |        | \$ -           | \$ -     | \$ -   | \$ -       |         |
|  |      |            |            |         |        | \$ -           | \$ -     | \$ -   | \$ -       |         |
|  |      |            |            |         |        | \$ -           | \$ -     | \$ -   | \$ -       |         |
|  |      |            |            |         |        | \$ -           | \$ -     | \$ -   | \$ -       |         |
|  |      |            |            |         |        | \$ -           | \$ -     | \$ -   | \$ -       |         |
|  |      |            |            |         |        | \$ -           | \$ -     | \$ -   | \$ -       |         |
|  |      |            |            |         |        | \$ -           | \$ -     | \$ -   | \$ -       |         |
|  |      |            |            |         |        | \$ -           | \$ -     | \$ -   | \$ -       |         |
|  |      |            |            |         |        | \$ -           | \$ -     | \$ -   | \$ -       |         |
|  |      |            |            |         |        | \$ -           | \$ -     | \$ -   | \$ -       |         |
|  |      |            |            |         |        | \$ -           | \$ -     | \$ -   | \$ -       |         |

|          |                    |
|----------|--------------------|
| \$ 4,627 | Subtotal           |
| \$ 463   | 10% Contingency    |
| \$ 509   | 10% Contractor O&P |
| \$ -     | 0% Engineering     |
| \$ 5,599 | Total              |

**APPENDIX D**

**ECM-3 Night Setback**



**Tabernacle Township**  
**CHA #21063**  
**Building: Department of Public Works Garage**

**ECM-3 Night Setback**

|                              |       |        |
|------------------------------|-------|--------|
| Building Footprint           | 2,288 | SF     |
| Heating Efficiency           | 75%   |        |
| Cooling Efficiency           | 1.3   | kW/ton |
| Building Balance Temp.       | 60    | *F     |
| Internal Gains               | 9,447 | btu/h  |
| Unoc Internal Gain factor    | 0.03  |        |
| Ave Occ Internal Gain Factor | 0.7   |        |

|                                 |           |
|---------------------------------|-----------|
| Ex Occupied CIng Temp.          | *F        |
| Ex Unoccupied CIng Temp.        | *F        |
| Prop Occupied CIng Temp.        | *F        |
| Prop Unoccupied CIng Temp.      | *F        |
| Occupied Cooling UA             | btu/hr/°F |
| Unoccupied Cooling UA           | btu/hr/°F |
| Cooling Occ Enthalpy Setpoint   |           |
| Cooling Unocc Enthalpy Setpoint |           |

Heating Energy Savings  
Cooling Energy Savings

|            |
|------------|
| 65 Gallons |
| 90 therms  |
| 0 kWh      |

Heating and cooling energy are unrelated in this model. If the building being analyzed is not cooled, disregard cooling energy calculations

| Avg Outdoor Air Temp. Bins °F | Avg Outdoor Air Enthalpy | PROPOSED LOADS           |              |                             |     |                               |         |                             |        |                               |         |          |              |              |              | Existing Cooling Energy kWh | Proposed Cooling Energy kWh | Existing Heating Energy therms | Proposed Heating Energy therms |   |   |
|-------------------------------|--------------------------|--------------------------|--------------|-----------------------------|-----|-------------------------------|---------|-----------------------------|--------|-------------------------------|---------|----------|--------------|--------------|--------------|-----------------------------|-----------------------------|--------------------------------|--------------------------------|---|---|
|                               |                          | Existing Total Bin Hours |              | Existing Occupied Bin Hours |     | Existing Unoccupied Bin Hours |         | Proposed Occupied Bin Hours |        | Proposed Unoccupied Bin Hours |         | Occupied |              |              | Unoccupied   |                             |                             |                                |                                |   |   |
|                               |                          | B                        | C            | D                           | E   | F                             | G       | H                           | I      | J                             | K       | L        | M            | N            | O            |                             |                             |                                |                                | P | K |
| 102.5                         | 49.1                     | 0                        | 0            | 0                           | 0   | 0                             | -90,705 | -54,899                     | -6,613 | -61,064                       | -54,899 | -283     | 0            | 0            | 0            | 0                           | 0                           | 0                              | 0                              |   |   |
| 97.5                          | 42.5                     | 3                        | 1            | 2                           | 1   | 2                             | -75,836 | -38,124                     | -6,613 | -47,494                       | -38,124 | -283     | 36           | 33           | 0            | 0                           | 0                           | 0                              | 0                              |   |   |
| 92.5                          | 39.5                     | 34                       | 14           | 20                          | 10  | 24                            | -60,966 | -30,499                     | -6,613 | -33,925                       | -30,499 | -283     | 325          | 290          | 0            | 0                           | 0                           | 0                              | 0                              |   |   |
| 87.5                          | 36.6                     | 131                      | 55           | 76                          | 39  | 92                            | -46,096 | -23,129                     | -6,613 | -20,355                       | -23,129 | -283     | 946          | 811          | 0            | 0                           | 0                           | 0                              | 0                              |   |   |
| 82.5                          | 34                       | 500                      | 208          | 292                         | 149 | 351                           | -31,226 | -16,520                     | -6,613 | -6,785                        | -16,520 | -283     | 2,487        | 1,972        | 0            | 0                           | 0                           | 0                              | 0                              |   |   |
| 77.5                          | 31.6                     | 620                      | 258          | 362                         | 185 | 435                           | -16,357 | -10,421                     | -6,613 | 0                             | 0       | -283     | 1,726        | 946          | 0            | 0                           | 0                           | 0                              | 0                              |   |   |
| 72.5                          | 29.2                     | 664                      | 277          | 387                         | 198 | 466                           | -1,487  | -4,321                      | -6,613 | 0                             | 0       | -283     | 384          | 384          | 0            | 0                           | 0                           | 0                              | 0                              |   |   |
| 67.5                          | 27                       | 854                      | 356          | 498                         | 254 | 600                           | 3,491   | 1,525                       | -6,613 | 0                             | 0       | -283     | 77           | 77           | 0            | 0                           | 0                           | 0                              | 0                              |   |   |
| 62.5                          | 24.5                     | 927                      | 386          | 541                         | 276 | 651                           | 10,472  | 4,575                       | -6,613 | 0                             | 0       | -283     | 0            | 0            | 41           | 29                          | 0                           | 0                              | 0                              |   |   |
| 57.5                          | 21.4                     | 600                      | 250          | 350                         | 179 | 421                           | 17,453  | 7,625                       | -6,613 | 6,283                         | 2,745   | -283     | 0            | 0            | 102          | 93                          | 0                           | 0                              | 0                              |   |   |
| 52.5                          | 18.7                     | 610                      | 254          | 356                         | 182 | 428                           | 24,435  | 10,675                      | -6,613 | 13,264                        | 5,795   | -283     | 0            | 0            | 186          | 176                         | 0                           | 0                              | 0                              |   |   |
| 47.5                          | 16.2                     | 611                      | 255          | 356                         | 182 | 429                           | 31,416  | 13,725                      | -6,613 | 20,246                        | 8,845   | -283     | 0            | 0            | 268          | 258                         | 0                           | 0                              | 0                              |   |   |
| 42.5                          | 14.4                     | 656                      | 273          | 383                         | 195 | 461                           | 38,397  | 16,775                      | -6,613 | 27,227                        | 11,895  | -283     | 0            | 0            | 375          | 365                         | 0                           | 0                              | 0                              |   |   |
| 37.5                          | 12.6                     | 1,023                    | 426          | 597                         | 304 | 719                           | 45,378  | 19,824                      | -6,613 | 34,208                        | 14,945  | -283     | 0            | 0            | 722          | 706                         | 0                           | 0                              | 0                              |   |   |
| 32.5                          | 10.7                     | 734                      | 306          | 428                         | 218 | 516                           | 52,360  | 22,874                      | -6,613 | 41,190                        | 17,995  | -283     | 0            | 0            | 616          | 605                         | 0                           | 0                              | 0                              |   |   |
| 27.5                          | 8.6                      | 334                      | 139          | 195                         | 99  | 235                           | 59,341  | 25,924                      | -6,613 | 48,171                        | 21,044  | -283     | 0            | 0            | 325          | 320                         | 0                           | 0                              | 0                              |   |   |
| 22.5                          | 6.8                      | 252                      | 105          | 147                         | 75  | 177                           | 66,322  | 28,974                      | -6,613 | 55,152                        | 24,094  | -283     | 0            | 0            | 279          | 275                         | 0                           | 0                              | 0                              |   |   |
| 17.5                          | 5.5                      | 125                      | 52           | 73                          | 37  | 88                            | 73,304  | 32,024                      | -6,613 | 62,133                        | 27,144  | -283     | 0            | 0            | 155          | 153                         | 0                           | 0                              | 0                              |   |   |
| 12.5                          | 4.1                      | 47                       | 20           | 27                          | 14  | 33                            | 80,285  | 35,074                      | -6,613 | 69,115                        | 30,194  | -283     | 0            | 0            | 65           | 64                          | 0                           | 0                              | 0                              |   |   |
| 7.5                           | 2.6                      | 22                       | 9            | 13                          | 7   | 15                            | 87,266  | 38,124                      | -6,613 | 76,096                        | 33,244  | -283     | 0            | 0            | 33           | 33                          | 0                           | 0                              | 0                              |   |   |
| 2.5                           | 1                        | 13                       | 5            | 8                           | 4   | 9                             | 94,247  | 41,174                      | -6,613 | 83,077                        | 36,294  | -283     | 0            | 0            | 21           | 21                          | 0                           | 0                              | 0                              |   |   |
| -2.5                          | 0                        | 0                        | 0            | 0                           | 0   | 0                             | 101,229 | 44,224                      | -6,613 | 90,059                        | 39,344  | -283     | 0            | 0            | 0            | 0                           | 0                           | 0                              | 0                              | 0 |   |
| -7.5                          | -1.5                     | 0                        | 0            | 0                           | 0   | 0                             | 108,210 | 47,274                      | -6,613 | 97,040                        | 42,394  | -283     | 0            | 0            | 0            | 0                           | 0                           | 0                              | 0                              | 0 |   |
| <b>TOTALS</b>                 |                          | <b>8,760</b>             | <b>3,650</b> | <b>5,110</b>                |     |                               |         |                             |        |                               |         |          | <b>5,980</b> | <b>4,512</b> | <b>3,188</b> | <b>3,098</b>                |                             |                                |                                |   |   |

|  |      |
|--|------|
| Existing Building Ventilation & Infiltration (occ)   | 565  |
| Overheat Ventilation Factor                          | 1.00 |
| Additional ventilation to offset overheat            | 0    |
| Existing Building Ventilation & Infiltration (unocc) | 565  |

**Tabernacle Township**  
**CHA #21063**  
**Building: Department of Public Works Garage**

**Reconcile Thermal Model**

|                              |             |                                 |                  |                         |                |
|------------------------------|-------------|---------------------------------|------------------|-------------------------|----------------|
| Building Footprint           | 2,289 SF    | Ex Occupied Cing Temp.          | 72 °F            | Ex Occupied Htg Temp.   | 70 °F          |
| Heating Efficiency           | 75%         | Ex Unoccupied Cing Temp.        | 80 °F            | Ex Unoccupied Htg Temp. | 62 °F          |
| Cooling Efficiency           | 1.30 kW/ton | Occupied Cooling UA             | (2,974) btu/hr°F | Occupied Heating UA     | 1,396 btu/hr°F |
| Internal Gains               | 9.447 btuh  | Unoccupied Cooling UA           | (2,714) btu/hr°F | Unoccupied Heating UA   | 1,396 btu/hr°F |
| Unoc Internal Gain factor    | 0.03        | Cooling Occ Enthalpy Setpoint   | 27.5 Btu/lb      |                         |                |
| Ave Occ Internal Gain Factor | 0.7         | Cooling Unocc Enthalpy Setpoint | 27.5 Btu/lb      |                         |                |
| Economizer available (Y/N)   | No          |                                 |                  |                         |                |

Heating and cooling energy are unrelated in this model. If the building being analyzed is not cooled, disregard cooling energy calculations

| Avg Outdoor Air Temp. Bins °F | A    | EXISTING LOADS  |                              |                                |                    |                       |                    |                               |                       |                    |                               | Existing Heating Energy therm | M            |                              |                             |                                  |                       |
|-------------------------------|------|-----------------|------------------------------|--------------------------------|--------------------|-----------------------|--------------------|-------------------------------|-----------------------|--------------------|-------------------------------|-------------------------------|--------------|------------------------------|-----------------------------|----------------------------------|-----------------------|
|                               |      | Occupied        |                              |                                |                    |                       | Unoccupied         |                               |                       |                    |                               |                               |              | Necessary Cooling Energy kWh | Existing Cooling Energy kWh | Available Economizer Cooling kWh |                       |
|                               |      | Total Bin Hours | Occupied Equipment Bin Hours | Unoccupied Equipment Bin Hours | Envelope Load BTUH | Ventilation Load BTUH | Internal Gain BTUH | Unoccupied Envelope Load BTUH | Ventilation Load BTUH | Internal Gain BTUH | Unoccupied Envelope Load BTUH |                               |              |                              |                             |                                  | Ventilation Load BTUH |
| B                             | C    | D               | E                            | F                              | G                  | H                     | I                  | J                             | K                     | L                  | M                             |                               |              |                              |                             |                                  |                       |
| 102.5                         | 49.1 | 0               | 0                            | 0                              | -90,705            | -98,639               | -6,613             | -61,064                       | -54,899               | -283               | 0                             | 0                             | 0            | 0                            | 0                           | 0                                | 0                     |
| 97.5                          | 42.5 | 3               | 1                            | 2                              | -75,836            | -88,499               | -6,613             | -47,494                       | -38,124               | -283               | 0                             | 0                             | 0            | 0                            | 0                           | 0                                | 0                     |
| 92.5                          | 34   | 34              | 8                            | 26                             | -60,966            | -75,836               | -6,613             | -33,925                       | -30,499               | -283               | 0                             | 0                             | 0            | 0                            | 0                           | 0                                | 0                     |
| 87.5                          | 36.6 | 131             | 31                           | 100                            | -46,096            | -54,799               | -6,613             | -20,355                       | -23,129               | -283               | 0                             | 0                             | 0            | 0                            | 0                           | 0                                | 0                     |
| 82.5                          | 34.0 | 500             | 148                          | 352                            | -31,226            | -29,683               | -6,613             | -6,785                        | -16,520               | -283               | 0                             | 0                             | 0            | 0                            | 0                           | 0                                | 0                     |
| 77.5                          | 31.6 | 620             | 158                          | 462                            | -16,357            | -18,723               | -6,613             | 0                             | 0                     | -283               | 0                             | 0                             | 0            | 0                            | 0                           | 0                                | 0                     |
| 72.5                          | 29.2 | 664             | 203                          | 461                            | -1,487             | -7,763                | -6,613             | 0                             | 0                     | -283               | 0                             | 0                             | 0            | 0                            | 0                           | 0                                | 0                     |
| 67.5                          | 27.0 | 854             | 221                          | 633                            | 3,491              | 2,740                 | -6,613             | 0                             | 0                     | -283               | 0                             | 0                             | 0            | 0                            | 0                           | 0                                | 0                     |
| 62.5                          | 24.5 | 927             | 143                          | 784                            | 10,472             | 8,220                 | -6,613             | 0                             | 0                     | -283               | 0                             | 0                             | 0            | 0                            | 0                           | 0                                | 0                     |
| 57.5                          | 21.4 | 600             | 145                          | 455                            | 17,453             | 13,700                | -6,613             | 6,283                         | 2,745                 | -283               | 0                             | 0                             | 0            | 0                            | 0                           | 0                                | 0                     |
| 52.5                          | 18.7 | 610             | 145                          | 465                            | 24,435             | 19,180                | -6,613             | 13,264                        | 5,795                 | -283               | 0                             | 0                             | 0            | 0                            | 0                           | 0                                | 0                     |
| 47.5                          | 16.2 | 511             | 156                          | 435                            | 31,416             | 24,660                | -6,613             | 20,246                        | 8,845                 | -283               | 0                             | 0                             | 0            | 0                            | 0                           | 0                                | 0                     |
| 42.5                          | 14.4 | 556             | 244                          | 412                            | 38,397             | 30,140                | -6,613             | 27,227                        | 11,895                | -283               | 0                             | 0                             | 0            | 0                            | 0                           | 0                                | 0                     |
| 37.5                          | 12.6 | 1,023           | 175                          | 848                            | 45,378             | 35,619                | -6,613             | 34,208                        | 14,945                | -283               | 0                             | 0                             | 0            | 0                            | 0                           | 0                                | 0                     |
| 32.5                          | 10.7 | 734             | 80                           | 654                            | 52,360             | 41,099                | -6,613             | 41,190                        | 17,995                | -283               | 0                             | 0                             | 0            | 0                            | 0                           | 0                                | 0                     |
| 27.5                          | 8.6  | 334             | 60                           | 274                            | 59,341             | 46,579                | -6,613             | 48,171                        | 21,044                | -283               | 0                             | 0                             | 0            | 0                            | 0                           | 0                                | 0                     |
| 22.5                          | 6.8  | 252             | 30                           | 222                            | 66,322             | 52,059                | -6,613             | 55,152                        | 24,094                | -283               | 0                             | 0                             | 0            | 0                            | 0                           | 0                                | 0                     |
| 17.5                          | 5.5  | 125             | 11                           | 114                            | 73,304             | 57,539                | -6,613             | 62,133                        | 27,144                | -283               | 0                             | 0                             | 0            | 0                            | 0                           | 0                                | 0                     |
| 12.5                          | 4.1  | 47              | 5                            | 42                             | 80,285             | 63,019                | -6,613             | 69,115                        | 30,194                | -283               | 0                             | 0                             | 0            | 0                            | 0                           | 0                                | 0                     |
| 7.5                           | 2.6  | 22              | 3                            | 19                             | 87,266             | 68,499                | -6,613             | 76,096                        | 33,244                | -283               | 0                             | 0                             | 0            | 0                            | 0                           | 0                                | 0                     |
| 2.5                           | 1.0  | 13              | 0                            | 13                             | 94,247             | 73,979                | -6,613             | 83,077                        | 36,294                | -283               | 0                             | 0                             | 0            | 0                            | 0                           | 0                                | 0                     |
| 0.0                           | 0.0  | 0               | 0                            | 0                              | 101,229            | 79,459                | -6,613             | 90,059                        | 39,344                | -283               | 0                             | 0                             | 0            | 0                            | 0                           | 0                                | 0                     |
| -7.5                          | -1.5 | 0               | 0                            | 0                              | 108,210            | 84,939                | -6,613             | 97,040                        | 42,394                | -283               | 0                             | 0                             | 0            | 0                            | 0                           | 0                                | 0                     |
| <b>TOTALS</b>                 |      | <b>8,760</b>    | <b>1,967</b>                 | <b>6,793</b>                   |                    |                       |                    |                               |                       |                    |                               |                               | <b>4,214</b> |                              |                             | <b>4,214</b>                     | <b>3,215</b>          |

|  |         |
|--|---------|
| Existing Building Ventilation & Infiltration (occ)   | 565 cfm |
| Overheat Ventilation Factor                          | 1.00    |
| Additional ventilation to offset overheat            | 450 cfm |
| Existing Building Ventilation & Infiltration (unocc) | 565 cfm |
| Economizer Ventilation (from AHU's)                  | 0 cfm   |

Energy Use Indices (calculated)

|           |           |        |
|-----------|-----------|--------|
| Heating   | Base Case | 3,215  |
| Target -> | 2,548     |        |
|           |           | 126.2% |

|           |           |         |
|-----------|-----------|---------|
| Cooling   | Base Case | 4,214   |
| Target -> | 300       |         |
|           |           | 1404.8% |

## HEAT GAIN/LOSS WORKSHEET

Project Name:   
 Location:   
 Building Name:   
 Engineer:

Project No.:   
 Site Elevation:  Feet  
 Date:

Specific Volume:  CF/#

Building/Facility Designation:

|                                      |  |                                     |  |
|--------------------------------------|--|-------------------------------------|--|
| Outdoor Winter Design DB Temperature | <input type="text" value="14"/> *F     | Indoor Winter Design DB Temperature | <input type="text" value="70"/> *F     |
| Outdoor Summer Design DB Temperature | <input type="text" value="91"/> *F     | Indoor Summer Design DB Temperature | <input type="text" value="72"/> *F     |
| Outdoor Summer Design WB Temperature | <input type="text" value="73"/> *F     | Indoor Summer Design WB Temperature | <input type="text" value="60"/> *F     |
| Outdoor Summer Humidity Ratio        | <input type="text" value="0.0121"/> ## | Indoor Air (70°F) Humidity Ratio    | <input type="text" value="0.0079"/> ## |

**ENVELOPE DESCRIPTIONS (Descriptions are from Interior to Exterior)**

| Walls (Select One - Type X)  | R Value | Wall Type |
|--|---------|-----------|
| <input type="checkbox"/> Steel Siding, 4" Insulation, Steel Siding   | 15.2    | 1         |
| <input type="checkbox"/> Plaster or Gypsum, frame construction, 5" Insulation, 1" stucco                         | 18.2    | 1         |
| <input type="checkbox"/> 4" WH CMU, 1" Insulation, Finished Exterior   | 5.2     | 2         |
| <input type="checkbox"/> Plaster or Gypsum, frame construction, 3" Insulation, 8" LW CMU                         | 7.8     | 5         |
| <input type="checkbox"/> 4" Face Brick, 2" Concrete, 1" Insulation, Exterior Finish                              | 5.1     | 12        |
| <input type="checkbox"/> 4" Face Brick, 4" Concrete, 1" Insulation, Exterior Finish                              | 4.0     | 11        |
| <input type="checkbox"/> Interior Finish, 2" Insulation, 8" CMU, 4" Face Brick                                   | 10.9    | 16        |
| <input type="checkbox"/> Finished Surface, 8" LW CMU (filled), Air Space, 4" Face Brick                          | 11.1    | 16        |
| <input type="checkbox"/> Stucco or Gypsum, 2.5" Insul, Face Brick  | 14.3    | 10        |
| <input type="checkbox"/> 4" Block, 1" insulation, 8" Block   | 19.9    | 16        |
| <input checked="" type="checkbox"/> 12" CMU unfinished interior, painted outside/finished walls inside lunchroom | 2.5     |           |

| Roofs (Select One)  | R Value | Roof Type |
|---|---------|-----------|
| <input type="checkbox"/> Tectum Deck, 3.3" Insul., BU Roof                  | 13.0    | 1         |
| <input type="checkbox"/> Steel Deck, 5" Insul., BU Roof                     | 18.2    | 1         |
| <input type="checkbox"/> Attic Roof with 6" Insul.                          | 25.0    | 4         |
| <input type="checkbox"/> 4" HW Concrete Deck, BU Roof                       | 2.7     | 2         |
| <input type="checkbox"/> Ceiling, 3" Insulation, 4" Concrete Deck, BU Roof  | 14.9    | 4         |
| <input type="checkbox"/> Ceiling, 4" Concrete Deck, 3" Insulation, BU Roof  | 18.5    | 13        |
| <input type="checkbox"/> Ceiling, 4" Concrete Deck, 6" Insulation, BU Roof  | 21.7    | 14        |
| <input type="checkbox"/> Ceiling, Wood Deck, 6" Insulation, Felt & Membrane | 22.7    | 10        |
| <input type="checkbox"/> Wood Deck, 6" insulation, Felt & Membrane          | 18.0    |           |
| <input checked="" type="checkbox"/> 6" Insulation, unfinished, metal roof   | 8.00    |           |

| Windows (Select One)  | U Value |
|---|---------|
| <input type="checkbox"/> Aluminum Frame, 1/8" SP Glazing        | 1.05    |
| <input type="checkbox"/> Aluminum Frame, 1/4" DP Glazing        | 0.60    |
| <input type="checkbox"/> Aluminum Frame, 3/16" DP Glazing       | 0.62    |
| <input type="checkbox"/> Aluminum Frame, 1/2" DP Glazing        | 0.50    |
| <input type="checkbox"/> Skylights                              | 0.90    |
| <input checked="" type="checkbox"/> Single pane, Aluminum frame | 1.10    |

|                            | No Storm |
|----------------------------|----------|
| Flat Glass                 | 1.05     |
| Flat Glass (e=.6)          | 1.00     |
| Flat Glass (e=0.4)         | 0.90     |
| Flat Glass (e=0.2)         | 0.77     |
| Double Glaze (3/16 in air) | 0.63     |
| Double Glaze (1/4 in air)  | 0.60     |
| Double Glaze (1/2 in air)  | 0.53     |
| Double Glaze (e=.6)        | 0.50     |
| Double Glaze (e=0.4)       | 0.42     |
| Double Glaze (e=0.2)       | 0.35     |
| Triple Glaze (1/4 in air)  | 0.42     |
| Triple Glaze (1/2 in air)  | 0.35     |

**BUILDING CHARACTERISTICS**

Roof Area:  SF  
 Occupied Area:  SF

Return Plenum?

|                | Gross Wall Length | Average Wall Height | Ceiling Height | Window Area | Door Area | Net Wall Area |
|----------------|-------------------|---------------------|----------------|-------------|-----------|---------------|
| North Exposure | 44 Ft             | 15.0 Ft             | 15.0 Ft        | 40 SF       | 468 SF    | 152 SF        |
| East Exposure  | 52 Ft             | 15.0 Ft             | 15.0 Ft        | 0 SF        | 15 SF     | 765 SF        |
| South Exposure | 44 Ft             | 15.0 Ft             | 15.0 Ft        | 40 SF       | 0 SF      | 620 SF        |
| West Exposure  | 52 Ft             | 15.0 Ft             | 15.0 Ft        | 40 SF       | 0 SF      | 740 SF        |

Forced Ventilation:  cfm

# HEAT GAIN/LOSS WORKSHEET

Project Name: **Tabernacle Township**  
 Location: **163 Carranza Road**  
 Building Name: **Department of Public Works Garage**  
 Engineer: **Frank Cuffita**

Project No.: **CHA #21063**  
 Site Elevation: **460** Feet  
 Date: \_\_\_\_\_

Specific Volume: **13.50** CF/#

Building/Facility Designation: **Department of Public Works Garage**

## COOLING HEAT GAINS TO THE ROOM - SENSIBLE

### SOLAR GAINS

| WINDOWS        | AREA (SF) | SHGF         | Shade Coef | Cooling Load Factor |              | Solar Heat Gain    |
|----------------|-----------|--------------|------------|---------------------|--------------|--------------------|
| North Exposure | 40        | 38 btu/h/sf  | 0.8        | 0.75                | Glass Type C | 912 Btu/hr         |
| East Exposure  | 0         | 216 btu/h/sf | 0.8        | 0.31                | Glass Type C | 0 Btu/hr           |
| South Exposure | 40        | 109 btu/h/sf | 0.8        | 0.58                | Glass Type C | 2,023 Btu/hr       |
| West Exposure  | 40        | 216 btu/h/sf | 0.8        | 0.29                | Glass Type C | 2,004 Btu/hr       |
|                |           |              |            |                     |              | <b>4,940 Btu/h</b> |

### CONDUCTION

|                | NET AREA (SF) | U-VALUE | Cooling Load Temp. Dif. | Return Air Factor |  | Room Heat Gain      |
|----------------|---------------|---------|-------------------------|-------------------|--|---------------------|
| North Exposure | 152           | 0.40    | 20 *F                   | 1.0               |  | 1,216 Btu/hr        |
| East Exposure  | 765           | 0.40    | 39 *F                   | 1.0               |  | 11,934 Btu/hr       |
| South Exposure | 620           | 0.40    | 27 *F                   | 1.0               |  | 6,696 Btu/hr        |
| West Exposure  | 740           | 0.40    | 22 *F                   | 1.0               |  | 6,512 Btu/hr        |
| Roof           | 2,288         | 0.13    | 73 *F                   | 1.0               |  | 20,878 Btu/hr       |
| Fenestration   | 120           | 1.10    | 19 *F                   |                   |  | 2,508 Btu/hr        |
| Doors          | 483           | 0.14    | 27 *F                   |                   |  | 1,821 Btu/hr        |
| Ceiling        | 2,288         | 0.14    | 0 *F                    |                   |  | 0 Btu/hr            |
| Partition      |               | 0.05    | 0 *F                    |                   |  | 0 Btu/hr            |
| Floor          | 2,288         | 0.04    | 0 *F                    |                   |  | 0 Btu/hr            |
|                |               |         |                         |                   |  | <b>51,565 Btu/h</b> |

### INTERNAL HEAT GAINS

|                        |             |                  |                     |           |             |                    |
|------------------------|-------------|------------------|---------------------|-----------|-------------|--------------------|
| Lights                 | 1.20 w/sf x | 2,288 Occ Area = | 2.7 KW x 3.4x       | 1.0 RAF = | 9,371 Btu/h |                    |
| Plug Load              | w/sf x      | 2,288 Occ Area = | 0.0 KW x 3.4x       | 1.0 RAF = | 0 Btu/h     |                    |
| People                 | 1 people x  | 255 btu/person x | 30% time in space = |           | 77 Btu/h    |                    |
| Computer Work Stations |             | 0 Units x        | W/Unit x            | 3414 =    | 0 Btu/h     |                    |
| Equipment              |             | KW x 3.413 =     |                     |           | 0 Btu/h     |                    |
| Misc.                  |             |                  |                     |           | 0 Btu/h     |                    |
|                        |             |                  |                     |           |             | <b>9,447 Btu/h</b> |

### VENTILATION AND INFILTRATION

|             | Infiltration Factor  | Perimeter Ratio | Coef | Temp. Diff. | Room Heat Gain |                     |
|-------------|----------------------|-----------------|------|-------------|----------------|---------------------|
| Walls       | 2,277 SF 0.20 CFM/SF |                 | 1.08 | 19 *F       | 10,115 Btu/h   |                     |
| Doors       | 483 SF 0.50 CFM/LF   | 0.32 LF/SF      | 1.08 | 19 *F       | 1,710 Btu/h    |                     |
| Windows     | 120 SF 0.30 CFM/LF   | 0.90 LF/SF      | 1.08 | 19 *F       | 720 Btu/h      |                     |
| Ventilation | 0 cfm                |                 | 1.08 | 19 *F       | 0 Btu/h        |                     |
|             |                      |                 |      |             |                | <b>12,545 Btu/h</b> |

## COOLING HEAT GAINS TO THE RA PLENUM - SENSIBLE

4,950

### CONDUCTION

|                | NET AREA (SF) | U-VALUE | Cooling Load Temp. Dif. | Return Air Factor | Room Heat Gain |                |
|----------------|---------------|---------|-------------------------|-------------------|----------------|----------------|
| North Exposure | 0             | 0.40    | 20                      | 1.0               | 0 Btu/hr       |                |
| East Exposure  | 0             | 0.40    | 39                      | 1.0               | 0 Btu/hr       |                |
| South Exposure | 0             | 0.40    | 27                      | 1.0               | 0 Btu/hr       |                |
| West Exposure  | 0             | 0.40    | 22                      | 1.0               | 0 Btu/hr       |                |
| Roof           | 2,288         | 0.13    | 73                      | 0.0               | 0 Btu/hr       |                |
|                |               |         |                         |                   |                | <b>0 Btu/h</b> |

### INTERNAL HEAT GAINS

|        |             |                  |                 |            |         |                |
|--------|-------------|------------------|-----------------|------------|---------|----------------|
| Lights | 1.20 w/sf x | 2,288 Occ Area = | 2.7 KW x 3.413x | 0.00 RAF = | 0 Btu/h |                |
| Misc.  |             |                  |                 |            | 0 Btu/h |                |
|        |             |                  |                 |            |         | <b>0 Btu/h</b> |

### SENSIBLE HEAT GAINS - TEMP. DEPENDENT

|                              |               |
|------------------------------|---------------|
| Solar                        | 4,940         |
| Conduction to Room           | 51,565        |
| Conduction to Plenum         | 0             |
| Ventilation and Infiltration | 12,545        |
| <b>Sub Total</b>             | <b>69,050</b> |

### SENSIBLE HEAT GAINS - TEMP. INDEPENDENT

|                          |              |
|--------------------------|--------------|
| Internal Gains to Room   | 9,447        |
| Internal Gains to Plenum | 0            |
| <b>Sub Total</b>         | <b>9,447</b> |

## HEAT GAIN/LOSS WORKSHEET

Project Name: Tabernacle Township  
 Location: 163 Carranza Road  
 Building Name: Department of Public Works Garage  
 Engineer: Frank Cufita

Project No.: CHA #21063  
 Site Elevation: 460 Feet  
 Date:

Specific Volume 13.50 CF/#

Building/Facility Designation Department of Public Works Garage

### LATENT COOLING LOADS

| Infiltration |          | Infiltration Factor | Air Density | Humidity Ratio Dif. | Room Heat Gain      |
|--------------|----------|---------------------|-------------|---------------------|---------------------|
| Walls        | 2,288 SF | 0.20 CFM/SF         | 4,800       | 0.0042 ##           | 9,319 Btu/h         |
| Doors        | 483 SF   | 0.50 CFM/LF         | 4,800       | 0.0042 ##           | 1,568 Btu/h         |
| Windows      | 120 SF   | 0.30 CFM/LF         | 4,800       | 0.0042 ##           | 660 Btu/h           |
| Ventilation  | 0 cfm    |                     | 4,800       | 0.0042 ##           | 0 Btu/h             |
| People       | 1 people | 0.30 time in space  |             | 250 Btu/hr/person   | 75 Btu/h            |
|              |          |                     |             |                     | <b>11,622 Btu/h</b> |

### Cooling Load Summary

|                             | Sensible | Latent | Total  | SHR= |  |
|-----------------------------|----------|--------|--------|------|--|
| Temperature Dependent Gains | 69,050   | 11,622 | 80,673 |      |  |
| Temperature Indep. Gains    | 9,447    |        | 9,447  | 0.87 |  |
| <b>Total</b>                | 78,498   | 11,622 | 90,120 |      |  |

Building Cooling Load 7.5 Tons at 305 SF/Ton

Building Air Flow to Condition Space based on a 12°F Temp Rise is

|             |
|-------------|
| 6,043 CFM   |
| 2.64 CFM/sf |

### HEATING CALCULATION

#### CONDUCTION

|                | NET AREA (SF) | U-VALUE | Heating Load Temp. Dif. | Room Heat Gain |
|----------------|---------------|---------|-------------------------|----------------|
| North Exposure | 152           | 0.40    | 56                      | 3,405 Btu/h    |
| East Exposure  | 765           | 0.40    | 56                      | 17,136 Btu/h   |
| South Exposure | 620           | 0.40    | 56                      | 13,888 Btu/h   |
| West Exposure  | 740           | 0.40    | 56                      | 16,576 Btu/h   |
| Fenestration   | 120           | 1.10    | 56                      | 7,392 Btu/h    |
| Roof           | 2,288         | 0.13    | 56                      | 16,016 Btu/h   |
| Doors          | 483           | 0.14    | 56                      | 3,778 Btu/h    |
| Ceiling        | 2,288         | 0.14    | 0                       | 0 Btu/h        |
| Partition      | 0             | 0.05    | 0                       | 0 Btu/h        |
| Floor          | 2,288         | 0.04    | 0                       | 0 Btu/h        |

#### Ventilation and Infiltration

|  | Infiltration Factor | Coef        | Temp. Difference | Air Flow | Room Heat Gain |              |
|--|---------------------|-------------|------------------|----------|----------------|--------------|
| Walls  | 2,277 SF            | 0.20 CFM/SF | 1.08             | 56       | 455 cfm        | 27,605 Btu/h |
| Doors  | 483 SF              | 0.50 CFM/LF | 1.08             | 56       | 77 cfm         | 4,668 Btu/h  |
| Windows  | 120 SF              | 0.30 CFM/LF | 1.08             | 56       | 32 cfm         | 1,964 Btu/h  |
| Ventilation Load                                 | 0 cfm               |             |                  | 56       | 0 cfm          | 0 Btu/h      |
| <b>Total Ventilation &amp; Infiltration Load</b> |                     |             |                  | 565 cfm  | 34,237 Btu/h   |              |

|                              |                |              |
|------------------------------|----------------|--------------|
| <b>Building Heating Load</b> | <b>112,428</b> | <b>btu/h</b> |
|                              |                | 49.1 btu/sf  |

**Tabernacle Township**  
**CHA #21063**  
**Building: Department of Public Works Garage**

**Doors**

|       | Width (ft) | Height (ft) | Quantity     | Area (SF)    | Lineal Feet  |  |       |      |
|-------|------------|-------------|--------------|--------------|--------------|--|-------|------|
| North | 15.0       | 15.0        | 2            | 450.0        | 120.0        |  |       |      |
|       | 3.0        | 6.0         | 1            | 18.0         | 18.0         |  |       |      |
|       |            |             |              | 0.0          | 0.0          |  |       |      |
|       |            |             |              | 0.0          | 0.0          |  |       |      |
|       |            |             |              | 0.0          | 0.0          |  |       |      |
|       |            |             | Sub-total    | 468.0        | 138.0        |  |       |      |
| East  | 3.0        | 5.0         | 1            | 15.0         | 16.0         |  |       |      |
|       |            |             |              | 0.0          | 0.0          |  |       |      |
|       |            |             |              | 0.0          | 0.0          |  |       |      |
|       |            |             |              | Sub-total    | 15.0         | 16.0   |       |      |
| South |            |             |              | 0.0          | 0.0          |  |       |      |
|       |            |             |              | 0.0          | 0.0          |  |       |      |
|       |            |             |              | 0.0          | 0.0          |  |       |      |
|       |            |             |              | 0.0          | 0.0          |  |       |      |
|       |            |             |              | Sub-total    | 0.0          | 0.0  |       |      |
| West  |            |             |              | 0.0          | 0.0          |  |       |      |
|       |            |             |              | 0.0          | 0.0          |  |       |      |
|       |            |             |              | Sub-total    | 0.0          | 0.0  |       |      |
|       |            |             | <b>Total</b> | <b>483.0</b> | <b>154.0</b> | <table border="1"> <tr> <td>LF/SF</td> </tr> <tr> <td>0.32</td> </tr> </table> | LF/SF | 0.32 |
| LF/SF |            |             |              |              |              |  |       |      |
| 0.32  |            |             |              |              |              |  |       |      |

**Walls**

|       | Width (ft) | Height (ft) | Quantity | Area (SF) | Lineal Feet |  |
|-------|------------|-------------|----------|-----------|-------------|--|
| North | 44.0       | 15.0        | 1        | 660.0     | 118.0       | All wall quantities must remain equal to 1 |
|       |            |             |          | 0.0       | 0.0         |  |
|       |            |             |          | 0.0       | 0.0         |  |
|       |            |             |          | 0.0       | 0.0         |  |
|       |            |             |          | 0.0       | 0.0         |  |
|       | 44.0       |             |          | 660.0     | 118.0       | Ave. height 15.0                           |

Average height wall automatically linked to

|      |      |      |   |       |       |                  |
|------|------|------|---|-------|-------|------------------|
| East | 52.0 | 15.0 | 1 | 780.0 | 134.0 |                  |
|      |      |      |   | 0.0   | 0.0   |                  |
|      |      |      |   | 0.0   | 0.0   |                  |
|      |      |      |   | 0.0   | 0.0   |                  |
|      |      |      |   | 0.0   | 0.0   |                  |
|      | 52.0 |      |   | 780.0 | 134.0 | Ave. height 15.0 |

Average height wall automatically linked to

|       |      |      |   |       |       |                  |
|-------|------|------|---|-------|-------|------------------|
| South | 44.0 | 15.0 | 1 | 660.0 | 118.0 |                  |
|       |      |      |   | 0.0   | 0.0   |                  |
|       |      |      |   | 0.0   | 0.0   |                  |
|       |      |      |   | 0.0   | 0.0   |                  |
|       |      |      |   | 0.0   | 0.0   |                  |
|       | 44.0 |      |   | 660.0 | 118.0 | Ave. height 15.0 |

Average height wall automatically linked to

|      |      |      |   |       |       |                  |
|------|------|------|---|-------|-------|------------------|
| West | 52.0 | 15.0 | 1 | 780.0 | 134.0 |                  |
|      |      |      |   | 0.0   | 0.0   |                  |
|      |      |      |   | 0.0   | 0.0   |                  |
|      |      |      |   | 0.0   | 0.0   |                  |
|      |      |      |   | 0.0   | 0.0   |                  |
|      | 52.0 |      |   | 780.0 | 134.0 | Ave. height 15.0 |

Average height auto linked to block load sheet

**Windows**

|       | Width (ft) | Height (ft) | Quantity  | Area (SF) | Lineal Feet |
|-------|------------|-------------|-----------|-----------|-------------|
| North | 4.0        | 5.0         | 2         | 40.0      | 36.0        |
|       |            |             |           | 0.0       | 0.0         |
|       |            |             |           | 0.0       | 0.0         |
|       |            |             |           | 0.0       | 0.0         |
|       |            |             |           | 0.0       | 0.0         |
|       |            |             |           | 0.0       | 0.0         |
|       |            |             | Sub-total | 40.0      | 36.0        |

|      |  |  |           |     |     |
|------|--|--|-----------|-----|-----|
| East |  |  |           | 0.0 | 0.0 |
|      |  |  |           | 0.0 | 0.0 |
|      |  |  |           | 0.0 | 0.0 |
|      |  |  |           | 0.0 | 0.0 |
|      |  |  |           | 0.0 | 0.0 |
|      |  |  |           | 0.0 | 0.0 |
|      |  |  | Sub-total | 0.0 | 0.0 |

|       |     |     |           |      |      |
|-------|-----|-----|-----------|------|------|
| South | 4.0 | 5.0 | 2         | 40.0 | 36.0 |
|       |     |     |           | 0.0  | 0.0  |
|       |     |     |           | 0.0  | 0.0  |
|       |     |     |           | 0.0  | 0.0  |
|       |     |     |           | 0.0  | 0.0  |
|       |     |     |           | 0.0  | 0.0  |
|       |     |     | Sub-total | 40.0 | 36.0 |

|      |     |     |           |      |      |
|------|-----|-----|-----------|------|------|
| West | 4.0 | 5.0 | 2         | 40.0 | 36.0 |
|      |     |     |           | 0.0  | 0.0  |
|      |     |     |           | 0.0  | 0.0  |
|      |     |     |           | 0.0  | 0.0  |
|      |     |     |           | 0.0  | 0.0  |
|      |     |     |           | 0.0  | 0.0  |
|      |     |     | Sub-total | 40.0 | 36.0 |

|              |  |  |  |              |              |            |
|--------------|--|--|--|--------------|--------------|------------|
| <b>Total</b> |  |  |  | <b>120.0</b> | <b>108.0</b> | LF/SF 0.90 |
|--------------|--|--|--|--------------|--------------|------------|



## **APPENDIX E**

### **ECM-4 Install Door Seals**



Tabernacle Township  
 CHA #21063  
 Building: Department of Public Works Garage

**ECM-4 Install Garage Door Seals**

Existing: Doors or Door Seals result in excessive heat loss and infiltration  
 Proposed: Install new doors and/or weatherstripping to eliminate door infiltration

|                              |             |                                 |                  |                           |                 |
|------------------------------|-------------|---------------------------------|------------------|---------------------------|-----------------|
| Building Footprint           | 2,288 SF    | Ex Occupied Cng Temp.           | 72 *F            | Ex Occupied Htg Temp.     | 70 *F           |
| Heating System Efficiency    | 75%         | Ex Unoccupied Cng Temp.         | 80 *F            | Ex Unoccupied Htg Temp.   | 62 *F           |
| Cooling System Efficiency    | 1.30 kW/ton | Prop Occupied Cng Temp.         | 72 *F            | Prop Occupied Htg Temp.   | 70 *F           |
| Internal Gains               | 9,447 btu/h | Prop Unoccupied Cng Temp.       | 80 *F            | Prop Unoccupied Htg Temp. | 62 *F           |
| Unoc Internal Gain factor    | 0.03        | Occupied Cooling UA             | -2,974 btu/hr/*F | Occupied Heating UA       | 1,396 btu/hr/*F |
| Ave Occ Internal Gain Factor | 0.7         | Unoccupied Cooling UA           | -2,714 btu/hr/*F | Unoccupied Heating UA     | 1,396 btu/hr/*F |
|                              |             | Cooling Occ Enthalpy Setpoint   | 27.5 Btu/lb      |                           |                 |
|                              |             | Cooling Unocc Enthalpy Setpoint | 27.5 Btu/lb      |                           |                 |

| Avg Outdoor Air Temp. Bins *F | Avg Outdoor Air Enthalpy | EXISTING LOADS               |                              |                                |                    |                       |                    |                    |                       |                    | PROPOSED LOADS     |                       |                    |                    |                       |                    |              |              |              | Existing Cooling Energy kWh | Proposed Cooling Energy kWh | Existing Heating Energy lbs | Proposed Heating Energy lbs |
|-------------------------------|--------------------------|------------------------------|------------------------------|--------------------------------|--------------------|-----------------------|--------------------|--------------------|-----------------------|--------------------|--------------------|-----------------------|--------------------|--------------------|-----------------------|--------------------|--------------|--------------|--------------|-----------------------------|-----------------------------|-----------------------------|-----------------------------|
|                               |                          | Occupied                     |                              |                                | Unoccupied         |                       |                    | Occupied           |                       |                    | Unoccupied         |                       |                    |                    |                       |                    |              |              |              |                             |                             |                             |                             |
|                               |                          | Existing Equipment Bin Hours | Occupied Equipment Bin Hours | Unoccupied Equipment Bin Hours | Envelope Load BTUH | Ventilation Load BTUH | Internal Gain BTUH | Envelope Load BTUH | Ventilation Load BTUH | Internal Gain BTUH | Envelope Load BTUH | Ventilation Load BTUH | Internal Gain BTUH | Envelope Load BTUH | Ventilation Load BTUH | Internal Gain BTUH |              |              |              |                             |                             |                             |                             |
| A                             | B                        | C                            | D                            | E                              | F                  | G                     | H                  | I                  | J                     | K                  | L                  | M                     | N                  | O                  | P                     | K                  | L            | M            | N            |                             |                             |                             |                             |
| 102.5                         | 49.1                     | 0                            | 0                            | 0                              | -90,705            | -54,899               | -6,613             | -61,064            | -54,899               | -283               | -90,705            | -48,911               | -6,613             | -61,064            | -48,911               | -283               | 0            | 0            | 0            | 0                           |                             |                             |                             |
| 97.5                          | 42.5                     | 3                            | 1                            | 2                              | -75,836            | -38,124               | -6,613             | -47,494            | -38,124               | -283               | -75,836            | -33,966               | -6,613             | -47,494            | -33,966               | -283               | 31           | 29           | 0            | 0                           |                             |                             |                             |
| 92.5                          | 39.5                     | 34                           | 8                            | 26                             | -60,966            | -30,499               | -6,613             | -33,925            | -30,499               | -283               | -60,966            | -27,173               | -6,613             | -33,925            | -27,173               | -283               | 268          | 255          | 0            | 0                           |                             |                             |                             |
| 87.5                          | 36.6                     | 131                          | 31                           | 100                            | -46,096            | -23,129               | -6,613             | -20,355            | -23,129               | -283               | -46,096            | -20,606               | -6,613             | -20,355            | -20,606               | -283               | 729          | 694          | 0            | 0                           |                             |                             |                             |
| 82.5                          | 34.0                     | 131                          | 31                           | 100                            | -31,226            | -16,520               | -6,613             | -6,785             | -16,520               | -283               | -31,226            | -14,719               | -6,613             | -6,785             | -14,719               | -283               | 439          | 413          | 0            | 0                           |                             |                             |                             |
| 77.5                          | 31.6                     | 620                          | 148                          | 472                            | -16,357            | -10,421               | -6,613             | 0                  | 0                     | -283               | -16,357            | -9,284                | -6,613             | 0                  | 0                     | -283               | 548          | 530          | 0            | 0                           |                             |                             |                             |
| 72.5                          | 29.2                     | 664                          | 158                          | 506                            | -1,487             | -4,321                | -6,613             | 0                  | 0                     | -283               | -1,487             | -3,849                | -6,613             | 0                  | 0                     | -283               | 228          | 220          | 0            | 0                           |                             |                             |                             |
| 67.5                          | 27.0                     | 854                          | 203                          | 651                            | 3,491              | 1,525                 | -6,613             | 0                  | 0                     | -283               | 3,491              | 1,359                 | -6,613             | 0                  | 0                     | -283               | 55           | 59           | 0            | 0                           |                             |                             |                             |
| 62.5                          | 24.5                     | 927                          | 221                          | 706                            | 10,472             | 4,575                 | -6,613             | 0                  | 0                     | -283               | 10,472             | 4,076                 | -6,613             | 0                  | 0                     | -283               | 0            | 0            | 22           | 21                          |                             |                             |                             |
| 57.5                          | 21.4                     | 600                          | 143                          | 457                            | 17,453             | 7,625                 | -6,613             | 6,283              | 2,745                 | -283               | 17,453             | 6,793                 | -6,613             | 6,283              | 2,446                 | -283               | 0            | 0            | 88           | 85                          |                             |                             |                             |
| 52.5                          | 18.7                     | 610                          | 145                          | 465                            | 24,435             | 10,675                | -6,613             | 13,264             | 5,795                 | -283               | 24,435             | 9,510                 | -6,613             | 13,264             | 5,163                 | -283               | 0            | 0            | 172          | 165                         |                             |                             |                             |
| 47.5                          | 16.2                     | 611                          | 145                          | 466                            | 31,416             | 13,725                | -6,613             | 20,246             | 8,845                 | -283               | 31,416             | 12,228                | -6,613             | 20,246             | 7,880                 | -283               | 0            | 0            | 254          | 245                         |                             |                             |                             |
| 42.5                          | 14.4                     | 656                          | 156                          | 500                            | 38,397             | 16,775                | -6,613             | 27,227             | 11,895                | -283               | 38,397             | 14,945                | -6,613             | 27,227             | 10,597                | -283               | 0            | 0            | 360          | 347                         |                             |                             |                             |
| 37.5                          | 12.6                     | 1,023                        | 244                          | 779                            | 45,378             | 19,824                | -6,613             | 34,208             | 14,945                | -283               | 45,378             | 17,662                | -6,613             | 34,208             | 13,315                | -283               | 0            | 0            | 698          | 674                         |                             |                             |                             |
| 32.5                          | 10.7                     | 734                          | 175                          | 559                            | 52,360             | 22,874                | -6,613             | 41,190             | 17,995                | -283               | 52,360             | 20,380                | -6,613             | 41,190             | 16,032                | -283               | 0            | 0            | 599          | 579                         |                             |                             |                             |
| 27.5                          | 8.6                      | 334                          | 80                           | 254                            | 59,341             | 25,924                | -6,613             | 48,171             | 21,044                | -283               | 59,341             | 23,097                | -6,613             | 48,171             | 18,749                | -283               | 0            | 0            | 317          | 306                         |                             |                             |                             |
| 22.5                          | 6.8                      | 252                          | 60                           | 192                            | 66,322             | 28,974                | -6,613             | 55,152             | 24,094                | -283               | 66,322             | 25,814                | -6,613             | 55,152             | 21,467                | -283               | 0            | 0            | 273          | 264                         |                             |                             |                             |
| 17.5                          | 5.5                      | 125                          | 30                           | 95                             | 73,304             | 32,024                | -6,613             | 62,133             | 27,144                | -283               | 73,304             | 28,531                | -6,613             | 62,133             | 24,184                | -283               | 0            | 0            | 152          | 147                         |                             |                             |                             |
| 12.5                          | 4.1                      | 47                           | 11                           | 36                             | 80,285             | 35,074                | -6,613             | 69,115             | 30,194                | -283               | 80,285             | 31,249                | -6,613             | 69,115             | 26,901                | -283               | 0            | 0            | 64           | 61                          |                             |                             |                             |
| 7.5                           | 2.6                      | 22                           | 5                            | 17                             | 87,266             | 38,124                | -6,613             | 76,096             | 33,244                | -283               | 87,266             | 33,966                | -6,613             | 76,096             | 29,618                | -283               | 0            | 0            | 33           | 32                          |                             |                             |                             |
| 2.5                           | 1.0                      | 13                           | 3                            | 10                             | 94,247             | 41,174                | -6,613             | 83,077             | 36,294                | -283               | 94,247             | 36,683                | -6,613             | 83,077             | 32,336                | -283               | 0            | 0            | 21           | 20                          |                             |                             |                             |
| -2.5                          | 0.0                      | 0                            | 0                            | 0                              | 101,229            | 44,224                | -6,613             | 90,059             | 39,344                | -283               | 101,229            | 39,401                | -6,613             | 90,059             | 35,053                | -283               | 0            | 0            | 0            | 0                           |                             |                             |                             |
| -7.5                          | -1.5                     | 0                            | 0                            | 0                              | 108,210            | 47,274                | -6,613             | 97,040             | 42,394                | -283               | 108,210            | 42,118                | -6,613             | 97,040             | 37,770                | -283               | 0            | 0            | 0            | 0                           |                             |                             |                             |
| <b>TOTALS</b>                 |                          | <b>8,391</b>                 | <b>1,998</b>                 | <b>6,393</b>                   |                    |                       |                    |                    |                       |                    |                    |                       |                    |                    |                       |                    | <b>2,298</b> | <b>2,201</b> | <b>3,053</b> | <b>2,947</b>                |                             |                             |                             |

|   |         |         |            |
|---|---------|---------|------------|
| Existing Building Ventilation & Infiltration        | 565 cfm | Savings | 106 therms |
| Existing Unocc. Building Ventilation & Infiltration | 565 cfm |         | 98 kWh     |
| Door infiltration                                   | 77 cfm  |         | 76 gallons |
| Proposed reduction (80%)                            | 62 cfm  |         |            |
| Proposed Building Ventilation & Infiltration        | 503 cfm |         |            |
| Proposed Unocc. Building Ventilation & Infiltration | 503 cfm |         |            |



## **APPENDIX F**

### **ECM-5 Lighting Replacements**



Tabernacle Township  
 CHA #21063  
 Building: Department of Public Works Garage

**ECM-5 Replacement of Incandescent and T-12 lights**

**Building Schedule:**

Existing conditions (master switch): 40 hrs/week  
 Supply Electric Rate \$ 0.165 /kWh  
 Demand Rate \$ 1.60 /kW

Instructions and notes:

Input existing fixtures and retrofit fixtures. Use light table

| Area Description | EXISTING CONDITIONS |              |                   |                                    |                                    |          |               |             |              |            | RETROFIT CONDITIONS |              |                   |          |                  |             |              |            | COST ANALYSIS |                  |                 |               |
|------------------|---------------------|--------------|-------------------|------------------------------------|------------------------------------|----------|---------------|-------------|--------------|------------|---------------------|--------------|-------------------|----------|------------------|-------------|--------------|------------|---------------|------------------|-----------------|---------------|
|                  | Number of Fixtures  | Fixture Code | Watts per Fixture | Number of Non-Operational Fixtures | Watts per Non-Operational Fixtures | kW/Space | Exist Control | Daily Hours | Annual Hours | Annual kWh | Number of Fixtures  | Fixture Code | Watts per Fixture | kW/Space | Retrofit Control | Daily Hours | Annual Hours | Annual kWh | kW Saved      | Annual kWh Saved | Annual \$ Saved | Retrofit Cost |
| Main area        | 17                  | F82SS        | 173               | 2                                  | 176.46                             | 3.29392  | switch        | 8           | 2,000        | 6,588      | 17                  | F82EHL       | 135               | 2.295    | switch           | 8           | 2,000        | 4,590      | 1             | 1,998            | \$ 349          | \$ 2,133      |
| Offices/Lunch    | 7                   | F44SE        | 172               | 0                                  | 175.44                             | 1.204    | switch        | 8           | 2,000        | 2,408      | 7                   | F43ILL       | 89                | 0.623    | switch           | 8           | 2,000        | 1,246      | 1             | 1,162            | \$ 203          | \$ 878        |
| Outside          | 5                   | I150         | 150               | 1                                  | 153                                | 0.903    | timeclock     | 8           | 2,920        | 2,637      | 5                   | CFT40        | 80                | 0.4      | switch           | 8           | 2,920        | 1,168      | 1             | 1,469            | \$ 252          | \$ 627        |
| TOTALS -         | 29                  |              |                   | 3                                  |                                    | 5.4      |               |             |              | 11,633     | 29                  |              | 3.3               |          |                  |             | 7,004        | 2.1        | 4,629         | \$ 805           | \$ 3,639        |               |

**APPENDIX G**

**New Jersey Incentive Program**

**Tabernacle Township**  
**CHA #21063**  
**Building: Department of Public Works Garage**

**New Jersey Pay For Performance Incentive Program**

**Note:** The following calculation is based on the New Jersey Pay For Performance Incentive Program per January, 2010. Building must have a minimum average electric demand of 200 kW. This minimum is waived for buildings owned by local governments or non-profit organizations.

The incentive values represented below are applicable through December 31, 2010.

|  |       |
|--|-------|
| Total Building Area (Square Feet)        | 2,290 |
| Is this audit funded by the NJ BPU (Y/N) | Yes   |

Bureau of Public Utilities (BPU)

| Incentive #1               |        |         |
|----------------------------|--------|---------|
| Audit not funded by NJ BPU | \$0.10 | \$/sqft |
| Audit is funded by NJ BPU  | \$0.05 | \$/sqft |

|                               | Annual Utilities |        |
|-------------------------------|------------------|--------|
|                               | kWh              | Therms |
| Existing Cost (from utility)  | \$3,300          | \$0    |
| Existing Usage (from utility) | 19,190           | 0      |
| Proposed Savings              | 4,629            | -1,220 |
| Existing Total MMBtus         | 65               |        |
| Proposed Savings MMBtus       | -106             |        |
| % Energy Reduction            | -162.2%          |        |
| Proposed Annual Savings       | \$3,000          |        |

| ≥ %15 - < 20% |        |          |
|---------------|--------|----------|
|               | \$/kWh | \$/therm |
| Incentive #2  | \$0.11 | \$1.10   |
| Incentive #3  | \$0.07 | \$0.70   |

|              |        |        |
|--------------|--------|--------|
| Incentive #2 | \$0.11 | \$1.10 |
| Incentive #3 | \$0.07 | \$0.70 |

| ≥ 20%        |        |          |
|--------------|--------|----------|
|              | \$/kWh | \$/therm |
| Incentive #2 | \$0.22 | \$2.20   |
| Incentive #3 | \$0.14 | \$1.40   |

|                      | Incentives \$ |     |       |
|----------------------|---------------|-----|-------|
|                      | Elec          | Gas | Total |
| Incentive #1         | \$0           | \$0 | \$115 |
| Incentive #2         | \$0           | \$0 | \$0   |
| Incentive #3         | \$0           | \$0 | \$0   |
| Total All Incentives | \$0           | \$0 | \$115 |

|  |          |
|--|----------|
| Total Project Cost                     | \$17,500 |
| % Incentives #1 of Utility Cost*       | 3.5%     |
| % Incentives #2 & #3 of Project Cost** | 0.0%     |
| Total Eligible Incentives**            | \$115    |
| Project Cost w/ Incentives             | \$17,386 |

| Project Payback (years) |               |
|-------------------------|---------------|
| w/o Incentives          | w/ Incentives |
| 5.8                     | 5.8           |

\* Maximum allowable incentive is 50% of annual utility cost if not funded by NJ BPU, and %25 if it is.

\*\* Maximum allowable amount of Incentive #1 is \$50,000 if not funded by NJ BPU, and \$25,000 if it is.

Maximum allowable amount of Incentive #2 & #3 is 80% of total project cost, or \$2 million per gas account and \$2 million per electric account

## **APPENDIX H**

### **Photovoltaic (PV) Rooftop Solar Power Generation**

**Tabernacle Township  
DPW Building**

Cost of Electricity      \$0.170      \$/kWh

**Photovoltaic (PV) Rooftop Solar Power Generation-8kW System**

| Budgetary<br>Cost     | Annual Utility Savings |          |                      | Estimated<br>Maintenance<br>Savings | Total<br>Savings     | New Jersey<br>Renewable<br>* Energy<br>Incentive | New Jersey<br>Renewable<br>** SREC | Payback<br>(without<br>incentive) | Payback<br>(with<br>incentive) |
|-----------------------|------------------------|----------|----------------------|-------------------------------------|----------------------|--|------------------------------------|-----------------------------------|--------------------------------|
|                       | kWh                    | therms   | \$                   |                                     |                      |  |                                    |                                   |                                |
| \$<br><b>\$56,000</b> | <b>0.0</b>             | <b>0</b> | \$<br><b>\$1,641</b> | \$<br><b>0</b>                      | \$<br><b>\$1,641</b> | \$<br><b>\$8,000</b>                             | \$<br><b>\$4,700</b>               | <b>34.1</b>                       | <b>7.6</b>                     |


Note: Budgetary cost is based on \$7,000/kW.

\*Incentive based on New Jersey renewable energy program for non-residential applications(PV)= \$1.00/W of installed PV system

\*\* Estimated Solar Renewable Energy Certificate Program (SREC) SREC for 15 Years= \$487/1000kwh

Estimated Solar Renewable Energy Certificate Program (SREC) payments for 15 Years from RR Renewable Energy Consultants

| Year       | SREC       |
|------------|------------|
| 1          | 600        |
| 2          | 600        |
| 3          | 600        |
| 4          | 500        |
| 5          | 500        |
| 6          | 500        |
| 7          | 500        |
| 8          | 500        |
| 9          | 500        |
| 10         | 500        |
| 11         | 400        |
| 12         | 400        |
| 13         | 400        |
| 14         | 400        |
| 15         | 400        |
| <b>AVG</b> | <b>487</b> |



\*\*\*

**AC Energy  
&  
Cost Savings**



| Station Identification   |              |
|--------------------------|--------------|
| City:                    | Philadelphia |
| State:                   | Pennsylvania |
| Latitude:                | 39.88° N     |
| Longitude:               | 75.25° W     |
| Elevation:               | 9 m          |
| PV System Specifications |              |
| DC Rating:               | 8.0 kW       |
| DC to AC Derate Factor:  | 0.770        |
| AC Rating:               | 6.2 kW       |
| Array Type:              | Fixed Tilt   |
| Array Tilt:              | 39.9°        |
| Array Azimuth:           | 180.0°       |
| Energy Specifications    |              |
| Cost of Electricity:     | 17.0 ¢/kWh   |

| Results |  |                    |                      |
|---------|--|--------------------|----------------------|
| Month   | Solar Radiation<br>(kWh/m <sup>2</sup> /day) | AC Energy<br>(kWh) | Energy Value<br>(\$) |
| 1       | 3.30   | 648                | 110.16               |
| 2       | 4.16   | 737                | 125.29               |
| 3       | 4.74   | 889                | 151.13               |
| 4       | 5.06   | 891                | 151.47               |
| 5       | 5.20   | 911                | 154.87               |
| 6       | 5.43   | 893                | 151.81               |
| 7       | 5.51   | 924                | 157.08               |
| 8       | 5.67   | 959                | 163.03               |
| 9       | 5.07   | 850                | 144.50               |
| 10      | 4.59   | 830                | 141.10               |
| 11      | 3.37   | 610                | 103.70               |
| 12      | 2.67   | 507                | 86.19                |
| Year    | 4.57   | 9648               | 1640.16              |

[Output Hourly Performance Data](#)

[Output Results as Text](#)

\*

[About the Hourly Performance Data](#)

[Saving Text from a Browser](#)

Run PVWATTS v.1 for another US location or an International location  
 Run PVWATTS v.2 (US only)

Please send questions and comments regarding PVWATTS to Webmaster

Disclaimer and copyright notice



## Cautions for Interpreting the Results

The monthly and yearly energy production are modeled using the PV system parameters you selected and weather data that are typical or representative of long-term averages. For reference, or comparison with local information, the solar radiation values modeled for the PV array are included in the performance results.

Because weather patterns vary from year-to-year, the values in the tables are better indicators of long-term performance than performance for a particular month or year. PV performance is largely proportional to the amount of solar radiation received, which may vary from the long-term average by  $\pm 30\%$  for monthly values and  $\pm 10\%$  for yearly values. How the solar radiation might vary for your location may be evaluated by examining the tables in the *Solar Radiation Data Manual for Flat-Plate and Concentrating Collectors* ([http://rredc.nrel.gov/solar/old\\_data/nsrdb/redbook/](http://rredc.nrel.gov/solar/old_data/nsrdb/redbook/)).

For these variations and the uncertainties associated with the weather data and the model used to model the PV performance, future months and years may be encountered where the actual PV performance is less than or greater than the values shown in the table. The variations may be as much as 40% for individual months and up to 20% for individual years. Compared to long-term performance over many years, the values in the table are accurate to within 10% to 12%.

If the default overall DC to AC derate factor is used, the energy values in the table will overestimate the actual energy production if nearby buildings, objects, or other PV modules and array structure shade the PV modules; if tracking mechanisms for one- and two-axis tracking systems do not keep the PV arrays at the optimum orientation with respect to the sun's position; if soiling or snow cover related losses exceed 5%; or if the system performance has degraded from new. (PV performance typically degrades 1% per year.) If any of these situations exist, an overall DC to AC derate factor should be used with PVWATTS that was calculated using system specific component derate factors for *shading, sun-tracking, soiling, and age*.

The PV system size is the nameplate DC power rating. The energy production values in the table are valid only for crystalline silicon PV systems.

The cost savings are determined as the product of the number of kilowatt hours (kWh) and the cost of electricity per kWh. These cost savings occur if the owner uses all the electricity produced by the PV system, or if the owner has a net-metering agreement with the utility. With net-metering, the utility bills the owner for the net electricity consumed. When electricity flows from the utility to the owner, the meter spins forward. When electricity flows from the PV system to the utility, the meter spins backwards.


If net-metering isn't available and the PV system sends surplus electricity to the utility grid, the utility generally buys the electricity from the owner at a lower price than the owner pays the utility for electricity. In this case, the cost savings shown in the table should be reduced.

Besides the cost savings shown in the table, other benefits of PV systems include greater energy independence and a reduction in fossil fuel usage and air pollution. For commercial customers, additional cost savings may come from reducing demand charges. Homeowners can often include the cost of the PV system in their home mortgage as a way of accommodating the PV system's initial cost.

To accelerate the use of PV systems, many state and local governments offer financial incentives and programs. Go to <http://www.nrel.gov/stateandlocal> for more information.

Please send questions and comments to Webmaster

Disclaimer and copyright notice.




Return to RReDC Home Page (<http://rredc.nrel.gov/>)

## **APPENDIX I**

### **Solar Thermal Domestic Hot Water Plant**





- Home
- What Can I Do?
- Electric Choice
- Home Energy
- FAQs
- LEARN**
- Fact Sheets
- Lesson Plans

## Interactive Energy Calculators

**RENEWABLE ENERGY**  
THE INFINITE POWER  
OF TEXAS

Our calculators help you understand energy production and consumption in a whole new way. Use them to develop a personal profile of your own energy use.

- Carbon Pollution Calculator
- Electric Power Pollution Calculator
- PV System Economics
- Solar Water Heating
- What's a Watt?

- PLAY**
- Calculators

### Solar Water Heating Calculator

Water heating is a major energy consumer. Although the energy consumed daily is often less than for air conditioning or heating, it is required year round, making it a good application of solar energy. Use this calculator to explore the energy usage of your water heater, and to estimate whether a solar water heater could save you money.

- NETWORK**
- Organizations
- Businesses
- Events Calendar

- BROWSE**
- Resources
- Solar
- Wind
- Biomass
- Geothermal
- Water

- Projects
- TX Energy - Past and Present
- Financial Help
- About Us
- About SECO
- RARE

| Water Heater Characteristics        |       |   |     |
|-------------------------------------|-------|---|-----|
| Physical                            |       | Thermal                                 |     |
| ? Diameter (feet)                   | .5    | ? Water Inlet Temperature (Degrees F)   | 50  |
| ? Capacity (gallons)                | 6     | ? Ambient Temperature (Degrees F)       | 70  |
| ? Surface Area (calculated - sq ft) | 6.809 | ? Hot Water Temperature (Degrees F)     | 120 |
| ? Effective R-value                 | NaN   | ? Hot Water Usage (Gallons per Day)     | 20  |
| Energy Use                          |       |   |     |
|                                     |       | ? Heat Delivered in Hot Water (BTU/hr)  |     |
|                                     |       | ? Heat loss through insulation (BTU/hr) |     |

| Gas vs. Electric Water Heating     |                                 |                            |
|------------------------------------|---------------------------------|----------------------------|
| Gas                                |                                 | Electric                   |
| 0                                  | ? Overall Efficiency            | 0.98                       |
| 0                                  | ? Conversion Efficiency         | 0.98                       |
| NaN BTU/hr                         | ? Power Into Water Heater       | 488.7 BTU/hr               |
| Cost                               |                                 |                            |
| \$0 /Therm                         | ? Utility Rates                 | \$0.17 /kWh                |
| \$NaN                              | ? Yearly Water Heating Cost     | \$213.146                  |
| How Does Solar Compare?            |                                 |                            |
| ? Solar Water Heater Cost: \$27100 |                                 | ? Percentage Solar: 70     |
| NaN years for gas                  | ? Payback Time for Solar System | 181.632 years for electric |

NJBPU Energy Audits  
 CHA #21063  
 DPW Building  
 Tabernacle Township

| Multipliers |      |
|-------------|------|
| Material:   | 0.98 |
| Labor:      | 1.21 |
| Equipment:  | 1.09 |


| Description                  | QTY | UNIT | UNIT COSTS |          |          | SUBTOTAL COSTS |          |          | TOTAL COST | REMARKS |
|------------------------------|-----|------|------------|----------|----------|----------------|----------|----------|------------|---------|
|                              |     |      | MAT.       | LABOR    | EQUIP.   | MAT.           | LABOR    | EQUIP.   |            |         |
| Synergy Solar Thermal System | 2   | ea   |            |          | \$ 3,600 | \$ -           | \$ -     | \$ 7,848 | \$ 7,848   |         |
| Piping modifications         | 1   | ls   | \$ 2,000   | \$ 3,500 |          | \$ 1,960       | \$ 4,235 | \$ -     | \$ 6,195   |         |
| Electrical modifications     | 1   | ls   | \$ 1,000   | \$ 1,000 |          | \$ 980         | \$ 1,210 | \$ -     | \$ 2,190   |         |
| 65 Gallon Storage Tanks      | 2   | ea   | \$ 200     | \$ 250   |          | \$ 400         | \$ 500   | \$ -     | \$ 900     |         |
| 10 Gallon Drip Tank          | 2   | ea   | \$ 100     | \$ 78    |          | \$ 200         | \$ 156   | \$ -     | \$ 356     |         |
|                              |     |      | \$ -       | \$ -     | \$ -     | \$ -           | \$ -     | \$ -     | \$ -       |         |

|                 |                    |
|-----------------|--------------------|
| \$17,489        | Subtotal           |
| \$ 2,623        | 15% Contingency    |
| \$ 2,623        | 15% Contractor O&P |
| \$ 4,372        | 25% Engineering    |
| <b>\$27,108</b> | <b>Total</b>       |


## **APPENDIX J**

### **Wind**





## Wind Resource of New Jersey Mean Annual Wind Speed at 30 Meters



**AWS Truewind**

Projection: Transverse Mercator,  
UTM Zone 17 WGS84


Spatial Resolution of Wind Resource Data: 200m  
This map was created by AWS Truewind using the MesoMap system and historical weather data. Although it is believed to represent an accurate overall picture of the wind energy resource, estimates at any location should be confirmed by measurement.


The transmission line information was obtained by AWS Truewind from the Global Energy Decisions Velocity Suite. AWS does not warrant the accuracy of the transmission line information.


### Bing Maps

**163 Carranza Rd, Tabernacle, NJ 08088-9304**

My Notes

 **FREE!** Use Bing 411 to find movies, businesses & more: **800-BING-411**





**APPENDIX K**

**EPA Portfolio Manager**



# STATEMENT OF ENERGY PERFORMANCE DPW

Building ID: 2209638  
For 12-month Period Ending: December 31, 2009<sup>1</sup>  
Date SEP becomes ineligible: N/A

Date SEP Generated: April 12, 2010

|   |   |  |
|---|---|--|
| <b>Facility</b><br>DPW<br>163 Carranza Road<br>Tabernacle, NJ 08088 | <b>Facility Owner</b><br>Tabernacle Township<br>163 Carranza Road<br>Tabernacle, NJ 08088 | <b>Primary Contact for this Facility</b><br>Douglas Cramer<br>163 Caranza oad<br>Tabrnacle, NJ 08088 |
|---|---|--|

Year Built: 1970  
Gross Floor Area (ft<sup>2</sup>): 1,600

Energy Performance Rating<sup>2</sup> (1-100) N/A

### Site Energy Use Summary<sup>3</sup>

|                                   |         |
|-----------------------------------|---------|
| Electricity - Grid Purchase(kBtu) | 72,825  |
| Fuel Oil (No. 2) (kBtu)           | 249,274 |
| Natural Gas - (kBtu) <sup>4</sup> | 0       |
| Total Energy (kBtu)               | 322,099 |

### Energy Intensity<sup>5</sup>

|                                   |     |
|-----------------------------------|-----|
| Site (kBtu/ft <sup>2</sup> /yr)   | 201 |
| Source (kBtu/ft <sup>2</sup> /yr) | 309 |

### Emissions (based on site energy use)

|   |    |
|---|----|
| Greenhouse Gas Emissions (MtCO <sub>2</sub> e/year) | 29 |
|---|----|

### Electric Distribution Utility

Pepco - Atlantic City Electric Co

### National Average Comparison

|   |   |
|---|---|
| National Average Site EUI                     | 77  |
| National Average Source EUI                   | 150   |
| % Difference from National Average Source EUI | 106%  |
| Building Type                                 | Service<br>(Vehicle<br>Repair/Service,<br>Postal Service) |

### Meets Industry Standards<sup>6</sup> for Indoor Environmental Conditions:

|   |     |
|---|-----|
| Ventilation for Acceptable Indoor Air Quality | N/A |
| Acceptable Thermal Environmental Conditions   | N/A |
| Adequate Illumination                         | N/A |

|  |
|--|
|  |
| Stamp of Certifying Professional   |
| Based on the conditions observed at the time of my visit to this building, I certify that the information contained within this statement is accurate. |

### Certifying Professional

N/A

#### Notes:

1. Application for the ENERGY STAR must be submitted to EPA within 4 months of the Period Ending date. Award of the ENERGY STAR is not final until approval is received from EPA.
2. The EPA Energy Performance Rating is based on total source energy. A rating of 75 is the minimum to be eligible for the ENERGY STAR.
3. Values represent energy consumption, annualized to a 12-month period.
4. Natural Gas values in units of volume (e.g. cubic feet) are converted to kBtu with adjustments made for elevation based on Facility zip code.
5. Values represent energy intensity, annualized to a 12-month period.
6. Based on Meeting ASHRAE Standard 62 for ventilation for acceptable indoor air quality, ASHRAE Standard 55 for thermal comfort, and IESNA Lighting Handbook for lighting quality.

## ENERGY STAR® Data Checklist for Commercial Buildings

In order for a building to qualify for the ENERGY STAR, a Professional Engineer (PE) must validate the accuracy of the data underlying the building's energy performance rating. This checklist is designed to provide an at-a-glance summary of a property's physical and operating characteristics, as well as its total energy consumption, to assist the PE in double-checking the information that the building owner or operator has entered into Portfolio Manager.

**Please complete and sign this checklist and include it with the stamped, signed Statement of Energy Performance.**

NOTE: You must check each box to indicate that each value is correct, OR include a note.

| CRITERION              | VALUE AS ENTERED IN PORTFOLIO MANAGER            | VERIFICATION QUESTIONS   | NOTES | <input checked="" type="checkbox"/> |
|------------------------|--|--|-------|-------------------------------------|
| Building Name          | DPW  | Is this the official building name to be displayed in the ENERGY STAR Registry of Labeled Buildings?   |       | <input type="checkbox"/>            |
| Type                   | Service (Vehicle Repair/Service, Postal Service) | Is this an accurate description of the space in question?  |       | <input type="checkbox"/>            |
| Location               | 163 Carranza Road, Tabernacle, NJ 08088          | Is this address accurate and complete? Correct weather normalization requires an accurate zip code.  |       | <input type="checkbox"/>            |
| Single Structure       | Single Facility                                  | Does this SEP represent a single structure? SEPs cannot be submitted for multiple-building campuses (with the exception of acute care or children's hospitals) nor can they be submitted as representing only a portion of a building  |       | <input type="checkbox"/>            |
| main shop (Other)      |  |  |       |                                     |
| CRITERION              | VALUE AS ENTERED IN PORTFOLIO MANAGER            | VERIFICATION QUESTIONS   | NOTES | <input checked="" type="checkbox"/> |
| Gross Floor Area       | 1,600 Sq. Ft.                                    | Does this square footage include all supporting functions such as kitchens and break rooms used by staff, storage areas, administrative areas, elevators, stairwells, atria, vent shafts, etc. Also note that existing atriums should only include the base floor area that it occupies. Interstitial (plenum) space between floors should not be included in the total. Finally gross floor area is not the same as leasable space. Leasable space is a subset of gross floor area. |       | <input type="checkbox"/>            |
| Number of PCs          | 1(Optional)                                      | Is this the number of personal computers in the space?   |       | <input type="checkbox"/>            |
| Weekly operating hours | 40Hours(Optional)                                | Is this the total number of hours per week that the space is 75% occupied? This number should exclude hours when the facility is occupied only by maintenance, security, or other support personnel. For facilities with a schedule that varies during the year, "operating hours/week" refers to the total weekly hours for the schedule most often followed.   |       | <input type="checkbox"/>            |
| Workers on Main Shift  | 2(Optional)                                      | Is this the number of employees present during the main shift? Note this is not the total number of employees or visitors who are in a building during an entire 24 hour period. For example, if there are two daily 8 hour shifts of 100 workers each, the Workers on Main Shift value is 100.  |       | <input type="checkbox"/>            |

## ENERGY STAR® Data Checklist for Commercial Buildings

### Energy Consumption

**Power Generation Plant or Distribution Utility:** Pepco - Atlantic City Electric Co

| Fuel Type: Electricity  |            |  |
|---|------------|--|
| <b>Meter: electric (kWh (thousand Watt-hours))</b><br><b>Space(s): main shop</b><br><b>Generation Method: Grid Purchase</b> |            |  |
| Start Date  | End Date   | Energy Use (kWh (thousand Watt-hours)) |
| 11/05/2009  | 12/04/2009 | 2,098.00                               |
| 10/05/2009  | 11/04/2009 | 1,384.00                               |
| 09/05/2009  | 10/04/2009 | 1,459.00                               |
| 08/05/2009  | 09/04/2009 | 1,289.00                               |
| 07/05/2009  | 08/04/2009 | 1,332.00                               |
| 06/05/2009  | 07/04/2009 | 1,687.00                               |
| 05/05/2009  | 06/04/2009 | 1,981.00                               |
| 04/05/2009  | 05/04/2009 | 1,349.00                               |
| 03/05/2009  | 04/04/2009 | 1,309.00                               |
| 02/05/2009  | 03/04/2009 | 1,344.00                               |
| 01/05/2009  | 02/04/2009 | 2,434.00                               |
| <b>electric Consumption (kWh (thousand Watt-hours))</b>   |            | <b>17,666.00</b>                       |
| <b>electric Consumption (kBtu (thousand Btu))</b>   |            | <b>60,276.39</b>                       |
| <b>Total Electricity (Grid Purchase) Consumption (kBtu (thousand Btu))</b>  |            | <b>60,276.39</b>                       |
| <b>Is this the total Electricity (Grid Purchase) consumption at this building including all Electricity meters?</b>         |            | <input type="checkbox"/>               |
| Fuel Type: Fuel Oil (No. 2)   |            |  |
| <b>Meter: Fuel Oil (Gallons)</b><br><b>Space(s): Entire Facility</b>  |            |  |
| Start Date  | End Date   | Energy Use (Gallons)                   |
| 11/05/2009  | 12/04/2009 | 0.00                                   |
| 10/05/2009  | 11/04/2009 | 0.00                                   |
| 09/05/2009  | 10/04/2009 | 0.00                                   |
| 08/05/2009  | 09/04/2009 | 0.00                                   |
| 07/05/2009  | 08/04/2009 | 0.00                                   |
| 06/05/2009  | 07/04/2009 | 0.00                                   |
| 05/05/2009  | 06/04/2009 | 145.00                                 |
| 04/05/2009  | 05/04/2009 | 0.00                                   |
| 03/05/2009  | 04/04/2009 | 349.00                                 |
| 02/05/2009  | 03/04/2009 | 583.00                                 |
| 01/05/2009  | 02/04/2009 | 300.00                                 |

|  |                          |
|--|--------------------------|
| Fuel Oil Consumption (Gallons)   | 1,377.00                 |
| Fuel Oil Consumption (kBtu (thousand Btu))   | 190,976.82               |
| Total Fuel Oil (No. 2) Consumption (kBtu (thousand Btu))   | 190,976.82               |
| Is this the total Fuel Oil (No. 2) consumption at this building including all Fuel Oil (No. 2) meters? | <input type="checkbox"/> |

|  |                          |
|--|--------------------------|
| <b>Additional Fuels</b>  |                          |
| Do the fuel consumption totals shown above represent the total energy use of this building?<br>Please confirm there are no additional fuels (district energy, generator fuel oil) used in this facility. | <input type="checkbox"/> |

|   |                          |
|---|--------------------------|
| <b>On-Site Solar and Wind Energy</b>  |                          |
| Do the fuel consumption totals shown above include all on-site solar and/or wind power located at your facility? Please confirm that no on-site solar or wind installations have been omitted from this list. All on-site systems must be reported. | <input type="checkbox"/> |

### Certifying Professional

(When applying for the ENERGY STAR, the Certifying Professional must be the same as the PE that signed and stamped the SEP.)

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Signature: \_\_\_\_\_

Signature is required when applying for the ENERGY STAR.

## FOR YOUR RECORDS ONLY. DO NOT SUBMIT TO EPA.

Please keep this Facility Summary for your own records; do not submit it to EPA. Only the Statement of Energy Performance (SEP), Data Checklist and Letter of Agreement need to be submitted to EPA when applying for the ENERGY STAR.

**Facility**  
 DPW  
 163 Carranza Road  
 Tabernacle, NJ 08088

**Facility Owner**  
 Tabernacle Township  
 163 Carranza Road  
 Tabernacle, NJ 08088

**Primary Contact for this Facility**  
 Douglas Cramer  
 163 Caranza oad  
 Tabrnacle, NJ 08088

### General Information

| DPW  |                   |
|--|-------------------|
| Gross Floor Area Excluding Parking: (ft <sup>2</sup> ) | 1,600             |
| Year Built   | 1970              |
| For 12-month Evaluation Period Ending Date:            | December 31, 2009 |

### Facility Space Use Summary

| main shop                          |  |
|------------------------------------|--|
| Space Type                         | Other - Service (Vehicle Repair/Service, Postal Service) |
| Gross Floor Area(ft <sup>2</sup> ) | 1,600  |
| Number of PCs*                     | 1  |
| Weekly operating hours*            | 40   |
| Workers on Main Shift*             | 2  |

### Energy Performance Comparison

| Performance Metrics                       | Evaluation Periods               |                                   | Comparisons  |        |                  |
|---|----------------------------------|-----------------------------------|--------------|--------|------------------|
|   | Current (Ending Date 12/31/2009) | Baseline (Ending Date 12/31/2009) | Rating of 75 | Target | National Average |
| Energy Performance Rating                 | N/A                              | N/A                               | 75           | N/A    | N/A              |
| Energy Intensity                          |                                  |                                   |              |        |                  |
| Site (kBtu/ft <sup>2</sup> )              | 201                              | 201                               | 0            | N/A    | 77               |
| Source (kBtu/ft <sup>2</sup> )            | 309                              | 309                               | 0            | N/A    | 150              |
| Energy Cost                               |                                  |                                   |              |        |                  |
| \$/year                                   | N/A                              | N/A                               | N/A          | N/A    | N/A              |
| \$/ft <sup>2</sup> /year                  | N/A                              | N/A                               | N/A          | N/A    | N/A              |
| Greenhouse Gas Emissions                  |                                  |                                   |              |        |                  |
| MtCO <sub>2</sub> e/year                  | 29                               | 29                                | 0            | N/A    | 11               |
| kgCO <sub>2</sub> e/ft <sup>2</sup> /year | 18                               | 18                                | 0            | N/A    | 7                |

More than 50% of your building is defined as Service (Vehicle Repair/Service, Postal Service). This building is currently ineligible for a rating. Please note the National Average column represents the CBECS national average data for Service (Vehicle Repair/Service, Postal Service). This building uses X% less energy per square foot than the CBECS national average for Service (Vehicle Repair/Service, Postal Service).

Notes:

o - This attribute is optional.

d - A default value has been supplied by Portfolio Manager.

**APPENDIX L**

**Equipment Inventory**



# New Jersey BPU Energy Audit Program

Borough of Tabernacle, NJ

CHA#21063

| DPW/Garage Building              |      |                 |               |            |          |           |     |     |         |                             |
|----------------------------------|------|-----------------|---------------|------------|----------|-----------|-----|-----|---------|-----------------------------|
| Item                             | Qty. | Manuf           | Model No.     | Serial No. | Capacity | Condition | Gas | MBH | Refrig. | Comments                    |
| <b>Forced Hot Air Furnace</b>    |      |                 |               |            |          |           |     |     |         |                             |
| 1                                | 1    | Heat Controller | ODHA95D3      | 8406A15521 |          | G         |     | 96  |         |                             |
| 2                                | 1    | Heat Controller | DOHA112/125F5 | 8404A10987 |          | G         |     | 125 |         |                             |
| <b>Upright Compressor</b>        |      |                 |               |            |          |           |     |     |         |                             |
| 3                                | 1    | US Electric     | G62718        | 184T       | 5hp      | G         |     |     |         | Compressor SaylorBeall- 705 |
| <b>Condensing unit</b>           |      |                 |               |            |          |           |     |     |         |                             |
| 4                                | 1    | Ducane          | AC10B18       | 268209820  |          | G         |     |     | R-22    |                             |
| <b>Domestic Hot Water Heater</b> |      |                 |               |            |          |           |     |     |         |                             |
| 5                                | 1    |                 |               |            | 6 gallon | E         |     |     |         | 1.5 KW                      |

|               |
|---------------|
| E = Excellent |
| G = Good      |
| P = Poor      |