

**TABERNACLE TOWNSHIP  
MUNICIPAL BUILDING  
ENERGY ASSESSMENT**

**for**

**NEW JERSEY  
BUREAU OF PUBLIC UTILITIES**

**CHA PROJECT NO. 21063**

June 2010

Prepared by:

**CLOUGH HARBOUR & ASSOCIATES LLP**

6 Campus Drive  
Parsippany, NJ 07054

(973) 538-2120

---

## TABLE OF CONTENTS

	<u>Page</u>
<b>1.0 INTRODUCTION &amp; BACKGROUND.....</b>	<b>1</b>
<b>2.0 EXECUTIVE SUMMARY.....</b>	<b>2</b>
<b>3.0 EXISTING CONDITIONS.....</b>	<b>3</b>
3.1 Building General	
3.2 Utility Usage	
3.3 HVAC Systems	
3.4 Control Systems	
3.5 Lighting/Electrical Systems	
3.6 Plumbing Systems	
<b>4.0 ENERGY CONSERVATION MEASURES.....</b>	<b>5</b>
4.1 ECM-1 Furnace Replacement	
4.2 ECM-2 Modify Night Setback	
4.3 ECM-3 Replace Windows	
4.4 ECM-4 Lighting Replacements	
<b>5.0 INCENTIVES OVERVIEW.....</b>	<b>8</b>
5.1 Incentives Overview	
5.2 Building Incentives	
<b>6.0 ALTERNATIVE ENERGY EVALUATION.....</b>	<b>10</b>
6.1 Geothermal	
6.2 Solar	
6.3 Wind	
6.4 Combined Heat and Power Generation (CHP)	
6.5 Biomass Power Generation	
6.6 Demand Response Curtailment	
<b>7.0 EPA PORTFOLIO MANAGER.....</b>	<b>15</b>
<b>8.0 CONCLUSIONS &amp; RECOMMENDATIONS.....</b>	<b>16</b>

---

## **APPENDICES**

- A Utility Usage Analysis
  - B ECM-1 Furnace Replacement
  - C ECM-2 Modify Night Setback Times
  - D ECM-3 Replace Windows
  - E ECM-4 Lighting Replacements
  - F New Jersey Incentive Program
  - G Photovoltaic (PV) Rooftop Solar Power Generation
  - H Solar Thermal Domestic Hot Water Plant
  - I Wind
  - J EPA Portfolio Manager
  - K Equipment Inventory
-

## **1.0 INTRODUCTION AND BACKGROUND**

The municipal building was constructed in 1875. The two story, 3,400 square foot structure, located at 163 Carranza Road in Tabernacle, New Jersey, includes the town courtroom and administrative offices.

New Jersey's Clean Energy Program, funded by the New Jersey Board of Public Utilities, supports energy efficiency and sustainability for Municipal and Local Government Energy Audits. Through the support of a utility trust fund, New Jersey is able to assist state and local authorities in reducing energy consumption while increasing comfort.

## 2.0 EXECUTIVE SUMMARY

This report summarizes the energy audit for the Tabernacle, New Jersey municipal building. The two story, 3,400 square foot facility includes the town courtroom and administrative offices. The following areas were evaluated for energy conservation measures:

- Lighting replacement
- Night setback
- Window replacement
- Furnace replacement

Various potential Energy Conservation Measures (ECMs) were identified for the above categories. Measures which are recommended for implementation have a payback of 10 years or less. This threshold is considered a viable return on investment. Potential annual savings of \$1,100 for the recommended ECMs may be realized with a payback of 4.8 years.

The ECMs identified in this report will allow for the building to reduce its energy usage and if pursued has the opportunity to qualify for the New Jersey SmartStart Buildings Program. A summary of the costs, savings, and paybacks for the recommended ECMs follows:

### ECM-2 Modify Night Setback

Budgetary Cost	Annual Utility Savings					ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Fuel Oil	Gas	Total				
\$	kW	kWh	Gallons	Therms	\$		\$	Years	Years
700	0	330	150	0	300	5.1	NA	2.5	NA

\* There is no incentive available through the New Jersey Smart Start Program for this measure.

### ECM-4 Lighting Replacements

Budgetary Cost	Annual Utility Savings					ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Fuel Oil	Gas	Total				
\$	kW	kWh	Gallons	Therms	\$		\$	Years	Years
4,600	1.7	4,540	0	0	800	1.6	500	5.8	5.1

\* Incentive shown is per the New Jersey Smart Start Program, Prescriptive Lighting Application.

## **3.0 EXISTING CONDITIONS**

### **3.1 Building - General**

The municipal building is a two story, 3,400 square foot structure which houses the town offices and the town courtroom.

The municipal offices operate from 8:00 AM to 4:00 PM five days a week and are occupied by about eight people. The courtroom is in session from 3:00 PM to 8:00 PM two nights per month.

The building's exterior walls consist of siding with wood framed studs, insulation and finished with plaster on the interior. The windows on the ground floor have been replaced; however, the second floor windows are single pane, uninsulated, and in poor condition. The roof has shingles on the exterior with several inches of batt insulation.

### **3.2 Utility Usage**

Utilities include electricity and fuel oil. Electricity is purchased from Atlantic City Electric and fuel oil is purchased from the Majestic Oil Company. The building has a well outside and does not pay for water.

From January 2009 through December 2009, electric usage was approximately 32,080 kWh at a cost of about \$6,000. Analyzing electricity bills during this period, the building was charged at a demand unit cost of \$19.00 per kW; and a blended unit cost of \$0.17 per kWh. Electricity usage was highest in the summer months due to air conditioning equipment. In 2009 the building heat required about 740 gallons of oil. Based on the annual cost of about \$1,400, the blended price per gallon was \$1.86. Fuel oil consumption is highest in the winter months to heat the building. Utility data can be found in Appendix A.

Electricity commodity supply and delivery is presently purchased from Atlantic City Electric. The delivery component will always be the responsibility of the utility that connects the facility to the power grid or gas line; however, the supply can be purchased from a third party. The electricity commodity supply entity will require submission of one to three years of past energy bills. Contract terms can vary among suppliers. A list of approved electrical energy commodity suppliers can be found in Appendix A.

### **3.3 HVAC Systems**

#### **3.3.1 Space Heating System**

The building's primary heating plant consists of two, Comfort Air Patriot 80 oil fired forced hot air furnaces located in the basement. These units were installed over 10 years' ago and are in average condition. One unit serves the main floor, the other serves the second level.

#### **3.3.2 Air Conditioning Systems**

The primary AC system consists of one cooling coil attached to each furnace. Each coil is connected to a five ton condensing unit located outside. Building personnel indicated that one condensing unit was installed about five years' ago; the other unit is older and beyond its useful life.

### 3.3.3 Building Ventilation and Exhaust Systems

Primary ventilation is provided by the operable windows throughout the building. The two restroom exhaust fans operate with the light switch in each room.

### 3.4 Control Systems

HVAC controls in this building are from two thermostats, one located on each level. The setpoints are 73°F occupied cooling, 80°F unoccupied cooling; 68°F occupied heating and 62°F unoccupied heating. Each floor is on a schedule with night setback only. The thermostats do not enable weekend schedules; the Monday through Friday schedule operates on Saturday and Sunday.

### 3.5 Lighting/Electrical Systems

The majority of lighting in the building is F34T-12 fixtures that use 34 watts per lamp. These fixtures are either 4' tubes or 2' u-tubes. The exit lights are incandescent.

Lighting in the municipal office areas are controlled by individual switches at the main entrance door. The lighting is left on during normal business hours. Generally, this lighting remains on eight to nine hours daily. There are some fixtures that use incandescent screw-type bulbs that can be easily upgraded.

The few outdoor lighting fixtures are incandescent and are mounted directly to the building. Several other fixtures are owned and maintained by the electrical utility company. These light fixtures are on the power poles around the parking lot, and light the building and lot at night.

### 3.6 Plumbing Systems

Domestic hot water is generated by a 19 gallon electric hot water heater with an input of 1,500 watts. This unit, located in the basement, is in good condition.

There are two restrooms located in the municipal office area of the building on the ground floor. All fixtures are standard high flow type.

## 4.0 ENERGY CONSERVATION MEASURES

### 4.1 ECM-1 Furnace Replacement

Space heating is provided by two, fuel oil fired, Comfort Air Patriot 80 furnaces. This ECM evaluates replacing both furnaces with two high efficiency, condensing furnaces along with new gas service to the building. The local gas utility, South Jersey Gas, was contacted and they stated that new gas service and meter to this building would be provided from the street at no charge. Modern condensing furnaces operate at much higher efficiencies and change fan speeds due to part load conditions, enabling the furnace to provide heat more accurately to match the changing building load, which saves energy.

Review of the fuel oil utility bills determined this building consumed about 740 gallons of fuel oil annually. With estimated average efficiencies of 95%, the proposed new gas fired condensing furnaces will require approximately 970 therms to meet the heat load, resulting in a savings of about \$200 per year. The proposed boiler efficiency rating is based on the use of two Rheem high efficiency 95% natural gas furnaces with 90,000 Btuh input. These furnaces were used as a direct replacement for the existing furnaces.

In addition to the two new condensing furnaces, other components of this measure include new direct vent flue system and new gas piping to each unit.

Condensing furnaces have an expected life of 18 years, according to ASHRAE, and total energy savings over the life of the project are estimated at 13,300 gallons fuel oil and (17,530) therms, totaling \$10,000.

The implementation cost and savings related to this ECM are presented in Appendix B and summarized below:

#### ECM-1 Furnace Replacement

Budgetary Cost	Annual Utility Savings					ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Fuel Oil	Gas	Total				
\$	kW	kWh	Gallons	Therms	\$		\$	Years	Years
14,300	0	0	740	(970)	200	(0.8)	600	>25	>25

\* Incentive shown is per the New Jersey Smart Start Program, Gas Heating Application.

This measure is not recommended.

### 4.2 ECM-2 Modify Night Setback

The HVAC system controls are based upon standard programmable thermostats for heating and cooling; some provisions have been made for temperature setback during unoccupied times. By replacing the older thermostats with new 7 day programmable models, the times of occupied and unoccupied modes can be changed to save heating and cooling energy. This ECM models the expected savings of adjusting the hours of the unoccupied temperature setpoints to include both weekend days. The current setpoints are 62°F for unoccupied heating, and 80°F during unoccupied cooling. In the calculations for this measure, occupied temperature setpoints were maintained per those in use at the time of the energy audit.

To calculate the benefits of increased setback hours, a block load building model was created to approximate the existing energy load for the building. The block load, provided in Appendix C, models the maximum overall cooling and heating load for the building, taking into account various parameters such as roof, wall, and window construction; total envelope surface area; ventilation and infiltration loads; building occupancy; internal heat generation; and other sources of heat gains and losses. By entering this calculated maximum load into a spreadsheet containing bin temperature data, the total accumulated year-round cooling and heating energy requirements were determined. The heating and cooling loads for the building were then reconciled to building utility data and HVAC equipment energy requirements to confirm the model's accuracy. The bin temperature spreadsheets are included in Appendix C.

The difference in heating therms and cooling kWh between the initial and proposed models is taken as the savings. Following implementation of this measure, it is expected the building's annual fuel oil and electricity consumption will be reduced by approximately 150 gallons and 330 kWh, respectively.

Programmable thermostats have an expected life of 15 years, according to ASHRAE, and total energy savings over the life of the project are estimated at 2,280 gallons and 4,870 kWh, totaling \$4,300.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

**ECM-2 Modify Night Setback**

Budgetary Cost	Annual Utility Savings					ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Fuel Oil	Gas	Total				
\$	kW	kWh	Gallons	Therms	\$		\$	Years	Years
700	0	330	150	0	300	5.1	NA	2.5	NA

\* There is no incentive available through the New Jersey Smart Start Program for this measure.

This measure is recommended.

**4.3 ECM-3 Replace Windows**

The second floor windows are double pane glass with an aluminum frame; they are old and leaking. The windows incur increased infiltration, cold drafts, and heat loss. This ECM evaluates replacement with new energy efficient windows.

It was estimated that the existing windows have a combined U-value of 0.8 and an infiltration rate of about 0.3 CFM/LF. To calculate the savings for this measure, the baseline energy loss was found by applying these values to the total square footage and perimeter length of the existing windows for the second floor only, in conjunction with weather bin data. The proposed energy loss was then determined using the expected U-value of 0.45 and infiltration rate of 0.2 CFM/LF for the new energy efficient windows. The difference in heating and cooling losses through the windows results in an annual savings of about 80 gallons of oil and 40 kWh.

Windows have an expected life of 25 years, according to the manufacturer, and total energy savings over the life of the project are estimated at 2,030 gallons and 950 kWh, totaling \$2,500.

The implementation cost and savings related to this ECM are presented in Appendix D and summarized below:

**ECM-3 Replace Windows**

Budgetary Cost	Annual Utility Savings					ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Fuel Oil	Gas	Total				
\$	kW	kWh	Gallons	Therms	\$		\$	Years	Years
42,800	0	40	80	0	100	(0.9)	NA	>25	NA

\* There is no incentive available through the New Jersey Smart Start Program for this measure.

This measure is not recommended.

**4.4 ECM-4 Lighting Replacements**

A comprehensive lighting fixture survey was conducted of the entire building. Each switch and circuit was identified, and the number of fixtures, locations, and existing wattage established. The majority of the lighting in the facility utilizes T-12 lamps with magnetic ballasts, which are regarded as inefficient by today’s standards. In addition, the existing exit signs utilize older, incandescent technology, which can be upgraded to more efficient lighting technology.

Energy savings for this measure were calculated by applying the existing and proposed fixture wattages to the estimated time of operation. The difference resulted in an annual savings of 4,600 kWh per year. Supporting calculations, including all assumptions for lighting hours and the annual energy usage for each fixture is provided in Appendix E.

Retrofitting fixtures that utilize T-12 lamps would require replacement with electronic ballasts and T-8 lamps. Incandescent lamps would be replaced with compact fluorescent spiral lightbulbs. Exit signs will be replaced with LED type signs.

Lighting has an expected life of 15 years, according to the manufacturer, and total energy savings over the life of the project are estimated at 68,070 kWh, totaling \$12,000.

The implementation cost and savings related to this ECM are presented in Appendix E and summarized below:

**ECM-4 Lighting Replacements**

Budgetary Cost	Annual Utility Savings					ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Fuel Oil	Gas	Total				
\$	kW	kWh	Gallons	Therms	\$		\$	Years	Years
4,600	1.7	4,540	0	0	800	1.6	500	5.8	5.1

\* Incentive shown is per the New Jersey Smart Start Program, Prescriptive Lighting Application.

This measure is recommended.

## 5.0 PROJECT INCENTIVES

### 5.1 Incentives Overview

#### 5.1.1 New Jersey Pay For Performance Program

The building will be eligible for incentives from the New Jersey Office of Clean Energy. The most significant incentives will be from the New Jersey Pay for Performance (P4P) Program. The P4P program is designed for qualified energy conservation projects in facilities whose demand in any of the preceding 12 months exceeds 200 kW. Facilities that meet this criterion must also achieve a minimum performance target of 15% energy reduction by using the EPA Portfolio Manager benchmarking tool before and after implementation of the measure(s). If the participant is a municipal electric company customer, and a customer of a regulated gas New Jersey Utility, only gas measures will be eligible under the Program. American Recovery and Reinvestment Act (ARRA) funding, when available, may allow oil, propane and municipal electric customers to be eligible for the P4P Program. Available incentives are as follows:

**Incentive #1: Energy Reduction Plan** – This incentive is designed to offset the cost of services associated with the development of the Energy Reduction Plan (ERP). The standard incentive pays \$0.10 per square foot, up to a maximum of \$50,000, not to exceed 50% of facility annual energy cost, paid after approval of application. For building audits funded by the New Jersey Board of Public Utilities, which receive an initial 75% incentive toward performance of the energy audit, facilities are only eligible for an additional \$0.05 per square foot, up to a maximum of \$25,000, rather than the standard incentive noted above.

**Incentive #2: Installation of Recommended Measures** – This incentive is based on projected energy saving and designed to pay approximately 60% of the total performance-based incentive. Base incentives deliver \$0.11/kWh and \$1.10/therm not to exceed 30% of total project cost.

**Incentive #3: Post-Construction Benchmarking Report** – This incentive is paid after acceptance of a report proving energy savings over one year utilizing the Environmental Protection Agency (EPA) Portfolio Manager benchmarking tool. Incentive #3 base incentives deliver \$0.07/kWh and \$0.70/therm not to exceed 20% of total project cost.

Combining incentives #2 and #3 will provide a total of \$0.18/ kWh and \$1.8/therm not to exceed 50% of total project cost. Additional incentives for #2 and #3 are increased by \$0.005/kWh and \$0.05/therm for each percentage increase above the 15% minimum target to 20%, calculated with the EPA Portfolio Manager benchmarking tool, not to exceed 50% of total project cost.

A new incentive structure is in place for projects exceeding 20% in energy savings, which doubles incentives #2 and #3 for a total of \$0.36/kWh and \$3.60/therm. For Incentive #1, the maximum incentive has been raised to 80% of project costs, or \$2 million per gas account and \$2 million per electric account. The 200 kW/month average minimum has been waived for buildings owned by local governments or municipalities and non-profit organizations. This new incentive structure has been extended to December 31, 2010.

#### 5.1.2 New Jersey Smart Start Program

For this program, specific incentives for energy conservation measures are calculated on an individual basis utilizing the 2010 New Jersey Smart Start incentive program. This program provides incentives

dependent upon mechanical and electrical equipment. If applicable, incentives from this program are reflected in the ECM summaries and attached appendices.

If the building qualifies and enters into the New Jersey Pay for Performance Program, all energy savings will be included in the total building energy reduction, and savings will be applied towards the Pay for Performance incentive. A project is not applicable for both New Jersey incentive programs.

## **5.2 Building Incentives**

### **5.2.1 New Jersey Pay For Performance Program**

Under incentive #1 of the New Jersey Pay for Performance Program, the 3,400 square foot building is eligible for about \$200 towards the development of an Energy Reduction Plan. When calculating the total amount under Incentives #2 and #3, all energy conservation measures are applicable as the amount received is based on building wide energy improvements. Since the overall energy reduction for the building is not estimated to exceed the 15% minimum, the facility is ineligible for Incentives #2 and #3 as previously discussed. See Appendix F for calculations.

### **5.2.2 New Jersey Smart Start Program**

The Tabernacle municipal building is eligible for several incentives available under New Jersey Smart Start Programs. The total amount of all qualified incentives is about \$1,100 and includes upgrades to the lighting system and new furnaces.

Incentives cannot be accepted under multiple programs.

## 6.0 ALTERNATIVE ENERGY SCREENING EVALUATION

### 6.1 Geothermal

Geothermal heat pumps (GHP) transfer heat between the constant temperature of the earth and the building to maintain the building's interior space conditions. Below the surface of the earth throughout New Jersey the temperature remains in the low 50°F range throughout the year. This stable temperature provides a source for heat in the winter and a means to reject excess heat in the summer. With GHP systems, water is circulated between the building and the piping buried in the ground. The ground heat exchanger in a GHP system is made up of a closed or open loop pipe system. Most common is the closed loop in which high density polyethylene pipe is buried horizontally at 4-6 feet deep or vertically at 100 to 400 feet deep. These pipes are filled with an environmentally friendly antifreeze/water solution that acts as a heat exchanger. In the summer, the water picks up heat from the building and moves it to the ground. In the winter the system reverses and fluid picks up heat from the ground and moves it to the building. Heat pumps make collection and transfer of this heat to and from the building possible.

This building uses oil fired furnaces to meet the HVAC requirements. Most of the existing equipment is not compatible with a geothermal energy source. Therefore, to take advantage of a GHP system, the existing mechanical equipment would have to be removed or overhauled; and either a low temperature closed loop water source heat pump system or a water to water heat pump system would have to be installed to realize the benefit of the consistent temperature of the ground.

This measure is not recommended due to the extent of HVAC system renovation needed for implementation.

### 6.2 Solar

#### 6.2.1 Photovoltaic Rooftop Solar Power Generation

The municipal building was evaluated for the potential to install rooftop photovoltaic (PV) solar panels for power generation. Present technology incorporates the use of solar cell arrays that produce direct current (DC) electricity. This DC current is converted to alternating current (AC) with the use of an electrical device known as an inverter.

The PVWATTS solar power generation model was utilized to calculate PV power generation. The New Jersey Clean Power Estimator provided by the New Jersey Clean Energy Program is presently being updated; therefore, the site recommended use of the PVWATT solar grid analyzer version 1. The closest city available in the model is Philadelphia, Pennsylvania and a fixed tilt array type was utilized to calculate energy production. The PVWATT solar power generation model is provided in Appendix G.

The State of New Jersey incentives for non-residential PV applications is \$1.00/watt up to 50 kW of installed PV array. Federal tax credits are also available for renewable energy projects up to 30% of installation cost. Municipalities do not pay federal taxes; therefore, would not be able to utilize the federal tax credit incentive.

Installation of (PV) arrays in the state New Jersey will allow the owner to participate in the New Jersey solar renewable energy certificates program (SREC). This is a program that has been set up to allow entities with large amounts of environmentally unfriendly emissions to purchase credits from zero emission (PV) solar-producers. An alternative compliance penalty (ACP) is paid for by the high emission

producers and is set each year on a declining scale of 3% per year. One SREC credit is equivalent to 1000 kilowatt hours of PV electrical production; these credits can be traded for period of 15 years from the date of installation. The cost of the ACP penalty for 2009 is \$700; this is the amount that must be paid per SERC by the high emission producers. Payments that will be received from the PV producer will change from year to year dependent upon supply and demand. Renewable Energy Consultants is a third party SREC broker that has been approved by the New Jersey Clean Energy Program. As stated above there is no definitive way to calculate an exact price that will be received by the PV producer per SREC over the next 15 years. Renewable Energy Consultants estimated an average of \$487/ SERC per year and this number was utilized in the cash flow for this report.

The building had a maximum electricity demand of 19.0 kW and a minimum of 11.8 kW, from January 2009 through December 2009. The monthly average over the observed 12 month period was 15.6 kW. The existing load justifies the use of 12 kW of installed PV solar array. The system costs for PV installations were derived from the most recent NYSERDA (New York State Energy Research and Development Agency) estimates of total cost of system installation. It should be noted that the cost of installation for a system of this size is currently estimated at \$7 per watt or \$7,000 per kW of installed system. This has increased in the past few years due to the rise in national demand for PV power generator systems. Other cost considerations will also need to be considered. PV panels have an approximate 20 year life span; however, the inverter device that converts DC electricity to AC has a life span of 10 to 12 years and will need to be replaced multiple times during the useful life of the PV system.

The implementation cost and savings related to this ECM are presented in Appendix G and summarized below:

**Photovoltaic (PV) Rooftop Solar Power Generation – 12 kW System**

Budgetary Cost	Annual Utility Savings			Total Savings	New Jersey Renewable Energy Incentive*	New Jersey Renewable SREC**	Payback (without incentive)	Payback (with incentives)	
	Electricity		Natural Gas						Total
\$	kW	kWh	Therms	\$	\$	\$	Years	Years	
84,000	0	14,470	0	2,500	2,500	12,000	7,000	>25	7.6

\*Incentive based on New Jersey Renewable Energy Program for non-residential applications of \$1.00 per Watt of installed capacity

\*\* Estimated Solar Renewable Energy Certificate Program (SREC) for 15 years at \$487/1000 kWh

While the payback period justifies recommendation of the measure, further investigation of possible installation locations, required system maintenance, and local installation costs are suggested prior to implementation.

**6.2.2 Solar Thermal Hot Water Plant**

Active solar thermal systems use solar collectors to gather the sun’s energy to heat water, another fluid, or air. An absorber in the collector converts the sun’s energy into heat. The heat is then transferred by circulating water, antifreeze, or sometimes air to another location for immediate use or storage for later utilization. Applications for active solar thermal energy include providing hot water, heating swimming pools, space heating, and preheating air in residential and commercial buildings.

A standard solar hot water system is typically composed of solar collectors, heat storage vessel, piping, circulators, and controls. Systems are typically integrated to work alongside a conventional heating

system that provides heat when solar resources are not sufficient. The solar collectors are usually placed on the roof of the building, oriented south, and tilted around the site's latitude, to maximize the amount of radiation collected on a yearly basis.

Several options exist for using active solar thermal systems for space heating. The most common method involves using glazed collectors to heat a liquid held in a storage tank (similar to an active solar hot water system). The most practical system would transfer the heat from the panels to thermal storage tanks and transfer solar produced thermal energy to use for domestic hot water production. DHW is presently produced by a natural gas fired water heater and, therefore, this measure would not save site electricity.

Currently, an incentive is not available for installation of thermal solar systems. A Federal tax credit of 30% of installation cost for the thermal applications is available; however, the Township of Tabernacle does not pay Federal taxes and, therefore, would not benefit from this program.

The implementation cost and savings related to this ECM are presented in Appendix H and summarized as follows:

#### Solar Thermal Domestic Hot Water Plant

Budgetary Cost	Annual Utility Savings			Total Savings	New Jersey Renewable Energy Incentive	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas				
\$	kW	kWh	Therms	\$	\$	Years	Years
27,100	0	2,510	0	400	400	NA	>25

\* No incentive is available in New Jersey at this time.

This measure is not recommended.

### 6.3 Wind

Small wind turbines use a horizontal axis propeller, or rotor, to capture the kinetic energy of the wind and convert it into rotary motion to drive a generator which usually is designed specifically for the wind turbine. The rotor consists of two or three blades, usually made from wood or fiberglass. These materials give the turbine the needed strength and flexibility, and have the added advantage of not interfering with television signals. The structural backbone of the wind turbine is the mainframe, and includes the slip-rings that connect the wind turbine, which rotates as it points into changing wind directions, and the fixed tower wiring. The tail aligns the rotor into the wind.

To avoid turbulence and capture greater wind energy, turbines are mounted on towers. Turbines should be mounted at least 30 feet above any structure or natural feature within 300 feet of the installation. Smaller turbines can utilize shorter towers. For example, a 250-watt turbine may be mounted on a 30-50 foot tower, while a 10 kW turbine will usually need a tower of 80-120 feet. Tower designs include tubular or latticed, guyed or self-supporting. Wind turbine manufacturers also provide towers.

The New Jersey Clean Energy Program for small wind installations has designated numerous pre-approved wind turbines for installation in the State of New Jersey. Incentives for wind turbine installations are based on kilowatt hours saved in the first year. Systems sized under 16,000 kWh per year of production will receive a \$3.20 per kWh incentive. Systems producing over 16,000 kWh will receive \$51,200 for the first 16,000 kWh of production with an additional \$0.50 per kWh up to a maximum cap

of 750,000 kWh per year. Federal tax credits are also available for renewable energy projects up to 30% of installation cost for systems less than 100 kW. However, as noted previously, municipalities do not pay federal taxes and is, therefore, not eligible for the tax credit incentive.

The most important part of any small wind generation project is the mean annual wind speed at the height of which the turbine will be installed. In the Tabernacle, NJ area, the map indicates a mean annual wind speed of just under 10 miles per hour. For the municipal building, there are site restrictions. Parking lots, trees and surrounding structures would greatly affect a tower location.

A wind speed map and aerial site photo are included in Appendix I.

This measure is not recommended due to the low mean annual wind speed and site restrictions.

#### **6.4 Combined Heat and Power Generation (CHP)**

Combined heat and power, cogeneration, is self-production of electricity on-site with beneficial recovery of the heat byproduct from the electrical generator. Common CHP equipment includes reciprocating engine-driven, micro turbines, steam turbines, and fuel cells. Typical CHP customers include industrial, commercial, institutional, educational institutions, and multifamily residential facilities. CHP systems that are commercially viable at the present time are sized approximately 50 kW and above, with numerous options in blocks grouped around 300 kW, 800 kW, 1,200 kW and larger. Typically, CHP systems are used to produce a portion of the electricity needed by a facility some or all of the time, with the balance of electric needs satisfied by purchase from the grid.

Any proposed CHP project will need to consider many factors, such as existing system load, use of thermal energy produced, system size, natural gas fuel availability, and proposed plant location. The municipal building does not have sufficient need for electrical generation and the ability to use most of the thermal byproduct during the winter, thermal usage during the summer months is low. Thermal energy produced by the CHP plant in the warmer months will be wasted. Purchasing this system and performing modifications to the existing HVAC and electrical systems would greatly outweigh the savings over the life of the equipment.

This measure is not recommended.

#### **6.5 Biomass Power Generation**

Biomass power generation is a process in which waste organic materials are used to produce electricity or thermal energy. These materials would otherwise be sent to the landfill or expelled to the atmosphere. To participate in NJCEP's Customer On-Site Renewable Energy program, participants must install an on-site sustainable biomass or fuel cell energy generation system. Incentives for bio-power installations are available to support up to 1MW-dc of rated capacity.

\*Class I organic residues are eligible for funding through the NJCEP CORE program. Class I wastes include the following renewable supply of organic material:

- Wood wastes not adulterated with chemicals, glues or adhesives
- Agricultural residues (corn stover, rice hulls or nut shells, manures, poultry litter, horse manure, etc) and/or methane gases from landfills
- Food wastes

- Municipal tree trimming and grass clipping wastes
- Paper and cardboard wastes
- Non adulterated construction wood wastes, pallets

The NJDEP evaluates biomass resources not identified in the RPS.

Examples of eligible facilities for a CORE incentive include:

- Digestion of sewage sludge
- Landfill gas facilities
- Combustion of wood wastes to steam turbine
- Gasification of wood wastes to reciprocating engine
- Gasification or pyrolysis of bio-solid wastes to generation equipment

\* from NJOCE Website

This measure is not recommended because of noise issues, potential zoning issues, and because the municipal building does not have a steady waste stream to fuel the power generation system. Additionally, purchasing this system and performing modifications to the existing HVAC and electrical systems would greatly outweigh the savings over the life of the equipment.

## **6.6 Demand Response Curtailment**

Utility Curtailment is an agreement with the electric utility company and an approved Curtailment Service Provider (CSP) to shed electrical load by either turning major equipment off or energizing all or part of a facility utilizing an emergency generator; therefore, reducing the electrical demand on the utility grid. This program is to benefit the utility company during high demand periods and incentives are offered to the CSP to participate in this program. Enrolling in the program will require program participants to drop electrical load or turn on emergency generators during high electrical demand conditions or during emergencies. Part of the program also will require that program participants reduce their required load or run emergency generators with notice to test the system.

A pre-approved CSP will require a minimum of 100 kW of load reduction to participate in any curtailment program. The building had a maximum electricity demand of 19.0 kW and an average of 15.6 kW, in 2009.

This measure is not recommended because the facility does not have an adequate load to meet the minimum load reduction requirement.

## 7.0 EPA PORTFOLIO MANAGER

The United State Environmental Protection Agency (EPA) is a federal agency in charge of regulating environment waste and policy in the United States. The EPA has released the EPA Portfolio Manager for public use. The program is designed to allow property owners and managers to share, compare and improve upon their facility's energy consumption. Inputting such parameters as electricity, heating fuel, building characteristics and location into the website based program generates a naturalized energy rating score out of 100. Once an account is registered, monthly utility data can be entered to track the savings progress and retrieve an updated energy rating score on a monthly basis.

The municipal building is considered a low energy consumer per the Portfolio Manager with a Site Energy Usage Index (EUI) of 72 kBTU/ft<sup>2</sup>/year. However, several building characteristic such as poorly insulated windows, unnecessary heating and cooling during unoccupied hours, and inefficient lighting, could be addressed to further reduce the Site EUI. Should all ECMs be implemented, it is expected that the Site EUI can be reduced to about 59 kBTU/ft<sup>2</sup>/year. The EPA Portfolio Manager did not generate an energy rating score for this building because the minimum size of the building needs to be 5,000 sq ft.

A full EPA Energy Star Portfolio Manager Report is located in Appendix J. The user name and password for the municipal building's EPA Portfolio Manager Account has been provided to Douglas Cramer of the Township of Tabernacle.

## 8.0 CONCLUSIONS & RECOMMENDATIONS

The energy audit conducted by CHA at the Tabernacle municipal building, in Tabernacle, New Jersey identified potential ECMs for lighting retrofits and night setback. Potential annual savings of \$1,100 may be realized for the recommended ECMs, with a summary of the costs, savings, and paybacks as follows:

### ECM-2 Modify Night Setback

Budgetary Cost	Annual Utility Savings					ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Fuel Oil	Gas	Total				
\$	kW	kWh	Gallons	Therms	\$		\$	Years	Years
700	0	330	150	0	300	5.1	NA	2.5	NA

\* There is no incentive available through the New Jersey Smart Start Program for this measure.

### ECM-4 Lighting Replacements

Budgetary Cost	Annual Utility Savings					ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Fuel Oil	Gas	Total				
\$	kW	kWh	Gallons	Therms	\$		\$	Years	Years
4,600	1.7	4,540	0	0	800	1.6	500	5.8	5.1

\* Incentive shown is per the New Jersey Smart Start Program, Prescriptive Lighting Application.

## **APPENDIX A**

### **Utility Usage Analysis**




**New Jersey BPU Energy Audit Program  
CHA #21063  
Tabernacle Township  
Municipal Building**

**Account Number:** 0039-6829-9994  
**Atlantic City Electric**

Date	Consumption		Demand		Charges			Unit Costs		
	(kWh)	(kW)	Total (\$)	Demand (\$)	Consumption (\$)	Blended Rate (\$/kWh)	Consumption (\$/kWh)	Demand (\$/kW)		
01/05/09	2996	11.8	\$ 462	\$31.00	\$431.00	0.1542	0.1439	2.63		
02/02/09	2617	11.8	423	\$37.00	\$386.00	0.1616	0.1475	3.14		
03/04/09	2816	13	450	\$37.00	\$413.00	0.1598	0.1467	2.85		
04/02/09	2313	12	375	\$32.00	\$343.00	0.1621	0.1483	2.67		
05/05/09	2370	19	380	\$113.00	\$267.00	0.1603	0.1127	5.95		
06/04/09	2451	12	414	\$35.00	\$379.00	0.1689	0.1546	2.92		
07/06/09	2654	18.2	524	\$0.00	\$524.00	0.1974	0.1974	-		
08/04/09	3785	17.9	744	\$0.00	\$744.00	0.1966	0.1966	-		
09/02/09	3410	18	671	\$0.00	\$671.00	0.1968	0.1968	-		
10/02/09	2525	17.9	494	\$0.00	\$494.00	0.1956	0.1956	-		
11/03/09	2043	17.8	348	\$0.00	\$348.00	0.1703	0.1703	-		
12/03/09	2100	17.9	357	\$0.00	\$357.00	0.1700	0.1700	-		
<b>Total</b>	<b>32,080</b>	<b>19.0</b>	<b>\$5,642.00</b>	<b>\$285.00</b>	<b>\$5,357.00</b>	<b>0.1759</b>	<b>0.1670</b>	<b>1.52</b>		
<b>Most Recent Yr</b>	<b>32,080</b>	<b>19.0</b>	<b>\$5,642.00</b>	<b>\$285.00</b>	<b>\$5,357.00</b>	<b>0.1759</b>	<b>0.1670</b>	<b>1.52</b>		

# Electric Usage - Municipal Building




**New Jersey BPU Energy Audit Program  
CHA #21063  
Tabernacle Township  
Municipal Building**

**Account Number:** 2351  
**Majestic Oil Company**

Date	Gallons	Cost	(\$/Gallon)
12/31/08	157	280	\$1.78
01/20/09	170	342	\$2.01
02/06/09	64	\$128	\$2.00
02/06/09	69	\$139	\$2.01
02/18/09	63	\$117	\$1.86
03/10/09	166	\$283	\$1.70
05/07/09	50	\$88	\$1.76

Total	739	\$1,377.00	1.863
Most Recent Yr	739	\$1,377.00	1.863

# Gallons Oil Purchased - Municipal Building



## ELECTRIC MARKETERS LIST

The following is a listing of marketers/suppliers/brokers that have been licensed by the NJ Board of Public Utilities to sell electricity to residential, small commercial and industrial customers served by the Public Service Electric and Gas Company distribution system. **This listing is provided for informational purposes only and PSE&G makes no representations or warranties as to the competencies of the entities listed herein or to the completeness of this listing.**

American Powernet Management  
867 Berkshire Blvd, Suite 101  
Wyomissing, PA 19610  
[www.americanpowernet.com](http://www.americanpowernet.com)

Gerda Ameristeel Energy Co.  
North Crossman Road  
Sayreville, NJ 08872

PPL EnergyPlus, LLC  
Energy Marketing Center  
Two North Ninth Street  
Allentown, PA 18101  
1-866-505-8825  
<http://www.pplenergyplus.com/>

BOC Energy Services  
575 Mountain Avenue  
Murray Hill, NJ 07974  
[www.boc-gases.com](http://www.boc-gases.com)

Gexa Energy LLC New Jersey  
20 Greenway Plaza, Suite 600  
Houston, TX 77046  
(866) 304-GEXA  
[Beth.miller@gexaenergy.com](mailto:Beth.miller@gexaenergy.com)

Sempra Energy Solutions  
The Mac-Cali Building  
581 Main Street, 8<sup>th</sup> Floor  
Woodbridge, NJ 07095  
(877) 273-6772  
[www.SempraSolutions.com](http://www.SempraSolutions.com)

Commerce Energy Inc.  
535 Route 38, Suite 138  
Cherry Hill, NJ 08002  
(888) 817-8572 or  
(858) 910-8099  
[www.commerceenergy.com](http://www.commerceenergy.com)

Glacial Energy of New Jersey  
2602 McKinney Avenue, Suite 220  
Dallas, TX 75204  
[www.glacialenergy.com](http://www.glacialenergy.com)

South Jersey Energy Company  
1 South Jersey Plaza, Route 54  
Folsom, NJ 08037  
(800) 756-3749  
[www.sjindustries.com](http://www.sjindustries.com)

ConEdison Solutions  
701 Westchester Avenue  
Suite 201 West  
White Plains, NY 10604  
(800) 316-8011  
[www.ConEdSolutions.com](http://www.ConEdSolutions.com)

Hess Corporation  
1 Hess Plaza  
Woodbridge, NJ 07095  
[www.hess.com](http://www.hess.com)

Strategic Energy, LLC  
6 East Main Street, Suite 6E  
Ramsey, NJ 07446  
(888) 925-9115  
[www.sel.com](http://www.sel.com)

Constellation NewEnergy, Inc.  
1199 Route 22 East  
Mountainside, NJ 07092  
908 228-5100  
[www.newenergy.com](http://www.newenergy.com)

Integrus Energy Services, Inc.  
99 Wood Avenue, Suite 802  
Iselin, NJ 08830  
[www.integrusenergy.com](http://www.integrusenergy.com)

Suez Energy Resources NA  
333 Thornall Street FL6  
Edison, NJ 08818  
866.999.8374(toll free)  
[www.suezenergyresources.com](http://www.suezenergyresources.com)

Credit Suisse (USA), Inc.  
700 College Road East  
Princeton, NJ 08450  
[www.creditsuisse.com](http://www.creditsuisse.com)

Liberty Power Delaware, LLC  
1901 W Cypress Road, Suite 600  
Fort Lauderdale, FL 33309  
(866) Power-99  
(866) 769-3799  
[www.libertypowercorp.com](http://www.libertypowercorp.com)

UGI Energy Services, Inc.  
d/b/a POWERMARK  
1 Meridian Blvd. Suite 2C01  
Wyomissing, PA 19610  
(800) 427-8545  
[www.ugienergyservices.com](http://www.ugienergyservices.com)

Direct Energy Services, LLC  
One Gateway Center, Suite 2600  
Newark, NJ 07102  
(973) 799-8568  
[www.directenergy.com](http://www.directenergy.com)

Liberty Power Holdings, LLC  
1901 W Cypress Creek Road, Suite 600  
Fort Lauderdale, FL 33309  
(866) Power-99  
(866) 769-3799  
[www.libertypowercorp.com](http://www.libertypowercorp.com)

FirstEnergy Solutions  
395 Ghent Road Suite 407  
Akron, OH 44333  
(800) 977-0500  
[www.fes.com](http://www.fes.com)

Pepco Energy Services, Inc.  
d/b/a Power Choice  
23 S. Kinderkamack Rd Ste D  
Montvale, NJ 07645  
(800) 363-7499  
[www.pepco-services.com](http://www.pepco-services.com)

## **APPENDIX B**

### **ECM-1 Furnace Replacement**



Tabernacle Township  
 CHA #-21063  
 Building: Municipal Building

**ECM-1 Furnace Replacement & New Gas Service**

Existing Fuel	#2 Oil	▼
Proposed Fuel	Nat.Gas	▼

Item	Value	Units	Formula/Comments
Baseline Fuel Cost	\$ 2.01		
Proposed Fuel Cost	\$ 1.20		
Baseline Fuel Use	953	Gals #2	Based on historical utility data
Existing Furnace Efficiency	70%		Estimated
Baseline Load	92,527	Mbtu/yr	Baseline Fuel Use x Existing Efficiency x 138.7 Mbtu/Gals #2
Baseline Fuel Cost	\$ 1,911		
Proposed Efficiency	95%		New Furnace Efficiency
Proposed Fuel Use	1,256	Therms	Baseline Boiler Load / Proposed Efficiency / 100 Mbtu/Therms
Proposed Fuel Cost	\$ 1,507		
Annual Savings	953	Gals #2	
	(1,256)	Therms	
<b>Annual Savings</b>	<b>\$ 404</b>	<b>/yr</b>	



## **APPENDIX C**

### **ECM-2 Modify Night Setback**



Tabernacle Township  
CHA #21063  
Building: Municipal Building

ECM-2 Night Setback

Building Footprint	3,360 SF	Ex Occupied Cing Temp.	73 °F	Ex Occupied Htg Temp.	68 °F	Heating Energy Savings	152 gallons
Heating Efficiency	70%	Ex Unoccupied Cing Temp.	80 °F	Ex Unoccupied Htg Temp.	62 °F	Cooling Energy Savings	213 therms
Cooling Efficiency	1.3 kW/ton	Prop Occupied Cing Temp.	73 °F	Prop Occupied Htg Temp.	68 °F		
Building Balance Temp.	60 °F	Prop Unoccupied Cing Temp.	80 °F	Prop Unoccupied Htg Temp.	60 °F		
Internal Gains	19,340 btu/h	Occupied Cooling UA	-2,105 btu/hr°F	Occupied Heating UA	687 btu/hr°F		
Unoc Internal Gain factor	0.3	Unoccupied Cooling UA	-1,217 btu/hr°F	Unoccupied Heating UA	687 btu/hr°F		
Ave Occ Internal Gain Factor	0.7	Cooling Occ Enthalpy Setpoint	27.5 Btu/lb				
		Cooling Unocc Enthalpy Setpoint	27.5 Btu/lb				

Heating and cooling energy are unrelated in this model. If the building being analyzed is not cooled, disregard cooling energy calculations

Avg Outdoor Air Temp. Bins °F	Avg Outdoor Air Enthalpy	EXISTING LOADS										PROPOSED LOADS						Existing Cooling Energy kWh	Proposed Cooling Energy kWh	Existing Heating Energy therms	Proposed Heating Energy therms	
		Occupied					Unoccupied					Occupied			Unoccupied							
		Bin Hours (total)	Existing Occupied Bin Hours	Remainder Unoccupied Bin Hours	Weekend hrs	Remainder weekend hrs	Envelope Load BTUH	Ventilation Load BTUH	Internal Gain BTUH	Unoccupied Envelope Load BTUH	Ventilation Load BTUH	Internal Gain BTUH	Envelope Load BTUH	Ventilation Load BTUH	Internal Gain BTUH	Unoccupied Envelope Load BTUH	Ventilation Load BTUH					Internal Gain BTUH
A	B	C	D	D-0	D-1	E	F	G	H	I	J	K	L	M	N	O	P	K	L	M	N	
102.5	49.1	0	0	0	0	0	-62,096	-40,858	-13,538	-27,377	-40,858	-5,802	-62,096	-40,858	-13,538	-27,377	-40,858	-5,802	0	0	0	0
97.5	42.5	3	1	2	0	3	-51,571	-28,374	-13,538	-21,293	-28,374	-5,802	-51,571	-28,374	-13,538	-21,293	-28,374	-5,802	21	19	0	0
87.5	36.6	131	37	94	12	119	-30,522	-17,213	-13,538	-9,126	-17,213	-5,802	-30,522	-17,213	-13,538	-9,126	-17,213	-5,802	553	496	0	0
82.5	34	500	143	357	48	452	-19,997	-12,295	-13,538	-3,042	-12,295	-5,802	-19,997	-12,295	-13,538	-3,042	-12,295	-5,802	1,447	1,272	0	0
77.5	31.6	620	177	443	59	561	-9,472	-7,755	-13,538	0	0	-5,802	-9,472	-7,755	-13,538	0	0	-5,802	770	549	0	0
72.5	29.2	664	190	474	63	601	0	0	-13,538	0	0	-5,802	0	0	-13,538	0	0	-5,802	470	470	0	0
67.5	27	854	244	610	81	773	344	227	-13,538	0	0	-5,802	344	227	-13,538	0	0	-5,802	590	600	0	0
62.5	24.5	927	265	662	88	839	3,780	2,497	-13,538	0	0	-5,802	3,780	2,497	-13,538	0	0	-5,802	477	597	0	0
57.5	21.4	600	171	429	57	543	7,216	4,767	-13,538	3,093	2,043	-5,802	7,216	4,767	-13,538	1,718	1,135	-5,802	0	0	0	0
52.5	18.7	610	174	436	58	552	10,653	7,037	-13,538	6,529	4,313	-5,802	10,653	7,037	-13,538	5,154	3,405	-5,802	0	0	55	25
47.5	16.2	611	175	436	58	553	14,089	9,307	-13,538	9,965	6,583	-5,802	14,089	9,307	-13,538	8,591	5,675	-5,802	0	0	104	75
42.5	14.4	656	187	469	62	594	17,525	11,576	-13,538	13,402	8,853	-5,802	17,525	11,576	-13,538	12,027	7,945	-5,802	0	0	166	134
37.5	12.6	1,023	292	731	97	926	20,961	13,846	-13,538	16,838	11,122	-5,802	20,961	13,846	-13,538	15,463	10,215	-5,802	0	0	342	292
32.5	10.7	734	210	524	70	664	24,398	16,116	-13,538	20,274	13,392	-5,802	24,398	16,116	-13,538	18,900	12,484	-5,802	0	0	305	270
27.5	8.6	334	95	239	32	302	27,834	18,386	-13,538	23,711	15,662	-5,802	27,834	18,386	-13,538	22,336	14,754	-5,802	0	0	166	150
22.5	6.8	252	72	180	24	228	31,270	20,656	-13,538	27,147	17,932	-5,802	31,270	20,656	-13,538	25,772	17,024	-5,802	0	0	146	134
17.5	5.5	125	36	89	12	113	34,707	22,926	-13,538	30,583	20,202	-5,802	34,707	22,926	-13,538	29,209	19,294	-5,802	0	0	83	76
12.5	4.1	47	13	34	4	43	38,143	25,196	-13,538	34,019	22,472	-5,802	38,143	25,196	-13,538	32,645	21,564	-5,802	0	0	35	33
7.5	2.6	22	6	16	2	20	41,579	27,466	-13,538	37,456	24,742	-5,802	41,579	27,466	-13,538	36,081	23,834	-5,802	0	0	18	17
2.5	1	13	4	9	1	12	45,016	29,736	-13,538	40,892	27,012	-5,802	45,016	29,736	-13,538	39,518	26,104	-5,802	0	0	12	11
-2.5	0	0	0	0	0	0	48,452	32,005	-13,538	44,328	29,282	-5,802	48,452	32,005	-13,538	42,954	28,374	-5,802	0	0	0	0
-7.5	-1.5	0	0	0	0	0	51,888	34,275	-13,538	47,765	31,551	-5,802	51,888	34,275	-13,538	46,390	30,644	-5,802	0	0	0	0
<b>TOTALS</b>		<b>8,726</b>	<b>2,493</b>	<b>6,233</b>	<b>831</b>	<b>7,895</b>													<b>4,328</b>	<b>4,003</b>	<b>1,430</b>	<b>1,217</b>

Existing Building Ventilation & Infiltration (occ)	420 cfm
Overheat Ventilation Factor	1.00
Additional ventilation to offset overheat	0 cfm
Existing Building Ventilation & Infiltration (unocc)	420 cfm

## HEAT GAIN/LOSS WORKSHEET

Project Name:   
 Location:   
 Building Name:   
 Engineer:

Project No.:   
 Site Elevation:  Feet  
 Date:   
 Specific Volume:  CF/#

Building/Facility Designation:

Outdoor Winter Design DB Temperature: <input type="text" value="14"/> *F	Indoor Winter Design DB Temperature: <input type="text" value="68"/> *F
Outdoor Summer Design DB Temperature: <input type="text" value="91"/> *F	Indoor Summer Design DB Temperature: <input type="text" value="73"/> *F
Outdoor Summer Design WB Temperature: <input type="text" value="73"/> *F	Indoor Summer Design WB Temperature: <input type="text" value="60"/> *F
Outdoor Summer Humidity Ratio: <input type="text" value="0.0121"/> ##	Indoor Air (70°F) Humidity Ratio: <input type="text" value="0.0078"/> ##

**ENVELOPE DESCRIPTIONS (Descriptions are from Interior to Exterior)**

**Walls (Select One - Type X)**

	R Value	Wall Type
<input type="checkbox"/> Steel Siding, 4" Insulation, Steel Siding	15.2	1
<input type="checkbox"/> Plaster or Gypsum, frame construction, 5" Insulation, 1" stucco	18.2	1
<input type="checkbox"/> 4" WH CMU, 1" Insulation, Finished Exterior	5.2	2
<input type="checkbox"/> Plaster or Gypsum, frame construction, 3" Insulation, 8" LW CMU	7.8	5
<input type="checkbox"/> 4" Face Brick, 2" Concrete, 1" Insulation, Exterior Finish	5.1	12
<input type="checkbox"/> 4" Face Brick, 4" Concrete, 1" Insulation, Exterior Finish	4.0	11
<input type="checkbox"/> Interior Finish, 2" Insulation, 8" CMU, 4" Face Brick	10.9	16
<input type="checkbox"/> Finished Surface, 8" LW CMU (filled), Air Space, 4" Face Brick	11.1	16
<input type="checkbox"/> Stucco or Gypsum, 2.5" Insul, Face Brick	14.3	10
<input type="checkbox"/> 4" Block, 1" insulation, 8" Block	19.9	16
<input checked="" type="checkbox"/> Gypsum, Wood framed, Blown Insulation, siding	10.0	

**Roofs (Select One)**

	R Value	Roof Type
<input type="checkbox"/> Tectum Deck, 3.3" Insul., BU Roof	13.0	1
<input type="checkbox"/> Steel Deck, 5" Insul., BU Roof	18.2	1
<input type="checkbox"/> Attic Roof with 6" Insul.	25.0	4
<input type="checkbox"/> 4" HW Concrete Deck, BU Roof	2.7	2
<input type="checkbox"/> Ceiling, 3" Insulation, 4" Concrete Deck, BU Roof	14.9	4
<input type="checkbox"/> Ceiling, 4" Concrete Deck, 3" Insulation, BU Roof	18.5	13
<input type="checkbox"/> Ceiling, 4" Concrete Deck, 6" Insulation, BU Roof	21.7	14
<input checked="" type="checkbox"/> Ceiling, Wood Deck, 6" Insulation, Felt & Membrane	14.0	10
<input type="checkbox"/> Wood Deck, 6" insulation, Felt & Membrane	18.0	
<input type="checkbox"/> Other		

**Windows (Select One)**

	U Value
<input type="checkbox"/> Aluminum Frame, 1/8" SP Glazing	1.05
<input type="checkbox"/> Aluminum Frame, 1/4" DP Glazing	0.60
<input type="checkbox"/> Aluminum Frame, 3/16" DP Glazing	0.62
<input type="checkbox"/> Aluminum Frame, 1/2" DP Glazing	0.50
<input type="checkbox"/> Skylights	0.90
<input checked="" type="checkbox"/> wood framed & single pane	0.70

	No Storm
Flat Glass	1.05
Flat Glass (e=.6)	1.00
Flat Glass (e=0.4)	0.90
Flat Glass (e=0.2)	0.77
Double Glaze (3/16 in air)	0.63
Double Glaze (1/4 in air)	0.60
Double Glaze (1/2 in air)	0.53
Double Glaze (e=.6)	0.50
Double Glaze (e=0.4)	0.42
Double Glaze (e=0.2)	0.35
Triple Glaze (1/4 in air)	0.42
Triple Glaze (1/2 in air)	0.35

**BUILDING CHARACTERISTICS**

Roof Area:  SF  
 Occupied Area:  SF  
 Return Plenum?

	Gross Wall Length	Average Wall Height	Ceiling Height	Window Area	Door Area	Net Wall Area
North Exposure	<input type="text" value="70"/> Ft	<input type="text" value="10.0"/> Ft	<input type="text" value="8.0"/> Ft	<input type="text" value="117"/> SF	<input type="text" value="36"/> SF	547 SF
East Exposure	<input type="text" value="100"/> Ft	<input type="text" value="10.0"/> Ft	<input type="text" value="8.0"/> Ft	<input type="text" value="93"/> SF	<input type="text" value="21"/> SF	886 SF
South Exposure	<input type="text" value="70"/> Ft	<input type="text" value="10.0"/> Ft	<input type="text" value="8.0"/> Ft	<input type="text" value="150"/> SF	<input type="text" value="0"/> SF	550 SF
West Exposure	<input type="text" value="100"/> Ft	<input type="text" value="10.0"/> Ft	<input type="text" value="8.0"/> Ft	<input type="text" value="15"/> SF	<input type="text" value="0"/> SF	985 SF

Forced Ventilation:  cfm

## HEAT GAIN/LOSS WORKSHEET

Project Name: Tabernacle Township  
 Location: \_\_\_\_\_  
 Building Name: Municipal Building  
 Engineer: Frank Cutitta

Project No.: CHA #-21063  
 Site Elevation: 460 Feet  
 Date: \_\_\_\_\_

Specific Volume 13.50 CF/#

Building/Facility Designation General Offices, Tax Office and Administration.

### COOLING HEAT GAINS TO THE ROOM - SENSIBLE

#### SOLAR GAINS

WINDOWS	AREA (SF)	SHGF	Shade Coef	Cooling Load Factor	Glass Type	Solar Heat Gain
North Exposure	117	38 btu/h/sf	0.8	0.75	Glass Type C	2,668 Btu/hr
East Exposure	93	216 btu/h/sf	0.8	0.31	Glass Type C	4,982 Btu/hr
South Exposure	150	109 btu/h/sf	0.8	0.58	Glass Type C	7,586 Btu/hr
West Exposure	15	216 btu/h/sf	0.8	0.29	Glass Type C	752 Btu/hr
						<b>15,988 Btu/h</b>

#### CONDUCTION

	NET AREA (SF)	U-VALUE	Cooling Load Temp. Dif.	Return Air Factor	Room Heat Gain	
North Exposure	407	0.10	20 *F	1.0	814 Btu/hr	
East Exposure	686	0.10	39 *F	1.0	2,675 Btu/hr	
South Exposure	410	0.10	27 *F	1.0	1,107 Btu/hr	
West Exposure	785	0.10	22 *F	1.0	1,727 Btu/hr	
Roof	1,680	0.07	73 *F	1.0	8,760 Btu/hr	
Fenestration	375	0.70	18 *F		4,725 Btu/hr	
Doors	57	0.14	27 *F		215 Btu/hr	
Ceiling	3,360	0.14	0 *F		0 Btu/hr	
Partition	0	0.05	0 *F		0 Btu/hr	
Floor	3,360	0.04	0 *F		0 Btu/hr	
						<b>20,023 Btu/h</b>

#### INTERNAL HEAT GAINS

Lights	1.20 w/sf x 3,360 Occ Area =	4.0 kW x 3.4x	1.0 RAF =	13,761 Btu/h
Plug Load	0.00 w/sf x 3,360 Occ Area =	0.0 kW x 3.4x	1.0 RAF =	0 Btu/h
People	3 people x 255 btu/person x	60% time in space =		459 Btu/h
Computer Work Stations	3 Units x	500 W/Unit x 3414 =		5,120 Btu/h
Equipment	0.0 kW x 3,413 =			0 Btu/h
Misc.				0 Btu/h
<b>19,340 Btu/h</b>				

#### VENTILATION AND INFILTRATION

	Infiltration Factor	Perimeter Ratio	Coef	Temp. Diff.	Room Heat Gain
Walls	2,288 SF 0.10 CFM/SF		1.08	18 *F	4,814 Btu/h
Doors	57 SF 0.25 CFM/LF	0.75 LF/SF	1.08	18 *F	226 Btu/h
Windows	375 SF 0.30 CFM/LF	1.00 LF/SF	1.08	18 *F	2,373 Btu/h
Ventilation	0 cfm		1.08	18 *F	0 Btu/h
<b>7,413 Btu/h</b>					

### COOLING HEAT GAINS TO THE RA PLENUM - SENSIBLE

4,950

#### CONDUCTION

	NET AREA (SF)	U-VALUE	Cooling Load Temp. Dif.	Return Air Factor	Room Heat Gain
North Exposure	140	0.10	20	1.0	280 Btu/hr
East Exposure	200	0.10	39	1.0	780 Btu/hr
South Exposure	140	0.10	27	1.0	378 Btu/hr
West Exposure	200	0.10	22	1.0	440 Btu/hr
Roof	1,680	0.07	73	0.0	0 Btu/hr
<b>1,878 Btu/h</b>					

#### INTERNAL HEAT GAINS

Lights	1.20 w/sf x 3,360 Occ Area =	4.0 kW x 3413x	0.00 RAF =	0 Btu/h
Misc.				0 Btu/h
<b>0 Btu/h</b>				

#### SENSIBLE HEAT GAINS - TEMP. DEPENDENT

Solar	15,988
Conduction to Room	20,023
Conduction to Plenum	1,878
Ventilation and Infiltration	7,413
<b>Sub Total</b>	<b>45,302</b>

#### SENSIBLE HEAT GAINS - TEMP. INDEPENDENT

Internal Gains to Room	19,340
Internal Gains to Plenum	0
<b>Sub Total</b>	<b>19,340</b>

## HEAT GAIN/LOSS WORKSHEET

Project Name: Tabernacle Township  
 Location:   
 Building Name: Municipal Building  
 Engineer: Frank Cutitta

Project No.: CHA # 21063  
 Site Elevation: 460 Feet  
 Date:   
 Specific Volume: 13.50 CF/#

Building/Facility Designation: General Offices, Tax Office and Administration.

### LATENT COOLING LOADS

Infiltration		Infiltration Factor	Air Density	Humidity Ratio Dif.	Room Heat Gain
Walls	2,360 SF	0.10 CFM/SF	4,800	0.0043 ##	4,871 Btu/h
Doors	57 SF	0.25 CFM/LF	4,800	0.0043 ##	222 Btu/h
Windows	375 SF	0.30 CFM/LF	4,800	0.0043 ##	2,328 Btu/h
Ventilation	0 cfm		4,800	0.0043 ##	0 Btu/h
People	3 people	0.60 time in space		250 Btu/hr/person	450 Btu/h
					<b>7,871 Btu/h</b>

### Cooling Load Summary

	Sensible	Latent	Total	SHR=	
Temperature Dependent Gains	45,302	7,871	53,173		
Temperature Indep. Gains	19,340	0	19,340	0.89	
<b>Total</b>	<b>64,642</b>	<b>7,871</b>	<b>72,513</b>		

Building Cooling Load: 6.0 Tons at 556 SF/Ton

Building Air Flow to Condition Space based on a 12°F Temp Rise is: 4,833 CFM  
1.44 CFM/sf

### HEATING CALCULATION

#### CONDUCTION

	NET AREA (SF)	U-VALUE	Heating Load Temp. Dif.	Room Heat Gain
North Exposure	547	0.10	54	2,954 Btu/h
East Exposure	886	0.10	54	4,784 Btu/h
South Exposure	550	0.10	54	2,970 Btu/h
West Exposure	985	0.10	54	5,319 Btu/h
Fenestration	375	0.70	54	14,175 Btu/h
Roof	1,680	0.07	54	6,480 Btu/h
Doors	57	0.14	54	430 Btu/h
Ceiling	3,360	0.14	0	0 Btu/h
Partition	0	0.05	0	0 Btu/h
Floor	1,680	0.04	0	0 Btu/h

#### Ventilation and Infiltration

	Infiltration Factor	Coef	Temp. Difference	Air Flow	Room Heat Gain
Walls	2,968 SF	0.10 CFM/SF	54	297 cfm	17,346 Btu/h
Doors	57 SF	0.25 CFM/LF	54	11 cfm	628 Btu/h
Windows	375 SF	0.30 CFM/LF	54	113 cfm	6,592 Btu/h
Ventilation Load	0 cfm		54	0 cfm	0 Btu/h
<b>Total Ventilation &amp; Infiltration Load</b>				<b>420 cfm</b>	<b>24,566 Btu/h</b>

**Building Heating Load** 61,678 btu/h  
 18.4 btu/sf

Tabernacle Township  
 CHA #-21063  
 Building: Municipal Building

Doors

	Width (ft)	Height (ft)	Quantity	Area (SF)	Lineal Feet
North	6.0	6.0	1	36.0	24.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
			Sub-total	36.0	24.0
East	3.5	6.0	1	21.0	19.0
				0.0	0.0
				0.0	0.0
				Sub-total	21.0
South	3.0	7.0	0	0.0	0.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
				Sub-total	0.0
West	3.5	7.0	0	0.0	0.0
				0.0	0.0
				0.0	0.0
				Sub-total	0.0
			<b>Total</b>	<b>57.0</b>	<b>43.0</b>

LF/SF
0.75

**Walls**

	Width (ft)	Height (ft)	Quantity	Area (SF)	Lineal Feet	
North	35.0	10.0	1	350.0	90.0	All wall quantities must remain equal to 1
	35.0	10.0	1	350.0	90.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
		70.0			700.0	
						Ave. height 10.0
						Average height wall automatically linked to

East	50.0	10.0	1	500.0	120.0	
	50.0	10.0	1	500.0	120.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
		100.0			1000.0	240.0
						Ave. height 10.0
						Average height wall automatically linked to

South	35.0	10.0	1	350.0	90.0	
	35.0	10.0	1	350.0	90.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
		70.0			700.0	180.0
						Ave. height 10.0
						Average height wall automatically linked to

West	50.0	10.0	1	500.0	120.0	
	50.0	10.0	1	500.0	120.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
		100.0			1000.0	240.0
						Ave. height 10.0
						Average height auto linked to block load sheet

**Windows**

	Width (ft)	Height (ft)	Quantity	Area (SF)	Lineal Feet
North	3.0	2.0	2	12.0	20.0
	3.0	7.0	5	105.0	100.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
			Sub-total	117.0	120.0

East	3.0	5.0	2	30.0	32.0
	3.0	7.0	3	63.0	60.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
			Sub-total	93.0	92.0

South	3.0	5.0	3	45.0	48.0
	3.0	7.0	5	105.0	100.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
			Sub-total	150.0	148.0

West	3.0	5.0	1	15.0	16.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
			Sub-total	15.0	16.0

<b>Total</b>				<b>375.0</b>	<b>376.0</b>	<b>LF/SF 1.00</b>
--------------	--	--	--	--------------	--------------	-------------------

Tabernacle Township  
CHA #-21063  
Building: Municipal Building

Reconcile Thermal Model

Building Footprint	3,350 SF
Heating Efficiency	70%
Cooling Efficiency	1.30 kW/ton
Internal Gains	19.340 btu/hr
Unoc Internal Gain factor	0.3
Ave Occ Internal Gain Factor	0.7
Economizer available (Y/N)	No

Ex Occupied Cing Temp.	73 °F
Ex Unoccupied Cing Temp.	80 °F
Occupied Cooling UA	(2.105) btu/hr°F
Unoccupied Cooling UA	(1,217) btu/hr°F
Cooling Occ Enthalpy Setpoint	27.5 Btu/lb
Cooling Unocc Enthalpy Setpoint	27.5 Btu/lb

Ex Occupied Htg Temp.	68 °F
Ex Unoccupied Htg Temp.	62 °F
Occupied Heating UA	687 btu/hr°F
Unoccupied Heating UA	687 btu/hr°F

Heating and cooling energy are unrelated in this model. If the building being analyzed is not cooled, disregard cooling energy calculations

Avg Outdoor Air Temp. Bins °F	Avg Outdoor Air Enthalpy	Total Bin Hours		Equipment Occupied Hours		Equipment Unoccupied Hours		EXISTING LOADS				Available Economizer Cooling kWh	Necessary Cooling Energy kWh	Existing Cooling Energy kWh	Existing Heating Energy therms
		A	B	C	D	E	F	G	H	I	J				
102.5	49.1	0	0	0	0	-62,096	-40,858	-13,538	-27,377	-40,858	-5,802	0	0	0	0
97.5	42.5	3	3	1	2	-51,571	-28,374	-13,538	-21,293	-28,374	-5,802	0	22	22	0
87.5	36.6	131	131	37	94	-30,522	-17,213	-13,538	-9,126	-17,213	-5,802	0	574	574	0
82.5	34.0	500	500	143	357	-19,997	-12,295	-13,538	-3,042	-12,295	-5,802	0	1,527	1,527	0
77.5	31.6	620	620	177	443	-9,472	-7,755	-13,538	0	0	-5,802	0	869	869	0
72.5	29.2	474	474	190	474	0	0	-13,538	0	0	-5,802	0	576	576	0
67.5	27.0	854	854	244	610	344	227	-13,538	0	0	-5,802	0	726	726	0
62.5	24.5	927	927	265	662	3,780	2,497	-13,538	0	0	-5,802	0	625	625	0
57.5	21.4	600	600	171	429	7,216	4,767	-13,538	3,093	2,043	-5,802	0	60	60	0
52.5	18.7	436	436	174	334	10,653	7,037	-13,538	6,529	4,313	-5,802	0	0	0	42
47.5	16.2	611	611	175	436	14,089	9,307	-13,538	9,965	6,583	-5,802	0	0	0	92
42.5	14.4	656	656	187	469	17,525	11,576	-13,538	13,402	8,853	-5,802	0	0	0	152
37.5	12.6	1,023	1,023	292	731	20,961	13,846	-13,538	16,838	11,122	-5,802	0	0	0	320
32.5	10.7	734	734	210	524	24,398	16,116	-13,538	20,274	13,392	-5,802	0	0	0	290
27.5	8.6	334	334	95	239	27,854	18,386	-13,538	23,711	15,662	-5,802	0	0	0	159
22.5	6.8	252	252	72	180	31,270	20,656	-13,538	27,147	17,932	-5,802	0	0	0	140
17.5	5.5	125	125	36	89	34,707	22,926	-13,538	30,583	20,202	-5,802	0	0	0	80
12.5	4.1	47	47	13	34	36,143	25,196	-13,538	34,019	22,472	-5,802	0	0	0	34
7.5	2.6	22	22	6	16	41,579	27,466	-13,538	37,456	24,742	-5,802	0	0	0	18
2.5	1.0	13	13	4	9	45,016	29,736	-13,538	40,892	27,012	-5,802	0	0	0	11
-2.5	0.0	0	0	0	0	48,452	32,005	-13,538	44,328	29,282	-5,802	0	0	0	0
-7.5	-1.5	0	0	0	0	51,888	34,275	-13,538	47,765	31,551	-5,802	0	0	0	0
<b>TOTALS</b>		<b>8,726</b>	<b>8,726</b>	<b>2,493</b>	<b>6,233</b>							<b>4,979</b>	<b>4,979</b>	<b>4,979</b>	<b>1,337</b>

Existing Building Ventilation & Infiltration (occ)	420 cfm
Overheat Ventilation Factor	1.00
Additional Ventilation to offset overheat	0 cfm
Existing Building Ventilation & Infiltration (unocc)	420 cfm
Economizer Ventilation (from AHU's)	0 cfm

Energy Use Indices (calculated)

Heating	Base Case	1,337
	Target ->	1,334
		100.2%

Cooling	Base Case	4,979
	Target ->	4,928
		101.0%

cooling for 5 ton ac unit	17
amps	3
ph	208
volls	1,918
hrs	0.8
pf	0.35
runtime	3285
kwhr/machine	4928
for 2 units	

## **APPENDIX D**

### **ECM-3 Replace Windows**



Tabernacle Township  
CHA #2-1063  
Building: Municipal Building

ECM-3 Window Replacement/Upgrade

\*Change U-value and air infiltration rates based on new windows or storm windows  
See block load spreadsheet for U-values

Description Windows can lead to increased energy consumption due to infiltration/exfiltration and heat gain/loss. Replacing older windows with more panes and low-emissivity coatings and insulated frames can decrease energy usage.

Occupied Cooling Hours per Week  
Heating Hours per Week  
Cooling Energy Cost  
Heating Energy Cost  
Occupied Cooling Setpoint Temperature  
Occupied Heating Setpoint Temperature  
Unoccupied Cooling Setpoint Temperature  
Unoccupied Heating Setpoint Temperature  
Window Area  
Window Perimeter  
Proposed U factor  
Proposed Air Infiltration  
Cooling Conversion  
Heating Efu Conversion

48 Hours  
48 Hours  
\$1,736  
\$0,176 \$4MM  
75.0 Degrees F  
25.5 bluf/air  
68.0 Degrees F  
62.0 Degrees F  
186 sq.ft.  
188 ft  
0.45 Btu/(°sqft°degf)  
0.20 cfm/ft  
12,000 Btu/ton  
1,000,000 Btu/MMBtu

(Assumption)  
(Assumption)  
(Assumption)  
(From window survey)  
(From window vendor)  
(From window vendor)

(From ASHRAE Fundamentals)  
(From ASHRAE Fundamentals)

Assumptions

Existing Air Infiltration  
Heating System Efficiency  
Cooling System Efficiency

0.73 Btu/(°sqft°degf)  
0.30 cfm/ft  
70%  
1.38 kW/ton

Formula Cooling Energy Consumption = (Existing U x Area x (OA Temp - RA Temp) x Op Hours)

Heating Energy Consumption = (Existing U x Area x (RA Temp - OA Temp) x Op Hours)  
Cooling Energy Infiltration = (4.5 x Leakage x Perimeter x (OA Enthalpy - RA Enthalpy) x Op Hours)

Heating Energy Infiltration = 1.08 x Leakage x Perimeter x (RA Temp - OA Temp) x Op Hours

Load = (Conduction) + (Infiltration)

Cooling Energy = (Cooling Load) / (12,000 Btu/Ton) x (kW/Ton)

Heating Energy = (Heating Load) / (1,000,000 Btu/MMBtu) / (Boiler Efficiency)

Energy Cost = (Energy) x (Cost/Unit)

Operation	OA Enthalpy	OA Temp	Total Hours	Cooling Occupied Hours	Heating Occupied Hours	Heating Unoccupied Hours	Cooling Unoccupied Hours	Heating Occupied Conduction	Heating Unoccupied Conduction	Cooling Occupied Infiltration	Heating Occupied Infiltration	Heating Unoccupied Infiltration
Cooling	38.3	82.5	3	0.9	0.0	0.0	2,194	0	0	0	0	0
Cooling	36.6	87.5	131	37.4	0.0	0.0	71,231	0	0	105,443	0	0
Cooling	33.5	82.5	500	142.9	0.0	0.0	178,125	0	0	290,057	0	0
Cooling	31.6	77.5	620	177.1	0.0	0.0	104,625	0	0	274,249	0	0
Heating	27.9	67.5	854	0.0	0.0	0.0	0	0	0	0	0	0
Heating	24.6	62.5	927	0.0	264.9	0.0	0	16,013	0	0	7,431	0
Heating	21.6	57.5	600	0.0	171.4	428.6	0	236,250	253,125	0	105,642	117,473
Heating	18.7	52.5	610	0.0	174.3	435.7	0	354,563	543,281	0	164,549	252,132
Heating	16.2	47.5	611	0.0	174.6	436.4	0	469,706	836,578	0	217,987	385,464
Heating	14.3	42.5	656	0.0	187.4	466.6	0	627,300	1,199,250	0	291,125	556,862
Heating	12.4	37.5	1,023	0.0	292.3	730.7	0	1,170,056	2,349,703	0	543,013	1,090,477
Heating	10.4	32.5	734	0.0	209.7	524.3	0	977,138	2,029,969	0	453,481	942,091
Heating	8.7	27.5	334	0.0	95.4	238.6	0	507,263	1,080,281	0	235,416	501,349
Heating	7	22.5	282	0.0	72.0	180.0	0	428,975	893,188	0	198,568	428,975
Heating	5.4	17.5	125	0.0	33.1	81.6	0	207,815	431,684	0	109,858	235,416
Heating	3.7	12.5	53	0.0	16.4	39.6	0	87,815	178,684	0	45,397	94,209
Heating	2.5	7.5	22	0.0	6.3	15.7	0	49,913	112,008	0	23,164	52,167
Heating	1.2	2.5	13	0.0	3.7	9.3	0	31,931	72,516	0	14,819	33,654
Heating	-0.2	-2.5	0	0.0	0.0	0.0	0	0	0	0	0	0
Heating	-1.4	-7.5	0	0.0	0.0	0.0	0	0	0	0	0	0
Subtotal =			8,726	358	1,945	3,591	356,175	5,395,838	10,143,891	672,534	2,504,162	4,707,693

Conduction	358175	+	( 672534 )	=	1,028,709	btu
Cooling Load	1028709	W	( 12000 )	+	( - 1.30 )	=
Cooling Energy	111.44	X	( - \$0.176 )	=	\$	19.60
Conduction	15539728	+	( 2211955 )	=	22,751,583	btu
Heating Load	22751583	W	( 70% )	W	1000000	=
Heating Energy	325.02	X	( \$1,200 )	=	\$	390

Operation	OA Enthalpy	OA Temp	Total Hrs	Cooling Occupied Hrs	Heating Occupied Hrs	Heating Unoccupied Hrs	Cooling Conduction	Heating Conduction	Heating Unoccupied Conduction	Cooling Occupied Infiltration	Heating Occupied Infiltration	Heating Unoccupied Infiltration
Cooling	38.3	82.5	9	0.9	0.0	0.0	1,410	0	0	1,856	0	0
Cooling	36.6	87.5	131	37.4	0.0	0.0	45,792	0	0	70,295	0	0
Cooling	33.5	82.5	500	142.9	0.0	0.0	114,509	0	0	193,371	0	0
Cooling	31.6	77.5	620	177.1	0.0	0.0	67,259	0	0	182,833	0	0
Heating	27.9	67.5	854	0.0	244.0	0.0	0	10,294	0	0	4,954	0
Heating	24.6	62.5	927	0.0	264.9	0.0	0	122,910	0	0	59,154	0
Heating	21.6	57.5	600	0.0	171.4	428.6	0	151,875	162,723	0	73,094	78,315
Heating	18.7	52.5	610	0.0	174.3	435.7	0	227,933	349,252	0	108,700	168,088
Heating	16.2	47.5	611	0.0	174.6	435.4	0	403,264	533,943	0	145,324	256,976
Heating	14.3	42.5	656	0.0	187.4	468.6	0	628,160	770,946	0	194,083	371,041
Heating	12.4	37.5	1,023	0.0	292.3	730.7	0	928,097	1,570,523	0	362,009	726,965
Heating	10.4	32.5	784	0.0	209.7	524.3	0	276,413	1,304,980	0	302,321	628,061
Heating	8.7	27.5	334	0.0	95.4	238.6	0	326,097	694,467	0	156,944	334,233
Heating	7	22.5	252	0.0	72.0	180.0	0	152,176	589,906	0	133,032	286,723
Heating	5.4	17.5	125	0.0	35.7	89.3	0	62,883	335,240	0	73,239	161,344
Heating	3.9	12.5	47	0.0	13.4	33.9	0	14,448	140,213	0	30,265	67,472
Heating	2.5	7.5	12	0.0	3.7	9.3	0	4,617	42,817	0	10,478	22,436
Heating	1.2	2.5	10	0.0	3.7	9.3	0	20,577	46,817	0	9,878	22,436
Heating	-0.2	-2.5	0	0.0	0.0	0.0	0	0	0	0	0	0
Heating	-1.4	-7.5	0	0.0	0.0	0.0	0	0	0	0	0	0
Subtotal =			8,726	358	1,945	3,591	228,970	3,468,753	6,521,073	448,356	1,669,441	3,136,462

Conduction	Infiltration	
228970 ) + ( 448356 ) =		
Cooling Load =	677,325	btu
Cooling Energy =	677,325 ) / ( 12000 ) * ( 1.30 ) =	73 kWh
Cooling Energy Cost =	73.38 ) x ( \$0.176 ) =	\$ 12.91
Conduction	Infiltration	
9968925 ) + ( 4807903 ) =		
Heating Load =	14,797,728	btu
Heating Energy =	14,797,728 ) / ( 100000 ) =	211 therms
Heating Energy Cost =	211.40 ) x ( \$1,200 ) =	\$ 254

EXISTING COOLING ENERGY	111.44	kWh	\$ 19.66
EXISTING HEATING ENERGY	325.02	therms	\$ 390.03
EXISTING ENERGY COST			\$ 409.63
PROPOSED COOLING ENERGY	73.38	kWh	\$ 12.91
PROPOSED HEATING ENERGY	211.40	therms	\$ 253.65
PROPOSED ENERGY COST			\$ 266.56
COOLING ENERGY SAVINGS	38.07	kWh	\$ 6.69
HEATING ENERGY SAVINGS	113.63	therms	\$ 136.35
ENERGY COST SAVINGS			\$ 143.05

34.2% of existing  
35.0% of existing  
34.9% of existing

Summary

Comments

Tabernacle Township  
 CHA #-21063  
 Building: Municipal Building

ECM-3 Window Replacement/Upgrade

Multipliers	
Material:	0.98
Labor:	1.21
Equipment:	1.09

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
windows for second floor	12	ea	\$ 340	\$ 74		\$ 3,998	\$ 1,067	\$ -	\$ 5,066	
Removal of old windows	12	ea	\$ 150	\$ 350		\$ 1,764	\$ 5,082	\$ -	\$ 6,846	
trim and finishing	1	ls	\$ 4,800	\$ 6,000		\$ 4,704	\$ 7,260	\$ -	\$ 11,964	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	

\$ 23,876	Subtotal
\$ 7,163	30% Contingency
\$ 4,656	Contractor
\$ 7,139	15% O&P
\$ 42,833	20% Engineering
	<b>Total</b>

**APPENDIX E**

**ECM-4 Lighting Replacement**



Tabernacle Township  
 CHA #-21063  
 Building: Municipal Building

ECM-4 Replacement of incandescent and T-12 lights

**Building Schedule:**  
 Existing conditions (master switch):  hrs/week  
 Supply Electric Rate \$ 0.167 /kWh  
 Demand Rate \$ 1.52 /kW

Instructions and notes:  
 Input existing fixtures and retrofit fixtures. Use light table

Area Description	EXISTING CONDITIONS										RETROFIT CONDITIONS							COST ANALYSIS					
	Number of Fixtures	Fixture Code	Watts per Fixture	Number of Non-Operational Fixtures	Watts per Non-Operational Fixtures	kW/Space	Exist Control	Daily Hours	Annual Hours	Annual kWh	Number of Fixtures	Fixture Code	Watts per Fixture	kW/Space	Retrofit Control	Daily Hours	Annual Hours	Annual kWh	kW Saved	Annual kWh Saved	Annual \$ Saved	Retrofit Cost	Simple Payback
Main Area & Offices	15	F42ES	80	0	81.6	1.2	switch	10	3,650	4,380	15	F42ILL	59	0.885	switch	10	3,650	3,230	0	1,150	\$ 198	\$ 1,882	9.5
Second Floor	12	F42ES	80	0	81.6	0.96	switch	6	2,190	2,102	12	F42ILL	0	0	switch	6	2,190	-	1	2,102	\$ 369	\$ 1,506	4.1
Misc	6	I40	40	0	40.8	0.24	switch	1	365	88	6	CF23	23	0.138	switch	1	365	50	0	37	\$ 8	\$ 753	93.2
Outdoor	3	I150	150	0	153	0.45	timer	10	3,650	1,643	3	CF42	42	0.126	timer	10	3,650	460	0	1,183	\$ 203	\$ 376	1.9
Outdoor	1	I60	60	0	61.2	0.06	timer	10	3,650	219	1	CF42	42	0.042	timer	10	3,650	153	0	66	\$ 11	\$ 125	11.1
<b>TOTALS -</b>	<b>37</b>			<b>0</b>		<b>2.9</b>				<b>8,432</b>	<b>37</b>		<b>1.2</b>				<b>3,894</b>	<b>1.7</b>	<b>4,538</b>	<b>\$ 789</b>	<b>\$ 4,643</b>	<b>5.9</b>	

**APPENDIX F**

**New Jersey Incentive Program**



**Tabernacle Township**  
**CHA #-21063**  
**Building: Municipal Building**

**New Jersey Pay For Performance Incentive Program**

**Note:** The following calculation is based on the New Jersey Pay For Performance Incentive Program per January, 2010. Building must have a minimum average electric demand of 200 kW. This minimum is waived for buildings owned by local governments or non-profit organizations.

The incentive values represented below are applicable through December 31, 2010.

Total Building Area (Square Feet)	3,400
Is this audit funded by the NJ BPU (Y/N)	Yes

Bureau of Public Utilities (BPU)

	Annual Utilities	
	kWh	Therms
Existing Cost (from utility)	\$5,600	\$0
Existing Usage (from utility)	32,080	0
Proposed Savings	4,901	(974)
Existing Total MMBtus	109	
Proposed Savings MMBtus	(81)	
% Energy Reduction	<b>-73.7%</b>	
Proposed Annual Savings	\$1,384	

Incentive #1		
Audit not funded by NJ BPU	\$0.10	\$/sqft
Audit is funded by NJ BPU	\$0.05	\$/sqft

	≥ %15 - < 20%	
	\$/kWh	\$/therm
Incentive #2	\$0.11	\$1.10
Incentive #3	\$0.07	\$0.70

	≥ 20%	
	\$/kWh	\$/therm
Incentive #2	\$0.22	\$2.20
Incentive #3	\$0.14	\$1.40

	Incentives \$		
	Elec	Gas	Total
Incentive #1	\$0	\$0	\$170
Incentive #2	\$0	\$0	\$0
Incentive #3	\$0	\$0	\$0
<b>Total All Incentives</b>	<b>\$0</b>	<b>\$0</b>	<b>\$170</b>

Total Project Cost	\$62,400
% Incentives #1 of Utility Cost*	3.0%
% Incentives #2 & #3 of Project Cost**	0.0%
Total Eligible Incentives***	\$170
Project Cost w/ Incentives	\$62,230

Project Payback (years)	
w/o Incentives	w/ Incentives
45.1	45.0

\* Maximum allowable incentive is 50% of annual utility cost if not funded by NJ BPU, and %25 if it is.

\*\* Maximum allowable amount of Incentive #2 & #3 is 80% of total project cost.

\*\*\* Maximum allowable amount of Incentive #1 is \$50,000 if not funded by NJ BPU, and \$25,000 if it is.

Maximum allowable amount of Incentive #2 & #3 is \$2 million per gas account and \$2 million per electric account

## **APPENDIX G**

### **Photovoltaic (PV) Rooftop Solar Power Generation**



**Township of Tabernacle  
Municipal Building**

Cost of Electricity      \$0.170      \$/kWh

**Photovoltaic (PV) Rooftop Solar Power Generation-12kW System**

Budgetary Cost	Annual Utility Savings			Estimated Maintenance Savings	Total Savings	New Jersey Renewable * Energy Incentive	New Jersey Renewable ** SREC	Payback (without incentive)	Payback (with incentive)
	kW	kWh	therms						
\$ <b>84,000</b>	<b>0.0</b>	<b>14,470</b>	<b>0</b>	\$ <b>0</b>	\$ <b>2,500</b>	\$ <b>12,000</b>	\$ <b>7,000</b>	<b>33.6</b>	<b>7.6</b>


Note: Budgetary cost is based on \$7,000/kW.

\*Incentive based on New Jersey renewable energy program for non-residential applications(PV)= \$1.00/W of installed PV system

\*\* Estimated Solar Renewable Energy Certificate Program (SREC) SREC for 15 Years= \$487/1000kwh

**Estimated Solar Renewable Energy Certificate Program (SREC) payments for 15 Years from RR Renewable Energy Consultants**

Year	SREC
1	600
2	600
3	600
4	500
5	500
6	500
7	500
8	500
9	500
10	500
11	400
12	400
13	400
14	400
15	400
<b>AVG</b>	<b>487</b>



\*\*\*

**AC Energy  
&  
Cost Savings**



Station Identification	
City:	Philadelphia
State:	Pennsylvania
Latitude:	39.88° N
Longitude:	75.25° W
Elevation:	9 m
PV System Specifications	
DC Rating:	12.0 kW
DC to AC Derate Factor:	0.770
AC Rating:	9.2 kW
Array Type:	Fixed Tilt
Array Tilt:	39.9°
Array Azimuth:	180.0°
Energy Specifications	
Cost of Electricity:	17.0 ¢/kWh

Results			
Month	Solar Radiation (kWh/m <sup>2</sup> /day)	AC Energy (kWh)	Energy Value (\$)
1	3.30	972	165.24
2	4.16	1106	188.02
3	4.74	1333	226.61
4	5.06	1336	227.12
5	5.20	1367	232.39
6	5.43	1339	227.63
7	5.51	1386	235.62
8	5.67	1438	244.46
9	5.07	1274	216.58
10	4.59	1245	211.65
11	3.37	915	155.55
12	2.67	760	129.20
Year	4.57	14472	2460.24

[Output Hourly Performance Data](#)

[Output Results as Text](#)

\*

[About the Hourly Performance Data](#)

[Saving Text from a Browser](#)

Run PVWATTS v.1 for another US location or an International location  
Run PVWATTS v.2 (US only)

Please send questions and comments regarding PVWATTS to Webmaster

Disclaimer and copyright notice



## Cautions for Interpreting the Results

The monthly and yearly energy production are modeled using the PV system parameters you selected and weather data that are typical or representative of long-term averages. For reference, or comparison with local information, the solar radiation values modeled for the PV array are included in the performance results.

Because weather patterns vary from year-to-year, the values in the tables are better indicators of long-term performance than performance for a particular month or year. PV performance is largely proportional to the amount of solar radiation received, which may vary from the long-term average by  $\pm 30\%$  for monthly values and  $\pm 10\%$  for yearly values. How the solar radiation might vary for your location may be evaluated by examining the tables in the *Solar Radiation Data Manual for Flat-Plate and Concentrating Collectors* ([http://rredc.nrel.gov/solar/old\\_data/nsrdb/redbook/](http://rredc.nrel.gov/solar/old_data/nsrdb/redbook/)).

For these variations and the uncertainties associated with the weather data and the model used to model the PV performance, future months and years may be encountered where the actual PV performance is less than or greater than the values shown in the table. The variations may be as much as 40% for individual months and up to 20% for individual years. Compared to long-term performance over many years, the values in the table are accurate to within 10% to 12%.

If the default overall DC to AC derate factor is used, the energy values in the table will overestimate the actual energy production if nearby buildings, objects, or other PV modules and array structure shade the PV modules; if tracking mechanisms for one- and two-axis tracking systems do not keep the PV arrays at the optimum orientation with respect to the sun's position; if soiling or snow cover related losses exceed 5%; or if the system performance has degraded from new. (PV performance typically degrades 1% per year.) If any of these situations exist, an overall DC to AC derate factor should be used with PVWATTS that was calculated using system specific component derate factors for *shading, sun-tracking, soiling, and age*.

The PV system size is the nameplate DC power rating. The energy production values in the table are valid only for crystalline silicon PV systems.

The cost savings are determined as the product of the number of kilowatt hours (kWh) and the cost of electricity per kWh. These cost savings occur if the owner uses all the electricity produced by the PV system, or if the owner has a net-metering agreement with the utility. With net-metering, the utility bills the owner for the net electricity consumed. When electricity flows from the utility to the owner, the meter spins forward. When electricity flows from the PV system to the utility, the meter spins backwards.


If net-metering isn't available and the PV system sends surplus electricity to the utility grid, the utility generally buys the electricity from the owner at a lower price than the owner pays the utility for electricity. In this case, the cost savings shown in the table should be reduced.

Besides the cost savings shown in the table, other benefits of PV systems include greater energy independence and a reduction in fossil fuel usage and air pollution. For commercial customers, additional cost savings may come from reducing demand charges. Homeowners can often include the cost of the PV system in their home mortgage as a way of accommodating the PV system's initial cost.

To accelerate the use of PV systems, many state and local governments offer financial incentives and programs. Go to <http://www.nrel.gov/stateandlocal> for more information.

Please send questions and comments to [Webmaster](#)

[Disclaimer and copyright notice.](#)




Return to RReDC Home Page (<http://rredc.nrel.gov/>)

## **APPENDIX H**

### **Solar Thermal Domestic Hot Water Plant**





- Home
- What Can I Do?
- Electric Choice
- Home Energy
- FAQs
- LEARN**
- Fact Sheets
- Lesson Plans

## Interactive Energy Calculators

**RENEWABLE ENERGY**  
THE INFINITE POWER  
OF TEXAS

Our calculators help you understand energy production and consumption in a whole new way. Use them to develop a personal profile of your own energy use.

- Carbon Pollution Calculator
- Electric Power Pollution Calculator
- PV System Economics
- Solar Water Heating
- What's a Watt?

**PLAY**  
Calculators

### Solar Water Heating Calculator

**NETWORK**  
Organizations  
Businesses  
Events Calendar

Water heating is a major energy consumer. Although the energy consumed daily is often less than for air conditioning or heating, it is required year round, making it a good application of solar energy. Use this calculator to explore the energy usage of your water heater, and to estimate whether a solar water heater could save you money.

**BROWSE**  
Resources  
Solar  
Wind  
Biomass  
Geothermal  
Water

- Projects
- TX Energy - Past and Present
- Financial Help
- About Us
- About SECO
- RARE

Water Heater Characteristics			
Physical		Thermal	
? Diameter (feet)	.75	? Water Inlet Temperature (Degrees F)	50
? Capacity (gallons)	19	? Ambient Temperature (Degrees F)	70
? Surface Area (calculated - sq ft)	14.43	? Hot Water Temperature (Degrees F)	120
? Effective R-value	NaN	? Hot Water Usage (Gallons per Day)	40
Energy Use			
957.8		? Heat Delivered in Hot Water (BTU/hr)	
0		? Heat loss through insulation (BTU/hr)	

Gas vs. Electric Water Heating		
Gas		Electric
0	? Overall Efficiency	0.98
0	? Conversion Efficiency	0.98
NaN BTU/hr	? Power Into Water Heater	977.3 BTU/hr
Cost		
\$ 0 /Therm	? Utility Rates	\$ 0.17 /kWh
\$ NaN	? Yearly Water Heating Cost	\$ 426.248
How Does Solar Compare?		
? Solar Water Heater Cost: \$ 27100		? Percentage Solar: 70
NaN years for gas	? Payback Time for Solar System	90.8255 years for electric

NJBPU Energy Audits  
 CHA #21063  
 Municipal Building  
 Tabernacle Township

Multipliers	
Material:	0.98
Labor:	1.21
Equipment:	1.09


Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
Synergy Solar Thermal System	2	ea			\$ 3,600	\$ -	\$ -	\$ 7,848	\$ 7,848	
Piping modifications	1	ls	\$ 2,000	\$ 3,500		\$ 1,960	\$ 4,235	\$ -	\$ 6,195	
Electrical modifications	1	ls	\$ 1,000	\$ 1,000		\$ 980	\$ 1,210	\$ -	\$ 2,190	
65 Gallon Storage Tanks	2	ea	\$ 200	\$ 250		\$ 400	\$ 500	\$ -	\$ 900	
10 Gallon Drip Tank	2	ea	\$ 100	\$ 78		\$ 200	\$ 156	\$ -	\$ 356	
						\$ -	\$ -	\$ -	\$ -	

\$17,489	Subtotal
\$ 2,623	15% Contingency
\$ 2,623	15% Contractor O&P
\$ 4,372	25% Engineering
<b>\$27,108</b>	<b>Total</b>



**APPENDIX I**

**Wind**





## Wind Resource of New Jersey Mean Annual Wind Speed at 30 Meters



**AWS Truewind**

Projection: Transverse Mercator,  
UTM Zone 17 WGS84


Spatial Resolution of Wind Resource Data: 200m  
This map was created by AWS Truewind using the MesoMap system and historical weather data. Although it is believed to represent an accurate overall picture of the wind energy resource, estimates at any location should be confirmed by measurement.

The transmission line information was obtained by AWS Truewind from the Global Energy Decisions Velocity Suite. AWS does not warrant the accuracy of the transmission line information.


### Bing Maps

163 Carranza Rd, Tabernacle, NJ 08088-9304

My Notes

 **FREE!** Use **Bing 411** to find movies, businesses & more: **800-BING-411**





**APPENDIX J**

**EPA Portfolio Manager**





# STATEMENT OF ENERGY PERFORMANCE

## Municipal Building

Building ID: 2209599  
 For 12-month Period Ending: December 31, 2009<sup>1</sup>  
 Date SEP becomes ineligible: N/A

Date SEP Generated: April 12, 2010

Facility	Facility Owner	Primary Contact for this Facility
Municipal Building 6 Carranza Road Tabernacle, NJ 08088	Tabernacle Township 163 Carranza Road Tabernacle, NJ 08088	Douglas Cramer 163 Caranza oad Tabrnacle, NJ 08088

Year Built: 1875  
 Gross Floor Area (ft<sup>2</sup>): 3,400

Energy Performance Rating<sup>2</sup> (1-100) N/A

### Site Energy Use Summary<sup>3</sup>

Electricity - Grid Purchase(kBtu)	109,505
Fuel Oil (No. 2) (kBtu)	133,637
Natural Gas - (kBtu) <sup>4</sup>	0
Total Energy (kBtu)	243,142

### Energy Intensity<sup>5</sup>

Site (kBtu/ft <sup>2</sup> /yr)	72
Source (kBtu/ft <sup>2</sup> /yr)	147

### Emissions (based on site energy use)

Greenhouse Gas Emissions (MtCO <sub>2</sub> e/year)	27
-----------------------------------------------------	----

### Electric Distribution Utility

Pepco - Atlantic City Electric Co

### National Average Comparison

National Average Site EUI	77
National Average Source EUI	182
% Difference from National Average Source EUI	-19%
Building Type	Office

Stamp of Certifying Professional
Based on the conditions observed at the time of my visit to this building, I certify that the information contained within this statement is accurate.

### Meets Industry Standards<sup>6</sup> for Indoor Environmental Conditions:

Ventilation for Acceptable Indoor Air Quality	N/A
Acceptable Thermal Environmental Conditions	N/A
Adequate Illumination	N/A

### Certifying Professional

N/A

#### Notes:

- Application for the ENERGY STAR must be submitted to EPA within 4 months of the Period Ending date. Award of the ENERGY STAR is not final until approval is received from EPA.
- The EPA Energy Performance Rating is based on total source energy. A rating of 75 is the minimum to be eligible for the ENERGY STAR.
- Values represent energy consumption, annualized to a 12-month period.
- Natural Gas values in units of volume (e.g. cubic feet) are converted to kBtu with adjustments made for elevation based on Facility zip code.
- Values represent energy intensity, annualized to a 12-month period.
- Based on Meeting ASHRAE Standard 62 for ventilation for acceptable indoor air quality, ASHRAE Standard 55 for thermal comfort, and IESNA Lighting Handbook for lighting quality.

## ENERGY STAR® Data Checklist for Commercial Buildings

In order for a building to qualify for the ENERGY STAR, a Professional Engineer (PE) must validate the accuracy of the data underlying the building's energy performance rating. This checklist is designed to provide an at-a-glance summary of a property's physical and operating characteristics, as well as its total energy consumption, to assist the PE in double-checking the information that the building owner or operator has entered into Portfolio Manager.

**Please complete and sign this checklist and include it with the stamped, signed Statement of Energy Performance.**

NOTE: You must check each box to indicate that each value is correct, OR include a note.

CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
<b>Building Name</b>	Municipal Building	Is this the official building name to be displayed in the ENERGY STAR Registry of Labeled Buildings?		<input type="checkbox"/>
<b>Type</b>	Office	Is this an accurate description of the space in question?		<input type="checkbox"/>
<b>Location</b>	6 Carranza Road, Tabernacle, NJ 08088	Is this address accurate and complete? Correct weather normalization requires an accurate zip code.		<input type="checkbox"/>
<b>Single Structure</b>	Single Facility	Does this SEP represent a single structure? SEPs cannot be submitted for multiple-building campuses (with the exception of acute care or children's hospitals) nor can they be submitted as representing only a portion of a building		<input type="checkbox"/>
<b>Municipal Building (Office)</b>				
CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
<b>Gross Floor Area</b>	3,400 Sq. Ft.	Does this square footage include all supporting functions such as kitchens and break rooms used by staff, storage areas, administrative areas, elevators, stairwells, atria, vent shafts, etc. Also note that existing atriums should only include the base floor area that it occupies. Interstitial (plenum) space between floors should not be included in the total. Finally gross floor area is not the same as leasable space. Leasable space is a subset of gross floor area.		<input type="checkbox"/>
<b>Weekly operating hours</b>	45 Hours	Is this the total number of hours per week that the Office space is 75% occupied? This number should exclude hours when the facility is occupied only by maintenance, security, or other support personnel. For facilities with a schedule that varies during the year, "operating hours/week" refers to the total weekly hours for the schedule most often followed.		<input type="checkbox"/>
<b>Workers on Main Shift</b>	4	Is this the number of employees present during the main shift? Note this is not the total number of employees or visitors who are in a building during an entire 24 hour period. For example, if there are two daily 8 hour shifts of 100 workers each, the Workers on Main Shift value is 100. The normal worker density ranges between 0.3 and 10 workers per 1000 square feet (92.8 square meters)		<input type="checkbox"/>
<b>Number of PCs</b>	5	Is this the number of personal computers in the Office?		<input type="checkbox"/>
<b>Percent Cooled</b>	50% or more	Is this the percentage of the total floor space within the facility that is served by mechanical cooling equipment?		<input type="checkbox"/>
<b>Percent Heated</b>	50% or more	Is this the percentage of the total floor space within the facility that is served by mechanical heating equipment?		<input type="checkbox"/>

## ENERGY STAR® Data Checklist for Commercial Buildings

### Energy Consumption

**Power Generation Plant or Distribution Utility:** Pepco - Atlantic City Electric Co

Fuel Type: Electricity		
<b>Meter: main electric (kWh (thousand Watt-hours))</b> <b>Space(s): Entire Facility</b> <b>Generation Method: Grid Purchase</b>		
Start Date	End Date	Energy Use (kWh (thousand Watt-hours))
11/05/2009	12/04/2009	2,100.00
10/05/2009	11/04/2009	2,043.00
09/05/2009	10/04/2009	2,525.00
08/05/2009	09/04/2009	3,410.00
07/05/2009	08/04/2009	3,785.00
06/05/2009	07/04/2009	2,654.00
05/05/2009	06/04/2009	2,451.00
04/05/2009	05/04/2009	2,370.00
03/05/2009	04/04/2009	2,313.00
02/05/2009	03/04/2009	2,816.00
01/05/2009	02/04/2009	2,996.00
<b>main electric Consumption (kWh (thousand Watt-hours))</b>		<b>29,463.00</b>
<b>main electric Consumption (kBtu (thousand Btu))</b>		<b>100,527.76</b>
<b>Total Electricity (Grid Purchase) Consumption (kBtu (thousand Btu))</b>		<b>100,527.76</b>
<b>Is this the total Electricity (Grid Purchase) consumption at this building including all Electricity meters?</b>		<input type="checkbox"/>
Fuel Type: Fuel Oil (No. 2)		
<b>Meter: Oil (Gallons)</b> <b>Space(s): Municipal Building</b>		
Start Date	End Date	Energy Use (Gallons)
11/05/2009	12/04/2009	0.00
10/05/2009	11/04/2009	0.00
09/05/2009	10/04/2009	0.00
08/05/2009	09/04/2009	214.00
07/05/2009	08/04/2009	49.00
06/05/2009	07/04/2009	166.00
05/05/2009	06/04/2009	64.00
04/05/2009	05/04/2009	69.00
03/05/2009	04/04/2009	64.00
02/05/2009	03/04/2009	170.00
01/05/2009	02/04/2009	157.00

Oil Consumption (Gallons)	953.00
Oil Consumption (kBtu (thousand Btu))	132,172.05
Total Fuel Oil (No. 2) Consumption (kBtu (thousand Btu))	132,172.05
Is this the total Fuel Oil (No. 2) consumption at this building including all Fuel Oil (No. 2) meters?	<input type="checkbox"/>

<b>Additional Fuels</b>	
Do the fuel consumption totals shown above represent the total energy use of this building? Please confirm there are no additional fuels (district energy, generator fuel oil) used in this facility.	<input type="checkbox"/>

<b>On-Site Solar and Wind Energy</b>	
Do the fuel consumption totals shown above include all on-site solar and/or wind power located at your facility? Please confirm that no on-site solar or wind installations have been omitted from this list. All on-site systems must be reported.	<input type="checkbox"/>

**Certifying Professional**

(When applying for the ENERGY STAR, the Certifying Professional must be the same as the PE that signed and stamped the SEP.)

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Signature: \_\_\_\_\_

Signature is required when applying for the ENERGY STAR.

# FOR YOUR RECORDS ONLY. DO NOT SUBMIT TO EPA.

Please keep this Facility Summary for your own records; do not submit it to EPA. Only the Statement of Energy Performance (SEP), Data Checklist and Letter of Agreement need to be submitted to EPA when applying for the ENERGY STAR.

**Facility**  
Municipal Building  
6 Carranza Road  
Tabernacle, NJ 08088

**Facility Owner**  
Tabernacle Township  
163 Carranza Road  
Tabernacle, NJ 08088

**Primary Contact for this Facility**  
Douglas Cramer  
163 Caranza oad  
Tabrnacle, NJ 08088

## General Information

Municipal Building	
Gross Floor Area Excluding Parking: (ft <sup>2</sup> )	3,400
Year Built	1875
For 12-month Evaluation Period Ending Date:	December 31, 2009

## Facility Space Use Summary

Municipal Building	
Space Type	Office
Gross Floor Area(ft <sup>2</sup> )	3,400
Weekly operating hours	45
Workers on Main Shift	4
Number of PCs	5
Percent Cooled	50% or more
Percent Heated	50% or more

## Energy Performance Comparison

Performance Metrics	Evaluation Periods		Comparisons		
	Current (Ending Date 12/31/2009)	Baseline	Rating of 75	Target	National Average
Energy Performance Rating	N/A		75	N/A	N/A
<b>Energy Intensity</b>					
<i>Site (kBtu/ft<sup>2</sup>)</i>	72	N/A	38	N/A	77
<i>Source (kBtu/ft<sup>2</sup>)</i>	147	N/A	78	N/A	182
<b>Energy Cost</b>					
<i>\$/year</i>	N/A	N/A	N/A	N/A	N/A
<i>\$/ft<sup>2</sup>/year</i>	N/A	N/A	N/A	N/A	N/A
<b>Greenhouse Gas Emissions</b>					
MtCO <sub>2</sub> e/year	27	N/A	14	N/A	29
kgCO <sub>2</sub> e/ft <sup>2</sup> /year	8	N/A	4	N/A	9

More than 50% of your building is defined as Office. This building is currently ineligible for a rating. Please note the National Average column represents the CBECS national average data for Office. This building uses X% less energy per square foot than the CBECS national average for Office.

**Notes:**

- o - This attribute is optional.
- d - A default value has been supplied by Portfolio Manager.

**APPENDIX K**

**Equipment Inventory**



# New Jersey BPU Energy Audit Program

Borough of Tabernacle, NJ

CHA#21063

Item	Qty.	Manuf	Model No.	Serial No.	Capacity	Condition	Gas	MBH	Refrig.	Comments
<b>Municipal Building</b>										
<b>Split System A/C Units</b>										
1	1	INTER CITY PRODUCTS	OHD125A	D924174311		P		120	R-22	SYNDER GENERAL CC- MODEL H801060
2	1	HEAT CONTROLLER	ODHA125D5	4607A82984		P		120	R-22	SYNDER GENERAL CC- MODEL H801060
<b>Window AC Unit</b>										
3	1	GE	AGN06LAG1		6,000 BTU	E				EER 8.8
<b>Shallow Well Pump</b>										
4	1	ProSource	PSP35-T05			E				Cushion Tank
5	1	Meyers	5KC33MN2702BX		3/4 HP	G				
<b>Condensing Units</b>										
6	1	Nordyne	JS5BD-060	JSF070802120		G				5 TON
7	1	INT COMFORT PRODUCTS	CAC060	LB2302		P				
<b>Domestic Hot Water Heater</b>										
8	1	Bradford White	M120OU6SS	FL12627558	19 gallon	E				1.5 KW
<b>Exhaust Fans</b>										
9	1	Broan				G				mens room
10	1	Broan				G				womens room

E = Excellent  
G = Good  
P = Poor