

**TOWNSHIP OF MARLBORO**

**SWIM COMPLEX**

**60 MASEPE TRAIL  
MARLBORO, NJ 07746**

**FACILITY ENERGY REPORT**

**TABLE OF CONTENTS**

|      |                                       |    |
|------|---------------------------------------|----|
| I.   | HISTORIC ENERGY CONSUMPTION/COST..... | 2  |
| II.  | FACILITY DESCRIPTION .....            | 5  |
| III. | MAJOR EQUIPMENT LIST .....            | 7  |
| IV.  | ENERGY CONSERVATION MEASURES.....     | 8  |
| V.   | ADDITIONAL RECOMMENDATIONS .....      | 21 |

Appendix A – ECM Cost & Savings Breakdown

Appendix B – New Jersey Smart Start<sup>®</sup> Program Incentives

Appendix C – Portfolio Manager “Statement of Energy Performance”

Appendix D – Major Equipment List

Appendix E – Investment Grade Lighting Audit

Appendix F – Renewable / Distributed Energy Measures Calculations

**I. HISTORIC ENERGY CONSUMPTION/COST**

The energy usage for the facility has been tabulated and plotted in graph form as depicted within this section. Each energy source has been identified and monthly consumption and cost noted per the information provided by the Owner.


|                                  |                                   |
|----------------------------------|-----------------------------------|
| Electric Utility Provider:       | Jersey Central Power & Light      |
| Electric Utility Rate Structure: | General Service Secondary 3 Phase |
| Third Party Supplier:            | N/A                               |

The electric usage profile represents the actual electrical usage for the facility. The electric utility measures consumption in kilowatt-hours (KWH) and maximum demand in kilowatts (KW). One KWH usage is equivalent to 1000 watts running for one hour. One KW of electric demand is equivalent to 1000 watts running at any given time. The basic usage charges are shown as generation service and delivery charges along with several non-utility generation charges. Rates used in this report reflect the historical data received for the facility.

**Table 1**  
**Electricity Billing Data**

| <b>ELECTRIC USAGE SUMMARY</b>  |                        |                  |                   |
|--|------------------------|------------------|-------------------|
| Utility Provider: Jersey Central Power & Light<br>Rate: General Service Secondary 3 Phase<br>Meter No: G23543379 / G23543379<br>Account No: 100 103 019 699 / 100 103 019 699<br>Third Party Utility Provider: -<br>TPS Meter / Acct No: - |                        |                  |                   |
| <b>MONTH OF USE</b>  | <b>CONSUMPTION KWH</b> | <b>DEMAND KW</b> | <b>TOTAL BILL</b> |
| Jan-13   | 0                      | 0.0              | \$0               |
| Feb-13   | 0                      | 0.0              | \$0               |
| Mar-13   | 0                      | 0.0              | \$0               |
| Apr-13   | 0                      | 0.0              | \$0               |
| May-13   | 1,600                  | 29.0             | \$370             |
| Jun-13   | 16,200                 | 62.1             | \$2,373           |
| Jul-13   | 32,960                 | 80.3             | \$4,454           |
| Aug-13   | 47,080                 | 80.7             | \$6,155           |
| Sep-13   | 7,520                  | 80.2             | \$1,444           |
| Oct-13   | 7,200                  | 82.6             | \$1,389           |
| Nov-13   | 640                    | 72.0             | \$536             |
| Dec-13   | 0                      | 0.0              | \$0               |
| <b>Totals</b>  | <b>113,200</b>         | <b>82.6 Max</b>  | <b>\$16,721</b>   |
| <b>AVERAGE DEMAND      40.6 KW average</b><br><b>AVERAGE RATE      \$0.148 \$/kWh</b>  |                        |                  |                   |

**Figure 1**  
**Electricity Usage Profile**



## II. FACILITY DESCRIPTION

The Marlboro Swim Club is located at 60 Masepe Trail in Marlboro Township, New Jersey. This 3,528 SF facility was built in 1975 with a major facility improvement in 1991. The complex consists of several single-story buildings comprised of a pool filter/pumping room, storage room, restrooms, and mechanical room. The facility has four (4) pools (main, dive, intermediate and wading).

### Occupancy Profile

The typical hours of operation for the facility are Monday through Sunday between 8:00 AM and 8:00 PM. The pool operates during the summer months only from June to August. There are approximately 25 employees that regularly occupy the facility.

### Building Envelope

The buildings are wood-framed structures with pitched, asphalt, shingle roofs and split brick exterior walls over insulation board and vapor barriers. Typical windows are double pane, 1/4" with aluminum frames. The amount of insulation below the roofing could not be determined.

### HVAC Systems

The Swim Complex is conditioned by two (2) packaged rooftop units with DX cooling only as follows:

| <u>Unit ID</u> | <u>Mfg.</u> | <u>Condenser Fan</u> | <u>Cooling Capacity</u> | <u>Efficiency</u> |
|----------------|-------------|----------------------|-------------------------|-------------------|
| RTU-1          | Aire Flow   | 1/5 HP               | 3.0-Tons                | 10.0 SEER         |
| RTU-2          | Lennox      | ¼ HP                 | 5.0-Tons                | 13.5 SEER         |

### Exhaust System

Toilet exhaust air and pool filter room ventilation air is relieved through various roof-mounted exhaust fans.

### HVAC System Controls

The cooling is controlled by 7-day programmable thermostats that control temperature and turn off the units based on an occupancy schedule.

### Domestic Hot Water

The domestic hot water is provided by an electric RHEEM Model 81V-30D tank water heater with a capacity of 30 gallons and rated at 4.5 kW located in the mechanical room.

Pool Filtering Equipment

The pool filter room consists of the dive pool filter, main pool filter, intermediate pool filter and the wading pool filter. The water is pumped to/from the pools by the following pump/motor units:

| <u>Unit ID</u>           | <u>Mfg.</u> | <u>Pump</u> | <u>Motor HP</u> | <u>Motor Eff.</u> |
|--------------------------|-------------|-------------|-----------------|-------------------|
| Intermediate/Wading Pool | Peerless    | 120 GPM     | 3               | 80%               |
| Main Pool                | Peerless    | 340 GPM     | 15              | 91%               |
| Diving Pool              | Peerless    | 360 GPM     | 15              | 89.5%             |

The pool water quality is controlled by various flow switches, flowcells, pH sensors, electro-chlorination, etc. The Strantrol controller with remote touch screen has the ability to control the chemical and filter functions for all of the filters and manage the backwash cycles.

Lighting

Refer to the Investment Grade lighting Audit Appendix for a detailed list of the lighting throughout the facility and estimated operating hours per space.

### III. MAJOR EQUIPMENT LIST

The equipment list contains major energy consuming equipment that through implementation of energy conservation measures could yield substantial energy savings. The list shows the major equipment in the facility and all pertinent information utilized in energy savings calculations. An approximate age was assigned to the equipment in some cases if a manufactures date was not shown on the equipment's nameplate. The ASHRAE service life for the equipment along with the remaining useful life is also shown in the Appendix.

Refer to the **Major Equipment List Appendix** for this facility.



#### IV. ENERGY CONSERVATION MEASURES

Energy Conservation Measures are developed specifically for this facility. The energy savings and calculations are highly dependent on the information received from the site survey and interviews with operations personnel. The assumptions and calculations should be reviewed by the owner to ensure accurate representation of this facility. The following ECMs were analyzed:

**Table 1**  
**ECM Financial Summary**

| <b>ENERGY CONSERVATION MEASURES (ECM's)</b> |                                     |  |                                   |                             |                            |
|---|-------------------------------------|--|-----------------------------------|-----------------------------|----------------------------|
| <b>ECM NO.</b>                              | <b>DESCRIPTION</b>                  | <b>NET INSTALLATION COST<sup>A</sup></b> | <b>ANNUAL SAVINGS<sup>B</sup></b> | <b>SIMPLE PAYBACK (Yrs)</b> | <b>SIMPLE LIFETIME ROI</b> |
| ECM #1                                      | Lighting Upgrade - General          | \$7,780                                  | \$1,044                           | 7.5                         | 101.3%                     |
| ECM #2                                      | Premium Efficient Motor Replacement | \$4,200                                  | \$164                             | 25.6                        | -29.7%                     |
| ECM #3                                      | Split System Replacement            | \$6,974                                  | \$260                             | 26.8                        | -44.1%                     |
| ECM #4                                      | Domestic Hot Water Heater Upgrade   | \$6,500                                  | \$92                              | 70.7                        | -83.0%                     |
| <b>RENEWABLE ENERGY MEASURES (REM's)</b>    |                                     |  |                                   |                             |                            |
| <b>ECM NO.</b>                              | <b>DESCRIPTION</b>                  | <b>NET INSTALLATION COST</b>             | <b>ANNUAL SAVINGS</b>             | <b>SIMPLE PAYBACK (Yrs)</b> | <b>SIMPLE LIFETIME ROI</b> |
| REM #1                                      | 31.44 kW PV System                  | \$123,180                                | \$13,583                          | 9.1                         | 65.4%                      |

**Notes:** A. Cost takes into consideration applicable NJ Smart Start<sup>TM</sup> incentives.  
B. Savings takes into consideration applicable maintenance savings.

**Table 2**  
**ECM Energy Summary**

| <b>ENERGY CONSERVATION MEASURES (ECM's)</b> |                                     |                                 |                                   |                             |
|---|-------------------------------------|---------------------------------|-----------------------------------|-----------------------------|
| <b>ECM NO.</b>                              | <b>DESCRIPTION</b>                  | <b>ANNUAL UTILITY REDUCTION</b> |                                   |                             |
|   |                                     | <b>ELECTRIC DEMAND (KW)</b>     | <b>ELECTRIC CONSUMPTION (KWH)</b> | <b>NATURAL GAS (THERMS)</b> |
| ECM #1                                      | Lighting Upgrade - General          | 3.8                             | 7,054                             | 0                           |
| ECM #2                                      | Premium Efficient Motor Replacement | 0.6                             | 1,108                             | 0                           |
| ECM #3                                      | Split System Replacement            | 1.6                             | 1,760                             | 0                           |
| ECM #4                                      | Domestic Hot Water Heater Upgrade   | 0.0                             | 624                               | 0                           |
| <b>RENEWABLE ENERGY MEASURES (REM's)</b>    |                                     |                                 |                                   |                             |
| <b>ECM NO.</b>                              | <b>DESCRIPTION</b>                  | <b>ANNUAL UTILITY REDUCTION</b> |                                   |                             |
|   |                                     | <b>ELECTRIC DEMAND (KW)</b>     | <b>ELECTRIC CONSUMPTION (KWH)</b> | <b>NATURAL GAS (THERMS)</b> |
| REM #1                                      | 31.44 kW PV System                  | 31.4                            | 40,059                            | 0                           |

**Table 3**  
**ECM Emissions Summary**

| <b>ENERGY CONSERVATION MEASURES (ECM's)</b> |   |   |                                       |                                       |
|---|---|---|---------------------------------------|---------------------------------------|
| <b>ECM NO.</b>                              | <b>DESCRIPTION</b>  | <b>GREENHOUSE GAS EMISSIONS REDUCTION</b> |                                       |                                       |
|   |   | <b>CO<sub>2</sub> EMISSIONS (LBS)</b>     | <b>NO<sub>x</sub> EMISSIONS (LBS)</b> | <b>SO<sub>2</sub> EMISSIONS (LBS)</b> |
| ECM #1                                      | Lighting Upgrade - General  | 10,722                                    | 20                                    | 46                                    |
| ECM #2                                      | Premium Efficient Motor Replacement   | 1,684                                     | 3                                     | 7                                     |
| ECM #3                                      | Split System Replacement  | 2,675                                     | 5                                     | 11                                    |
| ECM #4                                      | Domestic Hot Water Heater Upgrade   | 948                                       | 2                                     | 4                                     |
| <b>Notes:</b>                               | A. Emissions Reduction based on NJCEP published factors for electric & gas. |   |                                       |                                       |

**Table 4**  
**Facility Project Summary**

| FACILITY PROJECT SUMMARY TABLE      |                            |                   |                        |                 |                |
|-------------------------------------|----------------------------|-------------------|------------------------|-----------------|----------------|
| ENERGY CONSERVATION MEASURES        | ANNUAL ENERGY SAVINGS (\$) | PROJECT COST (\$) | SMART START INCENTIVES | CUSTOMER COST   | SIMPLE PAYBACK |
| Lighting Upgrade - General          | \$1,044                    | \$7,780           | \$0                    | \$7,780         | 7.5            |
| Premium Efficient Motor Replacement | \$164                      | \$4,200           | \$0                    | \$4,200         | 25.6           |
| Split System Replacement            | \$260                      | \$7,250           | \$276                  | \$6,974         | 26.8           |
| Domestic Hot Water Heater Upgrade   | \$92                       | \$7,000           | \$500                  | \$6,500         | 70.7           |
| <b>Total Project</b>                | <b>\$1,560</b>             | <b>\$26,230</b>   | <b>\$776</b>           | <b>\$25,454</b> | <b>16.3</b>    |

Note the measure totals in this table do not take into account interactive effects of measures; see Method of Analysis Section III in Executive Report for further explanation.

This project does not qualify for additional incentives through the Pay for Performance Program; please see the Installation Funding Options section for additional program options.

## ECM #1: Lighting Upgrade – General

### Description:

The majority of the interior lighting throughout the Swim Complex is provided with fluorescent fixtures with older generation, 32W T8 lamps and electronic ballasts. Additionally, there are several areas that still contain T12 fixtures with magnetic ballasts. These fixtures can be replaced and retrofit with new LED type fixtures and lamps.

This ECM includes replacing and retrofitting the interior lighting with new LED type lamps and fixtures. It is recommended the Township consult with a professional engineer prior to retrofitting or replacing fixtures to ensure code required minimum light levels will be met.

### Energy Savings Calculations:

The **Investment Grade Lighting Audit Appendix** outlines the hours of operation, proposed retrofits, costs, savings, and payback periods for each set of fixtures in the each building.

| LIGHTING UPGRADE SAVINGS SUMMARY |         |
|----------------------------------|---------|
| DESCRIPTION                      | SAVINGS |
| Electric Demand Savings (kW)     | 3.8     |
| Electric Usage Savings (kWh)     | 7,054   |
| Electric Cost Savings (\$)       | \$1,044 |

### Energy Savings Summary:

| ECM #1 - ENERGY SAVINGS SUMMARY          |            |
|--|------------|
| Installation Cost (\$):                  | \$7,780    |
| NJ Smart Start Equipment Incentive (\$): | \$0        |
| Net Installation Cost (\$):              | \$7,780    |
| Maintenance Savings (\$/Yr):             | \$0        |
| Energy Savings (\$/Yr):                  | \$1,044    |
| Total Yearly Savings (\$/Yr):            | \$1,044    |
| Estimated ECM Lifetime (Yr):             | 15         |
| Simple Payback                           | 7.5        |
| Simple Lifetime ROI                      | 101.3%     |
| Simple Lifetime Maintenance Savings      | \$0        |
| Simple Lifetime Savings                  | \$15,659   |
| Internal Rate of Return (IRR)            | 10%        |
| Net Present Value (NPV)                  | \$4,682.76 |

## ECM #2: Premium Efficiency Motors

### Description:

The improved efficiency of the NEMA Premium® efficient motors is primarily due to better designs with use of better materials to reduce losses. Surprisingly, the electricity used to power a motor represents 95 % of its total lifetime operating cost. Because many motors operate continuously 24 hours a day, even small increases in efficiency can yield substantial energy and dollar savings.

The electric motors driving the pumps are candidates for replacing with premium efficiency motors. These standard efficiency motors run considerable amount of time over a year.

This energy conservation measure replaces existing inefficient electric motors with NEMA Premium® efficiency motors.

| IMPLEMENTATION SUMMARY |                |          |                    |                     |                         |
|------------------------|----------------|----------|--------------------|---------------------|-------------------------|
| EQMT ID                | FUNCTION       | MOTOR HP | HOURS OF OPERATION | EXISTING EFFICIENCY | NEMA PREMIUM EFFICIENCY |
| P-1                    | Main Pool Pump | 15       | 2,000              | 91.0%               | 93.0%                   |
| P-2                    | Dive Pump      | 15       | 2,000              | 89.5%               | 93.0%                   |

### Energy Savings Calculations:

$$\text{Electric Usage, kWh} = \frac{\text{HP} \times \text{LF} \times 0.746 \times \text{Hours of Operation}}{\text{Motor Efficiency}}$$

where, HP = Motor Nameplate Horsepower Rating

$LF = \text{Load Factor}$                       Motor Efficiency = Motor Nameplate Efficiency

$$\text{Electric Usage Savings kWh} = \text{Electric Usage}_{\text{Existing}} - \text{Electric Usage}_{\text{Proposed}}$$

$$\text{Electric cost savings} = \text{Electric Usage Savings} \times \text{Electric Rate} \left( \frac{\$}{\text{kWh}} \right)$$

The calculations were carried out and the results are tabulated in the table below:

| <b>PREMIUM EFFICIENCY MOTOR CALCULATIONS</b> |            |                 |                    |                            |                            |                         |                           |                     |
|--|------------|-----------------|--------------------|----------------------------|----------------------------|-------------------------|---------------------------|---------------------|
| <b>EQMT ID</b>                               | <b>QTY</b> | <b>MOTOR HP</b> | <b>LOAD FACTOR</b> | <b>EXISTING EFFICIENCY</b> | <b>PROPOSED EFFICIENCY</b> | <b>POWER SAVINGS kW</b> | <b>ENERGY SAVINGS kWh</b> | <b>COST SAVINGS</b> |
| P-1  | 1          | 15              | 75%                | 91.0%                      | 93.0%                      | 0.20                    | 399                       | \$59                |
| P-2  | 1          | 15              | 75%                | 89.5%                      | 93.0%                      | 0.35                    | 710                       | \$105               |
| <b>TOTAL</b>                                 |            |                 |                    |                            |                            | <b>0.6</b>              | <b>1,108</b>              | <b>\$164</b>        |

There are no longer incentives available through NJ Smart Start for premium efficiency motors.

### Energy Savings Summary:

| <b>ECM #2 - ENERGY SAVINGS SUMMARY</b>          |              |
|---|--------------|
| <b>Installation Cost (\$):</b>                  | \$4,200      |
| <b>NJ Smart Start Equipment Incentive (\$):</b> | \$0          |
| <b>Net Installation Cost (\$):</b>              | \$4,200      |
| <b>Maintenance Savings (\$/Yr):</b>             | \$0          |
| <b>Energy Savings (\$/Yr):</b>                  | \$164        |
| <b>Total Yearly Savings (\$/Yr):</b>            | \$164        |
| <b>Estimated ECM Lifetime (Yr):</b>             | 18           |
| <b>Simple Payback</b>                           | 25.6         |
| <b>Simple Lifetime ROI</b>                      | -29.7%       |
| <b>Simple Lifetime Maintenance Savings</b>      | \$0          |
| <b>Simple Lifetime Savings</b>                  | \$2,952      |
| <b>Internal Rate of Return (IRR)</b>            | -3%          |
| <b>Net Present Value (NPV)</b>                  | (\$1,944.42) |

### ECM #3: Replace Split System Units with High Efficiency Units

#### Description:

The Swim Complex has one (1) split system air conditioning only unit which serves interior office space. The unit is 17 years old and has surpassed its ASHRAE service life expectancy. Replacing the unit with a newer more efficient unit could result in significant energy savings.

The unit currently installed is lower efficiency compared to modern units. The unit can be replaced with new high-efficiency unit. New units provide higher full load and part load efficiencies due to advances in inverter motor technologies, higher efficiency refrigerants such as R410A which would be used in place of R22 that is currently used in the existing unit.

This ECM includes one-for-one replacement of the one (1) older split system unit with new higher efficiency systems as well as replacing the indoor coil. It is recommended to fully evaluate the capacity needed for all new systems prior to moving forward with this ECM. A summary of the unit replacement for this ECM can be found in the table below:

| IMPLEMENTATION SUMMARY |              |                 |                          |                      |  |
|------------------------|--------------|-----------------|--------------------------|----------------------|--|
| ECM INPUTS             | SERVICE FOR  | NUMBER OF UNITS | COOLING CAPACITY, BTU/HR | TOTAL CAPACITY, TONS | REPLACE UNIT WITH                      |
| SS                     | Split System | 1               | 36,000                   | 3.0                  | York CZH and Indoor Coil or Equivalent |
| <b>Total</b>           |              | <b>1</b>        | <b>36,000</b>            | <b>3.00</b>          |  |

The manufacturer used as the basis for the calculation is York. The unit pricing and install cost were estimated based on current rates quotes and labor rates. The payback may change based on actual unit pricing and install costs if the ECM is implemented.

#### Energy Savings Calculations:

##### Cooling Energy Savings:

Seasonal energy consumption of the air conditioners at the cooling mode is calculated with the equation below:

$$\text{Energy Savings, kWh} = \text{Cooling Capacity, } \frac{\text{BTU}}{\text{Hr}} \times \left( \frac{1}{\text{SEER}_{\text{Old}}} - \frac{1}{\text{SEER}_{\text{New}}} \right) \times \frac{\text{Operation Hours}}{1000 \frac{\text{W}}{\text{kWh}}}$$

$$\text{Demand Savings, kW} = \frac{\text{Energy Savings (kWh)}}{\text{Hours of Cooling}}$$

$$\text{Cooling Cost Savings} = \text{Energy Savings, kWh} \times \text{Cost of Electricity} \left( \frac{\$}{\text{kWh}} \right)$$



| ENERGY SAVINGS CALCULATIONS |                          |                      |                    |               |            |                    |                   |
|-----------------------------|--------------------------|----------------------|--------------------|---------------|------------|--------------------|-------------------|
| ECM INPUTS                  | COOLING CAPACITY, BTU/Hr | ANNUAL COOLING HOURS | EXISTING UNITS EER | NEW UNITS EER | # OF UNITS | ENERGY SAVINGS kWh | DEMAND SAVINGS kW |
| SS                          | 36,000                   | 1,100                | 10 SEER            | 18 SEER       | 1          | 1,760              | 1.6               |
| <b>Total</b>                |                          |                      |                    |               | 1          | 1,760              | 1.6               |

### Project Cost, Incentives and Maintenance Savings

From the NJ Smart Start<sup>®</sup> Program appendix, the replacement of split system AC units and unitary systems with high efficiency AC systems falls under the category “Unitary HVAC Split System” and warrants an incentive based on efficiency (EER/SEER). The program incentives are calculated as follows:

$$\text{Smart Start}^{\text{®}} \text{ Incentive} = (\text{Cooling Tons} \times \$/\text{Ton Incentive})$$

| AC UNITS REBATE SUMMARY                            |                 |               |                        |                 |
|--|-----------------|---------------|------------------------|-----------------|
| UNIT DESCRIPTION                                   | UNIT EFFICIENCY | REBATE \$/TON | PROPOSED CAPACITY TONS | TOTAL REBATE \$ |
| 5.4 tons or less<br>Unitary AC and<br>Split System | ≥14 SEER        | \$92          | 3.0                    | \$276           |
| <b>TOTAL</b>                                       |                 |               | <b>3</b>               | <b>\$276</b>    |

**Energy Savings Summary:**

| <b>ECM #3 - ENERGY SAVINGS SUMMARY</b>          |              |
|---|--------------|
| <b>Installation Cost (\$):</b>                  | \$7,250      |
| <b>NJ Smart Start Equipment Incentive (\$):</b> | \$276        |
| <b>Net Installation Cost (\$):</b>              | \$6,974      |
| <b>Maintenance Savings (\$/Yr):</b>             | \$0          |
| <b>Energy Savings (\$/Yr):</b>                  | \$260        |
| <b>Total Yearly Savings (\$/Yr):</b>            | \$260        |
| <b>Estimated ECM Lifetime (Yr):</b>             | 15           |
| <b>Simple Payback</b>                           | 26.8         |
| <b>Simple Lifetime ROI</b>                      | -44.1%       |
| <b>Simple Lifetime Maintenance Savings</b>      | \$0          |
| <b>Simple Lifetime Savings</b>                  | \$3,900      |
| <b>Internal Rate of Return (IRR)</b>            | -7%          |
| <b>Net Present Value (NPV)</b>                  | (\$3,870.14) |

## ECM #4: Domestic Hot Water Heater Upgrade

### Description:

The domestic water for this facility is produced by a Rheem Water Heater Model 81V-30DA electric storage tank water heater with a capacity of 30 gallons and an input capacity of 4.5 kW. Maintaining an electric hot water heater for a building this size is not cost effective and upgrading to a hybrid electric unit may incur significant cost savings.

This ECM will replace this electric domestic water heater with a hybrid 2.40 energy factor General Electric Geospring Series water heater or equivalent. This unit will be replaced with a 4.5 kW, 50 gallon tank water heater. (Before proceeding with installation of aforementioned system, Concord Engineering suggests consulting a mechanical engineer to evaluate the system fully.)

### Energy Savings Calculations:

| DOM. HOT WATER HEATER CALCULATIONS |   |                                  |         |
|------------------------------------|---|----------------------------------|---------|
| ECM INPUTS                         | EXISTING  | PROPOSED                         | SAVINGS |
| ECM INPUTS                         | Existing Electric Hot Water Heaters   | Hybrid Electric Hot Water Heater |         |
| Building Type                      | Public Assembly   |                                  |         |
| Building Square-foot               | 3,528   | 3,528                            |         |
| Domestic Water Usage, kBtu         | 3,175.20  | 3,175.20                         |         |
| DHW Heating Fuel Type              | Electric  | Electric                         |         |
| Energy Factor                      | 0.92  | 2.40                             | 148%    |
| Total Usage (kBtu)                 | 3,451   | 1,323                            | 2,128   |
| Electric Cost (\$/kWh)             | \$ 0.148  | \$ 0.148                         |         |
| ENERGY SAVINGS CALCULATIONS        |   |                                  |         |
| ECM RESULTS                        | EXISTING  | PROPOSED                         | SAVINGS |
| Electric Usage (kWh)               | 1,011   | 388                              | 624     |
| Energy Cost (\$)                   | \$150   | \$57                             | \$92    |
| COMMENTS:                          | Savings are based on Energy Information Administration Commercial Building Energy Consumption Survey 2003 Information |                                  |         |

Energy Density for “Public Assembly” type building = 0.9 kBtu / SF / year

$$DHW \text{ Heat Usage} = \text{Energy Density} \left( \frac{\text{kBtu yr}}{\text{SF}} \right) \times \text{Building Square Footage (SF)}$$

$$DHW \text{ Total Usage} = \frac{\text{Dom HW Heat Cons. (Btu)}}{\text{Heating Eff. (\%)} \times \text{Fuel Heat Value} \left( \frac{\text{BTU}}{\text{Fuel Unit}} \right)}$$

$$\text{Energy Cost} = \text{Heating Fuel Usage (Fuel Units)} \times \text{Ave Fuel Cost} \left( \frac{\$}{\text{Fuel Unit}} \right)$$

#### Energy Savings Summary:

| ECM #4 - ENERGY SAVINGS SUMMARY          |              |
|--|--------------|
| Installation Cost (\$):                  | \$7,000      |
| NJ Smart Start Equipment Incentive (\$): | \$500        |
| Net Installation Cost (\$):              | \$6,500      |
| Maintenance Savings (\$/Yr):             | \$0          |
| Energy Savings (\$/Yr):                  | \$92         |
| Total Yearly Savings (\$/Yr):            | \$92         |
| Estimated ECM Lifetime (Yr):             | 12           |
| Simple Payback                           | 70.7         |
| Simple Lifetime ROI                      | -83.0%       |
| Simple Lifetime Maintenance Savings      | \$0          |
| Simple Lifetime Savings                  | \$1,104      |
| Internal Rate of Return (IRR)            | -20%         |
| Net Present Value (NPV)                  | (\$5,584.23) |

## REM #1: 31.44 kW Solar System

### Description:

The Swim Complex has available ground mount space that could accommodate solar arrays. Based on the available area a 31.44 kilowatt solar array could be installed. The array will produce approximately 40,059 kilowatt-hours annually that will reduce the overall electric usage of the facility by 35.39%. Ground mount solar is typically the least expensive option for owners to implement, and in this situation while ground area is likely used for recreational space we recommend the owner consider innovative approaches to incorporating solar on the ground area, such as installing a covered picnic canopy with solar located on the roof.

### Energy Savings Calculations:

See **Renewable / Distributed Energy Measures Calculations Appendix** for detailed financial summary and proposed solar layout areas. Financial results in table below are based on 100% financing of the system over a fifteen year period.

### Energy Savings Summary:

| REM #1 - ENERGY SAVINGS SUMMARY          |             |
|--|-------------|
| Installation Cost (\$):                  | \$123,180   |
| NJ Smart Start Equipment Incentive (\$): | \$0         |
| Net Installation Cost (\$):              | \$123,180   |
| Maintenance Savings (\$/Yr):             | \$7,655     |
| Energy Savings (\$/Yr):                  | \$5,929     |
| Total Yearly Savings (\$/Yr):            | \$13,583    |
| Estimated ECM Lifetime (Yr):             | 15          |
| Simple Payback                           | 9.1         |
| Simple Lifetime ROI                      | 65.4%       |
| Simple Lifetime Maintenance Savings      | \$114,820   |
| Simple Lifetime Savings                  | \$203,751   |
| Internal Rate of Return (IRR)            | 7.1%        |
| Net Present Value (NPV)                  | \$38,977.22 |

## **V. ADDITIONAL RECOMMENDATIONS**

The following recommendations include no cost/low cost measures, Operation & Maintenance (O&M) items, and water conservation measures with attractive paybacks. These measures are not eligible for the Smart Start Buildings incentives from the office of Clean Energy but save energy none the less.

- A. Chemically clean the condenser and evaporator coils periodically to optimize efficiency. Poorly maintained heat transfer surfaces can reduce efficiency 5-10%.
- B. Maintain all weather stripping on windows and doors.
- C. Clean all light fixtures to maximize light output.
- D. Provide more frequent air filter changes to decrease overall system power usage and maintain better IAQ.
- E. Turn off computers when not in use. Ensure computers are not running in screen saver mode.
- F. Replace any old CRT Monitors with LED/LCD Type Monitors, which can draw as much as a quarter the power of an equivalent CRT monitor.
- G. Ensure outside air dampers are functioning properly and only open during occupied mode.

## **APPENDIX A**

**ECM COST & SAVINGS BREAKDOWN**

CONCORD ENGINEERING GROUP

Marlboro Township - Swim Complex

**ECM ENERGY AND FINANCIAL COSTS AND SAVINGS SUMMARY**

| ECM NO.   | DESCRIPTION                         | INSTALLATION COST |         |                        |                             | YEARLY SAVINGS |               |          | ECM<br>LIFETIME | LIFETIME ENERGY<br>SAVINGS     | LIFETIME<br>MAINTENANCE<br>SAVINGS      | LIFETIME ROI                                  | SIMPLE PAYBACK              | INTERNAL RATE OF<br>RETURN (IRR)       | NET PRESENT VALUE<br>(NPV)            |
|---|-------------------------------------|-------------------|---------|------------------------|-----------------------------|----------------|---------------|----------|-----------------|--------------------------------|---|---|-----------------------------|--|---------------------------------------|
|   |                                     | MATERIAL          | LABOR   | REBATES,<br>INCENTIVES | NET<br>INSTALLATION<br>COST | ENERGY         | MAINT. / SREC | TOTAL    |                 | (Yearly Saving * ECM Lifetime) | (Yearly Maint Svaing * ECM<br>Lifetime) | (Lifetime Savings - Net Cost) /<br>(Net Cost) | (Net cost / Yearly Savings) | $\sum_{n=0}^N \frac{C_n}{(1 + IRR)^n}$ | $\sum_{n=0}^N \frac{C_n}{(1 + DR)^n}$ |
|   |                                     | (\$)              | (\$)    | (\$)                   | (\$)                        | (\$/Yr)        | (\$/Yr)       | (\$/Yr)  |                 | (\$)                           | (\$)                                    | (%)   | (Yr)                        | (\$)                                   | (\$)                                  |
| ECM #1  | Lighting Upgrade - General          | \$5,210           | \$2,570 | \$0                    | \$7,780                     | \$1,044        | \$0           | \$1,044  | 15              | \$15,659                       | \$0                                     | 101.3%  | 7.5                         | 10.36%                                 | \$4,682.76                            |
| ECM #2  | Premium Efficient Motor Replacement | \$3,200           | \$1,000 | \$0                    | \$4,200                     | \$164          | \$0           | \$164    | 18              | \$2,952                        | \$0                                     | -29.7%  | 25.6                        | -3.47%                                 | (\$1,944.42)                          |
| ECM #3  | Split System Replacement            | \$3,750           | \$3,500 | \$276                  | \$6,974                     | \$260          | \$0           | \$260    | 15              | \$3,900                        | \$0                                     | -44.1%  | 26.8                        | -6.52%                                 | (\$3,870.14)                          |
| ECM #4  | Domestic Hot Water Heater Upgrade   | \$4,000           | \$3,000 | \$500                  | \$6,500                     | \$92           | \$0           | \$92     | 12              | \$1,104                        | \$0                                     | -83.0%  | 70.7                        | -20.37%                                | (\$5,584.23)                          |
| <b>REM RENEWABLE ENERGY AND FINANCIAL COSTS AND SAVINGS SUMMARY</b> |                                     |                   |         |                        |                             |                |               |          |                 |                                |   |   |                             |  |                                       |
| REM #1  | 31.44 kW PV System                  | \$123,180         | \$0     | \$0                    | \$123,180                   | \$5,929        | \$7,655       | \$13,583 | 15              | \$203,751                      | \$114,820                               | 65.4%   | 9.1                         | 7.07%                                  | \$38,977.22                           |

- Notes:**
- 1) The variable Cn in the formulas for Internal Rate of Return and Net Present Value stands for the cash flow during each period.
  - 2) The variable DR in the NPV equation stands for Discount Rate
  - 3) For NPV and IRR calculations: From n=0 to N periods where N is the *lifetime of ECM* and Cn is the *cash flow during each period* .



## **APPENDIX B**

# Concord Engineering Group, Inc.

520 BURNT MILL ROAD  
VOORHEES, NEW JERSEY 08043  
PHONE: (856) 427-0200  
FAX: (856) 427-6508



## SmartStart Building Incentives

The NJ SmartStart Buildings Program offers financial incentives on a wide variety of building system equipment. The incentives were developed to help offset the initial cost of energy-efficient equipment. The following tables show the current available incentives from July 1, 2013 to June 30, 2014:

### **Electric Chillers**

|                       |                      |
|-----------------------|----------------------|
| Water-Cooled Chillers | \$16 - \$170 per ton |
| Air-Cooled Chillers   | \$8 - \$52 per ton   |

Energy Efficiency must comply with ASHRAE 90.1-2007

### **Gas Cooling**

|                            |   |
|----------------------------|---|
| Gas Absorption Chillers    | \$185 - \$450 per ton                   |
| Gas Engine-Driven Chillers | Calculated through custom measure path) |

### **Desiccant Systems**

|                                  |
|----------------------------------|
| \$1.00 per cfm – gas or electric |
|----------------------------------|

### **Electric Unitary HVAC**

|  |  |
|--|--|
| Unitary AC and Split Systems   | \$73 - \$92 per ton                    |
| Air-to-Air Heat Pumps  | \$73 - \$92 per ton                    |
| Water-Source Heat Pumps  | \$81 per ton                           |
| Packaged Terminal AC & HP  | \$65 per ton                           |
| Central DX AC Systems  | \$40- \$72 per ton                     |
| Dual Enthalpy Economizer Controls                                      | \$250                                  |
| Occupancy Controlled Thermostat (Hospitality & Institutional Facility) | \$75 per thermostat                    |
| A/C Economizing Controls   | ≤ 5 tons \$85/unit; >5 tons \$170/unit |

Energy Efficiency must comply with ASHRAE 90.1-2007

### **Gas Heating**

|                                      |  |
|--------------------------------------|--|
| Gas Fired Boilers < 300 MBH          | \$2.00 per MBH, but not less than \$300 per unit |
| Gas Fired Boilers ≥ 300 - 1500 MBH   | \$1.75 per MBH                                   |
| Gas Fired Boilers ≥1500 - ≤ 4000 MBH | \$1.00 per MBH                                   |
| Gas Fired Boilers > 4000 MBH         | (Calculated through Custom Measure Path)         |
| Gas Furnaces                         | \$400 per unit, AFUE ≥ 95%                       |
| Boiler Economizing Controls          | \$1,200 - \$2,700                                |
| Low Intensity Infrared Heating       | \$300 - \$500 per unit                           |

### Ground Source Heat Pumps

|             |  |
|-------------|--|
| Closed Loop | \$450 per ton, EER $\geq$ 16<br>\$600 per ton, EER $\geq$ 18<br>\$750 per ton, EER $\geq$ 20 |
|-------------|--|

Energy Efficiency must comply with ASHRAE 90.1-2007

### Variable Frequency Drives

|   |  |
|---|--|
| Variable Air Volume                       | \$65 - \$155 per hp  |
| Chilled-Water Pumps $\geq$ 20 hp          | \$60 per VFD rated hp  |
| Rotary Screw Air Compressors $\geq$ 25 hp | \$5,250 to \$12,500 per drive                                |
| Cooling Towers $\geq$ 10 hp               | \$60 per VFD rated hp  |
| Boiler Fans $\geq$ 5 HP                   | \$65 to \$155 per hp   |
| Boiler Feed Water Pumps $\geq$ 5 HP       | \$60 to \$155 per hp   |
| Commercial Kitchen Hood up to 50 HP       | Retrofit \$55 – \$300 per hp<br>New Hood \$55 - \$250 per hp |

### Natural Gas Water Heating

|   |                         |
|---|-------------------------|
| Gas Water Heaters $\leq$ 50 gallons, 0.67 energy factor or better | \$50 per unit           |
| Gas-Fired Water Heaters $>$ 50 gallons                            | \$1.00 - \$2.00 per MBH |
| Gas-Fired Booster Water Heaters                                   | \$17 - \$35 per MBH     |
| Gas Fired Tankless Water Heaters                                  | \$300 per unit          |

### Prescriptive Lighting

|   |                          |
|---|--------------------------|
| T-8 reduced Wattage<br>(28w/25w 4', 1-4 lamps)<br>Lamp & ballast replacement  | \$10 per fixture         |
| For retrofit of T-8 fixtures by<br>permanent de-lamping & new reflectors<br>(Electronic ballast replacement<br>required)            | \$15 per fixture         |
| T-5 and T-8 High Bay Fixtures   | \$16 - \$200 per fixture |
| Metal Halide w/Pulse Start<br>Including Parking Lot<br>(For fixtures $\geq$ 150w)   | \$25 per fixture         |
| HID $\geq$ 100w Replace with new<br>induction fixture.<br>(must be 30% less watts/fixture than<br>HID system)                       | \$70 per fixture         |
| HID $\geq$ 100w Retrofit with induction<br>lamp, power coupler and generator<br>(must be 30% less watts/fixture than<br>HID system) | \$50 per fixture         |

### Prescriptive Lighting - LED

|  |  |
|--|--|
| LED Display Case Lighting  | \$30 per display case  |
| LED Shelf-Mtd. Display & Task Lights   | \$15 per linear foot   |
| LED Portable Desk Lamp   | \$20 per fixture   |
| LED Wall-wash Lights   | \$30 per fixture   |
| LED Recessed Down Lights   | \$35 per fixture   |
| LED Outdoor Pole/Arm-Mounted Area and Roadway Luminaries   | \$175 per fixture  |
| LED Outdoor Pole/Arm-Mounted Decorative Luminaries   | \$175 per fixture  |
| LED Outdoor Wall-Mounted Area Luminaries   | \$100 per fixture  |
| LED Parking Garage Luminaries  | \$100 per fixture  |
| LED Track or Mono-Point Directional Lighting Fixtures  | \$50 per fixture   |
| LED High-Bay and Low-Bay Fixtures for Commercial & Industrial Bldgs.   | \$150 per fixture  |
| LED High-Bay-Aisle Lighting  | \$150 per fixture  |
| LED Stairwell and Passageway Luminaires  | \$40 per fixture   |
| LED Bollard Fixtures   | \$50 per fixture   |
| Luminaires for Ambient Lighting of Interior Commercial Spaces (1x4, 2x2, 2x4)                                | \$50 per fixture   |
| LED Fuel Pump Canopy   | \$100 per fixture  |
| LED Screw-based & Pin-based (PAR, MR, BR, R) Standards (A-Style) and Decorative Lamps                        | \$10 per lamp for R/PAR20,MR/PAR16,Globe,Candelabra or Misc<br>\$20 per lamp for R/BR/PAR 30, R/BR/PAR 38-40, A-Lamp |
| LED Refrigerator/Freezer case lighting replacement of fluorescent in medium and low temperature display case | \$30 per 4 foot<br>\$42 per 5 foot<br>\$65 per 6 foot  |
| LED Retrofit Kits  | To be evaluated through the customer measure path  |

### Lighting Controls – Occupancy Sensors

|  |                             |
|--|-----------------------------|
| Wall Mounted<br>(Existing Facilities Only)   | \$20 per control            |
| Remote Mounted<br>(Existing Facilities Only) | \$35 per control            |
| Daylight Dimming Controls                    | \$45 per fixture controlled |
| Occupancy Based hi-low Dimming<br>Control    | \$35 per fixture controlled |
| Occupancy Sensor Remote Mounted              | \$35 per control            |

### Refrigeration Doors/Covers

|  |                        |
|--|------------------------|
| Energy-Efficient Doors/Covers for<br>Installation on Open Refrigerated Cases | \$100 per door         |
| Aluminum Night Curtains for<br>Installation on Open Refrigerated Cases       | \$3.50 per linear foot |

### Refrigeration Controls

|                           |                  |
|---------------------------|------------------|
| Door Heater Controls      | \$50 per control |
| Electric Defrost Controls | \$50 per control |
| Evaporator Fan Controls   | \$75 per control |
| Novelty Cooler Shutoff    | \$50 per control |

### Other Equipment Incentives

|   |  |
|---|--|
| Performance Lighting                            | \$1.00 per watt per SF below program<br>incentive threshold, currently 5% more<br>energy efficient than ASHRAE 90.1-<br>2007 for New Construction and<br>Complete Renovation                               |
| Custom Electric and Gas Equipment<br>Incentives | not prescriptive   |
| Custom Measures                                 | \$0.16 KWh and \$1.60/Therm of 1st<br>year savings, or a buy down to a 1 year<br>payback on estimated savings.<br>Minimum required savings of 75,000<br>KWh or 1,500 Therms and an IRR of at<br>least 10%. |

## **APPENDIX C**



# ENERGY STAR<sup>®</sup> Statement of Energy Performance

# N/A

ENERGY STAR<sup>®</sup>  
Score<sup>1</sup>

## Swim Club

**Primary Property Function:** Swimming Pool  
**Gross Floor Area (ft<sup>2</sup>):** 2,700  
**Built:** 1985

**For Year Ending:** December 31, 2013  
**Date Generated:** July 11, 2014

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

### Property & Contact Information

**Property Address**

Swim Club  
60 Masepe Trail  
Marlboro, New Jersey 07746

**Property Owner**

Marlboro Township  
1979 Township Drive  
Marlboro, NJ 07446  
( ) -

**Primary Contact**

Jonathan Capp  
1979 Township Drive  
Marlboro, NJ 07446  
732-536-0200  
jcapp@marlboro-nj.gov

**Property ID:** 4091295

### Energy Consumption and Energy Use Intensity (EUI)

**Site EUI**

143.1 kBtu/ft<sup>2</sup>

**Annual Energy by Fuel**

Electric - Grid (kBtu) 386,238 (100%)

**National Median Comparison**

National Median Site EUI (kBtu/ft<sup>2</sup>) 30.8

National Median Source EUI (kBtu/ft<sup>2</sup>) 96.8

% Diff from National Median Source EUI 364%

**Source EUI**

449.2 kBtu/ft<sup>2</sup>

**Annual Emissions**

Greenhouse Gas Emissions (Metric Tons CO<sub>2</sub>e/year) 49

### Signature & Stamp of Verifying Professional

I \_\_\_\_\_ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

#### Licensed Professional

\_\_\_\_\_  
,  
( ) -  
\_\_\_\_\_



**Professional Engineer Stamp**  
(if applicable)

## **APPENDIX D**



## **MAJOR EQUIPMENT LIST**

### **Concord Engineering Group**

#### **Swim Complex**

### **Split System Units**

|  |                                   |                                 |  |
|--|-----------------------------------|---------------------------------|--|
| <b>Tag</b>                               |                                   |                                 |  |
| <b>Unit Type</b>                         | Split System<br>Condensing Unit   | Split System<br>Condensing Unit |  |
| <b>Qty</b>                               | 1                                 | 1                               |  |
| <b>Location</b>                          | Roof of Office Area               | Roof of Office Area             |  |
| <b>Area Served</b>                       | Offices                           | Offices                         |  |
| <b>Manufacturer</b>                      | International Comfort<br>Products | Lennox                          |  |
| <b>Model #</b>                           | CA5536VHD3 /<br>CBA036HB3         | 13ACD-060-230-15                |  |
| <b>Serial #</b>                          | L9743 47888                       | 1911D20891                      |  |
| <b>Cooling Type</b>                      | DX, R-22                          | DX, R-22                        |  |
| <b>Cooling Capacity (Tons)</b>           | 3 Tons                            | 5 Tons                          |  |
| <b>Cooling Efficiency<br/>(SEER/EER)</b> | 10 SEER                           | 13.5 SEER /<br>11 EER           |  |
| <b>Heating Type</b>                      | N/A                               | N/A                             |  |
| <b>Heating Input (MBH)</b>               | N/A                               | N/A                             |  |
| <b>Efficiency</b>                        | N/A                               | N/A                             |  |
| <b>Fuel</b>                              | N/A                               | N/A                             |  |
| <b>Approx Age</b>                        | 17                                | 3                               |  |
| <b>ASHRAE Service Life</b>               | 15                                | 15                              |  |
| <b>Remaining Life</b>                    | (2)                               | 12                              |  |
| <b>Comments</b>                          |                                   |                                 |  |

**Note:**

"N/A" = Not Applicable.

"-" = Info Not Available

# **MAJOR EQUIPMENT LIST**

## **Concord Engineering Group**

### **Swim Complex**

#### **Domestic Water Heaters**

|                                    |  |  |  |
|------------------------------------|--|--|--|
| <b>Tag</b>                         |  |  |  |
| <b>Unit Type</b>                   | Tank Hot Water Heater                    |  |  |
| <b>Qty</b>                         | 1  |  |  |
| <b>Location</b>                    | Janitor Closet in<br>Lifeguard prep area |  |  |
| <b>Area Served</b>                 | Restrooms                                |  |  |
| <b>Manufacturer</b>                | Rheem                                    |  |  |
| <b>Model #</b>                     | 81V-30D A                                |  |  |
| <b>Serial #</b>                    | R029310130B                              |  |  |
| <b>Size (Gallons)</b>              | 30                                       |  |  |
| <b>Input Capacity<br/>(MBH/KW)</b> | 4.5 kW                                   |  |  |
| <b>Recovery (Gal/Hr)</b>           | -  |  |  |
| <b>Efficiency %</b>                | 98%                                      |  |  |
| <b>Fuel</b>                        | Electric                                 |  |  |
| <b>Approx Age</b>                  | 21                                       |  |  |
| <b>ASHRAE Service Life</b>         | 12                                       |  |  |
| <b>Remaining Life</b>              | (9)                                      |  |  |
| <b>Comments</b>                    |  |  |  |

**Note:**

"N/A" = Not Applicable.

"-" = Info Not Available

# **MAJOR EQUIPMENT LIST**

## **Concord Engineering Group**

### **Swim Complex**

#### **Pumps**

|                            |                           |                           |  |
|----------------------------|---------------------------|---------------------------|--|
| <b>Tag</b>                 |                           |                           |  |
| <b>Unit Type</b>           | Base Mount End<br>Suction | Base Mount End<br>Suction |  |
| <b>Qty</b>                 | 1                         | 1                         |  |
| <b>Location</b>            | Pump Room                 | Pump Room                 |  |
| <b>Area Served</b>         | Main Pool                 | Dive Pool                 |  |
| <b>Manufacturer</b>        | Peerless Pump             | Peerless Pump             |  |
| <b>Model #</b>             | C1040AM-BE                | C1030AM-BE                |  |
| <b>Serial #</b>            | 469045                    | 468965                    |  |
| <b>Horse Power</b>         | 15.0                      | 15.0                      |  |
| <b>Flow</b>                | -                         | -                         |  |
| <b>Motor Info</b>          | Century II                | US Electric Motor         |  |
| <b>Electrical Power</b>    | 230/460/3/60              | 230/460/3/60              |  |
| <b>RPM</b>                 | 1750                      | 1765                      |  |
| <b>Motor Efficiency %</b>  | 91.0%                     | 89.5%                     |  |
| <b>Approx Age</b>          | 15                        | 15                        |  |
| <b>ASHRAE Service Life</b> | 20                        | 20                        |  |
| <b>Remaining Life</b>      | 5                         | 5                         |  |
| <b>Comments</b>            |                           |                           |  |

**Note:**

"N/A" = Not Applicable.

"-" = Info Not Available

# **MAJOR EQUIPMENT LIST**

## **Concord Engineering Group**

### **Swim Complex**

#### **Motors**

|                            |                  |              |                    |
|----------------------------|------------------|--------------|--------------------|
| <b>Tag</b>                 |                  |              |                    |
| <b>Unit Type</b>           | Motor            | Motor        | Motor              |
| <b>Qty</b>                 | 1                | 1            | 1                  |
| <b>Location</b>            | Pump Room        | Pump Room    | Pump Room          |
| <b>Area Served</b>         | Pool Pumps       | Main Pool    | Dive Pump          |
| <b>Manufacturer</b>        | Baldor           | Century II   | US Electric        |
| <b>Catalog #</b>           | JMM3158T         | -            | B089A/U01T298R041F |
| <b>Horse Power</b>         | 3.0              | 15.0         | 15.0               |
| <b>Enclosure Type</b>      | OPSB             | TEFC         | -                  |
| <b>Electrical Power</b>    | 208-230/460/3/60 | 230/460/3/60 | 230/460/3/60       |
| <b>RPM</b>                 | 3450             | 1750         | 1765               |
| <b>Efficiency %</b>        | 80.0%            | 91.0%        | 89.5%              |
| <b>Approx Age</b>          | 9                | 15           | 15                 |
| <b>ASHRAE Service Life</b> | 18               | 18           | 18                 |
| <b>Remaining Life</b>      | 9                | 3            | 3                  |
| <b>Comments</b>            |                  |              |                    |

**Note:**

"N/A" = Not Applicable.

"-" = Info Not Available


## **APPENDIX E**

CEG Project #: 1C13521  
 Facility Name: Swim Complex  
 Address: 60 Masepe Trail  
 City, State, Zip: Marlboro, NJ 07746

| Fixture Reference # | Location                       | Average Burn Hours | EXISTING FIXTURES   |                   |                   |                 |          |              | PROPOSED FIXTURE RETROFIT |   |                   |                   |                 |          | RETROFIT ENERGY SAVINGS |                    |                     | PROPOSED LIGHTING CONTROLS |               |                      |                 |                  |                     |                    |
|---------------------|--------------------------------|--------------------|---|-------------------|-------------------|-----------------|----------|--------------|---------------------------|---|-------------------|-------------------|-----------------|----------|-------------------------|--------------------|---------------------|----------------------------|---------------|----------------------|-----------------|------------------|---------------------|--------------------|
|                     |                                |                    | Description   | Lamps per Fixture | Watts per Fixture | Qty of Fixtures | Total kW | Usage kWh/Yr | Work Description          | Equipment Description                       | Lamps per Fixture | Watts per Fixture | Qty of Fixtures | Total kW | Usage kWh/Yr            | Energy Savings, kW | Energy Savings, kWh | Energy Savings, \$         | Control Ref # | Controls Description | Qty of Controls | Hour Reduction % | Energy Savings, kWh | Energy Savings, \$ |
| 1                   | Pump Room                      | 2000               | 8' Channel, 2 Lamp, 60w T12, Mag. Ballast, Surface Mnt., No Lens  | 2                 | 115.2             | 2               | 0.23     | 461          | Replace Fixture           | 1x4 Surface LED 48w                         | 1                 | 48                | 2               | 0.10     | 192                     | 0.13               | 269                 | \$40                       | 0             | No New Controls      | 0               | 0.0%             | 0                   | \$0                |
| 2                   |                                | 2000               | 8' Channel, 2 Lamp, 75w T12, Mag. Ballast, Surface Mnt., No Lens  | 2                 | 141.5             | 1               | 0.14     | 283          | Replace Fixture           | 1x4 Surface LED 48w                         | 1                 | 48                | 1               | 0.05     | 96                      | 0.09               | 187                 | \$28                       | 0             | No New Controls      | 0               | 0.0%             | 0                   | \$0                |
| 3                   |                                | 2000               | 8' Channel, 2 Lamp, 110w T12, Mag. Ballast, Surface Mnt., No Lens | 2                 | 230               | 2               | 0.46     | 920          | Replace Fixture           | 1x4 Surface LED 48w                         | 1                 | 48                | 2               | 0.10     | 192                     | 0.36               | 728                 | \$108                      | 0             | No New Controls      | 0               | 0.0%             | 0                   | \$0                |
| 4                   | Office                         | 1800               | 2x4 4 Lamp 32w T8 Elect. Ballast, Surface Mnt., Prismatic         | 4                 | 112               | 4               | 0.45     | 806          | Bypass Ballast, Relamp    | 4' Alledra 18w LED; LLT-X-T8-Y-SW-120-Z-S-N | 4                 | 72                | 4               | 0.29     | 518                     | 0.16               | 288                 | \$43                       | 0             | No New Controls      | 0               | 0.0%             | 0                   | \$0                |
| 4                   | Bathroom                       | 1800               | 2x4 4 Lamp 32w T8 Elect. Ballast, Surface Mnt., Prismatic         | 4                 | 112               | 1               | 0.11     | 202          | Bypass Ballast, Relamp    | 4' Alledra 18w LED; LLT-X-T8-Y-SW-120-Z-S-N | 4                 | 72                | 1               | 0.07     | 130                     | 0.04               | 72                  | \$11                       | 0             | No New Controls      | 0               | 0.0%             | 0                   | \$0                |
| 4                   | Entrance                       | 1800               | 2x4 4 Lamp 32w T8 Elect. Ballast, Surface Mnt., Prismatic         | 4                 | 112               | 4               | 0.45     | 806          | Bypass Ballast, Relamp    | 4' Alledra 18w LED; LLT-X-T8-Y-SW-120-Z-S-N | 4                 | 72                | 4               | 0.29     | 518                     | 0.16               | 288                 | \$43                       | 0             | No New Controls      | 0               | 0.0%             | 0                   | \$0                |
| 5                   | Mens Restroom/Changing Room    | 1800               | 1x4 2-Lamp 32w T8 Surface Mount, Prismatic Lens                   | 2                 | 62                | 3               | 0.19     | 335          | Bypass Ballast, Relamp    | 4' Alledra 18w LED; LLT-X-T8-Y-SW-120-Z-S-N | 2                 | 36                | 3               | 0.11     | 194                     | 0.08               | 140                 | \$21                       | 0             | No New Controls      | 0               | 0.0%             | 0                   | \$0                |
| 6                   |                                | 1800               | 175w MH Pendant Mount   | 1                 | 195               | 9               | 1.76     | 3,159        | Re-lamp & Bypass ballast  | 40w LED Par 56 Self-ballast Mogul Base Lamp | 1                 | 41                | 9               | 0.37     | 664                     | 1.39               | 2,495               | \$369                      | 0             | No New Controls      | 0               | 0.0%             | 0                   | \$0                |
| 5                   | Womens Restroom/ Changing Room | 1800               | 1x4 2-Lamp 32w T8 Surface Mount, Prismatic Lens                   | 2                 | 62                | 3               | 0.19     | 335          | Bypass Ballast, Relamp    | 4' Alledra 18w LED; LLT-X-T8-Y-SW-120-Z-S-N | 2                 | 36                | 3               | 0.11     | 194                     | 0.08               | 140                 | \$21                       | 0             | No New Controls      | 0               | 0.0%             | 0                   | \$0                |
| 6                   |                                | 1800               | 175w MH Pendant Mount   | 1                 | 195               | 8               | 1.56     | 2,808        | Re-lamp & Bypass ballast  | 40w LED Par 56 Self-ballast Mogul Base Lamp | 1                 | 41                | 8               | 0.33     | 590                     | 1.23               | 2,218               | \$328                      | 0             | No New Controls      | 0               | 0.0%             | 0                   | \$0                |
| 7                   | Storage                        | 2600               | 1x4 2-Lamp 32w T8 Surface Mount, No Lens                          | 2                 | 62                | 2               | 0.12     | 322          | Bypass Ballast, Relamp    | 4' Alledra 18w LED; LLT-X-T8-Y-SW-120-Z-S-N | 2                 | 36                | 2               | 0.07     | 187                     | 0.05               | 135                 | \$20                       | 0             | No New Controls      | 0               | 0.0%             | 0                   | \$0                |
| 7                   | Life Guard Prep Room           | 1800               | 1x4 2-Lamp 32w T8 Surface Mount, No Lens                          | 2                 | 62                | 2               | 0.12     | 223          | Bypass Ballast, Relamp    | 4' Alledra 18w LED; LLT-X-T8-Y-SW-120-Z-S-N | 2                 | 36                | 2               | 0.07     | 130                     | 0.05               | 94                  | \$14                       | 0             | No New Controls      | 0               | 0.0%             | 0                   | \$0                |
| TOTAL               |                                |                    |   |                   |                   | 41              | 6        | 10,660       |                           |   |                   |                   | 41              | 2        | 3,607                   | 4                  | 7,054               | \$1,044                    |               |                      | 0               | 0                | 0                   | \$0                |

## **APPENDIX F**

| Location Description | Area (Sq FT) | Panel           | Qty | Panel Sq Ft | Panel Total Sq Ft | Total KW <sub>DC</sub> | Total Annual kWh | Total KW <sub>AC</sub> | Panel Weight (41.9 lbs) | W/SQFT |
|----------------------|--------------|-----------------|-----|-------------|-------------------|------------------------|------------------|------------------------|-------------------------|--------|
| Swim Complex         | 4300         | SHARP ND-240QCJ | 131 | 17.5        | 2,298             | 31.44                  | 40,059           | 25.5                   | 5,489                   | 13.68  |



= Proposed PV Roof Layout

= Proposed PV Ground Mount Layout

Notes:

1. Estimated kWh based on the National Renewable Energy Laboratory PVWatts Version 1 Calculator Program.



|   |                        |  |                     |                        |              |                              |                |               |                      |
|---|------------------------|--|---------------------|------------------------|--------------|------------------------------|----------------|---------------|----------------------|
| Project Name: LGEA Solar PV Project - Swim Complex        |                        |  |                     |                        |              |                              |                |               |                      |
| Location: Marlboro, NJ                                    |                        |  |                     |                        |              |                              |                |               |                      |
| Description: Photovoltaic System 100% Financing - 15 year |                        |  |                     |                        |              |                              |                |               |                      |
| Simple Payback Analysis                                   |                        |  |                     |                        |              |                              |                |               |                      |
|   |                        | Photovoltaic System 100% Financing - 15 year |                     |                        |              |                              |                |               |                      |
| Total Construction Cost                                   |                        | \$123,180                                    |                     |                        |              |                              |                |               |                      |
| Annual kWh Production                                     |                        | 40,059                                       |                     |                        |              |                              |                |               |                      |
| Annual Energy Cost Reduction                              |                        | \$5,929                                      |                     |                        |              |                              |                |               |                      |
| Average Annual SREC Revenue                               |                        | \$7,655                                      |                     |                        |              |                              |                |               |                      |
| Simple Payback:   |                        | 9.07   |                     |                        |              |                              |                | Years         |                      |
| Life Cycle Cost Analysis                                  |                        |  |                     |                        |              |                              |                |               |                      |
| Analysis Period (years):                                  |                        | 15   |                     |                        |              | Financing %:                 |                | 100%          |                      |
| Discount Rate:  |                        | 3%   |                     |                        |              | Maintenance Escalation Rate: |                | 3.0%          |                      |
| Average Energy Cost (\$/kWh)                              |                        | \$0.148                                      |                     |                        |              | Energy Cost Escalation Rate: |                | 3.0%          |                      |
| Financing Rate:   |                        | 6.00%  |                     |                        |              | Average SREC Value (\$/kWh)  |                | \$0.191       |                      |
| Period  | Additional Cash Outlay | Energy kWh Production                        | Energy Cost Savings | Additional Maint Costs | SREC Revenue | Interest Expense             | Loan Principal | Net Cash Flow | Cumulative Cash Flow |
| 0   | \$0                    | 0  | 0                   | 0                      | \$0          | 0                            | 0              | 0             | 0                    |
| 1   | \$0                    | 40,059                                       | \$5,929             | \$0                    | \$10,015     | \$7,249                      | \$5,225        | \$3,470       | \$3,470              |
| 2   | \$0                    | 39,859                                       | \$6,107             | \$0                    | \$9,965      | \$6,926                      | \$5,547        | \$3,598       | \$7,068              |
| 3   | \$0                    | 39,659                                       | \$6,290             | \$0                    | \$9,915      | \$6,584                      | \$5,889        | \$3,731       | \$10,799             |
| 4   | \$0                    | 39,461                                       | \$6,478             | \$0                    | \$9,865      | \$6,221                      | \$6,253        | \$3,870       | \$14,669             |
| 5   | \$0                    | 39,264                                       | \$6,673             | \$404                  | \$9,816      | \$5,835                      | \$6,638        | \$3,611       | \$18,280             |
| 6   | \$0                    | 39,067                                       | \$6,873             | \$402                  | \$7,813      | \$5,426                      | \$7,048        | \$1,811       | \$20,090             |
| 7   | \$0                    | 38,872                                       | \$7,079             | \$400                  | \$7,774      | \$4,991                      | \$7,482        | \$1,980       | \$22,070             |
| 8   | \$0                    | 38,678                                       | \$7,292             | \$398                  | \$7,736      | \$4,530                      | \$7,944        | \$2,155       | \$24,225             |
| 9   | \$0                    | 38,484                                       | \$7,510             | \$396                  | \$7,697      | \$4,040                      | \$8,434        | \$2,337       | \$26,562             |
| 10  | \$0                    | 38,292                                       | \$7,736             | \$394                  | \$5,744      | \$3,520                      | \$8,954        | \$611         | \$27,174             |
| 11  | \$0                    | 38,101                                       | \$7,968             | \$392                  | \$5,715      | \$2,967                      | \$9,506        | \$817         | \$27,990             |
| 12  | \$0                    | 37,910                                       | \$8,207             | \$390                  | \$5,687      | \$2,381                      | \$10,092       | \$1,029       | \$29,020             |
| 13  | \$0                    | 37,720                                       | \$8,453             | \$389                  | \$5,658      | \$1,759                      | \$10,715       | \$1,249       | \$30,268             |
| 14  | \$0                    | 37,532                                       | \$8,707             | \$387                  | \$3,753      | \$1,098                      | \$11,376       | (\$400)       | \$29,868             |
| 15  | \$0                    | 37,344                                       | \$8,968             | \$385                  | \$3,734      | \$396                        | \$12,077       | (\$156)       | \$29,712             |
| Totals:   |                        | 580,303                                      | \$110,268           | \$4,339                | \$110,887    | \$63,924                     | \$123,180      | \$29,712      | \$321,264            |
| Net Present Value (NPV)                                   |                        |  |                     |                        |              |                              | \$24,144       |               |                      |