

WILLIAM PATTERSON UNIVERSITY

CAMPUS POLICE BUILDING

300 Pompton Road, Wayne NJ 07470

**LOCAL GOVERNMENT ENERGY AUDIT PROGRAM
FOR
NEW JERSEY
BOARD OF PUBLIC UTILITIES**

July 2014

Prepared by:



6 Campus Drive
Parsippany, NJ 07054
(973) 538-2120

CHA PROJECT NO. 28661

TABLE OF CONTENTS

1.0 EXECUTIVE SUMMARY	1
2.0 BUILDING INFORMATION AND EXISTING CONDITIONS	4
3.0 UTILITIES	7
4.0 BENCHMARKING.....	9
5.0 ENERGY CONSERVATION MEASURES.....	10
5.1 ECM-1 Add Attic Insulation	11
5.2 Replace DX/Electric Heating Systems	11
5.2.1 ECM-2A Replace Central heating /Cooling System with Individual Packaged Terminal Heat Pumps	11
5.2.2 ECM-2B Replace DX Units Unit with High Efficiency DX Units	12
5.3 ECM-3 Install Occupancy Sensors to Control Electric Heaters	12
5.4 ECM-4 Install Low Flow Plumbing Fixtures	13
5.5.1 ECM-L1 Lighting Replacement / Upgrades	13
5.5.2 ECM-L2 Install Lighting Controls (Occupancy Sensors)	14
5.5.3 ECM-L3 Lighting Replacements with Controls (Occupancy Sensors)	15
5.6 Additional O&M Opportunities.....	15
6.0 PROJECT INCENTIVES.....	16
6.1 Incentives Overview.....	16
6.1.1 New Jersey Smart Start Program.....	16
6.1.2 Direct Install Program	16
6.1.3 New Jersey Pay For Performance Program (P4P).....	17
6.1.4 Energy Savings Improvement Plan	18
6.1.5 Renewable Energy Incentive Program.....	19
7.0 ALTERNATIVE ENERGY SCREENING EVALUATION	20
7.1 Solar	20
7.1.1 Photovoltaic Rooftop Solar Power Generation	20
7.1.2 Solar Thermal Hot Water Generation.....	20
7.2 Wind Powered Turbines	20
7.3 Combined Heat and Power Plant and Fuel Cell	21

7.4	Demand Response Curtailment	22
8.0	CONCLUSIONS & RECOMMENDATIONS.....	23

APPENDICES

A	Utility Usage Analysis and List of Third Party Energy Suppliers
B	Equipment Inventory
C	ECM Calculations and Cost Estimates
D	New Jersey BPU Incentive Programs
	i. Smart Start
	ii. Direct Install
	iii. Pay For Performance Incentive Program (P4P)
	iv. Energy Savings Improvement Plan (ESIP)
E	Photovoltaic (PV) Solar Power Generation Analysis
F	Photos
G	EPA Benchmarking Report

REPORT DISCLAIMER

This audit was conducted in accordance with the standards developed by the American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) for a Level II audit. Cost and savings calculations for a given measure were estimated to within $\pm 20\%$, and are based on data obtained from the owner, data obtained during site observations, professional experience, historical data, and standard engineering practice. Cost data does not include soft costs such as engineering fees, legal fees, project management fees, financing, etc.

A thorough walkthrough of the building was performed, which included gathering nameplate information and operating parameters for all accessible equipment and lighting systems. Unless otherwise stated, model, efficiency, and capacity information included in this report were collected directly from equipment nameplates and /or from documentation provided by the owner during the site visit. Typical operation and scheduling information was obtained from interviewing staff and spot measurements taken in the field.

List of Common Energy Audit Abbreviations

- A/C – Air Conditioning
- AHS – Air Handling Unit
- BMS – Building Management System
- Btu – British thermal unit
- CDW – Condenser Water
- CFM – Cubic feet per minute
- CHW – Chilled Water
- DCV – Demand Control Ventilation
- DDC – Direct Digital Control
- DHW – Domestic Hot Water
- DX – Direct Expansion
- EER – Energy Efficiency Ratio
- EF – Exhaust Fan
- EUI – Energy Use Intensity
- Gal – Gallon
- GPD – Gallons per day
- GPF – Gallons Per Flush
- GPH – Gallons per hour
- GPM – Gallons per minute
- GPS – Gallons per second
- HHW – Heating Hot Water
- HID – High Intensity Discharge
- HP – Horsepower
- HRU – Heat Recovery Unit
- HVAC – Heating, Ventilation, Air Conditioning
- HX – Heat Exchanger
- kbtu/mbtu – One thousand (1,000) Btu
- kW – Kilowatt (1,000 watts)
- kWh – Kilowatt-hours
- LED – Light Emitting Diode
- mbh – Thousand Btu per hour
- mmbtu – One million (1,000,000) Btu
- OCC – Occupancy Sensor
- PSI – Pounds per square inch
- RTU – Rooftop Unit
- SBC – System Benefits Charge
- SF – Square foot
- UH – Unit Heater
- V – Volts
- VAV – Variable Air Volume
- VSD – Variable Speed Drive
- W – Watt

1.0 EXECUTIVE SUMMARY

This report summarizes the energy audit performed by CHA for William Patterson University (WPU) in connection with the New Jersey Board of Public Utilities (NJBPU) Local Government Energy Audit (LGEA) Program. The purpose of this report is to identify energy savings opportunities associated with major energy consumers and inefficient practices. Low-cost and no-cost are also identified during the study. This report details the results of the energy audit conducted for the building listed below:

Building Name	Address	Square Feet	Construction Date
Campus Police	300 Pompton Road, Wayne NJ 07470	4,600	1992

The potential total annual energy and cost savings for the recommended energy conservation measures (ECM) identified in the survey are shown below:

Building Name	Electric Savings (kWh)	NG Savings (therms)	Total Savings (\$)	Payback (years)
Campus Police	62,641	0	9,879	10.8

Each individual measure's annual savings are dependent on that measure alone, there are no interactive effects calculated. There are three options shown for Lighting ECM savings; only one option can be chosen. Incentives shown (if any) are based only on the SmartStart Incentive Program. Other NJBPU or local utility incentives may also be available/ applicable and are discussed in Section 6.0.

Each measure recommended by CHA typically has a stand-alone simple payback period of 15 years or less. However, if the owner chooses to pursue an Energy Savings Improvement Plan (ESIP), high payback measures could be bundled with lower payback measures which ultimately can result in a payback which is favorable for an ESIP project to proceed. Occasionally, we will recommend an ECM that has a longer payback period, based on the need to replace that piece(s) of equipment due to its age, such as a boiler for example.

The following table provides a detailed summary of each ECM for the building surveyed, including costs, savings, SmartStart incentives and payback.

Summary of Energy Conservation Measures


ECM #	Energy Conservation Measure	Est. Costs (\$)	Est. Savings (\$/year)	Payback w/o Incentive	Potential Incentive (\$)*	Payback w/ Incentive	Recommended
ECM-1	Add Attic Insulation	5,980	1,161	5.2	0	5.2	Y
ECM-2A	Replace DX Cooling and Electric Heaters with Heat Pumps	45,828	3,710	12.4	1,040	12.1	Y
ECM-2B**	Replace DX Units Unit with High Efficiency DX Units	14,880	673	22.1	1,040	20.6	N
ECM-3	Install Occupancy Sensors to control Electric Heaters	8,397	1,153	7.3	0	7.3	Y
ECM-4	Replace High Flow Plumbing Fixtures with Low Flow Plumbing Fixtures	17,260	215	80.3	0	80.3	Y
ECM-L1**	Lighting Replacements / Upgrades	23,906	3,408	7.0	5,750	5.3	N
ECM-L2**	Install Lighting Controls (Add Occupancy Sensors)	5,130	556	9.2	665	8.0	N
ECM-L3	Lighting Replacements with Controls (Occupancy Sensors)	29,036	3,640	8.0	6,415	6.2	Y
Total**		106,501	9,879	10.8	7,455	10.0	
Total (Recommended)		106,501	9,879	10.8	7,455	10.0	

* Incentive shown is per the New Jersey SmartStart Program.

** These ECMs are not included in the Total, as they are alternate measures not recommended.

If WPU implements the recommended ECMs, energy savings would be as follows:

	Existing Conditions	Post Recommended ECMs	Percent Savings
Costs (\$)	28,771	18,892	34%
Electricity (kWh)	194,010	131,369	32%
Natural Gas (therms)	0	0	0
Site EUI (kbtu/SF/Yr)	143.9	97.4	



2.0 BUILDING INFORMATION AND EXISTING CONDITIONS

The following is a summary of building information related to HVAC, plumbing, building envelope, lighting, kitchen equipment and domestic hot water systems as observed during CHAs site visit. See appendix B for detailed information on mechanical equipment, including capacities, model numbers and age. See appendix F for some representative photos of some of the existing conditions observed while onsite.

Building Name: Campus Police

Address: 300 Pompton Road, Wayne NJ 07470

Gross Floor Area: 4,600

Number of Floors: 1

Year Built: 1992



Building Envelope

Description of Spaces: Public safety offices, storage rooms, locker rooms and restrooms.

Description of Occupancy: There are approximately 15 full time police officers and support staff.

Number of Computers: The building has approximately 15 desktop and laptop computers as well as communication servers.

Building Usage: Operates 24 hours per day, 365 days per year.

Construction Materials: Modular wood frame construction with stucco on exterior. The building envelope appears to be in good condition.

Roof: The building has a pitched wood frame roof covered with shingles. The roof appears to be in good condition. An ECM is included to add more attic insulation.

Windows: The windows are double pane windows and covered by blinds. The windows are in good condition and there is no ECM is related to the windows.

Exterior Doors: Exterior doors in this building are aluminum frame with double pane safety glass. Sweeps on exterior doors are still in good condition. No door ECMs are evaluated.

Heating Ventilation & Air Conditioning (HVAC) Systems

Heating: The building does not have natural gas supply and is electric heating only. Duct mounted electric reheat coils are used at each room which are served by one of two air handling units (AHU). These two AHUs are located in attic. Each office also has a wall mounted electric heater to provide supplemental heat. Electric heaters are also used in the hallways and locker rooms. The electric heaters are manually controlled.

Cooling: The two AHUs are equipped with DX cooling coils and matching remote condensing units to provide cooling. The condensing units are located on the ground outside the building and each of the two DX units has a rated cooling capacity of 10 ton and EER of 11.2. Three office rooms have portable supplemental cooling units having a capacity of approximately 1 ton.

ECMs related to replacing the AHUs with heat pumps and replacing the DX units with high efficiency DX units are evaluated.

Ventilation: The ventilation of the building is provided by the two AHUs located in the attic. Each of the AHUs has an outdoor air intake and motorized damper. There are no ECMs related to the ventilation system.

Exhaust: This building has fractional HP exhaust fans for restrooms and locker rooms. However, it was found that these exhaust fans are randomly turned on after discussing with the staff. No ECMs are associated with exhaust fans.

Controls Systems

The AHUs are controlled by line voltage thermostats located in each space. The electric heaters are controlled by built-in manual controllers. This building is operational 24/7; however, the offices are not always occupied. Therefore, an ECM related to install occupancy sensors to control electric reheat coils and electric heaters is evaluated.

Domestic Hot Water Systems

The DHW is provided by an A.O. Smith electric heater located in one office room. The electric DHW heater has a rated of heating capacity of 4.5 kW and 80 gallon storage. This unit is brand new. There is no gas supply to this building, therefore, no ECM related to DHW heater is evaluated.

Kitchen Equipment

There is no kitchen in the building and therefore no ECM related to kitchen equipment is evaluated.

Plug Load

This building has computers, monitors, residential appliances (microwave, refrigerator), portable electric ACs which contribute to the plug load in the building. Due to the nature of the building use there is no ECM related to plug load reduction.

Plumbing Systems

The restrooms contain older style toilets and urinals that utilize a higher volume of water per flush (3.5 GPF) than currently available new units. The sink faucets are double handle type and do not appear to have low-flow type aerators, dispensing at 2.5 GPM. There is also a locker room which has shower heads, however, it is noted that the shower has never been used after discussing with the staff. An ECM is included to evaluate the water savings potential of installing low- flow plumbing fixtures.

Lighting Systems

The building has a mixture of U-shape 32 watt T-8 fluorescent lighting and linear T-8 fixtures. All of the lights in this building are controlled by manual switches. After discussions with facility staff, it was noted that the lights are on 24/7. The exterior lights are wall mounted metal halide fixtures. We have provided three alternatives for lighting that include adding occupancy sensors to the existing lights, replacing the lights with LED lights and a third ECM that evaluates adding occupancy sensors to the proposed LED lights.

3.0 UTILITIES

Natural gas and electricity are metered into this building under Account # 69-477-197-04. Utilities used by the building are delivered and supplied by the following utility companies:

	Electric
Deliverer	PSE&G
Supplier	Direct Energy

For the 12-month period ending in January 2014, the utilities usages and costs for the building were as follows:

Electric		
Annual Consumption	194,010	kWh
Annual Cost	28,771	\$
Blended Unit Rate	0.148	\$/kWh
Supply Rate	0.141	\$/kWh
Demand Rate	11.93	\$/kW
Peak Demand	10	kW

Blended Rate: Average rate charged determined by the annual cost / annual usage


Supply Rate: Actual rate charged for electricity usage in kWh (based on most recent electric bill)

Demand Rate: Rate charged for actual electrical demand in kW (based on most recent electric bill)

*Some months that do not have utility data and the missing demand usage are estimated and highlighted in the utility spreadsheet

**This building is an electric only building.

Campus Police Building Electric Usages



The electric usage is higher in cooling season and heating season because the building uses electric DX for cooling and electric heaters for heating. The usage in shoulder season is less.

See Appendix A for utility analysis.

Under New Jersey's energy deregulation law, the supply portion of the electric (or natural gas) bill is separated from the delivery portion. The supply portion is open to competition, and customers can shop around for the best price for their energy suppliers. The electric and natural gas distribution utilities will still deliver the gas/ electric supplies through their wires and pipes – and respond to emergencies, should they arise – regardless of where those supplies are purchased. Purchasing the energy supplies from a company other than your electric or gas utility is purely an economic decision; it has no impact on the reliability or safety of the service.

Comparison of Utility Rates to NJ State Average Rates*				Recommended to Shop for Third Party Supplier?
Utility	Units	School Average Rate	NJ Average Rate	
Electricity	\$/kWh	\$0.15	\$0.13	Y

* Per U.S. Energy Information Administration (2013 data – Electricity and Natural Gas, 2012 data – Fuel Oil)


Additional information on selecting a third party energy supplier is available here:

<http://www.state.nj.us/bpu/commercial/shopping.html>.

See Appendix A for a list of third-party energy suppliers licensed by the Board of Public Utilities to sell within the building's service area.

The charts below represent estimated utility end-use utility profiles for the building. The values used within the charts were estimated from a review of the utility analysis and the energy savings calculations.

Site End-Use Utility Profile



4.0 BENCHMARKING

The EPA Portfolio Manager benchmarking tool provides a site and source Energy Use Intensity (EUI), as well as an Energy Star performance rating for qualifying building types. The EUIs are provided in kBtu/ft²/year, and the performance rating represents how energy efficient a building is on a scale of 1 to 100, with 100 being the most efficient. In order for a building to receive an Energy Star label, the energy benchmark rating must be at least 75. As energy use decreases from implementation of the proposed measures, the Energy Star rating will increase. However, the EPA does not have score for all types of buildings. The buildings that do not have energy rating now are compared with national median EUI.

The site EUI is the amount of heat and electricity consumed by a building as reflected in utility bills. Site energy may be delivered to a facility in the form of primary energy, which is raw fuel burned to create heat or electricity, such as natural gas or oil; or as secondary energy, which is the product created from a raw fuel such as electricity or district steam. To provide an equitable comparison for different buildings with varying proportions of primary and secondary energy consumption, Portfolio Manager uses the convention of source EUIs. The source energy also accounts for losses incurred in production, storage, transmission, and delivery of energy to the site, which provide an equivalent measure for various types of buildings with differing energy sources. The results of the benchmarking are contained in the table below.

Site EUI kBtu/ft ² /yr	Source EUI (kBtu/ft ² /yr)	Energy Star Rating (1-100)
143.9	451.9	N/A

The building has higher EUIs than the national median EUIs (national median site EUI is 83.6 kBtu/ft² and national median source EUI is 262.6 kBtu/ft²). The possible reason for the higher EUI is that this building is operational 24/7 and the electric heating system uses more energy compared with natural gas heating.

5.0 ENERGY CONSERVATION MEASURES

The following types of energy savings opportunities are identified in this section of the report:

- Energy conservation measures (ECMs) are energy savings recommendations that typically require a financial investment. For these areas of opportunity, CHA prepared detailed calculations, as summarized in this section and in Appendix C. In general, additional savings may exist from reductions in maintenance activities associated with new equipment or better controls; however for conservatism, maintenance savings are not accounted for in this report; instead the only savings which are reported are those derived directly from reductions in energy which can be tracked by the utility bills.
- Operational and Maintenance measures (O&M) consist of low- or no-cost operational opportunities, which if implemented would have positive impacts on overall building operation, comfort levels, and/or energy usage. There are no estimated savings, costs or paybacks associated with the O&M measures included as part of this study.

Energy savings were quantified in the form of:

- electrical usage (kWh=Kilowatt-hour),
- electrical demand (kW=kilowatts),
- natural gas (therms=100,000 Btu),
- propane gas (gallons=91,650 Btu),
- fuel oil (gallons =138,700 Btu), and
- water (kgal=1,000 gallons).

These recommendations are influenced by the time period that it takes for a proposed project to “break even” referred to as “Simple Payback”. Simple payback is calculated by dividing the estimated cost of implementing the ECM by the energy cost savings (in dollars) of that ECM.

Another financial indicator of the performance of a particular ECM is the Return on Investment or ROI, which represents the benefit (annual savings over the life of a project) of an investment divided by the cost of the investment. The result is expressed as a percentage or ratio.

Two other financial analyses included in this report are Internal Rate of Return (IRR) and Net Present Value (NPV). Internal Rate of Return is the discount rate at which the present value of a project costs equals the present value of the project savings. Net Present Value is the difference between present value of an investment’s future net cash flows and the initial investment. If the NPV equals “0”, the project would equate to investing the same amount of dollars at the desired rate. NPV is sometimes referred to as Net Present Worth. These values are provided in the Summary Tab in Appendix C.

5.1 ECM-1 Add Attic Insulation

The roof has an attic space that is not well insulated. This ECM considers blowing in 9" of loose-fill cellulose insulation (R-2.7/inch) between the ceiling joists and the deck to reduce heating and cooling energy losses.

To calculate the savings, the heat loss through the roof assembly of the school was calculated using the existing roof's R-value and bin weather data for nearby Newark, NJ. The values were totaled to determine the existing annual energy losses. Heating and cooling energy loss values were then determined with a thermal resistance which included the additional R-27 loose-fill insulation.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-1 Add Attic Insulation

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
\$	kW	kWh	Therms	\$		\$	Years	Years
5,980	0	7,845	0	1,161	4.8	0	5.2	5.2

* Does not qualify for an Incentive per the New Jersey SmartStart Program. See section 5.0 for other incentive opportunities

This measure is recommended.

5.2 Replace DX/Electric Heating Systems

5.2.1 ECM-2A Replace Central heating /Cooling System with Individual Packaged Terminal Heat Pumps

The building has electric re-heat coils, electric cooling and many smaller electric unit heaters. The central system is operating in heating or cooling 24/7. It is recommended that these two AHUs be replaced with individual room packaged terminal heat pumps with a few electric unit heaters being used as supplemental heating only. This will allow for individual room control of the units and will incorporate a more efficient means of providing heating verses the electric re-heat coils. It is estimated that (10) 2 ton heat pump units would be sufficient to provide cooling/heating load of this building.

A heat pump will not need the second stage of the heat (4 kW) between the outside air temperatures from 35 °F – 60 °F. Electrical savings will be seen from heating and a higher EER value for cooling.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-2A Replace DX Cooling and Electric Heaters with Packaged Terminal Heat Pumps

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
\$	kW	kWh	Therms	\$		\$	Years	Years
45,828	0	25,070	0	3,710	1.0	1,040	12.4	12.1

* Incentive shown is per the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities.

This measure is recommended.

5.2.2 ECM-2B Replace DX Units Unit with High Efficiency DX Units

This measure is an alternative to ECM-2A. It looks at replacing the older 10 ton DX cooling units with higher efficient DX units. According to the manufacturers' data, the new technology could improve EER of the 10 ton DX units to the range of 15 EER. Therefore, the energy savings are from the EER improvement of the newer DX units and the existing heating system will not be changed.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-2B Replace DX Units Unit with High Efficiency DX Units

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
\$	kW	kWh	Therms	\$		\$	Years	Years
14,880	0	4,547	0	673	(0.1)	1,040	22.1	20.6

* Incentive shown is per the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities.

This measure is not recommended in lieu of ECM-2A.

5.3 ECM-3 Install Occupancy Sensors to Control Electric Heaters

Electric unit heaters and reheat units are widely used throughout this building. These heaters are manually controlled and the rooms could be overheated when they are not occupied. During the site visit, it was found that most of rooms are not occupied. Occupancy sensors that control both the lights and the heating units would help reduce the energy usage in the building. The occupancy sensors would set the heaters to unoccupied mode when the room is not occupied for 15 minutes and return to the occupied mode once they sense occupancy. The energy savings are calculated from the estimated operational hour reduction of the electric heaters.

To implement this ECM, occupancy sensors and thermostats would be installed. The occupancy sensors would communicate with the thermostats to set the room temperature based on the occupancy in the room. It should be noted that if WPU chose to implement ECM-2A, ECM-3 would not be applicable since the electric heaters replacement is included in ECM-2A.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-3 Install Occupancy Sensors to Control Electric Heaters

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
\$	kW	kWh	Therms	\$		\$	Years	Years
8,397	0	7,788	0	1,153	1.7	0	7.3	7.3

* Does not qualify for an Incentive per the New Jersey SmartStart Program. See section 5.0 for other incentive opportunities

This measure is recommended.

5.4 ECM-4 Install Low Flow Plumbing Fixtures

The plumbing fixtures in this building are older high flow fixtures. The water savings associated from replacing existing high flow fixtures with low-flow fixtures was calculated by taking the difference of the annual water usage for the proposed and base case. The basis of this calculation is the estimate usage of each fixture, gallons per use, and number of fixtures. Replacing the existing fixtures in the restrooms with 1.28 Gals/flush toilets, 1.0 gal/flush urinals, and 0.5 gpm faucets will conserve water which will result in lower annual water and sewer charges. Faucets with low-flow push valves were not considered for replacement.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-4 Install Low Flow Plumbing Fixtures

Budgetary Cost	Annual Utility Savings					ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Water	Total				
\$	kW	kWh	Therms	kGal	\$		\$	Years	Years
17,260	0	372	0	21	215	(0.8)	0	80.3	80.3

* Does not qualify for Incentive from the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities

This measure is recommended since the total payback including this measure is less than 15 years..

5.5.1 ECM-L1 Lighting Replacement / Upgrades

The existing lighting system consists of mostly 32 watt T8 linear fluorescent fixtures which until recently represented the most efficient lighting technology available. Exterior lighting includes 75W wall mounted metal halide area light fixtures. Recent technological improvements in light emitting diode (LED) technologies have driven down the initial costs making it a viable option for installation.

Overall energy consumption can be reduced by replacing inefficient bulbs and linear fluorescent bulbs with more efficient LED technology. To compute the annual savings for this ECM, the energy consumption of the current lighting fixtures was established and compared to the proposed fixture power requirement with the same annual hours of operation. The difference between the existing and proposed annual energy consumption was the energy savings. These calculations are based on 1 to 1 replacements of the fixtures, and do not take into account lumen output requirements for a given space. A more comprehensive engineering study should be performed to determine correct lighting levels.

Supporting calculations, including assumptions for lighting hours and annual energy usage for each fixture, are provided in Appendix C and summarized below:

ECM-L1 Lighting Replacement / Upgrades

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
\$	kW	kWh	Therms	\$		\$	Years	Years
23,906	4	19,922	0	3,408	0.5	5,750	7.0	5.3

* LED retrofits must go through the "custom" measures incentive option under New Jersey SmartStart Program. There are no "prescriptive" incentives for LED retrofits. Projects must achieve a minimum of 75,000 kWh annual savings to qualify for "custom" incentives. See section 6.0 for other incentive opportunities

This measure is not recommended in lieu of ECM L3.

5.5.2 ECM-L2 Install Lighting Controls (Occupancy Sensors)

Presently, all interior lighting fixtures are controlled by wall mounted switches. Review of the comprehensive lighting survey determined that lighting in some areas could benefit from installation of occupancy sensors to turn off lights when they are unoccupied.

This measure recommends installing occupancy sensors for the current lighting system. Using a process similar to that utilized in Section 5.7.1, the energy savings for this measure was calculated by applying the known fixture wattages in the space to the estimated existing and proposed times of operation for each fixture.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-L2 Install Lighting Controls (Occupancy Sensors)

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
\$	kW	kWh	Therms	\$		\$	Years	Years
5,130	0	3,944	0	556	0.1	665	9.2	8.0

* Incentive shown is per the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities.

This measure is not recommended in lieu of ECM L3.

5.5.3 ECM-L3 Lighting Replacements with Controls (Occupancy Sensors)

This measure is a combination of ECM-L1 and ECM-L2; recommending replace/upgrade the current lighting fixtures to more efficient ones and installing occupancy sensors on the new lights. Interactive effects of the higher efficiency lights and occupancy sensors lead the energy and cost savings for this measure to not be cumulative or equivalent to the sum of replacing the lighting fixtures alone and installing occupancy sensors without the lighting upgrade. The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-L3 Lighting Replacements with Controls (Occupancy Sensors)

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
\$	kW	kWh	Therms	\$		\$	Years	Years
29,036	4	21,565	0	3,640	0.3	6,415	8.0	6.2

* LED retrofits must go through the "custom" measures incentive option under New Jersey SmartStart Program. There are no "prescriptive" incentives for LED retrofits. Projects must achieve a minimum of 75,000 kWh annual savings to qualify for "custom" incentives. See section 6.0 for other incentive opportunities

This measure is recommended.

5.6 Additional O&M Opportunities

This list of operations and maintenance (O&M) - type measures represent low-cost or no-cost opportunities, which if implemented will have a positive impact on the overall building operations, comfort and/or energy consumption. The recommended O&M measures for this building are as follows:

- O&M-1 Add window seals to operable portion of windows
- O&M-2 Add Insulation Blanket on Domestic Water Heater
- O&M-3 Replace air filters in AHUs

6.0 PROJECT INCENTIVES

6.1 Incentives Overview

The following sections give detailed information on available incentive programs including New Jersey Smart Start, Direct Install, New Jersey Pay for Performance (P4P) and Energy Savings Improvement Plan (ESIP). If the School District wishes to and is eligible to participate in the Energy Savings Improvement Plan (ESIP) program and/or the Pay for Performance Incentive Program (P4P), it cannot participate in either the Smart Start or Direct Install Programs. Refer to Appendix D for more information on the Smart Start program.

6.1.1 New Jersey Smart Start Program

For this energy audit, The New Jersey Smart Start Incentives are used in the energy savings calculations, where applicable. This program is intended for medium and large energy users and provides incentives for:

- Electric Chillers
- Gas Chillers
- Gas Heating
- Unitary HVAC
- Ground Source Heat Pumps
- Variable frequency Drives/ motors
- Refrigeration
- Prescriptive and performance lighting and lighting controls

The equipment is procured using a typical bid- build method, installed and paid for and then the incentives are reimbursed to the owner.

Refer to Appendix D for more information on the Smart Start program.

6.1.2 Direct Install Program

The Direct Install Program applies to smaller facilities that have a peak electrical demand of 200 kW or less in any of the previous 12 months. Buildings must be located in New Jersey and served by one of the state's public, regulated electric utility companies.

Direct Install is funded through New Jersey's Clean Energy Program and is designed to provide capital for building energy upgrade projects to fast track implementation. The program will pay up to 70% of the costs for lighting, HVAC, motors, refrigeration, and other equipment upgrades with higher efficiency alternatives. If a building is eligible for this funding, the Direct Install Program can reduce the implementation cost of energy conservation projects.

The Direct Install program has specific HVAC equipment and lighting requirements and is generally applicable only to smaller package HVAC units, small boilers and lighting retrofits.

The program pays a maximum amount of \$75,000 per building, and up to \$250,000 per customer per year. Installations must be completed by an approved Direct Install participating contractor, a list of which can be found on the New Jersey Clean Energy Website. Contractors will coordinate with the applicant to arrange installation of recommended measures identified in a previous energy assessment, such as this energy audit. The incentive is reimbursed to the Owner upon successful replacement and payment of the equipment.

The building qualifies for this program because its electrical demand is less than the maximum peak electrical demand of 200 kW for the last 12 month period.

Refer to Appendix D for more information on this program.

6.1.3 New Jersey Pay For Performance Program (P4P)

This building may be eligible for incentives from the New Jersey Office of Clean Energy. The most significant incentives are available from the New Jersey Pay for Performance (P4P) Program. The P4P program is designed to offset the cost of energy conservation projects for facilities that pay the Societal Benefits Charge (SBC) and whose demand (kW) in any of the preceding 12 months exceeds 100 kW. This demand minimum has been waived for buildings owned by local governments or municipalities and non-profit organizations and *is not applicable to public schools*. Facilities that meet this criterion must also achieve a minimum performance target of 15% energy reduction by using the EPA Portfolio Manager benchmarking tool before and after implementation of the measure(s). Additionally, the overall return on investment (ROI) must exceed 10%. If the participant is a municipal electric company customer, and a customer of a regulated gas New Jersey Utility, only gas measures will be eligible under the Program. Available incentives are as follows:

Incentive #1: Energy Reduction Plan – This incentive is designed to offset the cost of services associated with the development of the Energy Reduction Plan (ERP). The ERP must include a detailed energy audit of the desired ECMs, energy savings calculations (using building modeling software) and inputting of all utility bills into the EPA Portfolio Manager website.

- Incentive Amount: \$0.10/SF
- Minimum incentive: \$5,000
- Maximum Incentive: \$50,000 or 50% of Facility annual energy cost

The standard incentive pays \$0.10 per square foot, up to a maximum of \$50,000, not to exceed 50% of facility annual energy cost, paid after approval of application. For building audits funded by the New Jersey Board of Public Utilities, which receive an initial 75% incentive toward performance of the energy audit, facilities are only eligible for an additional \$0.05 per square foot, up to a maximum of \$25,000, rather than the standard incentive noted above. The ERP must be completed by a Certified Energy Manager (CEM) and submitted along with the project application.

Incentive #2: Installation of Recommended Measures – This incentive is based on projected energy savings as determined in Incentive #1 (Minimum 15% savings must be achieved), and is paid upon successful installation of recommended measures.

Electric

- Base incentive based on 15% savings: \$0.09/ per projected kWh saved.
- For each % over 15% add: \$0.005 per projected kWh saved.
- Maximum incentive: \$0.11/ kWh per projected kWh saved.

Gas

- Base incentive based on 15% savings: \$0.90/ per projected Therm saved.
- For each % over 15% add: \$0.05 per projected Therm saved.
- Maximum incentive: \$1.25 per projected Therm saved.

Incentive cap: 25% of total project cost

Incentive #3: Post-Construction Benchmarking Report – This incentive is paid after acceptance of a report proving energy savings over one year utilizing the Environmental Protection Agency (EPA) Portfolio Manager benchmarking tool.

Electric

- Base incentive based on 15% savings: \$0.09/ per projected kWh saved.
- For each % over 15% add: \$0.005 per projected kWh saved.
- Maximum incentive: \$0.11/ kWh per projected kWh saved.

Gas

- Base incentive based on 15% savings: \$0.90/ per projected Therm saved.
- For each % over 15% add: \$0.05 per projected Therm saved.
- Maximum incentive: \$1.25 per projected Therm saved.

Combining Incentives #2 and #3 will provide a total of \$0.18/ kWh and \$1.8/therm not to exceed 50% of total project cost. Additional Incentives for #2 and #3 are increased by \$0.005/kWh and \$0.05/therm for each percentage increase above the 15% minimum target to 20%, calculated with the EPA Portfolio Manager benchmarking tool, not to exceed 50% of total project cost.

For the purpose of demonstrating the eligibility of the ECM's to meet the minimum savings requirement of 15% annual savings and 10% ROI for the Pay for Performance Program, all ECM's identified in this report have been included in the incentive calculations. The results for the building are shown in Appendix C, with more detailed program information in Appendix D.

6.1.4 Energy Savings Improvement Plan

The Energy Savings Improvement Program (ESIP) allows government agencies to make energy related improvements to their facilities and pay for the costs using the value of energy savings that result from the improvements. Under the recently enacted Chapter 4 of the Laws of 2009 (the law), the ESIP provides all government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources.

ESIP allows local units to use “energy savings obligations” (ESO) to pay for the capital costs of energy improvements to their facilities. ESIP loans have a maximum loan term of 15 year. ESOs are not considered “new general obligation debt” of a local unit and do not count against debt limits or require voter approval. They may be issued as refunding

bonds or leases. Savings generated from the installation of energy conservation measures pay the principal of and interest on the bonds; for that reason, the debt service created by the ESOs is not paid from the debt service fund, but is paid from the general fund.

For local governments interested in pursuing an ESIP, the first step is to perform an energy audit. Pursuing a Local Government Energy Audit through New Jersey's Clean Energy Program is a valuable first step to the ESIP approach. The "Local Finance Notice" outlines how local governments can develop and implement an ESIP for their facilities. The ESIP can be prepared internally if the entity has qualified staff. If not, the ESIP must be implemented by an independent contractor and not by the energy savings company producing the Energy Reduction Plan.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Local units should carefully consider all alternatives to develop an approach that best meets their needs. Refer to Appendix D for more information on this program.

6.1.5 Renewable Energy Incentive Program

The Renewable Energy Incentive Program (REIP) is part of New Jersey's efforts to reach its Energy Master Plan goals of striving to use 30 percent of electricity from renewable sources by 2020.

Incentives for sustainable bio-power projects and for energy storage projects are currently under development, with competitive solicitations for each of those technologies expected to begin in the first quarter of 2014. The wind program is currently on hold.

New solar projects are no longer eligible for REIP incentives, but can register for Solar Renewable Energy Certificates (SRECs) through the SREC Registration Program (SRP).

7.0 | ALTERNATIVE ENERGY SCREENING EVALUATION

7.1 Solar

7.1.1 Photovoltaic Rooftop Solar Power Generation

The building was evaluated for the potential to install rooftop photovoltaic (PV) solar panels for power generation. Present technology incorporates the use of solar cell arrays that produce direct current (DC) electricity. This DC current is converted to alternating current (AC) with the use of an electrical device known as an inverter. The amount of available roof area determines how large of a solar array can be installed on any given roof.

Due to the location of this building and the fact that the tree line significantly obstructs the sunlight from hitting the roof, a solar PV system was determined to not be feasible.

7.1.2 Solar Thermal Hot Water Generation

Active solar thermal systems use solar collectors to gather the sun's energy to heat a fluid. An absorber in the collector (usually black colored piping) converts the sun's energy into heat. The heat is transferred to circulating water, antifreeze, or air for immediate use or is storage for later utilization. Applications for active solar thermal energy include supplementing domestic hot water, heating swimming pools, space heating or preheating air in residential and commercial buildings.

A standard solar hot water system is typically composed of solar collectors, heat storage vessel, piping, circulators, and controls. Systems are typically integrated to work alongside a conventional heating system that provides heat when solar resources are not sufficient. The solar collectors are usually placed on the roof of the building, oriented south, and tilted at the same angle as the site's latitude, to maximize the amount of solar radiation collected on a yearly basis.


Several options exist for using active solar thermal systems for space heating. The most common method is called a passive solar hot water system involves using glazed collectors to heat a liquid held in a storage tank (similar to an active solar hot water system described above which requires pumping). The most practical system would transfer the heat from the panels to thermal storage tanks and then use the pre-heated water for domestic hot water production. DHW is presently produced by natural gas fired water heaters and, therefore, this measure would offer natural gas utility savings. Unfortunately, the amount of domestic hot water that is currently used by this school is very small. Installing a solar domestic hot water system is not recommended due to the limited amount of domestic hot water presently consumed by the school.

This measure is not recommended due to the relatively low domestic hot water usage.

7.2 Wind Powered Turbines

Wind power is the conversion of kinetic energy from wind into mechanical power that is used to drive a generator which creates electricity by means of a wind turbine. A wind

turbine consists of rotor and blades connected to a gearbox and generator that are mounted onto a tower. Newer wind turbines also use advanced technology to generate electricity at a variety of frequencies depending on the wind speed, convert it to DC and then back to AC before sending it to the grid. Wind turbines range from 50 – 750 kW for utility scale turbines down to below 50 kW for residential use. On a scale of 1 (the lowest) to 7 (the highest), Class 3 and above (wind speeds of 13 mph or greater) are generally considered “good wind resource” according to the Wind Energy Development Programmatic EIS Information Center hosted by the Bureau of Land Management. According to the map below, published by NREL, Newark, NJ is classified as Class 1 at 50m, meaning the city would not be a good candidate for wind power.



This measure is not recommended due to the location of the school.

7.3 Combined Heat and Power Plant and Fuel Cell

Combined heat and power (CHP), cogeneration, is self-production of electricity on-site with beneficial recovery of the heat byproduct from the electrical generator. Common CHP equipment includes reciprocating engine-driven, micro turbines, steam turbines, and fuel cells. Typical CHP customers include industrial, commercial, institutional, educational institutions, and multifamily residential facilities. CHP systems that are commercially viable at the present time are sized approximately 50 kW and above, with numerous options in blocks grouped around 300 kW, 800 kW, 1,200 kW and larger. Typically, CHP systems are used to produce a portion of the electricity needed by a facility some or all of the time, with the balance of electric needs satisfied by purchase from the grid.

Any proposed CHP project will need to consider many factors, such as existing system load, use of thermal energy produced, system size, natural gas fuel availability, and proposed plant location. The building has sufficient need for electrical generation and the ability to use most of the thermal byproduct during the winter; however thermal

usage during the summer months does not exist. Thermal energy produced by the CHP plant in the warmer months will be wasted. An absorption chiller could be installed to utilize the heat to produce chilled water; however, there is no chilled water distribution system in the building. CHP is not recommended due to the building's limited summer thermal demand.

This measure is not recommended due to the absence of year-round thermal loads which are needed for efficiency CHP operation. However, a mini-size CHP could be an option for the school to consider. The sizing and energy savings of the mini-size CHP require further study.

A fuel cell system with recovery and productive use of waste heat is another alternative energy option viable in the market. A full analysis of all campus buildings would need to be completed to determine the economic viability. The several buildings included in the scope of work are not good candidates for CHP or Fuel cell technology based on their utility usage and geographic locations on their own relative to the main campus.

7.4 Demand Response Curtailment

Presently, electricity is delivered by PSE&G, which receives the electricity from regional power grid RFC. PSE&G is the regional transmission organization (RTO) that coordinates the movement of wholesale electricity in all or parts of 13 states and the District of Columbia including the State of New Jersey.

Utility Curtailment is an agreement with the utility provider's regional transmission organization and an approved Curtailment Service Provider (CSP) to shed electrical load by either turning major equipment off or energizing all or part of a facility utilizing an emergency generator; therefore, reducing the electrical demand on the utility grid. This program is to benefit the utility company during high demand periods and utility provider offers incentives to the CSP to participate in this program. Enrolling in the program will require program participants to drop electrical load or turn on emergency generators during high electrical demand conditions or during emergencies. Part of the program also will require that program participants reduce their required load or run emergency generators with notice to test the system.

A pre-approved CSP will require a minimum of 100 kW of load reduction to participate in any curtailment program. From February 2013 through January 2014 the following table summarizes the electricity load profile for the building.

Building Electric Load Profile

Peak Demand kW	Min Demand kW	Avg Demand kW	Onsite Generation Y/N	Eligible? Y/N
10	10	10	N	N

This measure is not recommended because the building does not have adequate load to meet the required minimum load reduction.

8.0 CONCLUSIONS & RECOMMENDATIONS

The following section summarizes the LGEA energy audit conducted by CHA for the Campus Police building at William Patterson University.

The following projects should be considered for implementation:


- Add Attic Insulation
- Replace DX Cooling and Electric Heaters with Heat Pumps
- Install Occupancy Sensors to control Electric Heaters
- Replace High Flow Plumbing Fixtures with Low Flow Plumbing Fixtures
- Lighting Replacements with Controls (Occupancy Sensors)

The potential annual energy and cost savings for the recommended ECMs are shown in the following table.

Electric Savings (kWh)	Natural Gas Savings (therms)	Total Savings (\$)	Payback (years)
62,641	0	9,879	10.8

If NPS implements the recommended ECMs, energy savings would be as follows:

	Existing Conditions	Post Recommended ECMs	Percent Savings
Costs (\$)	28,771	18,892	34%
Electricity (kWh)	194,010	131,369	32%
Natural Gas (therms)	0	0	0
Site EUI (kbtu/SF/Yr)	143.9	97.4	



Next Steps: This energy audit has identified several areas of potential energy savings. William Paterson University can use this information to pursue incentives offered by the NJBPU's NJ Clean Energy Program. Additional meetings will be scheduled with WPU staff members to review possible options.

APPENDIX A

Utility Usage Analysis and Alternate Utility Suppliers

William Patterson University LGEA
Campus Police Building Electric Usages

Annual Utilities
12-month Summary

Electric		
Annual Usage	194,010	kWh/yr
Annual Cost	28,771	\$
Blended Rate	0.148	\$/kWh
Consumption Rate	0.141	\$/kWh
Demand Rate	11.93	\$/kW
Peak Demand	10.0	kW
Min. Demand	10.0	kW
Avg. Demand	10.0	kW

**William Patterson University LGEA
Campus Police Building**

Utility Bills: Account Numbers

<u>Account Number</u>	<u>Building Name</u>	<u>Location</u>	<u>Type</u>	<u>Notes</u>
69-477-197-04	Campus Police	300 Pompton Road, Wayne NJ 07470	Electricity	

William Patterson University LGEA
Campus Police Building Electric Usages

For Service at:

Account No.:69-477-197-04

Meter No.:678004959

Electric Service


Delivery -PSE&G

Supplier -Direct Energy

Month	Consumption (kWh)	Demand (kW)	Provider Charges			Usage (kWh) vs. Demand (kW) Charges		Unit Costs		
			Delivery (\$)	Supplier (\$)	Total (\$)	Consumption (\$)	Demand (\$)	Blended Rate (\$/kWh)	Consumption (\$/kWh)	Demand (\$/kW)
February-13	19,020	10.00	1,876.40	818.77	2,695.17	2,575.87	119.30	0.14	0.14	11.93
March-13	16,440	10.00	1,621.87	704.22	2,326.09	2,206.79	119.30	0.14	0.13	11.93
April-13	15,570	10.00	1,536.04	658.42	2,194.46	2,075.16	119.30	0.14	0.13	11.93
May-13	7,380	10.00	728.07	425.03	1,153.10	1,033.80	119.30	0.16	0.14	11.93
June-13	12,090	10.00	1,192.73	1,031.05	2,223.78	2,104.48	119.30	0.18	0.17	11.93
July-13	19,170	10.00	1,891.20	1,140.56	3,031.76	2,912.46	119.30	0.16	0.15	11.93
August-13	14,760	10.00	1,456.13	934.71	2,390.84	2,271.54	119.30	0.16	0.15	11.93
September-13	14,940	10.00	1,473.89	970.67	2,444.56	2,325.26	119.30	0.16	0.16	11.93
October-13	11,400	10.00	1,124.66	490.76	1,615.42	1,496.12	119.30	0.14	0.13	11.93
November-13	18,570	10.00	1,832.00	745.15	2,577.15	2,457.85	119.30	0.14	0.13	11.93
December-13	22,260	10.00	2,196.04	857.74	3,053.78	2,934.48	119.30	0.14	0.13	11.93
January-14	22,410	10.00	2,210.84	853.84	3,064.68	2,945.38	119.30	0.14	0.13	11.93
Total (All)	194,010	10.00	\$19,139.86	\$9,630.93	\$28,770.79	\$27,339.19	\$1,431.60	\$0.15	\$0.14	\$11.93
Notes	1	2	3	4	5	6	7	8	9	10

- 1.) Number of kWh of electric energy used per month
- 2.) Number of kW of power measured
- 3.) Electric charges from Delivery provider
- 4.) Electric charges from Supply provider
- 5.) Total charges (Delivery + Supplier)
- 6.) Charges based on the number of kWh of electric energy used
- 7.) Charges based on the number of kW of power measured
- 8.) Total Charges (\$) / Consumption (kWh)
- 9.) Consumption Charges (\$) / Consumption (kWh)
- 10.) Demand Charges (\$) / Demand (kW)
- Estimated

Campus Police Building Electric Usages



PSE&G ELECTRIC SERVICE TERRITORY
Last Updated: 10/24/12

***CUSTOMER CLASS - R – RESIDENTIAL C – COMMERCIAL I –INDUSTRIAL**

Supplier	Telephone & Web Site	*Customer Class
AEP Energy, Inc. 309 Fellowship Road, Fl. 2 Mount Laurel, NJ 08054	(866) 258-3782 www.aepenergy.com	C/I ACTIVE
Alpha Gas and Electric, LLC 641 5 th Street Lakewood, NJ 08701	(855) 553-6374 www.alphagasandelectric.com	R/C ACTIVE
Ambit Northeast, LLC 103 Carnegie Center Suite 300 Princeton, NJ 08540	(877)-30-AMBIT (877) 302-6248 www.ambitenergy.com	R/C ACTIVE
American Powernet Management, LP 437 North Grove St. Berlin, NJ 08009	(877) 977-2636 www.americanpowernet.com	C ACTIVE
Amerigreen Energy, Inc. 1463 Lamberton Road Trenton, NJ 08611	888-423-8357 www.amerigreen.com	R/C ACTIVE
AP Gas & Electric, LLC 10 North Park Place, Suite 420 Morristown, NJ 07960	(855) 544-4895 www.apge.com	R/C/I ACTIVE
Astral Energy LLC 16 Tyson Place Bergenfield, NJ 07621	(201) 384-5552 www.astralenergylc.com	R/C/I ACTIVE
Barclays Capital Services, Inc. 70 Hudson Street Jersey City, NJ 07302-4585	(888) 978-9974 www.group.barclays.com	C ACTIVE
BBPC, LLC d/b/a Great Eastern Energy 116 Village Blvd. Suite 200 Princeton, NJ 08540	(888) 651-4121 www.greateasternenergy.com	C/I ACTIVE
Champion Energy Services, LLC 72 Avenue L Newark, NJ 07105	(877) 653-5090 www.championenergyservices.com	R/C/I ACTIVE

Choice Energy, LLC 4257 US Highway 9, Suite 6C Freehold, NJ 07728	888-565-4490 www.4choiceenergy.com	R/C ACTIVE
Clearview Electric, Inc. 505 Park Drive Woodbury, NJ 08096	(888) CLR-VIEW (800) 746-4702 www.clearviewenergy.com	R/C/I ACTIVE
Commerce Energy, Inc. 7 Cedar Terrace Ramsey, NJ 07446	1-866-587-8674 www.commerceenergy.com	R ACTIVE
ConEdison Solutions Cherry Tree Corporate Center 535 State Highway Suite 180 Cherry Hill, NJ 08002	(888) 665-0955 www.conedsolutions.com	C/I ACTIVE
Constellation NewEnergy, Inc. 900A Lake Street, Suite 2 Ramsey, NJ 07446	(866) 237-7693 www.constellation.com	R/C/I ACTIVE
Constellation Energy 900A Lake Street, Suite 2 Ramsey, NJ 07446	(877) 997-9995 www.constellation.com	R ACTIVE
Credit Suisse, (USA) Inc. 700 College Road East Princeton, NJ 08450	(212) 538-3124 www.creditsuisse.com	C ACTIVE
Direct Energy Business, LLC 120 Wood Avenue, Suite 611 Iselin, NJ 08830	(888) 925-9115 www.directenergybusiness.com	C/I ACTIVE
Direct Energy Services, LLC 120 Wood Avenue, Suite 611 Iselin, NJ 08830	(866) 348-4193 www.directenergy.com	R ACTIVE
Discount Energy Group, LLC 811 Church Road, Suite 149 Cherry Hill, New Jersey 08002	(800) 282-3331 www.discountenergygroup.com	R/C ACTIVE
Dominion Retail, Inc. d/b/a Dominion Energy Solutions 395 Route #70 West Suite 125 Lakewood, NJ 08701	(866) 275-4240 www.dom.com/products	R/C ACTIVE

DTE Energy Supply, Inc. One Gateway Center, Suite 2600 Newark, NJ 07102	(877) 332-2450 www.dtesupply.com	C/I ACTIVE
Energy.me Midwest LLC 90 Washington Blvd Bedminster, NJ 07921	(855) 243-7270 www.energy.me	R/C/I ACTIVE
Energy Plus Holdings LLC 309 Fellowship Road East Gate Center, Suite 200 Mt. Laurel, NJ 08054	(877) 866-9193 www.energypluscompany.com	R/C ACTIVE
Ethical Electric Benefit Co. d/b/a Ethical Electric 100 Overlook Center, 2 nd Fl. Princeton, NJ 08540	(888) 444-9452 www.ethicalelectric.com	R/C ACTIVE
FirstEnergy Solutions 300 Madison Avenue Morristown, NJ 07962	(800) 977-0500 www.fes.com	C/I ACTIVE
Gateway Energy Services Corp. 44 Whispering Pines Lane Lakewood, NJ 08701	(800) 805-8586 www.gesc.com	R/C/I ACTIVE
GDF SUEZ Energy Resources NA, Inc. 333 Thornall Street Sixth Floor Edison, NJ 08837	(866) 999-8374 www.gdfsuezenergyresources.com	C/I ACTIVE
Glacial Energy of New Jersey, Inc. 75 Route 15 Building E Lafayette, NJ 07848	(888) 452-2425 www.glacialenergy.com	C/I ACTIVE
Global Energy Marketing LLC 129 Wentz Avenue Springfield, NJ 07081	(800) 542-0778 www.globalp.com	C/I ACTIVE
Green Mountain Energy Company 211 Carnegie Center Drive Princeton, NJ 08540	(866) 767-5818 www.greenmountain.com/commercial-home	C/I ACTIVE

Hess Corporation 1 Hess Plaza Woodbridge, NJ 07095	(800) 437-7872 www.hess.com	C/I ACTIVE
HIKO Energy, LLC 655 Suffern Road Teaneck, NJ 07666	(888) 264-4908 www.hikoenergy.com	R/C ACTIVE
HOP Energy, LLC d/b/a Metro Energy, HOP Fleet Fueling, HOP Energy Fleet Fueling 1011 Hudson Avenue Ridgefield, NJ 07657	(877) 390-7155 www.hopenergy.com	R/C/I ACTIVE
Hudson Energy Services, LLC 7 Cedar Street Ramsey, New Jersey 07446	(877) Hudson 9 www.hudsonenergyservices.com	C ACTIVE
IDT Energy, Inc. 550 Broad Street Newark, NJ 07102	(877) 887-6866 www.idtenergy.com	R/C ACTIVE
Independence Energy Group, LLC 3711 Market Street, 10 th Fl. Philadelphia, PA 19104	(877) 235-6708 www.chooseindependence.com	R/C ACTIVE
Integrus Energy Services, Inc. 99 Wood Ave, South, Suite 802 Iselin, NJ 08830	(877) 763-9977 www.integrusenergy.com	C/I ACTIVE
Keil & Sons, Inc. d/b/a Systrum Energy 1 Bergen Blvd. Fairview, NJ 07022	(877) 797-8786 www.systrumenergy.com	R/C/I ACTIVE
Liberty Power Delaware, LLC 1973 Highway 34, Suite 211 Wall, NJ 07719	(866) 769-3799 www.libertypowercorp.com	C/I ACTIVE
Liberty Power Holdings, LLC 1973 Highway 34, Suite 211 Wall, NJ 07719	(866) 769-3799 www.libertypowercorp.com	C/I ACTIVE

Linde Energy Services 575 Mountain Avenue Murray Hill, NJ 07974	(800) 247-2644 www.linde.com	C/I ACTIVE
Marathon Power LLC 302 Main Street Paterson, NJ 07505	(888) 779-7255 www.mecny.com	R/C/I ACTIVE
MXenergy Electric Inc. 900 Lake Street Ramsey, NJ 07446	(800) 785-4374 www.mxenergy.com	R/C/I ACTIVE
NATGASCO, Inc. 532 Freeman St. Orange, NJ 07050	(973) 678-1800 x. 251 www.supremeenergyinc.com	R/C ACTIVE
NextEra Energy Services New Jersey, LLC 651 Jernee Mill Road Sayreville, NJ 08872	(877) 528-2890 Commercial (800) 882-1276 Residential www.nexteraenergyservices.com	R/C/I ACTIVE
New Jersey Gas & Electric 1 Bridge Plaza fl. 2 Fort Lee, NJ 07024	(866) 568-0290 www.NJGandE.com	R/C ACTIVE
Noble Americas Energy Solutions The Mac-Cali Building 581 Main Street, 8th Floor Woodbridge, NJ 07095	(877) 273-6772 www.noblesolutions.com	C/I ACTIVE
North American Power and Gas, LLC 222 Ridgedale Avenue Cedar Knolls, NJ 07927	(888) 313-9086 www.napower.com	R/C/I ACTIVE
Palmco Power NJ, LLC One Greentree Centre 10,000 Lincoln Drive East, Suite 201 Marlton, NJ 08053	(877) 726-5862 www.PalmcoEnergy.com	R/C/I ACTIVE
Pepco Energy Services, Inc. 112 Main St. Lebanon, NJ 08833	(800) ENERGY-9 (363-7499) www.pepco-services.com	C/I ACTIVE
Plymouth Rock Energy, LLC 338 Maitland Avenue Teaneck, NJ 07666	(855) 32-POWER (76937) www.plymouthenergy.com	R/C/I ACTIVE

PPL Energy Plus, LLC 811 Church Road Cherry Hill, NJ 08002	(800) 281-2000 www.pplenergyplus.com	C/I ACTIVE
Public Power & Utility of New Jersey, LLC 39 Old Ridgebury Rd. Suite 14 Danbury, CT 06810	(888) 354-4415 www.ppandu.com	R/C/I ACTIVE
Reliant Energy 211 Carnegie Center Princeton, NJ 08540	(877) 297-3795 (877) 297-3780 www.reliant.com/pjm	R/C/I ACTIVE
ResCom Energy LLC 18C Wave Crest Ave. Winfield Park, NJ 07036	(888) 238-4041 http://rescomenergy.com	R/C/I ACTIVE
Respond Power LLC 10 Regency CT Lakewood, NJ 08701	(877) 973-7763 www.respondpower.com	R/C/I ACTIVE
South Jersey Energy Company 1 South Jersey Plaza, Route 54 Folsom, NJ 08037	(800) 266-6020 www.southjerseyenergy.com	C/I ACTIVE
Sperian Energy Corp. 1200 Route 22 East, Suite 2000 Bridgewater, NJ 08807	(888) 682-8082	R/C/I ACTIVE
S.J. Energy Partners, Inc. 208 White Horse Pike, Suite 4 Barrington, N.J. 08007	(800) 695-0666 www.sjnaturalgas.com	R/C ACTIVE
Spark Energy, L.P. 2105 CityWest Blvd., Ste 100 Houston, Texas 77042	(800) 441-7514 www.sparkenergy.com	R/C/I ACTIVE
Sprague Energy Corp. 12 Ridge Road Chatham Township, NJ 07928	(800) 225-1560 www.spragueenergy.com	C/I ACTIVE
Starion Energy PA Inc. 101 Warburton Avenue Hawthorne, NJ 07506	(800) 600-3040 www.starionenergy.com	R/C/I ACTIVE
Stream Energy 309 Fellowship Rd., Suite 200 Mt. Laurel, NJ 08054	(877) 39-8150 www.streamenergy.net	R ACTIVE

UGI Energy Services, Inc. d/b/a GASMARK 224 Strawbridge Drive Suite 107 Moorestown, NJ 08057	(856) 273-9995 www.ugienergyservices.com	C/I ACTIVE
Verde Energy USA, Inc. 50 East Palisades Avenue Englewood, NJ 07631	(800) 388-3862 www.lowcostpower.com	R/C/I ACTIVE
Viridian Energy 2001 Route 46, Waterview Plaza Suite 310 Parsippany, NJ 07054	(866) 663-2508 www.viridian.com	R/C/I ACTIVE
Xoom Energy New Jersey, LLC 744 Broad Street Newark, NJ 07102	(888) 997-8979 www.xoomenergy.com	R/C/I ACTIVE
YEP Energy 89 Headquarters Plaza North #1463 Morristown, NJ 07960	(855) 363-7736 www.yepenergyNJ.com	R/C/I ACTIVE
Your Energy Holdings, LLC One International Boulevard Suite 400 Mahwah, NJ 07495-0400	(855) 732-2493 www.thisisyourenergy.com	R/C/I ACTIVE

[Back to the main supplier page](#)

PSE&G GAS SERVICE TERRITORY

Last Updated: 10/24/12

***CUSTOMER CLASS - R – RESIDENTIAL C – COMMERCIAL I - INDUSTRIAL**

Supplier	Telephone & Web Site	*Customer Class
Ambit Northeast, LLC 103 Carnegie Center Suite 300 Princeton, NJ 08540	(877)-30-AMBIT (877) 302-6248 www.ambitenergy.com	R/C ACTIVE
Astral Energy LLC 16 Tyson Place Bergenfield, NJ 07621	888-850-1872 www.astralenergyllc.com	R/C/I ACTIVE
BBPC, LLC Great Eastern Energy 116 Village Blvd. Suite 200 Princeton, NJ 08540	888-651-4121 www.greateasternenergy.com	C/I ACTIVE
Clearview Electric Inc. d/b/a Clearview Gas 1744 Lexington Ave. Pennsauken, NJ 08110	800-746-4720 www.clearviewenergy.com	R/C ACTIVE
Colonial Energy, Inc. 83 Harding Road Wyckoff, NJ 07481	845-429-3229 www.colonialgroupinc.com	C/I ACTIVE
Commerce Energy, Inc. 7 Cedar Terrace Ramsey, NJ 07746	(888) 817-8572 www.commerceenergy.com	R ACTIVE
Compass Energy Services, Inc. 1085 Morris Avenue, Suite 150 Union, NJ 07083	866-867-8328 908-638-6605 www.compassenergy.net	C/I ACTIVE
ConocoPhillips Company 224 Strawbridge Drive, Suite 107 Moorestown, NJ 08057	800-646-4427 www.conocophillips.com	C/I ACTIVE
Consolidated Edison Energy, Inc. d/b/a Con Edison Solutions 535 State Highway 38, Suite 140 Cherry Hill, NJ 08002	888-686-1383 x2130 www.conedenergy.com	

Consolidated Edison Solutions, Inc. Cherry Tree Corporate Center 535 State Highway 38, Suite 140 Cherry Hill, NJ 08002	888-665-0955 www.conedsolutions.com	C/I ACTIVE
Constellation NewEnergy-Gas Division, LLC 900A Lake Street, Suite 2 Ramsey, NJ 07466	(800) 900-1982 www.constellation.com	C/I ACTIVE
Direct Energy Business, LLC 120 Wood Avenue, Suite 611 Iselin, NJ 08830	888-925-9115 www.directenergy.com	C/I ACTIVE
Direct Energy Services, LLP 120 Wood Avenue, Suite 611 Iselin, NJ 08830	866-348-4193 www.directenergy.com	R ACTIVE
Gateway Energy Services Corp. 44 Whispering Pines Lane Lakewood, NJ 08701	800-805-8586 www.gesc.com	R/C/I ACTIVE
UGI Energy Services, Inc. d/b/a GASMARK 224 Strawbridge Drive, Suite 107 Moorestown, NJ 08057	856-273-9995 www.ugienergyservices.com	C/I ACTIVE
Global Energy Marketing, LLC 129 Wentz Avenue Springfield, NJ 07081	800-542-0778 www.globalp.com	C/I ACTIVE
Great Eastern Energy 116 Village Blvd., Suite 200 Princeton, NJ 08540	888-651-4121 www.greateastern.com	C/I ACTIVE
Greenlight Energy 330 Hudson Street, Suite 4 Hoboken, NJ 07030	718-204-7467 www.greenlightenergy.us	C ACTIVE
Hess Energy, Inc. One Hess Plaza Woodbridge, NJ 07095	800-437-7872 www.hess.com	C/I ACTIVE
Hess Small Business Services, LLC One Hess Plaza Woodbridge, NJ 07095	888-494-4377 www.hessenergy.com	C/I ACTIVE
HIKO Energy, LLC 655 Suffern Road Teaneck, NJ 07666	(888) 264-4908 www.hikoenergy.com	R/C ACTIVE

Hudson Energy Services, LLC 7 Cedar Street Ramsey, NJ 07446	877- Hudson 9 www.hudsonenergyservices.com	C ACTIVE
IDT Energy, Inc. 550 Broad Street Newark, NJ 07102	877-887-6866 www.idtenergy.com	R/C ACTIVE
Integrus Energy Services – Natural Gas, LLC 99 Wood Avenue South Suite #802 Iselin, NJ 08830	800-536-0151 www.integrusenergy.com	C/I ACTIVE
Intelligent Energy 2050 Center Avenue, Suite 500 Fort Lee, NJ 07024	800-927-9794 www.intelligentenergy.org	R/C/I ACTIVE
Keil & Sons, Inc. d/b/a Systrum Energy 1 Bergen Blvd. Fairview, NJ 07022	1-877-797-8786 www.systrumenergy.com	R/C/I ACTIVE
Major Energy Services, LLC 10 Regency CT Lakewood, NJ 08701	888-625-6760 www.majorenergy.com	R/C/I ACTIVE
Marathon Power LLC 302 Main Street Paterson, NJ 07505	888-779-7255 www.mecny.com	R/C/I ACTIVE
Metromedia Energy, Inc. 6 Industrial Way Eatontown, NJ 07724	800-828-9427 www.metromediaenergy.com	C ACTIVE
Metro Energy Group, LLC 14 Washington Place Hackensack, NJ 07601	888-53-Metro www.metroenergy.com	R/C ACTIVE
MxEnergy, Inc. 900 Lake Street Ramsey, NJ 07446	800-758-4374 www.mxenergy.com	R/C/I ACTIVE
NATGASCO (Mitchell Supreme) 532 Freeman Street Orange, NJ 07050	800-840-4GAS www.natgasco.com	C ACTIVE
New Energy Services LLC 101 Neptune Avenue Deal, New Jersey 07723	800-660-3643 www.newenergyservicesllc.com	R/C/I ACTIVE

New Jersey Gas & Electric 1 Bridge Plaza, Fl. 2 Fort Lee, NJ 07024	866-568-0290 www.NJGandE.com	R/C ACTIVE
Noble Americas Energy Solutions The Mac-Cali Building 581 Main Street, 8th fl. Woodbridge, NJ 07095	877-273-6772 www.noblesolutions.com	C/I ACTIVE
North American Power & Gas, LLC d/b/a North American Power 197 Route 18 South Ste. 3000 East Brunswick, NJ 08816	(888) 313-9086 www.napower.com	R/C/I ACTIVE
Palmco Energy NJ, LLC One Greentree Centre 10,000 Lincoln Drive East, Suite 201 Marlton, NJ 08053	877-726-5862 www.PalmcoEnergy.com	R/C/I ACTIVE
Pepco Energy Services, Inc. 112 Main Street Lebanon, NJ 08833	800-363-7499 www.pepco-services.com	C/I ACTIVE
Plymouth Rock Energy, LLC 338 Maitland Avenue Teaneck, NJ 07666	855-32-POWER (76937) www.plymouthenergy.com	R/C/I ACTIVE
PPL EnergyPlus, LLC 811 Church Road - Office 105 Cherry Hill, NJ 08002	800-281-2000 www.pplenergyplus.com	C/I ACTIVE
Respond Power LLC 10 Regency CT Lakewood, NJ 08701	(877) 973-7763 www.respondpower.com	R/C/I ACTIVE
South Jersey Energy Company 1 South Jersey Plaza, Route 54 Folsom, NJ 08037	800-266-6020 www.southjerseyenergy.com	C/I ACTIVE
S.J. Energy Partners, Inc. 208 White Horse Pike, Suite 4 Barrington, NJ 08007	800-695-0666 www.sjnaturalgas.com	R/C ACTIVE
Spark Energy Gas, L.P. 2105 CityWest Blvd, Ste 100 Houston, Texas 77042	800-411-7514 www.sparkenergy.com	R/C/I ACTIVE
Sprague Energy Corp. 12 Ridge Road Chatham Township, NJ 07928	855-466-2842 www.spragueenergy.com	C/I ACTIVE

Stuyvesant Energy LLC 10 West Ivy Lane, Suite 4 Englewood, NJ 07631	800-640-6457 www.stuyfuel.com	C ACTIVE
Stream Energy New Jersey, LLC 309 Fellowship Road Suite 200 Mt. Laurel, NJ 08054	(973) 494-8097 www.streamenergy.net	R/C ACTIVE
Systrum Energy 1 Bergen Blvd. Fairview, NJ 07022	877-797-8786 www.systrumenergy.com	R/C/I ACTIVE
Woodruff Energy 73 Water Street Bridgeton, NJ 08302	800-557-1121 www.woodruffenergy.com	R/C/I ACTIVE
Woodruff Energy US LLC 73 Water Street, P.O. Box 777 Bridgeton, NJ 08302	856-455-1111 800-557-1121 www.woodruffenergy.com	C/I ACTIVE
Xoom Energy New Jersey, LLC 744 Broad Street Newark, NJ 07102	888-997-8979 www.xoomenergy.com	R/C/I ACTIVE
Your Energy Holdings, LLC One International Boulevard Suite 400 Mahwah, NJ 07495-0400	(855) 732-2493 www.thisisyourenergy.com	R/C/I ACTIVE

[Back to main supplier information page](#)

APPENDIX B

Equipment Inventory

CHA Project # 28661
Campus Police Department
William Paterson University

Description	QTY	Manufacturer Name	Model No.	Serial No.	Equipment Type / Utility	Capacity/Size	Efficiency	Location	Areas/Equipment Served	Date Installed	Remaining Useful Life (years)	Other Info.	Current year	Years Old	ASHRAE life expectancy
AHU	2	Trane	N/A	N/A	AHU	N/A	N/A	Attic	Most of the Building	1996	2		2014	18	20
DX For AHUs	2	Trane	TTA120A300AA	F43193250	DX Cooling Units with Condenser on the Ground Outside	10 ton	11.2 EER	High School MR	AHU	1996	2		2014	18	20
DHW Heater	1	Carrier	EEB 60 920	ML030003082	DHW Heater	4.5kW and 80 gallon storage	100%	Roof	The Whole Building	1996	2		2014	18	20
Electric Heaters	many	N/A	N/A	N/A	Electric Unit Heaters on the Wall	N/A	99%	Office Rooms and Hallways	Office Rooms and Hallways	1995	1		2014	19	20

Cost of Electricity:

\$0.141 \$/kWh

\$11.93 \$/kW

	EXISTING CONDITIONS										Retrofit Control	
	Area Description	Usage	No. of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/Space	Exist Control	Annual Hours	Annual kWh		
Field Code	Unique description of the location - Room number/Room name: Floor number (if applicable)	Describe Usage Type using Operating Hours	No. of fixtures before the retrofit	Lighting Fixture Code	Code from Table of Standard Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Fixt No.)	Pre-inst. control device	Estimated annual hours for the usage group	(kW/space) * (Annual Hours)	Retrofit control device	Notes
35LED	Foyer 101	Hallways	2	T 32 R F 3 (ELE)	F43ILL/2	90	0.18	SW	8736	1,572	NONE	
5LED	Corridor 100	Hallways	5	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.30	SW	8736	2,621	NONE	
5LED	Radio Room 102	Offices	6	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.36	SW	4368	1,572	NONE	
5LED	Mechanical Room 103	Mechanical Room	2	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.12	SW	8736	1,048	NONE	
5LED	Women's Locker Room 104	Locker	2	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.12	SW	2800	336	C-OCC	
5LED	Custodial 105	Storage Areas	1	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.06	SW	4368	262	C-OCC	
5LED	Men's Room 106A	Restroom	2	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.12	SW	4368	524	C-OCC	
5LED	Men's Locker Room 106	Locker	7	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.42	SW	2800	1,176	C-OCC	
5LED	Storage 107	Storage Areas	2	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.12	SW	4368	524	C-OCC	
5LED	Corridor 100A	Hallways	2	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.12	SW	8736	1,048	NONE	
36	Bathroom 110	Restroom	1	2T 3' 17 R F 1 (ELE)	F21ILL	20	0.02	SW	4368	87	C-OCC	
5LED	Storage 108	Storage Areas	1	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.06	SW	4368	262	C-OCC	
5LED	Lounge 109	Staff Lounge	6	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.36	SW	4368	1,572	C-OCC	
5LED	Interrogation Room 210	Offices	4	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.24	SW	4368	1,048	NONE	
5LED	Office 201	Offices	2	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.12	SW	4368	524	C-OCC	
5LED	Office 202	Offices	4	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.24	SW	4368	1,048	C-OCC	
5LED	Office 203	Offices	2	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.12	SW	4368	524	C-OCC	Locked, Estimated
5LED	Office 204	Offices	6	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.36	SW	4368	1,572	C-OCC	
5LED	Office 204A	Storage Areas	1	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.06	SW	4368	262	C-OCC	
5LED	Office 204B	Storage Areas	1	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.06	SW	4368	262	C-OCC	
36	Office 204C	Restroom	1	2T 3' 17 R F 1 (ELE)	F21ILL	20	0.02	SW	4368	87	C-OCC	
5LED	Foyer 205	Hallways	2	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.12	SW	8736	1,048	NONE	
5LED	Office 206	Offices	14	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.84	SW	4368	3,669	C-OCC	
5LED	Office 207	Offices	9	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.54	SW	4368	2,359	C-OCC	Locked, Estimated
5LED	Office 208	Offices	9	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.54	SW	4368	2,359	C-OCC	Locked, Estimated
5LED	Office 209	Offices	9	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.54	SW	4368	2,359	C-OCC	Locked, Estimated
227LED	Outdoor	Outdoor Lighting	8	70 W MH Wall Pack	MH70/1	95	0.76		4368	3,320		
	Total		111				6.92			33,049		

APPENDIX C

ECM Calculations

William Paterson University - Campus Police Department
CHA Project Numer: 28661

Rate of Discount (used for NPV) 3.0%

Utility Costs		Yearly Usage	Metric Ton Carbon Dioxide Equivalent	Building Area	Annual Utility Cost		
\$ 0.148	\$/kWh blended		0.000420205	4,600	Electric	Natural Gas	Fuel Oil
\$ 0.141	\$/kWh supply	194,010	0.000420205		\$ 28,771	\$ -	
\$ 11.93	\$/kW	10.0	0				
\$ -	\$/Therm	-	0.00533471				
\$ 7.50	\$/kgals		0				
	\$/Gal						

Estimated

Campus Police Department

Recommend?		Item	Savings					Cost	Simple Payback	Life Expectancy	Equivalent CO ₂ (Metric tons)	NJ Smart Start Incentives	Direct Install Eligible (Y/N)	Payback w/ Incentives	Simple Projected Lifetime Savings					ROI	NPV	IRR	
Y or N			kW	kWh	therms	No. 2 Oil gal	Water kgal	\$							kW	kWh	therms	kgal/yr	\$				
Y	ECM-1	Add Attic Insulation	0.0	7,845	0	0	0	1,161	\$ 5,980	5.2	30	3.3	\$ -	N	5.2	0.0	235,341	0	0	\$ 34,831	4.8	\$16,777	19.3%
Y	ECM-2A	Replace DX Cooling and Electric Heaters with Heat Pumps	0.0	25,070	0	0	0	3,710	\$ 45,828	12.4	25	10.5	\$ 1,040	N	12.1	0.0	626,761	0	0	\$ 92,761	1.0	\$19,822	6.6%
N	ECM-2B	Replace DX Units Unit with High Efficiency DX Units	0.0	4,547	0	0	0	673	\$ 14,880	22.1	20	1.9	\$ 1,040	N	20.6	0.0	90,937	0	0	\$ 13,459	(0.1)	(\$3,829)	-0.3%
Y	ECM-3	Install Occupancy Sensors to control Electric Heaters	0.0	7,788	0	0	0	1,153	\$ 8,397	7.3	20	3.3	\$ -	N	7.3	0.0	155,765	0	0	\$ 23,053	1.7	\$8,751	12.4%
Y	ECM-4	Replace High Flow Plumbing Fixtures with Low Flow Plumbing Fixtures	0.0	372	0	0	21	215	\$ 17,260	80.3	20	0.2	\$ -	N	80.3	0.0	7,445	0	426	\$ 4,299	(0.8)	(\$14,062)	-10.7%
N	ECM-L1	Lighting Replacements / Upgrades	4.2	19,922	0	0	0	3,408	\$ 23,906	7.0	10	8.4	\$ 5,750	N	5.3	41.9	199,220	0	0	\$ 35,476	0.5	\$10,916	13.5%
N	ECM-L2	Install Lighting Controls (Add Occupancy Sensors)	0.0	3,944	0	0	0	556	\$ 5,130	9.2	10	1.7	\$ 665	N	8.0	0.0	39,440	0	0	\$ 5,837	0.1	\$279	4.2%
Y	ECM-L3	Lighting Replacements with Controls (Occupancy Sensors)	4.2	21,565	0	0	0	3,640	\$ 29,036	8.0	10	9.1	\$ 6,415	N	6.2	41.9	215,650	0	0	\$ 37,907	0.3	\$8,427	9.7%
Total (Does Not Include ECM-L1 & ECM-L2)			4.2	62,641	0	0	21	\$ 9,879	\$ 106,501	10.8	21.0	26	\$ 7,455		10.03	42	1,240,963	-	426	\$ 192,851	0.8	53236.40	8.0%
Recommended Measures (highlighted green above)			4.2	62,641	0	0	21	\$ 9,879	\$ 106,501	10.8	21.0	26	\$ 7,455	0	10.03	42	1,240,963	-	426	\$ 192,851	0.8	53236.40	8.0%
% of Existing			42%	32%	#DIV/0!	0	0																

City:		Newark, NJ				
Occupied Hours/Week		168				
		Building	Auditorium	Gymnasium	Library	Classrooms
		Operating Hours	Occupied Hours	Occupied Hours	Occupied Hours	Occupied Hours
Temp	Enthalpy h (Btu/lb)	Bin Hours				
102.5						
97.5	35.4	6	6	0	0	0
92.5	37.4	31	31	0	0	0
87.5	35.0	131	131	0	0	0
82.5	33.0	500	500	0	0	0
77.5	31.5	620	620	0	0	0
72.5	29.9	664	664	0	0	0
67.5	27.2	854	854	0	0	0
62.5	24.0	927	927	0	0	0
57.5	20.3	600	600	0	0	0
52.5	18.2	730	730	0	0	0
47.5	16.0	491	491	0	0	0
42.5	14.5	656	656	0	0	0
37.5	12.5	1,023	1,023	0	0	0
32.5	10.5	734	734	0	0	0
27.5	8.7	334	334	0	0	0
22.5	7.0	252	252	0	0	0
17.5	5.4	125	125	0	0	0
12.5	3.7	47	47	0	0	0
7.5	2.1	34	34	0	0	0
2.5	1.3	1	1	0	0	0
-2.5						
-7.5						

Multipliers	
Material:	1.027
Labor:	1.246
Equipment:	1.124

Heating System Efficiency	80%
Cooling Eff (kW/ton)	1.2

Heating	
Hours	4,427 Hrs
Weighted Avg	40 F
Avg	28 F


Cooling	
Hours	4,333 Hrs
Weighted Avg	68 F
Avg	78 F

Utility End Use Analysis		
Electricity Use (kWh):		Notes/Comments:
194,010	Total	Based on utility analysis
48,000	Lighting	From Lighting Calculations
3,000	Motors	Estimated
108,000	Cooling/Heating	Estimated
10,000	Plug Load	Estimated
19,400	Computers	Estimated
5,000	DHW	Remaining
Natural Gas Use (Therms):		Notes/Comments:
-	Total	Based on utility analysis
0	Boilers	Therms/SF x Square Feet Served
0	DHW	Based on utility analysis

25%
2%
56%
5%
10%
3%
100%

#DIV/0!
#DIV/0!

Electricity Use (kWh):



William Paterson University - Campus Police Department
CHA Project Numer: 28661
Campus Police Department

ECM-1 Add Attic Insulation

Existing: Attic can lead to increased energy consumption due to infiltration/exfiltration and heat gain/loss.
Proposed: Install 9" fiberglass blown-in loose-fill insulation in attic cavity to reduce heat transfer.

Area of attic	4,600 SF	Cooling System Efficiency	1.2 kW/ton	Heating System Efficiency	100%
Existing Infiltration Factor	0.03 cfm/SF	Ex Occupied Cng Temp.	72 *F	Heating On Point	55 *F
Proposed Infiltration Factor	0.02 cfm/SF	Ex Unoccupied Cng Temp.	72 *F	Ex Occupied Htg Temp.	72 *F
Existing U Value	0.060 Btuh/SF/°F	Cooling Occ Enthalpy Setpoint	27.5 Btu/lb	Ex Unoccupied Htg Temp.	72 *F
Proposed U Value	0.033 Btuh/SF/°F	Cooling Unocc Enthalpy Setpoint	27.5 Btu/lb	Cooling Electricity	\$ 0.148 \$/kWh

					No significant cooling in building							
					EXISTING LOADS		PROPOSED LOADS		COOLING ENERGY		HEATING ENERGY	
					Occupied	Unoccupied	Occupied	Unoccupied				
Avg Outdoor Air Temp. Bins °F	Avg Outdoor Air Enthalpy	Existing Equipment Bin Hours	Occupied Equipment Bin Hours	Unoccupied Equipment Bin Hours	Wall Infiltration & Heat Load BTUH	Wall Infiltration & Heat Load BTUH	Wall Infiltration & Heat Load BTUH	Wall Infiltration & Heat Load BTUH	Existing Cooling Energy kWh	Proposed Cooling Energy kWh	Existing Heating Energy kWh	Proposed Heating Energy kWh
A		B	C	D	E	F	G	H	I	J	K	L
97.5	35.4	6	2	4	-11,948	-11,948	-7,184	-7,184	7	4	0	0
92.5	37.4	31	9	22	-11,807	-11,807	-7,243	-7,243	37	22	0	0
87.5	35.0	131	37	94	-8,926	-8,926	-5,475	-5,475	117	72	0	0
82.5	33.0	500	143	357	-6,343	-6,343	-3,906	-3,906	317	195	0	0
77.5	31.5	620	177	443	-4,032	-4,032	-2,519	-2,519	250	156	0	0
72.5	29.9	664	190	474	-1,632	-1,632	-1,073	-1,073	108	71	0	0
67.5	27.2	854	244	610	0	0	0	0	0	0	0	0
62.5	24.0	927	265	662	0	0	0	0	0	0	0	0
57.5	20.3	600	171	429	0	0	0	0	0	0	0	0
52.5	18.2	730	209	521	8,288	8,288	4,928	4,928	0	0	1,773	1,054
47.5	16.0	491	140	351	10,413	10,413	6,191	6,191	0	0	1,498	891
42.5	14.5	656	187	469	12,539	12,539	7,454	7,454	0	0	2,410	1,433
37.5	12.5	1,023	292	731	14,664	14,664	8,718	8,718	0	0	4,395	2,613
32.5	10.5	734	210	524	16,789	16,789	9,981	9,981	0	0	3,611	2,147
27.5	8.7	334	95	239	18,914	18,914	11,245	11,245	0	0	1,851	1,100
22.5	7.0	252	72	180	21,039	21,039	12,508	12,508	0	0	1,553	924
17.5	5.4	125	36	89	23,165	23,165	13,772	13,772	0	0	848	504
12.5	3.7	47	13	34	25,290	25,290	15,035	15,035	0	0	348	207
7.5	2.1	34	10	24	27,415	27,415	16,299	16,299	0	0	273	162
2.5	1.3	1	0	1	29,540	29,540	17,562	17,562	0	0	9	5
TOTALS		8,760	2,503	6,257					836	521	18,570	11,040

Existing Ceiling Infiltration	138 cfm	Savings		therms	\$ -
Existing Ceiling Heat Transfer	276 Btuh/°F		7,845 kWh		\$ 1,161
Proposed Ceiling Infiltration	92 cfm				\$ 1,161
Proposed Ceiling Heat Transfer	153 Btuh/°F				

William Paterson University - Campus Police Department
CHA Project Numer: 28661
Campus Police Department

Multipliers	
Material:	1.03
Labor:	1.25
Equipment:	1.12

ECM-1 Add Attic Insulation - Cost

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
Blown-In Attic Insulation (9" thick)	4,600	SF	\$ 0.470	\$ 0.330	\$ 0.130	\$ 2,220	\$ 1,891	\$ 672	\$ 4,784	RS Means
						\$ -	\$ -	\$ -	\$ -	

Note: Cost estimates are for energy savings calculations only, do not use for procurement

\$ 4,784	Subtotal
\$ 1,196	25% Contingency
\$ 5,980	Total

William Paterson University - Campus Police Department
CHA Project Numer: 28661
Campus Police Department

ECM-2A Replace DX Cooling and Electric Heaters with Heat Pumps

This measure evaluates replacing the two DX cooling units and electric heaters with individual Packaged Terminal Heat Pumps (PTHPs) having occupancy controls

Cooling Savings

ASSUMPTIONS			Comments	
Electric Cost	\$0.148	/ kWh		
Space Balance Point	55	F		
Space Temperature Setpoint	72	deg F	setpoint	
BTU / Hr Rating of Existing DXs	120,000	Btu / Hr	Total Cooling BTU/H of split systems	
Average EER	10.0		Nameplate	

Item	Value	Units	Comments
Total Number of Units	2		
Existing Annual Electric Usage	22,734	kWh	
Proposed EER	12.5		Heat Pump
Proposed Annual Electric Usage	18,187	kWh	Unit will cycle on w/ temp of room. Possible operating time shown below

Heating Savings

ASSUMPTIONS			Comments	
Electric Cost	\$0.148	/ kWh		
Space Balance Point	55	F		
Space Temperature Setpoint	72	deg F	setpoint	
kW Rating of Existing Electric Heaters	10	kW	Estimated	

Item	Value	Units	Comments
Total Number of Units	10		
Existing Annual Electric Usage	38,941	kWh	
Proposed Heating EER	12.5		Heat Pump with Supplemental Heat
Proposed Annual Electric Usage	18,418	kWh	Unit will cycle on w/ temp of room. Possible operating time shown below

ANNUAL SAVINGS		
Annual Electric Savings	25,070	kWh
Annual Cost Savings	\$3,710	

OAT - DB Bin Temp F	Enthalpy	Annual Hours	Assumed % of time of operation	Assumed hrs of Cooling Operation	Assumed % of time of operation	Assumed hrs of Heating Operation
102.5	0	0	100%	0	0%	0
97.5	35	6	89%	5	0%	0
92.5	37	31	79%	24	0%	0
87.5	35	131	68%	90	0%	0
82.5	33	500	58%	289	0%	0
77.5	32	620	47%	294	0%	0
72.5	30	664	37%	245	0%	0
67.5	27	854	0%	0	0%	0
62.5	24	927	0%	0	50%	464
57.5	20	600	0%	0	54%	325
52.5	18	730	0%	0	58%	426
47.5	16	491	0%	0	63%	307
42.5	15	656	0%	0	67%	437
37.5	13	1023	0%	0	71%	725
32.5	10	734	0%	0	75%	551
27.5	9	334	0%	0	79%	264
22.5	7	252	0%	0	83%	210
17.5	5	125	0%	0	88%	109
12.5	4	47	0%	0	92%	43
7.5	2	34	0%	0	96%	33
2.5	1	1	0%	0	100%	1
-2.5	0	0	0%	0	100%	0
-7.5	0	0	0%	0	100%	0
Total	374	8,760	11%	947	44%	3894

William Paterson University - Campus Police Department
CHA Project Numer: 28661
Campus Police Department

Multipliers	
Material:	1.03
Labor:	1.25
Equipment:	1.12

ECM-2B Replace DX Units Unit with High Efficiency DX Units - Cost

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
2 ton Heat Pmp	10	EA	\$ 1,250	\$ 1,000	\$ -	\$ 12,838	\$ 12,460	\$ -	\$ 25,298	Internet price Global
Wiring & Misc.	10	EA	\$ 500	\$ 500		\$ 5,135	\$ 6,230	\$ -	\$ 11,365	Estimated
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

\$ 36,663	Subtotal
\$ 9,166	25% Contingency
\$ 45,828	Total

William Paterson University - Campus Police Department
CHA Project Numer: 28661
Campus Police Department

ECM-2B Replace DX Units Unit with High Efficiency DX Units

This measure looks at replacing the two DX units for the AHUs with high efficiency DX units

Electric Savings

ASSUMPTIONS			Comments
Electric Cost	\$0.148	/ kWh	
Space Balance Point	55	F	
Space Temperature Setpoint	72	deg F	setpoint
BTU / Hr Rating of existing RTUs	120,000	Btu / Hr	Cooling BTU/H of One DX
Average EER	10.0		Derated to 10 due to age (Nameplate 11.2)

Item	Value	Units	Comments
Total Number of Units	2		
Existing Annual Electric Usage	22,734	kWh	
Proposed EER	12.5		New DX
Proposed Annual Electric Usage	18,187	kWh	Unit will cycle on w/ temp of room. Possible operati

ANNUAL SAVINGS		
Annual Electric Savings	4,547	kWh
Annual Cost Savings	\$673	

OAT - DB Bin Temp F	Annual Hours	Cooling Hrs at Temp Above balance point	Assumed % of time of operation	Assumed hrs of Cooling Operation
102.5	0	0	100%	0
97.5	35	6	89%	5
92.5	37	31	79%	24
87.5	35	131	68%	90
82.5	33	500	58%	289
77.5	32	620	47%	294
72.5	30	664	37%	245
67.5	27	854	0%	0
62.5	24	927	0%	0
57.5	20	600	0%	0
52.5	18	730	0%	0
47.5	16	491	0%	0
42.5	15	656	0%	0
37.5	13	1023	0%	0
32.5	10	734	0%	0
27.5	9	334	0%	0
22.5	7	252	0%	0
17.5	5	125	0%	0
12.5	4	47	0%	0
7.5	2	34	0%	0
2.5	1	1	0%	0
-2.5	0	0	0%	0
-7.5	0	0	0%	0

Total	374	8,760	11%	947
--------------	-----	-------	-----	-----

William Paterson University - Campus Police Department
CHA Project Numer: 28661
Campus Police Department

Multipliers	
Material:	1.03
Labor:	1.25
Equipment:	1.12

ECM-2B Replace DX Units Unit with High Efficiency DX Units - Cost

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
10 Ton DX HPs	2	EA	\$ 3,500	\$ 480	\$ -	\$ 7,189	\$ 1,196	\$ -	\$ 8,385	RS Means 2012
Wiring & Misc.	2	EA	\$ 500	\$ 1,000		\$ 1,027	\$ 2,492	\$ -	\$ 3,519	Estimated
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

\$ 11,904	Subtotal
\$ 2,976	25% Contingency
\$ 14,880	Total

William Paterson University - Campus Police Department
CHA Project Numer: 28661
Campus Police Department

ECM-3 Install Occupancy Sensors to control Electric Heaters

Description: This ECM evaluates the energy savings associated with installing thermostat controller with occupancy sensor to control the electric unit heaters in the spaces

Item	Value	Units	Formula/Comments
Electricity Rate	\$ 0.15	/kWh	
FORMULA CONSTANTS			
Heating Occupied %	80%		Estimated
HEATING			
Heating Capacity	10	kW	
Baseline Heating Efficiency	99%		
Existing Run Hours	3,894	hrs	Estimated
Proposed Run Hours	3,115	hrs	Estimated Based on School Hours
Heating Savings	7,788	kWh	
SAVINGS			
Electric Savings	7,788	kWh	
Cost Savings	\$ 1,153		

Savings calculation formulas are taken from NJ Protocols document for Electric HVAC Equipment

William Paterson University - Campus Police Department
CHA Project Numer: 28661
Campus Police Department

Multipliers	
Material:	1.03
Labor:	1.25
Equipment:	1.12

ECM-3 Install Occupancy Sensors to control Electric Heaters - Cost

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
Thermostat with Occupancy Sensors	10	EA	\$ 460	\$ 160	\$ -	\$ 4,724	\$ 1,994	\$ -	\$ 6,718	Internet Price
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

\$ 6,718	Subtotal
\$ 1,679	25% Contingency
\$ 8,397	Total

William Paterson University - Campus Police Department
CHA Project Numer: 28661
Campus Police Department

ECM: Replace urinals and flush valves with low flow

Description: This ECM evaluates the water savings associated with replacing/ upgrading urinals with 0.125 GPF urinals and or flush valves.

EXISTING CONDITIONS		
Cost of Water / 1000 Gallons	\$7.50	\$ / kGal
Urinals in Building to be replaced	1	
Average Flushes / Urinal (per Day)	10	
Average Gallons / Flush	1.5	Gal

PROPOSED CONDITIONS		
Proposed Urinals to be Replaced	1	
Proposed Gallons / Flush	0.125	Gal
Proposed Material Cost of new urinal & valve	\$1,200	RS Means 2012
Proposed Installation Cost of new urinal & valve	\$1,000	RS Means 2012
Total cost of new urinals & valves		

SAVINGS		
Current Urinal Water Use	5.48	kGal / year
Proposed Urinal Water Use	0.46	kGal / year
Water Savings	5.02	kGal / year
Cost Savings	\$38	/ year

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

William Paterson University - Campus Police Department
CHA Project Numer: 28661
Campus Police Department

ECM: Replace toilets and flush valves with low flow

Description: This ECM evaluates the water savings associated with repalcing/
upgrading toilets to 1.28 GPF fixtures and/or flush valves.

EXISTING CONDITIONS		
Cost of Water / 1000 Gallons	\$7.50	\$ / kGal
Toilets in Building	3	
Average Flushes / Toilet (per Day)	5	
Average Gallons / Flush	3.5	Gal

PROPOSED CONDITIONS		
Proposed Toilets to be Replaced	3	
Proposed Gallons / Flush	1.28	Gal

SAVINGS		
Current Toilet Water Use	19.16	kGal / year
Proposed Toilet Water Use	7.01	kGal / year
Water Savings	12.15	kGal / year
Cost Savings	\$91	/ year

William Paterson University - Campus Police Department
CHA Project Numer: 28661
Campus Police Department

ECM: Replace faucets with low flow

Description; This ECM evaluates the water savings resulting from replacing/ upgrading faucets to 0.5 gallon per minute flow

EXISTING CONDITIONS		
Cost of Water / 1000 Gallons	\$7.50	\$ / kGal
Faucets in Building	3	
Average Uses / Faucet (per day)	8	# Uses
Average Time of Use	30	seconds
Average Flowrate	2.0	gpm

PROPOSED CONDITIONS		
Proposed Faucets to be Replaced	3	
Proposed Flowrate	0.5	gpm

HEATING SAVINGS		
Fuel Cost	\$ 0.15	/kWh
Number of Faucets	3	
Hours per Day of Usage	0.067	hrs
Days per Year of Facility Usage	230	days
Average Flowrate	2.0	gpm
Proposed Flowrate	0.5	gpm
Heat Content of Water	8.33	Btu/gal/F
Temperature Difference (Intake and Output)	35	F
Water Heating Equipment Efficiency	95%	
Conversion Factor	3,413	btu/kWh

SAVINGS		
Current Faucet Water Use	5.52	kGal / year
Proposed Faucet Water Use	1.38	kGal / year
Water Savings	4.14	kGal / year
Heating Savings	372	kWh
Cost Savings	\$86	/ year

Savings calculation formulas are taken from NJ Protocols document for Faucet

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

William Paterson University - Campus Police Department

CHA Project Numer: 28661
Campus Police Department

Multipliers	
Material:	1.03
Labor:	1.25
Equipment:	1.12

ECM-4 Replace High Flow Plumbing Fixtures with Low Flow Plumbing Fixtures - Cost

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
									\$ -	
Low-Flow Urinal	1	EA	\$ 1,200	\$ 1,000	\$ -	\$ 1,232	\$ 1,246	\$ -	\$ 2,478	Vendor Estimate
Low-Flow Toilet	3	EA	\$ 1,400	\$ 1,000	\$ -	\$ 4,313	\$ 3,738	\$ -	\$ 8,051	Vendor Estimate
Low-Flow Faucet	3	EA	\$ 700	\$ 300	\$ -	\$ 2,157	\$ 1,121	\$ -	\$ 3,278	Vendor Estimate
						\$ -	\$ -	\$ -	\$ -	

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

\$ 13,808	Subtotal
\$ 3,452	25% Contingency
\$ 17,260	Total

William Paterson University - Campus Police Department
CHA Project Numer: 28661
Campus Police Department

New Jersey Pay For Performance Incentive Program

Note: The following calculation is based on the New Jersey Pay For Performance Incentive Program per April, 2012. Building must have a minimum average electric demand of 100 kW. This minimum is waived for buildings owned by local governments or non-profit organizations. At a minimum, all recommended measures were used for this calculation. To qualify for P4P incentives, the following P4P requirements must be met:

- At least 15% source energy savings
- No more than 50% savings from lighting measures
- Scope includes more than one measure
- Project has at least a 10% internal rate of return
- At least 50% of the source energy savings must come from investor-owned electricity and/or natural gas (note: exemption for fuel conversions)

Total Building Area (Square Feet)		4,600	
Is this audit funded by NJ BPU (Y/N)		Yes	
Board of Public Utilites (BPU)			
	Annual Utilities		
	kWh	Therms	
Existing Cost (from utility)	\$28,771	\$0	
Existing Usage (from utility)	194,010	0	
Proposed Savings	62,641	0	
Existing Total MMBtus	662		
Proposed Savings MMBtus	214		
% Energy Reduction	32.3%		
Proposed Annual Savings	\$9,879		

	Min (Savings = 15%)		Increase (Savings > 15%)		Max Incentive		Achieved Incentive	
	\$/kWh	\$/therm	\$/kWh	\$/therm	\$/kWh	\$/therm	\$/kWh	\$/therm
Incentive #2	\$0.09	\$0.90	\$0.005	\$0.05	\$0.11	\$1.25	\$0.11	\$1.25
Incentive #3	\$0.09	\$0.90	\$0.005	\$0.05	\$0.11	\$1.25	\$0.11	\$1.25

	Incentives \$		
	Elec	Gas	Total
Incentive #1	\$0	\$0	\$5,000
Incentive #2	\$6,890	\$0	\$6,890
Incentive #3	\$6,890	\$0	\$6,890
Total All Incentives	\$13,781	\$0	\$18,781

Total Project Cost	\$106,501
--------------------	-----------

	Allowable Incentive	
% Incentives #1 of Utility Cost*	17.4%	\$5,000
% Incentives #2 of Project Cost**	6.5%	\$6,890
% Incentives #3 of Project Cost**	6.5%	\$6,890
Total Eligible Incentives***	\$18,781	
Project Cost w/ Incentives	\$87,720	

Project Payback (years)	
w/o Incentives	w/ Incentives
10.8	8.9

* Maximum allowable incentive is 50% of annual utility cost if not funded by NJ BPU, and %25 if it is.

** Maximum allowable amount of Incentive #2 is 25% of total project cost.

Maximum allowable amount of Incentive #3 is 25% of total project cost.

*** Maximum allowable amount of Incentive #1 is \$50,000 if not funded by NJ BPU, and \$25,000 if it is.

Maximum allowable amount of Incentive #2 & #3 is \$1 million per gas account and \$1 million per electric account; maximum 2 million per project

Page 2, ECM-L1

Page 3, ECM-L2

		EXISTING CONDITIONS									RETROFIT CONDITIONS										COST & SAVINGS ANALYSIS						
Area Description		No. of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/Space	Exist Control	Annual Hours	Annual kWh		Standard Fixture Code	Fixture Code	Watts per Fixture	kW/Space	Retrofit Control	Annual Hours	Annual kWh	Annual kWh Saved	Annual kW Saved	Annual \$ Saved	Retrofit Cost	NJ Smart Start	Simple Payback				
Field Code	Unique description of the location - Room number/Room name: Floor number (if applicable)	No. of fixtures before the retrofit	Lighting Fixture Code	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Fixt No.)	Pre-inst. control device	Estimated daily hours for the usage group	(kW/Space) * (Annual Hours)	No. of fixtures after the retrofit	Lighting Fixture Code	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(kW/Space) * (Number of Fixtures)	Retrofit control device	Estimated annual hours for the usage group	(kW/Space) * (Annual Hours)	(Original Annual kWh) - (Retrofit Annual kWh)	(Original Annual kW) - (Retrofit Annual kW)	(kWh Saved) * (\$/kWh)	Cost for renovations to lighting system	Prescriptive Lighting Measures	Length of time for renovations cost to be recovered	Simple Payback			
35LED	Foyer 101	2	T 32 R F 3 (ELE)	F43ILL2	90	0.2	SW	8736	1,572	2	T 59 R LED	RTLED38	38	0.1	NONE	8,736	664	909	0.1	\$ 142.99	\$ 472.50	\$ -	3.3	3.3			
5LED	Corridor 100	5	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.3	SW	8736	2,621	5	2T XX R LED	2RTLLED	25	0.1	NONE	8,736	1,092	1,529	0.2	\$ 240.61	\$ 1,012.50	\$ 250	4.2	3.2			
5LED	Radio Room 102	6	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.4	SW	4368	1,572	6	2T XX R LED	2RTLLED	25	0.2	NONE	4,368	655	917	0.2	\$ 159.40	\$ 1,215.00	\$ 300	7.6	5.7			
5LED	Mechanical Room 103	2	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.1	SW	8736	1,048	2	2T XX R LED	2RTLLED	25	0.1	NONE	8,736	437	612	0.1	\$ 96.25	\$ 405.00	\$ 100	4.2	3.2			
5LED	Women's Locker Room 104	2	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.1	SW	2800	336	2	2T XX R LED	2RTLLED	25	0.1	C-CCC	2,000	100	236	0.1	\$ 43.30	\$ 675.00	\$ 135	15.6	12.5			
5LED	Custodial 105	1	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.1	SW	4368	262	1	2T XX R LED	2RTLLED	25	0.0	C-CCC	3,494	87	175	0.0	\$ 29.65	\$ 472.50	\$ 85	15.9	13.1			
5LED	Men's Room 106A	2	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.1	SW	4368	524	2	2T XX R LED	2RTLLED	25	0.1	C-CCC	4,368	218	306	0.1	\$ 53.13	\$ 675.00	\$ 135	12.7	10.2			
5LED	Men's Locker Room 106	7	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.4	SW	2800	1,176	7	2T XX R LED	2RTLLED	25	0.2	C-CCC	2,000	350	826	0.2	\$ 151.54	\$ 1,687.50	\$ 385	11.1	8.6			
5LED	Storage 107	2	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.1	SW	4368	524	2	2T XX R LED	2RTLLED	25	0.1	C-CCC	3,494	175	349	0.1	\$ 59.29	\$ 675.00	\$ 135	11.4	9.1			
5LED	Corridor 100A	2	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.1	SW	8736	1,048	2	2T XX R LED	2RTLLED	25	0.1	NONE	8,736	437	612	0.1	\$ 96.25	\$ 405.00	\$ 100	4.2	3.2			
36	Bathroom 110	1	2T 3' 17 R F 1 (ELE)	F21ILL	20	0.0	SW	4368	87	1	2T 3' 17 R F 1 (ELE)	F21ILL	20	0.0	C-CCC	4,368	87	-	0.0	\$ -	\$ 270.00	\$ 35					
5LED	Storage 108	1	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.1	SW	4368	262	1	2T XX R LED	2RTLLED	25	0.0	C-CCC	3,494	87	175	0.0	\$ 29.65	\$ 472.50	\$ 85	15.9	13.1			
5LED	Lounge 109	6	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.4	SW	4368	1,572	6	2T XX R LED	2RTLLED	25	0.2	C-CCC	3,494	524	1,048	0.2	\$ 177.88	\$ 1,485.00	\$ 335	8.3	6.5			
5LED	Interrogation Room 210	4	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.2	SW	4368	1,048	4	2T XX R LED	2RTLLED	25	0.1	NONE	4,368	437	612	0.1	\$ 106.27	\$ 810.00	\$ 200	7.6	5.7			
5LED	Office 201	2	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.1	SW	4368	524	2	2T XX R LED	2RTLLED	25	0.1	C-CCC	3,494	175	349	0.1	\$ 59.29	\$ 675.00	\$ 135	11.4	9.1			
5LED	Office 202	4	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.2	SW	4368	1,048	4	2T XX R LED	2RTLLED	25	0.1	C-CCC	3,494	349	699	0.1	\$ 116.58	\$ 1,080.00	\$ 235	9.1	7.1			
5LED	Office 203	2	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.1	SW	4368	524	2	2T XX R LED	2RTLLED	25	0.1	C-CCC	3,494	175	349	0.1	\$ 59.29	\$ 675.00	\$ 135	11.4	9.1			
5LED	Office 204	6	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.4	SW	4368	1,572	6	2T XX R LED	2RTLLED	25	0.2	C-CCC	3,494	524	1,048	0.2	\$ 177.88	\$ 1,485.00	\$ 335	8.3	6.5			
5LED	Office 204A	1	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.1	SW	4368	262	1	2T XX R LED	2RTLLED	25	0.0	C-CCC	3,494	87	175	0.0	\$ 29.65	\$ 472.50	\$ 85	15.9	13.1			
5LED	Office 204B	1	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.1	SW	4368	262	1	2T XX R LED	2RTLLED	25	0.0	C-CCC	3,494	87	175	0.0	\$ 29.65	\$ 472.50	\$ 85	15.9	13.1			
36	Office 204C	1	2T 3' 17 R F 1 (ELE)	F21ILL	20	0.0	SW	4368	87	1	2T 3' 17 R F 1 (ELE)	F21ILL	20	0.0	C-CCC	4,368	87	-	0.0	\$ -	\$ 270.00	\$ 35					
5LED	Foyer 205	2	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.1	SW	8736	1,048	2	2T XX R LED	2RTLLED	25	0.1	NONE	8,736	437	612	0.1	\$ 96.25	\$ 405.00	\$ 100	4.2	3.2			
5LED	Office 206	14	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.8	SW	4368	3,669	14	2T XX R LED	2RTLLED	25	0.4	C-CCC	3,494	1,223	2,446	0.5	\$ 415.05	\$ 3,105.00	\$ 735	7.5	5.7			
5LED	Office 207	9	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.5	SW	4368	2,359	9	2T XX R LED	2RTLLED	25	0.2	C-CCC	3,494	786	1,572	0.3	\$ 266.82	\$ 2,092.50	\$ 485	7.8	6.0			
5LED	Office 208	9	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.5	SW	4368	2,359	9	2T XX R LED	2RTLLED	25	0.2	C-CCC	3,494	786	1,572	0.3	\$ 266.82	\$ 2,092.50	\$ 485	7.8	6.0			
5LED	Office 209	9	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.5	SW	4368	2,359	9	2T XX R LED	2RTLLED	25	0.2	C-CCC	3,494	786	1,572	0.3	\$ 266.82	\$ 2,092.50	\$ 485	7.8	6.0			
227LED	Outdoor	8	70 W MH Wall Pack	MH70V1	95	0.8		4368	3,320	8	FXLED18	FXLED18/1	18	0.1	0	4,368	629	2,691	0.6	\$ 467.57	\$ 3,385.80	\$ 800	7.2	5.5			
															0	#N/A								#VALUE!			
															0	#N/A									#VALUE!		
															0	#N/A									#VALUE!		
															0	#N/A									#VALUE!		
S	Total	8				6.9			33,049	111				2.7			11,484		4.2	3,640	29,036	\$6,415					
S																		Demand Savings	4.2	\$599							
S																		kWh Savings	21,565	\$3,041							
S																		Total Savings		\$3,640		8.0	6.2				

APPENDIX D

New Jersey Board of Public Utilities Incentives

- i. Smart Start**
 - ii. Direct Install**
 - iii. Pay for Performance (P4P)**
 - iv. Energy Savings Improvement Plan (ESIP)**
-

I. SMART START



Your Power to Save

At Home, for Business, and for the Future

[About Us](#) | [Press Room](#) | [Library](#)

HOME

RESIDENTIAL

COMMERCIAL, INDUSTRIAL
AND LOCAL GOVERNMENT



[Home](#) » [Commercial & Industrial](#) » [Programs](#)

NJ SmartStart Buildings

Program Overview

COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

HURRICANE SANDY

PROGRAMS

NJ SMARTSTART BUILDINGS

EQUIPMENT INCENTIVES

FOOD SERVICE EQUIPMENT

APPLICATION FORMS

TOOLS AND RESOURCES

PAY FOR PERFORMANCE

COMBINED HEAT & POWER AND
FUEL CELLS

LOCAL GOVERNMENT ENERGY
AUDIT

LARGE ENERGY USERS PROGRAM

ENERGY SAVINGS IMPROVEMENT
PROGRAM

DIRECT INSTALL

ENERGY BENCHMARKING

OIL, PROPANE & MUNICIPAL
ELECTRIC CUSTOMERS

EDA PROGRAMS

SBC CREDIT PROGRAM



With New Jersey SmartStart Buildings ...

... A smart start now means better performance later! Whether you're starting a commercial or industrial project from the ground up, renovating existing space, or upgrading equipment, there are unique opportunities to upgrade the energy efficiency of the project.

Special Notice

Enhanced incentives are available for NJ SmartStart Building upgrades in buildings impacted by Hurricane Sandy. Eligible projects receive an additional 50% and new incentives have been added for high efficiency food service equipment.

Visit the Sandy web page for details and important links.

New Jersey SmartStart Buildings can provide a range of support — at no cost to you — for substantial energy savings, both now and for the future. Learn more about:

[Project Categories](#)

[Custom Measures](#)

[Incentives for Qualifying Equipment and Projects](#)

[Program Terms and Conditions](#)

[Find a Trade Ally](#)

Please note: pre-approval is required for almost all energy efficiency incentives. To receive an incentive, you must submit an application form (and applicable worksheets) and receive an approval letter from the program before any equipment is installed (click here for complete Terms and Conditions). Upon receipt of an approval letter, you may proceed to install the equipment listed on your approved application. Equipment installed prior to the date of the approval letter is not eligible for an incentive. **Any customer and/or agent who purchases equipment prior to the receipt of an incentive approval letter does so at his/her own risk.**

Getting Started

Submit your project application form as soon as you know you will be doing a construction project or replacing/adding equipment.

PAST PROGRAMS**TOOLS AND RESOURCES****PROGRAM UPDATES****CONTACT US**

Apply for pre-approval by submitting an application for the type of equipment you have or plan to install. The application should be accompanied by a related worksheet, where applicable, manufacturer's specification sheet (refer to the specific program requirements on the background application for specs needed for your project) for the equipment you are planning to install. (Program representatives will review your application package and approve it, reject it, or advise you of upgrades in equipment that will save energy costs and/or increase your incentive.)

Support for Custom Energy-Efficiency Measures

Custom measures allows program participants the opportunity to receive an incentive for energy-efficiency measures that are not on the prescriptive equipment Incentive list, but are project/facility specific.

Incentives for Qualifying Equipment and Projects

Financial incentives are available for large and small projects. These incentives offset some or maybe even all! — of the added cost to purchase qualifying energy-efficient equipment, and provides significant long-term energy savings. Ranges of incentives are available for qualifying equipment (depending on type, size, and efficiency) in several categories.

Find out more about equipment incentives

For specific details on equipment requirements and financial incentives, including incentives for equipment not listed here, contact a program representative. Fiscal year financial incentives will be limited to a maximum of \$500,000 per customer utility account and are available as long as permits are obtained.

[Home](#) | [Residential](#) | [Commercial & Industrial](#) | [Renewable Energy](#)
[About Us](#) | [Press Room](#) | [Library](#) | [FAQs](#) | [Calendar](#) | [Newsletters](#) | [Contact Us](#) | [Site](#)



Your Power to Save

At Home, for Business, and for the Future

[About Us](#) | [Press Room](#) | [Library](#)

HOME

RESIDENTIAL

COMMERCIAL, INDUSTRIAL
AND LOCAL GOVERNMENT



COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

HURRICANE SANDY

PROGRAMS

NJ SMARTSTART BUILDINGS

EQUIPMENT INCENTIVES

FOOD SERVICE EQUIPMENT

APPLICATION FORMS

TOOLS AND RESOURCES

PAY FOR PERFORMANCE

COMBINED HEAT & POWER AND
FUEL CELLS

LOCAL GOVERNMENT ENERGY
AUDIT

LARGE ENERGY USERS PROGRAM

ENERGY SAVINGS IMPROVEMENT
PROGRAM

DIRECT INSTALL

ENERGY BENCHMARKING

OIL, PROPANE & MUNICIPAL
ELECTRIC CUSTOMERS

EDA PROGRAMS

SBC CREDIT PROGRAM

[Home](#) » [Commercial & Industrial](#) » [Programs](#) » [NJ SmartStart Buildings](#)

Equipment Incentives

Special Notice

Enhanced incentives are available for NJ SmartStart Building upgrades in buildings impacted by Hurricane Sandy. Eligible projects receive an additional 50% and new incentives have been added for high efficiency food service equipment.

Visit the Sandy web page for details and important links.

More reasons for a smart start on your next project!

New Jersey SmartStart Buildings provides **financial incentives for qualifying equipment**. These incentives were developed to help our customers offset some of the added cost to purchase qualifying energy-efficient equipment, which provides significant long-term energy savings. A wide range of incentives are available for qualifying equipment (depending on type, size and efficiency).

Listed below are the types of qualifying equipment and ranges of incentives. For details on equipment requirements and full listings of incentives, refer to the **online application forms**.

Please note that almost all equipment incentives require pre-approval before equipment is installed. (click for exceptions) To start the pre-approval process, submit an Equipment Application, and appropriate Equipment Worksheets, for the type of equipment you are planning to install along with equipment specification sheets (refer to the specific program requirements on the back of the application for specific information needed for your project) and a current utility bill(s).

In order to be eligible to receive financial incentives under this Program, Applicants must receive electric and/or gas service from one of the regulated electric and/or gas utilities in the State of New Jersey. They are: Atlantic City Electric, Jersey Central Power & Light, Rockland Electric Company, New Jersey Natural Gas, Elizabethtown Gas, PSE&G, and South Jersey Gas.



Electric Chillers

Water-cooled chillers (\$12 - \$170 per ton)
Air-cooled chillers (\$8 - \$52 per ton)

Gas Cooling

Gas absorption chillers (\$185-\$450 per ton)
Gas Engine-Driven Chillers (Calculated through Custom Measure F

PAST PROGRAMS**TOOLS AND RESOURCES****PROGRAM UPDATES****CONTACT US****Desiccant Systems** (\$1.00 per cfm - gas or electric)**Electric Unitary HVAC**

Unitary AC and split systems (\$73 - \$92 per ton)
 Air-to-air heat pumps (\$73 - \$92 per ton)
 Water-source heat pumps (\$81 per ton)
 Packaged terminal AC & HP (\$65 per ton)
 Central DX AC Systems (\$40 - \$72 per ton)
 Dual Enthalpy Economizer Controls (\$250)
 Occupancy Controlled Thermostats (\$75 each)
 A/C Economizing Controls (\$85 - \$170 each)

Ground Source Heat Pumps

Closed Loop (\$450-750 per ton)

Gas Heating

Gas-fired boilers < 300 MBH (\$300 per unit)
 Gas-fired boilers ≥ 300 MBH - 1500 MBH (\$1.75 per MBH)
 Gas-fired boilers ≥ 1500 MBH - ≤ 4000 MBH (\$1.00 per MBH)
 Gas-fired boilers > 4000 MBH (Calculated through Custom Measure)
 Gas furnaces (\$300-\$400 per unit)
 Gas infrared heaters - indoor only (\$300 - \$500 per unit)
 Boiler economizing controls (\$1,200 - \$2,700 per unit)

Variable Frequency Drives

Variable air volume (\$65 - \$155 per hp)
 Chilled-water pumps (\$60 per hp)
 Compressors (\$5,250 to \$12,500 per drive)

Natural Gas Water Heating

Gas water heaters ≤ 50 gallons (\$50 per unit)
 Gas-fired water heaters > 50 gallons (\$1.00 - \$2.00 per MBH)
 Tankless water heaters replacing a free standing water heater > 82 energy factor (\$300 per heater)
 Gas-fired booster water heaters (\$17 - \$35 per MBH)

Premium Motors

Three-phase motors (\$45 - \$700 per motor) (**Incentive was discontinued effective March 1, 2013 except for buildings impacted by Hurricane Sandy. Approved applications will have the standard timeframe from the program commitment date to complete the installation.**)

Refrigerator/Freezer Case Premium Efficiency Motors (ECM)

Fractional (< 1 HP) Electronic Commutated Motors (ECM) (\$40 per for replacement of existing shaded-pole motor in refrigerated/freezer case)

Prescriptive Lighting

New Linear Fluorescent

T-12, HID and Incandescent to T-5 and T-8 (\$25 - \$200 per fixture) (**Note: T12 replacements are only available for buildings impacted by Hurricane Sandy**)

New Induction (\$70 per replaced HID fixture)

New LED

Screw-in/Plug-in (\$10 - \$20 per lamp)

Refrigerator/Freezer Case (\$30 - \$65 per fixture)

Outdoor pole/arm/wall-mounted luminaires (\$100 - \$175 per fixture)

Display case (\$30 per case)

Shelf-mounted display and task (\$15 per linear foot)

Wall-wash, desk, recessed (\$20 - \$35 per fixture)

Parking garage luminaires (\$100 per fixture)

Track or Mono-Point directional (\$50 per fixture)

Stairwell and Passageway luminaires (\$40 per fixture)

High-Bay, Low-Bay (\$150 per fixture)

Bollard (\$50 per fixture)

Luminaires for Ambient Lighting of Interior Commercial Space
Linear panels (\$50 per fixture)

Fuel pump canopy (\$100 per fixture)

LED retrofit kits (custom measures)

New Pulse-Start Metal Halide (\$25 per fixture)

Linear Fluorescent Retrofit (\$10 - \$20 per fixture)

Induction Retrofit (\$50 per retrofitted HID fixture)

New Construction/Complete Renovation (performance-based)

Note: Incentives for T-12 to T-5 and T-8 lamps with electronic ballast in facilities (\$10 per fixture, 1-4 lamps) and T-5/T-8 high bay fixtures (\$16 - per fixture) were discontinued effective March 1, 2013 for T-12 retrofits replacements except for buildings impacted by Hurricane Sandy. Approved applications will have the standard timeframe of one year from the project commitment date to complete the installation

Lighting Controls

Occupancy Sensors

Wall mounted (\$20 per control)

Remote mounted (\$35 per control)

Daylight dimmers (\$25 per fixture controlled, \$50 per fixture for office applications only)

Occupancy controlled hi-low fluorescent controls (\$25 per fixture controlled)

HID or Fluorescent Hi-Bay Controls

Occupancy hi-low (\$35 per fixture controlled)

Daylight dimming (\$45 per fixture controlled)

Refrigeration

Covers and Doors

Energy-Efficient doors for open refrigerated doors/covers (\$100 per door)

Aluminum Night Curtains for open refrigerated cases (\$3.50 per linear foot)

Controls

Door Heater Control (\$50 per control)

Electric Defrost Control (\$50 per control)

Evaporator Fan Control (\$75 per control)

Novelty Cooler Shutoff (\$50 per control)

Food Service Equipment**Cooking**

Combination Electric Oven/Steamer (\$1,000 per oven)
 Combination Gas Oven/Steamer (\$750 per oven)
 Electric Convection Oven (\$350 per oven)
 Gas Convection Oven (\$500 per oven)
 Gas Rack Oven (\$1,000 single, \$2,000 double)
 Gas Conveyor Oven (\$500 small deck, \$750 large deck)
 Electric Fryer (\$200 per vat)
 Gas Fryer (\$749 per vat)
 Electric Large Vat Fryer (\$200 per vat)
 Gas Large Vat Fryer (\$500 per vat)
 Electric Griddle (\$300 per griddle)
 Gas Griddle (\$125 per griddle)
 Electric Steam Cooker (\$1,250 per steamer)
 Gas Steam Cooker (\$2,000 per steamer)

Holding

Full Size Insulated Cabinets (\$300 per cabinet)
 Three Quarter Size Insulated Cabinets (\$250 per cabinet)
 Half Size Insulated Cabinets (\$200 per cabinet)

Cooling

Glass Door Refrigerators (\$75 - \$150 per unit)
 Solid Door Refrigerators (\$50 - \$200 per unit)
 Glass Door Freezers (\$200 - \$1,000 per unit)
 Solid Door Freezers (\$100 - \$600 per unit)
 Ice Machines (\$50 - \$500 per unit)

Cleaning

Dishwashers (\$400 - \$1,500 per unit)

Other Equipment Incentives*

Performance Lighting (\$1.00 per watt per square foot below program incentive threshold, currently 5% more energy efficient than ASHRAE 2007 for New Construction only.)

Custom electric and gas equipment incentives (not prescriptive)

*Equipment incentives are calculated based on type, efficiency, size, and application and are evaluated on a case-by-case basis. Contact us for details.

[Home](#) | [Residential](#) | [Commercial & Industrial](#) | [Renewable Energy](#)
[About Us](#) | [Press Room](#) | [Library](#) | [FAQs](#) | [Calendar](#) | [Newsletters](#) | [Contact Us](#) | [Site](#)

II. DIRECT INSTALL



Your Power to Save

At Home, for Business, and for the Future

[About Us](#) | [Press Room](#) | [Library](#)

HOME

RESIDENTIAL

COMMERCIAL, INDUSTRIAL
AND LOCAL GOVERNMENT

Home » Commercial & Industrial » Programs

Direct Install

COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

HURRICANE SANDY

PROGRAMS

NJ SMARTSTART BUILDINGS

PAY FOR PERFORMANCE

COMBINED HEAT & POWER AND
FUEL CELLSLOCAL GOVERNMENT ENERGY
AUDIT

LARGE ENERGY USERS PROGRAM

ENERGY SAVINGS IMPROVEMENT
PROGRAM

DIRECT INSTALL

PARTICIPATION STEPS

PARTICIPATING
CONTRACTORS

SUSTAINABLE JERSEY

ENERGY BENCHMARKING

OIL, PROPANE & MUNICIPAL
ELECTRIC CUSTOMERS

EDA PROGRAMS

SBC CREDIT PROGRAM

NEW JERSEY'S CLEAN ENERGY PROGRAM

DIRECT Install

Let us pay up to 70% of your energy efficiency upgrade.

Sometimes, the biggest challenge to improving energy efficiency is knowing where to and how to get through the process. Created specifically for existing small to medium facilities, Direct Install is a turnkey solution that makes it easy and affordable to upgrade high efficiency equipment. Direct Install is designed to cut your facility's energy costs replacing lighting, HVAC and other outdated operational equipment with energy efficient alternatives. The program pays up to 70% of retrofit costs, dramatically improving your payback on the project. There is a \$125,000 incentive cap on each project.

ELIGIBILITY



Existing small to mid-sized commercial and industrial facilities with a peak electric demand that did not exceed 200 kW any of the preceding 12 months are eligible to participate in Direct Install. Applicants will submit the last 12 months of electric utility bills indicating that they are below the demand threshold and have occupied the building during that time. Buildings must be located in New Jersey and served by the state's public, regulated electric or natural gas utility companies.

SYSTEMS & EQUIPMENT ADDRESSED BY THE PROGRAM

Lighting
Heating, Cooling & Ventilation (HVAC)
Refrigeration
Motors
Natural Gas
Variable Frequency Drives



Measures eligible for Direct Install are limited to specific equipment categories, types and capacities. Boilers may not exceed 500,000 Btuh and furnaces may not exceed 140,

III. PAY FOR PERFORMANCE (P4P)



Your Power to Save

At Home, for Business, and for the Future

[About Us](#) | [Press Room](#) | [Library](#)

HOME

RESIDENTIAL

COMMERCIAL, INDUSTRIAL
AND LOCAL GOVERNMENT

COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

HURRICANE SANDY

PROGRAMS

NJ SMARTSTART BUILDINGS

PAY FOR PERFORMANCE

EXISTING BUILDINGS

PARTICIPATION STEPS

APPLICATIONS AND
FORMS

APPROVED PARTNERS

NEW CONSTRUCTION

FAQS

BECOME A PARTNER

COMBINED HEAT & POWER AND
FUEL CELLSLOCAL GOVERNMENT ENERGY
AUDIT

LARGE ENERGY USERS PROGRAM

ENERGY SAVINGS IMPROVEMENT
PROGRAM

DIRECT INSTALL

ENERGY BENCHMARKING

[Home](#) » [Commercial & Industrial](#) » [Programs](#) » [Pay for Performance](#)

Pay for Performance - Existing Buildings

Download program applications and incentive forms.

The Greater the Savings, the Greater Your Incentives

Take a comprehensive, whole-building approach to saving energy in your existing facility. Earn incentives that are directly linked to your savings. Pay for Performance relies on a



program partners who provide technical services under direct contract to you. Acting as your energy expert, your partner will develop a whole-building energy reduction plan for each project with a whole-building technical component of a traditional energy audit, a financial plan for full implementation of energy efficient measures and a construction schedule for installation.

Eligibility

Existing commercial, industrial and institutional buildings with demand over 100 kW for any of the preceding twelve months to participate including hotels and casinos, large office buildings, family buildings, supermarkets, manufacturing facilities, schools, shopping malls and restaurants. Buildings that fall into the following customer classes are not required to meet the 100 kW demand threshold to participate in the program: hospitals, public colleges and universities, 501(c)(3) non-profit organizations, affordable multifamily housing, and local governmental entities. Your energy reduction plan will define a comprehensive package of measures capable of reducing the existing energy consumption of your building by 15% or more.

Exceptions to the 15% threshold requirement may be made for certain industrial, manufacturing, water treatment and datacenter building types whose annual energy consumption is heavily weighted on process loads. Details are available in the high energy intensity section of this page.

ENERGY STAR Portfolio Manager

Pay for Performance takes advantage of the ENERGY STAR Program with Portfolio Manager, EPA's interactive tool that allows facility managers to track and evaluate energy and water consumption across all of their buildings. The tool provides the opportunity to load in the characteristics and energy usage of your buildings and determine an energy performance benchmark score. You can then assess energy management goals over time, identify strategic opportunities for savings, and receive EPA recognition for superior energy performance.



This rating system assesses building performance by tracking and scoring energy use in your facilities and comparing it to similar buildings. That can be a big help in locating opportunities for cost-justified energy efficiency upgrades. And, based on our findings, you may be invited to participate in the Building Performance with ENERGY STAR initiative and receive special recognition as an industry leader in energy efficiency.

Incentives

**OIL, PROPANE & MUNICIPAL
ELECTRIC CUSTOMERS**

Pay for Performance incentives are awarded upon the satisfactory completion of three p milestones:

EDA PROGRAMS

Incentive #1 - Submittal of complete energy reduction plan prepared by an app program partner - Contingent on moving forward, incentives will be between \$5 \$50,000 based on approximately \$.10 per square foot, not to exceed 50% of th annual energy expense.

SBC CREDIT PROGRAM

Incentive #2 - Installation of recommended measures - Incentives are based on the projected level of electricity and natural gas savings resulting from the installation of comprehensive energy-efficiency measures.

PAST PROGRAMS

TOOLS AND RESOURCES

Incentive #3 - Completion of Post-Construction Benchmarking Report - A completed report verifying energy reductions based on one year of post-

PROGRAM UPDATES

implementation results. Incentives for electricity and natural gas savings will be based on actual savings, provided that the minimum performance threshold of savings has been achieved.

CONTACT US



A detailed Incentive Structure document is available on the applications and form

Steps to Participation

[Click here](#) for a step-by-step description of the program.

[Home](#) | [Residential](#) | [Commercial & Industrial](#) | [Renewable Energy](#)
[About Us](#) | [Press Room](#) | [Library](#) | [FAQs](#) | [Calendar](#) | [Newsletters](#) | [Contact Us](#) | [Site](#)



PAY FOR PERFORMANCE APPLICATION FORM

July 1, 2013 - June 30, 2014

Utility Serving Applicant: ☐ Atlantic City Electric ☐ Jersey Central Power & Light ☐ PSE&G
☐ New Jersey Natural Gas ☐ Elizabethtown Gas ☐ Rockland Electric Co. ☐ South Jersey Gas
☐ Other Electric Service Provider (please specify): _____
☐ Other Fuel Provider: _____ ☐ Oil: _____ ☐ Other (Please specify): _____

Instructions

1. Read the program material to determine project qualification.
2. Read the Participation Agreement and sign where indicated.
3. Fill out all applicable spaces on this form.
4. Provide a copy of the customer's company W-9 form.
5. Provide the most recent consecutive 12 month period of utility bills for the project.

6. Provide brief description of facility.
7. Partner must submit the application package via e-mail, mail or fax DIRECTLY to the Market Manager – see back of this form.

Approval of this Application is not an approval of the project's scope of work. Scope of work is only approved upon approval of the Energy Reduction Plan. See application and program guidelines for more information.

Customer/Owner Information (payment will be made to entity entered here)

Company Name		Project Contact/Title	
Company Address		City	State Zip
Phone/Fax	E-mail	Federal ID/SSN	

Partner Information

Company Name		Project Contact/Title	
Company Address		City	State Zip
Phone	Fax	E-mail	

Project Information

Project Name			
Building Address		City	State Zip
Utility Account Number(s): Electric		Gas	
* Note: Please use the back of this page for additional utility accounts if quantity exceeds space allotment.			
Annual Peak kW Demand	Building Type		Number of Buildings
Size of Building(s) (gross sq/ft)		Direct, Master or Sub Metered	

Funding

☐ Check the box if an Energy Savings Improvement Program (ESIP) will be a source of funding. ESIP allows government agencies to pay for energy related improvements using the value of the resulting energy savings.

Do you expect to receive funding under any other efficiency programs? ☐ No ☐ Yes If Yes, please specify below:

Utility Program #1 – Utility: _____	Program Name: _____
Utility Program #2 – Utility: _____	Program Name: _____
Federal Program #1 – Organization: _____	Program Name: _____
Federal Program #2 – Organization: _____	Program Name: _____
Other Program – Organization: _____	Program Name: _____

Additional Project information

Additional Utility Account(s)

Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number

Additional Comments:

Complete this application form and send it directly to the Commercial/Industrial Market Manager by e-mail, mail or fax.

New Jersey's Clean Energy Program
c/o TRC Energy Services-P4P
900 Route 9 North, Suite 404 • Woodbridge, NJ 07095

Phone: 866-657-6278 • Fax: 732-855-0422
E-mail: P4P@NJCleanEnergy.com

Visit our website: NJCleanEnergy.com/P4P

New Jersey SmartStart Buildings[®] is a registered trademark. Use of the mark without the permission of the New Jersey Board of Public Utilities, Office of Clean Energy is prohibited.

*Incentives/Requirements subject to change.



002-FY14-04/14

Pay For Performance-Existing Buildings

Participation Agreement

Definitions:

Design Incentives – Incentives that may be offered to design professionals by the Program.

Design Services – Services that may be offered to design professionals under the Program.

Energy-Efficient Measures – Any device eligible to receive a Program Incentive payment through the NJ Clean Energy Commercial and Industrial Program (New Jersey SmartStart Buildings).

New Jersey Utilities – The regulated electric and/or gas utilities in the State of New Jersey. They are: Atlantic City Electric, Jersey Central Power & Light, Rockland Electric Company, New Jersey Natural Gas, Elizabethtown Gas, PSE&G, and South Jersey Gas.

Administrator – New Jersey Board of Public Utilities, Office of Clean Energy

Participating Customers – Those non-residential electric and/or gas service customers of the New Jersey Utilities who participate in this Program.

Product Installation or Equipment Installation – Installation of the Energy-Efficient Measures.

Projects with a contract threshold of \$14,187 (increasing to \$15,444 effective July 1, 2014) are required to pay no less than prevailing wage rate to workers employed in the performance of any construction undertaken in connection with Board of Public Utilities financial assistance, or undertaken to fulfill any condition of receiving Board of Public Utilities financial assistance, including the performance of any contract to construct, renovate or otherwise prepare a facility, the operations of which are necessary for the receipt of Board of Public Utilities financial assistance. By submitting an application, or accepting program incentives, applicant agrees to adhere to New Jersey Prevailing Wage requirements, as applicable.

Program – The Commercial and Industrial Energy-Efficient Construction Program (New Jersey SmartStart Buildings) offered herein by the New Jersey Board of Public Utilities, Office of Clean Energy pursuant to state regulatory approval under the New Jersey Electric Discount and Energy Competition Act, NJSA 48:3-49, et seq.

Program Incentives – Refers to the amount or level of incentive that the Program provides to Participating Customers pursuant to the Program offered herein (see description under "Incentive Amount" heading).

Program Offer – Program Incentives are available to non-residential retail electric and/or gas service customers of the New Jersey Utilities identified above.

Program Manager – TRC Energy Services.

Application and Eligibility Process – The Program pays incentives after the installation of qualified energy-efficient

measures that were pre-approved (for exceptions to this condition, please refer to "Exceptions for Approval".) In order to be eligible for Program Incentives, a Customer, or an agent (contractor/vendor) authorized by a Customer, must submit a properly completed application package. The package must include an application signed by the customer; a complete (current) utility bill; and technology worksheet and manufacturer's cut sheets (where appropriate). This information must be submitted to the Program Manager before equipment is installed. Applications for measures that are self installed by customers must be submitted by the customer and not the sales vendor of the measure, however, the customer may elect to assign payment of the incentive to the sales vendor. This application package must be received by the Program Manager on or before June 30, 2014 in order to be eligible for the fiscal year July 1, 2013-June 30, 2014 incentives. The Program Manager will review the application package to determine if the project is eligible for a Program Incentive. If eligible, the Customer will receive an approval letter with the estimated authorized incentive amount and the date by which the equipment must be installed in order for the approval to remain in effect. Upon receipt of an approval letter, the Customer may then proceed to install the equipment listed on the approved application. Equipment installed prior to the date of the Program Manager's approval letter is not eligible for an incentive. The Program Manager reserves the right to conduct a pre-inspection of the facility prior to the installation of equipment. This will be done prior to the issuance of the approval letter. All equipment must be purchased within 12 months of date of application. **Any Customer and/or agent who purchases equipment prior to the receipt of an incentive approval letter does so at his/her own risk.**

Exceptions for Approval – The Application and Eligibility Process pertains to all projects except for those involving either Gas Heating, Unitary HVAC or Motors having an incentive amount less than \$5,000 that were installed within 12 months of receipt of the application. These measures, at this incentive level, may be installed without prior approval. In addition, but at the sole discretion of the Program Manager, emergency replacement of equipment may not require a prior approval determination and letter. **In such cases, please notify the Program Manager of such emergencies as early as possible, that an application will soon be sent in that was not pre-approved.**

Post-Installation Approval – After installation is completed, the Customer, or an agent authorized by the Customer, must finalize and submit an invoice for the purchase of the equipment (material cost must be broken out from labor costs), and any other required documentation as specified on the equipment application or in the Program Manager's initial approval letter.

Please refer to the program guide on the NJCleanEnergy.com/ssb website for the complete Application and Eligibility Process.

The Program Manager reserves the right to verify sales transactions and to have reasonable access to Participating Customer's facility to inspect both pre-existing product or equipment (if applicable) and the Energy-Efficient Measures

installed under this Program, either prior to issuing incentives or at a later time.

Energy-Efficient Measures must be installed in buildings located within a New Jersey Utilities' service territory and designated on the Participating Customer's incentive application. Program Incentives are available for qualified Energy-Efficient Measures as listed and described in the Program materials and incentive applications. The Participating Customer must ultimately own the equipment, either through an up-front purchase or at the end of a short-term lease. Design Incentives are available to design professionals as described in the Program materials and applications. A different and separate agreement must be executed by participating design professionals to be eligible for this type of incentive. The design professional does not need to be based in New Jersey.

Equipment procured by Participating Customers through another program offered by New Jersey's Clean Energy Program or the New Jersey Utilities, as applicable, is not eligible for incentives through this program. Customers who have not contributed to the Societal Benefits Charge of the applicable New Jersey Utility are not eligible for incentives offered through this program.

Incentive Amount – Program Incentives will equal either: a) the approved Program Incentive amount, or b) the actual equipment cost of the Energy-Efficient Measure, whichever is less, as determined by the Program Manager. Products offered at no direct cost to the customer are ineligible. Incomplete application submissions, applications requiring inspections and unanticipated high volume of activities may cause processing delays. Program Incentives are limited to \$500,000 per utility account in a calendar year. Contact the Program Manager regarding any questions.

Tax Liability – The Program Manager will not be responsible for any tax liability that may be imposed on any Participating Customer as a result of the payment of Program Incentives. All Participating Customers must supply their federal tax identification number or social security number to the Program Manager on the application form in order to receive a Program Incentive. In addition, Participating Customers must also provide a Tax Clearance Form (entitled "Business Assistance or Incentive Clearance Certificate") that is dated within 90 days of equipment installation.

Endorsement – The Program Manager and Administrator do not endorse, support or recommend any particular manufacturer, product or system design in promoting this Program.

Warranties – THE PROGRAM MANAGER AND ADMINISTRATOR DO NOT WARRANT THE PERFORMANCE OF INSTALLED EQUIPMENT, AND/OR SERVICES RENDERED AS PART OF THIS PROGRAM, EITHER EXPRESSLY OR IMPLICITLY. NO WARRANTIES OR REPRESENTATIONS OF ANY KIND, WHETHER STATUTORY, EXPRESSED, OR IMPLIED, INCLUDING, WITHOUT LIMITATIONS, WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE REGARDING EQUIPMENT OR SERVICES PROVIDED BY A MANUFACTURER OR VENDOR. CONTACT YOUR VENDOR/SERVICES PROVIDER FOR DETAILS REGARDING PERFORMANCE AND WARRANTIES.

Limitation of Liability – By virtue of participating in this Program, Participating Customers agree to waive any and all claims or damages against the Program Manager or the Administrator, except the receipt of the Program Incentive. Participating Customers agree that the Program Manager's and Administrator's liability, in connection with this Program, is limited to paying the Program Incentive specified. Under no circumstances shall the Program Manager, its representatives, or subcontractors, or the Administrator, be liable for any lost profits, special, punitive, consequential or incidental damages or for any other damages or claims connected with or resulting from participation in this Program. Further, any liability attributed to the Program Manager under this Program shall be individual, and not joint and/or several.

Assignment – The Participating Customer may assign Program Incentive payments to a specified vendor.

Participating Customer's Certification – Participating Customer certifies that he/she purchased and installed the equipment listed in their application at their defined New Jersey location. Participating Customer agrees that all information is true and that he/she has conformed to all of the Program and equipment requirements listed in the application.

Termination – The New Jersey Board of Public Utilities reserves the right to extend, modify (this includes modification of Program Incentive levels) or terminate this Program without prior or further notice.

Acknowledgement – I have read, understood and am in compliance with all rules and regulations concerning this incentive program. I certify that all information provided is correct to the best of my knowledge, and I give the Program Manager permission to share my records with the New Jersey Board of Public Utilities, and contractors it selects to manage, coordinate or evaluate the NJ SmartStart Buildings Program. Additionally, I allow reasonable access to my property to inspect the installation and performance of the technologies and installations that are eligible for incentives under the guidelines of New Jersey's Clean Energy Program.

CUSTOMER'S SIGNATURE
PARTNER SIGNATURE
By signing, I certify that I have read, understand and agree to the Participation Agreement listed above.

IV. ENERGY SAVINGS IMPROVEMENT PLAN (ESIP)



Your Power to Save

At Home, for Business, and for the Future

[About Us](#) | [Press Room](#) | [Library](#)

HOME

RESIDENTIAL

COMMERCIAL, INDUSTRIAL
AND LOCAL GOVERNMENT



COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

HURRICANE SANDY

PROGRAMS

NJ SMARTSTART BUILDINGS

PAY FOR PERFORMANCE

COMBINED HEAT & POWER AND
FUEL CELLS

LOCAL GOVERNMENT ENERGY
AUDIT

LARGE ENERGY USERS PROGRAM

ENERGY SAVINGS IMPROVEMENT
PROGRAM

DIRECT INSTALL

ENERGY BENCHMARKING

OIL, PROPANE & MUNICIPAL
ELECTRIC CUSTOMERS

EDA PROGRAMS

SBC CREDIT PROGRAM

PAST PROGRAMS

TOOLS AND RESOURCES

PROGRAM UPDATES

CONTACT US

[Home](#) » [Commercial & Industrial](#) » [Programs](#)

Energy Savings Improvement Program

A new State law allows government agencies to make energy related improvements to their facilities and pay for the costs using the value of energy savings that result from the improvements. Under Chapter 4 of the Laws of 2009 (the law), the "Energy Savings Improvement Program" (ESIP), provides all government agencies in New Jersey with a flexible tool to make improvements and reduce energy usage with minimal expenditure of new financial resources.

This Local Finance Notice outlines how local governments can develop and implement an ESIP at their facilities. Below are two sample RFPs:

Local Government
School Districts (K-12)

All RFPs must be submitted to the Board for approval at ESIP@bpu.state.nj.us.

The Board also adopted protocols to measure energy savings:

Measuring Energy Savings
Procedures for Implementation

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Local units should carefully consider all alternatives to develop an approach that best meets their needs. Local units considering an ESIP should carefully review the Local Finance Notice, the law, and consult with qualified professionals to determine how they should approach the task.

The NJ Board of Public Utilities sponsored Sustainable Jersey in the creation of an ESIP Guidebook that explains how to implement the program. The guidebook also includes a list of successful projects and a list of helpful resources.

FIRST STEP – ENERGY AUDIT

For local governments interested in pursuing an ESIP, the first step is to perform an energy audit as prescribed in P.L.2012 c.55.

ENERGY REDUCTION PLANS

If you have an ESIP plan that needs to be submitted to the Board of Public Utilities, please email it to ESIP@bpu.state.nj.us. Please limit the file size to 3MB (or break it into smaller files).

Frankford Township School District
Northern Hunterdon-Voorhees Regional High School
Manalapan Township (**180 MB** - [Right Click, Save As](#))

ESIP PROGRAM

Final version 42413

BPU RULES

1. Public Entity must decide if they will use an ESCO or DIY method or Hybrid thereof prior to issuing the RFP and the RFP must state the intended method. A change in the project procurement model after the RFP closing date will be cause for immediate rejection and disqualification of potential Clean Energy program incentives.
2. RFP procedures shall be adhered to as per the legislation, including the use of BPU approved forms. Any alteration of the forms, without prior approval from the BPU shall be grounds for rejection.
3. RFP must include copy of an audit (ASHRAE Level II w/Level III for lighting) and audit must be prepared by a firm classified by DPMC in the 036 discipline.
4. All firms, including professional services, whether using ESCO or DIY model, must be DPMC classified.
5. If an Architect is engaged by the public entity, the architectural fees are the responsibility of the public entity and must be paid directly to the firm. These fees may be included in the energy cost savings analysis and payback.

ESCO's may contract directly with an architectural firm, in which case the architectural firm serves as a subcontractor to the ESCO and the project related service costs may be included within the project's economic model.

6. Public entity shall conduct pre-bid meetings and site visits per existing statutes.

In the interest of open public bidding transparency, it is a requirement of the BPU that all proposers must attend the pre-proposal bid meeting.

7. There shall be no negative cash flow in any year of the program.
section 7 (1)(a)
"the energy savings resulting from the program will be sufficient to cover the cost of the program's energy conservation measures."
8. SREC values are not permitted to be used in the energy cost savings calculations.
9. Capital cost avoidance values are not to be used in the energy savings calculations.
10. Operational and Maintenance (O&M) cost savings may be permitted in the cost savings calculations, but only with supporting documentation.
11. Blended utility rates shall not be permitted. Use the actual utility tariff or local contracted rates if there is a third party supplier.

For the RFP proposals, the public entity shall define the utility rates in the RFP

12. Contracted third party utility rates may only be used for the term of the contract (5 yr. maximum)
Subsequent years are to be projected at the utility tariff rates plus the annual BPU escalation rates.
13. Public entity shall conduct M&V (measurement and verification) at the one (1) year operational date and shall provide a copy of the M&V report to the Board of Public Utilities.

For the RFP proposals, the ESCO shall provide the cost for the one (1) year M&V only. For comparative purposes, the one year M&V pricing shall be indicated on the proposal Form VI, under the “Annual Service Costs” column. Additional M&V costs are at the discretion of the local unit and are not to be included in the proposal.

14. The decisions made by BPU staff regarding compliance or other issues that arise in connection with the RFP procurement process shall be considered a final decision of the BPU. Any appeal will need to be through the New Jersey Superior Court, Appellate Division.
15. For the RFP proposals only, Demand Response (DR) revenues claimed by ESCO’s can only be projected for a maximum period of three (3) years. DR revenue projections beyond three years will not be permitted. DR revenues must be included and presented under the “Energy Rebates/Incentives” column of FORM VI.
16. ESCO “fees” proposed during the RFP phase of the project cannot increase post-award. ESCO’s are required to maintain the fee percentages through final contract negotiations and construction of the Board approved Energy Savings Plan
17. Public Bid openings shall be held on the due date of the proposal submissions. The public entity shall announce the name of the bidder and the total dollar amount. After award of a contract, all proposals received will be made available by the owner for public inspection
18. Rejection of bids by the public entity shall be conducted in accordance with the appropriate sections of the applicable legislation, as stated in Title 40A:11-13.2. Additionally all proposals must be returned to the respective ESCO’s upon rejection.
19. Field changes that exceed 5% of the project cost require BPU approval.
20. Energy Savings Plans (ESP) that is dependent upon incentives from the Clean Energy Program must review the current program requirements, at the time of application, for each incentive to insure eligibility. If any program incentive is denied, resubmission of all ESIP related forms will be necessary to remain ESIP qualified.

APPENDIX F

Photos

ECM-1 Add Attic Insulation



Existing Attic

ECM-2 Replace DX Cooling and Electric Heaters with Heat Pumps



Existing AHU in Attic

ECM-3 Replace the Two Old DX Unit with High Efficiency DXs



Existing DX Units

ECM-4 Install Occupancy Sensors to control electric Reheat Coils



Existing Unit Heater

ECM-5 Replace High Flow Plumbing Fixtures with Low Flow Plumbing Fixtures



Existing Plumbing Fixtures

ECM-L1 Lighting Replacement / Upgrades



Existing Lights

ECM-L2 Install Lighting Controls (Occupancy Sensors)

No Pictures Available

ECM-L3 Lighting Replacements with Controls (Occupancy Sensors)

See ECM L-1 and L-2

APPENDIX G

EPA Benchmarking Report



ENERGY STAR[®] Statement of Energy Performance

N/A

ENERGY STAR[®]
Score¹

Campus Police Department

Primary Property Function: College/University
Gross Floor Area (ft²): 4,600
Built: 1992

For Year Ending: January 31, 2014
Date Generated: July 19, 2014

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information

Property Address
Campus Police Department
300 Pompton Road
Wayne, New Jersey 07470

Property Owner

,
(____)____-____

Primary Contact

,
(____)____-____

Property ID: 4113325

Energy Consumption and Energy Use Intensity (EUI)

Site EUI	Annual Energy by Fuel	National Median Comparison	
143.9 kBtu/ft ²	Electric - Grid (kBtu) 661,962 (100%)	National Median Site EUI (kBtu/ft ²)	83.6
		National Median Source EUI (kBtu/ft ²)	262.6
		% Diff from National Median Source EUI	72%
Source EUI	Annual Emissions		
451.9 kBtu/ft ²	Greenhouse Gas Emissions (Metric Tons CO ₂ e/year)	84	

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: _____ Date: _____

Licensed Professional

,
(____)____-____



Professional Engineer Stamp
(if applicable)