THE NEWARK PUBLIC SCHOOLS

Group 3 Buildings

Sussex Ave School

307 Sussex Ave, Newark, NJ 07107

LOCAL GOVERNMENT ENERGY AUDIT PROGRAM FOR NEW JERSEY BOARD OF PUBLIC UTILITIES

April 2014

Prepared by:



6 Campus Drive Parsippany, NJ 07054 (973) 538-2120

CHA PROJECT NO. 27999

TABLE OF CONTENTS

1.0 E	XECUTIVE SUMMARY	1
2.0 BL	JILDING INFORMATION AND EXISTING CONDITIONS	4
3.0 UT	TILITIES	7
4.0 Be	enchmarking	10
5.0 EN	NERGY CONSERVATION MEASURES	11
5.1	ECM-1 Replace Door Sweeps and Seals	11
5.2	ECM-2 Install Window A/C Controller	12
5.3.1	ECM-3A Install Basic Controls	12
5.3.2	ECM-3B Install Full DDC Controls	13
5.4	ECM-4 Install Low Flow Plumbing Fixtures	14
5.5	ECM-L1 Lighting Replacement / Upgrades	14
5.6	ECM-L2 Install Lighting Controls (Occupancy Sensors)	15
5.7	ECM-L3 Lighting Replacements with Controls (Occupancy Sensors)	15
5.8	Additional O&M Opportunities	16
6.0 PF	ROJECT INCENTIVES	17
6.1	Incentives Overview	17
6.1.1	New Jersey Smart Start Program	17
6.1.2	Direct Install Program	17
6.1.3	New Jersey Pay For Performance Program (P4P)	18
6.1.4	Energy Savings Improvement Plan	19
6.1.5	Renewable Energy Incentive Program	20
7.0 AL	TERNATIVE ENERGY SCREENING EVALUATION	21
7.1	Solar	21
7.1.1	Photovoltaic Rooftop Solar Power Generation	21
7.1.2	Solar Thermal Hot Water Generation	22
7.1	Wind Powered Turbines	23
7.2	Combined Heat and Power Plant	23
7.3	Demand Response Curtailment	24
80 CC	ONCLUSIONS & RECOMMENDATIONS	25

APPENDICES

- A Utility Usage Analysis and List of Third Party Energy Suppliers
- B Equipment Inventory
- C ECM Calculations and Cost Estimates
- D New Jersey BPU Incentive Programs
 - i. Smart Start
 - ii. Direct Install
 - iii. Pay For Performance Incentive Program (P4P)
 - iv. Energy Savings Improvement Plan (ESIP)
- E Photovoltaic (PV) Solar Power Generation Analysis
- F Photos
- G EPA Portfolio Manager

REPORT DISCLAIMER

This audit was conducted in accordance with the standards developed by the American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) for a Level II audit. Cost and savings calculations for a given measure were estimated to within ±20%, and are based on data obtained from the owner, data obtained during site observations, professional experience, historical data, and standard engineering practice. Cost data does not include soft costs such as engineering fees, legal fees, project management fees, financing, etc.

A thorough walkthrough of the building was performed, which included gathering nameplate information and operating parameters for all accessible equipment and lighting systems. Unless otherwise stated, model, efficiency, and capacity information included in this report were collected directly from equipment nameplates and /or from documentation provided by the owner during the site visit. Typical operation and scheduling information was obtained from interviewing staff and spot measurements taken in the field.

List of Common Energy Audit Abbreviations

- A/C Air Conditioning
- AHS Air Handling Unit
- BMS Building Management System
- Btu British thermal unit
- CDW Condenser Water
- CFM Cubic feet per minute
- CHW Chilled Water
- DCV Demand Control Ventilation
- DDC Direct Digital Control
- DHW Domestic Hot Water
- DX Direct Expansion
- EER Energy Efficiency Ratio
- EF Exhaust Fan
- EUI Energy Use Intensity
- Gal Gallon
- GPD Gallons per day
- GPF Gallons Per Flush
- GPH Gallons per hour
- GPM Gallons per minute
- GPS Gallons per second
- HHW Heating Hot Water
- HID High Intensity Discharge
- HP Horsepower
- HRU Heat Recovery Unit
- HVAC Heating, Ventilation, Air Conditioning
- HX Heat Exchanger
- kbtu/mbtu One thousand (1,000) Btu
- kW Kilowatt (1,000 watts)
- kWh Kilowatt-hours
- LED Light Emitting Diode
- mbh Thousand Btu per hour
- mmbtu One million (1,000,000) Btu
- OCC Occupancy Sensor
- PSI Pounds per square inch
- RTU Rooftop Unit
- SBC System Benefits Charge
- SF Square foot
- UH Unit Heater
- V Volts
- VAV Variable Air Volume
- VSD Variable Speed Drive
- W Watt

1.0 EXECUTIVE SUMMARY

This report summarizes the energy audit performed by CHA for Newark Public Schools (NPS), in connection with the New Jersey Board of Public Utilities (NJBPU) Local Government Energy Audit (LGEA) Program. The purpose of this report is to identify energy savings opportunities associated with major energy consumers and inefficient practices. Low-cost and no-cost are also identified during the study. This report details the results of the energy audit conducted for the building listed below:

Building Name	Address	Square Feet	Construction Date	
Sussex Ave School	307 Sussex Ave, Newark, NJ 07107	64,762	1900,1955,1996	

The potential total annual energy and cost savings for the energy conservation measures (ECM) identified in the survey are shown below:

Building Name	Electric Savings (kWh)	NG Savings (therms)	Total Savings (\$)	Payback (years)
Sussex Ave School	118,918	1,442	20,527	9.7

Each individual measure's annual savings are dependent on that measure alone, there are no interactive effects calculated. There are three options shown for Lighting ECM savings; only one option can be chosen. Incentives shown (if any) are based only on the SmartStart Incentive Program. Other NJBPU or local utility incentives may also be available/ applicable and are discussed in Section 5.0.

Each measure recommended by CHA typically has a stand-alone simple payback period of 15 years or less. However, if the owner choses to pursue an Energy Savings Improvement Plan (ESIP), high payback measures could be bundled with lower payback measures which ultimately can result in a payback which is favorable for an ESIP project to proceed. Occasionally, we will recommend an ECM that has a longer payback period, based on the need to replace that piece(s) of equipment due to its age, such as a boiler for example.

The following table provides a detailed summary of each ECM for the building surveyed, including costs, savings, SmartStart incentives and payback.

Summary of Energy Conservation Measures

ECM #	Energy Conservation Measure	Est. Costs (\$)	Est. Savings (\$/year)	Payback w/o Incentive	Potential Incentive (\$)*	Payback w/ Incentive	Recommended
1	Install Door Seals	2,305	102	22.5	0	22.5	N
2	Install Window A/C Controller	1,900	1,270	1.5	0	1.5	Υ
3A	Install Basic Controls	21,309	5,094	4.2	0	4.2	Υ
3B**	Install Full DDC Controls	356,512	7,467	47.7	0	47.7	N
4	Install Low Flow Plumbing Fixtures	231,512	4,009	57.7	0	57.7	N
L1**	Lighting Replacements / Upgrades	152,679	12,599	12.1	3,750	11.8	N
L2**	Install Lighting Controls (Add Occupancy Sensors)	22,680	3,429	6.6	2,940	5.8	N
L3	Lighting Replacements with Controls (Occupancy Sensors)	175,359	14,163	12.4	6,690	11.9	Υ
	Total	432,385	24,638	17.5	6,690	17.3	
	Total (Recommended)	198,569	20,527	9.7	6,690	9.7	

The following alternative energy measures are also recommended for further study:


• Photovoltaic (PV) Rooftop Solar Power Generation – 180 kW System

^{*} Incentive shown is per the New Jersey SmartStart Program.

** These ECMs are not included in the Total, as they are alternate measures not recommended.

If NPS implements the recommended ECMs, energy savings would be as follows:

	Existing Conditions	Post Recommended ECMs	Percent Savings
Costs (\$)	117,797	97,270	17%
Electricity (kWh)	651,678	532,760	18%
Natural Gas			
(therms)	22,100	20,658	7%
Site EUI			
(kbtu/SF/Yr)	68.5	60.0	



2.0 BUILDING INFORMATION AND EXISTING CONDITIONS

The following is a summary of building information related to HVAC, plumbing, building envelope, lighting, kitchen equipment and domestic hot water systems as observed during CHAs site visit. See Appendix B for detailed information on mechanical equipment, including capacities, model numbers and age. See Appendix F for some representative photos of some of the existing conditions observed while onsite.

Building Name: Sussex Ave School (Index No. 72)

Address: 307 Sussex Ave Newark NJ 07107 **Gross Floor Area:** 64,762 square feet

Number of Floors: 3 Year Built: 1900 Additions: 1955, 1996



Description of Spaces: Classrooms, offices, cafeteria, auditorium, gymnasium, stage, library, storage rooms, toilet rooms and a boiler room.

Description of Occupancy: The school serves 508 students from Pre-K grade to 8th grade. There are about 55 school faculty and staff members.

Number of Computers: The school has approximately 128 desktop and laptop computers.

Building Usage: School hours are 8:00 AM - 3:00 PM Monday through Friday, with various after-school activities. The office hours are from 7:30 AM to 4:00 PM. The two-shift custodian hours are from 6:30 AM to 11:00 PM.

Construction Materials: Concrete masonry blocks and stones. The interior walls are plaster walls. It is presumed that the exterior walls have little or no insulation based on the age of the building.

Façade: Brick veneer

Roof: The original 1900 building has pitched asphalt roofing and the additional sections have a flat tar roof. The connection sections between the original building and the additions have

rubber membrane roofs. The roofs are in good condition and therefore no roofing ECMs were considered.

Windows: The building has double pane aluminum frame windows. Windows are in good condition and therefore no ECMs associated related to window replacements were evaluated.

Exterior Doors: The school has steel doors with small single pane windows. The seals around the doors are not in good condition. An ECM has been included to address this issue.

Heating Ventilation & Air Conditioning (HVAC) Systems

Heating: The 1900 and 1955 sections of the building are heated by two new 2012 Smith Cast Iron steam boilers. Each boiler has a rated maximum energy input of 2,718 MBH and energy output of 2,249 MBH which results in a nameplate efficiency of 82.7%. The burners of these two boilers are controlled by Power Flame burner controller. The condensate is returned to the boiler by using a condensate tank and two condensate return pumps. Each pump is driven by a ³/₄ HP Marathon electric motor. The whole building is heated by the steam system except the vestibule areas, which are heated by electric unit heaters. The gymnasium and auditorium are heated by two packaged heating ventilating (HV) units equipped with steam coils. During the site visit, it was observed that the outdoor air intake grill is covered up and sealed up with plastic covers and the HV units only circulate air from the mechanical room to the gymnasium/cafeteria. The classrooms and offices are heated by steam radiators and unit heaters. The 1996 addition is heated electrically by eight packaged classroom HVAC units (Airedale). The heating equipment is in good condition and therefore no ECMs were considered.

Cooling: The original 1900 building and 1955 addition are not cooled with an exception of a few rooms, which have window A/C units. According to the school staff, the library has a packaged AC unit with ductwork; however, it could not be located during the site visit. The main office room, conference room, principle office and some classrooms are cooled by using window AC units. There are about 10 window units in the building and they are controlled manually. Two types of window AC units are used in this building: one uses 120 V and the other uses 208 V. The current drawn by the window AC units ranges from 3.5 amps to 11.7 amps. The 1996 classrooms are cooled by eight Airedale packaged HVAC units. We have included an ECM that evaluates the energy savings associated with automatically controlling the window (and PTAC) units based on occupancy.

Ventilation: The HV units for gymnasium and auditorium are used only for heating as the outdoor air intakes are closed. The remaining areas including the gymnasium, cafeteria and classrooms use operable windows for natural ventilation

Exhaust: The gymnasium and auditorium have two exhaust fans, however, it was found that both of them are disconnected. During the site visit, it was observed that the gymnasium exhaust fan motor was still running with the belt missing.

Controls Systems

The steam heating system in the building has no controls and the boilers are manually turned off when it is too hot in the building. The heating temperature set point in the building was estimated to be 80 °F. The library has a programmable thermostat to control the packaged AC unit serving the space. However, it was not working. The school staff has to turn off the circuit breaker to shut down the AC unit. The (8) Airedale packaged HVAC units have built in temperature sensors to control the room temperature; however these too were not working. The units run continuously to maintain the space temperatures.

Section 5 of the reports addresses these issues with two alternative ECMs. The first is adding basic automatic boiler controls that will cycle the boiler(s) on/off based on outdoor and indoor air temperature. The second alternative evaluates the energy savings for implementing a full wireless direct digital control system that enables remote automatic control, monitoring and alarming of all HVAC equipment, including the boilers and the classroom units. Specific energy savings sequences would include optimum Start/ Stop, night setback, temporary occupied set back, and economizer control of UVs and/or AHU's.

Domestic Hot Water Systems

The building have an A.O Smith domestic hot water heater, however, it was disconnected and not running any more. Discussion with the facility staff, it was found that the building does not use domestic hot water, therefore no ECM was evaluated. The domestic hot water heater should be replaced; however is not considered as an ECM in this report; as there will be negative energy savings associated with replacement.

Drinking water is provided from bottled water.

Kitchen Equipment

The kitchen has one Glenco refrigerator and one Traulsen freezer. The kitchen equipment appears to be in good condition. Kitchen equipment appears to be in good condition and no kitchen equipment ECMs is being evaluated.

Plumbing Systems

The restrooms contain older style toilets and urinals that utilize a higher volume of water per flush than currently available new units. The sinks have manual metering faucets which are inherently low-flow ECMs are included that evaluate the water savings based on the installation of low-flow plumbing fixtures.

Plug Load

This school has computers, copiers, smart boards, residential appliances (microwave, refrigerator), printers and portable electric heaters (personal) which contribute to the plug load in the building.

Lighting Systems

The building has a mixture of T-8 fluorescent lighting, compact fluorescent lights (CFL) and some incandescent lights. The majority lighting fixtures in the building are T8 fluorescent pendent lensed fixtures. The gymnasium storage room has some CFLs. The auditorium and office restrooms have incandescent light bulbs. All the lights in this building are controlled by manual switches or key switches. After discussion with facility staff, it was noted that the classroom lights are typically turned off after the janitor cleaning the rooms and the hallway lights are on 24/7. We have provided three alternatives for lighting that include adding occupancy sensors to the existing lights, replacing the lights with LED lights and a third ECM that evaluates adding occupancy sensors to the proposed LED lights

3.0 UTILITIES


Utilities used by the building are delivered and supplied by the following utility companies:


	Electric	Natural Gas
Deliverer	PSEG	PSEG
Supplier	Nextera Energy Services	PSEG

For the 12-month period ending in December 2013, the utilities usages and costs for the building were as follows:

Electric							
Annual Consumption	645,258	kWh					
Annual Cost	\$93,837	\$					
Blended Unit Rate	\$0.15	\$/kWh					
Supply Rate	\$0.13	\$/kWh					
Demand Rate	\$5.41	\$/kW					
Peak Demand	148	kW					
Natu	iral Gas						
Annual Consumption	22,100	Therms					
Annual Cost	\$22,986	\$					
Unit Rate	\$1.04	\$/therm					

Blended Rate: Average rate charged determined by the annual cost / annual usage
Supply Rate: Actual rate charged for electricity usage in kWh (based on most recent electric bill)
Demand Rate: Rate charged for actual electrical demand in kW (based on most recent electric bill)





In addition, domestic water and sewer services are provided by City of Newark Division of Water at \$7.55/1000 gal.

See Appendix A for a detailed utility analysis.

Under New Jersey's energy deregulation law, the supply portion of the electric (or natural gas) bill is separated from the delivery portion. The supply portion is open to competition, and customers can shop around for the best price for their energy suppliers. The electric and natural gas distribution utilities will still deliver the gas/ electric supplies through their wires and pipes – and respond to emergencies, should they arise – regardless of where those supplies are purchased. Purchasing the energy supplies from a company other than your electric or gas utility is purely an economic decision; it has no impact on the reliability or safety of the service.

Com	Recommended to				
Utility	Units	Shop for Third			
	Utility Units School Average Rate NJ Average Rate				
Electricity	\$/kWh	\$0.15	\$0.12	Y	
Natural Gas	\$/Therm	\$1.04	\$0.95	Υ	

^{*} Per U.S. Energy Information Administration (2013 data - Electricity and Natural Gas, 2012 data - Fuel Oil)


Additional information on selecting a third party energy supplier is available here:


http://www.state.nj.us/bpu/commercial/shopping.html.

See Appendix A for a list of third-party energy suppliers licensed by the Board of Public Utilities to sell within the building's service area.

The charts below represent estimated utility end-use utility profiles for the building. The values used within the charts were estimated from a review of the utility analysis and the energy savings calculations.


Site End-Use Utility Profile





Most of the electricity consumed by educational facilities is used to for lighting and plug loads such as copiers; most of the natural gas is used for space heating. Each school's energy profile is different, and the following charts represent typical utility profiles for K-12 schools per U.S. Department of Energy.

Typical End-Use Utility Profile for Educational Facilities



Courtesy: E SOURCE; from Commercial Building Energy Consumption Survey, 1999 data

4.0 Benchmarking

TRC has previously benchmarked this building, the results of which have been provided to NPS. The results are summarized below. Copies of the benchmarking report are included in this report in Appendix G.

The EPA Portfolio Manager benchmarking tool provides a site and source Energy Use Intensity (EUI), as well as an Energy Star performance rating for qualifying building types. The EUIs are provided in kBtu/ft²/year, and the performance rating represents how energy efficient a building is on a scale of 1 to 100, with 100 being the most efficient. In order for a building to receive and Energy Star label, the energy benchmark rating must be at least 75. As energy use decreases from implementation of the proposed measures, the Energy Star rating will increase.

The site EUI is the amount of heat and electricity consumed by a building as reflected in utility bills. Site energy may be delivered to a facility in the form of primary energy, which is raw fuel burned to create heat or electricity, such as natural gas or oil; or as secondary energy, which is the product created from a raw fuel such as electricity or district steam. To provide an equitable comparison for different buildings with varying proportions of primary and secondary energy consumption, Portfolio Manager uses the convention of source EUIs. The source energy also accounts for losses incurred in production, storage, transmission, and delivery of energy to the site, which provide an equivalent measure for various types of buildings with differing energy sources. The results of the Portfolio Manager benchmarking are contained in the table below.

Site EUI kBtu/ft²/yr	Energy Star Rating (1-100)		
68.5*	13**		

^{*} Calculated by CHA using Utility Data provided by NPS

The school has a below average Energy Star Rating Score (50 being the median score), and as such by implementing the measures discussed in this report, it is expected that the EUI can be further reduced and the Energy Star Rating further increased.

^{**} Provided by TRC

5.0 ENERGY CONSERVATION MEASURES

The following types of energy savings opportunities are identified in this section of the report:

- Energy conservation measures (ECMs) are energy savings recommendations that typically require a financial investment. For these areas of opportunity, CHA prepared detailed calculations, as summarized in this section and in Appendix C.
- Operational and Maintenance measures (O&M) consist of low- or no-cost operational opportunities, which if implemented would have positive impacts on overall building operation, comfort levels, and/or energy usage.

Energy savings were quantified in the form of:

- electrical usage (kWh=Kilowatt-hour),
- electrical demand (kW=kilowatts),
- natural gas (therms=100,000 Btu),
- propane gas (gallons=91,650 Btu),
- fuel oil (gallons =138,700 Btu), and
- water (kgal=1,000 gallons).

These recommendations are influenced by the time period that it takes for a proposed project to "break even" referred to as "Simple Payback". Simple payback is calculated by dividing the estimated cost of implementing the ECM by the energy cost savings (in dollars) of that ECM.

Another financial indicator of the performance of a particular ECM is the Return on Investment or ROI, which represents the benefit (annual savings over the life of a project) of an investment divided by the cost of the investment. The result is expressed as a percentage or ratio.

Two other financial analyses included in this report are Internal Rate of Return (IRR) and Net Present Value (NPV). Internal Rate of Return is the discount rate at which the present value of a project costs equals the present value of the project savings. Net Present Value is the difference between present value of an investment's future net cash flows and the initial investment. If the NPV equals "0", the project would equate to investing the same amount of dollars at the desired rate. NPV is sometimes referred to as Net Present Worth. These values are provided in the Summary Tab in Appendix C.

5.1 ECM-1 Replace Door Sweeps and Seals

Exterior doors throughout the school have door sweeps and seals which have deteriorated over time. Presently, gaps exist which allow for infiltration of outdoor air during the winter months, wasting steam heat generated by the boiler system and therefore natural gas.

This measure calls for the replacement of all exterior door seals. Replacement of these seals will result in a reduction of the buildings heating and cooling loads, therefore

providing natural gas and electricity savings. The linear footage of gap and wind speed is used to estimate the infiltration rate, which is then multiplied by the BIN weather data and the equipment efficiencies to determine the annual energy savings.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-1 Replace Door Sweeps and Seals

Budgetary Cost		Annua	l Utility Savings		ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	El	ectricity	Natural Gas	Total				
\$	kW	kWh	Therms	\$	%	\$	Years	Years
2,305	0	0	98	102	(0.3)	0	22.5	22.5

^{*} Does not qualify for Incentive from the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities

This measure is not recommended due to long payback period.

5.2 ECM-2 Install Window A/C Controller

There are approximately ten (10) window air conditioners located throughout the school: the main office room, conference room, principle office and some classrooms. There are eight packaged heating and cooling units that serve the 1996 addition.

This ECM evaluates the installation of programmable "smart" timers that interrupt the electrical supply to the window air conditioners when cooling is not needed due to the room being unoccupied. The timers are configurable to operate as a standalone timer or they can be wirelessly interconnected to provide remote temperature control using software.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-2 Install Window A/C Controller

Budgetary Cost		Annua	l Utility Savings		ROI	Potential Incentive*	Payback (without	Payback (with	
Cost	Electricity		Natural Gas	Total		incentive	incentive)	incentive)	
\$	kW	kWh	Therms	\$		\$	Years	Years	
1,900	0	8,726	0	1,270	9.0	0	1.5	1.5	

^{*} Does not qualify for Incentive from the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities

This measure is recommended.

5.3.1 ECM-3A Install Basic Controls

The building uses steam boilers that are currently controlled manually by the building operators. Steam pressure is maintained most of the day with no regard to space temperature. Classrooms are overheated as a result and the teachers open the windows in an attempt to cool the rooms down. Furthermore, no night temperature set-back is implemented, unless the operator remembers to turn the boilers off before their shift ends. This highly inefficient method of operation consumes excessive fuel (natural gas).

A Basic Control (system will provide automatic control of the boiler(s) to produce only enough steam (or hot water) needed to heat the building, based on a single or multiple averaging space thermostats and outdoor air temperatures. This system will not provide for independent room temperature control, but could be expanded in the future to provide this function, if desired using thermostatic radiator control valves. This system could also provide basic boiler and space temperature monitoring, trending and remote notification of boiler failure.

ECM-3A Install Basic Controls

Budgetary Cost		Annua	l Utility Savings		ROI	Potential Incentive*	Payback (without	Payback (with	
Cost	Electricity		Natural Gas	Total		incentive	incentive)	incentive)	
\$	kW	kWh	Therms	\$		\$	Years	Years	
21,309	0	24,699	1,442	5,094	2.6	0	4.2	4.2	

^{*} Does not qualify for Incentive from the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities.

This measure is recommended.

5.3.2 ECM-3B Install Full DDC Controls

A Full Direct Digital Control (DDC) building automation system consists of automatic control of individual space heating and ventilation equipment, and provides monitoring, trending and alarms which notify an operator when a piece of equipment fails or operates outside a given set-point. This system allows for the implementation of energy efficient strategies, such as: time of day (TOD) optimization, set point optimization, staggered start, night setback, economizer (free cooling), demand control ventilation, exhaust fan TOD optimization, and holiday TOD optimization. It also allows for remote access and control of the building's systems.

Energy savings are seen from temperature reduction during the day and night as well as other controls sequences mentioned above.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-3B Install Full DDC Controls

Budgetary Cost		Annua	l Utility Savings		ROI	Potential Incentive*	Payback (without	Payback (with	
Cost	El	ectricity	Natural Gas	Total		incentive	incentive)	incentive)	
\$	kW	kWh	Therms	\$		\$	Years	Years	
356,512	0 26,003		3,542	7,467	(0.7)	0	47.7	47.7	

^{*} Does not qualify for Incentive from the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities.

This measure is not recommended due to the long payback period.

5.4 ECM-4 Install Low Flow Plumbing Fixtures

The plumbing fixtures in this building are older high flow fixtures. The water savings associated from replacing existing high flow fixtures with low-flow fixtures was calculated by taking the difference of the annual water usage for the proposed and base case. The basis of this calculation is the estimate usage of each fixture, gallons per use, and number of fixtures. Replacing the existing fixtures in the restrooms with 1.28 Gals/flush toilets, 1.0 gal/flush urinals, and 0.5 gpm faucets will conserve water which will result in lower annual water and sewer charges. Facets with low-flow metering valves were not considered for replacement.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

Budgetary Cost			Annual U	tility Savings		ROI	Potential Incentive*	Payback (without	Payback (with	
Cost	Electricity	Natural Gas	Water	Total		incentive	incentive)	incentive)		
\$	kW	kWh	Therms	kGal	\$	%	\$	Years	Years	
231,512	0	0	0	531	4,009	(0.7)	0	57.7	57.7	

^{*} Does not qualify for Incentive from the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities

This measure is not recommended due to the long payback period.

5.5 ECM-L1 Lighting Replacement / Upgrades

The existing lighting system consists of mostly T8 linear fluorescent fixtures which until recently represented the most efficient lighting technology available. Recent technological improvements in light emitting diode (LED) technologies have driven down the initial costs making it a viable option for installation.

Overall energy consumption can be reduced by replacing inefficient bulbs and linear fluorescent bulbs with more efficient LED technology. To compute the annual savings for this ECM, the energy consumption of the current lighting fixtures was established and compared to the proposed fixture power requirement with the same annual hours of operation. The difference between the existing and proposed annual energy consumption was the energy savings. These calculations are based on 1 to 1 replacements of the fixtures, and do not take into account lumen output requirements for a given space. A more comprehensive engineering study should be performed to determine correct lighting levels.

Supporting calculations, including assumptions for lighting hours and annual energy usage for each fixture, are provided in Appendix C and summarized below:

ECM-L1 Lighting Replacement / Upgrades

Budgetary Cost	-	Annua	l Utility Savings		ROI	Potential Incentive*	Payback (without	Payback (with	
Cost		Total		incentive	incentive)	incentive)			
\$	kW	kWh	Therms	\$	%	\$	Years	Years	
152,679	30.1 74,141 0 12,599		12,599	0.3	3,750	12.1	11.8		

^{*} LED retrofits must go through the "custom" measures incentive option under New Jersey SmartStart Program. There are no "prescriptive" incentives for LED retrofits. Projects must achieve a minimum of 75,000 kWh annual savings to qualify for "custom" incentives. See section 6.0 for other incentive opportunities

This measure is not recommended in lieu of ECM-L3.

5.6 ECM-L2 Install Lighting Controls (Occupancy Sensors)

Presently, all interior lighting fixtures are controlled by wall mounted switches. Review of the comprehensive lighting survey determined that lighting in some areas could benefit from installation of occupancy sensors to turn off lights when they are unoccupied.

This measure recommends installing occupancy sensors for the current lighting system. Using a process similar to that utilized in ECM L1, the energy savings for this measure was calculated by applying the known fixture wattages in the space to the estimated existing and proposed times of operation for each fixture.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-L2 Install Lighting Controls (Occupancy Sensors)

======================================											
Budgetary Cost		Annua	l Utility Savings		ROI	Potential Incentive*	Payback (without	Payback (with			
Cost	EI	ectricity	Natural Gas	Total		incentive	incentive)	incentive)			
\$	kW	kWh	Therms	\$	%	\$	Years	Years			
22,680	0 24,890		0	3,429	1.4	2,940	6.6	5.8			

^{*} Incentive shown is per the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities.

This measure is not recommended in lieu of ECM-L3.

5.7 ECM-L3 Lighting Replacements with Controls (Occupancy Sensors)

This measure is a combination of ECM-L1 and ECM-L2; recommending replace/upgrade the current lighting fixtures to more efficient ones and installing occupancy sensors on the new lights. Interactive effects of the higher efficiency lights and occupancy sensors lead the energy and cost savings for this measure to not be cumulative or equivalent to the sum of replacing the lighting fixtures alone and installing occupancy sensors without the lighting upgrade.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-L3 Lighting Replacements with Controls (Occupancy Sensors)

Budgetary		Annua	l Utility Savings		ROI	Potential Incentive*	Payback (without	Payback (with	
Cost	El	ectricity	Natural Gas	Total		incentive	incentive)	incentive)	
\$	kW	kWh	Therms	\$		\$	Years	Years	
	30.								
175,359	1	85,492	0	14,163	0.3	6,690	12.4	11.9	

^{*} LED retrofits must go through the "custom" measures incentive option under New Jersey SmartStart Program. There are no "prescriptive" incentives for LED retrofits. Projects must achieve a minimum of 75,000 kWh annual savings to qualify for "custom" incentives. See section 6.0 for other incentive opportunities

This measure is recommended.

5.8 Additional O&M Opportunities

This list of operations and maintenance (O&M) - type measures represent low-cost or no-cost opportunities, which if implemented will have a positive impact on the overall building operations, comfort and/or energy consumption. The recommended O&M measures for this building are as follows:

- Turn off the Gym Exhaust Fan Motor
- Perform steam trap replacement survey each year to ensure steam traps are operating as intended
- Install Covers on Window Air Conditioners
- Clean Window AC filters before each season
- Set computers monitors to turn off and computers to sleep mode when not in use
- Look for the ENERGY STAR® label when purchasing Window AC units or Kitchen Appliances
- Disconnect unnecessary or unused small appliances and electronics when not in use to reduce phantom loads
- Train custodians to turn off lights and set HVAC temperatures to minimum levels when rooms are unoccupied
- Develop an Energy Master Plan to measure and track energy performance
- Educate students and staff about how their behavior affects energy use. Create student energy patrols to monitor and inform administration when energy is being wasted.
- During the winter, Custodians should ensure all windows are closed as part of cleaning routine

6.0 PROJECT INCENTIVES

6.1 Incentives Overview

The following sections give detailed information on available incentive programs including New Jersey Smart Start, Direct Install, New Jersey Pay for Performance (P4P) and Energy Savings Improvement Plan (ESIP). If the School District wishes to and is eligible to participate in the Energy Savings Improvement Plan (ESIP) program and/or the Pay for Performance Incentive Program (P4P), it cannot participate in either the Smart Start or Direct Install Programs. Refer to Appendix D for more information on the Smart Start program.

6.1.1 New Jersey Smart Start Program

For this energy audit, The New Jersey Smart Start Incentives are used in the energy savings calculations, where applicable. This program is intended for medium and large energy users and provides incentives for:

- Electric Chillers
- Gas Chillers
- Gas Heating
- Unitary HVAC
- Ground Source Heat Pumps
- Variable frequency Drives/ motors
- Refrigeration
- Prescriptive and performance lighting and lighting controls

The equipment is procured using a typical bid-build method, installed and paid for and then the incentives are reimbursed to the owner.

Refer to Appendix D for more information on the Smart Start program.

6.1.2 Direct Install Program

The Direct Install Program applies to smaller facilities that have a peak electrical demand of 200 kW or less in any of the previous 12 months. Buildings must be located in New Jersey and served by one of the state's public, regulated electric utility companies.

Direct Install is funded through New Jersey's Clean Energy Program and is designed to provide capital for building energy upgrade projects to fast track implementation. The program will pay up to 70% of the costs for lighting, HVAC, motors, refrigeration, and other equipment upgrades with higher efficiency alternatives. If a building is eligible for this funding, the Direct Install Program can reduce the implementation cost of energy conservation projects.

The Direct Install program has specific HVAC equipment and lighting requirements and is generally applicable only to smaller package HVAC units, small boilers and lighting retrofits.

The program pays a maximum amount of \$75,000 per building, and up to \$250,000 per customer per year. Installations must be completed by an approved Direct Install participating contractor, a list of which can be found on the New Jersey Clean Energy Website. Contractors will coordinate with the applicant to arrange installation of recommended measures identified in

a previous energy assessment, such as this energy audit. The incentive is reimbursed to the owner upon successful replacement and payment of the equipment.

The building qualifies for this program because its electrical demand is less than the maximum peak electrical demand of 200 kW for the last 12 month period.

Refer to Appendix D for more information on this program.

6.1.3 New Jersey Pay For Performance Program (P4P)

The Sussex Ave School may be eligible for incentives from the New Jersey Office of Clean Energy. The most significant incentives are available from the New Jersey Pay for Performance (P4P) Program. The P4P program is designed to offset the cost of energy conservation projects for facilities that pay the Societal Benefits Charge (SBC) and whose demand (kW) in any of the preceding 12 months exceeds 100 kW. This demand minimum has been waived for buildings owned by local governments or municipalities and non-profit organizations and *is not applicable to public schools*. Facilities that meet this criterion must also achieve a minimum performance target of 15% energy reduction by using the EPA Portfolio Manager benchmarking tool before and after implementation of the measure(s). Additionally, the overall return on investment (ROI) must exceed 10%. If the participant is a municipal electric company customer, and a customer of a regulated gas New Jersey Utility, only gas measures will be eligible under the Program. Available incentives are as follows:

Incentive #1: Energy Reduction Plan – This incentive is designed to offset the cost of services associated with the development of the Energy Reduction Plan (ERP). The ERP must include a detailed energy audit of the desired ECMs, energy savings calculations (using building modeling software) and inputting of all utility bills into the EPA Portfolio Manager website.

Incentive Amount: \$0.10/SFMinimum incentive: \$5,000

Maximum Incentive: \$50,000 or 50% of Facility annual energy cost

The standard incentive pays \$0.10 per square foot, up to a maximum of \$50,000, not to exceed 50% of facility annual energy cost, paid after approval of application. For building audits funded by the New Jersey Board of Public Utilities, which receive an initial 75% incentive toward performance of the energy audit, facilities are only eligible for an additional \$0.05 per square foot, up to a maximum of \$25,000, rather than the standard incentive noted above. The ERP must be completed by a Certified Energy Manager (CEM) and submitted along with the project application.

Incentive #2: Installation of Recommended Measures – This incentive is based on projected energy savings as determined in Incentive #1 (Minimum 15% savings must be achieved), and is paid upon successful installation of recommended measures.

Electric

- Base incentive based on 15% savings: \$0.09/ per projected kWh saved.
- For each % over 15% add: \$0.005 per projected kWh saved.
- Maximum incentive: \$0.11/ kWh per projected kWh saved.

Gas

• Base incentive based on 15% savings: \$0.90/ per projected Therm saved.

- For each % over 15% add: \$0.05 per projected Therm saved.
- Maximum incentive: \$1.25 per projected Therm saved.

Incentive cap: 25% of total project cost

Incentive #3: Post-Construction Benchmarking Report – This incentive is paid after acceptance of a report proving energy savings over one year utilizing the Environmental Protection Agency (EPA) Portfolio Manager benchmarking tool.

Electric

- Base incentive based on 15% savings: \$0.09/ per projected kWh saved.
- For each % over 15% add: \$0.005 per projected kWh saved.
- Maximum incentive: \$0.11/kWh per projected kWh saved.

Gas

- Base incentive based on 15% savings: \$0.90/ per projected Therm saved.
- For each % over 15% add: \$0.05 per projected Therm saved.
- Maximum incentive: \$1.25 per projected Therm saved.

Combining Incentives #2 and #3 will provide a total of \$0.18/ kWh and \$1.8/therm not to exceed 50% of total project cost. Additional Incentives for #2 and #3 are increased by \$0.005/kWh and \$0.05/therm for each percentage increase above the 15% minimum target to 20%, calculated with the EPA Portfolio Manager benchmarking tool, not to exceed 50% of total project cost.

For the purpose of demonstrating the eligibility of the ECM's to meet the minimum savings requirement of 15% annual savings and 10% ROI for the Pay for Performance Program, all ECM's identified in this report have been included in the incentive calculations. The results for the building are shown in Appendix C, along with more detailed program information provided in Appendix D.

6.1.4 Energy Savings Improvement Plan

The Energy Savings Improvement Program (ESIP) allows government agencies to make energy related improvements to their facilities and pay for the costs using the value of energy savings that result from the improvements. Under the recently enacted Chapter 4 of the Laws of 2009 (the law), the ESIP provides all government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources.

ESIP allows local units to use "energy savings obligations" (ESO) to pay for the capital costs of energy improvements to their facilities. This can be done over a maximum term of 15 years. ESOs are not considered "new general obligation debt" of a local unit and do not count against debt limits or require voter approval. They may be issued as refunding bonds or leases. Savings generated from the installation of energy conservation measures pay the principal of and interest on the bonds; for that reason, the debt service created by the ESOs is not paid from the debt service fund, but is paid from the general fund.

For local governments interested in pursuing an ESIP, the first step is to perform an energy audit. Pursuing a Local Government Energy Audit through New Jersey's Clean Energy Program is a valuable first step to the ESIP approach. The "Local Finance Notice" outlines how local governments can develop and implement an ESIP for their facilities. The ESIP can be

prepared internally if the entity has qualified staff. If not, the ESIP must be implemented by an independent contractor and not by the energy savings company producing the Energy Reduction Plan.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Local units should carefully consider all alternatives to develop an approach that best meets their needs. Refer to Appendix D for more information on this program.

6.1.5 Renewable Energy Incentive Program

The Renewable Energy Incentive Program (REIP) is part of New Jersey's efforts to reach its Energy Master Plan goals of striving to use 30 percent of electricity from renewable sources by 2020.

Incentives for sustainable bio-power projects and for energy storage projects are currently under development, with competitive solicitations for each of those technologies expected to begin in the first quarter of 2014. The wind program is currently on hold.

New solar projects are no longer eligible for REIP incentives, but can register for Solar Renewable Energy Certificates (SRECs) through the SREC Registration Program (SRP).

7.0 ALTERNATIVE ENERGY SCREENING EVALUATION

7.1 Solar

7.1.1 Photovoltaic Rooftop Solar Power Generation

The building was evaluated for the potential to install rooftop photovoltaic (PV) solar panels for power generation. Present technology incorporates the use of solar cell arrays that produce direct current (DC) electricity. This DC current is converted to alternating current (AC) with the use of an electrical device known as an inverter. The amount of available roof area determines how large of a solar array can be installed on any given roof. The table below summarizes the approximate roof area available on the building and the associated solar array size that can be installed.

Available Roof	Potential PV
Area	Array Size
(Ft ²)	(kW)
23,286	180

The PVWATTS solar power generation model was utilized to calculate PV power generation; this model is provided in Appendix E.

Installation of (PV) arrays in the state New Jersey will allow the owner to participate in the New Jersey Solar Renewable Energy Certificates Program (SREC). This is a program that has been set up to allow entities with large amounts of environmentally unfriendly emissions to purchase credits from zero emission (PV) solar-producers. An alternative compliance penalty (ACP) is paid for by the high emission producers and is set each year on a declining scale of 3% per year. One SREC credit is equivalent to 1000 kilowatt hours of PV electrical production; these credits can be traded for period of 15 years from the date of installation. Payments that will be received by the PV producer (school) will change from year to year dependent upon supply and demand. There is no definitive way to calculate an exact price that will be received by the PV producer for SREC credits over the next 15 years. Renewable Energy Consultants estimates an average of \$155/SREC for 2013 and this number was utilized in the cash flow for this report.

The system costs for PV installations were derived from recent solar contractor budgetary pricing in the state of New Jersey and include the total cost of the system installation (PV panels, inverters, wiring, ballast, controls). The cost of installation is currently about \$4.00 per watt or \$4,000 per kW of installed system, for a typical 100 kW system. There are other considerations that have not been included in this pricing, such as the condition of the roof and need for structural reinforcement. Photovoltaic systems can be ground mounted if the roof is not suitable, however, this installation requires a substantial amount of open property (not wooded) and underground wiring, which adds more cost. PV panels have an approximate 20 year life span; however, the inverter device that converts DC electricity to AC has a life span of 10 to 12 years and will most likely need to be replaced during the useful life of the PV system.

The implementation cost and savings related to this ECM are presented in Appendix E and summarized as follows:

Photovoltaic (PV) Rooftop Solar Power Generation – 180 kW System

		•						
Budgetary Cost	An	inual Utility	Savings	Total Savings	New Jersey Renewable SREC	Payback (without incentive)	Payback (with incentives)	ecommended
	Electricity		Natural Gas					ă.
\$	kW	kWh	Therms	\$	\$	Years	Years	Y/N
\$720,000	180.0	234,600	0	\$35,098	\$36,363	20.5 10.1		FS

Note: CHA typically recommends a more detailed evaluation be conducted for the installation of PV Solar arrays when the screening evaluation shows a payback of less than 20 years. Therefore, this ECM is recommended for further study. Before implementation is pursued, the school district should consult with a certified solar PV contractor.

7.1.2 Solar Thermal Hot Water Generation

Active solar thermal systems use solar collectors to gather the sun's energy to heat a fluid. An absorber in the collector (usually black colored piping) converts the sun's energy into heat. The heat is transferred to circulating water, antifreeze, or air for immediate use or is storage for later utilization. Applications for active solar thermal energy include supplementing domestic hot water, heating swimming pools, space heating or preheating air in residential and commercial buildings.


A standard solar hot water system is typically composed of solar collectors, heat storage vessel, piping, circulators, and controls. Systems are typically integrated to work alongside a conventional heating system that provides heat when solar resources are not sufficient. The solar collectors are usually placed on the roof of the building, oriented south, and tilted at the same angle as the site's latitude, to maximize the amount of solar radiation collected on a yearly basis.

Several options exist for using active solar thermal systems for space heating. The most common method is called a passive solar hot water system involves using glazed collectors to heat a liquid held in a storage tank (similar to an active solar hot water system described above which requires pumping). The most practical system would transfer the heat from the panels to thermal storage tanks and then use the pre-heated water for domestic hot water production. DHW is presently produced by natural gas fired water heaters and, therefore, this measure would offer natural gas utility savings. Unfortunately, the amount of domestic hot water that is currently used by this school is very small. Installing a solar domestic hot water system is not recommended due to the limited amount of domestic hot water presently consumed by the school.

This measure is not recommended due to the small usage of domestic hot water and long payback period.

7.1 Wind Powered Turbines

Wind power is the conversion of kinetic energy from wind into mechanical power that is used to drive a generator which creates electricity by means of a wind turbine. A wind turbine consists of rotor and blades connected to a gearbox and generator that are mounted onto a tower. Newer wind turbines also use advanced technology to generate electricity at a variety of frequencies depending on the wind speed, convert it to DC and then back to AC before sending it to the grid. Wind turbines range from 50 – 750 kW for utility scale turbines down to below 50 kW for residential use. On a scale of 1 (the lowest) to 7 (the highest), Class 3 and above (wind speeds of 13 mph or greater) are generally considered "good wind resource" according to the Wind Energy Development Programmatic EIS Information Center hosted by the Bureau of Land Management. According to the map below, published by NREL, Newark, NJ is classified as Class 1 at 50m, meaning the city would not be a good candidate for wind power.



This measure is not recommended due to the location of the school.

7.2 Combined Heat and Power Plant

Combined heat and power (CHP), cogeneration, is self-production of electricity on-site with beneficial recovery of the heat byproduct from the electrical generator. Common CHP equipment includes reciprocating engine-driven, micro turbines, steam turbines, and fuel cells. Typical CHP customers include industrial, commercial, institutional, educational institutions, and multifamily residential facilities. CHP systems that are commercially viable at the present time are sized approximately 50 kW and above, with numerous options in blocks grouped around 300 kW, 800 kW, 1,200 kW and larger. Typically, CHP systems are used to produce a portion of the electricity needed by a facility some or all of the time, with the balance of electric needs satisfied by purchase from the grid.

Any proposed CHP project will need to consider many factors, such as existing system load, use of thermal energy produced, system size, natural gas fuel availability, and proposed plant

location. The building has sufficient need for electrical generation and the ability to use most of the thermal byproduct during the winter; however thermal usage during the summer months does not exist. Thermal energy produced by the CHP plant in the warmer months will be wasted. An absorption chiller could be installed to utilize the heat to produce chilled water; however, there is no chilled water distribution system in the building. CHP is not recommended due to the building's limited summer thermal demand.

This measure is not recommended due to the lack of year round thermal load that is required for a CHP system to be operating cost effectively.

7.3 Demand Response Curtailment

Presently, electricity is delivered by PSE&G, which receives the electricity from regional power grid RFC. PSE&G is the regional transmission organization (RTO) that coordinates the movement of wholesale electricity in all or parts of 13 states and the District of Columbia including the State of New Jersey.

Utility Curtailment is an agreement with the utility provider's regional transmission organization and an approved Curtailment Service Provider (CSP) to shed electrical load by either turning major equipment off or energizing all or part of a facility utilizing an emergency generator; therefore, reducing the electrical demand on the utility grid. This program is to benefit the utility company during high demand periods and utility provider offers incentives to the CSP to participate in this program. Enrolling in the program will require program participants to drop electrical load or turn on emergency generators during high electrical demand conditions or during emergencies. Part of the program also will require that program participants reduce their required load or run emergency generators with notice to test the system.

A pre-approved CSP will require a minimum of 100 kW of load reduction to participate in any curtailment program. From January 2013 through December 2013 the following table summarizes the electricity load profile for the building.

Building Electric Load Profile

			Onsite	
Peak Demand	Min Demand	Avg Demand	Generation	Eligible?
kW	kW	kW	Y/N	Y/N
148	90	120	Υ	Ν

This measure is not recommended because the building does not have adequate load to meet the required minimum load reduction.

8.0 CONCLUSIONS & RECOMMENDATIONS

The LGEA energy audit conducted by CHA for the building identified potential annual savings of \$20,527/yr with an overall payback of 9.7 years, if the recommended ECMs are implemented.

The potential annual energy and cost savings are shown in the following table.

Electric Savings (kWh)	Natural Gas Savings (therms)	Total Savings (\$)	Payback (years)
118,918	1,442	20,527	9.7

The following projects should be considered for implementation:


- Install Window A/C Controller
- Install Basic Controls
- Lighting Replacements with Controls

The following alternative energy measures are also recommended for further study:

Photovoltaic (PV) Rooftop Solar Power Generation – 180 kW System

If NPS implements the recommended ECMs, energy savings would be as follows:

	Existing Conditions	Post Recommended ECMs	Percent Savings
Costs (\$)	117,797	97,270	17%
Electricity (kWh)	651,678	532,760	18%
Natural Gas			
(therms)	22,100	20,658	7%
Site EUI			
(kbtu/SF/Yr)	68.5	60.0	





Blended

Demand


									Rate	С	Consumption	F	Rate
Start Date	End Date	kWh	Demand Usage (KW)	Total Charge	Supply Charge	Delivery Charge	Demand Charge	Consumption (\$)	(\$/kWh)	R	ate (\$/kWh)	(\$	(kW)
1/5/2012	2/2/2012	64198	140	10,850.00	0	2,724.04	488.13	10361.87	\$ 0.17	7 \$	0.16	\$	3.49
2/3/2012	2 3/5/2012	68476	134	11,570.00	0	2,844.60	467.2	11102.8	\$ 0.17	7 \$	0.16	\$	3.49
3/6/2012	2 4/3/2012	48877	140	8,260.00	0	2,286.52	488.12	7771.88	\$ 0.17	7 \$	0.16	\$	3.49
4/4/2012	5/3/2012	43527	122	7,355.00	0	2,133.26	425.37	6929.63	\$ 0.17	7 \$	0.16	\$	3.49
5/4/2012	6/4/2012	46657	126	7,885.00	0	3,264.77	439.31	7445.69	\$ 0.17	7 \$	0.16	\$	3.49
6/5/2012	7/3/2012	43060	122	7,753.36	4,139.79	3,188.20	425.37	7327.99	\$ 0.18	3 \$	0.17	\$	3.49
7/4/2012	8/2/2012	47603	98	7,957.66	4,485.99	3,129.44	341.69	7615.97	\$ 0.17	7 \$	0.16	\$	3.49
8/3/2012	8/31/2012	44130	88	7,372.49	4,117.16	2,948.51	306.82	7065.67	\$ 0.17	7 \$	0.16	\$	3.49
9/1/2012	2 10/2/2012	50932	120	7,461.66	4,615.63	2,427.64	418.39	7043.27	\$ 0.15	5 \$	0.14	\$	3.49
10/3/2012	2 12/3/2012	106677	132	15,157.02	9,352.37	4,974.84	829.81	14327.21	\$ 0.14	4 \$	0.13	\$	6.29
12/4/2012	2 1/3/2013	63312	132	8,596.78	5,347.94	2,787.87	460.97	8135.81	\$ 0.14	4 \$	0.13	\$	3.49
1/4/2013	3 2/1/2013	68218	134	9,146.65	5,672.06	2,999.64	474.95	8671.7	\$ 0.13	3 \$	0.13	\$	3.54
2/2/2013	3/5/2013	76082	140	9,855.47	6,266.80	3,092.45	496.22	9359.25	\$ 0.13	3 \$	0.12	\$	3.54
3/6/2013	3 4/4/2013	63270	130	8,681.79	5,502.11	2,718.91	460.77	8221.02	\$ 0.14	4 \$	0.13	\$	3.54
4/5/2013	5/3/2013	45333	120	7,033.46	4,404.19	2,203.94	425.33	6608.13	\$ 0.16	5 \$	0.15	\$	3.54
5/4/2013	6/4/2013	45857	112	8,061.25	4,490.25	2,229.63	1,341.37	6719.88	\$ 0.18	} \$	0.15	\$	11.98
6/4/2013	7/3/2013	43600	116	7,479.32	4,400.01	1,690.04	1,389.27	6090.05	\$ 0.17	7 \$	0.14	\$	11.98
7/4/2013	8/2/2013	45403	92	7,651.63	4,258.13	3,067.42	326.08	7325.55	\$ 0.17	1 \$	0.16	\$	3.54
8/2/2013	9/3/2013	36200	90	5,813.51	3,268.86	1,466.76	1,077.89	4735.62	\$ 0.16	5 \$	0.13	\$	11.98
9/4/2013	3 10/2/2013	42506	116	6,465.65	3,838.29	2,216.20	411.16	6054.49	\$ 0.15	; \$	0.14	\$	3.54
10/3/2013	3 10/31/2013	43582	112	5,979.95	3,323.04	2,259.94	396.97	5582.98	\$ 0.14	4 \$	0.13	\$	3.54
11/1/2013	3 12/3/2013	66095	128	8,614.52	5,201.28	2,959.56	453.68	8160.84	\$ 0.13	3 \$	0.12	\$	3.54
12/4/2013	3 1/3/2014	69112	148	9,053.96	5,490.24	3,039.15	524.57	8529.39	\$ 0.13	3 \$	0.12	\$	3.54

10/31/2013

Sussex Avenue		Start Date		End Date		Months	
307 Sussex Ave., 07	7107	1/	5/2012	1,	/3/2014		23
Account Number	2147483647						
Meter Number	778009455						

ELECTRIC USAGE - MOST RECENT 12 MONTHS, PERIOD ENDING:

Total Usage	645,258	kwh
Total Charges	\$93,837	
Blended Rate	\$0.15	\$/kWh
Consumption Rate	\$0.13	\$/kWh
Demand Rate	\$5.41	\$/kW
Max Demand	148	kW
Min Demand	90.0	kW
Avg Demand	120	kW



Blended

Demand


6 5 .	- 1		()				- 10	(4)	Rate	Consumption	Rate	
Start Date			_	_			_	Consumption (\$)	(\$/kWh)	Rate (\$/kWh)	(\$/kV	•
1/5/2012	2/2/2012	60	3.6	46.58	25.03	6.3	15.25	31.33	\$ 0.78	\$ 0.52	\$ 4.	1.24
2/3/2012	3/5/2012	120	0.6	40.77	30.01	8.22	2.54	38.23	\$ 0.34	\$ 0.32	\$ 4.	1.23
3/6/2012	5/3/2012	240	4.8	98.51	59.18	16.45	22.88	75.63	\$ 0.41	\$ 0.32	\$ 4.	1.77
5/4/2012	6/4/2012	420	0.6	79.38	51.56	25.28	2.54	76.84	\$ 0.19	\$ 0.18	\$ 4.	1.23
6/5/2012	7/3/2012	360	1.2	69.4	36.08	28.24	5.08	64.32	\$ 0.19	\$ 0.18	\$ 4.	1.23
7/4/2012	8/2/2012	420	1.2	77.18	41.45	30.65	5.08	72.1	\$ 0.18	\$ 0.17	\$ 4.	1.23
8/3/2012	8/30/2012	180	1.2	49.05	22.93	21.04	5.08	43.97	\$ 0.27	\$ 0.24	\$ 4.	1.23
8/31/2012	12/3/2012	1260	0.6	181.72	118.95	55.15	7.62	174.1	\$ 0.14	\$ 0.14	\$ 12.	2.70
12/4/2012	1/3/2013	540	0.6	72.9	47.97	22.38	2.55	70.35	\$ 0.14	\$ 0.13	\$ 4.	1.25
1/4/2013	2/5/2013	60	0.6	25.46	14.13	6.19	5.14	20.32	\$ 0.21	\$ 0.17	\$ 4.	1.28
2/6/2013	3/5/2013	60	0.6	25.46	14.13	6.19	5.14	20.32	\$ 0.21	\$ 0.17	\$ 4.	1.28
3/6/2013	4/4/2013	420	0.6	60.59	40.3	17.72	2.57	58.02	\$ 0.14	\$ 0.14	\$ 4.	1.28
4/5/2013	5/3/2013	360	0.6	55.07	36.71	15.79	2.57	52.5	\$ 0.15	\$ 0.15	\$ 4.	1.28
5/4/2013	6/5/2013	840	1.2	124.24	72.56	37.01	14.67	109.57	\$ 0.15	\$ 0.13	\$ 12.	2.23
6/6/2013	7/3/2013	360	1.2	69.3	35.76	28.4	5.14	64.16	\$ 0.19	\$ 0.18	\$ 4.	1.28
7/4/2013	8/2/2013	420	1.2	75.47	39.5	30.83	5.14	70.33	\$ 0.18	\$ 0.17	\$ 4.	1.28
8/3/2013	9/3/2013	240	1.2	50.35	21.67	23.54	5.14	45.21	\$ 0.21	\$ 0.19	\$ 4.	1.28
9/4/2013	10/2/2013	240	0.6	36.69	21.67	12.45	2.57	34.12	\$ 0.15	\$ 0.14	\$ 4.	1.28
10/3/2013	11/1/2013	1500	0	196.07	135.45	55.48	5.14	190.93	\$ 0.07	\$ 0.06	#DIV/	/0!
11/2/2013	12/1/2013	1500	0	196.07	135.45	55.48	5.14	190.93	\$ 0.07	\$ 0.06	#DIV/	/0!
12/2/2013	1/2/2014	420	0	59	37.93	18.5	2.57	56.43	\$ 0.14	\$ 0.13	#DIV/	/0!

1/2/2014

Sussex Avenue		Start Date		End Date	Months	
307 Sussex Ave., 07	107		1/5/2012	1/2/2014		23
Account Number	2147483647					
Meter Number	1265223					

ELECTRIC USAGE - MOST RECENT 12 MONTHS, PERIOD ENDING:

		,
Total Usage	6,420	kwh
Total Charges	\$974	
Blended Rate	\$0.15	\$/kWh
Consumption Rate	\$0.14	\$/kWh
Demand Rate	\$7.81	\$/kW
Max Demand	1.2	kW
Min Demand	0.0	kW
Avg Demand	0.7	kW



Newark Public Schools LGEA CHA Project# 27999


Sussex Avenue - Natural Gas Usage

Index No	Current Name	Acct	Meter	Start Date	End Date	Therms	Total Charge	\$/therm
	72 Sussex Avenue	4200782103	2413156	1/5/2012	2/2/2012	6,107.56	5,605.82	0.92
	72 Sussex Avenue	4200782103	2413156	2/3/2012	3/5/2012	7,093.90	5,982.70	0.84
	72 Sussex Avenue	4200782103	2413156	3/6/2012	4/3/2012	1,765.22	1,187.54	0.67
	72 Sussex Avenue	4200782103	2413156	4/4/2012	5/3/2012	1,832.01	1,182.62	0.65
	72 Sussex Avenue	4200782103	2413156	5/4/2012	6/4/2012	154.86	192.62	1.24
	72 Sussex Avenue	4200782103	2413156	6/5/2012	7/3/2012	1.07	100.22	93.66
	72 Sussex Avenue	4200782103	2413156	7/4/2012	8/2/2012	3.22	101.71	31.59
	72 Sussex Avenue	4200782103	2413156	8/3/2012	8/30/2012	2.14	101.02	47.21
	72 Sussex Avenue	4200782103	2413156	8/31/2012	10/1/2012	25.73	116.59	4.53
	72 Sussex Avenue	4200782103	2413156	10/2/2012	11/2/2012	182.24	1,073.37	5.89
	72 Sussex Avenue	4200782103	2413156	11/3/2012	12/3/2012	4,909.45	5,070.61	1.03
	72 Sussex Avenue	4200782103	2413156	12/4/2012	1/3/2013	2,005.51	2,651.77	1.32
	72 Sussex Avenue	4200782103	2413156	1/4/2013	2/1/2013	4,675.59	4,731.27	1.01
	72 Sussex Avenue	4200782103	2413156	2/2/2013	3/5/2013	5,737.94	5,466.47	0.95
	72 Sussex Avenue	4200782103	2413156	3/6/2013	4/4/2013	4,076.30	2,984.11	0.73
	72 Sussex Avenue	4200782103	2413156	4/5/2013	5/3/2013	476.5	471.38	0.99
	72 Sussex Avenue	4200782103	2413156	5/4/2013	6/5/2013	3.23	106.8	33.07
	72 Sussex Avenue	4200782103	2413156	6/6/2013	7/3/2013	2.16	105.9	49.03
	72 Sussex Avenue	4200782103	2413156	7/4/2013	8/2/2013	3.26	106.62	32.71
	72 Sussex Avenue	4200782103	2413156	9/4/2013	10/1/2013	0	0	#DIV/0!
	72 Sussex Avenue	4200782103	2413156	10/2/2013	10/31/2013	0	0	#DIV/0!
	72 Sussex Avenue	4200782103	2413156	11/1/2013	12/3/2013	0	0	#DIV/0!
	72 Sussex Avenue	4200782103	2413156	12/4/2013	1/3/2014	2,009.35	3,301.15	1.64

Sussex Avenue		Start Date	End Date	# Months	
Account Number	4200782103	1/5/2012	1/3/2014		23
Meter Number	2413156				

NATURAL GAS USAGE - MOST RECENT 12 MONTHS, PERIOD ENDING: 8/2/2013

Annual Usage	22,100 Therms	
Annual Cost	\$22,986	
Rate	\$1.04 \$/Therm	



PSE&G ELECTRIC SERVICE TERRITORY Last Updated: 10/24/12

$*\underline{CUSTOMER\ CLASS} - R - RESIDENTIAL\ C - COMMERCIAL\ I - INDUSTRIAL$

Supplier	Telephone	*Customer
**	& Web Site	Class
AEP Energy, Inc.	(866) 258-3782	C/I
309 Fellowship Road, Fl. 2		
Mount Laurel, NJ 08054	www.aepenergy.com	ACTIVE
Alpha Gas and Electric, LLC	(855) 553-6374	R/C
641 5 th Street		
Lakewood, NJ 08701	www.alphagasandelectric.com	ACTIVE
Ambit Northeast, LLC	(877)-30-AMBIT	R/C
103 Carnegie Center	(877) 302-6248	
Suite 300		
Princeton, NJ 08540	www.ambitenergy.com	ACTIVE
American Powernet	(877) 977-2636	C
Management, LP		
437 North Grove St.	www.americanpowernet.com	ACTIVE
Berlin, NJ 08009		
Amerigreen Energy, Inc.	888-423-8357	R/C
1463 Lamberton Road		
Trenton, NJ 08611	www.amerigreen.com	ACTIVE
AP Gas & Electric, LLC	(855) 544-4895	R/C/I
10 North Park Place, Suite 420		
Morristown, NJ 07960	www.apge.com	ACTIVE
Astral Energy LLC	(201) 384-5552	R/C/I
16 Tyson Place		
Bergenfield, NJ 07621	www.astralenergyllc.com	ACTIVE
Barclays Capital Services,	(888) 978-9974	C
Inc.		
70 Hudson Street		ACTIVE
Jersey City, NJ 07302-4585	www.group.barclays.com	
BBPC, LLC d/b/a Great	(888) 651-4121	C/I
Eastern Energy		
116 Village Blvd. Suite 200	www.greateasternenergy.com	
Princeton, NJ 08540		ACTIVE
Champion Energy Services,	(877) 653-5090	R/C/I
LLC		
72 Avenue L		ACTIVE
Newark, NJ 07105	www.championenergyservices.com	

Choice Energy, LLC	888-565-4490	R/C
4257 US Highway 9, Suite 6C Freehold, NJ 07728	www.4choiceenergy.com	ACTIVE
Clearview Electric, Inc.	(888) CLR-VIEW	R/C/I
505 Park Drive Woodbury, NJ 08096	(800) 746-4702 www.clearviewenergy.com	ACTIVE
Commerce Energy, Inc.	1-866-587-8674	R
7 Cedar Terrace Ramsey, NJ 07446	www.commerceenergy.com	ACTIVE
ConEdison Solutions Cherry Tree Corporate Center 535 State Highway Suite 180	(888) 665-0955	C/I ACTIVE
Cherry Hill, NJ 08002	www.conedsolutions.com	ACTIVE
Constellation NewEnergy,	(866) 237-7693	R/C/I
Inc. 900A Lake Street, Suite 2 Ramsey, NJ 07446	www.constellation.com	ACTIVE
Constellation Energy	(877) 997-9995	R
900A Lake Street, Suite 2 Ramsey, NJ 07446	www.constellation.com	ACTIVE
Credit Suisse, (USA) Inc.	(212) 538-3124	С
700 College Road East Princeton, NJ 08450	www.creditsuisse.com	ACTIVE
Direct Energy Business, LLC	(888) 925-9115	C/I
120 Wood Avenue, Suite 611 Iselin, NJ 08830	www.directenergybusiness.com	ACTIVE
Direct Energy Services, LLC	(866) 348-4193	R
120 Wood Avenue, Suite 611 Iselin, NJ 08830	www.directenergy.com	ACTIVE
Discount Energy Group,	(800) 282-3331	R/C
LLC 811 Church Road, Suite 149 Cherry Hill, New Jersey 08002	www.discountenergygroup.com	ACTIVE
Dominion Retail, Inc.	(866) 275-4240	R/C
d/b/a Dominion Energy Solutions 395 Route #70 West Suite 125		ACTIVE
Lakewood, NJ 08701	www.dom.com/products	ACTIVE

DTE Energy Supply, Inc.	(877) 332-2450	C/I
One Gateway Center,		
Suite 2600 Newark, NJ 07102	www.dtesupply.com	ACTIVE
Energy.me Midwest LLC	(855) 243-7270	R/C/I
90 Washington Blvd	(600) 2.0 , 2.0	10 0/1
Bedminster, NJ 07921	www.energy.me	ACTIVE
Energy Plus Holdings LLC	(877) 866-9193	R/C
309 Fellowship Road		
East Gate Center, Suite 200		
Mt. Laurel, NJ 08054	www.energypluscompany.com	ACTIVE
Ethical Electric Benefit Co.	(888) 444-9452	R/C
d/b/a Ethical Electric 100 Overlook Center, 2 nd Fl.	www.ethicalelectric.com	ACTIVE
Princeton, NJ 08540	<u>www.euncalelectric.com</u>	ACTIVE
FirstEnergy Solutions	(800) 977-0500	C/I
300 Madison Avenue	(000) 511 0000	0,1
Morristown, NJ 07962	www.fes.com	ACTIVE
Gateway Energy Services	(800) 805-8586	R/C/I
Corp.		
44 Whispering Pines Lane		ACTIVE
Lakewood, NJ 08701	www.gesc.com	
GDF SUEZ Energy	(866) 999-8374	C/I
Resources NA, Inc.		
333 Thornall Street Sixth Floor		
Edison, NJ 08837	www.gdfsuezenergyresources.com	ACTIVE
Glacial Energy of New	(888) 452-2425	C/I
Jersey, Inc.		
75 Route 15 Building E		
Lafayette, NJ 07848	www.glacialenergy.com	ACTIVE
Global Energy Marketing	(800) 542-0778	C/I
LLC	www.clab.clm.com	A CUDINATE
129 Wentz Avenue Springfield, NJ 07081	www.globalp.com	ACTIVE
	(0.65) 7.67 5010	0.7
Green Mountain Energy Company	(866) 767-5818	C/I
211 Carnegie Center Drive	www.greenmountain.com/commercial-	
Princeton, NJ 08540	home	ACTIVE
1111100011, 113 00570	Home	MOTIVE

Hess Corporation	(800) 437-7872	C/I
1 Hess Plaza Woodbridge, NJ 07095	www.hess.com	ACTIVE
HIKO Energy, LLC	(888) 264-4908	R/C
655 Suffern Road Teaneck, NJ 07666	www.hikoenergy.com	ACTIVE
HOP Energy, LLC d/b/a Metro Energy, HOP Fleet Fueling, HOP Energy Fleet Fueling 1011 Hudson Avenue Ridgefield, NJ 07657	(877) 390-7155 www.hopenergy.com	R/C/I ACTIVE
Hudson Energy Services,	(877) Hudson 9	С
LLC 7 Cedar Street Ramsey, New Jersey 07446	www.hudsonenergyservices.com	ACTIVE
IDT Energy, Inc. 550 Broad Street	(877) 887-6866	R/C
Newark, NJ 07102	www.idtenergy.com	ACTIVE
Independence Energy Group, LLC	(877) 235-6708	R/C
3711 Market Street, 10 th Fl. Philadelphia, PA 19104	www.chooseindependence.com	ACTIVE
Integrys Energy Services, Inc.	(877) 763-9977	C/I
99 Wood Ave, South, Suite 802 Iselin, NJ 08830	www.integrysenergy.com	ACTIVE
Keil & Sons, Inc. d/b/a Systrum Energy	(877) 797-8786	R/C/I
1 Bergen Blvd. Fairview, NJ 07022	www.systrumenergy.com	ACTIVE
Liberty Power Delaware, LLC	(866) 769-3799	C/I
1973 Highway 34, Suite 211 Wall, NJ 07719	www.libertypowercorp.com	ACTIVE
Liberty Power Holdings, LLC	(866) 769-3799	C/I
1973 Highway 34, Suite 211 Wall, NJ 07719	www.libertypowercorp.com	ACTIVE

Linde Energy Services	(800) 247-2644	C/I
575 Mountain Avenue Murray Hill, NJ 07974	www.linde.com	ACTIVE
Marathon Power LLC 302 Main Street	(888) 779-7255	R/C/I
Paterson, NJ 07505	www.mecny.com	ACTIVE
MXenergy Electric Inc.	(800) 785-4374	R/C/I
900 Lake Street Ramsey, NJ 07446	www.mxenergy.com	ACTIVE
NATGASCO, Inc.	(973) 678-1800 x. 251	R/C
532 Freeman St. Orange, NJ 07050	www.supremeenergyinc.com	ACTIVE
NextEra Energy Services	(877) 528-2890 Commercial	R/C/I
New Jersey, LLC 651 Jernee Mill Road	(800) 882-1276 Residential	
Sayreville, NJ 08872	www.nexteraenergyservices.com	ACTIVE
New Jersey Gas & Electric	(866) 568-0290	R/C
1 Bridge Plaza fl. 2 Fort Lee, NJ 07024	www.NJGandE.com	ACTIVE
Noble Americas Energy	(877) 273-6772	C/I
Solutions	(6/1) 2/3 3/12	
The Mac-Cali Building 581 Main Street, 8th Floor	www.noblesolutions.com	ACTIVE
Woodbridge, NJ 07095	www.nobiesofutions.com	ACTIVE
North American Power and	(888) 313-9086	R/C/I
Gas, LLC		
222 Ridgedale Avenue Cedar Knolls, NJ 07927	www.napower.com	ACTIVE
Palmco Power NJ, LLC	(877) 726-5862	R/C/I
One Greentree Centre		
10,000 Lincoln Drive East, Suite 201		
Marlton, NJ 08053	www.PalmcoEnergy.com	ACTIVE
Pepco Energy Services, Inc.	(800) ENERGY-9 (363-7499)	C/I
112 Main St. Lebanon, NJ 08833	www.pepco-services.com	ACTIVE
Plymouth Rock Energy, LLC	(855) 32-POWER (76937)	R/C/I
338 Maitland Avenue		
Teaneck, NJ 07666	www.plymouthenergy.com	ACTIVE

PPL Energy Plus, LLC 811 Church Road	(800) 281-2000	C/I
Cherry Hill, NJ 08002	www.pplenergyplus.com	ACTIVE
Public Power & Utility of New Jersey, LLC 39 Old Ridgebury Rd. Suite 14 Danbury, CT 06810	(888) 354-4415 www.ppandu.com	R/C/I ACTIVE
Reliant Energy 211 Carnegie Center Princeton, NJ 08540	(877) 297-3795 (877) 297-3780 www.reliant.com/pjm	R/C/I ACTIVE
ResCom Energy LLC 18C Wave Crest Ave. Winfield Park, NJ 07036	(888) 238-4041 http://rescomenergy.com	R/C/I ACTIVE
Respond Power LLC 10 Regency CT Lakewood, NJ 08701	(877) 973-7763 <u>www.respondpower.com</u>	R/C/I ACTIVE
South Jersey Energy Company 1 South Jersey Plaza, Route 54 Folsom, NJ 08037	(800) 266-6020 www.southjerseyenergy.com	C/I ACTIVE
Sperian Energy Corp. 1200 Route 22 East, Suite 2000 Bridgewater, NJ 08807	(888) 682-8082	R/C/I ACTIVE
S.J. Energy Partners, Inc. 208 White Horse Pike, Suite 4 Barrington, N.J. 08007	(800) 695-0666 <u>www.sjnaturalgas.com</u>	R/C ACTIVE
Spark Energy, L.P. 2105 CityWest Blvd., Ste 100 Houston, Texas 77042	(800) 441-7514 <u>www.sparkenergy.com</u>	R/C/I ACTIVE
Sprague Energy Corp. 12 Ridge Road Chatham Township, NJ 07928	(800) 225-1560 www.spragueenergy.com	C/I ACTIVE
Starion Energy PA Inc. 101 Warburton Avenue Hawthorne, NJ 07506	(800) 600-3040 www.starionenergy.com	R/C/I ACTIVE
Stream Energy 309 Fellowship Rd., Suite 200 Mt. Laurel, NJ 08054	(877) 39-8150 www.streamenergy.net	R ACTIVE

UGI Energy Services, Inc.	(856) 273-9995	C/I
d/b/a GASMARK		
224 Strawbridge Drive		
Suite 107		
Moorestown, NJ 08057	www.ugienergyservices.com	ACTIVE
Verde Energy USA, Inc.	(800) 388-3862	R/C/I
50 East Palisades Avenue		
Englewood, NJ 07631	www.lowcostpower.com	ACTIVE
Viridian Energy	(866) 663-2508	R/C/I
2001 Route 46, Waterview		
Plaza		
Suite 310		
Parsippany, NJ 07054	www.viridian.com	ACTIVE
Xoom Energy New Jersey,	(888) 997-8979	R/C/I
LLC		
744 Broad Street		
Newark, NJ 07102	www.xoomenergy.com	ACTIVE
YEP Energy	(855) 363-7736	R/C/I
89 Headquarters Plaza North		
#1463		
Morristown, NJ 07960	www.yepenergyNJ.com	ACTIVE
Your Energy Holdings, LLC	(855) 732-2493	R/C/I
One International Boulevard		
Suite 400		
Mahwah, NJ 07495-0400	www.thisisyourenergy.com	ACTIVE

Back to the main supplier page

PSE&G GAS SERVICE TERRITORY Last Updated: 10/24/12

$*\underline{CUSTOMER\ CLASS} - R - RESIDENTIAL\ C - COMMERCIAL\ I - INDUSTRIAL$

Supplier	Telephone & Web Site	*Customer Class
Ambit Northeast, LLC 103 Carnegie Center Suite 300	(877)-30-AMBIT (877) 302-6248	R/C
Princeton, NJ 08540	www.ambitenergy.com	ACTIVE
Astral Energy LLC 16 Tyson Place Bergenfield, NJ 07621	888-850-1872 www.astralenergyllc.com	R/C/I ACTIVE
BBPC, LLC Great Eastern Energy 116 Village Blvd. Suite 200	888-651-4121	C/I
Princeton, NJ 08540	www.greateasternenergy.com	ACTIVE
Clearview Electric Inc. d/b/a Clearview Gas 1744 Lexington Ave.	800-746-4720	R/C
Pennsauken, NJ 08110	www.clearviewenergy.com	ACTIVE
Colonial Energy, Inc. 83 Harding Road	845-429-3229	C/I
Wyckoff, NJ 07481	www.colonialgroupinc.com	ACTIVE
Commerce Energy, Inc. 7 Cedar Terrace	(888) 817-8572	R
Ramsey, NJ 07746	www.commerceenergy.com	ACTIVE
Compass Energy Services, Inc. 1085 Morris Avenue, Suite 150 Union, NJ 07083	866-867-8328 908-638-6605 <u>www.compassenergy.net</u>	C/I ACTIVE
ConocoPhillips Company 224 Strawbridge Drive, Suite 107	800-646-4427	C/I
Moorestown, NJ 08057	www.conocophillips.com	ACTIVE
Consolidated Edison Energy, Inc. d/b/a Con Edison Solutions 535 State Highway 38, Suite 140	888-686-1383 x2130 www.conedenergy.com	
Cherry Hill, NJ 08002	www.concucrergy.com	

Consolidated Edison Solutions, Inc.	888-665-0955	C/I
Cherry Tree Corporate Center 535 State Highway 38, Suite 140 Cherry Hill, NJ 08002	www.conedsolutions.com	ACTIVE
Constellation NewEnergy-Gas	(800) 900-1982	C/I
Division, LLC 900A Lake Street, Suite 2 Ramsey, NJ 07466	www.constellation.com	ACTIVE
Direct Energy Business, LLC	888-925-9115	C/I
120 Wood Avenue, Suite 611 Iselin, NJ 08830	www.directenergy.com	ACTIVE
Direct Energy Services, LLP	866-348-4193	R
120 Wood Avenue, Suite 611 Iselin, NJ 08830	www.directenergy.com	ACTIVE
Gateway Energy Services Corp.	800-805-8586	R/C/I
44 Whispering Pines Lane Lakewood, NJ 08701	www.gesc.com	ACTIVE
UGI Energy Services, Inc.	856-273-9995	C/I
d/b/a GASMARK 224 Strawbridge Drive, Suite 107 Moorestown, NJ 08057	www.ugienergyservices.com	ACTIVE
Global Energy Marketing, LLC	800-542-0778	C/I
129 Wentz Avenue Springfield, NJ 07081	www.globalp.com	ACTIVE
Great Eastern Energy	888-651-4121	C/I
116 Village Blvd., Suite 200 Princeton, NJ 08540	www.greateastern.com	ACTIVE
Greenlight Energy	718-204-7467	С
330 Hudson Street, Suite 4 Hoboken, NJ 07030	www.greenlightenergy.us	ACTIVE
Hess Energy, Inc.	800-437-7872	C/I
One Hess Plaza Woodbridge, NJ 07095	www.hess.com	ACTIVE
Hess Small Business Services, LLC One Hess Plaza	888-494-4377	C/I
Woodbridge, NJ 07095	www.hessenergy.com	ACTIVE
HIKO Energy, LLC 655 Suffern Road	(888) 264-4908	R/C
Teaneck, NJ 07666	www.hikoenergy.com	ACTIVE

Hudson Energy Services, LLC 7 Cedar Street	877- Hudson 9	С
Ramsey, NJ 07446	www.hudsonenergyservices.com	ACTIVE
IDT Energy, Inc.	877-887-6866	R/C
550 Broad Street Newark, NJ 07102	www.idtenergy.com	ACTIVE
Integrys Energy Services – Natural	800-536-0151	C/I
Gas, LLC 99 Wood Avenue South		
Suite #802 Iselin, NJ 08830	www.integrysenergy.com	ACTIVE
Intelligent Energy	800-927-9794	R/C/I
2050 Center Avenue, Suite 500 Fort Lee, NJ 07024	www.intelligentenergy.org	ACTIVE
Keil & Sons, Inc.	1-877-797-8786	R/C/I
d/b/a Systrum Energy 1 Bergen Blvd.		
Fairview, NJ 07022	www.systrumenergy.com	ACTIVE
Major Energy Services, LLC 10 Regency CT	888-625-6760	R/C/I
Lakewood, NJ 08701	www.majorenergy.com	ACTIVE
Marathon Power LLC	888-779-7255	R/C/I
302 Main Street Paterson, NJ 07505	www.mecny.com	ACTIVE
Metromedia Energy, Inc.	800-828-9427	С
6 Industrial Way Eatontown, NJ 07724	www.metromediaenergy.com	ACTIVE
Metro Energy Group, LLC	888-53-Metro	R/C
14 Washington Place Hackensack, NJ 07601	www.metroenergy.com	ACTIVE
MxEnergy, Inc.	800-758-4374	R/C/I
900 Lake Street Ramsey, NJ 07446	www.mxenergy.com	ACTIVE
NATGASCO (Mitchell Supreme) 532 Freeman Street	800-840-4GAS	С
Orange, NJ 07050	www.natgasco.com	ACTIVE
New Energy Services LLC	800-660-3643	R/C/I
101 Neptune Avenue Deal, New Jersey 07723	www.newenergyservicesllc.com	ACTIVE

New Jersey Gas & Electric	866-568-0290	R/C
1 Bridge Plaza, Fl. 2 Fort Lee, NJ 07024	www.NJGandE.com	ACTIVE
Noble Americas Energy Solutions The Mac-Cali Building 581 Main Street, 8th fl.	877-273-6772	C/I
Woodbridge, NJ 07095	www.noblesolutions.com	ACTIVE
North American Power & Gas, LLC d/b/a North American Power 197 Route 18 South Ste. 3000 East Brunswick, NJ 08816	(888) 313-9086 <u>www.napower.com</u>	R/C/I ACTIVE
Palmco Energy NJ, LLC One Greentree Centre 10,000 Lincoln Drive East, Suite 201	877-726-5862	R/C/I
Marlton, NJ 08053	www.PalmcoEnergy.com	ACTIVE
Pepco Energy Services, Inc. 112 Main Street	800-363-7499	C/I
Lebanon, NJ 08833	www.pepco-services.com	ACTIVE
Plymouth Rock Energy, LLC 338 Maitland Avenue	855-32-POWER (76937)	R/C/I
Teaneck, NJ 07666	www.plymouthenergy.com	ACTIVE
PPL EnergyPlus, LLC 811 Church Road - Office 105 Cherry Hill, NJ 08002	800-281-2000 www.pplenergyplus.com	C/I ACTIVE
Respond Power LLC	(877) 973-7763	R/C/I
10 Regency CT Lakewood, NJ 08701	www.respondpower.com	ACTIVE
South Jersey Energy Company 1 South Jersey Plaza, Route 54	800-266-6020	C/I
Folsom, NJ 08037	www.southjerseyenergy.com	ACTIVE
S.J. Energy Partners, Inc. 208 White Horse Pike, Suite 4	800-695-0666	R/C
Barrington, NJ 08007	www.sjnaturalgas.com	ACTIVE
Spark Energy Gas, L.P. 2105 CityWest Blvd, Ste 100	800-411-7514	R/C/I
Houston, Texas 77042	www.sparkenergy.com	ACTIVE
Sprague Energy Corp. 12 Ridge Road	855-466-2842	C/I
Chatham Township, NJ 07928	www.spragueenergy.com	ACTIVE

Stuyvesant Energy LLC	800-640-6457	C
10 West Ivy Lane, Suite 4 Englewood, NJ 07631	www.stuyfuel.com	ACTIVE
Stream Energy New Jersey, LLC	(973) 494-8097	R/C
309 Fellowship Road Suite 200	www.stroomonorgy.not	ACTIVE
Mt. Laurel, NJ 08054	www.streamenergy.net	ACTIVE
Systrum Energy	877-797-8786	R/C/I
1 Bergen Blvd. Fairview, NJ 07022	www.systrumenergy.com	ACTIVE
Woodruff Energy	800-557-1121	R/C/I
73 Water Street	1 66	A CONTENT
Bridgeton, NJ 08302	www.woodruffenergy.com	ACTIVE
Woodruff Energy US LLC	856-455-1111	C/I
73 Water Street, P.O. Box 777	800-557-1121	
Bridgeton, NJ 08302	www.woodruffenergy.com	ACTIVE
Xoom Energy New Jersey, LLC	888-997-8979	R/C/I
744 Broad Street		
Newark, NJ 07102	<u>www.xoomenergy.com</u>	ACTIVE
Your Energy Holdings, LLC	(855) 732-2493	R/C/I
One International Boulevard		
Suite 400		
Mahwah, NJ 07495-0400	www.thisisyourenergy.com	ACTIVE

Back to main supplier information page



0.827446652

Description	QTY	Manufacturer Name	Model No.	Serial No.	Equipment Type / Utility	Capacity/Size /Efficiency	Location	Areas/Equipment Served	Date Installed	Remaining Useful Life (years)	Other Info.
B-1	1	Smith	28HE-9	132144	Heating / Natural Gas	2,718 MBH input, 2,249 MBH output (82.7%)	MER	School	2005	16	
B-2	1	Smith	28HE-9	132142	Heating / Natural Gas	2,718 MBH input, 2,249 MBH output (82.7%)	MER	School	2005	16	
Window Air Conditioners	10	Various	Various	Various	DX Cooling / Electric	8,000 - 24,000 btu/h (10.7 EER)	Classroom Windows	Classroom	2005	6	
AHU-1	1	No nameplate	No nameplate	No nameplate	Heating / Natural Gas	5 HP	3rd Floor	Gymnasium	1955	0	Used for recirculation only (no ventilation)
AHU-2	1	Unknown	ITF-HV	Unknown	Heating / Natural Gas	Unknown	3rd Floor	Auditorium	1955	0	Used for recirculation only (no ventilation)
ACU	8	Airedale	SCHP-2	PA1112-U1903	DX Cooling / Electric	Unknown	Kindergarten Classrooms	Kindergarten Classrooms	1996	2	

Cost of Electricity:

\$0.138 \$/kWh \$6.61 \$/kW

1											
			No. of			Watts per				Retrofit Control	
Field	Area Description Unique description of the location - Room number/Room	Usage Describe Usage Type	Fixtures No. of	Standard Fixture Code Lighting Fixture Code	Fixture Code Code from Table of Standard Fixture	Fixture e Value from	kW/Space (Watts/Fixt) * (Fixt	Exist Control Pre-inst. control	Annual Hours Annual kWh Estimated (kW/space) *	Retrofit control	Notes
Code	name: Floor number (if applicable)	using Operating Hours	fixtures	Lighting Fixture Code	Wattages	Table of	No.)	device	annual hours for (Annual Hours)	device	Notes
			before the			Standard			the usage group		
			retrofit			Fixture					
20LED	300 Classroom	Classrooms	18	S 32 C F 1 (ELE)	F41LL	Wattages 32	0.58	SW	2400 1,382	C-OCC	
20LED	301 Classroom	Classrooms	18	S 32 C F 1 (ELE)	F41LL	32	0.58	SW	2400 1,382		
20LED	302 Classroom	Classrooms	15	S 32 C F 1 (ELE)	F41LL	32	0.48	SW	2400 1,152		
20LED 20LED	303 Classroom Corridor	Classrooms Hallways	15	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.48 0.10	SW SW	2400 1,152 2280 219		
20LED 20LED	Stair	Stairways	2	S 32 C F 1 (ELE)	F41LL	32	0.10	SW	6240 399		
20LED	Stair	Stairway	4	S 32 C F 1 (ELE)	F41LL	32	0.13	SW	6240 799		
20LED	304 Computer Room	Classrooms	15	S 32 C F 1 (ELE)	F41LL	32	0.48	SW	2400 1,152		
0LED	305 Classroom	Classrooms	15	S 32 C F 1 (ELE)	F41LL F41LL	32	0.48	SW	2400 1,152		
0LED	306 Classroom 308 Classroom	Classrooms Classrooms	19 17	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.61 0.54	SW SW	2400 1,459 2400 1,306		
OLED	310 Classroom	Classrooms	15	S 32 C F 1 (ELE)	F41LL	32	0.48	SW	2400 1,500		
0LED	Corridor	Hallways	4	S 32 C F 1 (ELE)	F41LL	32	0.13	SW	2280 292	NONE	
OLED	Mens TR	Restroom	1	S 32 C F 1 (ELE)	F41LL	32	0.03	SW	2400 77		
OLED	UN-52 UN-53	Storage Areas Storage Areas	1 1	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.03 0.03	SW SW	1000 32 1000 32		
OLED	UN-53 UN-54	Storage Areas Storage Areas	1 1	S 32 C F 1 (ELE)	F41LL F41LL	32	0.03	SW	1000 32		
0LED	UN-50	Storage Areas	1	S 32 C F 1 (ELE)	F41LL	32	0.03	SW	1000 32		
0LED	UN-51	Storage Areas	1	S 32 C F 1 (ELE)	F41LL	32	0.03	SW	1000 32	C-OCC	
OLED	Corridor	Hallways	11	S 32 C F 1 (ELE)	F41LL	32	0.35	SW	2280 803		
OLED 20LED	314A Office 314B Art	Offices Classrooms	13	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.19 0.42	SW SW	2400 461 2400 998		
OLED	314	Classrooms	1	S 32 C F 1 (ELE)	F41LL F41LL	32	0.03	SW	2400 996		
20LED	316 Science	Classrooms	12	S 32 C F 1 (ELE)	F41LL	32	0.38	SW	2400 922	C-OCC	
0LED	318 Classroom	Classrooms	12	S 32 C F 1 (ELE)	F41LL	32	0.38	SW	2400 922		
0LED	320 Classroom 313 Storage	Classrooms Storage Areas	12	S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.38	SW SW	2400 922 1000 32		
0LED	313 Storage	Storage Areas	1	S 32 C F 1 (ELE) T 32 R F 2 (ELE)	F41LL F42LL	60	0.03 0.06	SW	1000 32 1000 60		
OLED	309 Storage	Storage Areas	1	T 32 R F 2 (ELE)	F42LL	60	0.06	SW	1000 60		
0LED	307 Utility Room	Storage Areas	5	T 32 R F 2 (ELE)	F42LL	60	0.30	SW	1000 300	NONE	
10LED	Storage	Storage Areas	1	T 32 R F 2 (ELE)	F42LL	60	0.06	SW	1000 60		
10LED 20LED	Stairs 200 Classroom	Stairway Classrooms	2 15	T 32 R F 2 (ELE) S 32 C F 1 (ELE)	F42LL F41LL	60 32	0.12 0.48	SW SW	6240 749 2400 1,152		
20LED	201 Classroom	Classrooms	15	S 32 C F 1 (ELE)	F41LL	32	0.48	SW	2400 1,152		
0LED	202 Classroom	Classrooms	15	S 32 C F 1 (ELE)	F41LL	32	0.48	SW	2400 1,152		
20LED	203 Nurse Office	Offices	12	S 32 C F 1 (ELE)	F41LL	32	0.38	SW	2400 922		
OLED 20LED	Exam Room UN-29	Offices	3	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32	0.10 0.03	SW SW	2400 230 1000 32		
OLED	UN-28	Storage Areas Storage Areas	1	S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.03	SW	1000 32 1000 32		
OLED	Corridor	Hallways	4	S 32 C F 1 (ELE)	F41LL	32	0.13	SW	2280 292		
0LED	Stair	Stairway	3	S 32 C F 1 (ELE)	F41LL	32	0.10	SW	6240 599		
OLED	204 Classroom	Classrooms	15	S 32 C F 1 (ELE)	F41LL	32	0.48	SW	2400 1,152		
0LED 0LED	Storage 205 Classroom	Storage Areas Classrooms	15	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.03 0.48	SW SW	1000 32 2400 1,152		
OLED	Storage	Storage Areas	1	S 32 C F 1 (ELE)	F41LL	32	0.03	SW	1000 32		
0LED	Corridor	Hallways	6	S 32 C F 1 (ELE)	F41LL	32	0.19	SW	2280 438		
0LED	206 Classroom	Classrooms	15	S 32 C F 1 (ELE)	F41LL	32	0.48	SW	2400 1,152		
OLED	Storage 208 Classroom	Storage Areas Classrooms	1 15	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.03 0.48	SW SW	1000 32 2400 1,152		
OLED	Storage	Storage Areas	1	S 32 C F 1 (ELE)	F41LL F41LL	32	0.48	SW	1000 32		
0LED	210 Classroom	Classrooms	15	S 32 C F 1 (ELE)	F41LL	32	0.48	SW	2400 1,152		
0LED	Storage	Storage Areas	1	S 32 C F 1 (ELE)	F41LL	32	0.03	SW	1000 32		
OLED	Girls Locker Room UN-43	Locker Storage Areas	6 4	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32	0.19 0.13	SW SW	2400 461 1000 128		
OLED	UN-43 Corridor	Storage Areas Hallways	8	T 32 R F 2 (ELE)	F41LL F42LL	32 60	0.13	SW	1000 128 2280 1,094		
0LED	Storage	Storage Areas	2	T 32 R F 2 (ELE)	F42LL	60	0.12	SW	1000 120		
0LED	131 Main Office	Offices	21	S 32 C F 1 (ELE)	F41LL	32	0.67	SW	2400 1,613	C-OCC	
LED	103A Principal Office	Offices	10	S 32 C F 1 (ELE)	F41LL	32	0.32	SW	2400 768		
)LED	100A TR 103C	Restroom Offices	5	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.03 0.16	SW SW	2400 77 2400 384		
LED	103B Storage	Storage Areas	2	S 32 C F 1 (ELE)	F41LL	32	0.06	SW	1000 64		
0LED	Vest	Hallways	2	S 32 C F 1 (ELE)	F41LL	32	0.06	SW	2280 146	NONE	
0LED	Corridor	Hallways	2	S 32 C F 1 (ELE)	F41LL	32	0.06	SW	2280 146		
0LED	101 Office	Offices	5	S 32 C F 1 (ELE)	F41LL	32	0.16	SW	2400 384		
36 OLED	101A TR 103 Boys TR	Restroom Restroom	6	2T 3' 17 R F 1 (ELE) S 32 C F 1 (ELE)	F21ILL F41LL	20 32	0.02 0.19	SW SW	2400 48 2400 461		
0LED	Storage	Storage Areas	1	S 32 C F 1 (ELE)	F41LL F41LL	32	0.19	SW	1000 32		
0LED	105 Storage	Storage Areas	1	S 32 C F 1 (ELE)	F41LL	32	0.03	SW	1000 32	C-OCC	
0LED	Corridor	Hallways Hallways	3	S 32 C F 1 (ELE)	F41LL	32	0.10	SW	2280 219		
34LED	Corridor		1	1T 32 C F 4 (ELE)	F44ILL	112	0.11	SW	2280 255	NONE	

4/25/2014 Page 1, Existing

Cost of Electricity:

\$0.138 \$/kWh \$6.61 \$/kW

					EXISTING CONE	DITIONS				Retrofit	
			No. of			Watts per				Control	
	Area Description	Usage	Fixtures	Standard Fixture Code	Fixture Code	Fixture	kW/Space	Exist Control	Annual Hours Annual kWh		
Field	Unique description of the location - Room number/Room	Describe Usage Type	No. of	Lighting Fixture Code	Code from Table of Standard Fixture		(Watts/Fixt) * (Fixt	Pre-inst. control	Estimated (kW/space) *	Retrofit control	Notes
Code	name: Floor number (if applicable)	using Operating Hours	fixtures		Wattages	Table of	No.)	device	annual hours for (Annual Hours)	device	
			before the			Standard			the usage group		
			retrofit			Fixture					
401 ED	MED 400	D.1. D.	2	T 00 D E 0 (EL E)	54011	Wattages	0.40	014/	1000	4 NONE	
40LED	MER 102 107 Classroom	Boiler Room Classrooms	8	T 32 R F 2 (ELE)	F42LL	60	0.48	SW	1820 87		
20LED			18	S 32 C F 1 (ELE)	F41LL	32	0.58	SW	2400 1,38		
20LED 36	106 Storage 109 Storage	Storage Areas Storage Areas	1	S 32 C F 1 (ELE) 2T 3' 17 R F 1 (ELE)	F41LL F21ILL	32 20	0.03	SW SW	1000 3 1000 2		
20LED	Corridor	Hallways	4	S 32 C F 1 (ELE)	F21ILL F41LL	32	0.02	SW	2280 29		
40LED	Corridor	Hallways	4	T 32 R F 2 (ELE)	F41LL F42LL	60	0.06	SW	2280 29		
40LED	Corridor	Hallways	1	T 32 R F 2 (ELE)	F42LL F42LL	60	0.06	SW	2280 13		
34LED	Corridor	Hallways	1	1T 32 C F 4 (ELE)	F44ILL	112	0.00	SW	2280 25		
40LED	108 Office	Offices	9	T 32 R F 2 (ELE)	F42LL	60	0.54	SW	2400 1,29		
20LED	110 Girls TR	Restroom	5	S 32 C F 1 (ELE)	F41LL	32	0.16	SW	2400 1,29		
20LED	110 Girls TR	Restroom	1	S 32 C F 1 (ELE)	F41LL	32	0.03	SW	2400 7		
34LED	112 Library	Classrooms	14	1T 32 C F 4 (ELE)	F44ILL	112	1.57	SW	2400 3,76		
35LED	112A Office	Offices	4	T 32 R F 3 (ELE)	F43ILL/2	90	0.36	SW	2400 86		
34LED	Corridor	Hallways	8	1T 32 C F 4 (ELE)	F44ILL	112	0.90	SW	2280 2,04		
40LED	116 Social Worker	Offices	2	T 32 R F 2 (ELE)	F42LL	60	0.12	SW	2400 28		
40LED	114 Nurse	Offices	5	T 32 R F 2 (ELE)	F42LL	60	0.30	SW	2400 72		
40LED	114A Nurse Office	Offices	2	T 32 R F 2 (ELE)	F42LL	60	0.12	SW	2400 28		
36	TR	Restroom	1	2T 3' 17 R F 1 (ELE)	F21ILL	20	0.02	SW	2400 4		
6LED	120 Cafeteria / Gym	Gymnasium	80	T 34 R F 4 (MAG)	F44EE	144	11.52	SW	2912 33,54	6 NONE	
X4	120A Gym Storage	Storage Areas	3	CF26W	CF26/4-L	108	0.32	SW	1000 32		
40LED	120D Office	Offices	1	T 32 R F 2 (ELE)	F42LL	60	0.06	SW	2400 14		
65	TR	Restroom	1	I 100	1100/1	100	0.10	SW	2400 24		
40LED	120C Office	Offices	1	T 32 R F 2 (ELE)	F42LL	60	0.06	SW	2400 14		
65	120C Office	Offices	1	I 100	l100/1	100	0.10	SW	2400 24		
20LED	120 E3 TR	Restroom	2	S 32 C F 1 (ELE)	F41LL	32	0.06	SW	2400 15		
20LED	120 E1	Storage Areas	2	S 32 C F 1 (ELE)	F41LL	32	0.06	SW	1000 6		
20LED	120 E2	Storage Areas	2	S 32 C F 1 (ELE)	F41LL	32	0.06	SW	1000 6		
20LED	120 E4	Storage Areas	2	S 32 C F 1 (ELE)	F41LL	32	0.06	SW	1000 6		
40LED	118 Kitchen	Kitchen	3	T 32 R F 2 (ELE)	F42LL	60	0.18	SW	3000 54		
40LED	122 Storage	Storage Areas	3	T 32 R F 2 (ELE)	F42LL F44LL	60	0.18	SW	1000 18		
34LED 20LED	Corridor 124 Auditorium	Hallways Auditorium	20	1T 32 C F 4 (ELE) S 32 C F 1 (ELE)	F44ILL F41LL	112 32	0.34 0.64	SW SW	2280 76 1820 1,16		
9LED	124 Auditorium	Auditorium	24	High Bay MH 200 35 Feet High	MH200/1	232	5.57	SW	1820 1,16		
40LED	Stage	Stage	10	T 32 R F 2 (ELE)	F42LL	60	0.60	SW	5000 3,00		
9LED	Stage	Stage	1	High Bay MH 200 35 Feet High	MH200/1	232	0.23	SW	5000 3,00		
40LED	124A Dressing Room	Dressing Room	2	T 32 R F 2 (ELE)	F42LL	60	0.12	SW	8760 1,05		
40LED	124A Bressing Room	Storage Areas	2	T 32 R F 2 (ELE)	F42LL	60	0.12	SW	1000 1,00		
40LED	124B TR	Restroom	1	T 32 R F 2 (ELE)	F42LL	60	0.06	SW	2400 14		
20LED	Corridor	Hallways	12	S 32 C F 1 (ELE)	F41LL	32	0.38	SW	2280 87		
40LED	Corridor	Hallways	7	T 32 R F 2 (ELE)	F42LL	60	0.42	SW	2280 95		
34LED	Corridor	Hallways	2	1T 32 C F 4 (ELE)	F44ILL	112	0.22	SW	2280 51		
35LED	Classroom	Classrooms	12	T 32 R F 3 (ELE)	F43ILL/2	90	1.08	SW	2400 2,59		
35LED	Classroom	Classrooms	12	T 32 R F 3 (ELE)	F43ILL/2	90	1.08	SW	2400 2,59	2 C-OCC	
35LED	Classroom	Classrooms	12	T 32 R F 3 (ELE)	F43ILL/2	90	1.08	SW	2400 2,59		
35LED	Classroom	Classrooms	12	T 32 R F 3 (ELE)	F43ILL/2	90	1.08	SW	2400 2,59		
35LED	Classroom	Classrooms	12	T 32 R F 3 (ELE)	F43ILL/2	90	1.08	SW	2400 2,59		
35LED	Classroom	Classrooms	12	T 32 R F 3 (ELE)	F43ILL/2	90	1.08	SW	2400 2,59		-
35LED	Classroom	Classrooms	12	T 32 R F 3 (ELE)	F43ILL/2	90	1.08	SW	2400 2,59		
35LED	Classroom	Classrooms	12	T 32 R F 3 (ELE)	F43ILL/2	90	1.08	SW	2400 2,59		
40LED	Corridor	Hallways	10	T 32 R F 2 (ELE)	F42LL	60	0.60	SW	2280 1,36	8 NONE	· · · · · · · · · · · · · · · · · · ·
	Total		861				52.42		128,850		

4/25/2014 Page 2, Existing



of Discount	(used for NPV)	
or Discount	(used for the v)	

Utility	/ Costs	Yearly Usage	Metric Ton Carbon Dioxide Equivalent	Building Area	А	nnual Utility Co	st
\$ 0.145	\$/kWh blended		0.000420205	64,762	Electric	Natural Gas	Fuel Oil
\$ 0.138	\$/kWh supply	651,678	0.000420205		\$ 94,811	\$ 22,986	
\$ 6.61	\$/kW	149.2	0	•			-
\$ 1.04	\$/Therm	22,100	0.00533471				
\$ 7.55	\$/kgals		0				
	\$/Gal						

Sussex Avenue

Recommend?		Item			Sa	vings			Cost	Simple	Life	Equivalent CO ₂	NJ Smart Start	Direct Install	Payback w/		Simple Pro	jected Lifetime	Savings		ROI	NPV	IRR
Y or N			kW	kWh	therms	No. 2 Oil gal	Water kgal	\$		Payback	Expectancy	(Metric tons)	Incentives	Eligible (Y/N)	Incentives	kW	kWh	therms	kgal/yr	\$			
N	ECM-1	Replace Door Sweeps and Seals	0.0	0	98	0	0	102	\$ 2,305	22.5	15.0	0.5	-	N	22.5	0.0	0	1,476	0	\$ 1,536	(0.3)	(\$1,083)	-4.7%
Υ	ECM-2	Install Window A/C Controller	0.0	8,726	0	0	0	1,270	\$ 1,900	1.5	15.0	3.7	-	N	1.5	0.0	130,895	0	0	\$ 19,044	9.0	\$13,256	66.8%
Υ	ECM-3A	Install Basic Controls	0.0	24,699	1,442	0	0	5,094	\$ 21,309	4.2	15.0	18.1	-	N	4.2	0.0	370,489	21,636	0	\$ 76,405	2.6	\$39,499	22.8%
N	ECM-3B	Install Full DDC Controls	0.0	26,003	3,542	0	0	7,467	\$ 356,512	47.7	15.0	29.8	-	N	47.7	0.0	390,040	53,129	0	\$ 112,004	(0.7)	(\$267,372)	-11.9%
N	ECM-4	Install Low Flow Plumbing Fixtures	0.0	0	0	0	531	4,009	\$ 231,512	57.7	15.0	0.0	5 -	N	57.7	0.0	0	0	7,965	\$ 60,138	(0.7)	(\$183,650)	-13.5%
N	ECM-L1	Lighting Replacements / Upgrades	30.1	74,141	0	0	0	12,599	\$ 152,679	12.1	15.0	31.2	\$ 3,750	N	11.8	450.9	1,112,116	0	0	\$ 197,562	0.3	\$1,481	3.1%
N	ECM-L2	Install Lighting Controls (Add Occupancy Sensors)	0.0	24,890	0	0	0	3,429	\$ 22,680	6.6	15.0	10.5	\$ 2,940	N	5.8	0.0	373,344	0	0	\$ 54,317	1.4	\$21,198	15.3%
Y	ECM-L3	Lighting Replacements with Controls (Occupancy Sensors)	30.1	85,492	0	0	0	14,163	\$ 175,359	12.4	15.0	35.9	\$ 6,690	N	11.9	450.9	1,282,386	0	0	\$ 222,334	0.3	\$411	3.0%
		Total (Does Not Include 3B, ECM-L1 & ECM-L2)	30.1	118,918	1,541	0	531	\$ 24,638	\$ 432,385	17.5	15.0	58 5	6,690		17.3	451	1,783,770	23,113	7,965	\$ 379,457	(0.1)	(131,567)	-1.7%
		Recommended Measures (highlighted green above)	30.1	118,918	1,442	0	0	\$ 20,527	\$ 198,569	9.7	15.0	58 5	6,690	0	9.3	451	1,783,770	21,636	-	\$ 317,783	0.6	53,166	6.6%
		% of Existing	20%	18%	7%	#DIV/0!	#DIV/0!																

L				
% of Existing	20%	18%	7%	#DI\

		City:	Newar	k, NJ	1		
	Occupied I	Hours/Week	70	70	70	70	50
			Building	Auditorium	Gymnasium	Library	Classrooms
	Enthalpy		Operating	Occupied	Occupied	Occupied	Occupied
Temp	h (Btu/lb)	Bin Hours	Hours	Hours	Hours	Hours	Hours
102.5							
97.5	35.4	6	3	3	3	3	2
92.5	37.4	31	13	13	13	13	9
87.5	35.0	131	55	55	55	55	39
82.5	33.0	500	208	208	208	208	149
77.5	31.5	620	258	258	258	258	185
72.5	29.9	664	277	277	277	277	198
67.5	27.2	854	356	356	356	356	254
62.5	24.0	927	386	386	386	386	276
57.5	20.3	600	250	250	250	250	179
52.5	18.2	730	304	304	304	304	217
47.5	16.0	491	205	205	205	205	146
42.5	14.5	656	273	273	273	273	195
37.5	12.5	1,023	426	426	426	426	304
32.5	10.5	734	306	306	306	306	218
27.5	8.7	334	139	139	139	139	99
22.5	7.0	252	105	105	105	105	75
17.5	5.4	125	52	52	52	52	37
12.5	3.7	47	20	20	20	20	14
7.5	2.1	34	14	14	14	14	10
2.5	1.3	1	0	0	0	0	0
-2.5							
-7.5							
		8,760					


Multipliers	
Material:	1.027
Labor:	1.246
Equipment:	1.124

Heating System Efficiency	80%
Cooling Eff (kW/ton)	1.2

He	Heating						
Hours	4,427	Hrs					
Weighted Avg	40	F					
Avg	28	F					

Co	oling	
Hours	4,333	Hrs
Weighted Avg	68	F
Avg	78	F

		Post	
	Existing	Recommneded	Percent
	Conditions	ECMs	Savings
Costs (\$)	117,797	97,270	17%
Electricity (kWh)	651,678	532,760	18%
Natural Gas (therms)	22,100	20,658	7%
Fuel Oil (Gal)	0	0	#DIV/0!
Site EUI (kbtu/SF/Yr)	68.5	60.0	



Newark Board of Education - NJBPU

CHA Project Number: 27999


Sussex Avenue


Utility End Use Analysis						
Electric	ity Use (kWh):	Notes/Comments:				
651,678	Total	Based on utility analysis				
205,000	Lighting	From Lighting Calculations				
85,600	Motors	Estimated				
32,381	A/C	See Window AC Calculation				
150,667	Plug Load	Estimated				
20,750	Kitchen	Estimated				
87,600	Computers	Estimated				
69,680	Other	Remaining				
Natural Ga	ıs Use (Therms):	Notes/Comments:				
22,100	Total	Based on utility analysis				
,	Boilers	Therms/SF x Square Feet Served				
	RTU, AHU	Based on utility analysis				
2,652	DHW	Based on utility analysis				

31% 13% 5% 23% 3% 13% 11%

0.12

0.772057688 0.107942312





ECM-XX: Install Door Seals

Description: This ECM evaluates the thermal and electrical savings associate with adding door seals and sweeps to prevent infiltration of cold (hot) outdoor air.

Heating System Efficiency
Cooling System Efficiency
Linear Feet of Door Edge
Existing Infiltration Factor*

Proposed Infiltration Factor*

*Infiltration Factor per Carrier Handbook of Air Conditioning System Design

Ex Occupied Clng Temp.
Ex Unoccupied Clng Temp.
Cooling Occ Enthalpy Setpoint
Cooling Unocc Enthalpy Setpoint

80 *F 27.5 Btu/lb 27.5 Btu/lb

Ex Occupied Htg Temp. Ex Unoccupied Htg Temp. Electricity Natural Gas

	80	*F
	80	*F
\$	0.15	\$/kWl
\$	1.04	\$/ther

based on average door seal gap calculated below.

					EXISTING LOADS PROPOSED LOADS		COOLING ENERGY		HEATING ENERGY			
					Occupied	Unoccupied	Occupied	Unoccupied				
									Existing			Proposed
Avg Outdoor		Existing	Occupied	Unoccupied		Door		Door	Cooling	Proposed	Existing Heating	Heating
Air Temp.	_			Equipment Bin		Infiltration	Door Infiltration	Infiltration	Energy	Cooling Energy	Energy	Energy
Bins °F	Air Enthalpy	Hours	Hours	Hours	Load BTUH		Load BTUH		kWh	kWh	therms	therms
Α		В	С	D	E	F	G	н	I	J	K	L
100 F	0.0	0	0	0	F F60	F F60	1 671	1.671	0		0	
102.5	0.0 35.4	0	0	0	5,569		1,671 -480	1,671 -480	0	0	0	0
97.5 92.5	35.4 37.4	31	3 13	4 18	-1,601 -2,005	-1,601 -2,005			0	0	0	0
92.5 87.5	37.4 35.0	131	55	76	-2,005 -1,516	· ·			0	0		0
82.5	33.0	500	208	76 292	-1,123		-337	-337	0	0		0
77.5	31.5	620	258 258	362	122	122	36		0	0		0
77.5 72.5	29.9	664	277	387	365	365	109		0	0	2	1
67.5	29.9 27.2	854	356	498	608	608	182		0	0	6	1
62.5	24.0	927	386	541	851	851	255		0	0	10	3
57.5	20.3	600	250	350	1,094	1,094	328	328	0	0	8	2
52.5	18.2	730	304	426	1,337	1,337	401	401	0	0	12	1
47.5	16.0	491	205	286	1,580		474	474	0	0	10	3
42.5	14.5	656	273	383	1,823	1,823	547	547	0	0	15	4
37.5	12.5	1,023	426	597	2,066		620		0	0	26	8
32.5	10.5	734	306	428	2,309		693		0	0	21	6
27.5	8.7	334	139	195	2,552	2,552			0	0	11	3
22.5	7.0	252	105	147	2,795		838	838	0	0	9	3
17.5	5.4	125	52	73	3,038		911	911	0	0	5	1
12.5	3.7	47	20	27	3,281	3,281	984	984	0	0	2	1
7.5	2.1	34	14	20	3,524	3,524	1,057	1,057	0	0	1	0
2.5	1.3	1	0	1	3,767	3,767	1,130	1,130	0	0	0	C
-2.5	0.0	0	0	0	4,010	4,010	1,203		0	0	0	C
-7.5	0.0	0	0	0	4,253	4,253			0	0	0	C
TOTALS		8,760	3,650	5,110					0	0	141	42

Existing Door Infiltration Existing Unoccupied Door Infiltration Proposed Door Infiltration Proposed Unoccupied Door Infiltration

45 cfm 45 cfm 14 cfm 14 cfm

Savings	98	therms	\$ 102
	0	kWh	\$ •
			\$ 102

Door	Width (ft)	Height (ft)	Linear Feet (LF)	gap (in)	gap location	LF of gap	% door w/ gap	Average gap for door (in)
1	3	7	20	0.25	bottom/seam	3	15%	0.0375
2	3	7	20	0.25	bottom/seam	3	15%	0.0375
3	3	7	20	0.25	bottom/seam	3	15%	0.0375
4	3	7	20	0.25	bottom/seam	3	15%	0.0375
5	3	7	20	0.125	bottom/seam	3	15%	0.01875
6	3	7	20	0.125	bottom/seam	3	15%	0.01875
7	3	7	20	0.125	bottom/seam	3	15%	0.01875
8	3	7	20	0.0625	bottom/seam	3	15%	0.009375
9	3	7	20	0.25	bottom/seam	3	15%	0.0375
10	3	7	20	0.25	bottom/seam	3	15%	0.0375
Total	30	70	200	0.194		30	15%	0.029

Note: Doors labeled 'a', 'b', etc. are a part of the same door assembly.

ECM-XX: Install Door Seals - Cost

Multipliers	
Material:	1.03
Labor:	1.25
Equipment:	1.12

Description	QTY L	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL	REMARKS
Description	QII	OIVII	MAT.		EQUIP.	MAT.	LABOR	EQUIP.	COST	KEWAKKS
									\$ -	
Door Weatherization Seals & Sweeps	10	EA	\$ 40	\$ 115	\$ -	\$ 411	\$ 1,433	\$ -	\$ 1,844	
						\$ -	\$ -	\$ -	\$ -	

^{**}Cost Estimates are for Energy Savings calculations only, do not use for procurement

\$ 1,844	Subtotal
\$ 461	25% Contingency
\$ 2,305	Total

Newark Board of Education - NJBPU CHA Project Number: 27999

Sussex Avenue

ECM-2: Window A/C Controller

ECM Description: Window A/C units are currently controlled manually by the occupants and are not turned off when the room is unoccupied. This ECM evaluates implementation of a digital timer device that will automatically turn the window A/C unit off at a preset time.

ASSUMPTIO	NS	Comments		
Electric Cost	\$0.145	/ kWh		
Average run hours per Week	80	Hours		
Space Balance Point	55	F		
Space Temperature Setpoint	65	deg F	Setpoint.	
BTU/Hr Rating of existing DX equipment	120,000	Btu / Hr	Total BTU/hr of Window AC units	
Average EER	10.7			
Existing Annual Electric Usage	14,985	kWh		

<u>Item</u>	<u>Value</u>	<u>Units</u>	<u>Comments</u>
Proposed Annual Electric Usage	6,259	kWh	Unit will cycle on w/ temp of room. Possible operating time shown below

ANNUAL SAVINGS							
Annual Electrical Usage Savings	8,726	kWh					
Annual Cost Savings	\$1,270						
Total Project Cost	\$1,900						
Simple Payback	1	years					

OAT - DB		Existing	Proposed % of	Proposed
Bin	Annual	Hours of	hrs of	
Temp F	Hours	Operation	time of operation	Operation
102.5	0	0	100%	0
97.5	6	3	89%	3
92.5	31	15	79%	12
87.5	131	62	68%	43
82.5	500	238	58%	138
77.5	620	295	47%	140
72.5	664	316	37%	116
67.5	854	407	26%	107
62.5	927	0	0%	0
57.5	600	0	0%	0
52.5	730	0	0%	0
47.5	491	0	0%	0
42.5	656	0	0%	0
37.5	1,023	0	0%	0
32.5	734	0	0%	0
27.5	334	0	0%	0
22.5	252	0	0%	0
17.5	125	0	0%	0
12.5	47	0	0%	0
7.5	34	0	0%	0
2.5	1	0	0%	0
-2.5	0	0	0%	0
-7.5	0	0	0%	0
Total	8,760	1,336	42%	558

ECM-2: Window A/C Controller - Cost

Multipliers	
Material:	1.03
Labor:	1.25
Equipment:	1.12

Description	QTY	UNIT	UNIT COSTS		SUBTOTAL COSTS		TOTAL	REMARKS		
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.	COST	REWARKS
						0	\$ -	\$ -	\$ -	
Window AC Controller	10	EA	\$ 150	\$ -	\$ -	1540.5	\$ -	\$ -	\$ 1,541	Est wireless A/C controller
						\$ -	\$ -	\$ -	\$ -	

^{**}Cost Estimates are for Energy Savings calculations only, do not use for procurement

\$ 1,541	Subtotal
\$ 385	25% Contingency
\$ 1,900	Total

Newark Board of Education - NJBPU

CHA Project Number: 27999

Sussex Avenue

ECM-3A: Basic Controls

Description: This ECM evaluates adding automatic temperature controls that will turn the boilers on/off based on outdoor air and indoor air temperatures.

Day Se	etback		_				
EXISTING CONDITIONS							
Heating							
Heating Season Facility Temp	80	F	Th				
Weekly Occupied Hours	70	hrs	Н				
Heating Season Setback Temp	75	F	Sh				
Heating Season % Savings per	3%		Ph				
Annual Boiler Capacity		Mbtu/yr					
Connected Heating Load	579,036	Btu/hr	Caph				
Equivalent Full Load Heating	900	hrs	EFLHh				
Heating Equipment Efficiency	80%		AFUEh				
Cooling							
Cooling Season Facility Temp	74	F	Tc				
Weekly Occupied Hours	70	hrs	Н				
Cooling Season Setback Temp	79	F	Sc				
Cooling Season % Savings per	6%		Pc				
Connected Cooling Load	10	Tons	Capc				
Equivalent Full Load Cooling	381	hrs	EFLHc				
Cooling Equipment EER	14.0		AFUEc				
SAVINGS							
Natural Gas Savings	541	Therms ³					
Cooling Electricity Savings	12,404	kWh]				

Nighttime Setback						
EXISTING CONDITIONS						
Heating						
Heating Season Facility Temp	80	F				
Weekly Occupied Hours	70	hrs				
Heating Season Setback Temp	65	F				
Heating Season % Savings per	3%					
Annual Boiler Capacity		Mbtu/yr				
Connected Heating Load Capacity	579,036	Btu/hr				
Equivalent Full Load Heating Hours	500	hrs				
Heating Equipment Efficiency	80%					
Cooling						
Cooling Season Facility Temp	74	F				
Weekly Occupied Hours	70	hrs				
Cooling Season Setback Temp	80	F				
Cooling Season % Savings per	6%					
Connected Cooling Load Capacity	10	Tons				
Equivalent Full Load Cooling Hours	381	hrs				
Cooling Equipment EER	14.0					
SAVINGS						
Natural Gas Savings	902	Therms ³				
Cooling Electricity Savings	12,295	kWh				

\$0.15	\$/kWh Blended
\$1.04	\$/Therm

COMBINED SAVINGS						
Natural Gas Savings	1,442	Therms				
Cooling Electricity Savings	24,699	kWh				
Total Cost Savings	\$ 5,094					
Estimated Total Project Cost	\$ 21,309					
Simple Payback	4.2	Yrs				

Savings calculation formulas are taken from NJ Protocols document for Occupancy Controlled Thermostats

Algorithms

Cooling Energy Savings (kWh) = $(((T_c*(H+5)+S_c*(168-(H+5)))/168)$ T_c)*(P_c*Cap_{hp}*12*EFLH_c/EER_{hp})

Heating Energy Savings (kWh) = ((($T_h*(H+5)+S_h*(168-(H+5)))/168$)- $T_h)*(P_h*Cap_{hp}*12*EFLH_h/EER_{hp})$

Heating Energy Savings (Therms) = $(T_h-(T_h*(H+5)+S_h*(168-H))$ $(H+5))/168)*(P_h*Cap_h*EFLH_h/AFUE_h/100,000)$

Definition of Variables

 T_h = Heating Season Facility Temp. (°F)

T_c = Cooling Season Facility Temp. (°F)

 S_h = Heating Season Setback Temp. (°F)

S_c = Cooling Season Setup Temp. (°F)

H = Weekly Occupied Hours

Cap_{hp} = Connected load capacity of heat pump/AC (Tons) – Provided on Application. Cap_h = Connected heating load capacity (Btu/hr) – Provided on Application.

EFLH_c = Equivalent full load cooling hours

EFLH_h = Equivalent full load heating hours

P_h = Heating season percent savings per degree setback

 P_c = Cooling season percent savings per degree setup AFUE_h = Heating equipment efficiency – Provided on Application.

EER_{hp} = Heat pump/AC equipment efficiency – Provided on Application

Occupancy Controlled Thermostats

Component	Type	Value	Source
T _h	Variable		Application
T _c	Variable		Application
Sh	Fixed	T _h -5°	
Sc	Fixed	T_c+5°	
Н	Variable		Application; Default of 56 hrs/week
Cap _{hp}	Variable		Application
Caph	Variable		Application
EFLH _c	Fixed	381	1
EFLH _h	Fixed	900	PSE&G
Ph	Fixed	3%	2
Pc	Fixed	6%	2
AFUE _h	Variable		Application
EERhp	Variable		Application

Sources:

- 1. JCP&L metered data from 1995-1999
- 2. ENERGY STAR Products website

Newark Board of Education - NJBPU CHA Project Number: 27999

Sussex Avenue

Multipliers	
Material:	1.03
Labor:	1.25
Equipment:	1.00

ECM-3A: Basic Controls - Cost

Description	OTV LINIT		QTY UNIT		OTY LINIT UNIT COSTS		SUBTOTAL COSTS			TOTAL	REMARKS
Description	QII	UNIT	MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.	COST	KEWAKNO	
						\$ -	\$ -	\$ -	\$ -		
Boiler Controller	1	ea	\$ 7,500	\$ 7,500		\$ 7,703	\$ 9,345	\$ -	\$ 17,048		
						\$ -	\$ -	\$ -	\$ -		

^{**}Cost Estimates are for Energy Savings calculations only, do not use for procurement

\$ 17,048	Subtotal					
\$ 4,262	25% Contingency					
\$ 21,309 Total						

ECM-3B: Install Full DDC Controls

Description: This ECM evaluates the energy savings associated with implementing a full wireless direct digital control system that enable remote automatic control, monitoiring and alarming of all HVAC equipment. Specific energy savings sequences would include optium Start/ Stop, night setback, temporary occupied set back, economizer control of UVs and AHU's. This energy savings percentage is based on past performance of similar buildings which have a fully functioning DDC control system.

Building Information:

64,762 Sq Footage
Y Cooling
Y Heating

\$0.15 \$/kWh Blended \$1.04 \$/Therm

FULL DDC - TEMPERATURE SETBACK SAVINGS CALCULATION

EXISTING CONDI	TIONS	
Heating		
Heating Season Facility Temp	80	F
Weekly Occupied Hours	70	hrs
Heating Season Setback Temp	75	F
Heating Season % Savings per Degree Setback	3%	
Annual Boiler Capacity	-	Mbtu/yr
Connected Heating Load Capacity	579,036	Btu/hr
Equivalent Full Load Heating Hours	900	hrs
Heating System Efficiency	80%	
Cooling		
Cooling Season Facility Temp	74	F
Weekly Occupied Hours	70	hrs
Cooling Season Setback Temp	79	F
Cooling Season % Savings per Degree Setback	6%	
Connected Cooling Load Capacity	10	Tons
Equivalent Full Load Cooling Hours	381	hrs
Cooling Equipment EER	14.0	
SAVINGS		
Natural Gas Savings	541	Therms
Cooling Electricity Savings	12,404	kWh

Nighttime Setback

EXISTING CONDITIONS		
Heating		
Heating Season Facility Temp	80	F
Weekly Occupied Hours	70	hrs
Heating Season Setback Temp	65	F
Heating Season % Savings per Degree Setback	3%	
Annual Boiler Capacity		Mbtu/yr
Connected Heating Load Capacity	579,036	Btu/hr
Equivalent Full Load Heating Hours	500	hrs
Heating Equipment Efficiency	80%	
Cooling		
Cooling Season Facility Temp	74	F
Weekly Occupied Hours	70	hrs
Cooling Season Setback Temp	80	F
Cooling Season % Savings per Degree Setback	6%	
Connected Cooling Load Capacity	10	Tons
Equivalent Full Load Cooling Hours	381	hrs
Cooling Equipment EER	14.0	
SAVINGS		
Natural Gas Savings	902	Therms ³
Cooling Electricity Savings	12,295	kWh

FULL DDC - ADDITIONAL CONTROLS SAVINGS CALCULATION

EXISTING CONDITIONS							
Existing Facility Total Electric usage	651,678	kWh					
Existing Facility Total Gas usage	22,100	Therms					
Existing Facility Cooling Electric usage	13,033.6	kWh ¹					
Existing Facility Heating Natural Gas usage	20,995	Therms					
PROPOSED CONDI	TIONS						
Proposed Facility Cooling Electric Savings	1,303	kWh					
Proposed Facility Natural Gas Savings	2,100	Therms					
SAVINGS							
Electric Savings	1,303	kWh					
Natural Gas Savings	2,100	Therms					

Assumptions

- 2% of facility total electricity dedicated to Cooling; based on utility information
- 2 95% of facility total natural gas dedicated to Heating; based on utility information
- 3 10% Typical Savings associated with installation of DDC controls

COMBINED SAVINGS						
Natural Gas Savings	3,542	Therms				
Cooling Electricity Savings	26,003	kWh				
Total Cost Savings	\$ 7,467					
Estimated Total Project Cost	\$356,512					
Simple Payback	47.7	Yrs				

Savings calculation formulas for setback are taken from NJ Protocols document for Occupancy Controlled Thermostats Savings calculations for additional controls are estimated based on the level of control to be added and prior experience

Newark Board of Education - NJBPU CHA Project Number: 27999

Sussex Avenue

Multipliers	
Material:	1.03
Labor:	1.25
Equipment:	1.00

ECM-3A: Basic Controls - Cost

Description	QTY	UNIT		U	NIT	COSTS	3	SUB	то	TAL COS	STS	٦	OTAL	REMARKS	
Description	QII	UNIT	1	MAT.	L	ABOR	EQUIP.	MAT.	L	_ABOR	EQUIP.		COST	KEWAKNO	
								\$ -	\$	-	\$ -	\$	-		
Unit Ventilator Controls	40	ea			\$	4,000		\$ -	\$	199,360	\$ -	\$	199,360	Vendor Quote	
Radiator Control (Group of 4)	6	ea			\$	4,500		\$	\$	33,642	\$ -	\$	33,642	Vendor Quote	
Exhaust Fan Control (Group of 4)	3	ea			\$	3,300		\$	\$	12,335	\$ -	\$	12,335	Vendor Quote	
Head End Controller & Programming	1	ls			\$ 3	32,000		\$	\$	39,872	\$ -	\$	39,872	Vendor Quote	
New Unit Ventilator	0	ea	\$	5,000	\$	4,000		\$	\$		\$ -	\$		Engineering Estimate	
New Exhaust Fan	0	ea	\$	1,525	\$	239		\$ -	\$		\$ -	\$	-	RS Means 2012	
New Radiator	0	lf	\$	43	\$	21		\$	\$		\$ -	\$		RS Means 2012	
								\$ -	\$	-	\$ -	\$	-		
								\$ -	\$	-	\$ -	\$	-		

^{**}Cost Estimates are for Energy Savings calculations only, do not use for procurement

\$ 285,209	Subtotal
\$ 71,302	25% Contingency
\$ 356,512	Total

Newark Board of Education - NJBPU CHA Project Number: 27999

Sussex Avenue

ECM-4: Replace urinals and flush valves with low flow

Description: This ECM evaluates the water savings associated with replacing/ upgrading urinals with 0.125 GPF urinals and or flush valves.

EXISTING CO	ONDITIO	NS
Cost of Water / 1000 Gallons	\$7.55	\$ / kGal
Urinals in Building to be replaced	26	
Average Flushes / Urinal (per Day)	9	
Average Gallons / Flush	2.5	Gal

PROPOSED CONDITIONS							
Proposed Urinals to be Replaced	26						
Proposed Gallons / Flush	0.125	Gal					
Proposed Material Cost of new urinal & valve	\$1,200	RS Means 2012					
Proposed Installation Cost of new urinal & valve	\$1,000	RS Means 2012					
Total cost of new urinals & valves							

SAVINGS						
Current Urinal Water Use	213.53	kGal / year				
Proposed Urinal Water Use	10.68	kGal / year				
Water Savings	202.85	kGal / year				
Cost Savings	\$1,532	/ year				

^{**}Cost Estimates are for Energy Savings calculations only, do not use for procurement

Newark Board of Education - NJBPU

CHA Project Number: 27999

Sussex Avenue

ECM-4: Replace toilets and flush valves with low flow

Description: This ECM evaluates the water savings associated with repalcing/ upgrading toilets to 1.28 GPF fixtures and/or flush valves.

EXISTING CONDI	TIONS	
Cost of Water / 1000 Gallons	\$7.55	\$ / kGal
Toilets in Building	45	
Average Flushes / Toilet (per Day)	9	
Average Gallons / Flush	3.5	Gal

PROPOSED (CONDITIONS	
Proposed Toilets to be Replaced	45	
Proposed Gallons / Flush	1.28	Gal

SAVINGS		
Current Toilet Water Use	517.39	kGal / year
Proposed Toilet Water Use	189.22	kGal / year
Water Savings	328.17	kGal / year
Cost Savings	\$2,478	/ year

Multipliers	
Material:	1.03
Labor:	1.25
Equipment:	1.12

Replace Plumbing Fixtures with Low-Flow Equivalents - Cost

Description	QTY	UNIT	l	JNIT COST	S	SUE	STOTAL CO	STS	TOTAL COST	DEMVBKS
Description	QII	OIVII	MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.	TOTAL COST	KLIVIAKKS
									\$ -	
Low-Flow Urinal	26	EA	\$ 1,200	\$ 1,000	\$ -	\$ 32,042	\$ 32,396	\$ -	\$ 64,438	Vendor Estimate
Low-Flow Toilet	45	EA	\$ 1,400	\$ 1,000	\$ -	\$ 64,701	\$ 56,070	\$ -	\$ 120,771	Vendor Estimate
						\$ -	\$ -	\$ -	\$ -	

^{**}Cost Estimates are for Energy Savings calculations only, do not use for procurement

\$ 185,209	Subtotal
\$ 46,302	25% Contingency
\$ 231,512	Total

Newark Board of Education - NJBPU CHA Project Number: 27999

Sussex Avenue

New Jersey Pay For Performance Incentive Program

Note: The following calculation is based on the New Jersey Pay For Performance Incentive Program per April, 2012 Building must have a minimum average electric demand of 100 kW. This minimum is waived for buildings owned by local governments or non-profit organizations.

At a minimum, all recommended measures were used for this calculation. To qualify for P4P incentives, the following P4P requirements must be met:

- At least 15% source energy savings
- No more than 50% savings from lighting measures
- Scope includes more than one measure
- Project has at least a 10% internal rate of return
- At least 50% of the source energy savings must come from investor-owned electricity and/or natural gas (note: exemption for fuel conversions)

Total Building Area (Square Feet)	64,762
Is this audit funded by NJ BPU (Y/N)	Yes

Incentive	e #1	
Audit is funded by NJ BPU	\$0.05	\$/sqft

Board of Public Utilites (BPU)

	Annual Utilities		
	kWh	Therms	
Existing Cost (from utility)	\$94,811	\$22,986	
Existing Usage (from utility)	651,678	22,100	
Proposed Savings	118,918	1,442	
Existing Total MMBtus	4,434		
Proposed Savings MMBtus	550		
% Energy Reduction	12.4%		
Proposed Annual Savings	\$20,527		

	Min (Savir	ngs = 15%)	Increase (Sa	vings > 15%)	Max Inc	entive	Achieved	Incentive
Incentive #2	\$0.09	\$0.90	\$0.005	\$0.05	\$0.11	\$1.25	\$0.00	\$0.00
Incentive #3	\$0.09	\$0.90	\$0.005	\$0.05	\$0.11	\$1.25	\$0.00	\$0.00

	Incentives \$			
	Elec	Gas	Total	
Incentive #1	\$0	\$0	\$0	
Incentive #2	\$0	\$0	\$0	
Incentive #3	\$0	\$0	\$0	
Total All Incentives	\$0	\$0	\$0	

Total Project Cost \$198,569

		Allowable Incentive	
% Incentives #1 of Utility Cost	0.0%	\$0	
% Incentives #2 of Project Cost**	0.0%	\$0	
% Incentives #3 of Project Cost*	0.0%	\$0	
Total Eligible Incentives***	\$0		
Project Cost w/ Incentives	\$198,569		

Project Payl	
w/o Incentives	w/ Incentives
9.7	9.7

 $^{^{\}star}$ Maximum allowable incentive is 50% of annual utility cost if not funded by NJ BPU, and %25 if it is.

Maximum allowable amount of Incentive #3 is 25% of total project cost.

Maximum allowable amount of Incentive #2 & #3 is \$1 million per gas account and \$1 million per electric account; maximum 2 million per project

 $^{^{\}star\star}$ Maximum allowable amount of Incentive #2 is 25% of total project cost.

 $^{^{\}star\star\star}$ Maximum allowable amount of Incentive #1 is \$50,000 if not funded by NJ BPU, and \$25,000 if it is.

		EXISTING CONDITIONS						RETROFIT CO						COST & SAVING		Simple Payback	ck
Area Description	No. of Fixtures Standard Fixture Code	Watts per Fixture Code Fixture	kW/Space	Exist Control	Annual Hours Annual kWh	Number of Fixture	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/Space	Retrofit Control Annual Hours	Annual kWh	al kWh yed Annual kW Saved	Annual \$ Saved	NJ Smart St Retrofit Cost Lighting Ince		Simple
Unique description of the location - Room number/Room	om No. of fixtures "Lighting Fixture Code" Example	2T Code from Table of Standard Value from	(Watts/Fixt) * (F	ixt Pre-inst.	Estimated daily (kW/space) *	No. of fixtures after	"Lighting Fixture Code" Example	Code from Table of	Value from	(Watts/Fixt) *	Retrofit control Estimated	kW/space) * (Original	Annual (Original Annual	(kWh Saved) *	Cost for Prescriptive	Length of time	Leng
name: Floor number (if applicable)	before the retrofit 40 R F(U) = 2'x2' Troff 40 w Recestlamps U shape	ss. Floor 2 Fixture Wattages Table of Standard	No.)		nours for the (Annual Hours) usage group	the retrofit	2T 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape	Standard Fixture Wattages	Table of Standard	(Number of Fixtures)	device annual hours for the usage	Annual kWh) - (R lours) Annual k	etrofit kW) - (Retrofit Wh) Annual kW)		renovations to Lighting lighting system Measures	for renovations cost to be	s reno
		Fixture Wattages							Fixture Wattages		group					recovered	
300 Classroom 301 Classroom	18 S 32 C F 1 (ELE) 18 S 32 C F 1 (ELE)	F41LL 32	0.6 0.6	SW SW			4 ft LED Tube	200732x1	15	0.3	SW 2,400	648 648	734 0.3	\$ 125.46 \$ 125.46	\$ 2,150.55 \$0 \$ 2,150.55 \$0	17.1 17.1	
302 Classroom	15 S 32 C F 1 (ELE)	F41LL 32 F41LL 32	0.5	SW	2400 1,38 2400 1,15	15	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15	0.3 0.2	SW 2,400 SW 2,400	540	734 0.3 612 0.3	\$ 104.55	\$ 1,792.13 \$0	17.1	
303 Classroom Corridor	15 S 32 C F 1 (ELE) 3 S 32 C F 1 (ELE) 2 S 32 C F 1 (ELE) 2 S 32 C F 1 (ELE)	F41LL 32 F41LL 32	0.5 0.1	SW	2400 1,15 2280 21:		4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15	0.2	SW 2,400 SW 2,280	103	612 0.3 116 0.1	\$ 104.55 \$ 20.07		17.1 17.9	_
Stair Stair	2 S 32 C F 1 (ELE) 4 S 32 C F 1 (FLE)	F41LL 32	0.1	SW SW	6240 39	19 2	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15	0.0	SW 6,240	187	212 0.0	\$ 31.93 \$ 63.86	\$ 238.95 \$0	7.5 7.5	-
304 Computer Room	4 S 32 C F 1 (ELE) 15 S 32 C F 1 (ELE)	F41LL 32 F41LL 32	0.5	SW	2400 1,15	15	4 ft LED Tube	200732x1	15	0.2	SW 2,400	540	424 0.1 612 0.3	\$ 104.55	\$ 1,792.13 \$0	17.1	
305 Classroom 306 Classroom	15 S 32 C F 1 (ELE) 19 S 32 C F 1 (ELE)	F41LL 32 F41LL 32	0.5 0.6	SW	2400 1,15 2400 1,45	i9 19	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15	0.2	SW 2,400 SW 2,400	684	612 0.3 775 0.3	\$ 104.55 \$ 132.43	\$ 1,792.13 \$0 \$ 2,270.03 \$0	17.1 17.1	_
308 Classroom 310 Classroom	17 S 32 C F 1 (ELE) 15 S 32 C F 1 (ELE)	F41LL 32 F41LL 32	0.5	SW	2400 1,30 2400 1.15	16 17 i2 15	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15	0.3	SW 2,400 SW 2,400	612 540	694 0.3 612 0.3	\$ 118.49 \$ 104.55	\$ 2,031.08 \$0 \$ 1.792.13 \$0	17.1 17.1	+
Corridor	4 S 32 C F 1 (ELE)	F41LL 32	0.1	SW	2280 29		4 ft LED Tube	200732x1 200732x1	15	0.1	SW 2,280	137	155 0.1	\$ 26.76	\$ 477.90 \$0	17.9	
Mens TR UN-52	1 S 32 C F 1 (ELE) 1 S 32 C F 1 (ELE)	F41LL 32 F41LL 32	0.0	SW	2400 7 1000 3:	2 1	4 ft LED Tube 4 ft LED Tube	200732x1	15	0.0	SW 1,000	15	41 0.0 17 0.0	\$ 6.97 \$ 3.69	\$ 119.48 \$0 \$ 119.48 \$0	17.1 32.4	_
UN-53 UN-54	1 S 32 C F 1 (ELE) 1 S 32 C F 1 (ELE)	F41LL 32 F41LL 32	0.0	SW	1000 3: 1000 3:	12 1	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15 15	0.0	SW 1,000 SW 1,000	15 15	17 0.0 17 0.0	\$ 3.69 \$ 3.69	\$ 119.48 \$0 \$ 119.48 \$0	32.4 32.4	+
UN-50 UN-51	1 S 32 C F 1 (ELE) 1 S 32 C F 1 (ELE)	F41LL 32 F41LL 32	0.0	SW SW	1000 33	2 1	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15	0.0	SW 1,000 SW 1,000	15	17 0.0 17 0.0	\$ 3.69 \$ 3.69	\$ 119.48 \$0 \$ 119.48 \$0	32.4 32.4	4
Corridor	11 S 32 C F 1 (ELE)	F41LL 32	0.4	SW	2280 80	13 11	4 ft LED Tube	200732x1	15	0.2	SW 2,280	376	426 0.2	\$ 73.58	\$ 1,314.23 \$0	17.9	
314A Office 314B Art	6 S 32 C F 1 (ELE) 13 S 32 C F 1 (ELE)	F41LL 32 F41LL 32	0.2	SW		18 13	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15	0.1	SW 2,400 SW 2,400	468	245 0.1 530 0.2	\$ 41.82 \$ 90.61	\$ 716.85 \$0 \$ 1,553.18 \$0	17.1	_
314 316 Science	1 S 32 C F 1 (ELE) 12 S 32 C F 1 (ELE)	F41LL 32 F41LL 32	0.0	SW SW	2400 7 2400 92		4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15	0.0	SW 2,400 SW 2,400	36 432	41 0.0 490 0.2	\$ 6.97 \$ 83.64	\$ 119.48 \$0 \$ 1.433.70 \$0	17.1 17.1	+
318 Classroom	12 S 32 C F 1 (ELE) 12 S 32 C F 1 (ELE)	F41LL 32 F41LL 32	0.4	SW	2400 92	12 12	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15	0.2	SW 2,400 SW 2,400	432 432	490 0.2	\$ 83.64	\$ 1,433.70 \$0	17.1	
320 Classroom 313 Storage	1 S 32 C F 1 (ELE)	F41LL 32	0.4	SW	2400 92: 1000 3:		4 ft LED Tube	200732x1	15	0.2 0.0	SW 1,000	15	490 0.2 17 0.0	\$ 83.64 \$ 3.69	\$ 119.48 \$0	32.4	_
311 Storage 309 Storage	1 T 32 R F 2 (ELE) 1 T 32 R F 2 (ELE)	F42LL 60 F42LL 60	0.1	SW SW	1000 66 1000 66	i0 1 i0 1	T 59 R LED T 59 R LED	RTLED38 RTLED38	38	0.0	SW 1,000 SW 1,000	38	22 0.0 22 0.0	\$ 4.78 \$ 4.78	\$ 236.25 \$0 \$ 236.25 \$0	49.5 49.5	+
307 Utility Room Storage	5 T 32 R F 2 (ELE) 1 T 32 R F 2 (ELE)	F42LL 60 F42LL 60	0.3	SW SW	1000 30	0 5 0 1	T 59 R LED T 59 R LED	RTLED38 RTLED38	38	0.2	SW 1,000 SW 1,000	190 38	110 0.1 22 0.0	\$ 23.88 \$ 4.78		49.5 49.5	1
Stairs	2 T 32 R F 2 (ELE)	F42LL 60	0.1	SW	6240 74	9 2	T 59 R LED	RTLED38	38	0.1	SW 6,240	474	275 0.0	\$ 41.32	\$ 472.50 \$0	11.4	#
200 Classroom 201 Classroom	15 S 32 C F 1 (ELE) 15 S 32 C F 1 (ELE)	F41LL 32 F41LL 32	0.5 0.5	SW	2400 1,15 2400 1,15	2 15	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15	0.2 0.2	SW 2,400 SW 2,400	540 540	612 0.3 612 0.3 612 0.3	\$ 104.55 \$ 104.55	\$ 1,792.13 \$0	17.1 17.1	\pm
202 Classroom 203 Nurse Office	15 S 32 C F 1 (ELE) 12 S 32 C F 1 (ELE)	F41LL 32 F41LL 32	0.5 0.4	SW	2400 1,15	15	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15 15	0.2 0.2	SW 2,400 SW 2,400	540 432	612 0.3 490 0.2	\$ 104.55 \$ 83.64	\$ 1,792.13 \$0	17.1 17.1	+
Exam Room UN-29	3 S 32 C F 1 (ELE) 1 S 32 C F 1 (ELE)	F41LL 32 F41LL 32	0.1	SW	2400 23	10 3	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1 200732x1	15	0.0	SW 2,400 SW 1,000	108	122 0.1 17 0.0	\$ 20.91 \$ 3.69	\$ 358.43 \$0 \$ 119.48 \$0	17.1 32.4	1
UN-28	1 S 32 C F 1 (ELE)	F41LL 32	0.0	SW			4 ft LED Tube	200732x1	15	0.0	SW 1,000	15	17 0.0 17 0.0 155 0.1	\$ 3.69	\$ 119.48 \$0	32.4	\pm
Corridor Stair	4 S 32 C F 1 (ELE) 3 S 32 C F 1 (ELE)	F41LL 32 F41LL 32	0.1	SW	2280 29 6240 59	19 3	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15 15	0.1	SW 2,280 SW 6,240	137 281	318 0.1	\$ 26.76 \$ 47.89	\$ 477.90 \$0 \$ 358.43 \$0	17.9 7.5	+
204 Classroom Storage	15 S 32 C F 1 (ELE) 1 S 32 C F 1 (ELE)	F41LL 32 F41LL 32	0.5	SW	2400 1,15 1000 3	2 15	4 ft LED Tube	200732x1 200732x1	15	0.2	SW 2,400 SW 1,000	540	612 0.3 17 0.0	\$ 104.55 \$ 3.69	\$ 1,792.13 \$0 \$ 119.48 \$0	17.1 32.4	
205 Classroom	15 S 32 C F 1 (ELE)	F41LL 32	0.5	SW	2400 1,15		4 ft LED Tube 4 ft LED Tube	200732x1	15	0.0	SW 2,400	540	612 0.3	\$ 104.55	\$ 1,792.13 \$0	17.1	
Storage Corridor	1 S 32 C F 1 (ELE) 6 S 32 C F 1 (ELE)	F41LL 32 F41LL 32	0.0	SW	1000 3: 2280 43	12 1	4 ft LED Tube 4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15 15	0.0	SW 1,000 SW 2,280	15 205	17 0.0 233 0.1 612 0.3	\$ 3.69 \$ 40.13	\$ 119.48 \$0 \$ 716.85 \$0	32.4 17.9 17.1	+
206 Classroom	6 S 32 C F 1 (ELE) 15 S 32 C F 1 (ELE) 1 S 32 C F 1 (ELE)	F41LL 32 F41LL 32	0.5	SW SW	2400 1,15 1000 3:		4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15	0.2	SW 2,400 SW 1,000	540	612 0.3 17 0.0	\$ 104.55 \$ 3.69	\$ 1,792.13 \$0	17.1 32.4	1
Storage 208 Classroom	15 S 32 C F 1 (ELE)	F41LL 32	0.5	SW	2400 1,15	15	4 ft LED Tube	200732x1	15	0.0	SW 2,400	540	612 0.3	\$ 104.55	\$ 1,792.13 \$0	17.1	
Storage 210 Classroom	1 S 32 C F 1 (ELE) 15 S 32 C F 1 (ELE)	F41LL 32 F41LL 32	0.0	SW SW	1000 3: 2400 1,15:	i2 1 i2 15	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15	0.0	SW 1,000 SW 2,400	15 540	17 0.0 612 0.3	\$ 3.69 \$ 104.55	\$ 119.48 \$0 \$ 1,792.13 \$0	32.4 17.1	-
Storage Girls Locker Room	1 S 32 C F 1 (ELE) 6 S 32 C F 1 (ELE)	F41LL 32 F41LL 32	0.0	SW	1000 3: 2400 46	1 6	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15	0.0	SW 1,000 SW 2,400	15 216	17 0.0 245 0.1	\$ 3.69 \$ 41.82	\$ 119.48 \$0 \$ 716.85 \$0	32.4 17.1	-
UN-43	4 S 32 C F 1 (ELE)	F41LL 32	0.1	SW	1000 12	8 4	4 ft LED Tube	200732x1 RTI FD38	15	0.1	SW 1,000	60	68 0.1	\$ 14.76	\$ 477.90 \$0 \$ 1.890.00 \$0	32.4	
Corridor Storage 131 Main Office	8 T 32 R F 2 (ELE) 2 T 32 R F 2 (ELE)	F42LL 60 F42LL 60	0.5	SW	2280 1,09- 1000 12	10 2	T 59 R LED	RTLED38	38	0.3	SW 2,280 SW 1,000	76	401 0.2 44 0.0	\$ 69.25 \$ 9.55	\$ 472.50 \$0	27.3 49.5	_
131 Main Office 103A Principal Office	21 S 32 C F 1 (ELE) 10 S 32 C F 1 (ELE)	F41LL 32 F41LL 32	0.7	SW SW	2400 1,61: 2400 76		4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15 15	0.3 0.2	SW 2,400 SW 2,400	756 360	857 0.4 408 0.2	\$ 146.37 \$ 69.70	\$ 2,508.98 \$0 \$ 1,194.75 \$0	17.1 17.1	+
100A TR 103C	1 S 32 C F 1 (ELE) 5 S 32 C F 1 (ELE)	F41LL 32 F41LL 32	0.0	SW	2400 7	7 1	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15	0.0	SW 2,400 SW 2,400	36 180	41 0.0 204 0.1	\$ 6.97 \$ 34.85	\$ 119.48 \$0 \$ 597.38 \$0	17.1	#
103B Storage	2 S 32 C F 1 (ELE)	F41LL 32	0.1	SW	1000 6-	i4 2	4 ft LED Tube	200732x1	15	0.1	SW 1,000	30		\$ 7.38	\$ 238.95 \$0	32.4	\pm
Vest Corridor	2 S 32 C F 1 (ELE) 2 S 32 C F 1 (ELE)	F41LL 32 F41LL 32	0.1 0.1	SW	2280 14		4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15	0.0 0.0	SW 2,280 SW 2,280	68 68	34 0.0 78 0.0 78 0.0	\$ 13.38 \$ 13.38	\$ 238.95 \$0 \$ 238.95 \$0	17.9 17.9	\pm
101 Office 101A TR	5 S 32 C F 1 (ELE) 1 2T 3' 17 R F 1 (ELE)	F41LL 32 F21ILL 20	0.2	SW SW		14 5 18 1	4 ft LED Tube 2T 3' 17 R F 1 (ELE)	200732x1 F21ILL	15 20	0.1 0.0	SW 2,400 SW 2,400	180 48	204 0.1	\$ 34.85 \$ -	\$ 597.38 \$0 \$ - \$0	17.1	+
103 Boys TR	6 S 32 C F 1 (ELE)	F41LL 32	0.2	SW	2400 46	1 6	4 ft LED Tube	200732x1	15	0.1	SW 2,400	216	245 0.1	\$ 41.82	\$ 716.85 \$0 \$ 110.48 \$0	17.1	#
Storage 105 Storage	1 S 32 C F 1 (ELE) 1 S 32 C F 1 (ELE)	F41LL 32 F41LL 32	0.0	SW	1000 3:	2 1	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15	0.0	SW 1,000 SW 1,000	15	17 0.0 17 0.0	\$ 3.69 \$ 3.69	\$ 119.48 \$0	32.4 32.4	\pm
Corridor Corridor	3 S 32 C F 1 (ELE) 1 1T 32 C F 4 (ELE)	F41LL 32 F44ILL 112	0.1	SW			4 ft LED Tube 4 ft LED Tube	200732x1 200732x2	15	0.0	SW 2,280 SW 2,280	103	116 0.1 187 0.1	\$ 20.07 \$ 32.26	\$ 358.43 \$0 \$ 163.35 \$0	17.9 5.1	+
106 Custodial Office MER 102	4 S 32 C F 1 (ELE) 8 T 32 R F 2 (ELE)	F41LL 32 F42LL 60	0.1 0.5	SW		74 8	4 ft LED Tube T 59 R LED	200732x1 RTI FD38	15	0.1 0.3	SW 2,400 SW 1.820	144 553	163 0.1 320 0.2	\$ 27.88 \$ 58.09		17.1 32.5	
107 Classroom	18 S 32 C F 1 (ELE)	F41LL 32	0.6	SW	2400 1,38	12 18	4 ft LED Tube	200732x1	15	0.3	SW 2,400	648	734 0.3	\$ 125.46	\$ 2,150.55 \$0	17.1	
106 Storage 109 Storage	1 S 32 C F 1 (ELE) 1 2T 3' 17 R F 1 (ELE)	F41LL 32 F21ILL 20	0.0	SW	1000 20	10 1	4 ft LED Tube 2T 3' 17 R F 1 (ELE)	200732x1 F21ILL	15 20	0.0	SW 1,000 SW 1,000	15 20	17 0.0	\$ 3.69	\$ 119.48 \$0 \$ - \$0	32.4	_
Corridor Corridor	4 S 32 C F 1 (ELE) 1 T 32 R F 2 (ELE)	F41LL 32 F42LL 60	0.1	SW			4 ft LED Tube T 59 R I ED	200732x1 RTLED38	15	0.1	SW 2,280 SW 2,280	137	155 0.1	\$ 26.76 \$ 8.66	\$ 477.90 \$0 \$ 236.25 \$0	17.9	-
Corridor Corridor	1 T32 R F 2 (ELE) 1 T32 R F 2 (ELE) 1 1T32 C F 4 (ELE)	F42LL 60 F42LL 112	0.1	SW SW			T 59 R LED 4 ft LED Tube	RTLED38	38	0.0 0.0 0.0	SW 2,280 SW 2,280 SW 2,280	87 69	50 0.0 50 0.0 187 0.1	\$ 8.66 \$ 8.66 \$ 32.26	\$ 236.25 \$0	27.3 27.3 5.1	#
108 Office	9 T 32 R F 2 (ELE)	F42LL 60	0.5	SW	2280 250 2400 1,29	16 9	T 59 R LED	200732x2 RTLED38	38	0.3	SW 2,400	821	187 0.1 475 0.2 204 0.1	\$ 81.18		5.1 26.2 17.1	\pm
110 Girls TR 110 Girls TR	5 S 32 C F 1 (ELE) 1 S 32 C F 1 (ELE)	F41LL 32	0.2	SW	2400 38- 2400 7	14 5	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15 15	0.1	SW 2,400 SW 2,400	180	204 0.1 41 0.0	\$ 34.85	\$ 597.38 \$0 \$ 119.48 \$0	17.1 17.1	+
112 Library 112A Office	14 1T 32 C F 4 (ELE) 4 T 32 R F 3 (ELE)	F41LL 32 F44ILL 112 F43ILL/2 90	1.6	SW SW	2400 3,76		4 ft LED Tube 4 ft LED Tube T 59 R LED	200732x2 RTLED38	30	0.4	SW 2,400	1,008	41 0.0 2,755 1.1 499 0.2	\$ 6.97 \$ 470.67 \$ 85.28	\$ 2,286.90 \$0 \$ 945.00 \$0	4.9	1
Corridor 116 Social Worker	8 1T 32 C F 4 (ELE)	F44ILL 112	0.9	SW	2400 86 2280 2,04		4 ft LED Tube	200732x2	30	0.2	SW 2,280	547	499 0.2 1,496 0.7	\$ 258.11	\$ 1,306.80 \$0	5.1	
114 Nurse	2 T 32 R F 2 (ELE) 5 T 32 R F 2 (ELE)	F42LL 60 F42LL 60	0.1	SW	2400 28 2400 72	8 2 9 5	T 59 R LED T 59 R LED	RTLED38 RTLED38	38	0.1 0.2	SW 2,400 SW 2,400	182 456	106 0.0 264 0.1	\$ 18.04 \$ 45.10	\$ 1,181.25 \$0	26.2 26.2	\pm
114A Nurse Office TR	2 T 32 R F 2 (ELE) 1 2T 3' 17 R F 1 (ELE)	F42LL 60 F21ILL 20	0.1	SW			T 59 R LED 2T 3' 17 R F 1 (ELE)	RTLED38 F21ILL	20	0.1	SW 2,400 SW 2,400	182 48	106 0.0	\$ 18.04 \$ -	\$ 472.50 \$0 \$ - \$0	26.2	+
120 Cafeteria / Gym 120A Gym Storage	80 T 34 R F 4 (MAG)	F21ILL 20 F44EE 144	11.5	SW	2912 33,54	80	2T 3' 17 R F 1 (ELE) T 74 R LED	RTLED50	50	4.0	SW 2,912	11,648	21,898 7.5	\$ 3,613.63	\$ 18,900.00 \$0	5.2	\perp
120D Office	3 CF26W 1 T 32 R F 2 (ELE)	CF26/4-L 108 F42LL 60	0.3 0.1	SW			CF26W T 59 R LED	CF26/4-L RTLED38	38	0.3	SW 1,000 SW 2,400	91	- 0.0 53 0.0	\$ 9.02	\$ - \$0 \$ 236.25 \$0	26.2	\pm
TR 120C Office	1 100 1 T 32 R F 2 (ELE)	I100/1 100 F42LL 60	0.1 0.1	SW		1 1 1	CF 26 T 59 R LED	CFQ26/1-L RTLED38	38	0.0	SW 2,400 SW 2,400	65 91	175 0.1 53 0.0	\$ 29.93 \$ 9.02	\$ 40.50 \$0 \$ 236.25 \$0	1.4 26.2	\pm
120C Office 120 E3 TR	1 100 2 S 32 C F 1 (FLF)	1100/1 100 F41LL 32	0.1	SW		i0 1 i4 2	CF 26 4 ft LED Tube	CFQ26/1-L 200732x1	27 15	0.0	SW 2,400 SW 2,400	65 72	175 0.1 82 0.0	\$ 29.93 \$ 13.94	\$ 40.50 \$0	1.4	\pm
120 E1	2 S 32 C F 1 (ELE)	F41LL 32	0.1	SW	1000 6-	i4 2	4 ft LED Tube	200732x1	15	0.0	SW 1,000	30	34 0.0	\$ 7.38	\$ 238.95 \$0	32.4	\pm
120 E2 120 E4	2 S 32 C F 1 (ELE) 2 S 32 C F 1 (ELE)	F41LL 32 F41LL 32	0.1	SW			4 ft LED Tube 4 ft LED Tube T 59 R LED	200732x1 200732x1 RTLED38	15	0.0	SW 1,000 SW 1,000	30 30	34 0.0 34 0.0	\$ 7.38 \$ 7.38	\$ 238.95 \$0	32.4 32.4	\pm
118 Kitchen 122 Storage	3 T 32 R F 2 (ELE) 3 T 32 R F 2 (ELE)	F42LL 60 F42LL 60	0.2	SW SW	3000 54 1000 18	14 2 10 3 10 3	T 59 R LED T 59 R LED	RTLED38 RTLED38	38 38	0.1 0.1	SW 3,000 SW 1,000	342 114	34 0.0 198 0.1 66 0.1	\$ 32.52 \$ 14.33	\$ 708.75 \$0	21.8 49.5	-
122 Storage Corridor	3 1T 32 C F 4 (ELE)	F44ILL 112	0.3	SW	2280 76	6 3	4 ft LED Tube	200732x2	30	0.1	SW 2,280	205	561 0.2	\$ 96.79		5.1	1
124 Auditorium 124 Auditorium	20 S 32 C F 1 (ELE) 24 High Bay MH 200 35 Feet High	F41LL 32 MH200/1 232	0.6 5.6	SW	1820 10,13	14 24	4 ft LED Tube FXLED78	200732x1 FXLED78/1	78	0.3 1.9	SW 1,820 SW 1,820	546 3,407	619 0.3 6,727 3.7	\$ 112.23 \$ 1,219.98	\$ 20,260.69 \$3,600	21.3 16.6	\pm
Stage Stage	10 T 32 R F 2 (ELE) 1 High Bay MH 200 35 Feet High	F42LL 60 MH200/1 232	0.6 0.2	SW SW	5000 3,00 5000 1,16	0 1	T 59 R LED FXLED78	FXLED78/1	38 78	0.4 0.1	SW 5,000 SW 5,000	1,900 390	1,100 0.2 770 0.2	\$ 169.01 \$ 118.31	\$ 2,362.50 \$0 \$ 844.20 \$150	14.0 7.1	+
124A Dressing Room 124C	2 T 32 R F 2 (ELE) 2 T 32 R F 2 (ELE)	F42LL 60 F42LL 60	0.1	SW	8760 1,05	1 2	T 59 R LED T 59 R LED	RTLED38	38	0.1	SW 8,760 SW 1,000	666 76	385 0.0	\$ 56.60	\$ 472.50 \$0	8.3	1
124B TR	1 T 32 R F 2 (ELE)	F42LL 60	0.1	SW	1000 120 2400 14	4 1	T 59 R LED	RTLED38	38	0.1	SW 2,400	91	44 0.0 53 0.0	\$ 9.55 \$ 9.02	\$ 236.25 \$0	49.5 26.2	\pm
Corridor Corridor	12 S 32 C F 1 (ELE) 7 T 32 R F 2 (ELE)	F41LL 32 F42LL 60	0.4	SW SW	2280 87	6 12	4 ft LED Tube T 59 R LED	200732x1 RTLED38	15 38	0.2 0.3	SW 2,280 SW 2,280	410 606	465 0.2 351 0.2	\$ 80.27 \$ 60.59	\$ 1,433.70 \$0	17.9 27.3	+
Corridor Classroom	2 1T 32 C F 4 (ELE) 12 T 32 R F 3 (ELE)	F44ILL 112 F43ILL/2 90	0.2	SW	2280 51 2400 2,59	1 2	4 ft LED Tube T 59 R LED	200732x2 RTLED38	30	0.1 0.5	SW 2,280 SW 2,400	137	374 0.2 1,498 0.6	\$ 64.53 \$ 255.84	\$ 326.70 \$0	5.1 11.1	1
Classroom	12 T 32 R F 3 (ELE)	F43ILL/2 90	1.1	SW	2400 2,59	12 12	T 59 R LED	RTLED38	38	0.5	SW 2,400	1,094	1,498 0.6	\$ 255.84	\$ 2,835.00 \$0	11.1	\pm
Classroom Classroom	12 T 32 R F 3 (ELE) 12 T 32 R F 3 (ELE)	F43ILL/2 90 F43ILL/2 90	1.1	SW SW	2400 2,59 2400 2,59	12 12	T 59 R LED T 59 R LED	RTLED38	38 38	0.5 0.5	SW 2,400 SW 2,400	1,094 1,094	1,498 0.6 1,498 0.6	\$ 255.84 \$ 255.84	\$ 2,835.00 \$0	11.1	+
Classroom Classroom	12 T 32 R F 3 (ELE) 12 T 32 R F 3 (ELE)	F43ILL/2 90 F43ILL/2 90	1.1	SW	2400 2,59	12 12	T 59 R LED T 59 R LED	RTLED38 RTLED38	38	0.5	SW 2,400	1,094	1,498 0.6 1.498 0.6	\$ 255.84 \$ 255.84	\$ 2,835.00 \$0 \$ 2,835.00 \$0	11.1	#
	12 T 32 R F 3 (ELE) 12 T 32 R F 3 (ELE)	F43ILL/2 90 F43ILL/2 90	1.1	SW	2400 2,59 2400 2,59	12 12 12 12	T 59 R LED T 59 R LED	RTLED38 RTLED38	38	0.5 0.5	SW 2,400 SW 2,400	1,094 1,094	1,498 0.6	\$ 255.84 \$ 255.84		11.1	+
Classroom Classroom	12 T 32 R F 3 (ELE)	F43ILL/2 90	1.1	SW	2400 2,59 2280 1,36	12 12	T 59 R LED	RTLED38	38	0.5	SW 2,400	1,094	1,498 0.6	\$ 255.84	\$ 2,835.00 \$0	11.1	

Energy Audit of Sussec Avenue Elementary School CHA Project No. 27999 ECM-L1 Lighting Replacements

		EXISTING CONDITIONS										COST & SAVINGS ANALYSIS												
	Area Description	No. of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/Space	Exist Control	Annual Hours	Annual kWh	Number of Fixture	s Standard Fixture Code	RETROFIT C	Watts per Fixture	kW/Space	Retrofit Control	Annual Hours	Annual kWh	Annual kWh Saved	Annual kW Saved	Annual \$ Saved	Retrofit Cost	NJ Smart Start Lighting Incentive	Simple Payback With Out Incentive	Simple Payback
Field Code	Unique description of the location - Room number/Room name: Floor number (if applicable)	No. of fixtures "Lig before the retrofit 40 R lamp	hting Fixture Code" Example 2T F(U) = 2'x2' Troff 40 w Recess. Floor 2 bs U shape	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Fixt No.)	Pre-inst. control device	Estimated daily hours for the usage group	(kW/space) * (Annual Hours)	No. of fixtures afte the retrofit	2T 40 R F(U) = 2'x2' Troff 40 w	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Number of Fixtures)		annual hours	(kW/space) * (Annual Hours)	(Original Annual kWh) - (Retrofit Annual kWh)	(Original Annual kW) - (Retrofit Annual kW)	(kWh Saved) * (\$/kWh)	Cost for renovations to lighting system	Prescriptive Lighting Measures	Length of time for renovations cost to be recovered	Length of time for renovations cost to be recovered
-	Total	861				52.4			128,850	861			2,957	22.4				74,141 nd Savings Savings	30.1	\$12,599 30.1 74.141	\$152,679 \$2,384 \$10,215	\$3,750		

4/25/2014 Page 4, ECM-L1

ECM-L2 Instal	occupancy sensors		EXISTING COND	ITIONS					RETROFIT	CONDITIONS							COST & SAVIN	GS ANALYSIS		
			EXISTING COND	Watts per					KEIKOITI	Watts per		Retrofit			Annual kWh		COST & SAVIR	OU AIRAETOIS	NJ Smart Start Simple Lighting Wit	Payback th Out
Field Code	Area Description	No. of Fixtures Standard Fixture Code No. of fixtures Lighting Fixture Code	Fixture Code Code from Table of Standard	Fixture Value from	kW/Space Exist (Watts/Fixt) * (Fixt Pre-ins	Control Annual Hours Annual t. Estimated annual (kW/space)		es Standard Fixture Code er "Lighting Fixture Code" Example	Fixture Code Code from Table of	Fixture Value from	kW/Space (Watts/Fixt) *	Control Retrofit cont	Annual Hours	s Annual kWh (kW/space) *	Saved (Original Annual	Annual kW Saved		Retrofit Cost	Incentive Ince	entive Simple Payback of time Length of time for
	name: Floor number (if applicable)	before the retrofit	Fixture Wattages	Table of Standard	No.) contro	device hours for the usage group (Annual Ho		2T 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape	Standard Fixture Wattages	Table of Standard	(Number of Fixtures)	device	annual hours for the usage	(Annual Hours)	kWh) - (Retrofit Annual kWh)		(\$/kWh)	renovations to lighting system		ovations renovations cost to
				Fixture Wattages						Fixture Wattages	,		group					3 . 3 . 3	recover	
20LED 20LED	300 Classroom 301 Classroom	18 S 32 C F 1 (ELE) 18 S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.6	W 2400 W 2400	1,382.4 18 1,382.4 18	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.6 0.6	C-OCC	1680 1680	967.7 967.7	414.7 414.7	0.0	\$57.14 \$57.14	\$270.00 \$270.00		4.7 4.1 4.7 4.1 5.7 4.9
20LED 20LED	302 Classroom 303 Classroom	15 S 32 C F 1 (ELE) 15 S 32 C F 1 (ELE)	F41LL F41LL	32 32		W 2400 W 2400	1,152.0 15 1,152.0 15	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.5 0.5	C-OCC	1680 1680	806.4 806.4	345.6 345.6		\$47.62 \$47.62	\$270.00 \$270.00		5.7 4.9 5.7 4.9
20LED 20LED	Corridor Stair	3 S 32 C F 1 (ELE) 2 S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.1	W 2280 W 6240	218.9 3 399.4 2	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.1 0.1	NONE NONE	6240	218.9 399.4	0.0	0.0	\$0.00 \$0.00	\$0.00 \$0.00	\$0.00 \$0.00	#DIV/0! #DIV/0!
20LED 20LED	Stair 304 Computer Room	4 S 32 C F 1 (ELE) 15 S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.5	W 6240 W 2400	798.7 4 1,152.0 15	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.1 0.5	NONE C-OCC	6240 1680	798.7 806.4	0.0 345.6		\$0.00 \$47.62	\$0.00 \$270.00		#DIV/0! 5.7 4.9
20LED	305 Classroom 306 Classroom	15 S 32 C F 1 (ELE) 19 S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.6	W 2400 W 2400	1,152.0 15 1,459.2 19	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.5	C-OCC	1680 1680	806.4 1,021.4	345.6 437.8	0.0	\$47.62 \$60.31	\$270.00 \$270.00	\$35.00	5.7 4.9 4.5 3.9
20LED 20LED 20LED	308 Classroom 310 Classroom Corridor	17 S 32 C F 1 (ELE) 15 S 32 C F 1 (ELE) 4 S 32 C F 1 (ELE)	F41LL F41LL F41LL	32 32	0.5	W 2400 W 2400 W 2280	1,305.6 17 1,152.0 15 291.8 4	S 32 C F 1 (ELE) S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL F41LL	32 32	0.5	C-OCC C-OCC NONE	1680 1680 2280	913.9 806.4 291.8	345.6	0.0	\$47.62 \$0.00	\$270.00 \$270.00 \$0.00	\$35.00 \$35.00 \$0.00	5.0 4.4 5.7 4.9 #DIV/0!
20LED 20LED	Mens TR UN-52	1 S 32 C F 1 (ELE) 1 S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.0	W 2400 W 1000	76.8 1 32.0 1	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32	0.0	NONE C-OCC	2400	76.8	0.0	0.0	\$0.00 \$3.31	\$0.00 \$270.00	\$0.00 \$35.00 835.00	#DIV/0! #DIV/0! 31.7 71.1
20LED 20LED	UN-53 UN-54	1 S 32 C F 1 (ELE) 1 S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.0	W 1000 W 1000	32.0 1 32.0 1	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.0	C-OCC	250 250	8.0 8.0	24.0	0.0	\$3.31 \$3.31	\$270.00 \$270.00	\$35.00 8	31.7 71.1 31.7 71.1
20LED 20LED	UN-50 UN-51	1 S 32 C F 1 (ELE) 1 S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.0	W 1000 W 1000	32.0 1 32.0 1	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.0	C-OCC	250 250	8.0	24.0 24.0	0.0	\$3.31 \$3.31	\$270.00 \$270.00	\$35.00 8	31.7 71.1 31.7 71.1
20LED 20LED	Corridor 314A Office	11 S 32 C F 1 (ELE) 6 S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.4	W 2280 W 2400	802.6 11 460.8 6	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.4 0.2	NONE C-OCC	2280 1500	802.6 288.0	0.0 172.8	0.0	\$0.00 \$23.81	\$0.00 \$270.00	\$0.00	#DIV/0! 11.3 9.9
20LED 20LED	314B Art 314	13 S 32 C F 1 (ELE) 1 S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.0	W 2400 W 2400	998.4 13 76.8 1	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.4	C-OCC	1680 1680	698.9 53.8	299.5 23.0	0.0	\$41.27 \$3.17	\$270.00 \$270.00	\$35.00 8	6.5 5.7 35.1 74.0
20LED 20LED	316 Science 318 Classroom	12 S 32 C F 1 (ELE) 12 S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.4	W 2400 W 2400	921.6 12 921.6 12	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.4	C-OCC	1680 1680	645.1 645.1	276.5 276.5	0.0	\$38.09 \$38.09	\$270.00 \$270.00	\$35.00	7.1 6.2 7.1 6.2
20LED 20LED	320 Classroom 313 Storage	12 S 32 C F 1 (ELE) 1 S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.0	W 2400 W 1000	921.6 12 32.0 1	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.4	C-OCC	1680 250	645.1 8.0	276.5 24.0	0.0	\$38.09 \$3.31	\$270.00 \$270.00	\$35.00 8	7.1 6.2 31.7 71.1
40LED	311 Storage 309 Storage	1 T 32 R F 2 (ELE) 1 T 32 R F 2 (ELE)	F42LL F42LL	60 60	0.1	W 1000 W 1000	60.0 1 60.0 1	T 32 R F 2 (ELE) T 32 R F 2 (ELE)	F42LL F42LL	60	0.1	C-OCC	250 250		45.0 45.0		\$6.20 \$6.20	\$270.00 \$270.00		43.5 37.9 43.5 37.9
40LED 40LED 40LED	307 Utility Room Storage Stairs	5 T 32 R F 2 (ELE) 1 T 32 R F 2 (ELE)	F42LL F42LL F42LL	60	0.1	W 1000 W 1000	300.0 5 60.0 1 748.8 2	T 32 R F 2 (ELE) T 32 R F 2 (ELE) T 32 R F 2 (ELE)	F42LL F42LL F42LL	60	0.3	C-OCC	1000 250	300.0 15.0 748.8	45.0	0.0	\$6.20	\$0.00 \$270.00	\$35.00 4	#DIV/0! 43.5 37.9
20LED 20LED	200 Classroom 201 Classroom	2 T 32 R F 2 (ELE) 15 S 32 C F 1 (ELE) 15 S 32 C F 1 (ELE)	F41LL F41LL	32	0.5	W 6240 W 2400 W 2400	1,152.0 15	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32	0.5	C-OCC	6240 1680	806.4 806.4	345.6 345.6	0.0	\$47.62	\$0.00 \$270.00 \$270.00		#DIV/0! 5.7 4.9 5.7 4.9
20LED 20LED	202 Classroom 203 Nurse Office	15 S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.5	W 2400	1,152.0 15 1,152.0 15 921.6 12	S 32 C F 1 (ELE) S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.5 0.4	C-OCC	1680	806.4 576.0	345.6 345.6		\$47.62 \$47.62	\$270.00 \$270.00 \$270.00	\$35.00	5.7 4.9 5.7 4.9
20LED 20LED	Exam Room UN-29	12 S 32 C F 1 (ELE) 3 S 32 C F 1 (ELE) 1 S 32 C F 1 (ELE)	F41LL F41LL	32 32		W 2400 W 2400 W 1000	921.6 12 230.4 3 32.0 1	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.1 0.0	C-OCC	1500 250	144.0 8.0	86.4 24.0		\$11.90 \$3.31	\$270.00 \$270.00 \$270.00	\$35.00	22.7 19.7 31.7 71.1
20LED 20LED	UN-28 Corridor	1 S 32 C F 1 (ELE) 4 S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.0 S 0.1 S	W 1000 W 2280	32.0 1 291.8 4	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.0 0.1	C-OCC NONE	250 2280	8.0 291.8	24.0 0.0	0.0	\$3.31 \$0.00	\$270.00 \$0.00	\$35.00 8 \$0.00	31.7 71.1 #DIV/0!
20LED 20LED	Stair 204 Classroom	3 S 32 C F 1 (ELE) 15 S 32 C F 1 (ELE)	F41LL F41LL	32 32		W 6240 W 2400	599.0 3 1,152.0 15	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.1 0.5	NONE C-OCC	6240 1680	599.0 806.4	0.0 345.6	0.0	\$0.00 \$47.62	\$0.00 \$270.00		#DIV/0! 5.7 4.9
20LED 20LED	Storage 205 Classroom	1 S 32 C F 1 (ELE) 15 S 32 C F 1 (ELE)	F41LL F41LL	32 32		W 1000 W 2400	32.0 1 1,152.0 15	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.0	C-OCC	250 1680	8.0 806.4	24.0 345.6	0.0	\$3.31 \$47.62	\$270.00 \$270.00	\$35.00	31.7 71.1 5.7 4.9
20LED 20LED 20LED	Storage Corridor 206 Classroom	1 S 32 C F 1 (ELE) 6 S 32 C F 1 (ELE) 15 S 32 C F 1 (ELE)	F41LL F41LL F41LL	32 32 32		W 1000 W 2280 W 2400	32.0 1 437.8 6 1,152.0 15	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL F41LL	32 32	0.0 0.2 0.5	NONE	250 2280	8.0 437.8 806.4	24.0 0.0 345.6	0.0	\$3.31 \$0.00 \$47.62	\$270.00 \$0.00 \$270.00	\$0.00	31.7 71.1 #DIV/0! 5.7 4.9
20LED 20LED	Storage 208 Classroom	15 S 32 C F 1 (ELE) 1 S 32 C F 1 (ELE) 15 S 32 C F 1 (ELE)	F41LL F41LL	32	0.0	W 2400 W 1000 W 2400	32.0 1 1,152.0 15	S 32 C F 1 (ELE) S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32	0.0 0.5	0-000	250	8.0 806.4	24.0 345.6	0.0	\$3.31 \$47.62	\$270.00 \$270.00 \$270.00	\$35.00 8	31.7 71.1 5.7 4.9
20LED 20LED	Storage 210 Classroom	1 S 32 C F 1 (ELE) 15 S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.0	W 1000 W 2400	32.0 1 1,152.0 15	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.0 0.5	C-OCC C-OCC	250 1680	8.0 806.4	24.0 345.6	0.0	\$3.31 \$47.62	\$270.00 \$270.00 \$270.00	\$35.00 8	31.7 71.1 5.7 4.9
20LED 20LED	Storage Girls Locker Room	1 S 32 C F 1 (ELE) 6 S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.0	W 1000 W 2400	32.0 1 460.8 6	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.0	C-OCC	250 900	8.0 172.8	24.0 288.0	0.0	\$3.31 \$39.68	\$270.00 \$270.00	\$35.00 8	31.7 71.1 6.8 5.9
20LED 40LED	UN-43 Corridor	4 S 32 C F 1 (ELE) 8 T 32 R F 2 (ELE)	F41LL F42LL	32 60	0.1	W 1000 W 2280	128.0 4 1,094.4 8	S 32 C F 1 (ELE) T 32 R F 2 (ELE)	F41LL F42LL	32 60	0.1 0.5	C-OCC NONE	250	32.0 1,094.4	96.0 0.0	0.0	\$13.23 \$0.00	\$270.00 \$0.00	\$35.00 2 \$0.00	20.4 17.8 #DIV/0!
40LED 20LED	Storage 131 Main Office	2 T 32 R F 2 (ELE) 21 S 32 C F 1 (ELE)	F42LL F41LL	60 32	0.7	W 1000 W 2400	120.0 2 1,612.8 21	T 32 R F 2 (ELE) S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F42LL F41LL	60 32	0.1	C-OCC	250 1500		90.0 604.8	0.0	\$12.40 \$83.33	\$270.00 \$270.00		21.8 19.0 3.2 2.8 6.8 5.9
20LED 20LED	103A Principal Office 100A TR	10 S 32 C F 1 (ELE) 1 S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.0	W 2400 W 2400	768.0 10 76.8 1	S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.3		1500 2400	76.8	288.0 0.0	0.0	\$39.68 \$0.00	\$270.00 \$0.00	\$0.00	#DIV/0!
20LED 20LED	103C 103B Storage	5 \$ 32 C F 1 (ELE) 2 \$ 32 C F 1 (ELE)	F41LL F41LL	32 32 32	0.1	W 2400 W 1000	384.0 5 64.0 2	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.2 0.1 0.1	C-OCC NONE	1500 250	240.0 16.0	144.0 48.0	0.0	\$19.84 \$6.61	\$270.00 \$270.00	\$35.00 4	13.6 11.8 40.8 35.5
20LED 20LED 20LED	Vest Corridor	2 S 32 C F 1 (ELE) 2 S 32 C F 1 (ELE) 5 S 32 C F 1 (ELE)	F41LL F41LL F41LL	32	0.1	W 2280 W 2280 W 2400	145.9 2 145.9 2	S 32 C F 1 (ELE) S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL F41LL	32 32	0.1	NONE	2280 2280	145.9	0.0 0.0 144.0	0.0	\$0.00 \$0.00 \$19.84	\$0.00 \$0.00 \$270.00	\$0.00 \$0.00 \$35.00	#DIV/0! #DIV/0! 13.6 11.8
36 20LED	101 Office 101A TR 103 Boys TR	1 2T 3' 17 R F 1 (ELE) 6 S 32 C F 1 (ELE)	F21ILL F41LL	20	0.0	W 2400 W 2400	384.0 5 48.0 1	2T 3' 17 R F 1 (ELE) S 32 C F 1 (ELE)	F21ILL F41LL	20	0.0	NONE NONE		48.0 460.8	0.0	0.0	\$0.00 \$0.00	\$0.00 \$0.00	\$0.00 \$0.00	#DIV/0! #DIV/0!
20LED 20LED	Storage 105 Storage	1 S 32 C F 1 (ELE) 1 S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.0	W 1000 W 1000	460.8 6 32.0 1 32.0 1	S 32 C F 1 (ELE) S 32 C F 1 (ELE) S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.0	C-OCC	250 250	8.0	24.0 24.0	0.0	\$3.31 \$3.31	\$270.00 \$270.00	\$35.00 8	31.7 71.1 31.7 71.1
20LED 34LED	Corridor Corridor	3 S 32 C F 1 (ELE) 1 1T 32 C F 4 (ELE)	F41LL F44ILL	32 112	0.1	W 2280 W 2280	218.9 3 255.4 1	S 32 C F 1 (ELE) 1T 32 C F 4 (ELE)	F41LL F44ILL	32 112	0.1 0.1	NONE NONE	2280 2280	218.9 255.4	0.0	0.0	\$0.00 \$0.00	\$0.00 \$0.00	\$0.00 \$0.00	#DIV/0! #DIV/0!
20LED 40LED	106 Custodial Office MER 102	4 S 32 C F 1 (ELE) 8 T 32 R F 2 (ELE)	F41LL F42LL	32 60	0.1 S 0.5 S	W 2400 W 1820	307.2 4 873.6 8	S 32 C F 1 (ELE) T 32 R F 2 (ELE)	F41LL F42LL	32 60	0.1 0.5	C-OCC	1500 1820	192.0 873.6	115.2 0.0	0.0	\$15.87 \$0.00	\$270.00 \$0.00	\$35.00 1 \$0.00	17.0 14.8 #DIV/0!
20LED 20LED	107 Classroom 106 Storage	18 S 32 C F 1 (ELE) 1 S 32 C F 1 (ELE)	F41LL F41LL	32 32		W 2400 W 1000	1,382.4 18 32.0 1	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.6	C-OCC	1680 250	967.7 8.0	414.7 24.0	0.0	\$57.14 \$3.31	\$270.00 \$270.00		4.7 4.1 31.7 71.1
36 20LED	109 Storage Corridor Corridor	1 2T 3' 17 R F 1 (ELE) 4 S 32 C F 1 (ELE) 1 T 32 R F 2 (ELE)	F21ILL F41LL	20 32		W 1000 W 2280	20.0 1 291.8 4 136.8 1	2T 3' 17 R F 1 (ELE) S 32 C F 1 (ELE) T 32 R F 2 (ELE)	F21ILL F41LL	20 32	0.0	NONE	250 2280	5.0 291.8	0.0	0.0	\$2.07 \$0.00	\$270.00 \$0.00	\$35.00 13 \$0.00	30.6 113.7 #DIV/0!
40LED 40LED 34LED	Corridor Corridor	1 T 32 R F 2 (ELE) 1 T 32 R F 2 (ELE)	F42LL F42LL F44II I	60		W 2280 W 2280 W 2280	136.8 1 255.4 1	T 32 R F 2 (ELE)	F42LL F42LL	60	0.1	NONE NONE NONE	2280 2280 2280	136.8 136.8 255.4	0.0	0.0	\$0.00	\$0.00 \$0.00	\$0.00 \$0.00	#DIV/0! #DIV/0! #DIV/0!
40LED 20LED	108 Office 110 Girls TR	9 T 32 R F 2 (ELE) 5 S 32 C F 1 (ELE)	F42LL F41LL	60	0.5 0.2	W 2400 W 2400	1,296.0 9 384.0 5	T 32 R F 2 (ELE) S 32 C F 1 (ELE)	F42LL F41LL	60	0.5	C-OCC	1500 2400	810.0 384.0	486.0 0.0	0.0	\$66.96 \$0.00	\$270.00 \$0.00	\$35.00 \$0.00	4.0 3.5 #DIV/0!
20LED 34LED	110 Girls TR	1 S 32 C F 1 (ELE) 14 1T 32 C F 4 (ELE)	F41LL F44ILL	32 112	0.0	W 2400 W 2400	76.8 1 3,763.2 14	S 32 C F 1 (ELE) 1T 32 C F 4 (ELE)	F41LL F44ILL	32 112	0.0 1.6	NONE C-OCC	2400 1680	76.8 2,634.2	0.0 1,129.0	0.0	\$0.00 \$155.55	\$0.00 \$270.00		#DIV/0! 1.7 1.5
35LED 34LED	112 Library 112A Office Corridor	4 T 32 R F 3 (ELE) 8 1T 32 C F 4 (ELE)	F43ILL/2 F44ILL	90 112		W 2400 W 2280	864.0 4 2,042.9 8	T 32 R F 3 (ELE) 1T 32 C F 4 (ELE)	F43ILL/2 F44ILL	90 112	0.4 0.9	C-OCC NONE	1500 2280	540.0 2,042.9	324.0 0.0	0.0	\$44.64 \$0.00	\$270.00 \$0.00	\$0.00	6.0 5.3 #DIV/0!
40LED 40LED	116 Social Worker 114 Nurse	2 T 32 R F 2 (ELE) 5 T 32 R F 2 (ELE)	F42LL F42LL	60 60		W 2400 W 2400	288.0 2 720.0 5	T 32 R F 2 (ELE) T 32 R F 2 (ELE)	F42LL F42LL	60 60	0.1 0.3	C-OCC	1500 1500	180.0 450.0	108.0 270.0	0.0	\$14.88 \$37.20	\$270.00 \$270.00	\$35.00	18.1 15.8 7.3 6.3
40LED 36 6LED	114A Nurse Office TR	2 T 32 R F 2 (ELE) 1 2T 3' 17 R F 1 (ELE)	F42LL F21LL F44EE	60 20	0.0	W 2400 W 2400	288.0 2 48.0 1	T 32 R F 2 (ELE) 2T 3' 17 R F 1 (ELE)	F42LL F21ILL	60 20	0.1 0.0	NONE	1500 2400	180.0 48.0	108.0 0.0	0.0	\$14.88 \$0.00	\$270.00 \$0.00	\$0.00	18.1 15.8 #DIV/0!
X4	120 Cafeteria / Gym 120A Gym Storage	80 T 34 R F 4 (MAG) 3 CF26W 1 T 32 R F 2 (FLF)	F44EE CF26/4-L F42LL	144 108 60	0.3	W 1000	33,546.2 80 324.0 3 144.0 1	T 34 R F 4 (MAG) CF26W T 32 R F 2 (FLF)	F44EE CF26/4-L F42LL	144 108 60	11.5 0.3 0.1	C-OCC	2912 250	33,546.2 81.0 90.0	0.0 243.0 54.0	0.0	\$0.00 \$33.48 \$7.44	\$0.00 \$270.00 \$270.00		#DIV/0! 8.1 7.0 36.3 31.6
40LED 65 40LED	120D Office TR 120C Office	1 T 32 R F 2 (ELE) 1 I 100 1 T 32 R F 2 (ELE)	1100/1 F42LL	100	0.1		144.0 1 240.0 1 144.0 1	T 32 R F 2 (ELE) I 100 T 32 R F 2 (ELE)	1100/1 F42LL	100	0.1 0.1 0.1	NONE C-OCC	2400 1500	240.0	0.0 54.0	0.0	\$7.44 \$0.00 \$7.44	\$270.00 \$0.00 \$270.00	\$0.00	36.3 31.6 #DIV/0! 36.3 31.6
65 20LED	120C Office 120 E3 TR	1 I 100 2 S 32 C F 1 (ELE)	1100/1 F41LL	100	0.1	W 2400 W 2400 W 2400	240.0 1 153.6 2	I 100 S 32 C F 1 (ELE)	1100/1 F41LL	100	0.1 0.1 0.1	C-OCC NONE	1500 1500 2400	150.0 153.6	90.0	0.0	\$12.40 \$0.00	\$270.00 \$270.00 \$0.00	\$35.00 2 \$0.00	21.8 19.0 #DIV/0!
20LED 20LED	120 E1 120 E2	2 S 32 C F 1 (ELE) 2 S 32 C F 1 (ELE)	F41LL F41LL	32 32	0.1 S	W 1000 W 1000	64.0 2 64.0 2	S 32 C F 1 (ELE) S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	32	0.1	C-OCC	250 250	16.0 16.0	48.0 48.0	0.0	\$6.61 \$6.61	\$270.00 \$270.00	\$35.00 4 \$35.00 4	40.8 35.5 40.8 35.5
20LED 40LED	120 E4 118 Kitchen	2 S 32 C F 1 (ELE) 3 T 32 R F 2 (ELE)	F41LL F42LL	32 60	0.1 S 0.2 S	W 1000 W 3000	64.0 2 540.0 3 180.0 3	T 32 R F 2 (ELE)	F41LL F42LL	32 60	0.1 0.2	C-OCC	250 1500 250	16.0 270.0	48.0 270.0	0.0	\$6.61 \$37.20	\$270.00 \$270.00	\$35.00 4 \$35.00	40.8 35.5 7.3 6.3
40LED 34LED	122 Storage Corridor	3 T 32 R F 2 (ELE) 3 1T 32 C F 4 (ELE)	F42LL F44ILL	60 112	0.2	W 1000 W 2280	766.1 3	T 32 R F 2 (ELE) 1T 32 C F 4 (ELE)	F42LL F44ILL	60 112	0.2	C-OCC NONE	2280	45.0 766.1	135.0 0.0	0.0	\$18.60 \$0.00	\$270.00 \$0.00	\$35.00 1 \$0.00	14.5 12.6 #DIV/0!
20LED 9LED	124 Auditorium 124 Auditorium	20 S 32 C F 1 (ELE) 24 High Bay MH 200 35 Feet High	F41LL MH200/1	32 232	5.6	W 1820 W 1820	1,164.8 20 10,133.8 24	S 32 C F 1 (ELE) High Bay MH 200 35 Feet High	F41LL MH200/1	32 232	0.6 5.6	C-OCC	1365 1365	873.6 7,600.3	291.2 2,533.4	0.0	\$40.12 \$349.06	\$270.00 \$270.00	\$35.00	6.7 5.9 0.8 0.7
40LED 9LED	Stage Stage 124A Dressing Room	10 T 32 R F 2 (ELE) 1 High Bay MH 200 35 Feet High	F42LL MH200/1	60 232			3,000.0 10 1,160.0 1	T 32 R F 2 (ELE) High Bay MH 200 35 Feet High	F42LL MH200/1	60 232	0.6 0.2	C-0CC	3000 3000	696.0	1,200.0 464.0	0.0	\$165.33 \$63.93	\$270.00 \$270.00		1.6 1.4 4.2 3.7
40LED 40LED 40LED	124A Dressing Room 124C 124B TR	2 T 32 R F 2 (ELE) 2 T 32 R F 2 (ELE) 1 T 32 R F 2 (ELE)	F42LL F42LL F42LL	60 60 60		W 8760 W 1000	1,051.2 2 120.0 2 144.0 1	T 32 R F 2 (ELE) T 32 R F 2 (ELE) T 32 R F 2 (ELE)	F42LL F42LL F42LL	60 60	0.1 0.1 0.1	C-OCC C-OCC NONE	250	1,051.2 30.0	90.0		\$0.00 \$12.40 \$0.00	\$270.00 \$270.00		#DIV/0! 21.8 19.0 #DIV/0!
20LED 40LED	Corridor Corridor	1 132 K F 2 (ELE) 12 S 32 C F 1 (ELE) 7 T 32 R F 2 (ELE)	F42LL F41LL F42LL	32 60	0.4	W 2400 W 2280 W 2280	144.0 1 875.5 12 957.6 7	T 32 R F 2 (ELE) S 32 C F 1 (ELE) T 32 R F 2 (ELE)	F42LL F41LL F42LL	32 60	0.1 0.4 0.4	NONE NONE	2400 2280 2280		0.0	0.0	\$0.00 \$0.00	\$0.00 \$0.00 \$0.00	\$0.00 \$0.00 \$0.00	#DIV/0! #DIV/0! #DIV/0!
34LED 35LED	Corridor Classroom	2 1T 32 C F 4 (ELE) 12 T 32 R F 3 (ELE)	F44ILL F43ILL/2	112 90	0.4 0.2 5 1.1	W 2280 W 2280 W 2400	510.7 2 2,592.0 12	1T 32 C F 4 (ELE) T 32 R F 3 (ELE)	F44ILL F43ILL/2	112 90	0.4 0.2 1.1	NONE C-OCC	2280 2280 1680	957.6 510.7 1,814.4	0.0 777.6	0.0	\$0.00 \$0.00 \$107.14	\$0.00 \$0.00 \$270.00	\$0.00 \$0.00 \$35.00	#DIV/0! 2.5 2.2
35LED 35LED	Classroom Classroom	12 T 32 R F 3 (ELE) 12 T 32 R F 3 (ELE)	F43ILL/2 F43ILL/2	90	1.1 5	W 2400 W 2400	2,592.0 12 2,592.0 12	T 32 R F 3 (ELE) T 32 R F 3 (ELE)	F43ILL/2 F43ILL/2	90	1.1	C-OCC	1680 1680	1,814.4 1,814.4	777.6 777.6	0.0	\$107.14 \$107.14	\$270.00 \$270.00	\$35.00 \$35.00	2.5 2.2 2.5 2.2
35LED 35LED	Classroom Classroom	12 T 32 R F 3 (ELE) 12 T 32 R F 3 (ELE)	F43ILL/2 F43ILL/2	90 90	1.1 S 1.1 S	W 2400 W 2400	2,592.0 12 2,592.0 12	T 32 R F 3 (ELE) T 32 R F 3 (ELE)	F43ILL/2 F43ILL/2	90 90	1.1	C-OCC	1680 1680	1,814.4 1,814.4	777.6 777.6	0.0	\$107.14 \$107.14	\$270.00 \$270.00	\$35.00 \$35.00	2.5 2.2 2.5 2.2
35LED 35LED	Classroom Classroom	12 T 32 R F 3 (ELE) 12 T 32 R F 3 (ELE)	F43ILL/2 F43ILL/2	90 90	1.1	W 2400 W 2400	2,592.0 12 2,592.0 12	T 32 R F 3 (ELE) T 32 R F 3 (ELE)	F43ILL/2 F43ILL/2	90 90	1.1 1.1	C-OCC	1680 1680	1,814.4 1,814.4	777.6 777.6	0.0	\$107.14 \$107.14	\$270.00 \$270.00	\$35.00	2.5 2.2 2.5 2.2
35LED 40LED	Classroom Corridor	12 T 32 R F 3 (ELE) 10 T 32 R F 2 (ELE)	F43ILL/2 F42LL	90 60	1.1 §	W 2400 W 2280	2,592.0 12 1,368.0 10	T 32 R F 3 (ELE) T 32 R F 2 (ELE)	F43ILL/2 F42LL	90 60	1.1 0.6		1680 2280	1,814.4 1,368.0	777.6 0.0	0.0	\$107.14 \$0.00	\$270.00 \$0.00	\$35.00 \$0.00	2.5 2.2 #DIV/0!
												0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!	1	#VA	ALUE! #VALUE!

Energy Audit of Sussec Avenue Elementary School CHA Project No. 27999 ECM-L2 Install Occupancy Sensors

				EXISTING CONDI	TIONS							RETROFIT (CONDITIONS							COST & SAVING	S ANALYSIS			
	Area Description	No. of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/Space	Exist Control	Annual Hours	Annual kWh	Number of Fixture	s Standard Fixture Code	Fixture Code	Watts per Fixture	kW/Space	Retrofit Control	Annual Hours	Annual kWh	Annual kWh Saved	Annual kW Save	d Annual \$ Saved	Retrofit Cost	NJ Smart Start Lighting Incentive	Simple Payback With Out Incentive	Simple Payback
Field Code	Unique description of the location - Room number/Room name: Floor number (if applicable)	No. of fixtures before the retrofit	Lighting Fixture Code	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Fixt No.)	Pre-inst. control device	Estimated annual hours for the usage group	(kW/space) * (Annual Hours)		r "Lighting Fixture Code" Example 2T 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape	Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Number of Fixtures)		Estimated annual hours for the usage group	(kW/space) * (Annual Hours)	(Original Annual kWh) - (Retrofit Annual kWh)	(Original Annual kW) - (Retrofit Annual kW)	(kW Saved) * (\$/kWh)	Cost for renovations to lighting system		Length of time for renovations cost to be recovered	Length of time for renovations cost to be recovered
	otal	861				52.4			128850.1	861.0				52.4			103960.5	24889.6	0.0	3429.3	22680.0	2940.0		
																	Deman	d Savings		0.0	\$0			
																		Savings		24,890	\$3,429			

4/25/2014 Page 6, ECM-L2

Zom Zo zigiti	ng Replacements with Occupancy Sensors			EXISTING CONDIT	TONS							RETROFI	CONDITIONS						COST & SA	AVINGS ANALYSIS			
					Watts per								Watts per	,	Retrofit			Annual kWh			NJ Smart Start Lighting	Simple Payback With Out	
Field Code	Area Description Unique description of the location - Room number/Room	No. of Fixtures No. of fixtures	Standard Fixture Code Lighting Fixture Code	Fixture Code Code from Table of Standard	Fixture Value from	kW/Space (Watts/Fixt) * (Fixt	Pre-inst.	Annual Hours Estimated daily	(kW/space) *		s Standard Fixture Code	Fixture Code Code from Table of	Fixture Value from	(Watts/Fixt) *	Control Retrofit control	ol Estimated	s Annual kWh (kW/space) *	(Original Annual (Original Annual		Cost for	Incentive Prescriptive	Incentive Length of time	Simple Payback Length of time for
	name: Floor number (if applicable)	before the retrofit		Fixture Wattages	Table of Standard	No.)	control device	hours for the usage group	(Annual Hours)	the retrofit		Standard Fixture Wattages	Table of Standard	(Number of Fixtures)	device	annual hours for the usage	(Annual Hours)	kWh) - (Retrofit Annual kWh)	(\$/kWh)	renovations to lighting system	Lighting Measures	for renovations cost to be	renovations cost to be recovered
	***		0.00.0 5.4 (51.5)	5444	Fixture Wattages							440-00	Fixture Wattages			group						recovered	
20LED 20LED	300 Classroom 301 Classroom	18 18	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL F41LL	3.	2 0.6 2 0.6 2 0.5	SW SW	240	00 1,382 00 1,382 00 1,152	18	4 ft LED Tube 4 ft LED Tube 4 ft LED Tube	200732x1 200732x1 200732x1	15 15 15	0.3	C-OCC	1,68	0 454 0 454		\$ 152 \$ 152 \$ 126	.24 \$ 2,420.55 .24 \$ 2,420.55	\$ 35	15.9 15.9	15.7 15.7
20LED 20LED	302 Classroom 303 Classroom	15	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL F41LL	3.	2 0.5 2 0.5 2 0.1	SW SW	240 240	00 1,152	15	4 ft LED Tube 4 ft LED Tube 4 ft LED Tube	200732x1	15 15 15	0.2 0.2 0.0	C-OCC NONE	1,68	0 378	774 0.3 774 0.3	\$ 126. \$ 126. \$ 20.	.87 \$ 2,062.13	\$ 35	16.3 16.3 17.9	16.0 16.0 17.9
20LED 20LED 20LED	Corridor Stair Stair	2	S 32 C F 1 (ELE) S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	3.	2 0.1	SW	228 624 624	40 399	2	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1 200732x1	15	0.0	NONE NONE	6,24 6,24		212 0.0	\$ 31. \$ 63.	.93 \$ 238.95	\$ -	7.5 7.5	7.5
20LED 20LED	304 Computer Room 305 Classroom	15	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	3.	2 0.5	SW	240		15	4 ft LED Tube 4 ft LED Tube	200732X1 200732X1 200732X1		0.2	C-OCC	1,68	0 378		\$ 126. \$ 126.	.87 \$ 2,062.13	\$ 35	16.3 16.3	16.0 16.0
20LED 20LED	306 Classroom 308 Classroom	19	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	3.	2 0.6	SW	240		19	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15 15	0.3	C-OCC	1,68	0 479 0 428		\$ 160. \$ 143.	.70 \$ 2,540.03	\$ 35	15.8 16.0	15.6 15.8
20LED 20LED	310 Classroom Corridor	15 4	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	3:	2 0.5 2 0.1	SW	240 228	00 1,152	15	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15 15	0.2	C-OCC NONE	1,68 2,28	0 378		\$ 126. \$ 26.	.87 \$ 2,062.13	\$ 35	16.3 17.9	16.0 17.9
20LED 20LED	Mens TR UN-52	1 1	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	3:	2 0.0	SW SW	240 100		1 1	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1		0.0	NONE C-OCC	2,40	0 36	41 0.0 28 0.0	\$ 6.	.97 \$ 119.48 .24 \$ 389.48	\$ -	17.1	17.1 67.6
20LED 20LED	UN-53 UN-54	1	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	3.	2 0.0 2 0.0	SW	100	00 32 00 32	1 1	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15	0.0	C-OCC	25 25	0 4	28 0.0	\$ 5.	24 \$ 389.48 24 \$ 389.48	\$ 35	74.3 74.3	67.6 67.6
20LED 20LED	UN-50 UN-51	1 1	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	3:	2 0.0	SW	100	00 32 00 32	1 1	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15 15	0.0	C-OCC	25 25	0 4	28 0.0 28 0.0		24 \$ 389.48 24 \$ 389.48			67.6 67.6
20LED 20LED	Corridor 314A Office	11 6	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	3.		SW	228 240	00 461	11 6	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1		0.2 0.1	NONE C-OCC	2,28 1,50	0 135	326 0.1	\$ 52.	.58 \$ 1,314.23 .98 \$ 986.85	\$ 35	17.9 18.6	17.9 18.0
20LED 20LED	314B Art 314	13	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	3.	2 0.4 2 0.0	SW	240 240 240		13	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15 15	0.2	C-OCC	1,68 1,68	0 328	52 0.0	\$ 8.	.95 \$ 1,823.18 .46 \$ 389.48	\$ 35	16.6 46.0	16.3 41.9
20LED 20LED	316 Science 318 Classroom	12 12	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	3	2 0.4 2 0.4	SW SW	240	00 922	12	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15 15	0.2 0.2	C-OCC C-OCC	1,68 1,68	0 302	619 0.2	\$ 101.	.49 \$ 1,703.70 .49 \$ 1,703.70	\$ 35	16.8	16.4 16.4
20LED 20LED	320 Classroom 313 Storage	12	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	3.	2 0.4 2 0.0	SW SW	100	00 32	12	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1 RTLED38	15 15	0.2	C-OCC	1,68 25	0 302	619 0.2 28 0.0	\$ 5.	.49 \$ 1,703.70 .24 \$ 389.48	\$ 35		16.4 67.6
40LED 40LED	311 Storage 309 Storage	1	T 32 R F 2 (ELE) T 32 R F 2 (ELE)	F42LL F42LL	6	0 0.1	SW	100	00 60	1	T 59 R LED T 59 R LED	RTLED38 RTLED38	38	0.0	C-0CC	25	0 10	51 0.0 51 0.0	\$ 8.	.70 \$ 506.25 .70 \$ 506.25	\$ 35	58.2 58.2	54.1 54.1
40LED 40LED 40LED	307 Utility Room Storage Stairs	1	T 32 R F 2 (ELE) T 32 R F 2 (ELE) T 32 R F 2 (ELE)	F42LL F42LL F42LL	6	0 0.3	SW SW SW	100 100 624		1	T 59 R LED T 59 R LED T 59 R LED	RTLED38 RTLED38 RTLED38	38 38	0.2	NONE C-OCC	1,00	0 10	110 0.1 51 0.0	\$ 8.	.88 \$ 1,181.25 .70 \$ 506.25	\$ 35	49.5 58.2	49.5 54.1
20LED	200 Classroom	15	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	3	2 0.5	SW	240	00 1,152		4 ft LED Tube	200732x1	38 15	0.1	NONE C-OCC	6,24 1,68	0 474 0 378		\$ 41. \$ 126.			11.4 16.3	11.4 16.0
20LED 20LED 20LED	201 Classroom 202 Classroom 203 Nurse Office	15	S 32 C F 1 (ELE) S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL F41LL	3.	2 0.5 2 0.5 2 0.4	SW	240	00 1.152	15	4 ft LED Tube 4 ft LED Tube 4 ft LED Tube	200732x1 200732x1 200732x1	15 15	0.2 0.2	0.000	1,68	0 378 0 378		\$ 126. \$ 126. \$ 105.	.87 \$ 2,062.13	\$ 35	16.3 16.3 16.1	16.0 16.0 15.7
20LED 20LED 20LED	Exam Room UN-29	3	S 32 C F 1 (ELE) S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	3.	2 0.1	SW	240 240 100	00 230	3	4 ft LED Tube 4 ft LED Tube 4 ft LED Tube	200732x1 200732x1 200732x1	15 15 15	0.0	C-00C	1,50	0 68 0 4	652 0.2 163 0.1 28 0.0	\$ 26.	.49 \$ 628.43 .24 \$ 389.48	\$ 35	16.1 23.7 74.3	22.4 67.6
20LED 20LED	UN-28 Corridor	1 4	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	3.	2 0.0	SW	100	00 32	1 4	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15 15	0.0	C-OCC NONE	25 2.28	0 4	28 0.0 155 0.1	\$ 5.	24 \$ 389.48 .76 \$ 477.90	\$ 35	74.3 17.9	67.6 17.9
20LED 20LED	Stair 204 Classroom	3 15	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	3.	2 0.1	SW	228 624 240		3 15	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15	0.0	NONE C-OCC	6,24	0 281 0 378	318 0.1 774 0.3	\$ 47. \$ 126.	.89 \$ 358.43	\$ -	7.5 16.3	7.5 16.0
20LED 20LED	Storage 205 Classroom	1 15	S 32 C F 1 (ELE)	F41LL F41LL	3.	2 0.0 2 0.5	SW	240 100 240 100		1 15	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15 15 15	0.0 0.2	C-OCC C-OCC	25 1,68	0 4 0 378	28 0.0 774 0.3		.24 \$ 389.48	\$ 35	74.3 16.3	67.6 16.0
20LED 20LED	Storage Corridor	6	S 32 C F 1 (ELE) S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	3.	2 0.0	SW SW	100		1 6	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15 15	0.0 0.1	C-OCC NONE	25 2,28	0 4	28 0.0 233 0.1	\$ 40.	24 \$ 389.48 .13 \$ 716.85	\$ 35	74.3 17.9	67.6 17.9
20LED 20LED	206 Classroom Storage 208 Classroom	15 1	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	3:	2 0.5	SW	240	00 1,152	15	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15 15	0.2	C-OCC	1,68 25	0 378	28 0.0		.24 \$ 389.48	\$ 35	16.3 74.3	16.0 67.6
20LED 20LED	Storage	15 1	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	3.	2 0.5 2 0.0	SW	240 100		15	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15 15	0.2	C-OCC	1,68 25	0 378	28 0.0	\$ 126. \$ 5.	.24 \$ 389.48	\$ 35	16.3 74.3	16.0 67.6
20LED 20LED	210 Classroom Storage	15	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	3:	2 0.5 2 0.0	SW	240 100		15	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15 15	0.2	C-OCC	1,68 25	0 378	28 0.0	\$ 126. \$ 5.	.24 \$ 389.48	\$ 35	16.3 74.3	16.0 67.6
20LED 20LED	Girls Locker Room UN-43	6	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	3.	2 0.2 2 0.1	SW	100		6	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1 RTLED38	15 15	0.1 0.1	C-OCC	90 25	0 81	380 0.1 113 0.1		.96 \$ 747.90	\$ 35	16.3 35.7	15.8 34.0
40LED 40LED	Corridor Storage 131 Main Office	2	T 32 R F 2 (ELE) T 32 R F 2 (ELE) S 32 C F 1 (ELE)	F42LL F42LL F41LL	6	0 0.5	SW SW SW	228 100 240	00 120	2	T 59 R LED T 59 R LED	RTLED38	38	0.3 0.1	C-OCC	2,28	0 19	101 0.0	\$ 17.		\$ 35	27.3 42.7	27.3 40.6
20LED 20LED	131 Main Office 103A Principal Office 100A TR	10	S 32 C F 1 (ELE) S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL F41LL	3.	2 0.7 2 0.3 2 0.0	SW	240	00 768	10	4 ft LED Tube 4 ft LED Tube 4 ft LED Tube	200732x1 200732x1 200732x1	15 15 15	0.3	C-OCC NONE	1,50 1,50 2,40	0 473 0 225	543 0.2	\$ 185. \$ 88.	.30 \$ 1,464.75	\$ 35	15.0 16.6 17.1	14.8 16.2 17.1
20LED 20LED 20LED	103C 103B Storage	5	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	3.	2 0.2	SW	240	00 384	5	4 ft LED Tube 4 ft LED Tube	200732X1 200732X1 200732X1	15 15 15	0.0 0.1 0.0	C-OCC	1,50	0 113	41 0.0 272 0.1 57 0.0		.97 \$ 119.48 .15 \$ 867.38 .48 \$ 508.95	\$ 35	19.6 48.6	18.9 45.2
20LED 20LED	Vest Corridor	2 2	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	3.	2 0.1	SW	228	30 146	2 2	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15	0.0	NONE NONE	2,28 2,28	0 68	78 0.0 78 0.0	\$ 13.	38 \$ 238.95 38 \$ 238.95	\$ -	17.9 17.9	17.9 17.9
20LED 36	101 Office 101A TR	5 1	S 32 C F 1 (ELE) 2T 3' 17 R F 1 (ELE)	F41LL F21LL	3.	2 0.2 0 0.0	SW SW	240 240		5	4 ft LED Tube 2T 3' 17 R F 1 (ELE)	200732x1 F21ILL	15 20	0.1 0.0	C-OCC NONE	1,50 2,40	0 113	272 0.1		.15 \$ 867.38		19.6	18.9
20LED 20LED	103 Boys TR Storage	6	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	3.	2 0.2 2 0.0	SW	240 100	00 461	6	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15 15	0.1 0.0	NONE C-OCC	2,40 25		28 0.0	\$ 5.	.82 \$ 716.85 .24 \$ 389.48	\$ 35	17.1 74.3	17.1 67.6
20LED 20LED	Storage 105 Storage Corridor	1 3	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	3:	2 0.0 2 0.1	SW	100	30 219	1 3	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15 15	0.0	C-OCC NONE	25 2,28	0 4	28 0.0 116 0.1	\$ 5. \$ 20.	24 \$ 389.48 .07 \$ 358.43	\$ 35	74.3 17.9	67.6 17.9
34LED 20LED	Corridor 106 Custodial Office	1 4	1T 32 C F 4 (ELE) S 32 C F 1 (ELE)	F44ILL F41LL	11:	2 0.1 2 0.1	SW SW SW	228 240 182		1 4	4 ft LED Tube 4 ft LED Tube	200732x2 200732x1	30 15	0.0 0.1	NONE C-OCC	2,28 1,50	0 68	187 0.1 217 0.1	\$ 35.	.26 \$ 163.35 .32 \$ 747.90	\$ 35	5.1 21.2	5.1 20.2
40LED 20LED	MER 102 107 Classroom	8 18	T 32 R F 2 (ELE) S 32 C F 1 (ELE)	F42LL F41LL	6	0 0.5 2 0.6	SW SW SW	182 240 100		8	T 59 R LED 4 ft LED Tube	RTLED38 200732x1	38 15 15	0.3	NONE C-OCC	1,82 1,68	0 553 0 454	320 0.2 929 0.3	\$ 152.	.09 \$ 1,890.00 .24 \$ 2,420.55	\$ 35	32.5 15.9	32.5 15.7
20LED 36	106 Storage 109 Storage	1	S 32 C F 1 (ELE) 2T 3' 17 R F 1 (ELE)	F41LL F21ILL	3	2 0.0 0 0.0	SW	100	00 20	1 1	4 ft LED Tube 2T 3' 17 R F 1 (ELE)	200732x1 F21ILL	20	0.0	C-OCC	25 25	0 4	28 0.0 15 0.0	\$ 2.	.24 \$ 389.48 .07 \$ 270.00 .76 \$ 477.90		74.3 130.6	67.6 113.7
20LED 40LED	Corridor Corridor	1	S 32 C F 1 (ELE) T 32 R F 2 (ELE)	F41LL F42LL	6	0.1	SW SW SW	228	30 137	1	4 ft LED Tube T 59 R LED T 59 R LED	200732x1 RTLED38	15 38 38	0.1	NONE NONE	2,28	0 87	155 U.1 50 0.0	\$ 8.	.66 \$ 236.25	\$ -	17.9 27.3 27.3	17.9 27.3 27.3
40LED 34LED	Corridor Corridor	1	T 32 R F 2 (ELE) 1T 32 C F 4 (ELE)	F42LL F44ILL F42LL	11:	0 0.1 2 0.1	SW SW	228 228	30 255	1	4 ft LED Tube T 59 R LED	RTLED38 200732x2 RTLED38	30	0.0	NONE	2,28	0 68	187 0.1	\$ 32.	.66 \$ 236.25 .26 \$ 163.35 .59 \$ 2.396.25	\$ -	27.3 5.1 19.4	5.1
40LED 20LED 20LED	108 Office 110 Girls TR 110 Girls TR	5	T 32 R F 2 (ELE) S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F42LL F41LL F41LL	3	0 0.5 2 0.2 2 0.0	SW SW	240 240 240	00 1,296 00 384	5	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	38 15 15	0.3 0.1 0.0	NONE NONE	2,40 2,40		783 0.2 204 0.1 41 0.0	\$ 34.	.59 \$ 2,396.25 .85 \$ 597.38 .97 \$ 119.48	\$ -	19.4 17.1 17.1	19.1 17.1 17.1
34LED 35LED	112 Library 112A Office	14	1T 32 C F 4 (ELE) T 32 R F 3 (ELE)	F44ILL F43ILL/2	11:		SW	240		14	4 ft LED Tube 4 ft LED Tube T 59 R LED	200732X1 200732X2 RTLED38	30 38	0.4	C-000	1,68	0 706		\$ 512 \$ 104	.34 \$ 2,556.90	\$ 35	5.0 11.7	4.9 11.3
34LED 40LED	Corridor 116 Social Worker	8 2	1T 32 C F 4 (ELE) T 32 R F 2 (ELE)	F44ILL F42LL	11:	2 0.9 0 0.1	SW	228 240	30 2,043 00 288	8 2	4 ft LED Tube T 59 R LED	200732x2 RTLED38	30	0.2 0.2 0.1	NONE C-OCC	2,28 1,50	0 547 0 114	1,496 0.7	\$ 258. \$ 27.	.11 \$ 1,306.80	\$ -	5.1 27.0	5.1 25.8
40LED 40LED	114 Nurse 114A Nurse Office	5 2	T 32 R F 2 (ELE) T 32 R F 2 (ELE)	F42LL F42LL	6	0 0.3	SW	240	00 720 00 288	5 2	T 59 R LED T 59 R LED	RTLED38 RTLED38	30 38 38 38	0.2 0.1	C-OCC	1,50 1,50	0 285 0 114	435 0.1 174 0.0	\$ 68.	.66 \$ 1,451.25 .46 \$ 742.50	\$ 35	21.1 27.0	20.6 25.8
36 6LED	TR 120 Cafeteria / Gym	1 80	2T 3' 17 R F 1 (ELE) T 34 R F 4 (MAG)	F21ILL F44EE	214	0 0.0 4 11.5	SW SW	240 291	00 48 12 33,546	1 80	2T 3' 17 R F 1 (ELE) T 74 R LED	F21ILL RTLED50	20 50	0.0 4.0	NONE NONE	2,40 2,91	0 48 2 11,648	- 0.0 21,898 7.5	\$ -	. \$ -	\$ -	5.2	5.2
X4 40LED	120A Gym Storage 120D Office	3	CF26W T 32 R F 2 (ELE)	CF26/4-L F42LL	10	8 0.3 0 0.1	SW	100 240	00 <u>32</u> 4 00 144	3	CF26W T 59 R LED	CF26/4-L RTLED38	108 38	0.3 0.0	C-OCC	25 1,50	0 81 0 57	243 0.0 87 0.0	\$ 33. \$ 13.	.48 \$ 270.00 .73 \$ 506.25	\$ 35	8.1 36.9	7.0 34.3
65 40LED	TR 120C Office	1	I 100 T 32 R F 2 (ELE)	1100/1 F42LL	10	0 0.1 0 0.1 0 0.1	SW SW SW	240 240 240	00 240	1 1	CF 26 T 59 R LED	CFQ26/1-L RTLED38	27 38	0.0 0.0	NONE C-OCC	2,40 1,50	0 65 0 57	175 0.1 87 0.0	\$ 29. \$ 13.	.93 \$ 40.50 .73 \$ 506.25	\$ -	1.4 36.9	1.4 34.3
65 20LED	120C Office 120 E3 TR	1 2	I 100 S 32 C F 1 (ELE)	I100/1 F41LL		2 0.1	SW	240 240 100	00 240 00 154	1 2	CF 26 4 ft LED Tube	CFQ26/1-L 200732x1 200732x1	27	0.0	C-OCC NONE	1,50 2,40	0 41 0 72	200 0.1	\$ 13.	.28 \$ 310.50 .94 \$ 238.95	S -	9.3 17.1	8.3 17.1
20LED 20LED	120 E1 120 E2	2	S 32 C F 1 (ELE) S 32 C F 1 (ELE)	F41LL F41LL	3.	2 0.1	SW SW	100 100 100		2	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1 200732x1	15	0.0	C-OCC	25 25	0 8	57 0.0 57 0.0 57 0.0	\$ 10.	.48 \$ 508.95 .48 \$ 508.95	\$ 35	48.6 48.6	45.2 45.2
20LED 40LED	120 E4 118 Kitchen	3	S 32 C F 1 (ELE) T 32 R F 2 (ELE)	F41LL F42LL	6		SW SW	300	00 540	3	4 ft LED Tube T 59 R LED	RTLED38	15 38	0.0 0.1	C-OCC C-OCC	25 1,50	0 8	369 0.1	\$ 56.	.48 \$ 508.95 .08 \$ 978.75	\$ 35	17.5	45.2 16.8
40LED 34LED	122 Storage Corridor 124 Auditorium	3 3	T 32 R F 2 (ELE) 1T 32 C F 4 (ELE)	F42LL F44ILL F41LL	11:		SW SW	100	30 766	3	T 59 R LED 4 ft LED Tube	RTLED38 200732x2	38 30 15	0.1 0.1	C-OCC NONE	25 2,28	0 29 0 205	561 0.2	\$ 96.	.11 \$ 978.75 .79 \$ 490.05 .03 \$ 2.659.50	\$ -	5.1	36.1 5.1
20LED 9LED 40LED	124 Auditorium	20 24 10	S 32 C F 1 (ELE) High Bay MH 200 35 Feet High T 32 R F 2 (FLE)	MH200/1	23		SW SW	182 182 500	20 10,134	24	4 ft LED Tube FXLED78 T 59 R LED	200732x1 FXLED78/1 RTI FD38	78	0.3 1.9	0.000	1,36	5 410 5 2,555 0 1 140	7,578 3.7	\$ 131. \$ 1,337. \$ 273	.34 \$ 20,530.69	\$ 3,635	15.4	20.0 12.6
40LED 9LED 40LED	Stage Stage 124A Dressing Room	1 1	T 32 R F 2 (ELE) High Bay MH 200 35 Feet High T 32 R F 2 (ELE)	F42LL MH200/1 F42LL	23	0 0.6 2 0.2 0 0.1	SW SW SW	500 500 876	3,000 3,000 1,160 1,051	1 1	FXLED78 T 59 R LED	RTLED38 FXLED78/1 RTLED38	38 78 38	0.4 0.1 0.1	0.000	3,00	0 1,140 0 234	926 0.2	\$ 273. \$ 139. \$ 56		\$ 185		9.5 6.6 12.5
40LED 40LED	124A Diessing Room 124C 124B TR	2	T 32 R F 2 (ELE) T 32 R F 2 (ELE) T 32 R F 2 (ELE)	F42LL F42LL F42LL	6		SW	100	00 120	2	T 59 R LED T 59 R LED	RTLED38 RTLED38 RTLED38	38 38 38	0.1 0.0	C-OCC NONE	8,76 25 2.40	0 19	101 0.0	\$ 56. \$ 17. \$ 9	.60 \$ 742.50 .41 \$ 742.50 .02 \$ 236.25			12.5 40.6 26.2
20LED 40LED	Corridor Corridor	12	S 32 C F 1 (ELE) T 32 R F 2 (ELE)	F41LL F42LL	3.	0.4 0 0.4	SW	240 228 228			4 ft LED Tube T 59 R LED	200732x1	15	0.0 0.2 0.3	NONE	2,40 2,28 2,28			\$ 80.	.02 \$ 236.25 .27 \$ 1,433.70 .59 \$ 1,653.75	\$ -	26.2 17.9 27.3	26.2 17.9 27.3
34LED 35LED	Corridor Classroom	2 12	1T 32 C F 4 (ELE) T 32 R F 3 (ELE)	F44ILL F43ILL/2	11:	2 0.2	SW	228	30 511 00 2,592		4 ft LED Tube T 59 R LED	RTLED38 200732x2 RTLED38	38 30 38	0.5 0.1 0.5	NONE NONE C-OCC	2,28 2,28 1,68	0 137 0 766	374 0.2	\$ 64. \$ 301.	.53 \$ 326.70	S -	5.1 10.3	27.3 5.1 10.2
35LED 35LED	Classroom Classroom	12 12	T 32 R F 3 (ELE) T 32 R F 3 (ELE)	F43ILL/2 F43ILL/2	9	0 1.1 0 1.1	SW SW	240 240 240		12	T 59 R LED T 59 R LED	RTLED38 RTLED38 RTLED38	38 38 38	0.5 0.5	C-OCC	1,68 1,68	0 766 0 766	1,826 0.6 1,826 0.6	\$ 301. \$ 301.	.07 \$ 3,105.00 .07 \$ 3,105.00	\$ 35	10.3 10.3	10.2 10.2
35LED 35LED	Classroom Classroom	12	T 32 R F 3 (ELE) T 32 R F 3 (ELE)	F43ILL/2 F43ILL/2	9	0 1.1 0 1.1	SW	240 240 240	00 2,592	12	T 59 R LED T 59 R LED	RTLED38	38	0.5 0.5	C-OCC	1,68 1,68	0 766 0 766	1,826 0.6 1,826 0.6	\$ 301. \$ 301.	.07 \$ 3,105.00 .07 \$ 3.105.00	\$ 35	10.3 10.3	10.2 10.2
35LED 35LED	Classroom Classroom	12 12	T 32 R F 3 (ELE) T 32 R F 3 (ELE)	F43ILL/2 F43ILL/2	9	0 1.1 0 1.1	SW SW	240 240 240	00 2,592	12	T 59 R LED T 59 R LED	RTLED38 RTLED38	38	0.5 0.5	C-OCC	1,68 1,68	0 766 0 766	1,826 0.6 1,826 0.6	\$ 301. \$ 301.	.07 \$ 3,105.00 .07 \$ 3,105.00	\$ 35	10.3 10.3	10.2 10.2
35LED 40LED	Classroom Corridor	12 10	T 32 R F 3 (ELE) T 32 R F 2 (ELE)	F43ILL/2 F42LL	9	0 1.1 0 0.6	SW SW	240 228	00 2,592	12	T 59 R LED T 59 R LED	RTLED38 RTLED38	38 38	0.5 0.4	C-OCC NONE	1,68 2,28 #N/A	0 766 0 866	1,826 0.6	\$ 301. \$ 86.	.07 \$ 3,105.00 .56 \$ 2,362.50	\$ 35	10.3 27.3	10.2 27.3
				<u> </u>							1				0	#N/A	_				1 -		#VALUE!

				EXISTING CONDI	TIONS							RETROFIT CO	ONDITIONS							COST & SAVI	IGS ANALYSIS			
					Watts per								Watts per		Retrofit			Annual kWh				NJ Smart Start Lighting	Simple Payback With Out	
	Area Description	No. of Fixtures	Standard Fixture Code	Fixture Code	Fixture	kW/Space	Exist Control	Annual Hours	Annual kWh	Number of Fixtures	Standard Fixture Code	Fixture Code	Fixture	kW/Space	Control	Annual Hours	Annual kWh	Saved	Annual kW Saved	Annual \$ Saved	Retrofit Cost	Incentive	Incentive	Simple Payback
Field Code	Unique description of the location - Room number/Room name: Floor number (if applicable)	No. of fixtures before the retrofit	Lighting Fixture Code	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture	(Watts/Fixt) * (Fi	ixt Pre-inst. control device	Estimated daily hours for the usage group		No. of fixtures after the retrofit		Wattages	Table of	(Watts/Fixt) * (Number of Fixtures)	Retrofit contr device	annual hours	(kW/space) * (Annual Hours)	(Original Annual kWh) - (Retrofit Annual kWh)	(Original Annual kW) - (Retrofit Annual kW)	(kWh Saved) * (\$/kWh)	Cost for renovations to lighting system	Prescriptive Lighting Measures	Length of time for renovations cost to be recovered	Length of time for renovations cost to be recovered
					Wattages								Wattages			• '								
s T	otal	861				52.4			128,850	861				22.4			43,358		30.1	14,163	175,359	\$6,690		
S		-	-	-	-		-	-	-	_	•	-		-	-			and Savings		30.1	\$2,384			
S																		h Savings		85,492	\$11,779			
S																	Tot	al Savings			\$14,163		12.4	11.9

4/25/2014 Page 8, ECM-L3

APPENDIX D

New Jersey Board of Public Utilities Incentives

- i. Smart Start
- ii. Direct Install
- iii. Pay for Performance (P4P)
- iv. Energy Savings Improvement Plan (ESIP)

I. SMART START



At Home, for Business, and for the Future

About Us | Press Room | Library

HOME

RESIDENTIAL

COMMERCIAL, NOUS TRIAL AND LOGAL GOVERNMENT





Home » Commercial & Industrial » Programs

NJ SmartStart Buildings

Program Overview



HURRICANE SANDY

PROGRAMS

NJ SMARTSTART BUILDINGS

EQUIPMENT INCENTIVES

FOOD SERVICE EQUIPMENT

APPLICATION FORMS

TOOLS AND RESOURCES

PAY FOR PERFORMANCE

COMBINED HEAT & POWER AND FUEL CELLS

LOCAL GOVERNMENT ENERGY AUDIT

LARGE ENERGY USERS PROGRAM

ENERGY SAVINGS IMPROVEMENT PROGRAM

DIRECT INSTALL

ENERGY BENCHMARKING

OIL, PROPANE & MUNICIPAL **ELECTRIC CUSTOMERS**

EDA PROGRAMS

SBC CREDIT PROGRAM



With New Jersey SmartStart Buildings ...

... A smart start now means better performance later! Whether you're starting a commer industrial project from the ground up, renovating existing space, or upgrading equipmenunique opportunities to upgrade the energy efficiency of the project.

Special Notice

Enhanced incentives are available for NJ SmartStart Building upgrades in buildings im-Hurricane Sandy. Eligible projects receive an additional 50% and new incentives have added for high efficiency food service equipment.

Visit the Sandy web page for details and important links.

New Jersey SmartStart Buildings can provide a range of support — at no cost to you substantial energy savings, both now and for the future. Learn more about:

> **Project Categories Custom Measures**

Incentives for Qualifying Equipment and Projects

Program Terms and Conditions

Find a Trade Ally

Please note: pre-approval is required for almost all energy efficiency incentives. I you must submit an application form (and applicable worksheets) and receive an approv from the program before any equipment is installed (click here for complete Terms and (Upon receipt of an approval letter, you may proceed to install the equipment listed on yo approved application. Equipment installed prior to the date of the approval letter is not e an incentive. Any customer and/or agent who purchases equipment prior to the rec incentive approval letter does so at his/her own risk.

Getting Started

Submit your project application form as soon as you know you will be doing a constructive or replacing/adding equipment.

PAST PROGRAMS

TOOLS AND RESOURCES

PROGRAM UPDATES

CONTACT US

Apply for pre-approval by submitting an application for the type of equipment you have c install. The application should be accompanied by a related worksheet, where applicable manufacturer's specification sheet (refer to the specific program requirements on the ba application for specs needed for your project) for the equipment you are planning to inst (Program representatives will review your application package and approve it, reject it, advise you of upgrades in equipment that will save energy costs and/or increase your in

Support for Custom Energy-Efficiency Measures

Custom measures allows program participants the opportunity to receive an incentive fo energy-efficiency measures that are not on the prescriptive equipment Incentive list, but project/facility specific.

Incentives for Qualifying Equipment and Projects

Financial incentives are available for large and small projects. These incentives offset so maybe even all! — of the added cost to purchase qualifying energy-efficient equipment, provides significant long-term energy savings. Ranges of incentives are available for quequipment (depending on type, size, and efficiency) in several categories.

Find out more about equipment incentives

For specific details on equipment requirements and financial incentives, including ince equipment not listed here, contact a program representative. Fiscal year financial incent be limited to a maximum of \$500,000 per customer utility account and are available as fi permits.

Home | Residential | Commercial & Industrial | Renewable Energy About Us | Press Room | Library | FAQs | Calendar | Newsletters | Contact Us | Site



At Home, for Business, and for the Future

About Us | Press Room | Library

HOME

RESIDENTIAL

BOMMERGIAL, INDUSTRIAL





COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

HURRICANE SANDY

PROGRAMS

NJ SMARTSTART BUILDINGS

EQUIPMENT INCENTIVES

FOOD SERVICE EQUIPMENT

APPLICATION FORMS

TOOLS AND RESOURCES

PAY FOR PERFORMANCE

COMBINED HEAT & POWER AND FUEL CELLS

LOCAL GOVERNMENT ENERGY AUDIT

LARGE ENERGY USERS PROGRAM

ENERGY SAVINGS IMPROVEMENT PROGRAM

DIRECT INSTALL

ENERGY BENCHMARKING

OIL, PROPANE & MUNICIPAL **ELECTRIC CUSTOMERS**

EDA PROGRAMS

SBC CREDIT PROGRAM

Home » Commercial & Industrial » Programs » NJ SmartStart Buildings

AND LOGAL GOVERNMENT

Equipment Incentives

Special Notice


Enhanced incentives are available for NJ SmartStart Building upgrades in buildings imp Hurricane Sandy. Eligible projects receive an additional 50% and new incentives have added for high efficiency food service equipment.

Visit the Sandy web page for details and important links.

More reasons for a smart start on your next project!

New Jersey SmartStart Buildings provides financial incentives for qualifying equipment. These incentives were developed to help our customers offset some of the added cost to purchase qualifying energy-efficient equipment, which provides significant long-term energy savings. A wide range of incentives are available for qualifying equipment (depending on type, size and efficiency).

Listed below are the types of qualifying equipment and ranges of incentives. For details on equipment requirements and full listings of incentives, refer to the online application forms.



(click for exceptions) To start the pre-approval process,

submit an Equipment Application, and appropriate Equipment Worksheets, for the type of types of equipment you are planning to install along with equipment specification sheets (refer to the specific program requirements on the back of the application for specificatic needed for your project) and a current utility bill(s).

In order to be eligible to receive financial incentives under this Program, Applicants mus receive electric and/or gas service from one of the regulated electric and/or gas utilities in the State of New Jersey. They are: Atlantic City Electric, Jersey Central Power & Light, Rockland Electric Company, New Jersey Natural Gas, Elizabethtown Gas, PSE&G, and South Jersey Gas.

Electric Chillers

Water-cooled chillers (\$12 - \$170 per ton) Air-cooled chillers (\$8 - \$52 per ton)

Gas Cooling

Gas absorption chillers (\$185-\$450 per ton) Gas Engine-Driven Chillers (Calculated through Custom Measure F **PAST PROGRAMS**

TOOLS AND RESOURCES

PROGRAM UPDATES

CONTACT US

Desiccant Systems (\$1.00 per cfm - gas or electric)

Electric Unitary HVAC

Unitary AC and split systems (\$73 - \$92 per ton)
Air-to-air heat pumps (\$73 - \$92 per ton)
Water-source heat pumps (\$81 per ton)
Packaged terminal AC & HP (\$65 per ton)
Central DX AC Systems (\$40 - \$72 per ton)
Dual Enthalpy Economizer Controls (\$250)
Occupancy Controlled Thermostats (\$75 each)
A/C Economizing Controls (\$85 - \$170 each)

Ground Source Heat Pumps

Closed Loop (\$450-750 per ton)

Gas Heating

Gas-fired boilers < 300 MBH (\$300 per unit)
Gas-fired boilers ≥ 300 MBH - 1500 MBH (\$1.75 per MBH)
Gas-fired boilers ≥ 1500 MBH - ≤ 4000 MBH (\$1.00 per MBH)
Gas-fired boilers > 4000 MBH (Calculated through Custom Measure
Gas furnaces (\$300-\$400 per unit)
Gas infrared heaters - indoor only (\$300 - \$500 per unit)
Boiler economizing controls (\$1,200 - \$2,700 per unit)

Variable Frequency Drives

Variable air volume (\$65 - \$155 per hp)
Chilled-water pumps (\$60 per hp)
Compressors (\$5,250 to \$12,500 per drive)

Natural Gas Water Heating

Gas water heaters ≤ 50 gallons (\$50 per unit)
Gas-fired water heaters > 50 gallons (\$1.00 - \$2.00 per MBH)
Tankless water heaters replacing a free standing water heater > 82 energy factor (\$300 per heater)
Gas-fired booster water heaters (\$17 - \$35 per MBH)

Premium Motors

Three-phase motors (\$45 - \$700 per motor) (Incentive was discor effective March 1, 2013 except for buildings impacted by Hurric Sandy. Approved applications will have the standard timeframyear from the program commitment date to complete the instal

Refrigerator/Freezer Case Premium Efficiency Motors (ECM)

Fractional (< 1 HP) Electronic Commutated Motors (ECM) (\$40 per for replacement of existing shaded-pole motor in refrigerated/freeze

Prescriptive Lighting

New Linear Fluorescent

T-12, HID and Incandescent to T-5 and T-8 (\$25 - \$200 pt fixture) (Note: T12 replacements are only available for buildings impacted by Hurricane Sandy)

New Induction (\$70 per replaced HID fixture)

New LED

Screw-in/Plug-in (\$10 - \$20 per lamp)

Refrigerator/Freezer Case (\$30 - \$65 per fixture)

Outdoor pole/arm/wall-mounted luminaires (\$100 - \$175 p fixture)

Display case (\$30 per case)

Shelf-mounted display and task (\$15 per linear foot)

Wall-wash, desk, recessed (\$20 - \$35 per fixture)

Parking garage luminaires (\$100 per fixture)

Track or Mono-Point directional (\$50 per fixture)

Stairwell and Passageway luminaires (\$40 per fixture)

High-Bay, Low-Bay (\$150 per fixture)

Bollard (\$50 per fixture)

luminaires for Ambient Lighting of Interior Commercial Spa

Linear panels (\$50 per fixture)

Fuel pump canopy (\$100 per fixture)

LED retrofit kits (custom measures)

New Pulse-Start Metal Hallide (\$25 per fixture)

Linear Fluorescent Retrofit (\$10 - \$20 per fixture)

Induction Retrofit (\$50 per retrofitted HID fixture)

New Construction/Complete Renovation (performance-based)

Note: Incentives for T-12 to T-5 and T-8 lamps with electronic ballast in facilities (\$10 per fixture, 1-4 lamps) and T-5/T-8 high bay fixtures (\$16 per fixture) were discontinued effective March 1, 2013 for T-12 retrofits replacements except for buildings impacted by Hurricane Sandy, Appro applications will have the standard timeframe of one year from the proc commitment date to complete the installation

Lighting Controls

Occupancy Sensors

Wall mounted (\$20 per control)

Remote mounted (\$35 per control)

Daylight dimmers (\$25 per fixture controlled, \$50 per fixture office applications only)

Occupancy controlled hi-low fluorescent controls (\$25 per controlled)

HID or Fluorescent Hi-Bay Controls

Occupancy hi-low (\$35 per fixture controlled)

Daylight dimming (\$45 per fixture controlled)

Refrigeration

Covers and Doors

Energy-Efficient doors for open refrigerated doors/covers

Aluminum Night Curtains for open refrigerated cases (\$3.5 linear foot)

Controls

Door Heater Control (\$50 per control)

Electric Defrost Control (\$50 per control)

Evaporator Fan Control (\$75 per control)

Novelty Cooler Shutoff (\$50 per control)

Food Service Equipment

Cooking

Combination Electric Oven/Steamer (\$1,000 per oven)

Combination Gas Oven/Steamer (\$750 per oven)

Electric Convection Oven (\$350 per oven)

Gas Convection Oven (\$500 per oven)

Gas Rack Oven (\$1,000 single, \$2,000 double)

Gas Conveyor Oven (\$500 small deck, \$750 large deck)

Electric Fryer (\$200 per vat)

Gas Fryer (\$749 per vat)

Electric Large Vat Fryer (\$200 per vat)

Gas Large Vat Fryer (\$500 per vat)

Electric Griddle (\$300 per griddle)

Gas Griddle (\$125 per griddle)

Electric Steam Cooker (\$1,250 per steamer)

Gas Steam Cooker (\$2,000 per steamer)

Holding

Full Size Insulated Cabinets (\$300 per cabinet)

Three Quarter Size Insulated Cabinets (\$250 per cabinet)

Half Size Insulated Cabinets (\$200 per cabinet)

Cooling

Glass Door Refrigerators (\$75 - \$150 per unit)

Solid Door Refrigerators (\$50 - \$200 per unit)

Glass Door Freezers (\$200 - \$1,000 per unit)

Solid Door Freezers (\$100 - \$600 per unit)

Ice Machines (\$50 - \$500 per unit)

Cleaning

Dishwashers (\$400 - \$1,500 per unit)

Other Equipment Incentives*

Performance Lighting (\$1.00 per watt per square foot below prograi incentive threshold, currently 5% more energy efficient than ASHRA 2007 for New Construction only.)

Custom electric and gas equipment incentives (not prescriptive)

*Equipment incentives are calculated based on type, efficiency, size, and apand are evaluated on a case-by-case basis. Contact us for details.

Home | Residential | Commercial & Industrial | Renewable Energy About Us | Press Room | Library | FAQs | Calendar | Newsletters | Contact Us | Site

II. DIRECT INSTALL



At Home, for Business, and for the Future

About Us | Press Room | Library

HOME

RESIDENTIAL

COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT





Home » Commercial & Industrial » Programs

Direct Install



HURRICANE SANDY

PROGRAMS

NJ SMARTSTART BUILDINGS

PAY FOR PERFORMANCE

COMBINED HEAT & POWER AND FUEL CELLS

LOCAL GOVERNMENT ENERGY AUDIT

LARGE ENERGY USERS PROGRAM

ENERGY SAVINGS IMPROVEMENT PROGRAM

DIRECT INSTALL

PARTICIPATION STEPS

PARTICIPATING CONTRACTORS

SUSTAINABLE JERSEY

ENERGY BENCHMARKING

OIL, PROPANE & MUNICIPAL ELECTRIC CUSTOMERS

EDA PROGRAMS

SBC CREDIT PROGRAM



Let us pay up to 70% of your energy efficiency upgrade.

Sometimes, the biggest challenge to improving energy efficiency is knowing where to and how to get through the process. Created specifically for existing small to medium facilities, Direct Install is a turnkey solution that makes it easy and affordable to upgrahigh efficiency equipment. Direct Install is designed to cut your facility's energy costs replacing lighting, HVAC and other outdated operational equipment with energy efficient alternatives. The program pays up to 70% of retrofit costs, dramatically improving yo payback on the project. There is a \$125,000 incentive cap on each project.

ELIGIBILITY



Existing small to mid-sized commercial and industrial fawith a peak electric demand that did not exceed 200 k any of the preceding 12 months are eligible to participa Direct Install. Applicants will submit the last 12 months electric utility bills indicating that they are below the deithreshold and have occupied the building during that till Buildings must be located in New Jersey and served by the state's public, regulated electric or natural gas utility companies.

SYSTEMS & EQUIPMENT ADDRESSED BY THE PROGRAM

Lighting
Heating, Cooling & Ventilation (HVAC)
Refrigeration

Motors

Natural Gas

Variable Frequency Drives



Measures eligible for Direct Install are limited to specific equipment categories, types capacities. Boilers may not exceed 500,000 Btuh and furnaces may not exceed 140,

III. PAY FOR PERFORMANCE (P4P)



At Home, for Business, and for the Future

About Us | Press Room | Library

HOME

RESIDENTIAL





Home » Commercial & Industrial » Programs » Pay for Performance

Pay for Performance - Existing Buildings

Download program applications and incentive forms.

The Greater the Savings, the Greater Your Incentives

Take a comprehensive, whole-building approach to saving energy in your existing facilities earn incentives that are directly linked to your savings. Pay for Performance relies on a

COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

HURRICANE SANDY

PROGRAMS

NJ SMARTSTART BUILDINGS

PAY FOR PERFORMANCE

EXISTING BUILDINGS

PARTICIPATION STEPS

APPLICATIONS AND FORMS

APPROVED PARTNERS

NEW CONSTRUCTION

FAQS

BECOME A PARTNER

COMBINED HEAT & POWER AND FUEL CELLS

LOCAL GOVERNMENT ENERGY **AUDIT**

LARGE ENERGY USERS PROGRAM

ENERGY SAVINGS IMPROVEMENT PROGRAM

DIRECT INSTALL

ENERGY BENCHMARKING



program partners who provide technical services under direct you. Acting as your energy expert, your partner will develop ε reduction plan for each project with a whole-building technica component of a traditional energy audit, a financial plan for fu energy efficient measures and a construction schedule for ins

Eligibility

Existing commercial, industrial and institutional buildings with demand over 100 kW for any of the preceding twelve months to participate including hotels and casinos, large office buildir family buildings, supermarkets, manufacturing facilities, schoshopping malls and restaurants. Buildings that fall into the fol customer classes are not required to meet the 100 kW demai

to participate in the program: hospitals, public colleges and universities, 501(c)(3) non-p affordable multifamily housing, and local governmental entities. Your energy reduction p define a comprehensive package of measures capable of reducing the existing energy consumption of your building by 15% or more.

Exceptions to the 15% threshold requirement may be made for certain industrial, manufwater treatment and datacenter building types whose annual energy consumption is her weighted on process loads. Details are available in the high energy intensity section of t

ENERGY STAR Portfolio Manager

Pay for Performance takes advantage of the ENERGY STAR Program with Portfolio Manager, EPA's interactive tool that allows facility managers to track and evaluate energy and water consumption across all of their buildings. The tool provides the opportunity to load in the characteristics and energy usage of your buildings and determine an energy performance benchmark score. You can then assess energy management goals over time, identify strategic opportunities for savings, and receive EPA recognition for superior energy performance



This rating system assesses building performance by tracking and scoring energy use in facilities and comparing it to similar buildings. That can be a big help in locating opportui cost-justified energy efficiency upgrades. And, based on our findings, you may be invited participate in the Building Performance with ENERGY STAR initiative and receive specirecognition as an industry leader in energy efficiency.

Incentives

OIL, PROPANE & MUNICIPAL ELECTRIC CUSTOMERS

EDA PROGRAMS

SBC CREDIT PROGRAM

PAST PROGRAMS

TOOLS AND RESOURCES

PROGRAM UPDATES

CONTACT US

Pay for Performance incentives are awarded upon the satisfactory completion of three p milestones:

Incentive #1 - Submittal of complete energy reduction plan prepared by an app program partner - Contingent on moving forward, incentives will be between \$5 \$50,000 based on approximately \$.10 per square foot, not to exceed 50% of the annual energy expense.

Incentive #2 - Installation of recommended measures - Incentives are based on the projected level of electricity and natural gas savings resulting from the installation of comprehensive energy-efficiency measures.

Incentive #3 - Completion of Post-Construction Benchmarking Report - A completed report verifying energy reductions based on one year of post-

implementation results. Incentives for electricity and natural gas savings will be based on actual savings, provided that the minimum performance threshold of savings has been achieved.

A detailed Incentive Structure document is available on the applications and form

Steps to Participation

Click here for a step-by-step description of the program.

Home | Residential | Commercial & Industrial | Renewable Energy
About Us | Press Room | Library | FAQs | Calendar | Newsletters | Contact Us | Site





PAY FOR PERFORMANCE APPLICATION FORM

July 1, 2013 - June 30, 2014

Utility Serving Applicant: New Jersey Natural Gas Other Electric Service Pro Other Fuel Provider:	□ Elizabe wider (please			Central Power & and Electric Co.		□ PSE&G □ South Jersey Gas
Instructions					ARIIIIA AAY AA A	
1. Read the program material to determ 2. Read the Participation Agreement at 3. Fill out all applicable spaces on this 4. Provide a copy of the customer's cor 5. Provide the most recent consecutive for the project.	nd sign where is form. mpany W-9 forn	ndicated. n.	7. Partner mu DIRECTL' Approval of th Scope of work		ation package vio nager – see back an approval of t on approval of th	of this form. he project's scope of work. he Energy Reduction Plan.
Customer/Owner In	formati	iON (paymeı	nt will be n	Project Contact/Title	entered h	ere)
Company Address			City	A TOTAL CONTRACTOR CON	State	Zip
Phone/Fax	E-mail			Federal ID	/SSN	
Partner Information Company Name	n ·			Project Contact/Tit	le	
Company Address			City		State	Zip
Phone	Fax		E-mail			A PORT LA PORT LA CONTRACTOR DE LA CONTR
Project Information Project Name	1					
Building Address			City		State	Zip
Utility Account Number(s): Electric	}			Gas		
° Note: Please use the back of this page for additional Annual Peak kW Demand		ntity exceeds space allotme ding Type	ent.		Number of t	Buildings
Size of Building(s) (gross sq/ft)			Direct, A	Naster or Sub Metered		,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,
Funding Check the box if an Energy Savin	gs Improveme	nt Program (ESII	P) will be a sou	rce of funding. ES	IP allows gove	rnment
agencies to pay for energy related	improvements	using the value o	f the resulting e	energy savings.		
Do you expect to receive funding	-		•			•
Utility Program #1 – Utility: Utility Program #2 – Utility:				gram Name: gram Name:		
Federal Program #1 – Organizati				gram Name:		
Federal Program #2 – Organizati	ion:			gram Name:		
Other Program - Organization: _				gram Name:		

Additional Project inf	ormation
Additional Utility Account(s)	
Additional Other Account(s)	
Account type	Account number
dditional Comments:	

Complete this application form and send it directly to the Commercial/Industrial Market Manager by e-mail, mail or fax.

New Jersey's Clean Energy Program c/o TRC Energy Services-P4P 900 Route 9 North, Suite 404 • Woodbridge, NJ 07095

> Phone: 866-657-6278 • Fax: 732-855-0422 E-mail: P4P@NJCleanEnergy.com

0

Pay For Performance-Existing Buildings

Participation Agreement

Definitions:

Design Incentives – Incentives that may be offered to design professionals by the Program.

Design Services – Services that may be offered to design professionals under the Program.

Energy-Efficient Measures – Any device eligible to receive a Program Incentive payment through the NJ Clean Energy Commercial and Industrial Program (New Jersey SmartStart Buildings).

New Jersey Utilities – The regulated electric and/or gas utilities in the State of New Jersey. They are: Atlantic City Electric, Jersey Central Power & Light, Rockland Electric Company, New Jersey Natural Gas, Elizabethtown Gas, PSE&G, and South Jersey Gas.

Administrator – New Jersey Board of Public Utilities, Office of Clean Energy

Participating Customers – Those non-residential electric and/or gas service customers of the New Jersey Utilities who participate in this Program.

Product Installation or Equipment Installation – Installation of the Energy-Efficient Measures.

Projects with a contract threshold of \$14,187 (increasing to \$15,444 effective July 1, 2014) are required to pay no less than prevailing wage rate to workers employed in the performance of any construction undertaken in connection with Board of Public Utilities financial assistance, or undertaken to fulfill any condition of receiving Board of Public Utilities financial assistance, including the performance of any contract to construct, renovate or otherwise prepare a facility, the operations of which are necessary for the receipt of Board of Public Utilities financial assistance. By submitting an application, or accepting program incentives, applicant agrees to adhere to New Jersey Prevailing Wage requirements, as applicable.

Program – The Commercial and Industrial Energy-Efficient Construction Program (New Jersey SmartStart Buildings) offered herein by the New Jersey Board of Public Utilities, Office of Clean Energy pursuant to state regulatory approval under the New Jersey Electric Discount and Energy Competition Act, NJSA 48:3-49, et seq.

Program Incentives – Refers to the amount or level of incentive that the Program provides to Participating Customers pursuant to the Program offered herein (see description under "Incentive Amount" heading).

Program Offer – Program Incentives are available to nonresidential retail electric and/or gas service customers of the New Jersey Utilities identified above.

Program Manager - TRC Energy Services.

Application and Eligibility Process - The Program pays incentives after the installation of qualified energy-efficient

measures that were pre-approved (for exceptions to this condition, please refer to "Exceptions for Approval".) In order to be eligible for Program Incentives, a Customer, or an agent (contractor/vendor) authorized by a Customer, must submit a properly completed application package. The package must include an application signed by the customer; a complete (current) utility bill; and technology worksheet and manufacturer's cut sheets (where appropriate). This information must be submitted to the Program Manager before equipment is installed. Applications for measures that are self installed by customers must be submitted by the customer and not the sales vendor of the measure, however, the customer may elect to assign payment of the incentive to the sales vendor. This application package must be received by the Program Manager on or before June 30, 2014 in order to be eligible for the fiscal year July 1, 2013-June 30, 2014 incentives. The Program Manager will review the application package to determine if the project is eligible for a Program Incentive. If eligible, the Customer will receive an approval letter with the estimated authorized incentive amount and the date by which the equipment must be installed in order for the approval to remain in effect. Upon receipt of an approval letter, the Customer may then proceed to install the equipment listed on the approved application. Equipment installed prior to the date of the Program Manager's approval letter is not eligible for an incentive. The Program Manager reserves the right to conduct a pre-inspection of the facility prior to the installation of equipment. This will be done prior to the issuance of the approval letter. All equipment must be purchased within 12 months of date of application. Any Customer and/ or agent who purchases equipment prior to the receipt of an incentive approval letter does so at his/her own risk.

Exceptions for Approval – The Application and Eligibility Process pertains to all projects except for those involving either Gas Heating, Unitary HVAC or Motors having an incentive amount less than \$5,000 that were installed within 12 months of receipt of the application. These measures, at this incentive level, may be installed without prior approval. In addition, but at the sole discretion of the Program Manager, emergency replacement of equipment may not require a prior approval determination and letter. In such cases, please notify the Program Manager of such emergencies as early as possible, that an application will soon be sent in that was not pre-approved.

Post-Installation Approval — After installation is completed, the Customer, or an agent authorized by the Customer, must finalize and submit an invoice for the purchase of the equipment (material cost must be broken out from labor costs), and any other required documentation as specified on the equipment application or in the Program Manager's initial approval letter.

Please refer to the program guide on the NJCleanEnergy.com/ ssb website for the complete Application and Eligibility Process.

The Program Manager reserves the right to verify sales transactions and to have reasonable access to Participating Customer's facility to inspect both pre-existing product or equipment (if applicable) and the Energy-Efficient Measures installed under this Program, either prior to issuing incentives or at a later time.

Energy-Efficient Measures must be installed in buildings located within a New Jersey Utilities' service territory and designated on the Participating Customer's incentive application. Program Incentives are available for qualified Energy-Efficient Measures as listed and described in the Program materials and incentive applications. The Participating Customer must ultimately own the equipment, either through an up-front purchase or at the end of a short-term lease. Design Incentives are available to design professionals as described in the Program materials and applications. A different and separate agreement must be executed by participating design professionals to be eligible for this type of incentive. The design professional does not need to be based in New Jersey.

Equipment procured by Participating Customers through another program offered by New Jersey's Clean Energy Program or the New Jersey Utilities, as applicable, is not eligible for incentives through this program. Customers who have not contributed to the Societal Benefits Charge of the applicable New Jersey Utility are not be eligible for incentives offered through this program.

Incentive Amount – Program Incentives will equal either: a) the approved Program Incentive amount, or b) the actual equipment cost of the Energy-Efficient Measure, whichever is less, as determined by the Program Manager. Products offered at no direct cost to the customer are ineligible. Incomplete application submissions, applications requiring inspections and unanticipated high volume of activities may cause processing delays. Program Incentives are limited to \$500,000 per utility account in a calendar year. Contact the Program Manager regarding any questions.

Tax Liability – The Program Manager will not be responsible for any tax liability that may be imposed on any Participating Customer as a result of the payment of Program Incentives. All Participating Customers must supply their federal tax identification number or social security number to the Program Manager on the application form in order to receive a Program Incentive. In addition, Participating Customers must also provide a Tax Clearance Form (entitled "Business Assistance or Incentive Clearance Certificate") that is dated within 90 days of equipment installation.

Endorsement – The Program Manager and Administrator do not endorse, support or recommend any particular manufacturer, product or system design in promoting this Program.

Warranties – THE PROGRAM MANAGER AND ADMINISTRATOR DO NOT WARRANT THE PERFORMANCE OF INSTALLED EQUIPMENT, AND/OR SERVICES RENDERED AS PART OF THIS PROGRAM, EITHER EXPRESSLY OR IMPLICITLY. NO WARRANTIES OR REPRESENTATIONS OF ANY KIND, WHETHER STATUTORY, EXPRESSED, OR IMPLIED, INCLUDING, WITHOUT LIMITATIONS, WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE REGARDING EQUIPMENT OR SERVICES PROVIDED BY A MANUFACTURER OR VENDOR. CONTACT YOUR VENDOR/SERVICES PROVIDER FOR DETAILS REGARDING PERFORMANCE AND WARRANTIES.

Limitation of Liability – By virtue of participating in this Program, Participating Customers agree to waive any and all claims or damages against the Program Manager or the Administrator, except the receipt of the Program Incentive. Participating Customers agree that the Program Manager's and Administrator's liability, in connection with this Program, is limited to paying the Program Incentive specified. Under no circumstances shall the Program Manager, its representatives, or subcontractors, or the Administrator, be liable for any lost profits, special, punitive, consequential or incidental damages or for any other damages or claims connected with or resulting from participation in this Program. Further, any liability attributed to the Program Manager under this Program shall be individual, and not joint and/or several.

Assignment – The Participating Customer may assign Program Incentive payments to a specified vendor.

Participating Customer's Certification – Participating Customer certifies that he/she purchased and installed the equipment listed in their application at their defined New Jersey location. Participating Customer agrees that all information is true and that he/she has conformed to all of the Program and equipment requirements listed in the application.

Termination – The New Jersey Board of Public Utilities reserves the right to extend, modify (this includes modification of Program Incentive levels) or terminate this Program without prior or further notice.

Acknowledgement – I have read, understood and am in compliance with all rules and regulations concerning this incentive program. I certify that all information provided is correct to the best of my knowledge, and I give the Program Manager permission to share my records with the New Jersey Board of Public Utilities, and contractors it selects to manage, coordinate or evaluate the NJ SmartStart Buildings Program. Additionally, I allow reasonable access to my property to inspect the installation and performance of the technologies and installations that are eligible for incentives under the guidelines of New Jersey's Clean Energy Program.

CUSTOMER'S SIGNATURE

PARTNER SIGNATURE

By signing, I certify that I have read, understand and agree to the Participation Agreement listed above.

IV. ENERGY SAVINGS IMPROVEMENT PLAN (ESIP)



At Home, for Business, and for the Future

About Us | Press Room | Library

HOME

RESIDENTIAL

COMMERCIAL, INDUSTRIAL RND L€CAL GOVERNMENT





COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

HURRICANE SANDY

PROGRAMS

NJ SMARTSTART BUILDINGS

PAY FOR PERFORMANCE

COMBINED HEAT & POWER AND FUEL CELLS

LOCAL GOVERNMENT ENERGY AUDIT

LARGE ENERGY USERS PROGRAM

ENERGY SAVINGS IMPROVEMENT PROGRAM

DIRECT INSTALL

ENERGY BENCHMARKING

OIL, PROPANE & MUNICIPAL **ELECTRIC CUSTOMERS**

EDA PROGRAMS

SBC CREDIT PROGRAM

PAST PROGRAMS

TOOLS AND RESOURCES

PROGRAM UPDATES

CONTACT US

Home » Commercial & Industrial » Programs

Energy Savings Improvement Program

A new State law allows government agencies to make energy related improvements to t facilities and pay for the costs using the value of energy savings that result from the imp Under Chapter 4 of the Laws of 2009 (the law), the "Energy Savings Improvement Program" (ESIP), provides all government agencies in New Jersey with a flexible tool to and reduce energy usage with minimal expenditure of new financial resources.

This Local Finance Notice outlines how local governments can develop and implement a their facilities. Below are two sample RFPs:

> Local Government School Districts (K-12)

All RFPs must be submitted to the Board for approval at ESIP@bpu.state.nj.us.

The Board also adopted protocols to measure energy savings:

Measuring Energy Savings Procedures for Implementation

The ESIP approach may not be appropriate for all energy conservation and energy effic improvements. Local units should carefully consider all alternatives to develop an approbest meets their needs. Local units considering an ESIP should carefully review the Loc Notice, the law, and consult with qualified professionals to determine how they should a task.

The NJ Board of Public Utilities sponsored Sustainable Jersey in the creation of an ESIF Guidebook that explains how to implement the program. The guidebook also includes ca of successful projects and a list of helpful resources.

FIRST STEP - ENERGY AUDIT

For local governments interested in pursuing an ESIP, the first step is to perform an ene as prescribed in P.L.2012 c.55.

ENERGY REDUCTION PLANS

If you have an ESIP plan that needs to be submitted to the Board of Public Utilities, plea to ESIP@bpu.state.nj.us. Please limit the file size to 3MB (or break it into smaller files).

Frankford Township School District


Northern Hunterdon-Voorhees Regional High School

Manalapan Township (180 MB - Right Click, Save As)

BPU RULES

- 1. Public Entity must decide if they will use an ESCO or DIY method or Hybrid thereof prior to issuing the RFP and the RFP must state the intended method. A change in the project procurement model after the RFP closing date will be cause for immediate rejection and disqualification of potential Clean Energy program incentives.
- 2. RFP procedures shall be adhered to as per the legislation, including the use of BPU approved forms. Any alteration of the forms, without prior approval from the BPU shall be grounds for rejection.
- 3. RFP must include copy of an audit (ASHRAE Level II w/Level III for lighting) and audit must be prepared by a firm classified by DPMC in the 036 discipline.
- 4. All firms, including professional services, whether using ESCO or DIY model, must be DPMC classified.
- 5. If an Architect is engaged by the public entity, the architectural fees are the responsibility of the public entity and must be paid directly to the firm. These fees may be included in the energy cost savings analysis and payback.
 - ESCO's may contract directly with an architectural firm, in which case the architectural firm serves as a subcontractor to the ESCO and the project related service costs may be included within the project's economic model.
- 6. Public entity shall conduct pre-bid meetings and site visits per existing statutes.
 - In the interest of open public bidding transparency, it is a requirement of the BPU that all proposers must attend the pre-proposal bid meeting.
- 7. There shall be no negative cash flow in any year of the program. section 7 (1)(a)
 - "the energy savings resulting from the program will be sufficient to cover the cost of the program's energy conservation measures."
- 8. SREC values are not permitted to be used in the energy cost savings calculations.
- 9. Capital cost avoidance values are not to be used in the energy savings calculations.
- 10. Operational and Maintenance (O&M) cost savings may be permitted in the cost savings calculations, but only with supporting documentation.
- 11. Blended utility rates shall not be permitted. Use the actual utility tariff or local contracted rates if there is a third party supplier.
 - For the RFP proposals, the public entity shall define the utility rates in the RFP

- 12. Contracted third party utility rates may only be used for the term of the contract (5 yr. maximum) Subsequent years are to be projected at the utility tariff rates plus the annual BPU escalation rates.
- 13. Public entity shall conduct M&V (measurement and verification) at the one (1) year operational date and shall provide a copy of the M&V report to the Board of Public Utilities.
 - For the RFP proposals, the ESCO shall provide the cost for the one (1) year M&V only. For comparative purposes, the one year M&V pricing shall be indicated on the proposal Form VI, under the "Annual Service Costs" column. Additional M&V costs are at the discretion of the local unit and are not to be included in the proposal.
- 14. The decisions made by BPU staff regarding compliance or other issues that arise in connection with the RFP procurement process shall be considered a final decision of the BPU. Any appeal will need to be through the New Jersey Superior Court, Appellate Division.
- 15. For the RFP proposals only, Demand Response (DR) revenues claimed by ESCO's can only be projected for a maximum period of three (3) years. DR revenue projections beyond three years will not be permitted. DR revenues must be included and presented under the "Energy Rebates/Incentives" column of FORM VI.
- 16. ESCO "fees" proposed during the RFP phase of the project cannot increase post-award. ESCO's are required to maintain the fee percentages through final contract negotiations and construction of the Board approved Energy Savings Plan
- 17. Public Bid openings shall be held on the due date of the proposal submissions. The public entity shall announce the name of the bidder and the total dollar amount. After award of a contract, all proposals received will be made available by the owner for public inspection
- 18. Rejection of bids by the public entity shall be conducted in accordance with the appropriate sections of the applicable legislation, as stated in Title 40A:11-13.2. Additionally all proposals must be returned to the respective ESCO's upon rejection.
- 19. Field changes that exceed 5% of the project cost require BPU approval.
- 20. Energy Savings Plans (ESP) that is dependent upon incentives from the Clean Energy Program must review the current program requirements, at the time of application, for each incentive to insure eligibility. If any program incentive is denied, resubmission of all ESIP related forms will be necessary to remain ESIP qualified.



Newark Public Schools Sussex Avenue

Cost of Electricity	\$0.15	/kWh
Electricity Usage	651,678	kWh/yr
System Unit Cost	\$4,000	/kW

Photovoltaic (PV) Solar Power Generation - Screening Assessment

Budgetary		Annual Utility S	Savings		Estimated	Total	Federal Tax	New Jersey Renewable	Payback (without	Payback (with
Cost					Maintenance	Savings	Credit	** SREC	incentive)	incentive)
					Savings					
\$	kW	kWh	therms	\$	\$	\$	\$	\$	Years	Years
\$720,000	180.0	234,600	0	\$35,098	0	\$35,098	\$0	\$36,363	20.5	10.1

^{**} Estimated Solar Renewable Energy Certificate Program (SREC) SREC for 15 Years= /1000kwh \$155

Area Output*

2,545 m2 27,396 ft2

Perimeter Output*

528 m

Available Roof Space for PV:

(Area Output - 10 ft x Perimeter) x 85% 23,286 ft2

Approximate System Size:

Is the roof flat? (Yes/No) Yes

watt/ft2 186,290 DC watts

kW 180 Enter into PV Watts

PV Watts Inputs***

Enter into PV Watts (always 20 if flat, if Array Tilt Angle pitched - enter estimated roof angle) 20 Array Azimuth Enter into PV Watts (default) 180 Zip Code Enter into PV Watts 07112 DC/AC Derate Factor Enter info PV Watts 0.83

PV Watts Output

234,600 annual kWh calculated in PV Watts program

% Offset Calc

651,678 (from utilities) Usage PV Generation 234,600 (generated using PV Watts)

36%

% offset

http://www.freemaptools.com/area-calculator.htm

http://www.flettexchange.com

http://gisatnrel.nrel.gov/PVWatts_Viewer/index.html





AC Energy & Cost Savings



Station Identification								
Cell ID:	0268370							
State:	New Jersey							
Latitude:	40.9 ° N							
Longitude:	74.2 ° W							
PV System Specification	S							
DC Rating:	180.0 kW							
DC to AC Derate Factor:	0.830							
AC Rating:	149.4 kW							
Array Type:	Fixed Tilt							
Array Tilt:	20.0 °							
Array Azimuth:	180.0 °							
Energy Specifications								
Cost of Electricity:	15.0 ¢/kWh							

	J	Results	
Month	Solar Radiation (kWh/m²/day)	AC Energy (kWh)	Energy Value (\$)
1	2.65	12575	1886.25
2	3.47	14893	2233.95
3	4.83	22103	3315.45
4	5.28	22655	3398.25
5	5.93	25848	3877.20
6	6.32	25954	3893.10
7	5.87	24430	3664.50
8	5.55	23257	3488.55
9	5.04	20817	3122.55
10	4.14	18306	2745.90
11	2.82	12294	1844.10
12	2.46	11468	1720.20
Year	4.54	234600	35190.00

(Gridded data is monthly, hourly output not available.)

Saving Text from a Browser

Run PVWATTS v.2 for another location

Run PVWATTS v.1

Please send questions and comments to Webmaster Disclaimer and copyright notice.



RReDC home page (http://rredc.nrel.gov)



1: Typical Door in need of new door sweeps and seals



2: Typical window a/c which is used for cooling




3: Existing Burner for Steam Boiler



4: Existing Airedale Packaged HVAC Unit for kindergarten classrooms



5: Existing Fixture with T-8 Lamps





ENERGY STAR[®] Statement of Energy Performance

31

Sussex Avenue Elementary

Primary Property Function: K-12 School

Gross Floor Area (ft²): 66,500

Built: 1900

ENERGY STAR® Score¹ For Year Ending: September 30, 2009 Date Generated: April 21, 2014

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property ID: 3877107

Energy Consur	mption and Energy U	Ise Intensity (EUI)		
Site EUI	Annual Energy by Fu	iel	National Median Comparison	
66.6 kBtu/ft²	Electric - Grid (kBtu)	1,966,404 (44%)	National Median Site EUI (kBtu/ft²)	56.5
00.0 KDIU/II-	Natural Gas (kBtu)	2,461,532 (56%)	National Median Source EUI (kBtu/ft²)	111.8
	, ,	,	% Diff from National Median Source EUI	18%
Source EUI			Annual Emissions	
131.7 kBtu/ft²	2		Greenhouse Gas Emissions (MtCO2e/year)	380

Signature & Stamp of Verifying Professional

I (Name) ve	rify that the above informa	ation is true and correct to th	e best of my knowledge.
Signature:	Date:	_	
Licensed Professional			
Gregory Coleman 10 Maxwell Drive Suite 200 Clifton Park, NY 12065 000-000-0000 mvadney@trcsolutions.com			

Professional Engineer Stamp (if applicable)

webmaster@nps.k12.nj.us