

THE NEWARK PUBLIC SCHOOLS

Group 2 Buildings

**BARD EARLY COLLEGE, NEWARK BRIDGES, PEOPLES PREP CHARTER
321 Bergen St, Newark, NJ 07103**

**LOCAL GOVERNMENT ENERGY AUDIT PROGRAM
FOR
NEW JERSEY
BOARD OF PUBLIC UTILITIES**

May 2014

Prepared by:



6 Campus Drive
Parsippany, NJ 07054
(973) 538-2120

CHA PROJECT NO. 27998

TABLE OF CONTENTS

1.0 EXECUTIVE SUMMARY	1
2.0 BUILDING INFORMATION AND EXISTING CONDITIONS	4
3.0 UTILITIES	8
4.0 BENCHMARKING.....	11
5.0 ENERGY CONSERVATION MEASURES.....	12
5.1 ECM-1 Replace Hot Water Boilers with Condensing Hot Water Boilers.....	13
5.2 ECM-2 Install Premium Efficiency Motors	13
5.3 ECM-3 Install Window A/C Controller.....	14
5.4 ECM-4 Install Full DDC Controls	14
5.5 ECM-5 Domestic Hot Water System Improvements.....	15
5.6 ECM-6 Install Vending Misers	15
5.7 ECM-7 Install Low Flow Plumbing Fixtures	16
5.8.1 ECM-L1 Lighting Replacement / Upgrades	16
5.8.2 ECM-L2 Install Lighting Controls (Occupancy Sensors)	17
5.8.3 ECM-L3 Lighting Replacements with Controls (Occupancy Sensors)	18
5.9 Additional O&M Opportunities.....	18
6.0 PROJECT INCENTIVES	19
6.1 Incentives Overview	19
6.1.1 New Jersey Smart Start Program.....	19
6.1.2 Direct Install Program	19
6.1.3 New Jersey Pay For Performance Program (P4P).....	20
6.1.4 Energy Savings Improvement Plan	21
6.1.5 Renewable Energy Incentive Program.....	22
7.0 ALTERNATIVE ENERGY SCREENING EVALUATION	23
7.1 Solar	23
7.1.1 Photovoltaic Rooftop Solar Power Generation	23
7.1.2 Solar Thermal Hot Water Generation.....	23
7.2 Wind Powered Turbines	23
7.3 Combined Heat and Power Plant.....	24

7.4	Demand Response Curtailment	25
8.0	CONCLUSIONS & RECOMMENDATIONS.....	26

APPENDICES

A	Utility Usage Analysis and List of Third Party Energy Suppliers
B	Equipment Inventory
C	ECM Calculations and Cost Estimates
D	New Jersey BPU Incentive Programs
	i. Smart Start
	ii. Direct Install
	iii. Pay For Performance Incentive Program (P4P)
	iv. Energy Savings Improvement Plan (ESIP)
E	Photovoltaic (PV) Solar Power Generation Analysis
F	Photos
G	EPA Portfolio Manager

REPORT DISCLAIMER

This audit was conducted in accordance with the standards developed by the American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) for a Level II audit. Cost and savings calculations for a given measure were estimated to within $\pm 20\%$, and are based on data obtained from the owner, data obtained during site observations, professional experience, historical data, and standard engineering practice. Cost data does not include soft costs such as engineering fees, legal fees, project management fees, financing, etc.

A thorough walkthrough of the building was performed, which included gathering nameplate information and operating parameters for all accessible equipment and lighting systems. Unless otherwise stated, model, efficiency, and capacity information included in this report were collected directly from equipment nameplates and /or from documentation provided by the owner during the site visit. Typical operation and scheduling information was obtained from interviewing staff and spot measurements taken in the field.

List of Common Energy Audit Abbreviations

- A/C – Air Conditioning
- AHS – Air Handling Unit
- BMS – Building Management System
- Btu – British thermal unit
- CDW – Condenser Water
- CFM – Cubic feet per minute
- CHW – Chilled Water
- DCV – Demand Control Ventilation
- DDC – Direct Digital Control
- DHW – Domestic Hot Water
- DX – Direct Expansion
- EER – Energy Efficiency Ratio
- EF – Exhaust Fan
- EUI – Energy Use Intensity
- Gal – Gallon
- GPD – Gallons per day
- GPF – Gallons Per Flush
- GPH – Gallons per hour
- GPM – Gallons per minute
- GPS – Gallons per second
- HHW – Heating Hot Water
- HID – High Intensity Discharge
- HP – Horsepower
- HRU – Heat Recovery Unit
- HVAC – Heating, Ventilation, Air Conditioning
- HX – Heat Exchanger
- kbtu/mbtu – One thousand (1,000) Btu
- kW – Kilowatt (1,000 watts)
- kWh – Kilowatt-hours
- LED – Light Emitting Diode
- mbh – Thousand Btu per hour
- mmbtu – One million (1,000,000) Btu
- OCC – Occupancy Sensor
- PSI – Pounds per square inch
- RTU – Rooftop Unit
- SBC – System Benefits Charge
- SF – Square foot
- UH – Unit Heater
- V – Volts
- VAV – Variable Air Volume
- VSD – Variable Speed Drive
- W – Watt

1.0 EXECUTIVE SUMMARY

This report summarizes the energy audit performed by CHA for Newark Public Schools (NPS), in connection with the New Jersey Board of Public Utilities (NJBPU) Local Government Energy Audit (LGEA) Program. The purpose of this report is to identify energy savings opportunities associated with major energy consumers and inefficient practices. Low-cost and no-cost are also identified during the study. This report details the results of the energy audit conducted for the building listed below:

Building Name	Address	Square Feet	Construction Date
Bard Early College, Newark Bridges, Peoples Prep Charter	321 Bergen St Newark NJ 07103	153,163	1973

The annual energy and cost savings for the recommended energy conservation measures (ECM) identified in the survey are shown below:

Building Name	Electric Savings (kWh)	NG Savings (therms)	Total Savings (\$)	Payback (years)
Bard Early College, Newark Bridges, Peoples Prep Charter	272,949	23,559	61,010	15.8

Each individual measure's annual savings are dependent on that measure alone, there are no interactive effects calculated. There are three options shown for Lighting ECM savings; only one option can be chosen. Incentives shown (if any) are based only on the SmartStart Incentive Program. Other NJBPU or local utility incentives may also be available/ applicable and are discussed in Section 6.0.

Each measure recommended by CHA typically has a stand-alone simple payback period of 15 years or less. However, if the owner chooses to pursue an Energy Savings Improvement Plan (ESIP), high payback measures could be bundled with lower payback measures which ultimately can result in a payback which is favorable for an ESIP project to proceed. Occasionally, we will recommend an ECM that has a longer payback period, based on the need to replace that piece(s) of equipment due to its age, such as a boiler for example.

The following table provides a detailed summary of each ECM for the building surveyed, including costs, savings, SmartStart incentives and payback.

Summary of Energy Conservation Measures

ECM #	Energy Conservation Measure	Est. Costs (\$)	Est. Savings (\$/year)	Payback w/o Incentive	Potential Incentive (\$)*	Payback w/ Incentive	Recommended
1	Replace Hot Water Boilers w/ Condensing Hot Water Boilers	220,697	3,573	61.8	0	61.8	Y
2	Install Premium Efficiency Motors	4,811	185	25.9	0	25.9	Y
3	Install Window AC Controllers	8,900	5,146	1.7	0	1.7	Y
4	Install DDC Controls	392,179	16,906	23.2	0	23.2	Y
5	Domestic Hot Water System Improvements	35,796	1,431	25.0	0	25.0	Y
6	Install Vending Machine Controls	840	1,231	0.7	0	0.7	Y
7	Install Low Flow Plumbing Fixtures	273,566	2,919	93.7	0	93.7	N
L1**	Lighting Replacements / Upgrades	268,898	29,057	9.3	2,600	9.2	N
L2**	Install Lighting Controls (Add Occupancy Sensors)	30,240	8,116	3.7	3,920	3.2	N
L3	Lighting Replacements with Controls (Occupancy Sensors)	299,138	32,539	9.2	6,520	9.0	Y
Total**		1,235,926	63,931	19.3	6,520	19.2	
Total (Recommended)		962,360	61,012	15.8	6,520	15.7	


* Incentive shown is per the New Jersey SmartStart Program.

** These ECMs are not included in the Total, as they are alternate measures not recommended.

There are no alternative ECMs recommended for further study.

If NPS implements the recommended ECMs, energy savings would be as follows:

	Existing Conditions	Post Recommended ECMs	Percent Savings
Costs (\$)	241,917	180,905	25%
Electricity (kWh)	1,114,500	841,551	24%
Natural Gas (therms)	94,362	70,803	25%
Site EUI (kbtu/SF/Yr)	86.4	65.0	



2.0 BUILDING INFORMATION AND EXISTING CONDITIONS

The following is a summary of building information related to HVAC, plumbing, building envelope, lighting, kitchen equipment and domestic hot water systems as observed during CHAs site visit. See Appendix B for detailed information on mechanical equipment, including capacities, model numbers and age. See Appendix F for some representative photos of some of the existing conditions observed while onsite.

Building Name: Bard Early College, Newark Bridges, Peoples Prep Charter (Index No. 32)

Address: 321 Bergen St, Newark, NJ 07103

Gross Floor Area: 153,163 Square Feet

Number of Floors: 4

Year Built: 1973

Additions: N/A



Description of Spaces: Classrooms, offices, cafeteria with a stage, kitchen, gymnasium, wood shop, metal shop, library, computer lab, science lab, storage rooms, toilet rooms and a mechanical room.

Description of Occupancy: The school serves 349 students from 9th to 12th grade. There are 40 school faculty and staff members.

Number of Computers: The school has approximately 55 desktop and laptop computers.

Building Usage: Hours of operation are 8:00 AM – 3:00 PM Monday through Friday, with various after-school activities until 6:00 PM. Custodians are in the building until 11:00 each night. In general the occupied hours are considered 80 hours per week, 10 months per year

Construction Materials: The building is constructed of brick and concrete masonry units (CMU) with steel framing and no insulation. The interior walls are a mixture of CMU and plaster.

Façade: Brick and concrete

Roof: The roof is flat with about 3" of sprayed high density closed cell polyurethane spray foam coated with an enriched polyuria coating to prevent leaks and seal the roof.

Windows: The windows throughout the building are double pane, double hung aluminum framed windows. Windows are in good condition and no ECMs associated with window replacement were evaluated.

Exterior Doors: Exterior doors throughout the school are FRP with double pane safety glass. Sweeps and seals on exterior doors are in good condition.

Heating Ventilation & Air Conditioning (HVAC) Systems

Heating: The heating system consists of seven (7) Futera II natural gas fired, 85% efficient non-condensing hot water (HW) boilers with a maximum input capacity of 1,950 MBH each. The boilers were installed in 2007 and appear to be in good condition. In general the boilers are sequenced to share the building heating load. The target HW temperature is usually between 185-190F. Hot water is distributed throughout the building by two (2) 30 HP pumps which were both operating during the facility visit. End use equipment includes unit ventilators (UV) in classrooms with HW coils, HW radiators or perimeter fin tube radiators, as well as four (4) heating and ventilation (HV) units with HW coils. One of the HV units located in the boiler room adjacent to the HW pumps had a small fractional horsepower booster pump which was operating during the facility visit.

An ECM has been included to replace one Futera boiler with a higher efficiency condensing boiler. This boiler would operate as the primary boiler to maximize its efficiency.

An ECM has also been included which evaluates the savings associated with replacing the existing 92.4% efficient hot water pump motors with premium efficiency motors.

Cooling: This building has no central cooling system, however approximately 20% is cooled using various independent systems. There are roughly 46 window air conditioners as well as several portable "Move-and-Cool" type air conditioning units serving classrooms; additionally four (4) split system condensing units and one (1) packaged DX roof top unit (RTU) on the roof. Since there is no automated control, occasionally window ACs may be left on while the building is un-occupied. The split systems and packaged RTU are controlled by non-programmable thermostats. A window A/C controller ECM is included.

Ventilation: Each classroom in general has at least one (1) UV which provides a small amount of ventilation air for the room. The gymnasium and cafeteria are supplied with ventilation air by one McQuay HV unit accessible from the roof. There are two other HV units located in the boiler room that were not operating at the time of our site visit and the custodian was not sure what spaces were supplied by these units. There are no ECMs associated with the ventilation systems.

Exhaust: There are several small fractional horsepower exhaust fans located throughout the school which provide general exhaust, exhaust for restrooms and some specialty exhaust for science room fume hoods. There is one 4'x12' kitchen hood which has an estimated 1 HP fan (on the roof) which is manually controlled by a wall mounted switch. Kitchen staff indicated that the kitchen hood is used as needed to cool off the kitchen. Normally a kitchen hood controller would be recommended, however since the kitchen is used for reheating food only, it is assumed that the exhaust fan is minimally used and therefore savings would be small. No ECMs are considered for the exhaust systems.

Controls Systems

The boilers are controlled by a Heat-Timer sequencer with an additional combustion air/vent controller which sequences the draft and combustion air fans. The custodian on staff noted that for the most part the boilers run automatically, however occasionally he will manually turn boilers on if the building seems cold. The boilers are typically turned on in October and off in April.

UVs in classrooms for the most part are not controlled, except for in those where the side panel has been removed. In those cases teachers can adjust the fan on or off, but have no control over the hot water valve.

The HV units, split systems and packaged RTU are individually controlled by dedicated thermostats located in the rooms with which the units serve. In general set points are 70F for heat and 72F for cooling. Both programmable and non-programmable thermostats were observed, however not all thermostats were found. It is estimated that 25% are programmable.

An ECM is included that evaluates the energy savings potential of adding a full DDC controls system, which would combine the control of all units.

Domestic Hot Water Systems

Domestic hot water (DHW) is generated by one (1) dedicated Futera II hot water boiler which is identical to the seven used to generate heating HW in the building. The DHW boiler circulates 140F-160F domestic water to an estimated 750 gallon storage tank. DHW is used in toilet rooms, custodial mop sinks and in kitchen scullery sinks. An ECM is included which evaluates the energy saving potential of replacing the existing DHW system with a higher efficiency, smaller capacity system as the amount of hot water being produced and stored is more than what is actually needed.

Kitchen Equipment

The kitchen at is only used to reheat food (cooking is performed elsewhere). Kitchen equipment includes one (1) double door steam pressure cooker, one (1) range with a conventional (non-convection) oven, one (1) double door convection oven and one (1) kettle. All kitchen equipment is electric. In addition to the equipment used for heating there are also two (2) double door reach-in coolers, one (1) triple door reach-in cooler and two (2) double door reach-in freezers. There is no dishwasher and therefore no dishwasher booster heater in this school; all pots and pans are washed by hand in the kitchen scullery sinks. The kitchen equipment is in good condition; therefore there are no ECMs associated with the kitchen.

Plug Load

This school has computers, copiers, smart boards, residential appliances (microwave, refrigerator), printers, portable electric heaters (personal) and vending machines which contribute to the plug load in the building. The installation of vending machine occupancy sensors has been evaluated in an effort to reduce the plug load in the building.

Plumbing Systems

The plumbing fixtures (i.e., toilets and urinals) appear to be high flow and lavatory faucets have metering-type faucets. More modern stainless steel drinking fountains are present in corridors. An ECM is included to evaluate the water savings potential of installing low- flow water closet and urinals

Lighting Systems

The lighting in the building is primarily 4' ceiling/flush mounted linear fluorescent T8 strip fixtures as well as some recessed troffer fixtures with either one, two or four lamps. The gymnasium has 400W metal halide (MH) fixtures. In general all fixtures are controlled by switches mounted on the wall; although the corridors are controlled by breaker.

Exterior lighting consists of 70W metal halide wall packs. Exterior fixtures are likely controlled by photo-sensors mounted on the lighting fixtures. Three lighting ECM options have been included to evaluate adding occupancy sensors to the existing lighting; replacing the existing lighting with LED lighting and a third ECM which assesses the savings of occupancy sensors installed on the proposed LED lights.

3.0 UTILITIES

Utilities used by the building are delivered and supplied by the following utility companies:

	Electric	Natural Gas
Deliverer	PSEG	PSEG
Supplier	Nextera Energy Services	PSEG


For the 12-month period ending in December 2013, the utilities usages and costs for the building were as follows:

Electric		
Annual Consumption	1,114,500	kWh
Annual Cost	154,398	\$
Blended Unit Rate	0.14	\$/kWh
Supply Rate	0.12	\$/kWh
Demand Rate	5.91	\$/kW
Peak Demand	366	kW
Natural Gas		
Annual Consumption	94,362	Therms
Annual Cost	87,519	\$
Unit Rate	0.93	\$/therm


Blended Rate: Average rate charged determined by the annual cost / annual usage

Supply Rate: Actual rate charged for electricity usage in kWh (based on most recent electric bill)

Demand Rate: Rate charged for actual electrical demand in kW (based on most recent electric bill)



The electricity consumption per month is consistent throughout the year except for in June and July where there is a peak in electricity and demand. It is presumed that cooling equipment use is the cause of the increased summer month usage.



Natural gas is used primarily for space heating during the winter months with a small amount of baseline usage during the non-winter months for domestic hot water production as well as a small amount of kitchen equipment usage.

In addition, domestic water and sewer services are provided by City of Newark Division of Water at \$7.55/1000 gal.

See Appendix A for utility analysis.

Under New Jersey's energy deregulation law, the supply portion of the electric (or natural gas) bill is separated from the delivery portion. The supply portion is open to competition, and customers can shop around for the best price for their energy suppliers. The electric and natural gas distribution utilities will still deliver the gas/ electric supplies through their wires and pipes – and respond to emergencies, should they arise – regardless of where those supplies are purchased. Purchasing the energy supplies from a company other than your electric or gas utility is purely an economic decision; it has no impact on the reliability or safety of the service.

Comparison of Utility Rates to NJ State Average Rates*				Recommended to Shop for Third Party Supplier?
Utility	Units	School Average Rate	NJ Average Rate	
Electricity	\$/kWh	\$0.124	\$0.128	N
Natural Gas	\$/Therm	\$0.927	\$0.955	N

* Per U.S. Energy Information Administration (Annual 2013 data – Electricity and Natural Gas)


Additional information on selecting a third party energy supplier is available here:

<http://www.state.nj.us/bpu/commercial/shopping.html>.

See Appendix A for a list of third-party energy suppliers licensed by the Board of Public Utilities to sell within the building's service area.


The charts below represent estimated utility end-use utility profiles for the building. The values used within the charts were estimated from a review of the utility analysis and the energy savings calculations.

Site End-Use Utility Profile



Most of the electricity consumed by educational facilities is used to for lighting, cooling, and plug loads such as computers and copiers; most of the natural gas is used for space heating. Each school's energy profile is different, and the following charts represent typical utility profiles for K-12 schools per U.S. Department of Energy.

Typical End-Use Utility Profile for Educational Facilities



Courtesy: E SOURCE; from Commercial Building Energy Consumption Survey, 1999 data

4.0 BENCHMARKING

TRC has previously benchmarked this building, the results of which have been provided to NPS. The results are summarized below. Copies of the benchmarking report are available in Appendix G.

The EPA Portfolio Manager benchmarking tool provides a site and source Energy Use Intensity (EUI), as well as an Energy Star performance rating for qualifying building types. The EUIs are provided in kBtu/ft²/year, and the performance rating represents how energy efficient a building is on a scale of 1 to 100, with 100 being the most efficient. In order for a building to receive an Energy Star label, the energy benchmark rating must be at least 75. As energy use decreases from implementation of the proposed measures, the Energy Star rating will increase.

The site EUI is the amount of heat and electricity consumed by a building as reflected in utility bills. Site energy may be delivered to a facility in the form of primary energy, which is raw fuel burned to create heat or electricity, such as natural gas or oil; or as secondary energy, which is the product created from a raw fuel such as electricity or district steam. To provide an equitable comparison for different buildings with varying proportions of primary and secondary energy consumption, Portfolio Manager uses the convention of source EUIs. The source energy also accounts for losses incurred in production, storage, transmission, and delivery of energy to the site, which provide an equivalent measure for various types of buildings with differing energy sources. The results of the benchmarking are contained in the table below.

Site EUI kBtu/ft ² /yr	Energy Star Rating (1-100)
86.4*	17**

* Calculated by CHA using Utility Data provided by NPS

** Provided by TRC

The school has a below average Energy Star Rating Score (50 being the median score), and as such by implementing the measures discussed in this report, it is expected that the EUI can be further reduced and the Energy Star Rating further increased.

5.0 ENERGY CONSERVATION MEASURES

The following types of energy savings opportunities are identified in this section of the report:

- Energy conservation measures (ECMs) are energy savings recommendations that typically require a financial investment. For these areas of opportunity, CHA prepared detailed calculations, as summarized in this section and in Appendix C. In general, additional savings may exist from reductions in maintenance activities associated with new equipment or better controls; however for conservatism, maintenance savings are not accounted for in this report; instead the only savings which are reported are those derived directly from reductions in energy which can be tracked by the utility bills.
- Operational and Maintenance measures (O&M) consist of low- or no-cost operational opportunities, which if implemented would have positive impacts on overall building operation, comfort levels, and/or energy usage. There are no estimated savings, costs or paybacks associated with the O&M measures included as part of this study.

Energy savings were quantified in the form of:

- electrical usage (kWh=Kilowatt-hour),
- electrical demand (kW=kilowatts),
- natural gas (therms=100,000 Btu),
- propane gas (gallons=91,650 Btu),
- fuel oil (gallons =138,700 Btu), and
- water (kgal=1,000 gallons).

These recommendations are influenced by the time period that it takes for a proposed project to “break even” referred to as “Simple Payback”. Simple payback is calculated by dividing the estimated cost of implementing the ECM by the energy cost savings (in dollars) of that ECM.

Another financial indicator of the performance of a particular ECM is the Return on Investment or ROI, which represents the benefit (annual savings over the life of a project) of an investment divided by the cost of the investment. The result is expressed as a percentage or ratio.

Two other financial analyses included in this report are Internal Rate of Return (IRR) and Net Present Value (NPV). Internal Rate of Return is the discount rate at which the present value of a project costs equals the present value of the project savings. Net Present Value is the difference between present value of an investment's future net cash flows and the initial investment. If the NPV equals “0”, the project would equate to investing the same amount of dollars at the desired rate. NPV is sometimes referred to as Net Present Worth. These values are provided in the Summary Tab in Appendix C.

5.1 ECM-1 Replace Hot Water Boilers with Condensing Hot Water Boilers

Presently, the building is heated by seven (7) 85% efficient non-condensing hot water boilers. New high-turndown condensing gas boilers are available that minimally operate at 88%, and can operate as high as 96%. To implement this ECM, one existing boiler will be removed and one condensing boiler put in its place. Some piping and wiring modifications will be needed. New dedicated boiler venting would also need to be installed either through the roof or sidewall.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-1 Replace Hot Water Boilers with Condensing Hot Water Boilers

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
\$	kW	kWh	Therms	\$		\$	Years	Years
220,697	-	-	3,842	3,573	(0.6)	-	61.8	61.8

* Incentive shown is per the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities.

This measure is recommended. It is important to note that this ECM is recommended only if ECM-4 is also to be pursued. The presence of DDC controls will allow the proposed condensing boilers to operate at the upmost efficiency as all equipment in the building will be able to talk to the control system.

5.2 ECM-2 Install Premium Efficiency Motors

The hot water pump motors in the boiler room were observed to be less than premium efficiency. These include two (2) 30 HP HHW pumps which are 92.4% efficient, while premium efficiency are 94% efficient.

The savings of this measure are calculated from the motor efficiency improvement for the motors operating at full load.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-2 Install Premium Efficiency Motors

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
\$	kW	kWh	Therms	\$		\$	Years	Years
4,811	-	1,334	-	185	(0.3)	-	25.9	25.9

* Does not qualify for Incentive from the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities

This measure is recommended.

5.3 ECM-3 Install Window A/C Controller

There are approximately (46) window air conditioners located throughout the school in classrooms and offices.

This ECM evaluates the installation of programmable “smart” timers that interrupt the electrical supply to the window air conditioners when cooling is not needed due to the room being unoccupied. The timers are configurable to operate as a standalone timer or they can be wirelessly interconnected to provide remote temperature control using software.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-3 Install Window A/C Controller

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
\$	kW	kWh	Therms	\$		\$	Years	Years
8,900	-	37,024	-	5,146	4.8	-	1.7	1.7

* Does not qualify for Incentive from the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities

This measure is recommended.

5.4 ECM-4 Install Full DDC Controls

The current control system consists of independently electrically controlled thermostats, some of which are programmable and others are not. Some HVAC equipment operates while the building is unoccupied.

A Full Direct Digital Control (DDC) building automation system consists of automatic control of individual space heating and ventilation equipment, and provides monitoring, trending and alarms which notify an operator when a piece of equipment fails or operates outside a given set-point. This system allows for the implementation of energy efficient strategies, such as: time of day (TOD) optimization, set point optimization, staggered start, night setback, temporary daytime setback, economizer (free cooling), demand control ventilation, exhaust fan shut down, and holiday TOD optimization.

Energy savings are generated from temperature reduction during the day and night as well as other controls sequences mentioned above, as applicable to the proposed HVAC system improvements. The savings is estimated at 10% overall energy reduction based on past experience with similar sized school buildings having fully functioning digital controls.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-4 Install Full DDC Controls

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
\$	kW	kWh	Therms	\$		\$	Years	Years
392,179	-	-	18,179	16,906	(0.4)	-	23.2	23.2

* Does not qualify for Incentive from the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities.

This measure is recommended.

5.5 ECM-5 Domestic Hot Water System Improvements

The existing domestic hot water heating system consists of one (1) Futera natural gas fired boiler which circulated DHW through one (1) estimated 750 gallon storage tank. The DHW boiler has a thermal efficiency of 80%. The amount of stored water is oversized for this type of school which only uses hot water at hand sinks and some kitchen sinks.

Implementation of this ECM will entail replacing the existing DHW boiler with a high efficiency condensing water heaters. The tank size of the existing system will be reduced which will result in a combined savings from reducing the storage losses as well as reducing the overall fuel consumption. The proposed DHW heaters include two (2) high efficiency condensing heaters with 100 gallon capacity each.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-5 Domestic Hot Water System Improvements

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
\$	kW	kWh	Therms	\$		\$	Years	Years
35,796	-	-	1,539	1,431	(0.0)	-	25.0	25.0

* Does not qualify for Incentive from the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities.

This measure is recommended.

5.6 ECM-6 Install Vending Misers

The building presently has three (3) cold beverage vending machines.

These vending machines operate continuously 24 hours per day, seven (7) days a week. Installing controls such as timers or occupancy sensors allow the machines to turn on only when a customer is present or when the compressor must run to maintain the product at the desired temperature. By implementing this measure electrical energy savings could be realized.

The calculation uses electrical consumption and annual electrical cost as the baseline, vs. the reduced electrical consumption and cost for the proposed case. The difference between the two values is the energy savings.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-6 Install Vending Misers

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
\$	kW	kWh	Therms	\$		\$	Years	Years
840	-	8,858	-	1,231	13.7	-	0.7	0.7

* Incentive shown is per the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities.

This measure is recommended.

5.7 ECM-7 Install Low Flow Plumbing Fixtures

The plumbing fixtures in this building are older high flow fixtures. The water savings associated from replacing existing high flow fixtures with low-flow fixtures was calculated by taking the difference of the annual water usage for the proposed and base case. The basis of this calculation is the estimate usage of each fixture, gallons per use, and number of fixtures. Replacing the existing fixtures in the restrooms with 1.28 Gals/flush toilets, 1.0 gal/flush urinals, and 0.5 gpm faucets will conserve water which will result in lower annual water and sewer charges. Faucets with low-flow push valves were not considered for replacement.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-7 Install Low Flow Plumbing Fixtures

Budgetary Cost	Annual Utility Savings					ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Water	Total				
\$	kW	kWh	Therms	kGal	\$		\$	Years	Years
273,566	-	-	-	387	2,919	(0.7)	-	93.7	93.7

* Does not qualify for Incentive from the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities

This measure is not recommended due to the long payback period.

5.8.1 ECM-L1 Lighting Replacement / Upgrades

The existing lighting system consists of mostly T8 linear fluorescent fixtures which until recently represented the most efficient lighting technology available. Exterior lighting includes 70W wall mounted area light fixtures. Recent technological improvements in light emitting diode (LED) technologies have driven down the initial costs making it a viable option for installation.

Overall energy consumption can be reduced by replacing inefficient bulbs and linear fluorescent bulbs with more efficient LED technology. To compute the annual savings for this ECM, the energy consumption of the current lighting fixtures was established and compared to the proposed fixture power requirement with the same annual hours of operation. The difference between the existing and proposed annual energy consumption was the energy savings. These calculations are based on 1 to 1 replacements of the fixtures, and do not take into account lumen output requirements for a given space. A more comprehensive engineering study should be performed to determine correct lighting levels.

Supporting calculations, including assumptions for lighting hours and annual energy usage for each fixture, are provided in Appendix C and summarized below:

ECM-L1 Lighting Replacement / Upgrades

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
\$	kW	kWh	Therms	\$		\$	Years	Years
268,898	64	197,653	-	29,057	0.2	2,600	9.3	9.2

* LED retrofits must go through the "custom" measures incentive option under New Jersey SmartStart Program. There are no "prescriptive" incentives for LED retrofits. Projects must achieve a minimum of 75,000 kWh annual savings to qualify for "custom" incentives. See section 6.0 for other incentive opportunities

This measure is not recommended in lieu of ECM L3.

5.8.2 ECM-L2 Install Lighting Controls (Occupancy Sensors)

Presently, all interior lighting fixtures are controlled by wall mounted switches. The comprehensive lighting survey determined that lighting in some areas could benefit from installation of occupancy sensors to turn off lights when rooms are unoccupied.

This measure recommends installing occupancy sensors for the current lighting system. Using a process similar to that utilized in Section 5.8.1, the energy savings for this measure was calculated by applying the known fixture wattages in the space to the estimated existing and proposed times of operation for each fixture.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-L2 Install Lighting Controls (Occupancy Sensors)

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
\$	kW	kWh	Therms	\$		\$	Years	Years
30,240	0	65,453	-	8,116	2.0	3,920	3.7	3.2

* Incentive shown is per the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities.

This measure is not recommended in lieu of ECM L3.

5.8.3 ECM-L3 Lighting Replacements with Controls (Occupancy Sensors)

This measure is a combination of ECM-L1 and ECM-L2; recommending replace/upgrade the current lighting fixtures to more efficient ones and installing occupancy sensors on the new lights. Interactive effects of the higher efficiency lights and occupancy sensors lead the energy and cost savings for this measure to not be cumulative or equivalent to the sum of replacing the lighting fixtures alone and installing occupancy sensors without the lighting upgrade. The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-L3 Lighting Replacements with Controls (Occupancy Sensors)

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
\$	kW	kWh	Therms	\$		\$	Years	Years
299,138	64	225,733	-	32,539	0.2	6,520	9.2	9.0

* LED retrofits must go through the "custom" measures incentive option under New Jersey SmartStart Program. There are no "prescriptive" incentives for LED retrofits. Projects must achieve a minimum of 75,000 kWh annual savings to qualify for "custom" incentives. See section 6.0 for other incentive opportunities

This measure is recommended.

5.9 Additional O&M Opportunities

This list of operations and maintenance (O&M) - type measures represent low-cost or no-cost opportunities, which if implemented will have a positive impact on the overall building operations, comfort and/or energy consumption. The recommended O&M measures for this building are as follows:

- Install Covers on Window Air Conditioners
- Clean Window AC filters before each season
- Replace Unit Ventilator filters at least twice a year
- Clear surface above unit ventilators of materials, plants, or books
- Set computers monitors to turn off and computers to sleep mode when not in use
- Look for the ENERGY STAR® label when purchasing Window AC units or Kitchen Appliances
- Disconnect unnecessary or unused small appliances and electronics when not in use to reduce phantom loads
- Train custodians to turn off lights and set HVAC temperatures to minimum levels when rooms are unoccupied
- Develop an Energy Master Plan to measure and track energy performance
- Educate students and staff about how their behavior affects energy use. Create student energy patrols to monitor and inform administration when energy is being wasted.
- During the winter, Custodians should ensure all windows are closed as part of cleaning routine

6.0 PROJECT INCENTIVES

6.1 Incentives Overview

The following sections give detailed information on available incentive programs including New Jersey Smart Start, Direct Install, New Jersey Pay for Performance (P4P) and Energy Savings Improvement Plan (ESIP). If the School District wishes to and is eligible to participate in the Energy Savings Improvement Plan (ESIP) program and/or the Pay for Performance Incentive Program (P4P), it cannot participate in either the Smart Start or Direct Install Programs. Refer to Appendix D for more information on the Smart Start program.

6.1.1 New Jersey Smart Start Program

For this energy audit, The New Jersey Smart Start Incentives are used in the energy savings calculations, where applicable. This program is intended for medium and large energy users and provides incentives for:

- Electric Chillers
- Gas Chillers
- Gas Heating
- Unitary HVAC
- Ground Source Heat Pumps
- Variable frequency Drives/ motors
- Refrigeration
- Prescriptive and performance lighting and lighting controls

The equipment is procured using a typical bid- build method, installed and paid for and then the incentives are reimbursed to the owner.

Refer to Appendix D for more information on the Smart Start program.

6.1.2 Direct Install Program

The Direct Install Program applies to smaller facilities that have a peak electrical demand of 200 kW or less in any of the previous 12 months. Buildings must be located in New Jersey and served by one of the state's public, regulated electric utility companies.

Direct Install is funded through New Jersey's Clean Energy Program and is designed to provide capital for building energy upgrade projects to fast track implementation. The program will pay up to 70% of the costs for lighting, HVAC, motors, refrigeration, and other equipment upgrades with higher efficiency alternatives. If a building is eligible for this funding, the Direct Install Program can reduce the implementation cost of energy conservation projects.

The Direct Install program has specific HVAC equipment and lighting requirements and is generally applicable only to smaller package HVAC units, small boilers and lighting retrofits.

The program pays a maximum amount of \$75,000 per building, and up to \$250,000 per customer per year. Installations must be completed by an approved Direct Install participating contractor, a list of which can be found on the New Jersey Clean Energy Website. Contractors will coordinate with the applicant to arrange installation of recommended measures identified in a previous energy assessment, such as this energy audit. The incentive is reimbursed to the Owner upon successful replacement and payment of the equipment.

The building does not qualify for this program because its electrical demand is more than the maximum peak electrical demand of 200 kW for the last 12 month period.

Refer to Appendix D for more information on this program.

6.1.3 New Jersey Pay For Performance Program (P4P)

This building may be eligible for incentives from the New Jersey Office of Clean Energy. The most significant incentives are available from the New Jersey Pay for Performance (P4P) Program. The P4P program is designed to offset the cost of energy conservation projects for facilities that pay the Societal Benefits Charge (SBC) and whose demand (kW) in any of the preceding 12 months exceeds 100 kW. This demand minimum has been waived for buildings owned by local governments or municipalities and non-profit organizations and *is not applicable to public schools*. Facilities that meet this criterion must also achieve a minimum performance target of 15% energy reduction by using the EPA Portfolio Manager benchmarking tool before and after implementation of the measure(s). Additionally, the overall return on investment (ROI) must exceed 10%. If the participant is a municipal electric company customer, and a customer of a regulated gas New Jersey Utility, only gas measures will be eligible under the Program. Available incentives are as follows:

Incentive #1: Energy Reduction Plan – This incentive is designed to offset the cost of services associated with the development of the Energy Reduction Plan (ERP). The ERP must include a detailed energy audit of the desired ECMs, energy savings calculations (using building modeling software) and inputting of all utility bills into the EPA Portfolio Manager website.

- Incentive Amount: \$0.10/SF
- Minimum incentive: \$5,000
- Maximum Incentive: \$50,000 or 50% of Facility annual energy cost

The standard incentive pays \$0.10 per square foot, up to a maximum of \$50,000, not to exceed 50% of facility annual energy cost, paid after approval of application. For building audits funded by the New Jersey Board of Public Utilities, which receive an initial 75% incentive toward performance of the energy audit, facilities are only eligible for an additional \$0.05 per square foot, up to a maximum of \$25,000, rather than the standard incentive noted above. The ERP must be completed by a Certified Energy Manager (CEM) and submitted along with the project application.

Incentive #2: Installation of Recommended Measures – This incentive is based on projected energy savings as determined in Incentive #1 (Minimum 15% savings must be achieved), and is paid upon successful installation of recommended measures.

Electric

- Base incentive based on 15% savings: \$0.09/ per projected kWh saved.
- For each % over 15% add: \$0.005 per projected kWh saved.
- Maximum incentive: \$0.11/ kWh per projected kWh saved.

Gas

- Base incentive based on 15% savings: \$0.90/ per projected Therm saved.
- For each % over 15% add: \$0.05 per projected Therm saved.
- Maximum incentive: \$1.25 per projected Therm saved.

Incentive cap: 25% of total project cost

Incentive #3: Post-Construction Benchmarking Report – This incentive is paid after acceptance of a report proving energy savings over one year utilizing the Environmental Protection Agency (EPA) Portfolio Manager benchmarking tool.

Electric

- Base incentive based on 15% savings: \$0.09/ per projected kWh saved.
- For each % over 15% add: \$0.005 per projected kWh saved.
- Maximum incentive: \$0.11/ kWh per projected kWh saved.

Gas

- Base incentive based on 15% savings: \$0.90/ per projected Therm saved.
- For each % over 15% add: \$0.05 per projected Therm saved.
- Maximum incentive: \$1.25 per projected Therm saved.

Combining Incentives #2 and #3 will provide a total of \$0.18/ kWh and \$1.8/therm not to exceed 50% of total project cost. Additional Incentives for #2 and #3 are increased by \$0.005/kWh and \$0.05/therm for each percentage increase above the 15% minimum target to 20%, calculated with the EPA Portfolio Manager benchmarking tool, not to exceed 50% of total project cost.

For the purpose of demonstrating the eligibility of the ECM's to meet the minimum savings requirement of 15% annual savings and 10% ROI for the Pay for Performance Program, all ECM's identified in this report have been included in the incentive calculations. The results for the building are shown in Appendix C, along with more detailed program information provided in Appendix D.

6.1.4 Energy Savings Improvement Plan

The Energy Savings Improvement Program (ESIP) allows government agencies to make energy related improvements to their facilities and pay for the costs using the value of energy savings that result from the improvements. Under the recently enacted Chapter 4 of the Laws of 2009 (the law), the ESIP provides all government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources.

ESIP allows local units to use “energy savings obligations” (ESO) to pay for the capital costs of energy improvements to their facilities. ESIP loans have a maximum loan term of 15 year. ESOs are not considered “new general obligation debt” of a local unit and do not count against debt limits or require voter approval. They may be issued as refunding

bonds or leases. Savings generated from the installation of energy conservation measures pay the principal of and interest on the bonds; for that reason, the debt service created by the ESOs is not paid from the debt service fund, but is paid from the general fund.

For local governments interested in pursuing an ESIP, the first step is to perform an energy audit. Pursuing a Local Government Energy Audit through New Jersey's Clean Energy Program is a valuable first step to the ESIP approach. The "Local Finance Notice" outlines how local governments can develop and implement an ESIP for their facilities. The ESIP can be prepared internally if the entity has qualified staff. If not, the ESIP must be implemented by an independent contractor and not by the energy savings company producing the Energy Reduction Plan.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Local units should carefully consider all alternatives to develop an approach that best meets their needs. Refer to Appendix D for more information on this program.

6.1.5 Renewable Energy Incentive Program

The Renewable Energy Incentive Program (REIP) is part of New Jersey's efforts to reach its Energy Master Plan goals of striving to use 30 percent of electricity from renewable sources by 2020.

Incentives for sustainable bio-power projects and for energy storage projects are currently under development, with competitive solicitations for each of those technologies expected to begin in the first quarter of 2014. The wind program is currently on hold.

New solar projects are no longer eligible for REIP incentives, but can register for Solar Renewable Energy Certificates (SRECs) through the SREC Registration Program (SRP).

7.0 | ALTERNATIVE ENERGY SCREENING EVALUATION

7.1 Solar

7.1.1 Photovoltaic Rooftop Solar Power Generation

The roof of this building contains a large solar array and there is no additional space to install more solar panels. The solar panels are owned by PSEG. It is not recommended that the school install any further PV solar panels at this time.

7.1.2 Solar Thermal Hot Water Generation

Active solar thermal systems use solar collectors to gather the sun's energy to heat a fluid. An absorber in the collector (usually black colored piping) converts the sun's energy into heat. The heat is transferred to circulating water, antifreeze, or air for immediate use or is storage for later utilization. Applications for active solar thermal energy include supplementing domestic hot water, heating swimming pools, space heating or preheating air in residential and commercial buildings.

A standard solar hot water system is typically composed of solar collectors, heat storage vessel, piping, circulators, and controls. Systems are typically integrated to work alongside a conventional heating system that provides heat when solar resources are not sufficient. The solar collectors are usually placed on the roof of the building, oriented south, and tilted at the same angle as the site's latitude, to maximize the amount of solar radiation collected on a yearly basis.


Several options exist for using active solar thermal systems for space heating. The most common method is called a passive solar hot water system involves using glazed collectors to heat a liquid held in a storage tank (similar to an active solar hot water system described above which requires pumping). The most practical system would transfer the heat from the panels to thermal storage tanks and then use the pre-heated water for domestic hot water production. DHW is presently produced by natural gas fired water heaters and, therefore, this measure would offer natural gas utility savings. Unfortunately, the amount of domestic hot water that is currently used by this school is very small. Installing a solar domestic hot water system is not recommended due to the limited amount of domestic hot water presently consumed by the school.

This measure is not recommended due to the relatively low domestic hot water usage.

7.2 Wind Powered Turbines

Wind power is the conversion of kinetic energy from wind into mechanical power that is used to drive a generator which creates electricity by means of a wind turbine. A wind turbine consists of rotor and blades connected to a gearbox and generator that are mounted onto a tower. Newer wind turbines also use advanced technology to generate electricity at a variety of frequencies depending on the wind speed, convert it to DC and then back to AC before sending it to the grid. Wind turbines range from 50 – 750 kW for utility scale turbines down to below 50 kW for residential use. On a scale of 1 (the lowest) to 7 (the highest), Class 3 and above (wind speeds of 13 mph or greater) are generally considered “good wind resource” according to the Wind Energy Development

Programmatic EIS Information Center hosted by the Bureau of Land Management. According to the map below, published by NREL, Newark, NJ is classified as Class 1 at 50m, meaning the city would not be a good candidate for wind power.



This measure is not recommended due the location of the school.

7.3 Combined Heat and Power Plant

Combined heat and power (CHP), cogeneration, is self-production of electricity on-site with beneficial recovery of the heat byproduct from the electrical generator. Common CHP equipment includes reciprocating engine-driven, micro turbines, steam turbines, and fuel cells. Typical CHP customers include industrial, commercial, institutional, educational institutions, and multifamily residential facilities. CHP systems that are commercially viable at the present time are sized approximately 50 kW and above, with numerous options in blocks grouped around 300 kW, 800 kW, 1,200 kW and larger. Typically, CHP systems are used to produce a portion of the electricity needed by a facility some or all of the time, with the balance of electric needs satisfied by purchase from the grid.

Any proposed CHP project will need to consider many factors, such as existing system load, use of thermal energy produced, system size, natural gas fuel availability, and proposed plant location. The building has sufficient need for electrical generation and the ability to use most of the thermal byproduct during the winter; however thermal usage during the summer months does not exist. Thermal energy produced by the CHP plant in the warmer months will be wasted. An absorption chiller could be installed to utilize the heat to produce chilled water; however, there is no chilled water distribution system in the building. CHP is not recommended due to the building's limited summer thermal demand.

This measure is not recommended due to the lack of sufficient year round thermal load need to make a CHP system financially viable.

7.4 Demand Response Curtailment

Presently, electricity is delivered by PSE&G, which receives the electricity from regional power grid RFC. PSE&G is the regional transmission organization (RTO) that coordinates the movement of wholesale electricity in all or parts of 13 states and the District of Columbia including the State of New Jersey.

Utility Curtailment is an agreement with the utility provider's regional transmission organization and an approved Curtailment Service Provider (CSP) to shed electrical load by either turning major equipment off or energizing all or part of a facility utilizing an emergency generator; therefore, reducing the electrical demand on the utility grid. This program is to benefit the utility company during high demand periods and utility provider offers incentives to the CSP to participate in this program. Enrolling in the program will require program participants to drop electrical load or turn on emergency generators during high electrical demand conditions or during emergencies. Part of the program also will require that program participants reduce their required load or run emergency generators with notice to test the system.

A pre-approved CSP will require a minimum of 100 kW of load reduction to participate in any curtailment program. From January 2013 through December 2013 the following table summarizes the electricity load profile for the building.

Building Electric Load Profile

Peak Demand kW	Min Demand kW	Avg Demand kW	Onsite Generation Y/N	Eligible? Y/N
366	180	229	Y	Y

This measure is not recommended because the building does not have adequate onsite generation in order to support the electrical load reduction needed to participate in curtailment and cannot shut down equipment while students are present.

8.0 CONCLUSIONS & RECOMMENDATIONS

The LGEA energy audit conducted by CHA for the building identified potential annual savings of \$61,012/yr with an overall payback of 15.8 years, if the recommended ECMs are implemented.

The potential annual energy and cost savings for the recommended ECMs are shown in the following table.

Electric Savings (kWh)	Natural Gas Savings (therms)	Total Savings (\$)	Payback (years)
272,949	23,559	61,012	15.8


The following projects should be considered for implementation:

- Replace Hot Water Boilers with Condensing Hot Water Boilers
- Install Premium Efficiency Motors
- Install Window A/C Controller
- Install DDC Controls
- Domestic Hot Water System Improvements
- Install Vending Machine Controls
- Lighting Replacements with Controls (Occupancy Sensors)

There are no alternative ECMs recommended for further study.

If NPS implements the recommended ECMs, energy savings would be as follows:

	Existing Conditions	Post Recommended ECMs	Percent Savings
Costs (\$)	241,917	180,905	25%
Electricity (kWh)	1,114,500	841,551	24%
Natural Gas (therms)	94,362	70,803	25%
Site EUI (kbtu/SF/Yr)	86.4	65.0	



Next Steps: This energy audit has identified several areas of potential energy savings. Newark Public Schools can use this information to pursue incentives offered by the NJBPU's NJ Clean Energy Program. Additional meetings will be scheduled with NPS staff members to review possible options.

APPENDIX A

Utility Usage Analysis and Alternate Utility Suppliers

Bard Early College High School, Newark Bridges High School - Electric Usage

Start Date	End Date	kWh	Demand Usage (KW)	Total Charge	Supply Charge	Delivery Charge	Demand Charge	Consumption (\$)	Blended Rate (\$/kWh)	Consumption Rate (\$/kWh)	Demand Rate (\$/kW)
1/5/2012	2/2/2012	81000	186	13,690.00	0	2,658.78	648.5	13,041.50	0.17	0.16	3.49
2/3/2012	3/5/2012	88800	186	15,010.00	0	2,877.77	648.51	14361.49	0.17	0.16	3.49
3/6/2012	4/3/2012	82200	180	13,890.00	0	2,692.47	627.59	13262.41	0.17	0.16	3.49
4/4/2012	5/3/2012	85200	186	14,395.00	0	2,776.69	648.51	13746.49	0.17	0.16	3.49
5/4/2012	6/4/2012	85200	198	14,400.00	0	4,419.07	690.34	13709.66	0.17	0.16	3.49
6/5/2012	7/3/2012	66000	192	10,827.85	6,232.21	3,926.21	669.43	10158.42	0.16	0.15	3.49
7/4/2012	8/2/2012	63600	150	10,178.72	6,143.10	3,512.63	522.99	9,655.73	0.16	0.15	3.49
8/3/2012	8/31/2012	61800	150	9,921.13	5,935.32	3,462.82	522.99	9398.14	0.16	0.15	3.49
9/1/2012	12/3/2012	220800	234	29,838.72	19,983.72	7,658.44	2,196.56	27642.16	0.14	0.13	9.39
12/4/2012	1/3/2013	88800	216	11,396.10	7,649.52	2,992.27	754.31	10641.79	0.13	0.12	3.49
1/4/2013	2/1/2013	90600	216	11,707.75	7,845.90	3,096.26	765.59	10942.16	0.13	0.12	3.54
2/2/2013	3/5/2013	101400	222	12,725.59	8,708.71	3,230.02	786.86	11938.73	0.13	0.12	3.54
3/6/2013	4/4/2013	88200	222	11,514.74	7,869.58	2,858.30	786.86	10727.88	0.13	0.12	3.54
4/5/2013	5/3/2013	85800	222	11,500.01	7,922.45	2,790.70	786.86	10713.15	0.13	0.12	3.54
5/3/2013	6/4/2013	88800	222	13,749.78	8,192.87	2,898.12	2,658.79	11090.99	0.15	0.12	11.98
6/4/2013	7/3/2013	152400	366	22,029.29	12,673.04	4,972.85	4,383.40	17645.89	0.14	0.12	11.98
7/3/2013	8/2/2013	113100	273	16,725.23	9,668.59	4,545.94	2,510.70	14214.53	0.15	0.13	9.20
8/3/2013	9/3/2013	73800	180	11,421.16	6,664.14	4,119.03	637.99	10783.17	0.15	0.15	3.54
9/4/2013	10/2/2013	69600	228	9,568.15	6,284.88	2,475.15	808.12	8760.03	0.14	0.13	3.54
10/3/2013	10/31/2013	69000	204	9,417.30	6,230.70	2,463.54	723.06	8694.24	0.14	0.13	3.54
11/1/2013	12/3/2013	92400	198	12,217.50	8,343.72	3,171.99	701.79	11515.71	0.13	0.12	3.54
12/4/2013	1/3/2014	89400	192	11,821.61	8,072.82	3,068.26	680.53	11141.08	0.13	0.12	3.54

Bard Early College High School, Newark Bridges H	Start Date	End Date	Months
321 Bergen St, 07103	1/5/2012	1/3/2014	23
Account Number	2147483647		
Meter Number	778017983		


ELECTRIC USAGE - MOST RECENT 12 MONTHS, PERIOD ENDING:

1/3/2014

Total Usage	1,114,500	kwh
Total Charges	\$154,398	
Blended Rate	\$0.14	\$/kWh
Consumption Rate	\$0.12	\$/kWh
Demand Rate	\$5.91	\$/kW
Max Demand	366.0	kW
Min Demand	180.0	kW
Avg Demand	228.8	kW

Bill missing, two month average used

**Bard Early College High School, Newark Bridges High School- Electric Usage -
Meter no.: 778017983**



Bard Early College High School, Newark Bridges High School - Natural Gas Usage

Index No	Current Name	Acct	Meter	Start Date	End Date	Therms	Total Charge	\$/therm
32	Bard Early College High School, Newark Bridges High School, Peoples Prep Charter (tenant)	4200056607	C0000000727234	1/5/2012	2/2/2012	14,660.66	13,113.32	0.89
32	Bard Early College High School, Newark Bridges High School, Peoples Prep Charter (tenant)	4200056607	C0000000727234	2/3/2012	3/5/2012	15,048.42	12,501.37	0.83
32	Bard Early College High School, Newark Bridges High School, Peoples Prep Charter (tenant)	4200056607	C0000000727234	3/6/2012	4/3/2012	8,104.29	4,932.03	0.61
32	Bard Early College High School, Newark Bridges High School, Peoples Prep Charter (tenant)	4200056607	C0000000727234	4/4/2012	5/3/2012	5,963.00	3,522.66	0.59
32	Bard Early College High School, Newark Bridges High School, Peoples Prep Charter (tenant)	4200056607	C0000000727234	5/4/2012	6/4/2012	270.48	262.12	0.97
32	Bard Early College High School, Newark Bridges High School, Peoples Prep Charter (tenant)	4200056607	C0000000727234	6/5/2012	7/3/2012	250.17	260.57	1.04
32	Bard Early College High School, Newark Bridges High School, Peoples Prep Charter (tenant)	4200056607	C0000000727234	7/4/2012	8/1/2012	171.22	215.81	1.26
32	Bard Early College High School, Newark Bridges High School, Peoples Prep Charter (tenant)	4200056607	C0000000727234	8/2/2012	8/30/2012	146.92	203.01	1.38
32	Bard Early College High School, Newark Bridges High School, Peoples Prep Charter (tenant)	4200056607	C0000000727234	8/31/2012	12/3/2012	16,144.47	17,248.75	1.07
32	Bard Early College High School, Newark Bridges High School, Peoples Prep Charter (tenant)	4200056607	C0000000727234	12/4/2012	1/3/2013	16,771.52	16,285.63	0.97
32	Bard Early College High School, Newark Bridges High School, Peoples Prep Charter (tenant)	4200056607	C0000000727234	1/4/2013	2/1/2013	17,526.36	16,302.82	0.93
32	Bard Early College High School, Newark Bridges High School, Peoples Prep Charter (tenant)	4200056607	C0000000727234	2/2/2013	3/5/2013	21,232.72	19,847.12	0.93
32	Bard Early College High School, Newark Bridges High School, Peoples Prep Charter (tenant)	4200056607	C0000000727234	3/6/2013	4/4/2013	14,027.81	9,932.23	0.71
32	Bard Early College High School, Newark Bridges High School, Peoples Prep Charter (tenant)	4200056607	C0000000727234	4/5/2013	5/3/2013	5,301.18	4,043.36	0.76
32	Bard Early College High School, Newark Bridges High School, Peoples Prep Charter (tenant)	4200056607	C0000000727234	5/4/2013	6/5/2013	427.7	441.48	1.03
32	Bard Early College High School, Newark Bridges High School, Peoples Prep Charter (tenant)	4200056607	C0000000727234	6/6/2013	7/3/2013	213.85	272.86	1.28
32	Bard Early College High School, Newark Bridges High School, Peoples Prep Charter (tenant)	4200056607	C0000000727234	7/4/2013	8/2/2013	0	104.24	#DIV/0!
32	Bard Early College High School, Newark Bridges High School, Peoples Prep Charter (tenant)	4200056607	C0000000727235	8/3/2013	9/3/2013	0	104.24	#DIV/0!
32	Bard Early College High School, Newark Bridges High School, Peoples Prep Charter (tenant)	4200056607	C0000000727235	9/4/2013	10/2/2013	290.56	311.78	1.07
32	Bard Early College High School, Newark Bridges High School, Peoples Prep Charter (tenant)	4200056607	C0000000727235	10/3/2013	11/1/2013	3,373.39	5,315.92	1.58
32	Bard Early College High School, Newark Bridges High School, Peoples Prep Charter (tenant)	4200056607	C0000000727234	11/2/2013	12/3/2013	15,164.64	14,446.11	0.95
32	Bard Early College High School, Newark Bridges High School, Peoples Prep Charter (tenant)	4200056607	C0000000727235	12/4/2013	1/3/2014	16,803.65	16,396.99	0.98


Bard Early College High School, Newark Bridges High School, Peoples Prep Charter (tenant)	Start Date	End Date	# Months
Account Number 4200056607	1/5/2012	1/3/2014	23
Meter Number C0000000727235			

NATURAL GAS USAGE - MOST RECENT 12 MONTHS, PERIOD ENDING:

1/3/2014

Annual Usage	94,362	Therms	
Annual Cost	\$87,519		
Rate	\$0.93	\$/Therm	Bill missing. Two month average used

**Bard Early College High School, Newark Bridges High School- Natural Gas Usage -
Meter No.: C0000000727234**



PSE&G ELECTRIC SERVICE TERRITORY
Last Updated: 10/24/12

***CUSTOMER CLASS - R – RESIDENTIAL C – COMMERCIAL I –INDUSTRIAL**

Supplier	Telephone & Web Site	*Customer Class
AEP Energy, Inc. 309 Fellowship Road, Fl. 2 Mount Laurel, NJ 08054	(866) 258-3782 www.aepenergy.com	C/I ACTIVE
Alpha Gas and Electric, LLC 641 5 th Street Lakewood, NJ 08701	(855) 553-6374 www.alphagasandelectric.com	R/C ACTIVE
Ambit Northeast, LLC 103 Carnegie Center Suite 300 Princeton, NJ 08540	(877)-30-AMBIT (877) 302-6248 www.ambitenergy.com	R/C ACTIVE
American Powernet Management, LP 437 North Grove St. Berlin, NJ 08009	(877) 977-2636 www.americanpowernet.com	C ACTIVE
Amerigreen Energy, Inc. 1463 Lamberton Road Trenton, NJ 08611	888-423-8357 www.amerigreen.com	R/C ACTIVE
AP Gas & Electric, LLC 10 North Park Place, Suite 420 Morristown, NJ 07960	(855) 544-4895 www.apge.com	R/C/I ACTIVE
Astral Energy LLC 16 Tyson Place Bergenfield, NJ 07621	(201) 384-5552 www.astralenergylc.com	R/C/I ACTIVE
Barclays Capital Services, Inc. 70 Hudson Street Jersey City, NJ 07302-4585	(888) 978-9974 www.group.barclays.com	C ACTIVE
BBPC, LLC d/b/a Great Eastern Energy 116 Village Blvd. Suite 200 Princeton, NJ 08540	(888) 651-4121 www.greateasternenergy.com	C/I ACTIVE
Champion Energy Services, LLC 72 Avenue L Newark, NJ 07105	(877) 653-5090 www.championenergyservices.com	R/C/I ACTIVE

Choice Energy, LLC 4257 US Highway 9, Suite 6C Freehold, NJ 07728	888-565-4490 www.4choiceenergy.com	R/C ACTIVE
Clearview Electric, Inc. 505 Park Drive Woodbury, NJ 08096	(888) CLR-VIEW (800) 746-4702 www.clearviewenergy.com	R/C/I ACTIVE
Commerce Energy, Inc. 7 Cedar Terrace Ramsey, NJ 07446	1-866-587-8674 www.commerceenergy.com	R ACTIVE
ConEdison Solutions Cherry Tree Corporate Center 535 State Highway Suite 180 Cherry Hill, NJ 08002	(888) 665-0955 www.conedsolutions.com	C/I ACTIVE
Constellation NewEnergy, Inc. 900A Lake Street, Suite 2 Ramsey, NJ 07446	(866) 237-7693 www.constellation.com	R/C/I ACTIVE
Constellation Energy 900A Lake Street, Suite 2 Ramsey, NJ 07446	(877) 997-9995 www.constellation.com	R ACTIVE
Credit Suisse, (USA) Inc. 700 College Road East Princeton, NJ 08450	(212) 538-3124 www.creditsuisse.com	C ACTIVE
Direct Energy Business, LLC 120 Wood Avenue, Suite 611 Iselin, NJ 08830	(888) 925-9115 www.directenergybusiness.com	C/I ACTIVE
Direct Energy Services, LLC 120 Wood Avenue, Suite 611 Iselin, NJ 08830	(866) 348-4193 www.directenergy.com	R ACTIVE
Discount Energy Group, LLC 811 Church Road, Suite 149 Cherry Hill, New Jersey 08002	(800) 282-3331 www.discountenergygroup.com	R/C ACTIVE
Dominion Retail, Inc. d/b/a Dominion Energy Solutions 395 Route #70 West Suite 125 Lakewood, NJ 08701	(866) 275-4240 www.dom.com/products	R/C ACTIVE

DTE Energy Supply, Inc. One Gateway Center, Suite 2600 Newark, NJ 07102	(877) 332-2450 www.dtesupply.com	C/I ACTIVE
Energy.me Midwest LLC 90 Washington Blvd Bedminster, NJ 07921	(855) 243-7270 www.energy.me	R/C/I ACTIVE
Energy Plus Holdings LLC 309 Fellowship Road East Gate Center, Suite 200 Mt. Laurel, NJ 08054	(877) 866-9193 www.energypluscompany.com	R/C ACTIVE
Ethical Electric Benefit Co. d/b/a Ethical Electric 100 Overlook Center, 2 nd Fl. Princeton, NJ 08540	(888) 444-9452 www.ethicalelectric.com	R/C ACTIVE
FirstEnergy Solutions 300 Madison Avenue Morristown, NJ 07962	(800) 977-0500 www.fes.com	C/I ACTIVE
Gateway Energy Services Corp. 44 Whispering Pines Lane Lakewood, NJ 08701	(800) 805-8586 www.gesc.com	R/C/I ACTIVE
GDF SUEZ Energy Resources NA, Inc. 333 Thornall Street Sixth Floor Edison, NJ 08837	(866) 999-8374 www.gdfsuezenergyresources.com	C/I ACTIVE
Glacial Energy of New Jersey, Inc. 75 Route 15 Building E Lafayette, NJ 07848	(888) 452-2425 www.glacialenergy.com	C/I ACTIVE
Global Energy Marketing LLC 129 Wentz Avenue Springfield, NJ 07081	(800) 542-0778 www.globalp.com	C/I ACTIVE
Green Mountain Energy Company 211 Carnegie Center Drive Princeton, NJ 08540	(866) 767-5818 www.greenmountain.com/commercial-home	C/I ACTIVE

Hess Corporation 1 Hess Plaza Woodbridge, NJ 07095	(800) 437-7872 www.hess.com	C/I ACTIVE
HIKO Energy, LLC 655 Suffern Road Teaneck, NJ 07666	(888) 264-4908 www.hikoenergy.com	R/C ACTIVE
HOP Energy, LLC d/b/a Metro Energy, HOP Fleet Fueling, HOP Energy Fleet Fueling 1011 Hudson Avenue Ridgefield, NJ 07657	(877) 390-7155 www.hopenergy.com	R/C/I ACTIVE
Hudson Energy Services, LLC 7 Cedar Street Ramsey, New Jersey 07446	(877) Hudson 9 www.hudsonenergyservices.com	C ACTIVE
IDT Energy, Inc. 550 Broad Street Newark, NJ 07102	(877) 887-6866 www.idtenergy.com	R/C ACTIVE
Independence Energy Group, LLC 3711 Market Street, 10 th Fl. Philadelphia, PA 19104	(877) 235-6708 www.chooseindependence.com	R/C ACTIVE
Integrus Energy Services, Inc. 99 Wood Ave, South, Suite 802 Iselin, NJ 08830	(877) 763-9977 www.integrusenergy.com	C/I ACTIVE
Keil & Sons, Inc. d/b/a Systrum Energy 1 Bergen Blvd. Fairview, NJ 07022	(877) 797-8786 www.systrumenergy.com	R/C/I ACTIVE
Liberty Power Delaware, LLC 1973 Highway 34, Suite 211 Wall, NJ 07719	(866) 769-3799 www.libertypowercorp.com	C/I ACTIVE
Liberty Power Holdings, LLC 1973 Highway 34, Suite 211 Wall, NJ 07719	(866) 769-3799 www.libertypowercorp.com	C/I ACTIVE

Linde Energy Services 575 Mountain Avenue Murray Hill, NJ 07974	(800) 247-2644 www.linde.com	C/I ACTIVE
Marathon Power LLC 302 Main Street Paterson, NJ 07505	(888) 779-7255 www.mecny.com	R/C/I ACTIVE
MXenergy Electric Inc. 900 Lake Street Ramsey, NJ 07446	(800) 785-4374 www.mxenergy.com	R/C/I ACTIVE
NATGASCO, Inc. 532 Freeman St. Orange, NJ 07050	(973) 678-1800 x. 251 www.supremeenergyinc.com	R/C ACTIVE
NextEra Energy Services New Jersey, LLC 651 Jernee Mill Road Sayreville, NJ 08872	(877) 528-2890 Commercial (800) 882-1276 Residential www.nexteraenergyservices.com	R/C/I ACTIVE
New Jersey Gas & Electric 1 Bridge Plaza fl. 2 Fort Lee, NJ 07024	(866) 568-0290 www.NJGandE.com	R/C ACTIVE
Noble Americas Energy Solutions The Mac-Cali Building 581 Main Street, 8th Floor Woodbridge, NJ 07095	(877) 273-6772 www.noblesolutions.com	C/I ACTIVE
North American Power and Gas, LLC 222 Ridgedale Avenue Cedar Knolls, NJ 07927	(888) 313-9086 www.napower.com	R/C/I ACTIVE
Palmco Power NJ, LLC One Greentree Centre 10,000 Lincoln Drive East, Suite 201 Marlton, NJ 08053	(877) 726-5862 www.PalmcoEnergy.com	R/C/I ACTIVE
Pepco Energy Services, Inc. 112 Main St. Lebanon, NJ 08833	(800) ENERGY-9 (363-7499) www.pepco-services.com	C/I ACTIVE
Plymouth Rock Energy, LLC 338 Maitland Avenue Teaneck, NJ 07666	(855) 32-POWER (76937) www.plymouthenergy.com	R/C/I ACTIVE

PPL Energy Plus, LLC 811 Church Road Cherry Hill, NJ 08002	(800) 281-2000 www.pplenergyplus.com	C/I ACTIVE
Public Power & Utility of New Jersey, LLC 39 Old Ridgebury Rd. Suite 14 Danbury, CT 06810	(888) 354-4415 www.ppandu.com	R/C/I ACTIVE
Reliant Energy 211 Carnegie Center Princeton, NJ 08540	(877) 297-3795 (877) 297-3780 www.reliant.com/pjm	R/C/I ACTIVE
ResCom Energy LLC 18C Wave Crest Ave. Winfield Park, NJ 07036	(888) 238-4041 http://rescomenergy.com	R/C/I ACTIVE
Respond Power LLC 10 Regency CT Lakewood, NJ 08701	(877) 973-7763 www.respondpower.com	R/C/I ACTIVE
South Jersey Energy Company 1 South Jersey Plaza, Route 54 Folsom, NJ 08037	(800) 266-6020 www.southjerseyenergy.com	C/I ACTIVE
Sperian Energy Corp. 1200 Route 22 East, Suite 2000 Bridgewater, NJ 08807	(888) 682-8082	R/C/I ACTIVE
S.J. Energy Partners, Inc. 208 White Horse Pike, Suite 4 Barrington, N.J. 08007	(800) 695-0666 www.sjnaturalgas.com	R/C ACTIVE
Spark Energy, L.P. 2105 CityWest Blvd., Ste 100 Houston, Texas 77042	(800) 441-7514 www.sparkenergy.com	R/C/I ACTIVE
Sprague Energy Corp. 12 Ridge Road Chatham Township, NJ 07928	(800) 225-1560 www.spragueenergy.com	C/I ACTIVE
Starion Energy PA Inc. 101 Warburton Avenue Hawthorne, NJ 07506	(800) 600-3040 www.starionenergy.com	R/C/I ACTIVE
Stream Energy 309 Fellowship Rd., Suite 200 Mt. Laurel, NJ 08054	(877) 39-8150 www.streamenergy.net	R ACTIVE

UGI Energy Services, Inc. d/b/a GASMARK 224 Strawbridge Drive Suite 107 Moorestown, NJ 08057	(856) 273-9995 www.ugienergyservices.com	C/I ACTIVE
Verde Energy USA, Inc. 50 East Palisades Avenue Englewood, NJ 07631	(800) 388-3862 www.lowcostpower.com	R/C/I ACTIVE
Viridian Energy 2001 Route 46, Waterview Plaza Suite 310 Parsippany, NJ 07054	(866) 663-2508 www.viridian.com	R/C/I ACTIVE
Xoom Energy New Jersey, LLC 744 Broad Street Newark, NJ 07102	(888) 997-8979 www.xoomenergy.com	R/C/I ACTIVE
YEP Energy 89 Headquarters Plaza North #1463 Morristown, NJ 07960	(855) 363-7736 www.yepenergyNJ.com	R/C/I ACTIVE
Your Energy Holdings, LLC One International Boulevard Suite 400 Mahwah, NJ 07495-0400	(855) 732-2493 www.thisisyourenergy.com	R/C/I ACTIVE

[Back to the main supplier page](#)

PSE&G GAS SERVICE TERRITORY
Last Updated: 10/24/12

***CUSTOMER CLASS - R – RESIDENTIAL C – COMMERCIAL I - INDUSTRIAL**

Supplier	Telephone & Web Site	*Customer Class
Ambit Northeast, LLC 103 Carnegie Center Suite 300 Princeton, NJ 08540	(877)-30-AMBIT (877) 302-6248 www.ambitenergy.com	R/C ACTIVE
Astral Energy LLC 16 Tyson Place Bergenfield, NJ 07621	888-850-1872 www.astralenergyllc.com	R/C/I ACTIVE
BBPC, LLC Great Eastern Energy 116 Village Blvd. Suite 200 Princeton, NJ 08540	888-651-4121 www.greateasternenergy.com	C/I ACTIVE
Clearview Electric Inc. d/b/a Clearview Gas 1744 Lexington Ave. Pennsauken, NJ 08110	800-746-4720 www.clearviewenergy.com	R/C ACTIVE
Colonial Energy, Inc. 83 Harding Road Wyckoff, NJ 07481	845-429-3229 www.colonialgroupinc.com	C/I ACTIVE
Commerce Energy, Inc. 7 Cedar Terrace Ramsey, NJ 07746	(888) 817-8572 www.commerceenergy.com	R ACTIVE
Compass Energy Services, Inc. 1085 Morris Avenue, Suite 150 Union, NJ 07083	866-867-8328 908-638-6605 www.compassenergy.net	C/I ACTIVE
ConocoPhillips Company 224 Strawbridge Drive, Suite 107 Moorestown, NJ 08057	800-646-4427 www.conocophillips.com	C/I ACTIVE
Consolidated Edison Energy, Inc. d/b/a Con Edison Solutions 535 State Highway 38, Suite 140 Cherry Hill, NJ 08002	888-686-1383 x2130 www.conedenergy.com	

Consolidated Edison Solutions, Inc. Cherry Tree Corporate Center 535 State Highway 38, Suite 140 Cherry Hill, NJ 08002	888-665-0955 www.conedsolutions.com	C/I ACTIVE
Constellation NewEnergy-Gas Division, LLC 900A Lake Street, Suite 2 Ramsey, NJ 07466	(800) 900-1982 www.constellation.com	C/I ACTIVE
Direct Energy Business, LLC 120 Wood Avenue, Suite 611 Iselin, NJ 08830	888-925-9115 www.directenergy.com	C/I ACTIVE
Direct Energy Services, LLP 120 Wood Avenue, Suite 611 Iselin, NJ 08830	866-348-4193 www.directenergy.com	R ACTIVE
Gateway Energy Services Corp. 44 Whispering Pines Lane Lakewood, NJ 08701	800-805-8586 www.gesc.com	R/C/I ACTIVE
UGI Energy Services, Inc. d/b/a GASMARK 224 Strawbridge Drive, Suite 107 Moorestown, NJ 08057	856-273-9995 www.ugienergyservices.com	C/I ACTIVE
Global Energy Marketing, LLC 129 Wentz Avenue Springfield, NJ 07081	800-542-0778 www.globalp.com	C/I ACTIVE
Great Eastern Energy 116 Village Blvd., Suite 200 Princeton, NJ 08540	888-651-4121 www.greateastern.com	C/I ACTIVE
Greenlight Energy 330 Hudson Street, Suite 4 Hoboken, NJ 07030	718-204-7467 www.greenlightenergy.us	C ACTIVE
Hess Energy, Inc. One Hess Plaza Woodbridge, NJ 07095	800-437-7872 www.hess.com	C/I ACTIVE
Hess Small Business Services, LLC One Hess Plaza Woodbridge, NJ 07095	888-494-4377 www.hessenergy.com	C/I ACTIVE
HIKO Energy, LLC 655 Suffern Road Teaneck, NJ 07666	(888) 264-4908 www.hikoenergy.com	R/C ACTIVE

Hudson Energy Services, LLC 7 Cedar Street Ramsey, NJ 07446	877- Hudson 9 www.hudsonenergyservices.com	C ACTIVE
IDT Energy, Inc. 550 Broad Street Newark, NJ 07102	877-887-6866 www.idtenergy.com	R/C ACTIVE
Integrus Energy Services – Natural Gas, LLC 99 Wood Avenue South Suite #802 Iselin, NJ 08830	800-536-0151 www.integrusenergy.com	C/I ACTIVE
Intelligent Energy 2050 Center Avenue, Suite 500 Fort Lee, NJ 07024	800-927-9794 www.intelligentenergy.org	R/C/I ACTIVE
Keil & Sons, Inc. d/b/a Systrum Energy 1 Bergen Blvd. Fairview, NJ 07022	1-877-797-8786 www.systrumenergy.com	R/C/I ACTIVE
Major Energy Services, LLC 10 Regency CT Lakewood, NJ 08701	888-625-6760 www.majorenergy.com	R/C/I ACTIVE
Marathon Power LLC 302 Main Street Paterson, NJ 07505	888-779-7255 www.mecny.com	R/C/I ACTIVE
Metromedia Energy, Inc. 6 Industrial Way Eatontown, NJ 07724	800-828-9427 www.metromediaenergy.com	C ACTIVE
Metro Energy Group, LLC 14 Washington Place Hackensack, NJ 07601	888-53-Metro www.metroenergy.com	R/C ACTIVE
MxEnergy, Inc. 900 Lake Street Ramsey, NJ 07446	800-758-4374 www.mxenergy.com	R/C/I ACTIVE
NATGASCO (Mitchell Supreme) 532 Freeman Street Orange, NJ 07050	800-840-4GAS www.natgasco.com	C ACTIVE
New Energy Services LLC 101 Neptune Avenue Deal, New Jersey 07723	800-660-3643 www.newenergyservicesllc.com	R/C/I ACTIVE

New Jersey Gas & Electric 1 Bridge Plaza, Fl. 2 Fort Lee, NJ 07024	866-568-0290 www.NJGandE.com	R/C ACTIVE
Noble Americas Energy Solutions The Mac-Cali Building 581 Main Street, 8th fl. Woodbridge, NJ 07095	877-273-6772 www.noblesolutions.com	C/I ACTIVE
North American Power & Gas, LLC d/b/a North American Power 197 Route 18 South Ste. 3000 East Brunswick, NJ 08816	(888) 313-9086 www.napower.com	R/C/I ACTIVE
Palmco Energy NJ, LLC One Greentree Centre 10,000 Lincoln Drive East, Suite 201 Marlton, NJ 08053	877-726-5862 www.PalmcoEnergy.com	R/C/I ACTIVE
Pepco Energy Services, Inc. 112 Main Street Lebanon, NJ 08833	800-363-7499 www.pepco-services.com	C/I ACTIVE
Plymouth Rock Energy, LLC 338 Maitland Avenue Teaneck, NJ 07666	855-32-POWER (76937) www.plymouthenergy.com	R/C/I ACTIVE
PPL EnergyPlus, LLC 811 Church Road - Office 105 Cherry Hill, NJ 08002	800-281-2000 www.pplenergyplus.com	C/I ACTIVE
Respond Power LLC 10 Regency CT Lakewood, NJ 08701	(877) 973-7763 www.respondpower.com	R/C/I ACTIVE
South Jersey Energy Company 1 South Jersey Plaza, Route 54 Folsom, NJ 08037	800-266-6020 www.southjerseyenergy.com	C/I ACTIVE
S.J. Energy Partners, Inc. 208 White Horse Pike, Suite 4 Barrington, NJ 08007	800-695-0666 www.sjnaturalgas.com	R/C ACTIVE
Spark Energy Gas, L.P. 2105 CityWest Blvd, Ste 100 Houston, Texas 77042	800-411-7514 www.sparkenergy.com	R/C/I ACTIVE
Sprague Energy Corp. 12 Ridge Road Chatham Township, NJ 07928	855-466-2842 www.spragueenergy.com	C/I ACTIVE

Stuyvesant Energy LLC 10 West Ivy Lane, Suite 4 Englewood, NJ 07631	800-640-6457 www.stuyfuel.com	C ACTIVE
Stream Energy New Jersey, LLC 309 Fellowship Road Suite 200 Mt. Laurel, NJ 08054	(973) 494-8097 www.streamenergy.net	R/C ACTIVE
Systrum Energy 1 Bergen Blvd. Fairview, NJ 07022	877-797-8786 www.systrumenergy.com	R/C/I ACTIVE
Woodruff Energy 73 Water Street Bridgeton, NJ 08302	800-557-1121 www.woodruffenergy.com	R/C/I ACTIVE
Woodruff Energy US LLC 73 Water Street, P.O. Box 777 Bridgeton, NJ 08302	856-455-1111 800-557-1121 www.woodruffenergy.com	C/I ACTIVE
Xoom Energy New Jersey, LLC 744 Broad Street Newark, NJ 07102	888-997-8979 www.xoomenergy.com	R/C/I ACTIVE
Your Energy Holdings, LLC One International Boulevard Suite 400 Mahwah, NJ 07495-0400	(855) 732-2493 www.thisisyourenergy.com	R/C/I ACTIVE

[Back to main supplier information page](#)

APPENDIX B

Equipment Inventory

Description	QTY	Manufacturer Name	Model No.	Serial No.	Equipment Type / Utility	Capacity/Size /Efficiency	Location	Areas/Equipment Served	Actual	Remaining Useful Life (years)	Other Info.
									Estimated Date Installed		
Boiler	7	RBI	33-FB1950NR2AIPS	070332524	Hot Water Boiler, Natural Gas	In: 1,950 / 571 MBH, Out: 1,657.5 / 485 MBH (85%)	Boiler Room	Heating System	2007	23	OA temp reset
DHW Heater	1	RBI	33-FB1950NR2AIPS	070332521	Domestic Hot Water Boiler, Natural Gas	In: 1,950 / 571 MBH, Out: 1,657.5 / 485 MBH (85%)	Boiler Room	Domestic Hot Water System	2007	23	Same model as Boiler, 180F
DHW Storage Tank	1	Armstrong	Unknown	L-14574	Domestic Hot Water Storage Tank	600 Gal	Boiler Room	Domestic Hot Water System	1971	-13	Reduced to 140F
AHU-1	1	McQuay	CAH006FHAC	FB0U030600637	Air Handling Unit, Hot water heat	Unknown (Custom Build)	Boiler Room	Unknown	2003	14	Inulated OA duct (Common intanke)
AHU-2	1	McQuay	CAH003FHAC	FB0U030600639	Air Handling Unit, Hot Water Heat	Unknown (Custom Build)	Boiler Room	Unknown	2003	14	Inulated OA duct (Common intanke)
UV	1/class	Unknown	U.AVV.5.613.A.Z.65.9.2 3.AK.22.G.I.B.2	E749837060	Unit Ventilator, Hot Water Heat	1/4 hp	Classroom	Classroom	1990	1	
Window AC	46	Various	Various	Various	Window Air Conditioning Unit	12,000 - 24,000 btu/h	Classroom	Classroom	2006	7	
Hot Water Pump	2	Marathon Electric	9VN 286TTDP4027EE L	Unknown	Electric Motor, Pump	30 HP, 92.4%	Boiler Room	Heating System	2000	4	
Hot Water Booster Pump	1	Bell & Gossett	QH56A17D59F	Unknown	Electric Motor, Pump	1/3HP	Boiler Room	Heating System	2000	4	
AHU-4	1	McQuay	CAH003FHAC	FB0U030600630	Air Handling Unit, Hot water heat	Unknown (Custom Build)	Penthouse	Cafeteria	2003		
AHU-5	1	McQuay	CAH003FHAC	FB0U030600636	Air Handling Unit, Hot water heat	Unknown (Custom Build)	Penthouse	Gymnasium	2003	14	
Move n' Cool AC	2	LG	LP1111WXR	104TARU07446	Portable Air Conditioner	11,000 btu/h, 9.2 EER	Classroom	Classroom	2006	7	
Fume Hood	1	Mott	7221000	20976	Fume Hood	Unknown	Science Classroom	Science Classroom	2009	10	
Generator	1	Kohler	180R0ZJ71	366625	Electric Generator / Diesel	180 kW	Boiler Room	Backup Electricity / Emerency System	2005	16	
RTU	1	Carrier	50HJ-015--591AA	5002F94239	Packaged DX Rooftop Unit	12 Tons, 10.8 EER	Roof	Unknown	2005	16	
Condensing Unit	4	Goodman	EABA-P036SG	W085625831	Split System Condensing Unit	3 Tons	Roof	Unknown	2008	14	
Reach-in cooler	1	Unknown	Unknown	Unknown	Triple door reach-in refrigerator	Unknown	Kitchen	Kitchen	2008	4	
Reach-in freezer	2	Unknown	Unknown	Unknown	double door reach in freezer	Unknown	Kitchen	Kitchen	2008	4	

Cost of Electricity:

\$0.124	\$/kWh
\$5.91	\$/kW

			EXISTING CONDITIONS								Retrofit Control	
	Area Description	Usage	No. of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/Space	Exist Control	Annual Hours	Annual kWh		
Field Code	Unique description of the location - Room number/Room name: Floor number (if applicable)	Describe Usage Type using Operating Hours	No. of fixtures before the retrofit	Lighting Fixture Code	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Fixt No.)	Pre-inst. control device	Estimated annual hours for the usage group	(kW/space) * (Annual Hours)	Retrofit control device	Notes
46LED	Kitchen	Cafeteria	45	W 28 C F 2 (ELE)	F42LL	60	2.70	SW	2000	5,400	NONE	
15LED	Storage	Storage	3	S 32 C F 2 (ELE)	F42LL	60	0.18	SW	520	94	NONE	
15LED	Loading Dock	Cafeteria	2	S 32 C F 2 (ELE)	F42LL	60	0.12	SW	2000	240	NONE	
15LED	Loading Dock Storage	Storage	1	S 32 C F 2 (ELE)	F42LL	60	0.06	SW	520	31	NONE	
185LED	Office	Offices	1	W 40 C F 4 (ELE)	F44ILL	112	0.11	SW	2600	291	NONE	
218ALED	Corridor 1st Floor	Hallways	10	W 32 C F 3 (ELE)	F46ILL	175	1.75	SW	6240	10,920	NONE	
18LED	Corridor 1st Floor	Hallways	60	T 32 R F 4 (ELE)	F44ILL	112	6.72	SW	6240	41,933	NONE	
15LED	116	Classrooms	20	S 32 C F 2 (ELE)	F42LL	60	1.20	SW	2600	3,120	C-OCC	
162	Storage	Storage	1	S 34 C F 4 (MAG)	F44EE	144	0.14	SW	520	75	NONE	
104LED	114	Classrooms	24	S 32 P F 1	F41LL	32	0.77	SW	2600	1,997	C-OCC	
104LED	117	Classrooms	27	S 32 P F 1	F41LL	32	0.86	SW	2600	2,246	C-OCC	
104LED	118	Classrooms	27	S 32 P F 1	F41LL	32	0.86	SW	2600	2,246	C-OCC	
104LED	Storage	Storage	20	S 32 P F 1	F41LL	32	0.64	SW	520	333	NONE	
104LED	Boy's Restroom	Restroom	5	S 32 P F 1	F41LL	32	0.16	SW	3120	499	C-OCC	
104LED	Girl's Restroom	Restroom	5	S 32 P F 1	F41LL	32	0.16	SW	3120	499	C-OCC	
220LED	Custodial Closet	Linen/Utility/Wet/Janitor/Electrical	1	S 17 C F 1(ELE)	F21ILL	20	0.02	SW	780	16	NONE	
104LED	112	Classrooms	30	S 32 P F 1	F41LL	32	0.96	SW	2600	2,496	C-OCC	
104LED	119	Classrooms	33	S 32 P F 1	F41LL	32	1.06	SW	2600	2,746	C-OCC	
55LED	Guidance Office	Offices	4	2T 17 R F 3 (ELE)	F23ILL	47	0.19	SW	2600	489	C-OCC	
55LED	Guidance Office - Office	Offices	4	2T 17 R F 3 (ELE)	F23ILL	47	0.19	SW	2600	489	C-OCC	
104LED	Guidance Office - Office	Offices	2	S 32 P F 1	F41LL	32	0.06	SW	2600	166	C-OCC	
104LED	Guidance Office - Office	Offices	2	S 32 P F 1	F41LL	32	0.06	SW	2600	166	C-OCC	
104LED	Guidance Office - Office	Offices	2	S 32 P F 1	F41LL	32	0.06	SW	2600	166	C-OCC	
104LED	Guidance Office - Office	Offices	2	S 32 P F 1	F41LL	32	0.06	SW	2600	166	C-OCC	
18LED	General Office	Offices	19	T 32 R F 4 (ELE)	F44ILL	112	2.13	SW	2600	5,533	C-OCC	
18LED	106	Classrooms	10	T 32 R F 4 (ELE)	F44ILL	112	1.12	SW	2600	2,912	C-OCC	
18LED	School Nurse	Offices	5	T 32 R F 4 (ELE)	F44ILL	112	0.56	SW	2600	1,456	NONE	
18LED	School Nurse - Office	Offices	3	T 32 R F 4 (ELE)	F44ILL	112	0.34	SW	2600	874	NONE	
18LED	School Nurse - Office	Offices	2	T 32 R F 4 (ELE)	F44ILL	112	0.22	SW	2600	582	NONE	
104LED	Girl's Restroom	Restroom	5	S 32 P F 1	F41LL	32	0.16	SW	3120	499	C-OCC	
104LED	Boy's RestRoom	Restroom	5	S 32 P F 1	F41LL	32	0.16	SW	3120	499	C-OCC	
220LED	Custodial Closet	Linen/Utility/Wet/Janitor/Electrical	1	S 17 C F 1(ELE)	F21ILL	20	0.02	SW	780	16	NONE	
18LED	105	Classrooms	10	T 32 R F 4 (ELE)	F44ILL	112	1.12	SW	2600	2,912	C-OCC	
104LED	Medical Office	Offices	4	S 32 P F 1	F41LL	32	0.13	SW	2600	333	NONE	
55LED	Medical Office - Waiting Room	Offices	4	2T 17 R F 3 (ELE)	F23ILL	47	0.19	SW	2600	489	NONE	
104LED	Medical Office - Conference Room	Offices	2	S 32 P F 1	F41LL	32	0.06	SW	2600	166	NONE	
104LED	Medical Office - Patient Room	Offices	6	S 32 P F 1	F41LL	32	0.19	SW	2600	499	NONE	
15LED	Restroom	Restroom	1	S 32 C F 2 (ELE)	F42LL	60	0.06	SW	3120	187	C-OCC	
18LED	103	Classrooms	12	T 32 R F 4 (ELE)	F44ILL	112	1.34	SW	2600	3,494	C-OCC	
104LED	Men's Restroom	Restroom	5	S 32 P F 1	F41LL	32	0.16	SW	3120	499	C-OCC	
104LED	Women's Restroom	Restroom	5	S 32 P F 1	F41LL	32	0.16	SW	3120	499	C-OCC	
18LED	103B	Classrooms	10	T 32 R F 4 (ELE)	F44ILL	112	1.12	SW	2600	2,912	C-OCC	
104LED	104	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC	
146LED	Gymnasium	Gymnasium	24	High Bay MH 400	MH400/1	458	10.99	SW	2600	28,579	C-OCC	
104LED	Boy's Locker Room	Locker	26	S 32 P F 1	F41LL	32	0.83	SW	2600	2,163	C-OCC	
104LED	Boy's Locker Room Restroom	Restroom	2	S 32 P F 1	F41LL	32	0.06	SW	3120	200	NONE	
104LED	Coach's Office	Offices	4	S 32 P F 1	F41LL	32	0.13	SW	2600	333	C-OCC	
104LED	Girl's Locker Room	Locker	26	S 32 P F 1	F41LL	32	0.83	SW	2600	2,163	C-OCC	
104LED	Girls's Locker Room Restroom	Restroom	2	S 32 P F 1	F41LL	32	0.06	SW	3120	200	NONE	
104LED	Bard Main Office	Offices	36	S 32 P F 1	F41LL	32	1.15	SW	2600	2,995	C-OCC	
18LED	Bard Main Office - Office	Offices	2	T 32 R F 4 (ELE)	F44ILL	112	0.22	SW	2600	582	C-OCC	
104LED	Bard Main Office - Office	Offices	2	S 32 P F 1	F41LL	32	0.06	SW	2600	166	C-OCC	
104LED	107	Classrooms	30	S 32 P F 1	F41LL	32	0.96	SW	2600	2,496	C-OCC	
104LED	111	Classrooms	26	S 32 P F 1	F41LL	32	0.83	SW	2600	2,163	C-OCC	
18LED	Corridor 2nd Floor	Hallways	35	T 32 R F 4 (ELE)	F44ILL	112	3.92	SW	6240	24,461	NONE	
104LED	223	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC	
104LED	225	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC	
104LED	224	Classrooms	9	S 32 P F 1	F41LL	32	0.29	SW	2600	749	C-OCC	
104LED	226	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC	
18LED	222 - Library	Classrooms	45	T 32 R F 4 (ELE)	F44ILL	112	5.04	SW	2600	13,104	C-OCC	
104LED	227	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC	
104LED	228	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC	
104LED	229	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC	
104LED	230	Classrooms	21	S 32 P F 1	F41LL	32	0.67	SW	2600	1,747	C-OCC	
104LED	231	Classrooms	21	S 32 P F 1	F41LL	32	0.67	SW	2600	1,747	C-OCC	
45	Cafeteria	Cafeteria	8	SP 26 R CF 1	CFQ26/1-L	27	0.22	SW	2000	432	C-OCC	
20LED	Cafeteria	Cafeteria	2	S 32 C F 1 (ELE)	F41LL	32	0.06	SW	2000	128	C-OCC	
9LED	Cafeteria	Cafeteria	18	High Bay MH 200 35 Feet High	MH250/1	295	5.31	SW	2000	10,620	C-OCC	
218ALED	Cafeteria	Cafeteria	8	W 32 C F 3 (ELE)	F46ILL	175	1.40	SW	2000	2,800	C-OCC	
35LED	Cafeteria	Cafeteria	8	T 32 R F 3 (ELE)	F43SSILL	72	0.58	SW	2000	1,152	C-OCC	
232	Multi-Purpose Room	Gymnasium	34	R 60 C 1 1	I60/1	60	2.04	SW	2600	5,304	C-OCC	

Cost of Electricity:

\$0.124	\$/kWh
\$5.91	\$/kW

EXISTING CONDITIONS												Retrofit Control	Notes
Field Code	Area Description	Usage	No. of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/Space	Exist Control	Annual Hours	Annual kWh		Retrofit control device	
	Unique description of the location - Room number/Room name: Floor number (if applicable)	Describe Usage Type using Operating Hours	No. of fixtures before the retrofit	Lighting Fixture Code	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Fixt No.)	Pre-inst. control device	Estimated annual hours for the usage group	(kW/space) * (Annual Hours)			
104LED	206	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	207	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	208	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	209	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	210	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	211	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	212	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	214	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	213	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	215	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	216	Classrooms	9	S 32 P F 1	F41LL	32	0.29	SW	2600	749	C-OCC		
104LED	204	Classrooms	20	S 32 P F 1	F41LL	32	0.64	SW	2600	1,664	C-OCC		
104LED	205	Classrooms	20	S 32 P F 1	F41LL	32	0.64	SW	2600	1,664	C-OCC		
104LED	203	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	202	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	201	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	233	Classrooms	27	S 32 P F 1	F41LL	32	0.86	SW	2600	2,246	C-OCC		
104LED	232	Classrooms	30	S 32 P F 1	F41LL	32	0.96	SW	2600	2,496	C-OCC		
104LED	220	Classrooms	34	S 32 P F 1	F41LL	32	1.09	SW	2600	2,829	C-OCC		
104LED	219	Classrooms	27	S 32 P F 1	F41LL	32	0.86	SW	2600	2,246	C-OCC		
104LED	218	Classrooms	36	S 32 P F 1	F41LL	32	1.15	SW	2600	2,995	C-OCC		
104LED	217 - Faculty Lounge	Staff Lounge	6	S 32 P F 1	F41LL	32	0.19	SW	2600	499	C-OCC		
104LED	UN-89	Storage	4	S 32 P F 1	F41LL	32	0.13	SW	520	67	NONE		
104LED	UN-90	Storage	4	S 32 P F 1	F41LL	32	0.13	SW	520	67	NONE		
104LED	UN-81	Storage	5	S 32 P F 1	F41LL	32	0.16	SW	520	83	NONE		
104LED	UN-80	Storage	5	S 32 P F 1	F41LL	32	0.16	SW	520	83	NONE		
104LED	UN-83	Storage	2	S 32 P F 1	F41LL	32	0.06	SW	520	33	NONE		
104LED	UN-84	Storage	2	S 32 P F 1	F41LL	32	0.06	SW	520	33	NONE		
104LED	UN-85	Storage	2	S 32 P F 1	F41LL	32	0.06	SW	520	33	NONE		
104LED	UN-86	Storage	2	S 32 P F 1	F41LL	32	0.06	SW	520	33	NONE		
104LED	UN-91	Storage	1	S 32 P F 1	F41LL	32	0.03	SW	520	17	NONE		
104LED	UN-97 - Vice Principal Office	Offices	9	S 32 P F 1	F41LL	32	0.29	SW	2600	749	C-OCC		
104LED	306	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
15LED	307	Classrooms	15	S 32 C F 2 (ELE)	F42LL	60	0.90	SW	2600	2,340	C-OCC		
104LED	308	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
218LED	309	Classrooms	9	W 32 C F 3 (ELE)	F43ILL/2	90	0.81	SW	2600	2,106	C-OCC		
218LED	310	Classrooms	9	W 32 C F 3 (ELE)	F43ILL/2	90	0.81	SW	2600	2,106	C-OCC		
5LED	311 - Principal's Office	Offices	2	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.12	SW	2600	312	C-OCC		
218LED	312	Classrooms	13	W 32 C F 3 (ELE)	F43ILL/2	90	1.17	SW	2600	3,042	C-OCC		
5LED	312	Classrooms	2	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.12	SW	2600	312	C-OCC		
104LED	313	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	314	Classrooms	33	S 32 P F 1	F41LL	32	1.06	SW	2600	2,746	C-OCC		
104LED	315	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
218LED	316 - Faculty Lounge	Staff Lounge	9	W 32 C F 3 (ELE)	F43ILL/2	90	0.81	SW	2600	2,106	C-OCC		
15LED	304	Classrooms	18	S 32 C F 2 (ELE)	F42LL	60	1.08	SW	2600	2,808	C-OCC		
104LED	305	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	UN-105	Storage	1	S 32 P F 1	F41LL	32	0.03	SW	520	17	NONE		
104LED	UN-103	Storage	4	S 32 P F 1	F41LL	32	0.13	SW	520	67	NONE		
104LED	UN-104	Storage	4	S 32 P F 1	F41LL	32	0.13	SW	520	67	NONE		
104LED	301	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	302	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	303	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	317	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	318	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	319	Classrooms	30	S 32 P F 1	F41LL	32	0.96	SW	2600	2,496	C-OCC		
104LED	320	Classrooms	36	S 32 P F 1	F41LL	32	1.15	SW	2600	2,995	C-OCC		
104LED	321	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	335	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	336	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	337	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	338	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
18LED	Corridor 3rd Floor	Hallways	50	T 32 R F 4 (ELE)	F44ILL	112	5.60	SW	6240	34,944	NONE		
104LED	322	Classrooms	16	S 32 P F 1	F41LL	32	0.51	SW	2600	1,331	C-OCC		
104LED	323	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	324	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	325	Classrooms	36	S 32 P F 1	F41LL	32	1.15	SW	2600	2,995	C-OCC		
104LED	326	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	327 - Office	Offices	9	S 32 P F 1	F41LL	32	0.29	SW	2600	749	C-OCC		
104LED	328	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	329	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		
104LED	330	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC		

Cost of Electricity:

\$0.124	\$/kWh
\$5.91	\$/kW

			EXISTING CONDITIONS								Retrofit Control	
	Area Description	Usage	No. of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/Space	Exist Control	Annual Hours	Annual kWh		
Field Code	Unique description of the location - Room number/Room name: Floor number (if applicable)	Describe Usage Type using Operating Hours	No. of fixtures before the retrofit	Lighting Fixture Code	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Fixt No.)	Pre-inst. control device	Estimated annual hours for the usage group	(kW/space) * (Annual Hours)	Retrofit control device	Notes
104LED	331	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC	
104LED	332	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC	
104LED	333	Classrooms	20	S 32 P F 1	F41LL	32	0.64	SW	2600	1,664	C-OCC	
104LED	334	Classrooms	15	S 32 P F 1	F41LL	32	0.48	SW	2600	1,248	C-OCC	
185LED	UN-109	Storage	2	W 40 C F 4 (ELE)	F44ILL	112	0.22	SW	520	116	NONE	
185LED	UN-110	Storage	2	W 40 C F 4 (ELE)	F44ILL	112	0.22	SW	520	116	NONE	
	Total		2,054				111.57			344,405		

APPENDIX C

ECM Calculations

Newark Public Schools
CHA Project Number: 27998

Rate of Discount (used for NPV) 3.0%

Utility Costs		Yearly Usage	Metric Conversion Domestic Equipment	Building Area		Annual Utility Cost		
\$	0.139	\$/kWh blended	0.000420205	153,163	Electric	Natural Gas	Fuel Oil	
\$	0.124	\$/kWh supply	1,114,500	0.000420205	\$	154,398	\$	87,519
\$	5.91	\$/kW	366.0					
\$	0.93	\$/Therm	84,362	0.00533471				
\$	7.55	\$/kgals	1,000					
\$	-	\$/Gal	-					

Bard Early College High School																							
Recommend?		Item	Savings					Cost	Simple Payback	Life Expectancy	Equivalent CO ₂ (Metric tons)	NJ Smart Start Incentives	Direct Install Eligible (Y/N)	Payback w/ Incentives	Simple Projected Lifetime Savings					ROI	NPV	IRR	
Y or N			kW	kWh	therms	No. 2 Oil gal	Water kgal	\$							kW	kWh	therms	kgal/yr	\$				
Y	ECM-1	Replace Hot Water Boilers w/ Condensing Hot Water Boilers	0.0	0	3,842	0	0	3,573	\$ 220,697	61.8	25	20.5	N	61.8	0.0	0	96,041	0	\$ 89,318	(0.6)	(\$158,485)	-6.0%	
Y	ECM-2	Install Premium Efficiency Motors	0.0	1,334	0	0	0	185	\$ 4,811	25.9	18	0.6	N	25.9	0.0	24,015	0	0	\$ 3,338	(0.3)	(\$2,260)	-3.6%	
Y	ECM-3	Install Window AC Controllers	0.0	37,024	0	0	0	5,146	\$ 8,900	1.7	10	15.6	N	1.7	0.0	370,237	0	0	\$ 51,463	4.8	\$34,999	57.2%	
Y	ECM-4	Install DDC Controls	0.0	0	18,179	0	0	16,906	\$ 392,179	23.2	15	97.0	N	23.2	0.0	0	272,680	0	\$ 253,593	(0.4)	(\$190,354)	-5.0%	
Y	ECM-5	Domestic Hot Water System Improvements	0.0	0	1,539	0	0	1,431	\$ 35,796	25.0	25	8.2	N	25.0	0.0	0	38,467	0	\$ 35,774	(0.0)	(\$10,878)	0.0%	
Y	ECM-6	Install Vending Machine Controls	0.0	8,858	0	0	0	1,231	\$ 840	0.7	10	3.7	N	0.7	0.0	88,583	0	0	\$ 12,313	13.7	\$9,663	146.5%	
N	ECM-7	Install Low Flow Plumbing Fixtures	0.0	0	0	0	387	2,919	\$ 273,566	93.7	30	0.0	N	93.7	0.0	0	0	11,600	\$ 87,584	(0.7)	(\$216,343)	-6.2%	
N	ECM-L1	Lighting Replacements / Upgrades	64.1	197,653	0	0	0	29,057	\$ 268,898	9.3	10	83.1	\$ 2,600	N	9.2	641.0	1,976,530	0	0	\$ 320,197	0.2	(\$18,436)	1.6%
N	ECM-L2	Install Lighting Controls (Add Occupancy Sensors)	0.0	65,453	0	0	0	8,116	\$ 30,240	3.7	10	27.5	\$ 3,920	N	3.2	0.0	654,530	0	0	\$ 90,980	2.0	\$42,913	28.3%
Y	ECM-L3	Lighting Replacements with Controls (Occupancy Sensors)	64.1	225,733	0	0	0	32,539	\$ 299,138	9.2	10	94.9	\$ 6,520	N	9.0	641.0	2,257,330	0	0	\$ 359,229	0.2	(\$15,054)	2.0%
Total (Not Including [B] Option ECMs or L1, L2)			64.1	272,949	23,559	0	387	\$ 63,931	\$ 1,235,926	19.3	17.9	240	\$ 6,520		19.2	641	2,740,165	407,187	11,600	\$ 892,611	(0.3)	(\$387,679)	-1.3%
Recommended Measures (highlighted green above)			64.1	272,949	23,559	0	0	\$ 61,012	\$ 962,360	15.8	16.1	240	\$ 6,520	0	15.7	641	2,740,165	407,187	-	\$ 805,027	(0.2)	(\$189,464)	0.2%
% of Existing			18%	24%	25%	0%	0%																

		City: Newark, NJ					
		Occupied Hours/Week					
		70	70	70	70	50	
		Building	Auditorium	Gymnasium	Library	Classrooms	
Temp	Enthalpy h (Btu/lb)	Operating Hours	Occupied Hours	Occupied Hours	Occupied Hours	Occupied Hours	
102.5							
97.5	35.4	6	3	3	3	2	
92.5	37.4	31	13	13	13	9	
87.5	39.0	131	35	35	35	38	
82.5	33.0	560	208	208	208	149	
77.5	31.5	620	258	258	258	185	
72.5	29.9	664	277	277	277	198	
67.5	27.2	654	356	356	356	254	
62.5	24.0	927	386	386	386	276	
57.5	20.3	600	250	250	250	179	
52.5	18.2	730	304	304	304	217	
47.5	16.0	491	205	205	205	148	
42.5	14.5	656	273	273	273	195	
37.5	12.5	1,023	426	426	426	304	
32.5	10.5	734	306	306	306	218	
27.5	8.7	324	139	139	139	99	
22.5	7.0	252	105	105	105	75	
17.5	5.4	125	52	52	52	37	
12.5	3.7	47	20	20	20	14	
7.5	2.1	34	14	14	14	10	
2.5	1.3	1	0	0	0	0	
-2.5							
-7.5							

Multipliers	
Material:	1.007
Labor:	1.245
Equipment:	1.124

Heating System Efficiency	80%
Cooling Eff (kW/ton)	1.2



Heating	
Hours	4,427 Hrs
Weighted Avg	40 F
Avg	28 F
Cooling	
Hours	4,333 Hrs
Weighted Avg	68 F
Avg	28 F

Newark Public Schools
 CHA Project Number: 27998
 Bard Early College High School

Utility End Use Analysis		
Electricity Use (kWh):		Notes/Comments:
1,114,500	Total	Based on utility analysis
344,405	Lighting	From Lighting Calculations
93,053	Motors	Estimated
71,930	A/C	See Window AC Calculation
184,408	Plug Load	Estimated
87,071	Kitchen	Estimated
160,105	Computers	Estimated
173,528	Other	Remaining
Natural Gas Use (Therms):		Notes/Comments:
94,362	Total	Based on utility analysis
89,644	Boilers	Therms/SF x Square Feet Served
4,718	DHW	Based on utility analysis

31%
 8%
 6%
 17%
 8%
 14%
 16%

95%
 5%



Newark Public Schools
CHA Project Number: 27998
Bard Early College High School

ECM-1: Boiler Replacement

Description: This ECM evaluates the replacement of two how water boilers with two high efficiency condensing gas boilers. The existing boiler efficiency is 85% and the proposed boiler efficiency is 96% (Assumed to operate only in condensing mode). Electrical power consumption due to pumps is considered to be the same for both the proposed system and the baseline system.

Item	Value	Units	Formula/Comments
Baseline Fuel Cost	\$ 0.93	/ Therm	Natural Gas
Baseline Fuel Cost		/ Gal	No. 2 Oil
FORMULA CONSTANTS			
Oversize Factor	0.8		
Hours per Day	24		
Design Outdoor Temp	14	F	
Infrared Conversion Factor	1.0		1.0 if Boiler, 0.8 if Infrared Heater
EXISTING			
Capacity	4,000,000	btu/hr	Average
Heating Combustion Efficiency	85%		From Futura data plate
Heating Degree-Day	2,783	Degree-day	
Design Temperature Difference	75	F	
Fuel Conversion	100,000	btu/therm	
PROPOSED			
Capacity	4,000,000	btu/hr	
Efficiency	96%		100% Operation in condensing mode
SAVINGS			
Fuel Savings	3,842	Therms	NJ Protocols Calculation
Fuel Cost Savings	\$ 3,573		

Savings calculation formulas are taken from NJ Protocols document for Occupancy Controlled Thermostats

Algorithms

Gas Savings (Therms)

$$= \frac{OF \times ((CAPY_{Bl} \times EFF_Q) - (CAPY_{Qi} \times EFF_B \times ICF)) \times HDD_{mod} \times 24}{\Delta T \times HC_{fuel} \times EFF_B \times ICF \times EFF_Q}$$

Definition of Variables

OF = Oversize factor of standard boiler or furnace (OF=0.8)

CAPY_{Bi} = Total input capacity of the baseline furnace, boiler or heater in Btu/hour

CAPY_{Qi} = Total input capacity of the qualifying furnace, boiler or heater in Btu/hour

HDD_{mod} = HDD by zone and building type

24 = Hours/Day

ΔT = design temperature difference

HC_{fuel} = Conversion from Btu to therms of gas or gallons of oil or propane (100,000 btu/therm; 138,700 btu/gal of #2 oil; 92,000 btu/gal of propane)

EFF_Q = Efficiency of qualifying heater(s) (AFUE %)

EFF_B = Efficiency of baseline heaters (AFUE %)

ICF = Infrared Compensation Factor (ICF = 0.8 for IR Heaters, 1.0 for furnaces/boilers)²

Furnaces and Boilers

Component	Type	Value	Source
$AFUE_q$	Variable		Application
$AFUE_b$	Fixed	Furnaces: 78% Boilers: 80% Infrared: 78%	EPACT Standard for furnaces and boilers
$CAPY_{in}$	Variable		Application
ΔT	Variable	See Table Below	1
HDD_{mod}	Fixed	See Table Below	1

Sources:

1. KEMA, *Smartstart Program Protocol Review*. 2009.
2. http://www.spaceray.com/1_space-ray_faqs.php

Adjusted Heating Degree Days by Building Type

Building Type	Heating Energy Density (kBtu/sf)	Degree Day Adjustment Factor	Atlantic City (HDD)	Newark (HDD)	Philadelphia (HDD)	Monticello (HDD)
Education	29.5	0.55	2792	2783	2655	3886
Food Sales	35.6	0.66	3369	3359	3204	4689
Food Service	39.0	0.73	3691	3680	3510	5137
Health Care	53.6	1.00	5073	5057	4824	7060
Lodging	15.0	0.28	1420	1415	1350	1976
Retail	29.3	0.55	2773	2764	2637	3859
Office	28.1	0.52	2660	2651	2529	3701
Public Assembly	33.8	0.63	3199	3189	3042	4452
Public Order/Safety	24.1	0.45	2281	2274	2169	3174
Religious Worship	29.1	0.54	2754	2745	2619	3833
Service	47.8	0.89	4524	4510	4302	6296
Warehouse/Storage	20.2	0.38	1912	1906	1818	2661

Heating Degree Days and Outdoor Design Temperature by Zone

Weather Station	HDD	Outdoor Design Temperature (F)
Atlantic City	5073	13
Newark	5057	14
Philadelphia, PA	4824	15
Monticello, NY	7060	8

Newark Public Schools
 CHA Project Number: 27998
 Bard Early College High School

ECM-1: Boiler Replacement - Cost

Multipliers	
Material:	1.03
Labor:	1.25
Equipment:	1.12

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
Aerco BMK2.0 w/ condensate neutralizer	2	EA	\$ 32,000	\$ 8,000	\$ -	\$ 65,728	\$ 19,936	\$ -	\$ 85,664	Vendor Estimate
Primary pumps	2	EA	\$3,000.0	\$1,500.00		\$ 6,162	\$ 3,738	\$ -	\$ 9,900	RS Means 2012
Flue Installation	200	LF	\$ 150.0	\$ 50.00		\$ 30,810	\$ 12,460	\$ -	\$ 43,270	RS Means 2012
Controls	1	EA	\$2,500.0	\$2,500.00		\$ 2,568	\$ 3,115	\$ -	\$ 5,683	RS Means 2012
Miscellaneous Electrical	2	LS	\$ 1,500	\$ 2,500		\$ 3,081	\$ 6,230	\$ -	\$ 9,311	RS Means 2012
Miscellaneous HW Piping	2	LS	\$ 5,000	\$ 5,000		\$ 10,270	\$ 12,460	\$ -	\$ 22,730	RS Means 2012
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

\$ 176,558	Subtotal
\$ 44,139	25% Contingency
\$ 220,697	Total

Newark Public Schools
CHA Project Number: 27998
Bard Early College High School

ECM-2: Install Premium Efficiency Motors

Description: This ECM evaluates the electrical savings associated with replacing less efficient electric motors with NEMA standard MG-1 rated motors

Savings Analysis

Demand
Cost
\$/kW-month
\$ - 5.91

Energy
Cost
\$/kWh
\$ - 0.12

Multipliers		
Material	Labor	Equipment
1.03	1.25	1.12

Cost Estimates

			Existing	Load	Coincidence	IF _{red}		Existing	New	ΔkW	Demand	Demand	Annual	kWh	\$ kWh	Total \$	Estimated	Payback								
#	Description	Location	HP	Factor	Factor	Y/N	Factor	Efficiency _a	Efficiency _a	kW	Savings	Savings \$	Hours	Savings	Savings	Savings	Cost	Years	Unit Costs			Subtotal Costs				
																			Materials	Labor	Equipment	Materials	Labor	Equipment	Total Cost	Remarks
1	HW Pump-1		30	0.75	0.74	N	1.0	92.4%	94.1%	0.4	0.324	\$ 23	2,033	667	\$ 83	\$ 106	\$ 2,406	22.8								
2	HW Pump-2		30	0.75	0.74	N	1.0	92.4%	94.1%	0.4	0.324	\$ 23	2,033	667	\$ 83	\$ 106	\$ 2,406	22.8								
	Total		60							0.9	0.65	\$ 46			1,334	\$ 165	\$ 211	\$ 4,811								

- Notes
- a Existing and new efficiencies should be entered if known. If not known, use provided curve fit based on "DOE Survey Installed Average" and NEMA Premium values, respectively.
 - b Same as existing HP unless resized to better match load

Newark Public Schools
CHA Project Number: 27998
Bard Early College High School

EQUIPMENT	AREA/EQUIPMENT SERVED	COOLING CAPACITY (btu/h)
Window A/C 46	Classrooms and Offices	828,000

Total btu/h of all window A/C Units: 828,000 btu/h

ECM-3: Window A/C Controller

ECM Description : Window A/C units are currently controlled manually by the occupants and are not turned off when the room is unoccupied. This ECM evaluates implementation of a digital timer device that will automatically turn the window A/C unit off at a preset time .

ASSUMPTIONS		Comments
Electric Cost	\$0.139 / kWh	
Average run hours per Week	80 Hours	
Space Balance Point	55 F	
Space Temperature Setpoint	72 deg F	Setpoint.
BTU/Hr Rating of existing DX equipment	828,000 Btu / Hr	Total BTU/hr of A/C units
Average EER	10.7	
Existing Annual Electric Usage	71,930 kWh	

Item	Value	Units	Comments
Proposed Annual Electric Usage	34,906	kWh	Unit will cycle on w/ temp of room. Possible operating time shown below

ANNUAL SAVINGS	
Annual Electrical Usage Savings	37,024 kWh
Annual Cost Savings	\$5,146
Total Project Cost	\$8,900
Simple Payback	2 years

OAT - DB Bin Temp F	Annual Hours	Existing Hours of Operation	Proposed % of time of operation	Proposed hrs of Operation
102.5	0	0	100%	0
97.5	6	3	89%	3
92.5	31	15	79%	12
87.5	131	62	68%	43
82.5	500	238	58%	138
77.5	620	295	47%	140
72.5	664	316	37%	116
67.5	854	0	0%	0
62.5	927	0	0%	0
57.5	600	0	0%	0
52.5	730	0	0%	0
47.5	491	0	0%	0
42.5	656	0	0%	0
37.5	1,023	0	0%	0
32.5	734	0	0%	0
27.5	334	0	0%	0
22.5	252	0	0%	0
17.5	125	0	0%	0
12.5	47	0	0%	0
7.5	34	0	0%	0
2.5	1	0	0%	0
-2.5	0	0	0%	0
-7.5	0	0	0%	0
Total	8,760	930	49%	451

Newark Public Schools
CHA Project Number: 27998
Bard Early College High School

ECM-3: Window A/C Controller - Cost

Multipliers	
Material:	1.03
Labor:	1.25
Equipment:	1.12

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
						0	\$ -	\$ -	\$ -	
Window AC Controller	46	EA	\$ 150	\$ -	\$ -	7086.3	\$ -	\$ -	\$ 7,086	Estimated
						\$ -	\$ -	\$ -	\$ -	

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

\$ 7,086	Subtotal
\$ 1,772	25% Contingency
\$ 8,900	Total

Newark Public Schools
CHA Project Number: 27998
Bard Early College High School

ECM-4: Install Full DDC Controls

Description: This ECM evaluates the energy savings associated with implementing a full wireless direct digital control system that enable remote automatic control, monitoring and alarming of all HVAC equipment. Specific energy savings sequences would include optimum Start/ Stop, night setback, temporary occupied set back, economizer control of UVs and AHU's. This energy savings percentage is based on past performance of similar buildings which have a fully functioning DDC control system.

Building Information:

153,163	Sq Footage	\$0.14	\$/kWh Blended
N	Cooling	\$0.93	\$/Therm
Y	Heating		

FULL DDC - TEMPERATURE SETBACK SAVINGS CALCULATION

EXISTING CONDITIONS		
Heating		
Heating Season Facility Temp	80	F
Weekly Occupied Hours	80	hrs
Heating Season Setback Temp	75	F
Heating Season % Savings per Degree Setback	3%	
Annual Boiler Capacity	-	Mbtu/yr
Connected Heating Load Capacity	4,000,000	Btu/hr
Equivalent Full Load Heating Hours	900	hrs
Heating System Efficiency	65%	
Cooling		
Cooling Season Facility Temp		F
Weekly Occupied Hours		hrs
Cooling Season Setback Temp		F
Cooling Season % Savings per Degree Setback		
Connected Cooling Load Capacity		Tons
Equivalent Full Load Cooling Hours		hrs
Cooling Equipment EER	-	
No Significant Cooling		
SAVINGS		
Natural Gas Savings	4,104	Therms
Cooling Electricity Savings	0	kWh

FULL DDC - ADDITIONAL CONTROLS SAVINGS CALCULATION

EXISTING CONDITIONS		
Existing Facility Total Electric usage	1,114,500	kWh
Existing Facility Total Gas usage	94,362	Therms
Existing Facility Cooling Electric usage	-	kWh ¹
Existing Facility Heating Natural Gas usage	89,644	Therms ²
PROPOSED CONDITIONS		
Proposed Facility Cooling Electric Savings	0	kWh
Proposed Facility Natural Gas Savings	8,964	Therms
SAVINGS		
Electric Savings	0	kWh
Natural Gas Savings	8,964	Therms

Assumptions

- 0% of facility total electricity dedicated to Cooling; based on utility information
- 95% of facility total natural gas dedicated to Heating; based on utility information
- 10% Typical Savings associated with installation of DDC controls

Nighttime Setback

EXISTING CONDITIONS		
Heating		
Heating Season Facility Temp	80	F
Weekly Occupied Hours	70	hrs
Heating Season Setback Temp	70	F
Heating Season % Savings per Degree Setback	3%	
Annual Boiler Capacity	-	Mbtu/yr
Connected Heating Load Capacity	4,000,000	Btu/hr
Equivalent Full Load Heating Hours	500	hrs
Heating Equipment Efficiency	65%	
Cooling		
Cooling Season Facility Temp	-	F
Weekly Occupied Hours	-	hrs
Cooling Season Setback Temp	-	F
Cooling Season % Savings per Degree Setback	-	
Connected Cooling Load Capacity	-	Tons
Equivalent Full Load Cooling Hours	-	hrs
Cooling Equipment EER	-	
No Significant Cooling in Bldg		
SAVINGS		
Natural Gas Savings	5,110	Therms ³
Cooling Electricity Savings	0	kWh

COMBINED SAVINGS

Natural Gas Savings	18,179	Therms
Cooling Electricity Savings	0	kWh
Total Cost Savings	\$ 16,906	
Estimated total Project Cost	\$ 392,179	
Simple Payback	23.2	Yrs

Savings calculation formulas for setback are taken from NJ Protocols document for Occupancy Controlled Thermostats
Savings calculations for additional controls are estimated based on the level of control to be added and prior experience

Newark Public Schools
 CHA Project Number: 27998
 Bard Early College High School

Multipliers	
Material:	1.03
Labor:	1.25
Equipment:	1.00

ECM-4: Install Full DDC Controls - Cost

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
						\$ -	\$ -	\$ -	\$ -	
Unit Ventilator Controls	50	ea		\$ 4,000		\$ -	\$ 249,200	\$ -	\$ 249,200	Vendor Quote
Radiator Control (Group of 4)	0	ea		\$ 4,500		\$ -	\$ -	\$ -	\$ -	Vendor Quote
Exhaust Fan Control (Group of 4)	6	ea		\$ 3,300		\$ -	\$ 24,671	\$ -	\$ 24,671	Vendor Quote
Head End Controller & Programming	1	ls		\$ 32,000		\$ -	\$ 39,872	\$ -	\$ 39,872	Vendor Quote
New Unit Ventilator	0	ea	\$ 5,000	\$ 4,000		\$ -	\$ -	\$ -	\$ -	Engineering Estimate
New Exhaust Fan	0	ea	\$ 1,525	\$ 239		\$ -	\$ -	\$ -	\$ -	RS Means 2012
New Radiator	0	lf	\$ 43	\$ 21		\$ -	\$ -	\$ -	\$ -	RS Means 2012
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

\$ 313,743	Subtotal
\$ 78,436	25% Contingency
\$ 392,179	Total

Newark Public Schools
CHA Project Number: 27998
Bard Early College High School

ECM-5: Replace Gas-Fired DHW Heater w/ High Efficiency Condensing Gas-Fired DHW Heater

Description: This ECM evaluates the energy savings associated with replacing a gas fired tank type water heater with an equivalent capacity condensing tank type water heater.

Item	Value	Units	Formula/Comments
Avg. Monthly Utility Demand by Water Heater	393	Therms/month	Calculated from utility bill
Total Annual Utility Demand by Water Heater	471,810	MBTU/yr	1therm = 100 MBTU
Existing DHW Heater Efficiency	85%		Per manufacturer nameplate
Total Annual Hot Water Demand (w/ standby losses)	401,039	MBTU/yr	
Existing Tank Size	750	Gallons	Per manufacturer nameplate
Hot Water Piping System Capacity	5	Gallons	Estimated Per existing system (includes HWR piping)
Hot Water Temperature	160	°F	Per building personnel
Room Temperature	72	°F	
Standby Losses (% by Volume)	2.5%		(2.5% of stored capacity per hour, per U.S. Department of Energy)
Standby Losses (Heat Loss)	13.8	MBH	
Annual Standby Hot Water Load	121,253	MBTU/yr	
New Tank Size	200	Gallons	
Hot Water Piping System Capacity	5	Gallons	Estimated Per existing system (includes HWR piping)
Hot Water Temperature	140	°F	
Room Temperature	72	°F	
Standby Losses (% by Volume)	2.5%		(2.5% of stored capacity per hour, per U.S. Department of Energy)
Standby Losses (Heat Loss)	2.9	MBH	
Annual Standby Hot Water Load	25,441	MBTU/yr	
Total Annual Hot Water Demand	305,226	MBTU/yr	
Proposed Avg. Hot water heater efficiency	96%		AO Smith Cyclone
Proposed Fuel Use	3,179	Therms	Standby Losses and inefficient DHW heater eliminated
Utility Cost	\$0.93	\$/Therm	
Existing Operating Cost of DHW	\$4,388	\$/yr	
Proposed Operating Cost of DHW	\$2,957	\$/yr	

Savings Summary:

Utility	Energy Savings	Cost Savings
Therms/yr	1,539	\$1,431

Newark Public Schools

CHA Project Number: 27998

Bard Early College High School

ECM-5 Cost

Multipliers	
Material:	1.03
Labor:	1.25
Equipment:	1.12

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
Gas-Fired DHW Heater Removal	1	LS		\$ 50		\$ -	\$ 62	\$ -	\$ 62	RS Means 2012
High Efficiency Gas-Fired DHW Heater	2	EA	\$ 5,500	\$ 4,500		\$ 11,297	\$ 11,214	\$ -	\$ 22,511	RS Means 2012
Miscellaneous Electrical	2	LS	\$ 300	\$ 500		\$ 616	\$ 1,246	\$ -	\$ 1,862	RS Means 2012
Venting Kit	2	EA	\$ 450	\$ 650		\$ 924	\$ 1,620	\$ -	\$ 2,544	RS Means 2012
Miscellaneous Piping and Valves	2	LS	\$ 200	\$ 500		\$ 411	\$ 1,246	\$ -	\$ 1,657	RS Means 2012

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

\$ 28,636	Subtotal
\$ 7,159	25% Contingency
\$ 35,796	Total

Newark Public Schools
CHA Project Number: 27998
Bard Early College High School

ECM-6: Install Vending Machine Controls

Description : Vending machines generally operate 24/7 regardless of the actual usage. This measure proposes installing vending machine controls to reduce the total run time of these units. Cold beverage machines will cycle on for 15 minutes every two hours in order to keep beverages at a desired temperature. The result is a reduction in total electrical energy usage.

Unit Cost: \$0.139 \$/kWh blended

Energy Savings Calculations:

Existing	
Cold Beverage Vending Machine Electric usage	10,512 kWh ^{1,4,7}
Snack Vending Machine Electric usage	- kWh ^{2,5,7}
Dual Vending Machine Electric Usage	- kWh ^{3,6,7}
Total Vending Machine Electric Usage	10,512 kWh

Proposed	
Cold Beverage Vending Machine Electric usage	1,654 kWh ⁸
Snack Vending Machine Electric usage	0 kWh
Dual Vending Machine Electric Usage	0 kWh
Total Vending Machine Electric Usage	1,654 kWh

Vending Machine Controls Usage Savings	8,858 kWh
Total cost savings	\$ 1,231
Estimated Total Project Cost	\$ 840⁹
Simple Payback	1 years

Assumptions

1	3	Number of cold beverage vending machines
2	0	Number of snack vending machines
3	0	Number of dual snack/beverage vending machines
4	400	Average wattage, typical of cold beverage machines based on prior project experience
5	200	Average wattage, typical of snack machines based on prior project experience
6	300	Average wattage, typical of dual snack/beverage machines based on prior project experience
7	8760	Hours per year vending machine plugged in
8	3150	Building Occupied Hours
9	0.50	Vending Machine Traffic Factor (0.75 for High Traffic, 0.5 for Medium, 0.25 for low)

Newark Public Schools
CHA Project Number: 27998
Bard Early College High School

Multipliers	
Material:	1.03
Labor:	1.25
Equipment:	1.12

ECM-6: Install Vending Machine Controls - Cost

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
									\$ -	
Vending Miser	3	EA	\$ 200	\$ 15	\$ -	\$ 616	\$ 56	\$ -	\$ 672	Vendor Estimation
						\$ -	\$ -	\$ -	\$ -	

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

\$ 672	Subtotal
\$ 168	25% Contingency
\$ 840	Total

Newark Public Schools
CHA Project Number: 27998
Bard Early College High School

ECM-7: Replace urinals and flush valves with low flow

Description: This ECM evaluates the water savings associated with replacing/ upgrading urinals with 0.125 GPF urinals and or flush valves.

EXISTING CONDITIONS		
Cost of Water / 1000 Gallons	\$7.55	\$ / kGal
Urinals in Building to be replaced	19	
Total Flushes / Urinal (per Day)	9.2	Based on # of occupants
Average Gallons / Flush	2.5	Gal

PROPOSED CONDITIONS		
Proposed Urinals to be Replaced	19	
Proposed Gallons / Flush	0.125	Gal
Proposed Material Cost of new urinal & valve	\$1,200	RS Means 2012
Proposed Installation Cost of new urinal & valve	\$1,000	RS Means 2012
Total cost of new urinals & valves		

SAVINGS		
Current Urinal Water Use	158.78	kGal / year
Proposed Urinal Water Use	7.94	kGal / year
Water Savings	150.84	kGal / year
Cost Savings	\$1,139	/ year

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

Newark Public Schools
CHA Project Number: 27998
Bard Early College High School

ECM-7: Replace toilets and flush valves with low flow

Description: This ECM evaluates the water savings associated with replacing/ upgrading toilets to 1.28 GPF fixtures and/or flush valves.

EXISTING CONDITIONS		
Cost of Water / 1000 Gallons	\$7.55	\$ / kGal
Toilets in Building	64	
Total Flushes / Toilet (per Day)	4.5	Based on # of occupants
Average Gallons / Flush	3.5	Gal

PROPOSED CONDITIONS		
Proposed Toilets to be Replaced	64	
Proposed Gallons / Flush	1.28	Gal

SAVINGS		
Current Toilet Water Use	371.83	kGal / year
Proposed Toilet Water Use	135.98	kGal / year
Water Savings	235.85	kGal / year
Cost Savings	\$1,781	/ year

Newark Public Schools
 CHA Project Number: 27998
 Bard Early College High School

Multipliers	
Material:	1.03
Labor:	1.25
Equipment:	1.12

ECM-7 Replace Plumbing Fixtures with Low-Flow Equivalents - Cost

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
									\$ -	
Low-Flow Urinal	19	EA	\$ 1,200	\$ 1,000	\$ -	\$ 23,416	\$ 23,674	\$ -	\$ 47,090	Vendor Estimate
Low-Flow Toilet	64	EA	\$ 1,400	\$ 1,000	\$ -	\$ 92,019	\$ 79,744	\$ -	\$ 171,763	Vendor Estimate
						\$ -	\$ -	\$ -	\$ -	

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

\$ 218,853	Subtotal
\$ 54,713	25% Contingency
\$ 273,566	Total

Newark Public Schools
CHA Project Number: 27998
Bard Early College High School

New Jersey Pay For Performance Incentive Program

Note: The following calculation is based on the New Jersey Pay For Performance Incentive Program per April, 2012 Building must have a minimum average electric demand of 100 kW. This minimum is waived for buildings owned by local governments or non-profit organizations.

At a minimum, all recommended measures were used for this calculation. To qualify for P4P incentives, the following P4P requirements must be met:

- At least 15% source energy savings
- No more than 50% savings from lighting measures
- Scope includes more than one measure
- Project has at least a 10% internal rate of return
- At least 50% of the source energy savings must come from investor-owned electricity and/or natural gas (note: exemption for fuel conversions)

Total Building Area (Square Feet)	153,163
Is this audit funded by NJ BPU (Y/N)	Yes

Board of Public Utilities (BPU)

Incentive #1		
Audit is funded by NJ BPU	\$0.05	\$/sqft

	Annual Utilities	
	kWh	Therms
Existing Cost (from utility)	\$154,398	\$87,519
Existing Usage (from utility)	1,114,500	94,362
Proposed Savings	272,949	23,559
Existing Total MMBtus	13,240	
Proposed Savings MMBtus	3,287	
% Energy Reduction	24.8%	
Proposed Annual Savings	\$61,012	

	Min (Savings = 15%)		Increase (Savings > 15%)		Max Incentive		Achieved Incentive	
Incentive #2	\$0.09	\$0.90	\$0.005	\$0.05	\$0.11	\$1.25	\$0.11	\$1.25
Incentive #3	\$0.09	\$0.90	\$0.005	\$0.05	\$0.11	\$1.25	\$0.11	\$1.25

	Incentives \$		
	Elec	Gas	Total
Incentive #1	\$0	\$0	\$7,658
Incentive #2	\$30,024	\$29,449	\$59,473
Incentive #3	\$30,024	\$29,449	\$59,473
Total All Incentives	\$60,049	\$58,897	\$126,604

Total Project Cost	\$962,360
--------------------	-----------

	Allowable Incentive	
% Incentives #1 of Utility Cost*	3.2%	\$7,658
% Incentives #2 of Project Cost**	6.2%	\$59,473
% Incentives #3 of Project Cost**	6.2%	\$59,473
Total Eligible Incentives***	\$126,604	
Project Cost w/ Incentives	\$835,756	

Project Payback (years)	
w/o Incentives	w/ Incentives
15.8	13.7

* Maximum allowable incentive is 50% of annual utility cost if not funded by NJ BPU, and %25 if it is.

** Maximum allowable amount of Incentive #2 is 25% of total project cost.

Maximum allowable amount of Incentive #3 is 25% of total project cost.

*** Maximum allowable amount of Incentive #1 is \$50,000 if not funded by NJ BPU, and \$25,000 if it is.

Maximum allowable amount of Incentive #2 & #3 is \$1 million per gas account and \$1 million per electric account; maximum 2 million per project

Field Code		Area Description	EXISTING CONDITIONS								RETROFIT CONDITIONS								COST & SAVINGS ANALYSIS									
			No. of Fixtures before the retrofit	Standard Fixture Code "Lighting Fixture Code" Example 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape	Fixture Code Code from Table of Standard Fixture Wattages	Watts per Fixture Value from Table of Standard Fixture Wattages	kW/Space (Watts/Fixt) * (Fixt No.)	Exist Control Pre-inst. control device	Annual Hours Estimated daily hours for the usage group	Annual kWh (kW/Space) * (Annual Hours)	Number of Fixtures No. of fixtures after the retrofit	Standard Fixture Code "Lighting Fixture Code" Example 2T 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape	Fixture Code Code from Table of Standard Fixture Wattages	Watts per Fixture Value from Table of Standard Fixture Wattages	kW/Space (Watts/Fixt) * (Number of Fixtures)	Retrofit Control device	Annual Hours Estimated annual hours for the usage group	Annual kWh (kW/Space) (Annual Hours)	Annual kWh Saved (Original Annual kWh) - (Retrofit Annual kWh)	Annual kWh Saved (Original Annual kWh) - (Retrofit Annual kWh)	Annual \$ Saved (kWh Saved) * (\$/kWh)	Retrofit Cost Cost for renovations to lighting system	NJ Smart Start Lighting Incentive Prescriptive Lighting Measures	Simple Payback With Out Incentive Length of time for renovations cost to be recovered	Simple Payback Length of time for renovations cost to be recovered			
46LED		Kitchen	45	W 28 C F 2 (ELE)	F42LL	60	2.7	SW	2000	5,400	45	4 f LED Tube	200732x2	30	1.4	SW	2,000	2,700	2,700	1.4	\$ 430.54	\$ 7,350.75	\$0	17.1	17.1			
15LED		Storage	3	S 32 C F 2 (ELE)	F42LL	60	0.2	SW	520	94	3	4 f LED Tube	200732x2	30	0.1	SW	520	47	47	0.1	\$ 12.19	\$ 490.05	\$0	40.2	40.2			
15LED		Loading Dock	2	S 32 C F 2 (ELE)	F42LL	60	0.1	SW	2000	240	2	4 f LED Tube	200732x2	30	0.1	SW	2,000	120	120	0.1	\$ 19.14	\$ 326.70	\$0	17.1	17.1			
15LED		Loading Dock Storage	1	S 32 C F 2 (ELE)	F42LL	60	0.1	SW	520	31	1	4 f LED Tube	200732x2	30	0.0	SW	520	16	16	0.0	\$ 4.06	\$ 163.35	\$0	40.2	40.2			
18LED		Office	1	W 40 C F 4 (ELE)	F44LL	112	0.1	SW	2600	291	1	T 74 R LED	RTLED50	50	0.1	SW	2,600	130	161	0.1	\$ 24.39	\$ 236.25	\$0	9.7	9.7			
218ALED		Corridor 1st Floor	10	W 32 C F 3 (ELE)	F46LL	175	1.8	SW	6240	10,920	10	4 f LED Tube	200732x3	45	0.5	SW	6,240	2,808	8,112	1.3	\$ 1,098.08	\$ 4,900.50	\$0	4.5	4.5			
18LED		Corridor 1st Floor	60	T 32 R F 4 (ELE)	F44LL	112	6.7	SW	6240	41,933	60	T 74 R LED	RTLED50	50	3.0	SW	6,240	18,720	23,213	3.7	\$ 3,142.21	\$ 14,175.00	\$0	4.5	4.5			
15LED		116	20	S 32 C F 2 (ELE)	F42LL	60	1.2	SW	2600	3,120	20	4 f LED Tube	200732x2	30	0.6	SW	2,600	1,560	1,560	0.6	\$ 235.99	\$ 1,633.50	\$0	13.8	13.8			
162		Storage	1	S 34 C F 4 (MAG)	F44EE	144	0.1	SW	520	75	1	S 28 C F 4	F44SSILL	96	0.1	SW	520	50	25	0.0	\$ 6.50	\$ 141.75	\$0	21.8	21.8			
104LED		114	24	S 32 P F 1	F41LL	32	0.8	SW	2600	1,997	24	4 f LED Tube	200732x1	15	0.4	SW	2,600	936	1,061	0.4	\$ 160.47	\$ 1,960.20	\$0	12.2	12.2			
104LED		117	27	S 32 P F 1	F41LL	32	0.9	SW	2600	2,246	27	4 f LED Tube	200732x1	15	0.4	SW	2,600	1,053	1,193	0.5	\$ 180.53	\$ 2,205.23	\$0	12.2	12.2			
104LED		118	27	S 32 P F 1	F41LL	32	0.9	SW	2600	2,246	27	4 f LED Tube	200732x1	15	0.4	SW	2,600	1,053	1,193	0.5	\$ 180.53	\$ 2,205.23	\$0	12.2	12.2			
104LED		Storage	20	S 32 P F 1	F41LL	32	0.6	SW	520	333	20	4 f LED Tube	200732x1	15	0.3	SW	520	156	177	0.3	\$ 46.04	\$ 1,633.50	\$0	35.5	35.5			
104LED		Boy's Restroom	5	S 32 P F 1	F41LL	32	0.2	SW	3120	499	5	4 f LED Tube	200732x1	15	0.1	SW	3,120	234	265	0.1	\$ 38.91	\$ 408.38	\$0	10.5	10.5			
104LED		Girl's Restroom	5	S 32 P F 1	F41LL	32	0.2	SW	3120	499	5	4 f LED Tube	200732x1	15	0.1	SW	3,120	234	265	0.1	\$ 38.91	\$ 408.38	\$0	10.5	10.5			
220LED		Custodial Closer	1	S 17 C F 1 (ELE)	F21LL	20	0.0	SW	780	16	1	2 f LED Tube	200714x2	16	0.0	SW	780	12	3	0.0	\$ 0.67	\$ 182.25	\$0	271.8	271.8			
104LED		112	30	S 32 P F 1	F41LL	32	1.0	SW	2600	2,496	30	4 f LED Tube	200732x1	15	0.5	SW	2,600	1,170	1,326	0.5	\$ 200.59	\$ 2,450.25	\$0	12.2	12.2			
104LED		119	33	S 32 P F 1	F41LL	32	1.1	SW	2600	2,746	33	4 f LED Tube	200732x1	15	0.5	SW	2,600	1,287	1,459	0.6	\$ 220.65	\$ 2,695.28	\$0	12.2	12.2			
55LED		Guidance Office	4	2T 17 R F 3 (ELE)	F23LL	47	0.2	SW	2600	489	4	2T 25 R LED	2RTLED	25	0.1	SW	2,600	260	34.61	\$ 810.00	\$0	23.4	23.4					
55LED		Guidance Office - Office	4	2T 17 R F 3 (ELE)	F23LL	47	0.2	SW	2600	489	4	2T 25 R LED	2RTLED	25	0.1	SW	2,600	260	34.61	\$ 810.00	\$0	23.4	23.4					
104LED		Guidance Office - Office	2	S 32 P F 1	F41LL	32	0.1	SW	2600	166	2	4 f LED Tube	200732x1	15	0.0	SW	2,600	78	88	0.0	\$ 13.37	\$ 163.35	\$0	12.2	12.2			
104LED		Guidance Office - Office	2	S 32 P F 1	F41LL	32	0.1	SW	2600	166	2	4 f LED Tube	200732x1	15	0.0	SW	2,600	78	88	0.0	\$ 13.37	\$ 163.35	\$0	12.2	12.2			
104LED		Guidance Office - Office	2	S 32 P F 1	F41LL	32	0.1	SW	2600	166	2	4 f LED Tube	200732x1	15	0.0	SW	2,600	78	88	0.0	\$ 13.37	\$ 163.35	\$0	12.2	12.2			
104LED		Guidance Office - Office	2	S 32 P F 1	F41LL	32	0.1	SW	2600	166	2	4 f LED Tube	200732x1	15	0.0	SW	2,600	78	88	0.0	\$ 13.37	\$ 163.35	\$0	12.2	12.2			
18LED		General Office	19	T 32 R F 4 (ELE)	F44LL	112	2.1	SW	2600	5,533	19	T 74 R LED	RTLED50	50	1.0	SW	2,600	2,470	3,063	1.2	\$ 463.33	\$ 4,488.75	\$0	9.7	9.7			
18LED		106	10	T 32 R F 4 (ELE)	F44LL	112	1.1	SW	2600	2,912	10	T 74 R LED	RTLED50	50	0.5	SW	2,600	1,300	1,612	0.6	\$ 243.86	\$ 2,362.50	\$0	9.7	9.7			
18LED		School Nurse	5	T 32 R F 4 (ELE)	F44LL	112	0.6	SW	2600	1,456	5	T 74 R LED	RTLED50	50	0.3	SW	2,600	650	806	0.3	\$ 121.93	\$ 1,181.25	\$0	9.7	9.7			
18LED		School Nurse - Office	3	T 32 R F 4 (ELE)	F44LL	112	0.3	SW	2600	874	3	T 74 R LED	RTLED50	50	0.2	SW	2,600	390	484	0.2	\$ 73.16	\$ 708.75	\$0	9.7	9.7			
18LED		School Nurse - Office	2	T 32 R F 4 (ELE)	F44LL	112	0.6	SW	2600	1,456	2	T 74 R LED	RTLED50	50	0.3	SW	2,600	650	806	0.3	\$ 121.93	\$ 1,181.25	\$0	9.7	9.7			
104LED		Girl's Restroom	5	S 32 P F 1	F41LL	32	0.2	SW	3120	499	5	4 f LED Tube	200732x1	15	0.1	SW	3,120	234	265	0.1	\$ 38.91	\$ 408.38	\$0	10.5	10.5			
104LED		Boy's RestRoom	5	S 32 P F 1	F41LL	32	0.2	SW	3120	499	5	4 f LED Tube	200732x1	15	0.1	SW	3,120	234	265	0.1	\$ 38.91	\$ 408.38	\$0	10.5	10.5			
220LED		Custodial Closer	1	S 17 C F 1 (ELE)	F21LL	20	0.0	SW	780	16	1	2 f LED Tube	200714x2	16	0.0	SW	780	12	3	0.0	\$ 0.67	\$ 182.25	\$0	271.8	271.8			
18LED		105	10	T 32 R F 4 (ELE)	F44LL	112	1.1	SW	2600	2,912	10	T 74 R LED	RTLED50	50	0.5	SW	2,600	1,300	1,612	0.6	\$ 243.86	\$ 2,362.50	\$0	9.7	9.7			
104LED		Medical Office	4	S 32 P F 1	F41LL	32	0.1	SW	2600	383	4	4 f LED Tube	200732x1	15	0.1	SW	2,600	156	26.75	\$ 326.70	\$0	12.2	12.2					
55LED		Medical Office - Waiting Room	4	2T 17 R F 3 (ELE)	F23LL	47	0.2	SW	2600	489	4	2T 25 R LED																

		EXISTING CONDITIONS										RETROFIT CONDITIONS										COST & SAVINGS ANALYSIS						
Field Code	Area Description	No. of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/Space	Exist Control	Annual Hours	Annual kWh	Number of Fixtures after the retrofit	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/Space	Retrofit Control	Annual Hours	Annual kWh	Annual kWh Saved (Original Annual kWh) - (Retrofit Annual kWh)	Annual kW Saved (Original Annual kW) - (Retrofit Annual kW)	Annual \$ Saved (\$/kWh)	Retrofit Cost	NJ Smart Start Lighting Incentive	Simple Payback Length of time for renovations cost to be recovered	Simple Payback Length of time for renovations cost to be recovered				
		No. of fixtures before the retrofit	Lighting Fixture Code	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Fixt No.)	Pre-inst. control device	Estimated annual hours for the usage group	(kW/Space) * (Annual Hours)		"Lighting Fixture Code" Example 2T 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Number of Fixtures)	Retrofit control device	Estimated annual hours for the usage group	(kW/Space) * (Annual Hours)	(Original Annual kWh) - (Retrofit Annual kWh)	(Original Annual kW) - (Retrofit Annual kW)	(kW Saved) * (\$/kWh)	Cost for renovations to lighting system							
46LED	Kitchen	45	W 28 C F 2 (ELE)	F42LL	60	2.7	SW	2000	5,400.0	45	W 28 C F 2 (ELE)	F42LL	60	2.7	NONE	2000	5,400.0	0.0	0.0	\$0.00	\$0.00	\$0.00		#DIV/0!				
15LED	Storage	3	S 32 C F 2 (ELE)	F42LL	60	0.2	SW	520	93.6	3	S 32 C F 2 (ELE)	F42LL	60	0.2	NONE	520	93.6	0.0	0.0	\$0.00	\$0.00	\$0.00		#DIV/0!				
15LED	Loading Dock	2	S 32 C F 2 (ELE)	F42LL	60	0.1	SW	2000	240.0	2	S 32 C F 2 (ELE)	F42LL	60	0.1	NONE	2000	240.0	0.0	0.0	\$0.00	\$0.00	\$0.00		#DIV/0!				
15LED	Loading Dock Storage	1	S 32 C F 2 (ELE)	F42LL	60	0.1	SW	520	31.2	1	S 32 C F 2 (ELE)	F42LL	60	0.1	NONE	520	31.2	0.0	0.0	\$0.00	\$0.00	\$0.00		#DIV/0!				
18LED	Office	1	W 40 C F 4 (ELE)	F44LL	112	0.1	SW	2600	291.2	1	W 40 C F 4 (ELE)	F44LL	112	0.1	NONE	2600	291.2	0.0	0.0	\$0.00	\$0.00	\$0.00		#DIV/0!				
218ALED	Corridor 1st Floor	10	W 32 C F 3 (ELE)	F46LL	175	1.8	SW	6240	10,920.0	10	W 32 C F 3 (ELE)	F46LL	175	1.8	NONE	6240	10,920.0	0.0	0.0	\$0.00	\$0.00	\$0.00		#DIV/0!				
18LED	Corridor 1st Floor	60	T 32 R F 4 (ELE)	F44LL	112	6.7	SW	6240	41,932.8	60	T 32 R F 4 (ELE)	F44LL	112	6.7	NONE	6240	41,932.8	0.0	0.0	\$0.00	\$0.00	\$0.00		#DIV/0!				
15LED	116	20	S 32 C F 2 (ELE)	F42LL	60	1.2	SW	2600	3,120.0	20	S 32 C F 2 (ELE)	F42LL	60	1.2	C-CCC	1820	2,184.0	936.0	0.0	\$116.06	\$270.00	\$35.00	2.3	2.0				
162	Storage	1	S 34 C F 4 (MAG)	F44EE	144	0.1	SW	520	74.9	1	S 34 C F 4 (MAG)	F44EE	144	0.1	NONE	520	74.9	0.0	0.0	\$0.00	\$0.00	\$0.00		#DIV/0!				
104LED	114	24	S 32 P F 1	F41LL	32	0.8	SW	2600	1,996.8	24	S 32 P F 1	F41LL	32	0.8	C-CCC	1820	1,397.8	599.0	0.0	\$74.28	\$270.00	\$35.00	3.6	2.8				
104LED	117	27	S 32 P F 1	F41LL	32	0.9	SW	2600	2,246.4	27	S 32 P F 1	F41LL	32	0.9	C-CCC	1820	1,572.5	673.9	0.0	\$83.57	\$270.00	\$35.00	3.2	2.8				
104LED	118	27	S 32 P F 1	F41LL	32	0.9	SW	2600	2,246.4	27	S 32 P F 1	F41LL	32	0.9	C-CCC	1820	1,572.5	673.9	0.0	\$83.57	\$270.00	\$35.00	3.2	2.8				
104LED	Storage	20	S 32 P F 1	F41LL	32	0.6	SW	520	332.8	20	S 32 P F 1	F41LL	32	0.6	NONE	520	332.8	0.0	0.0	\$0.00	\$0.00	\$0.00		#DIV/0!				
104LED	Boy's Restroom	5	S 32 P F 1	F41LL	32	0.2	SW	3120	499.2	5	S 32 P F 1	F41LL	32	0.2	C-CCC	2028	324.5	174.7	0.0	\$21.67	\$270.00	\$35.00	12.5	10.8				
104LED	Girl's Restroom	5	S 32 P F 1	F41LL	32	0.2	SW	3120	499.2	5	S 32 P F 1	F41LL	32	0.2	C-CCC	2028	324.5	174.7	0.0	\$21.67	\$270.00	\$35.00	12.5	10.8				
220LED	Custodial Closer	1	S 17 C F 1 (ELE)	F21LL	20	0.0	SW	780	15.6	1	S 17 C F 1 (ELE)	F21LL	20	0.0	NONE	780	15.6	0.0	0.0	\$0.00	\$0.00	\$0.00		#DIV/0!				
104LED	112	30	S 32 P F 1	F41LL	32	1.0	SW	2600	2,496.0	30	S 32 P F 1	F41LL	32	1.0	C-CCC	1820	1,747.2	748.8	0.0	\$92.85	\$270.00	\$35.00	2.9	2.5				
104LED	119	33	S 32 P F 1	F41LL	32	1.1	SW	2600	2,745.6	33	S 32 P F 1	F41LL	32	1.1	C-CCC	1820	1,921.9	823.7	0.0	\$102.14	\$270.00	\$35.00	2.6	2.3				
55LED	Guidance Office	4	2T 17 R F 3 (ELE)	F23LL	47	0.2	SW	2600	488.8	4	2T 17 R F 3 (ELE)	F23LL	47	0.2	NONE	2600	488.8	0.0	0.0	\$0.00	\$0.00	\$0.00		#DIV/0!				
55LED	Guidance Office - Office	4	2T 17 R F 3 (ELE)	F23LL	47	0.2	SW	2600	488.8	4	2T 17 R F 3 (ELE)	F23LL	47	0.2	C-CCC	1200	225.6	263.2	0.0	\$32.64	\$270.00	\$35.00	8.3	7.2				
104LED	Guidance Office - Office	2	S 32 P F 1	F41LL	32	0.1	SW	2600	166.4	2	S 32 P F 1	F41LL	32	0.1	C-CCC	1200	76.8	89.6	0.0	\$11.11	\$270.00	\$35.00	24.3	21.2				
104LED	Guidance Office - Office	2	S 32 P F 1	F41LL	32	0.1	SW	2600	166.4	2	S 32 P F 1	F41LL	32	0.1	C-CCC	1200	76.8	89.6	0.0	\$11.11	\$270.00	\$35.00	24.3	21.2				
104LED	Guidance Office - Office	2	S 32 P F 1	F41LL	32	0.1	SW	2600	166.4	2	S 32 P F 1	F41LL	32	0.1	C-CCC	1200	76.8	89.6	0.0	\$11.11	\$270.00	\$35.00	24.3	21.2				
104LED	Guidance Office - Office	2	S 32 P F 1	F41LL	32	0.1	SW	2600	166.4	2	S 32 P F 1	F41LL	32	0.1	C-CCC	1200	76.8	89.6	0.0	\$11.11	\$270.00	\$35.00	24.3	21.2				
18LED	General Office	19	T 32 R F 4 (ELE)	F44LL	112	2.1	SW	2600	5,532.8	19	T 32 R F 4 (ELE)	F44LL	112	2.1	C-CCC	1200	2,553.6	2,979.2	0.0	\$369.42	\$270.00	\$35.00	0.7	0.6				
18LED	106	10	T 32 R F 4 (ELE)	F44LL	112	1.1	SW	2600	2,912.0	10	T 32 R F 4 (ELE)	F44LL	112	1.1	C-CCC	1820	2,038.4	873.6	0.0	\$108.33	\$270.00	\$35.00	2.5	2.2				
18LED	School Nurse	5	T 32 R F 4 (ELE)	F44LL	112	0.6	SW	2600	1,456.0	5	T 32 R F 4 (ELE)	F44LL	112	0.6	NONE	2600	1,456.0	0.0	0.0	\$0.00	\$0.00	\$0.00		#DIV/0!				
18LED	School Nurse - Office	3	T 32 R F 4 (ELE)	F44LL	112	0.3	SW	2600	873.6	3	T 32 R F 4 (ELE)	F44LL	112	0.3	NONE	2600	873.6	0.0	0.0	\$0.00	\$0.00	\$0.00		#DIV/0!				
18LED	School Nurse - Office	3	T 32 R F 4 (ELE)	F44LL	112	0.3	SW	2600	873.6	3	T 32 R F 4 (ELE)	F44LL	112	0.3	NONE	2600	873.6	0.0	0.0	\$0.00	\$0.00	\$0.00		#DIV/0!				
104LED	Girl's Restroom	5	S 32 P F 1	F41LL	32	0.2	SW	3120	499.2	5	S 32 P F 1	F41LL	32	0.2	C-CCC	2028	324.5	174.7	0.0	\$21.67	\$270.00	\$35.00	12.5	10.8				
104LED	Boy's RestRoom	5	S 32 P F 1	F41LL	32	0.2	SW	3120	499.2	5	S 32 P F 1	F41LL	32	0.2	C-CCC	2028	324.5	174.7	0.0	\$21.67	\$270.00	\$35.00	12.5	10.8				
220LED	Custodial Closer	1	S 17 C F 1 (ELE)	F21LL	20	0.0	SW	780	15.6	1	S 17 C F 1 (ELE)	F21LL	20	0.0	NONE	780	15.6	0.0	0.0	\$0.00	\$0.00	\$0.00		#DIV/0!				
18LED	105	10	T 32 R F 4 (ELE)	F44LL	112	1.1	SW	2600	2,912.0	10	T 32 R F 4 (ELE)	F44LL	112	1.1	C-CCC	1820	2,038.4	873.6	0.0	\$108.33	\$270.00	\$35.00	2.5	2.2				
104LED	Medical Office	4	S 32 P F 1	F41LL	32	0.1	SW	2600	332.8	4	S 32 P F 1	F41LL	32	0.1	NONE	2600	332.8											

		EXISTING CONDITIONS										RETROFIT CONDITIONS										COST & SAVINGS ANALYSIS												
Field Code	Area Description Unique description of the location - Room number/Room name: Floor number (if applicable)	No. of Fixtures before the retrofit	Standard Fixture Code	Lighting Fixture Code	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Fixt No.)	kW/Space	Watts per Fixture	Pre-Inst. control device	Annual Hours	Annual kWh	(kW/Space) * (Annual Hours)	No. of fixtures after the retrofit	Standard Fixture Code	Lighting Fixture Code	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Number of Fixtures)	kW/Space	Watts per Fixture	Retrofit Control device	Estimated annual hours for the usage group	Annual kWh	(kW/Space) * (Annual Hours)	Annual kWh Saved (Original Annual kWh) - (Retrofit Annual kWh)	Annual kWh Saved (Original Annual kWh) - (Retrofit Annual kWh)	Annual \$ Saved (kWh Saved) * (\$/kWh)	Retrofit Cost for renovations to lighting system	NJ Smart Start Lighting Incentive	Prescriptive Lighting Measures	Length of time for renovations cost to be recovered	Simple Payback With Out Incentive	Simple Payback Length of time for renovations cost to be recovered
46LED	Kitchen	45	W 28 C F 2 (ELE)	F42LL	F42LL	60	2.7	SW	2000		2000	5,400	45	4 ft LED Tube	200732x2		200732x2	30	1.4	NONE	2000	2,700	2,700	1.4	\$ 430.54	\$ 7,350.75	\$ -	17.1	17.1					
15LED	Storage	3	S 32 C F 2 (ELE)	F42LL	F42LL	60	0.2	SW	520		520	94	3	4 ft LED Tube	200732x2		200732x2	30	0.1	NONE	520	47	47	0.1	\$ 12.19	\$ 490.05	\$ -	40.2	40.2					
15LED	Loading Dock	2	S 32 C F 2 (ELE)	F42LL	F42LL	60	0.1	SW	2000		2000	240	2	4 ft LED Tube	200732x2		200732x2	30	0.1	NONE	2000	120	120	0.1	\$ 19.14	\$ 326.70	\$ -	17.1	17.1					
15LED	Loading Dock Storage	1	S 32 C F 2 (ELE)	F42LL	F42LL	60	0.1	SW	520		520	31	1	4 ft LED Tube	200732x2		200732x2	30	0.0	NONE	520	16	16	0.0	\$ 4.06	\$ 163.35	\$ -	40.2	40.2					
18LED	Office	1	W 40 C F 4 (ELE)	F44LL	F44LL	112	0.1	SW	2600		2600	291	1	T 74 R LED	RTLED50		RTLED50	50	0.1	NONE	2600	130	130	0.1	\$ 24.39	\$ 236.25	\$ -	9.7	9.7					
218ALED	Corridor 1st Floor	10	W 32 C F 3 (ELE)	F46LL	F46LL	175	1.8	SW	6240		10,920	10	4 ft LED Tube	200732x3		200732x3	45	0.5	NONE	6240	2,808	2,808	8,112	1.3	\$ 1,098.08	\$ 4,900.50	\$ -	4.5	4.5					
18LED	Corridor 1st Floor	60	T 32 R F 4 (ELE)	F44LL	F44LL	112	6.7	SW	6240		41,933	60	T 74 R LED	RTLED50		RTLED50	50	3.0	NONE	6240	18,720	18,720	23,213	3.7	\$ 3,142.21	\$ 14,175.00	\$ -	4.5	4.5					
15LED	116	20	S 32 C F 2 (ELE)	F42LL	F42LL	60	1.2	SW	2600		3,120	20	4 ft LED Tube	200732x2		200732x2	30	0.6	C-CCC	1,820	1,092	1,092	2,028	0.6	\$ 294.02	\$ 3,537.00	\$ 35	12.0	11.9					
162	Storage	1	S 34 C F 4 (MAG)	F44EE	F44EE	144	0.1	SW	520		75	1	S 28 C F 4	F44SLL		F44SLL	96	0.1	NONE	520	50	50	25	0.0	\$ 6.50	\$ 141.75	\$ -	21.8	21.8					
104LED	114	24	S 32 P F 1	F41LL	F41LL	32	0.8	SW	2600		1,997	24	4 ft LED Tube	200732x1		200732x1	15	0.4	C-CCC	1,820	664	664	1,345	0.4	\$ 195.29	\$ 2,230.20	\$ 35	11.4	11.2					
104LED	117	27	S 32 P F 1	F41LL	F41LL	32	0.9	SW	2600		2,246	27	4 ft LED Tube	200732x1		200732x1	15	0.4	C-CCC	1,820	737	737	1,509	0.5	\$ 219.71	\$ 2,475.23	\$ 35	11.3	11.1					
104LED	118	27	S 32 P F 1	F41LL	F41LL	32	0.9	SW	2600		2,246	27	4 ft LED Tube	200732x1		200732x1	15	0.4	C-CCC	1,820	737	737	1,509	0.5	\$ 219.71	\$ 2,475.23	\$ 35	11.3	11.1					
104LED	Storage	20	S 32 P F 1	F41LL	F41LL	32	0.6	SW	520		333	20	4 ft LED Tube	200732x1		200732x1	15	0.3	NONE	520	156	156	177	0.3	\$ 46.04	\$ 1,633.50	\$ -	35.5	35.5					
104LED	Boy's Restroom	5	S 32 P F 1	F41LL	F41LL	32	0.2	SW	3120		499	5	4 ft LED Tube	200732x1		200732x1	15	0.1	C-CCC	2,028	152	152	347	0.1	\$ 49.07	\$ 678.38	\$ 35	13.8	13.1					
104LED	Girl's Restroom	5	S 32 P F 1	F41LL	F41LL	32	0.2	SW	3120		499	5	4 ft LED Tube	200732x1		200732x1	15	0.1	C-CCC	2,028	152	152	347	0.1	\$ 49.07	\$ 678.38	\$ 35	13.8	13.1					
220LED	Custodial Closer	1	S 17 C F 1 (ELE)	F21LL	F21LL	20	0.0	SW	780		16	1	2 ft LED Tube	200714x2		200714x2	16	0.0	NONE	780	12	12	3	0.0	\$ 0.67	\$ 182.25	\$ -	271.8	271.8					
104LED	112	30	S 32 P F 1	F41LL	F41LL	32	1.0	SW	2600		2,490	30	4 ft LED Tube	200732x1		200732x1	15	0.5	C-CCC	1,820	819	819	1,677	0.5	\$ 244.12	\$ 2,720.25	\$ 35	11.1	11.0					
104LED	119	33	S 32 P F 1	F41LL	F41LL	32	1.1	SW	2600		2,746	33	4 ft LED Tube	200732x1		200732x1	15	0.5	C-CCC	1,820	901	901	1,845	0.6	\$ 268.53	\$ 2,965.28	\$ 35	11.0	10.9					
56LED	Guidance Office	4	T 17 R F 3 (ELE)	F23LL	F23LL	47	0.2	SW	2600		489	4	T 17 R LED	RTLED		RTLED	25	0.1	C-CCC	1,200	120	120	369	0.1	\$ 1,080.00	\$ 1,080.00	\$ 35	20.8	20.1					
56LED	Guidance Office - Office	4	T 17 R F 3 (ELE)	F23LL	F23LL	47	0.2	SW	2600		489	4	T 17 R LED	RTLED		RTLED	25	0.1	C-CCC	1,200	120	120	369	0.1	\$ 51.87	\$ 1,080.00	\$ 35	20.8	20.1					
104LED	Guidance Office - Office	2	S 32 P F 1	F41LL	F41LL	32	0.1	SW	2600		166	2	4 ft LED Tube	200732x1		200732x1	15	0.0	C-CCC	1,200	36	36	130	0.0	\$ 18.58	\$ 433.35	\$ 35	23.3	21.4					
104LED	Guidance Office - Office	2	S 32 P F 1	F41LL	F41LL	32	0.1	SW	2600		166	2	4 ft LED Tube	200732x1		200732x1	15	0.0	C-CCC	1,200	36	36	130	0.0	\$ 18.58	\$ 433.35	\$ 35	23.3	21.4					
104LED	Guidance Office - Office	2	S 32 P F 1	F41LL	F41LL	32	0.1	SW	2600		166	2	4 ft LED Tube	200732x1		200732x1	15	0.0	C-CCC	1,200	36	36	130	0.0	\$ 18.58	\$ 433.35	\$ 35	23.3	21.4					
104LED	Guidance Office - Office	2	S 32 P F 1	F41LL	F41LL	32	0.1	SW	2600		166	2	4 ft LED Tube	200732x1		200732x1	15	0.0	C-CCC	1,200	36	36	130	0.0	\$ 18.58	\$ 433.35	\$ 35	23.3	21.4					
18LED	General Office	19	T 32 R F 4 (ELE)	F44LL	F44LL	112	2.1	SW	2600		5,533	19	T 74 R LED	RTLED50		RTLED50	50	1.0	C-CCC	1,200	1,140	1,140	4,393	1.2	\$ 628.25	\$ 4,758.75	\$ 35	7.6	7.5					
18LED	106	10	T 32 R F 4 (ELE)	F44LL	F44LL	112	1.1	SW	2600		2,912	10	T 74 R LED	RTLED50		RTLED50	50	0.5	C-CCC	1,820	910	910	2,002	0.6	\$ 292.22	\$ 2,632.50	\$ 35	9.0	8.9					
18LED	School Nurse	5	T 32 R F 4 (ELE)	F44LL	F44LL	112	0.6	SW	2600		1,456	5	T 74 R LED	RTLED50		RTLED50	50	0.3	NONE	2,600	650	650	806	0.3	\$ 121.93	\$ 1,181.25	\$ -	9.7	9.7					
18LED	School Nurse - Office	3	T 32 R F 4 (ELE)	F44LL	F44LL	112	0.3	SW	2600		874	3	T 74 R LED	RTLED50		RTLED50	50	0.2	NONE	2,600	390	390	484	0.2	\$ 73.16	\$ 708.75	\$ -	9.7	9.7					
18LED	School Nurse - Office	2	T 32 R F 4 (ELE)	F44LL	F44LL	112	0.2	SW	2600		586	2	T 74 R LED	RTLED50		RTLED50	50	0.1	NONE	2,600	260	260	327	0.1	\$ 172.50.									

		EXISTING CONDITIONS										RETROFIT CONDITIONS										COST & SAVINGS ANALYSIS							
Area Description		No. of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/Space	Exist Control	Annual Hours	Annual kWh		Standard Fixture Code	Fixture Code	Watts per Fixture	kW/Space	Retrofit Control	Annual Hours	Annual kWh	Annual kWh Saved	Annual kW Saved	Annual \$ Saved	Retrofit Cost	NJ Smart Start Lighting Incentive	Simple Payback						
Field Code	Unique description of the location - Room number/Room name: Floor number (if applicable)	No. of fixtures before the retrofit	Lighting Fixture Code	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Fixt No.)	Pre-inst. control device	Estimated daily hours for the usage group	(kW/Space) * (Annual Hours)	No. of fixtures after the retrofit	Lighting Fixture Code	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Number of Fixtures)	Retrofit control device	Estimated annual hours for the usage group	(kW/Space) * (Annual Hours)	(Original Annual kWh) - (Retrofit Annual kWh)	(Original Annual kW) - (Retrofit Annual kW)	(kWh Saved) * (\$/kWh)	Cost for renovations to lighting system	Prescriptive Lighting Measures	Length of time for renovations cost to be recovered	Simple Payback					
104LED	303	15	S 32 P F 1	F41LL	32	0.5	SW	2600	1,248	15	4 ft LED Tube	200732x1	15	0.2	C-OCC	1,820	410	839	0.3	\$ 122.06	\$ 1,495.13	\$ 35	12.2	12.0					
104LED	317	15	S 32 P F 1	F41LL	32	0.5	SW	2600	1,248	15	4 ft LED Tube	200732x1	15	0.2	C-OCC	1,820	410	839	0.3	\$ 122.06	\$ 1,495.13	\$ 35	12.2	12.0					
104LED	318	15	S 32 P F 1	F41LL	32	0.5	SW	2600	1,248	15	4 ft LED Tube	200732x1	15	0.2	C-OCC	1,820	410	839	0.3	\$ 122.06	\$ 1,495.13	\$ 35	12.2	12.0					
104LED	319	30	S 32 P F 1	F41LL	32	1.0	SW	2600	2,496	30	4 ft LED Tube	200732x1	15	0.5	C-OCC	1,820	819	1,677	0.5	\$ 244.12	\$ 2,720.25	\$ 35	11.1	11.0					
104LED	320	36	S 32 P F 1	F41LL	32	1.2	SW	2600	2,995	36	4 ft LED Tube	200732x1	15	0.5	C-OCC	1,820	983	2,012	0.6	\$ 292.94	\$ 3,210.30	\$ 35	11.0	10.8					
104LED	321	15	S 32 P F 1	F41LL	32	0.5	SW	2600	1,248	15	4 ft LED Tube	200732x1	15	0.2	C-OCC	1,820	410	839	0.3	\$ 122.06	\$ 1,495.13	\$ 35	12.2	12.0					
104LED	335	15	S 32 P F 1	F41LL	32	0.5	SW	2600	1,248	15	4 ft LED Tube	200732x1	15	0.2	C-OCC	1,820	410	839	0.3	\$ 122.06	\$ 1,495.13	\$ 35	12.2	12.0					
104LED	336	15	S 32 P F 1	F41LL	32	0.5	SW	2600	1,248	15	4 ft LED Tube	200732x1	15	0.2	C-OCC	1,820	410	839	0.3	\$ 122.06	\$ 1,495.13	\$ 35	12.2	12.0					
104LED	337	15	S 32 P F 1	F41LL	32	0.5	SW	2600	1,248	15	4 ft LED Tube	200732x1	15	0.2	C-OCC	1,820	410	839	0.3	\$ 122.06	\$ 1,495.13	\$ 35	12.2	12.0					
104LED	338	15	S 32 P F 1	F41LL	32	0.5	SW	2600	1,248	15	4 ft LED Tube	200732x1	15	0.2	C-OCC	1,820	410	839	0.3	\$ 122.06	\$ 1,495.13	\$ 35	12.2	12.0					
18LED	Corridor 3rd Floor	50	T 32 R F 4 (ELE)	F44LL	112	5.6	SW	6240	34,944	50	T 74 R LED	RTL6D50	50	2.5	NONE	6,240	15,600	19,344	3.1	\$ 2,618.51	\$ 11,812.50	\$ -	4.5	4.5					
104LED	322	16	S 32 P F 1	F41LL	32	0.5	SW	2600	1,331	16	4 ft LED Tube	200732x1	15	0.2	C-OCC	1,820	437	894	0.3	\$ 130.20	\$ 1,576.80	\$ 35	12.1	11.8					
104LED	323	15	S 32 P F 1	F41LL	32	0.5	SW	2600	1,248	15	4 ft LED Tube	200732x1	15	0.2	C-OCC	1,820	410	839	0.3	\$ 122.06	\$ 1,495.13	\$ 35	12.2	12.0					
104LED	324	15	S 32 P F 1	F41LL	32	0.5	SW	2600	1,248	15	4 ft LED Tube	200732x1	15	0.2	C-OCC	1,820	410	839	0.3	\$ 122.06	\$ 1,495.13	\$ 35	12.2	12.0					
104LED	325	36	S 32 P F 1	F41LL	32	1.2	SW	2600	2,995	36	4 ft LED Tube	200732x1	15	0.5	C-OCC	1,820	983	2,012	0.6	\$ 292.94	\$ 3,210.30	\$ 35	11.0	10.8					
104LED	326	15	S 32 P F 1	F41LL	32	0.5	SW	2600	1,248	15	4 ft LED Tube	200732x1	15	0.2	C-OCC	1,820	410	839	0.3	\$ 122.06	\$ 1,495.13	\$ 35	12.2	12.0					
104LED	327 - Office	9	S 32 P F 1	F41LL	32	0.3	SW	2600	749	9	4 ft LED Tube	200732x1	15	0.1	C-OCC	1,200	162	587	0.2	\$ 83.61	\$ 1,005.08	\$ 35	12.0	11.6					
104LED	328	15	S 32 P F 1	F41LL	32	0.5	SW	2600	1,248	15	4 ft LED Tube	200732x1	15	0.2	C-OCC	1,820	410	839	0.3	\$ 122.06	\$ 1,495.13	\$ 35	12.2	12.0					
104LED	329	15	S 32 P F 1	F41LL	32	0.5	SW	2600	1,248	15	4 ft LED Tube	200732x1	15	0.2	C-OCC	1,820	410	839	0.3	\$ 122.06	\$ 1,495.13	\$ 35	12.2	12.0					
104LED	330	15	S 32 P F 1	F41LL	32	0.5	SW	2600	1,248	15	4 ft LED Tube	200732x1	15	0.2	C-OCC	1,820	410	839	0.3	\$ 122.06	\$ 1,495.13	\$ 35	12.2	12.0					
104LED	331	15	S 32 P F 1	F41LL	32	0.5	SW	2600	1,248	15	4 ft LED Tube	200732x1	15	0.2	C-OCC	1,820	410	839	0.3	\$ 122.06	\$ 1,495.13	\$ 35	12.2	12.0					
104LED	332	15	S 32 P F 1	F41LL	32	0.5	SW	2600	1,248	15	4 ft LED Tube	200732x1	15	0.2	C-OCC	1,820	410	839	0.3	\$ 122.06	\$ 1,495.13	\$ 35	12.2	12.0					
104LED	333	20	S 32 P F 1	F41LL	32	0.6	SW	2600	1,664	20	4 ft LED Tube	200732x1	15	0.3	C-OCC	1,820	546	1,118	0.3	\$ 162.74	\$ 1,903.50	\$ 35	11.7	11.5					
104LED	334	15	S 32 P F 1	F41LL	32	0.5	SW	2600	1,248	15	4 ft LED Tube	200732x1	15	0.2	C-OCC	1,820	410	839	0.3	\$ 122.06	\$ 1,495.13	\$ 35	12.2	12.0					
185LED	UN-109	2	W 40 C F 4 (ELE)	F44LL	112	0.2	SW	520	116	2	T 74 R LED	RTL6D50	50	0.1	NONE	520	52	64	0.1	\$ 16.79	\$ 472.50	\$ -	28.1	28.1					
185LED	UN-110	2	W 40 C F 4 (ELE)	F44LL	112	0.2	SW	520	116	2	T 74 R LED	RTL6D50	50	0.1	NONE	520	52	64	0.1	\$ 16.79	\$ 472.50	\$ -	28.1	28.1					
S	Total	2,054				111.6			344,405	2,054				47.4		#N/A		118,673		64.1	32,539	299,138	\$6,520		#VALUE!				
S																				Demand Savings		64.1	\$4,548						
S																				kWh Savings		225,733	\$27,991						
S																				Total Savings			\$32,539		9.2	9.0			

APPENDIX D

New Jersey Board of Public Utilities Incentives

- i. Smart Start**
 - ii. Direct Install**
 - iii. Pay for Performance (P4P)**
 - iv. Energy Savings Improvement Plan (ESIP)**
-

I. SMART START



Your Power to Save

At Home, for Business, and for the Future

[About Us](#) | [Press Room](#) | [Library](#)

HOME

RESIDENTIAL

COMMERCIAL, INDUSTRIAL
AND LOCAL GOVERNMENT



[Home](#) » [Commercial & Industrial](#) » [Programs](#)

NJ SmartStart Buildings

Program Overview

COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

HURRICANE SANDY

PROGRAMS

NJ SMARTSTART BUILDINGS

EQUIPMENT INCENTIVES

FOOD SERVICE EQUIPMENT

APPLICATION FORMS

TOOLS AND RESOURCES

PAY FOR PERFORMANCE

COMBINED HEAT & POWER AND
FUEL CELLS

LOCAL GOVERNMENT ENERGY
AUDIT

LARGE ENERGY USERS PROGRAM

ENERGY SAVINGS IMPROVEMENT
PROGRAM

DIRECT INSTALL

ENERGY BENCHMARKING

OIL, PROPANE & MUNICIPAL
ELECTRIC CUSTOMERS

EDA PROGRAMS

SBC CREDIT PROGRAM



With New Jersey SmartStart Buildings ...

... A smart start now means better performance later! Whether you're starting a commercial or industrial project from the ground up, renovating existing space, or upgrading equipment, there are unique opportunities to upgrade the energy efficiency of the project.

Special Notice

Enhanced incentives are available for NJ SmartStart Building upgrades in buildings impacted by Hurricane Sandy. Eligible projects receive an additional 50% and new incentives have been added for high efficiency food service equipment.

Visit the Sandy web page for details and important links.

New Jersey SmartStart Buildings can provide a range of support — at no cost to you — for substantial energy savings, both now and for the future. Learn more about:

[Project Categories](#)

[Custom Measures](#)

[Incentives for Qualifying Equipment and Projects](#)

[Program Terms and Conditions](#)

[Find a Trade Ally](#)

Please note: pre-approval is required for almost all energy efficiency incentives. To receive an incentive, you must submit an application form (and applicable worksheets) and receive an approval letter from the program before any equipment is installed (click here for complete Terms and Conditions). Upon receipt of an approval letter, you may proceed to install the equipment listed on your approved application. Equipment installed prior to the date of the approval letter is not eligible for an incentive. **Any customer and/or agent who purchases equipment prior to the receipt of an incentive approval letter does so at his/her own risk.**

Getting Started

Submit your project application form as soon as you know you will be doing a construction project or replacing/adding equipment.

PAST PROGRAMS**TOOLS AND RESOURCES****PROGRAM UPDATES****CONTACT US**

Apply for pre-approval by submitting an application for the type of equipment you have or plan to install. The application should be accompanied by a related worksheet, where applicable, manufacturer's specification sheet (refer to the specific program requirements on the background application for specs needed for your project) for the equipment you are planning to install. (Program representatives will review your application package and approve it, reject it, or advise you of upgrades in equipment that will save energy costs and/or increase your incentive.)

Support for Custom Energy-Efficiency Measures

Custom measures allows program participants the opportunity to receive an incentive for energy-efficiency measures that are not on the prescriptive equipment Incentive list, but are project/facility specific.

Incentives for Qualifying Equipment and Projects

Financial incentives are available for large and small projects. These incentives offset some or maybe even all! — of the added cost to purchase qualifying energy-efficient equipment, and provides significant long-term energy savings. Ranges of incentives are available for qualifying equipment (depending on type, size, and efficiency) in several categories.

Find out more about equipment incentives

For specific details on equipment requirements and financial incentives, including incentives for equipment not listed here, contact a program representative. Fiscal year financial incentives will be limited to a maximum of \$500,000 per customer utility account and are available as long as permits are obtained.

[Home](#) | [Residential](#) | [Commercial & Industrial](#) | [Renewable Energy](#)
[About Us](#) | [Press Room](#) | [Library](#) | [FAQs](#) | [Calendar](#) | [Newsletters](#) | [Contact Us](#) | [Site](#)



Your Power to Save

At Home, for Business, and for the Future

[About Us](#) | [Press Room](#) | [Library](#)

HOME

RESIDENTIAL

COMMERCIAL, INDUSTRIAL
AND LOCAL GOVERNMENT



COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

HURRICANE SANDY

PROGRAMS

NJ SMARTSTART BUILDINGS

EQUIPMENT INCENTIVES

FOOD SERVICE EQUIPMENT

APPLICATION FORMS

TOOLS AND RESOURCES

PAY FOR PERFORMANCE

COMBINED HEAT & POWER AND
FUEL CELLS

LOCAL GOVERNMENT ENERGY
AUDIT

LARGE ENERGY USERS PROGRAM

ENERGY SAVINGS IMPROVEMENT
PROGRAM

DIRECT INSTALL

ENERGY BENCHMARKING

OIL, PROPANE & MUNICIPAL
ELECTRIC CUSTOMERS

EDA PROGRAMS

SBC CREDIT PROGRAM

[Home](#) » [Commercial & Industrial](#) » [Programs](#) » [NJ SmartStart Buildings](#)

Equipment Incentives

Special Notice

Enhanced incentives are available for NJ SmartStart Building upgrades in buildings impacted by Hurricane Sandy. Eligible projects receive an additional 50% and new incentives have been added for high efficiency food service equipment.

Visit the Sandy web page for details and important links.

More reasons for a smart start on your next project!

New Jersey SmartStart Buildings provides **financial incentives for qualifying equipment**. These incentives were developed to help our customers offset some of the added cost to purchase qualifying energy-efficient equipment, which provides significant long-term energy savings. A wide range of incentives are available for qualifying equipment (depending on type, size and efficiency).

Listed below are the types of qualifying equipment and ranges of incentives. For details on equipment requirements and full listings of incentives, refer to the **online application forms**.

Please note that almost all equipment incentives require pre-approval before equipment is installed. (click for exceptions) To start the pre-approval process, submit an Equipment Application, and appropriate Equipment Worksheets, for the type of equipment you are planning to install along with equipment specification sheets (refer to the specific program requirements on the back of the application for specific details needed for your project) and a current utility bill(s).

In order to be eligible to receive financial incentives under this Program, Applicants must receive electric and/or gas service from one of the regulated electric and/or gas utilities in the State of New Jersey. They are: Atlantic City Electric, Jersey Central Power & Light, Rockland Electric Company, New Jersey Natural Gas, Elizabethtown Gas, PSE&G, and South Jersey Gas.



Electric Chillers

Water-cooled chillers (\$12 - \$170 per ton)
Air-cooled chillers (\$8 - \$52 per ton)

Gas Cooling

Gas absorption chillers (\$185-\$450 per ton)
Gas Engine-Driven Chillers (Calculated through Custom Measure F

PAST PROGRAMS**TOOLS AND RESOURCES****PROGRAM UPDATES****CONTACT US****Desiccant Systems** (\$1.00 per cfm - gas or electric)**Electric Unitary HVAC**

Unitary AC and split systems (\$73 - \$92 per ton)
 Air-to-air heat pumps (\$73 - \$92 per ton)
 Water-source heat pumps (\$81 per ton)
 Packaged terminal AC & HP (\$65 per ton)
 Central DX AC Systems (\$40 - \$72 per ton)
 Dual Enthalpy Economizer Controls (\$250)
 Occupancy Controlled Thermostats (\$75 each)
 A/C Economizing Controls (\$85 - \$170 each)

Ground Source Heat Pumps

Closed Loop (\$450-750 per ton)

Gas Heating

Gas-fired boilers < 300 MBH (\$300 per unit)
 Gas-fired boilers ≥ 300 MBH - 1500 MBH (\$1.75 per MBH)
 Gas-fired boilers ≥ 1500 MBH - ≤ 4000 MBH (\$1.00 per MBH)
 Gas-fired boilers > 4000 MBH (Calculated through Custom Measure)
 Gas furnaces (\$300-\$400 per unit)
 Gas infrared heaters - indoor only (\$300 - \$500 per unit)
 Boiler economizing controls (\$1,200 - \$2,700 per unit)

Variable Frequency Drives

Variable air volume (\$65 - \$155 per hp)
 Chilled-water pumps (\$60 per hp)
 Compressors (\$5,250 to \$12,500 per drive)

Natural Gas Water Heating

Gas water heaters ≤ 50 gallons (\$50 per unit)
 Gas-fired water heaters > 50 gallons (\$1.00 - \$2.00 per MBH)
 Tankless water heaters replacing a free standing water heater > 82 energy factor (\$300 per heater)
 Gas-fired booster water heaters (\$17 - \$35 per MBH)

Premium Motors

Three-phase motors (\$45 - \$700 per motor) (**Incentive was discontinued effective March 1, 2013 except for buildings impacted by Hurricane Sandy. Approved applications will have the standard timeframe from the program commitment date to complete the installation.**)

Refrigerator/Freezer Case Premium Efficiency Motors (ECM)

Fractional (< 1 HP) Electronic Commutated Motors (ECM) (\$40 per for replacement of existing shaded-pole motor in refrigerated/freezer case)

Prescriptive Lighting

New Linear Fluorescent

T-12, HID and Incandescent to T-5 and T-8 (\$25 - \$200 per fixture) (**Note: T12 replacements are only available for buildings impacted by Hurricane Sandy**)

New Induction (\$70 per replaced HID fixture)

New LED

Screw-in/Plug-in (\$10 - \$20 per lamp)

Refrigerator/Freezer Case (\$30 - \$65 per fixture)

Outdoor pole/arm/wall-mounted luminaires (\$100 - \$175 per fixture)

Display case (\$30 per case)

Shelf-mounted display and task (\$15 per linear foot)

Wall-wash, desk, recessed (\$20 - \$35 per fixture)

Parking garage luminaires (\$100 per fixture)

Track or Mono-Point directional (\$50 per fixture)

Stairwell and Passageway luminaires (\$40 per fixture)

High-Bay, Low-Bay (\$150 per fixture)

Bollard (\$50 per fixture)

luminaires for Ambient Lighting of Interior Commercial Space
Linear panels (\$50 per fixture)

Fuel pump canopy (\$100 per fixture)

LED retrofit kits (custom measures)

New Pulse-Start Metal Halide (\$25 per fixture)

Linear Fluorescent Retrofit (\$10 - \$20 per fixture)

Induction Retrofit (\$50 per retrofitted HID fixture)

New Construction/Complete Renovation (performance-based)

Note: Incentives for T-12 to T-5 and T-8 lamps with electronic ballast in facilities (\$10 per fixture, 1-4 lamps) and T-5/T-8 high bay fixtures (\$16 - per fixture) were discontinued effective March 1, 2013 for T-12 retrofits replacements except for buildings impacted by Hurricane Sandy. Approved applications will have the standard timeframe of one year from the project commitment date to complete the installation

Lighting Controls

Occupancy Sensors

Wall mounted (\$20 per control)

Remote mounted (\$35 per control)

Daylight dimmers (\$25 per fixture controlled, \$50 per fixture for office applications only)

Occupancy controlled hi-low fluorescent controls (\$25 per fixture controlled)

HID or Fluorescent Hi-Bay Controls

Occupancy hi-low (\$35 per fixture controlled)

Daylight dimming (\$45 per fixture controlled)

Refrigeration

Covers and Doors

Energy-Efficient doors for open refrigerated doors/covers (\$100 per door)

Aluminum Night Curtains for open refrigerated cases (\$3.50 per linear foot)

Controls

Door Heater Control (\$50 per control)

Electric Defrost Control (\$50 per control)

Evaporator Fan Control (\$75 per control)

Novelty Cooler Shutoff (\$50 per control)

Food Service Equipment

Cooking

Combination Electric Oven/Steamer (\$1,000 per oven)
 Combination Gas Oven/Steamer (\$750 per oven)
 Electric Convection Oven (\$350 per oven)
 Gas Convection Oven (\$500 per oven)
 Gas Rack Oven (\$1,000 single, \$2,000 double)
 Gas Conveyor Oven (\$500 small deck, \$750 large deck)
 Electric Fryer (\$200 per vat)
 Gas Fryer (\$749 per vat)
 Electric Large Vat Fryer (\$200 per vat)
 Gas Large Vat Fryer (\$500 per vat)
 Electric Griddle (\$300 per griddle)
 Gas Griddle (\$125 per griddle)
 Electric Steam Cooker (\$1,250 per steamer)
 Gas Steam Cooker (\$2,000 per steamer)

Holding

Full Size Insulated Cabinets (\$300 per cabinet)
 Three Quarter Size Insulated Cabinets (\$250 per cabinet)
 Half Size Insulated Cabinets (\$200 per cabinet)

Cooling

Glass Door Refrigerators (\$75 - \$150 per unit)
 Solid Door Refrigerators (\$50 - \$200 per unit)
 Glass Door Freezers (\$200 - \$1,000 per unit)
 Solid Door Freezers (\$100 - \$600 per unit)
 Ice Machines (\$50 - \$500 per unit)

Cleaning

Dishwashers (\$400 - \$1,500 per unit)

Other Equipment Incentives*

Performance Lighting (\$1.00 per watt per square foot below program incentive threshold, currently 5% more energy efficient than ASHRAE 2007 for New Construction only.)

Custom electric and gas equipment incentives (not prescriptive)

*Equipment incentives are calculated based on type, efficiency, size, and application and are evaluated on a case-by-case basis. Contact us for details.

Home | Residential | Commercial & Industrial | Renewable Energy
 About Us | Press Room | Library | FAQs | Calendar | Newsletters | Contact Us | Site

II. DIRECT INSTALL



Your Power to Save

At Home, for Business, and for the Future

[About Us](#) | [Press Room](#) | [Library](#)

HOME

RESIDENTIAL

COMMERCIAL, INDUSTRIAL
AND LOCAL GOVERNMENT

Home » Commercial & Industrial » Programs

Direct Install

COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

HURRICANE SANDY

PROGRAMS

NJ SMARTSTART BUILDINGS

PAY FOR PERFORMANCE

COMBINED HEAT & POWER AND
FUEL CELLSLOCAL GOVERNMENT ENERGY
AUDIT

LARGE ENERGY USERS PROGRAM

ENERGY SAVINGS IMPROVEMENT
PROGRAM

DIRECT INSTALL

PARTICIPATION STEPS

PARTICIPATING
CONTRACTORS

SUSTAINABLE JERSEY

ENERGY BENCHMARKING

OIL, PROPANE & MUNICIPAL
ELECTRIC CUSTOMERS

EDA PROGRAMS

SBC CREDIT PROGRAM

NEW JERSEY'S CLEAN ENERGY PROGRAM

DIRECT Install

Let us pay up to 70% of your energy efficiency upgrade.

Sometimes, the biggest challenge to improving energy efficiency is knowing where to and how to get through the process. Created specifically for existing small to medium facilities, Direct Install is a turnkey solution that makes it easy and affordable to upgrade high efficiency equipment. Direct Install is designed to cut your facility's energy costs replacing lighting, HVAC and other outdated operational equipment with energy efficient alternatives. The program pays up to 70% of retrofit costs, dramatically improving your payback on the project. There is a \$125,000 incentive cap on each project.

ELIGIBILITY



Existing small to mid-sized commercial and industrial facilities with a peak electric demand that did not exceed 200 kW in any of the preceding 12 months are eligible to participate in Direct Install. Applicants will submit the last 12 months of electric utility bills indicating that they are below the demand threshold and have occupied the building during that time. Buildings must be located in New Jersey and served by the state's public, regulated electric or natural gas utility companies.

SYSTEMS & EQUIPMENT ADDRESSED BY THE PROGRAM

Lighting
Heating, Cooling & Ventilation (HVAC)
Refrigeration
Motors
Natural Gas
Variable Frequency Drives



Measures eligible for Direct Install are limited to specific equipment categories, types and capacities. Boilers may not exceed 500,000 Btuh and furnaces may not exceed 140,

III. PAY FOR PERFORMANCE (P4P)



Your Power to Save

At Home, for Business, and for the Future

[About Us](#) | [Press Room](#) | [Library](#)

HOME

RESIDENTIAL

COMMERCIAL, INDUSTRIAL
AND LOCAL GOVERNMENT



COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

HURRICANE SANDY

PROGRAMS

NJ SMARTSTART BUILDINGS

PAY FOR PERFORMANCE

EXISTING BUILDINGS

PARTICIPATION STEPS

APPLICATIONS AND
FORMS

APPROVED PARTNERS

NEW CONSTRUCTION

FAQS

BECOME A PARTNER

COMBINED HEAT & POWER AND
FUEL CELLS

LOCAL GOVERNMENT ENERGY
AUDIT

LARGE ENERGY USERS PROGRAM

ENERGY SAVINGS IMPROVEMENT
PROGRAM

DIRECT INSTALL

ENERGY BENCHMARKING

[Home](#) » [Commercial & Industrial](#) » [Programs](#) » [Pay for Performance](#)

Pay for Performance - Existing Buildings

Download program applications and incentive forms.

The Greater the Savings, the Greater Your Incentives

Take a comprehensive, whole-building approach to saving energy in your existing facility. Earn incentives that are directly linked to your savings. Pay for Performance relies on a



program partners who provide technical services under direct contract to you. Acting as your energy expert, your partner will develop a whole-building energy reduction plan for each project with a whole-building technical component of a traditional energy audit, a financial plan for full implementation of energy efficient measures and a construction schedule for installation.

Eligibility

Existing commercial, industrial and institutional buildings with a peak demand over 100 kW for any of the preceding twelve months are eligible to participate including hotels and casinos, large office buildings, family buildings, supermarkets, manufacturing facilities, schools, shopping malls and restaurants. Buildings that fall into the following customer classes are not required to meet the 100 kW demand threshold to participate in the program: hospitals, public colleges and universities, 501(c)(3) non-profit organizations, affordable multifamily housing, and local governmental entities. Your energy reduction plan will define a comprehensive package of measures capable of reducing the existing energy consumption of your building by 15% or more.

Exceptions to the 15% threshold requirement may be made for certain industrial, manufacturing, water treatment and datacenter building types whose annual energy consumption is heavily weighted on process loads. Details are available in the high energy intensity section of this page.

ENERGY STAR Portfolio Manager

Pay for Performance takes advantage of the ENERGY STAR Program with Portfolio Manager, EPA's interactive tool that allows facility managers to track and evaluate energy and water consumption across all of their buildings. The tool provides the opportunity to load in the characteristics and energy usage of your buildings and determine an energy performance benchmark score. You can then assess energy management goals over time, identify strategic opportunities for savings, and receive EPA recognition for superior energy performance.



This rating system assesses building performance by tracking and scoring energy use in your facilities and comparing it to similar buildings. That can be a big help in locating opportunities for cost-justified energy efficiency upgrades. And, based on our findings, you may be invited to participate in the Building Performance with ENERGY STAR initiative and receive special recognition as an industry leader in energy efficiency.

Incentives

**OIL, PROPANE & MUNICIPAL
ELECTRIC CUSTOMERS**

Pay for Performance incentives are awarded upon the satisfactory completion of three p milestones:

EDA PROGRAMS

Incentive #1 - Submittal of complete energy reduction plan prepared by an app program partner - Contingent on moving forward, incentives will be between \$5 \$50,000 based on approximately \$.10 per square foot, not to exceed 50% of th annual energy expense.

SBC CREDIT PROGRAM

Incentive #2 - Installation of recommended measures - Incentives are based on the projected level of electricity and natural gas savings resulting from the installation of comprehensive energy-efficiency measures.

PAST PROGRAMS

TOOLS AND RESOURCES

Incentive #3 - Completion of Post-Construction Benchmarking Report - A completed report verifying energy reductions based on one year of post-

PROGRAM UPDATES

implementation results. Incentives for electricity and natural gas savings will be based on actual savings, provided that the minimum performance threshold of savings has been achieved.

CONTACT US



A detailed Incentive Structure document is available on the applications and form

Steps to Participation

[Click here](#) for a step-by-step description of the program.

[Home](#) | [Residential](#) | [Commercial & Industrial](#) | [Renewable Energy](#)
[About Us](#) | [Press Room](#) | [Library](#) | [FAQs](#) | [Calendar](#) | [Newsletters](#) | [Contact Us](#) | [Site](#)



PAY FOR PERFORMANCE APPLICATION FORM

July 1, 2013 - June 30, 2014

Utility Serving Applicant:

☐ New Jersey Natural Gas	☐ Atlantic City Electric	☐ Jersey Central Power & Light	☐ PSE&G
☐ Other Electric Service Provider (please specify): _____	☐ Elizabethtown Gas	☐ Rockland Electric Co.	☐ South Jersey Gas
☐ Other Fuel Provider: _____	☐ Oil: _____	☐ Other (Please specify): _____	

Instructions

1. Read the program material to determine project qualification.
2. Read the Participation Agreement and sign where indicated.
3. Fill out all applicable spaces on this form.
4. Provide a copy of the customer's company W-9 form.
5. Provide the most recent consecutive 12 month period of utility bills for the project.

6. Provide brief description of facility.
7. Partner must submit the application package via e-mail, mail or fax **DIRECTLY** to the Market Manager – see back of this form.

Approval of this Application is not an approval of the project's scope of work. Scope of work is only approved upon approval of the Energy Reduction Plan. See application and program guidelines for more information.

Customer/Owner Information (payment will be made to entity entered here)

Company Name		Project Contact/Title	
Company Address		City	State Zip
Phone/Fax	E-mail	Federal ID/SSN	

Partner Information

Company Name		Project Contact/Title	
Company Address		City	State Zip
Phone	Fax	E-mail	

Project Information

Project Name			
Building Address		City	State Zip
Utility Account Number(s): Electric		Gas	
* Note: Please use the back of this page for additional utility accounts if quantity exceeds space allotment.			
Annual Peak kW Demand	Building Type		Number of Buildings
Size of Building(s) (gross sq/ft)		Direct, Master or Sub Metered	

Funding

☐ Check the box if an Energy Savings Improvement Program (ESIP) will be a source of funding. ESIP allows government agencies to pay for energy related improvements using the value of the resulting energy savings.

Do you expect to receive funding under any other efficiency programs? ☐ No ☐ Yes If Yes, please specify below:

Utility Program #1 – Utility: _____	Program Name: _____
Utility Program #2 – Utility: _____	Program Name: _____
Federal Program #1 – Organization: _____	Program Name: _____
Federal Program #2 – Organization: _____	Program Name: _____
Other Program – Organization: _____	Program Name: _____

Additional Project information

Additional Utility Account(s)

Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number

Additional Comments:

Complete this application form and send it directly to the Commercial/Industrial Market Manager by e-mail, mail or fax.

New Jersey's Clean Energy Program
c/o TRC Energy Services-P4P
900 Route 9 North, Suite 404 • Woodbridge, NJ 07095

Phone: 866-657-6278 • Fax: 732-855-0422
E-mail: P4P@NJCleanEnergy.com

Visit our website: NJCleanEnergy.com/P4P

New Jersey SmartStart Buildings[®] is a registered trademark. Use of the mark without the permission of the New Jersey Board of Public Utilities, Office of Clean Energy is prohibited.

*Incentives/Requirements subject to change.



002-FY14-04/14

Pay For Performance-Existing Buildings

Participation Agreement

Definitions:

Design Incentives – Incentives that may be offered to design professionals by the Program.

Design Services – Services that may be offered to design professionals under the Program.

Energy-Efficient Measures – Any device eligible to receive a Program Incentive payment through the NJ Clean Energy Commercial and Industrial Program (New Jersey SmartStart Buildings).

New Jersey Utilities – The regulated electric and/or gas utilities in the State of New Jersey. They are: Atlantic City Electric, Jersey Central Power & Light, Rockland Electric Company, New Jersey Natural Gas, Elizabethtown Gas, PSE&G, and South Jersey Gas.

Administrator – New Jersey Board of Public Utilities, Office of Clean Energy

Participating Customers – Those non-residential electric and/or gas service customers of the New Jersey Utilities who participate in this Program.

Product Installation or Equipment Installation – Installation of the Energy-Efficient Measures.

Projects with a contract threshold of \$14,187 (increasing to \$15,444 effective July 1, 2014) are required to pay no less than prevailing wage rate to workers employed in the performance of any construction undertaken in connection with Board of Public Utilities financial assistance, or undertaken to fulfill any condition of receiving Board of Public Utilities financial assistance, including the performance of any contract to construct, renovate or otherwise prepare a facility, the operations of which are necessary for the receipt of Board of Public Utilities financial assistance. By submitting an application, or accepting program incentives, applicant agrees to adhere to New Jersey Prevailing Wage requirements, as applicable.

Program – The Commercial and Industrial Energy-Efficient Construction Program (New Jersey SmartStart Buildings) offered herein by the New Jersey Board of Public Utilities, Office of Clean Energy pursuant to state regulatory approval under the New Jersey Electric Discount and Energy Competition Act, NJSA 48:3-49, et seq.

Program Incentives – Refers to the amount or level of incentive that the Program provides to Participating Customers pursuant to the Program offered herein (see description under "Incentive Amount" heading).

Program Offer – Program Incentives are available to non-residential retail electric and/or gas service customers of the New Jersey Utilities identified above.

Program Manager – TRC Energy Services.

Application and Eligibility Process – The Program pays incentives after the installation of qualified energy-efficient

measures that were pre-approved (for exceptions to this condition, please refer to "Exceptions for Approval".) In order to be eligible for Program Incentives, a Customer, or an agent (contractor/vendor) authorized by a Customer, must submit a properly completed application package. The package must include an application signed by the customer; a complete (current) utility bill; and technology worksheet and manufacturer's cut sheets (where appropriate). This information must be submitted to the Program Manager before equipment is installed. Applications for measures that are self installed by customers must be submitted by the customer and not the sales vendor of the measure, however, the customer may elect to assign payment of the incentive to the sales vendor. This application package must be received by the Program Manager on or before June 30, 2014 in order to be eligible for the fiscal year July 1, 2013-June 30, 2014 incentives. The Program Manager will review the application package to determine if the project is eligible for a Program Incentive. If eligible, the Customer will receive an approval letter with the estimated authorized incentive amount and the date by which the equipment must be installed in order for the approval to remain in effect. Upon receipt of an approval letter, the Customer may then proceed to install the equipment listed on the approved application. Equipment installed prior to the date of the Program Manager's approval letter is not eligible for an incentive. The Program Manager reserves the right to conduct a pre-inspection of the facility prior to the installation of equipment. This will be done prior to the issuance of the approval letter. All equipment must be purchased within 12 months of date of application. **Any Customer and/or agent who purchases equipment prior to the receipt of an incentive approval letter does so at his/her own risk.**

Exceptions for Approval – The Application and Eligibility Process pertains to all projects except for those involving either Gas Heating, Unitary HVAC or Motors having an incentive amount less than \$5,000 that were installed within 12 months of receipt of the application. These measures, at this incentive level, may be installed without prior approval. In addition, but at the sole discretion of the Program Manager, emergency replacement of equipment may not require a prior approval determination and letter. **In such cases, please notify the Program Manager of such emergencies as early as possible, that an application will soon be sent in that was not pre-approved.**

Post-Installation Approval – After installation is completed, the Customer, or an agent authorized by the Customer, must finalize and submit an invoice for the purchase of the equipment (material cost must be broken out from labor costs), and any other required documentation as specified on the equipment application or in the Program Manager's initial approval letter.

Please refer to the program guide on the NJCleanEnergy.com/ssb website for the complete Application and Eligibility Process.

The Program Manager reserves the right to verify sales transactions and to have reasonable access to Participating Customer's facility to inspect both pre-existing product or equipment (if applicable) and the Energy-Efficient Measures

installed under this Program, either prior to issuing incentives or at a later time.

Energy-Efficient Measures must be installed in buildings located within a New Jersey Utilities' service territory and designated on the Participating Customer's incentive application. Program Incentives are available for qualified Energy-Efficient Measures as listed and described in the Program materials and incentive applications. The Participating Customer must ultimately own the equipment, either through an up-front purchase or at the end of a short-term lease. Design Incentives are available to design professionals as described in the Program materials and applications. A different and separate agreement must be executed by participating design professionals to be eligible for this type of incentive. The design professional does not need to be based in New Jersey.

Equipment procured by Participating Customers through another program offered by New Jersey's Clean Energy Program or the New Jersey Utilities, as applicable, is not eligible for incentives through this program. Customers who have not contributed to the Societal Benefits Charge of the applicable New Jersey Utility are not be eligible for incentives offered through this program.

Incentive Amount – Program Incentives will equal either: a) the approved Program Incentive amount, or b) the actual equipment cost of the Energy-Efficient Measure, whichever is less, as determined by the Program Manager. Products offered at no direct cost to the customer are ineligible. Incomplete application submissions, applications requiring inspections and unanticipated high volume of activities may cause processing delays. Program Incentives are limited to \$500,000 per utility account in a calendar year. Contact the Program Manager regarding any questions.

Tax Liability – The Program Manager will not be responsible for any tax liability that may be imposed on any Participating Customer as a result of the payment of Program Incentives. All Participating Customers must supply their federal tax identification number or social security number to the Program Manager on the application form in order to receive a Program Incentive. In addition, Participating Customers must also provide a Tax Clearance Form (entitled "Business Assistance or Incentive Clearance Certificate") that is dated within 90 days of equipment installation.

Endorsement – The Program Manager and Administrator do not endorse, support or recommend any particular manufacturer, product or system design in promoting this Program.

Warranties – THE PROGRAM MANAGER AND ADMINISTRATOR DO NOT WARRANT THE PERFORMANCE OF INSTALLED EQUIPMENT, AND/OR SERVICES RENDERED AS PART OF THIS PROGRAM, EITHER EXPRESSLY OR IMPLICITLY. NO WARRANTIES OR REPRESENTATIONS OF ANY KIND, WHETHER STATUTORY, EXPRESSED, OR IMPLIED, INCLUDING, WITHOUT LIMITATIONS, WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE REGARDING EQUIPMENT OR SERVICES PROVIDED BY A MANUFACTURER OR VENDOR. CONTACT YOUR VENDOR/SERVICES PROVIDER FOR DETAILS REGARDING PERFORMANCE AND WARRANTIES.

Limitation of Liability – By virtue of participating in this Program, Participating Customers agree to waive any and all claims or damages against the Program Manager or the Administrator, except the receipt of the Program Incentive. Participating Customers agree that the Program Manager's and Administrator's liability, in connection with this Program, is limited to paying the Program Incentive specified. Under no circumstances shall the Program Manager, its representatives, or subcontractors, or the Administrator, be liable for any lost profits, special, punitive, consequential or incidental damages or for any other damages or claims connected with or resulting from participation in this Program. Further, any liability attributed to the Program Manager under this Program shall be individual, and not joint and/or several.

Assignment – The Participating Customer may assign Program Incentive payments to a specified vendor.

Participating Customer's Certification – Participating Customer certifies that he/she purchased and installed the equipment listed in their application at their defined New Jersey location. Participating Customer agrees that all information is true and that he/she has conformed to all of the Program and equipment requirements listed in the application.

Termination – The New Jersey Board of Public Utilities reserves the right to extend, modify (this includes modification of Program Incentive levels) or terminate this Program without prior or further notice.

Acknowledgement – I have read, understood and am in compliance with all rules and regulations concerning this incentive program. I certify that all information provided is correct to the best of my knowledge, and I give the Program Manager permission to share my records with the New Jersey Board of Public Utilities, and contractors it selects to manage, coordinate or evaluate the NJ SmartStart Buildings Program. Additionally, I allow reasonable access to my property to inspect the installation and performance of the technologies and installations that are eligible for incentives under the guidelines of New Jersey's Clean Energy Program.

CUSTOMER'S SIGNATURE
PARTNER SIGNATURE
By signing, I certify that I have read, understand and agree to the Participation Agreement listed above.

IV. ENERGY SAVINGS IMPROVEMENT PLAN (ESIP)



Your Power to Save

At Home, for Business, and for the Future

[About Us](#) | [Press Room](#) | [Library](#)

HOME

RESIDENTIAL

COMMERCIAL, INDUSTRIAL
AND LOCAL GOVERNMENT

COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

HURRICANE SANDY

PROGRAMS

NJ SMARTSTART BUILDINGS

PAY FOR PERFORMANCE

COMBINED HEAT & POWER AND
FUEL CELLSLOCAL GOVERNMENT ENERGY
AUDIT

LARGE ENERGY USERS PROGRAM

ENERGY SAVINGS IMPROVEMENT
PROGRAM

DIRECT INSTALL

ENERGY BENCHMARKING

OIL, PROPANE & MUNICIPAL
ELECTRIC CUSTOMERS

EDA PROGRAMS

SBC CREDIT PROGRAM

PAST PROGRAMS

TOOLS AND RESOURCES

PROGRAM UPDATES

CONTACT US

Home » Commercial & Industrial » Programs

Energy Savings Improvement Program

A new State law allows government agencies to make energy related improvements to their facilities and pay for the costs using the value of energy savings that result from the improvements. Under Chapter 4 of the Laws of 2009 (the law), the "Energy Savings Improvement Program" (ESIP), provides all government agencies in New Jersey with a flexible tool to make energy related improvements to their facilities and pay for the costs using the value of energy savings that result from the improvements. The program provides all government agencies in New Jersey with a flexible tool to make energy related improvements to their facilities and pay for the costs using the value of energy savings that result from the improvements.

This Local Finance Notice outlines how local governments can develop and implement an ESIP for their facilities. Below are two sample RFPs:

Local Government
School Districts (K-12)

All RFPs must be submitted to the Board for approval at ESIP@bpu.state.nj.us.

The Board also adopted protocols to measure energy savings:

Measuring Energy Savings
Procedures for Implementation

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Local units should carefully consider all alternatives to develop an approach that best meets their needs. Local units considering an ESIP should carefully review the Local Finance Notice, the law, and consult with qualified professionals to determine how they should approach the task.

The NJ Board of Public Utilities sponsored Sustainable Jersey in the creation of an ESIP Guidebook that explains how to implement the program. The guidebook also includes a list of successful projects and a list of helpful resources.

FIRST STEP – ENERGY AUDIT

For local governments interested in pursuing an ESIP, the first step is to perform an energy audit as prescribed in P.L.2012 c.55.

ENERGY REDUCTION PLANS

If you have an ESIP plan that needs to be submitted to the Board of Public Utilities, please email it to ESIP@bpu.state.nj.us. Please limit the file size to 3MB (or break it into smaller files).

Frankford Township School District
Northern Hunterdon-Voorhees Regional High School
Manalapan Township (**180 MB** - Right Click, Save As)

ESIP PROGRAM

Final version 42413

BPU RULES

1. Public Entity must decide if they will use an ESCO or DIY method or Hybrid thereof prior to issuing the RFP and the RFP must state the intended method. A change in the project procurement model after the RFP closing date will be cause for immediate rejection and disqualification of potential Clean Energy program incentives.
2. RFP procedures shall be adhered to as per the legislation, including the use of BPU approved forms. Any alteration of the forms, without prior approval from the BPU shall be grounds for rejection.
3. RFP must include copy of an audit (ASHRAE Level II w/Level III for lighting) and audit must be prepared by a firm classified by DPMC in the 036 discipline.
4. All firms, including professional services, whether using ESCO or DIY model, must be DPMC classified.
5. If an Architect is engaged by the public entity, the architectural fees are the responsibility of the public entity and must be paid directly to the firm. These fees may be included in the energy cost savings analysis and payback.

ESCO's may contract directly with an architectural firm, in which case the architectural firm serves as a subcontractor to the ESCO and the project related service costs may be included within the project's economic model.

6. Public entity shall conduct pre-bid meetings and site visits per existing statutes.

In the interest of open public bidding transparency, it is a requirement of the BPU that all proposers must attend the pre-proposal bid meeting.

7. There shall be no negative cash flow in any year of the program.
section 7 (1)(a)
"the energy savings resulting from the program will be sufficient to cover the cost of the program's energy conservation measures."
8. SREC values are not permitted to be used in the energy cost savings calculations.
9. Capital cost avoidance values are not to be used in the energy savings calculations.
10. Operational and Maintenance (O&M) cost savings may be permitted in the cost savings calculations, but only with supporting documentation.
11. Blended utility rates shall not be permitted. Use the actual utility tariff or local contracted rates if there is a third party supplier.

For the RFP proposals, the public entity shall define the utility rates in the RFP

12. Contracted third party utility rates may only be used for the term of the contract (5 yr. maximum)
Subsequent years are to be projected at the utility tariff rates plus the annual BPU escalation rates.
13. Public entity shall conduct M&V (measurement and verification) at the one (1) year operational date and shall provide a copy of the M&V report to the Board of Public Utilities.

For the RFP proposals, the ESCO shall provide the cost for the one (1) year M&V only. For comparative purposes, the one year M&V pricing shall be indicated on the proposal Form VI, under the “Annual Service Costs” column. Additional M&V costs are at the discretion of the local unit and are not to be included in the proposal.

14. The decisions made by BPU staff regarding compliance or other issues that arise in connection with the RFP procurement process shall be considered a final decision of the BPU. Any appeal will need to be through the New Jersey Superior Court, Appellate Division.
15. For the RFP proposals only, Demand Response (DR) revenues claimed by ESCO’s can only be projected for a maximum period of three (3) years. DR revenue projections beyond three years will not be permitted. DR revenues must be included and presented under the “Energy Rebates/Incentives” column of FORM VI.
16. ESCO “fees” proposed during the RFP phase of the project cannot increase post-award. ESCO’s are required to maintain the fee percentages through final contract negotiations and construction of the Board approved Energy Savings Plan
17. Public Bid openings shall be held on the due date of the proposal submissions. The public entity shall announce the name of the bidder and the total dollar amount. After award of a contract, all proposals received will be made available by the owner for public inspection
18. Rejection of bids by the public entity shall be conducted in accordance with the appropriate sections of the applicable legislation, as stated in Title 40A:11-13.2. Additionally all proposals must be returned to the respective ESCO’s upon rejection.
19. Field changes that exceed 5% of the project cost require BPU approval.
20. Energy Savings Plans (ESP) that is dependent upon incentives from the Clean Energy Program must review the current program requirements, at the time of application, for each incentive to insure eligibility. If any program incentive is denied, resubmission of all ESIP related forms will be necessary to remain ESIP qualified.

APPENDIX E

Photovoltaic Analysis

Photovoltaic (PV) Solar Power Generation - Screening Assessment

NEWARK PUBLIC SCHOOL DISTRICT BARD EARLY COLLEGE, NEWARK BRIDGES, PEOPLES PREP CHARTER

Cost of Electricity	\$0.14	/kWh
Electricity Usage	1,114,500	kWh/yr
System Unit Cost	\$4,000	/kW

NO FURTHER PV RECOMMENDED

Photovoltaic (PV) Solar Power Generation - Screening Assessment

Budgetary	Annual Utility Savings				Estimated	Total		New Jersey	Payback	Payback
Cost					Maintenance	Savings	Federal Tax	Renewable	(without	(with
					Savings		Credit	** SREC	SREC	SREC
\$	kW	kWh	therms	\$	\$	\$	\$	\$	Years	Years
\$0	0.0	0	0	\$0	0	\$0	\$0	\$0	#DIV/0!	#DIV/0!

** Estimated Solar Renewable Energy Certificate Program (SREC) SREC for 15 Years= \$155 /1000kwh

Area Output*

0 m2
0 ft2

Perimeter Output*

0 m
0 ft

Available Roof Space for PV:

(Area Output - 5 ft x Perimeter) x 65%
0 ft2

Approximate System Size:

Is the roof flat? (Yes/No) Yes

8 watt/ft2
0 DC watts
0 kW

Enter into PV Watts

PV Watts Inputs***

Array Tilt Angle 20 Enter into PV Watts (always 20 if flat, if pitched - enter estimated roof angle)
Array Azimuth 180 Enter into PV Watts (default)
Zip Code 07103 Enter into PV Watts
DC/AC Derate Factor 0.83 Enter into PV Watts

PV Watts Output

annual kWh calculated in PV Watts program

% Offset Calc

Usage 1,114,500 (from utilities)
PV Generation 0 (generated using PV Watts)
% offset 0%



* <http://www.freemaptools.com/area-calculator.htm>
** <http://www.flettexchange.com>
*** http://gisatnrel.nrel.gov/PVWatts_Viewer/index.html

APPENDIX F

Photos



1: Existing hot water boilers (7 total)



2: Heating hot water pump motors



3: Portable window air conditioning unit



4: Boiler controller system



5: Domestic hot water (DHW) boiler



6: DHW storage tank



7: Sample corridor lighting fixtures



8: Sample multi-purpose room lighting fixtures



9: Sample classroom lighting fixtures

APPENDIX G

EPA Portfolio Manager



ENERGY STAR[®] Statement of Energy Performance

17

ENERGY STAR[®]
Score¹

Bard Early College High School

Primary Property Function: K-12 School
Gross Floor Area (ft²): 153,163
Built: 1973

For Year Ending: May 31, 2013
Date Generated: May 07, 2014

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information

Property Address

Bard Early College High School
321 Bergen Street 07103
Newark, New Jersey 07103

Property Owner

Newark Public Schools
2 Cedar Street
Newark, NJ 07102
() -

Primary Contact

Newark Public Schools
2 Cedar Street
Newark, NJ 07102
9737337334
webmaster@nps.k12.nj.us

Property ID: 3902977

Energy Consumption and Energy Use Intensity (EUI)

Site EUI

81.4 kBtu/ft²

Annual Energy by Fuel

Electric - Grid (kBtu)	3,261,189 (26%)
Natural Gas (kBtu)	9,200,007 (74%)

National Median Comparison

National Median Site EUI (kBtu/ft ²)	59.3
National Median Source EUI (kBtu/ft ²)	94.7
% Diff from National Median Source EUI	37%

Source EUI

129.9 kBtu/ft²

Annual Emissions

Greenhouse Gas Emissions (Metric Tons CO ₂ e/year)	901
---	-----

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: _____ Date: _____

Licensed Professional

,
() -



Professional Engineer Stamp
(if applicable)