

CARTERET BOARD OF EDUCATION

CARTERET BOARD OFFICE

599 Roosevelt Avenue, NJ 07008

**LOCAL GOVERNMENT ENERGY AUDIT PROGRAM
FOR
NEW JERSEY
BOARD OF PUBLIC UTILITIES**

June 2015

Prepared by:



6 Campus Drive
Parsippany, NJ 07054
(973) 538-2120

CHA PROJECT NO. 30201

TABLE OF CONTENTS

1.0 EXECUTIVE SUMMARY	1
2.0 BUILDING INFORMATION AND EXISTING CONDITIONS.....	4
3.0 UTILITIES	7
4.0 BENCHMARKING	11
5.0 ENERGY CONSERVATION MEASURES.....	12
5.1 ECM-1 Add Attic Insulation to R-38	12
5.2 ECM-2 Replace Windows in Rear Wing.....	13
5.3 ECM-3 Steam to Hot Water Conversion	14
5.4 ECM-4 Window A/C Unit Controllers	15
5.5 ECM-5 Replace Gas DHW Heater w/ Condensing DHW Heater	15
5.6 ECM-6 Install Low Flow Plumbing Fixtures	16
5.7.1 ECM-L1 Lighting Replacement / Upgrades	16
5.7.2 ECM-L2 Install Lighting Controls (Occupancy Sensors)	17
5.7.3 ECM-L3 Lighting Replacements with Controls (Occupancy Sensors)	17
5.8 Additional O&M Opportunities.....	18
6.0 PROJECT INCENTIVES	19
6.1 Incentives Overview	19
6.1.1 New Jersey Smart Start Program.....	19
6.1.2 Direct Install Program	19
6.1.3 New Jersey Pay For Performance Program (P4P).....	20
6.1.4 Energy Savings Improvement Plan	21
6.1.5 Renewable Energy Incentive Program.....	22
7.0 ALTERNATIVE ENERGY SCREENING EVALUATION	23
7.1 Solar	23
7.1.1 ECM-S1 Photovoltaic Rooftop Solar Power Generation.....	23
7.1.2 Solar Thermal Hot Water Generation.....	24
7.2 Wind Powered Turbines.....	24
7.3 Combined Heat and Power Plant.....	25
7.4 Demand Response Curtailment	26

8.0 CONCLUSIONS & RECOMMENDATIONS.....	27
--	----

APPENDICES

- A Utility Usage Analysis and List of Third Party Energy Suppliers
- B Equipment Inventory
- C ECM Calculations and Cost Estimates
- D New Jersey BPU Incentive Programs
 - i. Smart Start
 - ii. Direct Install
 - iii. Pay For Performance Incentive Program (P4P)
 - iv. Energy Savings Improvement Plan (ESIP)
- F Photos
- G EPA Benchmarking Report

REPORT DISCLAIMER

This audit was conducted in accordance with the standards developed by the American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) for a Level II audit. Cost and savings calculations for a given measure were estimated to within $\pm 20\%$, and are based on data obtained from the owner, data obtained during site observations, professional experience, historical data, and standard engineering practice. Cost data does not include soft costs such as engineering fees, legal fees, project management fees, financing, etc.

A thorough walkthrough of the building was performed, which included gathering nameplate information and operating parameters for all accessible equipment and lighting systems. Unless otherwise stated, model, efficiency, and capacity information included in this report were collected directly from equipment nameplates and /or from documentation provided by the owner during the site visit. Typical operation and scheduling information was obtained from interviewing staff and spot measurements taken in the field.

List of Common Energy Audit Abbreviations

- A/C – Air Conditioning
- AHS – Air Handling Unit
- BMS – Building Management System
- Btu – British thermal unit
- CDW – Condenser Water
- CFM – Cubic feet per minute
- CHW – Chilled Water
- DCV – Demand Control Ventilation
- DDC – Direct Digital Control
- DHW – Domestic Hot Water
- DX – Direct Expansion
- EER – Energy Efficiency Ratio
- EF – Exhaust Fan
- EUI – Energy Use Intensity
- Gal – Gallon
- GPD – Gallons per day
- GPF – Gallons Per Flush
- GPH – Gallons per hour
- GPM – Gallons per minute
- GPS – Gallons per second
- HHW – Heating Hot Water
- HID – High Intensity Discharge
- HP – Horsepower
- HRU – Heat Recovery Unit
- HVAC – Heating, Ventilation, Air Conditioning
- HX – Heat Exchanger
- kbtu/mbtu – One thousand (1,000) Btu
- kW – Kilowatt (1,000 watts)
- kWh – Kilowatt-hours
- LED – Light Emitting Diode
- mbh – Thousand Btu per hour
- mmbtu – One million (1,000,000) Btu
- OCC – Occupancy Sensor
- PSI – Pounds per square inch
- RTU – Rooftop Unit
- SBC – System Benefits Charge
- SF – Square foot
- UH – Unit Heater
- V – Volts
- VAV – Variable Air Volume
- VSD – Variable Speed Drive
- W – Watt

1.0 EXECUTIVE SUMMARY

This report summarizes the energy audit performed by CHA for the Carteret Board Office in connection with the New Jersey Board of Public Utilities (NJBPU) Local Government Energy Audit (LGEA) Program. The purpose of this report is to identify energy savings opportunities associated with major energy consumers and inefficient practices. Low-cost and no-cost are also identified during the study. This report details the results of the energy audit conducted for the building listed below:

Building Name	Address	Square Feet	Construction Date
Carteret Board Office	599 Roosevelt Avenue, Carteret, NJ 07008	17,248	1939

The potential total annual energy and cost savings for the recommended energy conservation measures (ECM) identified in the survey are shown below:

Building Name	Electric Savings (kWh)	NG Savings (therms)	Total Savings (\$)	Payback (years)
Carteret Board Office	44,389	2,084	9,623	16.8

The annual savings for each individual measure are dependent on that measure alone, there are no interactive effects calculated. There are three options shown for Lighting ECM savings; only one option can be chosen. Incentives shown (if any) are based only on the SmartStart Incentive Program. Other NJBPU or local utility incentives may also be available/ applicable and are discussed in Section 6.0.

Each measure recommended by CHA typically has a stand-alone simple payback period of 15 years or less. However, if the owner chooses to pursue an Energy Savings Improvement Plan (ESIP), high payback measures could be bundled with lower payback measures which ultimately can result in a payback which is favorable for an ESIP project to proceed. Occasionally, we will recommend an ECM that has a longer payback period, based on the need to replace that piece(s) of equipment due to its age, such as a boiler for example.

The following table provides a detailed summary of each ECM for the building surveyed, including costs, savings, SmartStart incentives and payback.

Summary of Energy Conservation Measures

ECM #	Energy Conservation Measure	Est. Costs (\$)	Est. Savings (\$/year)	Payback w/o Incentive	Potential Incentive (\$)*	Payback w/ Incentive	Recommended
1	Install Attic Insulation to R-38	17,452	1,700	10.3	0	10.3	Y
2	Replace Windows in Rear Addition	56,100	1,032	54.3	0	54.3	Y
3	Steam to Hot Water Conversion	740,969	3,717	199.3	2,000	198.8	N
4	Window A/C Unit Controllers	3,500	2,225	1.6	0	1.6	Y
5	Replace Gas DHW Heater w/ Condensing DHW Heater	8,848	178	49.8	300	48.1	Y
6	Install Low Flow Plumbing Fixtures	32,387	871	37.2	0	37.2	Y
L1*	Lighting Replacements	47,185	3,161	14.9	4,830	13.4	N
L2*	Lighting Controls	5,130	1,194	4.3	400	4.0	N
L3	Lighting Replacements with Controls	52,315	3,795	13.8	5,230	12.4	Y
Total**		911,570	13,518	67.4	7,530	66.9	
Total (Recommended)		161,753	9,623	16.8	5,230	16.3	

* Incentive shown is per the New Jersey SmartStart Program.


** These ECMs are not included in the Total, as they are alternate measures not recommended.

The following alternative energy measures are also recommended for further study:

- Photovoltaic (PV) Rooftop Solar Power Generation – 10 kW System

If the Carteret Board of Education implements the recommended ECMs, energy savings would be as follows:

	Existing Conditions	Post Recommended ECMs	Percent Savings
Costs (\$)	35,188	25,565	27%
Electricity (kWh)	170,960	126,571	26%
Natural Gas (therms)	7,685	5,601	27%
Site EUI (kbtu/SF/Yr)	78.4	57.5	



2.0 BUILDING INFORMATION AND EXISTING CONDITIONS

The following is a summary of building information related to HVAC, plumbing, building envelope, lighting, kitchen equipment and domestic hot water systems as observed during CHAs site visit. See appendix B for detailed information on mechanical equipment, including capacities, model numbers and age. See appendix F for some representative photos of some of the existing conditions observed while onsite.

Building Name: Carteret Board Office

Address: 599 Roosevelt Avenue, Carteret, NJ 07008

Gross Floor Area: 17,248 Square Feet

Number of Floors: 2 and a basement

Year Built: 1939



Description of Spaces: Board personnel offices, administration, conference rooms, training rooms, storage rooms, network room, mechanical rooms, and restrooms.

Description of Occupancy: There are approximately 50 employees, and at any given time there are approximately 150 members of the public within the building.

Number of Computers: The building has approximately 30 desktop and laptop computers.

Building Usage: Hours of operation for the Carteret Board Office are 7:00 am to 5:00 pm Monday through Friday.

Building Envelope

Construction Materials: The Carteret Board Office is a steel framed building with CMU and brick exterior walls without insulation. Interior walls are constructed of wooden studs with plaster and lathe walls, as well as sheetrock finish, except for the elevator core chase which is CMW.

Roof: The roof is flat and surfaced with a rolled asphalt sheeting over rigid insulation and wooden decking, and appears to be in good condition. The roof structure is framed by wooden joists with a substantial attic space, and no visible insulation. An ECM adding attic insulation is considered.

Windows The building has mostly aluminum framed double pane windows installed in 1996. Although these appear to be in good condition, maintenance personnel indicated that some of these windows leak when it rains. The rear single story storage wing has older 1960's vintage single pane windows in aluminum frames which are in poor condition. An ECM for window replacement is included.

Exterior Doors: Exterior doors throughout the building are aluminum framed with full length safety glass, and solid metal doors for employee use only. There is a vestibule at each public entrance. Sweeps and seals are in good condition. No additional ECMs are evaluated for exterior doors.

Heating Ventilation & Air Conditioning (HVAC) Systems

Heating: One Weil McLain model 88 series 2 boiler with a Powerflame gas burner provides steam heat for the building. The boiler has a capacity of 2,887 MBH and is approximately eight (8) years old. The boiler supplies steam via a two-pipe steam heating system to unit ventilators, unit heaters, and perimeter radiators around the building. The rear storage area is heated and ventilated by an air handling unit outfitted with a steam heating coil. A small electric unit heater provides additional heat to this space. A condensate receiver / duplex pump system returns the steam condensate to the boiler.

Cooling: The building is almost entirely air conditioned except for the rear storage area. This space is equipped with an under-sized window A/C unit, and is exhausted by the AHU in the warmer months—its fan switched to reverse in the summertime. The offices and conference rooms are cooled by 1 ton window A/C units and by 2.5 ton Fujitsu split DX units.

Ventilation: Every room and office in the building is located on an exterior wall and thus has outside air available through the double-hung openable windows. Ventilation air is provided to two offices via unit ventilators ducted to louvers installed in the exterior wall. In general, building ventilation is adequate and no associated ECMs are included.

Exhaust: The facility utilizes exhaust fans of various sizes located on the roof to exhaust air from restrooms and storage areas, and provide general pressure relief.

Controls Systems

The Carteret Board Office does not have a building-wide BMS temperature controls system. Radiators and other steam heating units have individual thermostats directly connected to the units themselves. The primary boiler is turned on in October and turned off at the end of April. Similarly, DX cooling units are each individually controlled with their own dedicated thermostats. Temperatures in the building are maintained between 70-72°F in the heating season and 73-75°F in the cooling season during both occupied and unoccupied times. No temperature controls related ECMs are included.

Domestic Hot Water Systems

Domestic hot water is provided to lavatory sinks by one 50 gallon Rheemglas Fury type gas fired water heater with a capacity of 36,000 BTUH. Domestic hot water is used primarily for hand-washing. As these units are new, no ECMs related to the DHW are considered.

Kitchen Equipment

The building does not have a kitchen; but it does have a break-room with a microwave and a residential style refrigerator. No ECMs were included for kitchen equipment.

Plug Load

The Carteret Board Office building has computers, copiers, residential appliances (microwave, refrigerator), printers, and portable heaters which contribute to the plug load in the building. By implementing other ECMs, plug load from the portable heaters may be reduced.

Plumbing Systems

Plumbing fixtures are 1960's vintage high flow fixtures with wall recessed urinals and 3.5 GPF water closets. Some of the lavatory sinks have been upgraded to the metering type spring-loaded lavatory faucets. Toilet rooms do have high flow fixtures, and ECMs evaluating these fixtures are included.

Lighting Systems

Lighting is primarily T-8 32watt fluorescent lamps mounted in a variety of fixture types. Corridors have 2x4 recessed ceiling fixtures with three lamps per fixture. Some offices have 4' pendant hung fixtures with 2 lamps per fixture; or 4' ceiling recessed fixtures with 2 lamps per fixture. The large storeroom area has 2x4 hanging fixtures with 4 lamps per fixture. CFL lamps are used in a couple storage spaces. All light fixtures are switched. Exterior lighting consists of wall mounted 150 watt metal halide wall-packs, 400 watt metal halide pole-mounted lamps, and 80 watt induction lights.

Three lighting ECMs have been included which include adding occupancy sensors to the existing lighting, replacement of the T-8 lighting with LED lighting and a third ECM that evaluates the effect of occupancy sensors used with the LED lighting upgrades.

3.0 UTILITIES

Utilities used by the building are delivered and supplied by the following utility companies:

	Electric	Natural Gas
Deliverer	PSE&G	Elizabethtown Gas
Supplier	Direct Energy	Woodruff Energy


For the 12-month period ending in May 2015, the utilities usages and costs for the building were as follows:

Electric		
Annual Consumption	170,960	kWh/yr.
Annual Cost	25,614	\$
Blended Unit Rate	0.150	\$/kWh
Supply Rate	0.128	\$/kWh
Demand Rate	5.22	\$/kW
Peak Demand	67.2	kW
Natural Gas		
Annual Usage	7,685	Therms/yr.
Annual Cost	9,574	\$
Rate	1,246	\$/therm
Water		
Annual Consumption	42,636	gallons/yr.
Annual Cost	1,559	\$
Rate	0.037	\$/gallon


Blended Rate: Average rate charged determined by the annual cost / annual usage

Supply Rate: Actual rate charged for electricity usage in kWh (based on most recent electric bill)

Demand Rate: Rate charged for actual electrical demand in kW (based on most recent electric bill)



The electrical usage for this building is relatively constant, with somewhat increased usage in the summer months for air conditioning. Spring and summer peaks occur during the maximum cooling season. The peaks during winter months which could be caused by electric heaters.



The natural gas usage is mostly driven by space heating in the winter months with a steep drop-off of usage during the summer months. The building does not have kitchen use, and only one small DHW heater.

See Appendix A for utility analysis.

Under New Jersey's energy deregulation law, the supply portion of the electric (or natural gas) bill is separated from the delivery portion. The supply portion is open to competition, and customers can shop around for the best price for their energy suppliers. The electric and natural gas distribution utilities will still deliver the gas/ electric supplies through their wires and pipes – and respond to emergencies, should they arise – regardless of where those supplies are purchased. Purchasing the energy supplies from a company other than your electric or gas utility is purely an economic decision; it has no impact on the reliability or safety of the service.

Comparison of Utility Rates to NJ State Average Rates*				Recommended to Shop for Third Party Supplier?
Utility	Units	Building Average Rate	NJ Average Rate	
Electricity	\$/kWh	\$0.15	\$0.13	Y
Natural Gas	\$/Therm	\$1.25	\$0.96	Y

* Per U.S. Energy Information Administration (2013 data – Electricity and Natural Gas)


Additional information on selecting a third party energy supplier is available here:

<http://www.state.nj.us/bpu/commercial/shopping.html>.

See Appendix A for a list of third-party energy suppliers licensed by the Board of Public Utilities to sell within the building's service area.

The charts below represent estimated utility end-use utility profiles for the building. The values used within the charts were estimated from a review of the utility analysis and the energy savings calculations.


Site End-Use Utility Profile



Most of the electricity consumed by municipal buildings is used to for lighting, cooling, and plug loads such as computers and copiers; most of the natural gas is used for space heating. Each

building's energy profile is different, and the following charts represent typical utility profiles for commercial buildings per U.S. Department of Energy.

Typical End-Use Utility Profile for Commercial Buildings



Courtesy: E SOURCE; from Commercial Building Energy Consumption Survey, 1999 data

4.0 BENCHMARKING

The EPA Portfolio Manager benchmarking tool provides a site and source Energy Use Intensity (EUI), as well as an Energy Star performance rating for qualifying building types. The EUIs are provided in kBtu/ft²/year, and the performance rating represents how energy efficient a building is on a scale of 1 to 100, with 100 being the most efficient. In order for a building to receive an Energy Star label, the energy benchmark rating must be at least 75. As energy use decreases from implementation of the proposed measures, the Energy Star rating will increase.

The site EUI is the amount of heat and electricity consumed by a building as reflected in utility bills. Site energy may be delivered to a facility in the form of primary energy, which is raw fuel burned to create heat or electricity, such as natural gas or oil; or as secondary energy, which is the product created from a raw fuel such as electricity or district steam. To provide an equitable comparison for different buildings with varying proportions of primary and secondary energy consumption, Portfolio Manager uses the convention of source EUIs. The source energy also accounts for losses incurred in production, storage, transmission, and delivery of energy to the site, which provide an equivalent measure for various types of buildings with differing energy sources. The results of the benchmarking are contained in the table below.

Building	Site EUI kBtu/ft ² /yr	Source EUI Btu/ft ² /yr	Energy Star Rating (1-100)
Carteret Board Office	78.4	153.0	63

The building has an above average Energy Star Rating Score (50 being the median score). By implementing the measures discussed in this report, it is expected that the EUI can be reduced and the Energy Star Rating further increased.

5.0 ENERGY CONSERVATION MEASURES

The following types of energy savings opportunities are identified in this section of the report:

- Energy conservation measures (ECMs) are energy savings recommendations that typically require a financial investment. For these areas of opportunity, CHA prepared detailed calculations, as summarized in this section and in Appendix C. In general, additional savings may exist from reductions in maintenance activities associated with new equipment or better controls; however for conservatism, maintenance savings are not accounted for in this report; instead the only savings which are reported are those derived directly from reductions in energy which can be tracked by the utility bills.
- Operational and Maintenance measures (O&M) consist of low- or no-cost operational opportunities, which if implemented would have positive impacts on overall building operation, comfort levels, and/or energy usage. There are no estimated savings, costs or paybacks associated with the O&M measures included as part of this study.

Energy savings were quantified in the form of:

- electrical usage (kWh=Kilowatt-hour),
- electrical demand (kW=kilowatts),
- natural gas (therms=100,000 Btu),
- propane gas (gallons=91,650 Btu),
- fuel oil (gallons =138,700 Btu), and
- water (kgal=1,000 gallons).

These recommendations are influenced by the time period that it takes for a proposed project to “break even” referred to as “Simple Payback”. Simple payback is calculated by dividing the estimated cost of implementing the ECM by the energy cost savings (in dollars) of that ECM.

Another financial indicator of the performance of a particular ECM is the Return on Investment or ROI, which represents the benefit (annual savings over the life of a project) of an investment divided by the cost of the investment. The result is expressed as a percentage or ratio.

Two other financial analyses included in this report are Internal Rate of Return (IRR) and Net Present Value (NPV). Internal Rate of Return is the discount rate at which the present value of a project costs equals the present value of the project savings. Net Present Value is the difference between present value of an investment’s future net cash flows and the initial investment. If the NPV equals “0”, the project would equate to investing the same amount of dollars at the desired rate. NPV is sometimes referred to as Net Present Worth. These values are provided in the Summary Tab in Appendix C.

5.1 ECM-1 Add Attic Insulation to R-38

Portions of the attic were investigated during the site visit, and no insulation was observed installed either above the original ceiling or into the rafter spaces underneath the roof deck. It is estimated that the insulating value of the existing roof assembly has a thermal resistance value of R-9. Providing insulation into the attic will further reduce heat loss from the building.

To calculate the savings, the heat losses through the roof assembly of the facility were found using the existing roof's R-value of 9 and bin weather data. The values were totaled to determine the existing annual energy losses. Heating and cooling energy loss values were then determined with a thermal resistance which included the additional R-29 fiberglass batting insulation. The total proposed roof R-value with insulation is approximately R-38.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-1 Add Attic Insulation to R-38

Budgetary Cost	Annual Utility Savings			ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas				
\$	kW	kWh	Therms	\$	%	\$	Years
17,452	0	1,013	1,243	1,700	1.4	0	10.3

* Does not qualify for Incentive from the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities

This measure is recommended.

5.2 ECM-2 Replace Windows in Rear Wing

Although the majority of windows in the building are newer, aluminum framed type with double panes, the rear single story wing is outfitted with 1970's vintage single pane windows in deteriorating frames. These windows can only provide average thermal resistance to heat transfer. Energy loss due to excess air infiltration and radiated heat transfer is occurring between the building and its surroundings. An assessment is included which considers the installation of double pane windows with aluminum frames.

The calculation uses bin weather data, and the occupied & unoccupied building temperature set-points for these bin hours. This is converted into energy losses for both occupied and unoccupied cases using the existing window U-factor. The two are summed together to create an annual baseline for existing utility usage. The same steps are performed for the new windows to calculate the proposed utility usage. The difference in heating losses through the windows results in annual heating natural gas and cooling electricity savings.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized as follows:

ECM-2 Replace Windows in Rear Wing

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
\$	kW	kWh	Therms	\$		\$	Years	Years
56,100	0	0	828	1,032	(0.7)	0	54.3	54.3

This measure is recommended, despite the long payback.

5.3 ECM-3 Steam to Hot Water Conversion

The heating system consists of one (1) steam boiler providing steam via a two-pipe system to various radiators, unit ventilators, and unit heaters around the building.

Steam heating systems are inherently inefficient and require high maintenance as compared to re-circulated hot water heating systems or other modern heating systems. As steam systems age, the steam traps fail which then requires more untreated cold make-up water. This in turn requires more chemical treatment and increases the risk of boiler thermal shock. Steam piping becomes fouled with scale and corrosion over time resulting in poor heat transfer and ultimately pipe failure. Steam heating systems use boilers that only operate up to 84% combustion efficiency and have even lower thermal efficiency. Multiple condensate pumps and boiler feed water pumps consume electricity that would not be needed in other modern heating systems.

In lieu of replacing the boilers in kind, this ECM evaluates replacing the steam system in its entirety with a more efficient hot water system. New modulating condensing gas boilers are available that minimally operate at 88%, and can operate as high as 96%. To implement this ECM, the old steam boilers, distribution piping, venting and terminal units would be removed and the new hot water boilers, distribution piping and primary pumps put in their place. Significant piping and wiring modifications would be needed. New dedicated boiler venting would also need to be installed either through the roof or sidewall. Asbestos abatement may need to be performed prior to any work and the cost for this is not included in the payback analysis.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-3 Steam to Hot Water Conversion

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
\$	kW	kWh	Therms	\$		\$	Years	Years
740,969	0	0	2,857	3,717	(0.9)	2,000	>100	>100

* Incentive shown is per the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities.

This measure is not recommended.

5.4 ECM-4 Window A/C Unit Controllers

Approximately seventeen (17) window air conditioners were noted throughout the building during the site visit, in miscellaneous offices and locations. These units will occasionally be left 'on' when the room is not occupied, which is wasteful of energy.

This ECM evaluates the installation of programmable "smart" timers that interrupt the electrical supply to the window air conditioners when cooling is not needed due to the room being unoccupied. The timers are configurable to operate as a standalone timer or they can be wirelessly interconnected to provide remote temperature control using software.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-4 Window A/C Unit Controllers

Budgetary Cost	Annual Utility Savings			ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas				
\$	kW	kWh	Therms	\$	%	\$	Years
3,500	0	14,835	0	2,225	5.4	0	1.6

* Does not qualify for Incentive from the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities.

This measure is recommended.

5.5 ECM-5 Replace Gas DHW Heater w/ Condensing DHW Heater

The building has one gas-fired 50 gallon Rheemglas Fury hot water heater which has a rated thermal efficiency of 81%. The domestic hot water heater serves the toilet rooms and sinks located throughout the office building. Energy savings could be realized by replacing the existing unit with a high efficiency condensing gas fired heater, which can operate at efficiencies up to 94% and will not suffer from standby energy loss from the storage tank.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-5 Replace Gas DHW Heater w/ Condensing DHW Heater

Budgetary Cost	Annual Utility Savings			ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas				
\$	kW	kWh	Therms	\$	%	\$	Years
8,848	0	0	143	178	(0.7)	300	49.8

* Does not qualify for Incentive from the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities.

This measure is recommended.

5.6 ECM-6 Install Low Flow Plumbing Fixtures

The plumbing fixtures in this building are older high flow fixtures. The water savings associated from replacing existing high flow fixtures with low-flow fixtures was calculated by taking the difference of the annual water usage for the proposed and base case. The basis of this calculation is the estimate usage of each fixture, gallons per use, and number of fixtures. Replacing the existing fixtures in the restrooms with 1.28 Gals/flush toilets, 1.0 gal/flush urinals, and 0.5 gpm faucets will conserve water which will result in lower annual water and sewer charges. Facets with low-flow push valves were not considered for replacement.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-6 Install Low Flow Plumbing Fixtures

Budgetary Cost	Annual Utility Savings					ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Water	Total				
\$	kW	kWh	Therms	kGal	\$	%	\$	Years	Years
32,387	0	0	13	23	871	(1.0)	0	37.2	37.2

* Does not qualify for Incentive from the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities

This measure is recommended despite the long payback period.

5.7.1 ECM-L1 Lighting Replacement / Upgrades

The lighting within the Carteret Board Office Building offices consists of 2x4 and 2x2 recessed and ceiling mounted troffers having 32W T8 fluorescent lamps with prismatic lenses. Several areas also contain recessed cans outfitted with compact fluorescent lamps. Storage areas also contain CFLs, as well as a few incandescent bulbs. A combination of occupancy sensors and wall switches control the interior lighting.

Overall energy consumption can be reduced by replacing inefficient bulbs and linear fluorescent bulbs with more efficient LED technology. To compute the annual savings for this ECM, the energy consumption of the current lighting fixtures was established and compared to the proposed fixture power requirement with the same annual hours of operation. The difference between the existing and proposed annual energy consumption was the energy savings. These calculations are based on 1 to 1 replacements of the fixtures, and do not take into account lumen output requirements for a given space. A more comprehensive engineering study should be performed to determine correct lighting levels.

Supporting calculations, including assumptions for lighting hours and annual energy usage for each fixture, are provided in Appendix C and summarized below:

ECM-L1 Lighting Replacement / Upgrades

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
\$	kW	kWh	Therms	\$		\$	Years	Years
47,185	7.8	23,386	0	3,161	(0.2)	4,830	14.9	13.4

* LED retrofits must go through the "custom" measures incentive option under New Jersey SmartStart Program. There are no "prescriptive" incentives for LED retrofits. Projects must achieve a minimum of 75,000 kWh annual savings to qualify for "custom" incentives. See section 6.0 for other incentive opportunities

This measure is not recommended in lieu of ECM L3.

5.7.2 ECM-L2 Install Lighting Controls (Occupancy Sensors)

Presently, interior lighting fixtures are controlled by a combination of wall mounted switches and occupancy sensors. Review of the comprehensive lighting survey determined that lighting in some areas could benefit from installation of occupancy sensors to turn off lights when they are unoccupied.

This measure recommends installing occupancy sensors for the current lighting system. Using a process similar to that utilized in Section 5.7.1, the energy savings for this measure was calculated by applying the known fixture wattages in the space to the estimated existing and proposed times of operation for each fixture.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-L2 Install Lighting Controls (Occupancy Sensors)

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
\$	kW	kWh	Therms	\$		\$	Years	Years
5,130	0	9,707	0	1,194	1.8	400	4.3	4.0

* Incentive shown is per the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities.

This measure is not recommended in lieu of ECM L3.

5.7.3 ECM-L3 Lighting Replacements with Controls (Occupancy Sensors)

This measure is a combination of ECM-L1 and ECM-L2; recommending replace/upgrade the current lighting fixtures to more efficient ones and installing occupancy sensors on the new lights. Interactive effects of the higher efficiency lights and occupancy sensors lead the energy and cost savings for this measure to not be cumulative or equivalent to the sum of replacing the lighting fixtures alone and installing occupancy sensors without the lighting upgrade. The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-L3 Lighting Replacements with Controls (Occupancy Sensors)

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
\$	kW	kWh	Therms	\$		\$	Years	Years
52,315	7.8	28,541	0	3,795	(0.1)	5,230	13.8	12.4

* LED retrofits must go through the "custom" measures incentive option under New Jersey SmartStart Program. There are no "prescriptive" incentives for LED retrofits. Projects must achieve a minimum of 75,000 kWh annual savings to qualify for "custom" incentives. See section 6.0 for other incentive opportunities

This measure is recommended.

5.8 Additional O&M Opportunities

This list of operations and maintenance (O&M) - type measures represent low-cost or no-cost opportunities, which if implemented will have a positive impact on the overall building operations, comfort and/or energy consumption. The recommended O&M measures for this building are as follows:

- Set computers monitors to turn off and computers to sleep mode when not in use
- Purchase ENERGY STAR® label Appliances
- Disconnect unnecessary or unused small appliances and electronics when not in use to reduce phantom loads
- Train staff to turn off lights when rooms are unoccupied
- Develop an Energy Master Plan to measure and track energy performance

6.0 PROJECT INCENTIVES

6.1 Incentives Overview

The following sections give detailed information on available incentive programs including New Jersey Smart Start, Direct Install, New Jersey Pay for Performance (P4P) and Energy Savings Improvement Plan (ESIP). If Carteret Board of Education wishes to and is eligible to participate in the Energy Savings Improvement Plan (ESIP) program and/or the Pay for Performance Incentive Program (P4P), it cannot participate in either the Smart Start or Direct Install Programs. Refer to Appendix D for more information on the Smart Start program.

6.1.1 New Jersey Smart Start Program

For this energy audit, The New Jersey Smart Start Incentives are used in the energy savings calculations, where applicable. This program is intended for medium and large energy users and provides incentives for:

- Electric Chillers
- Gas Chillers
- Gas Heating
- Unitary HVAC
- Ground Source Heat Pumps
- Variable frequency Drives/ motors
- Refrigeration
- Prescriptive and performance lighting and lighting controls

The equipment is procured using a typical bid- build method, installed and paid for and then the incentives are reimbursed to the owner.

Refer to Appendix D for more information on the Smart Start program.

6.1.2 Direct Install Program

The Direct Install Program applies to smaller facilities that have a peak electrical demand of 200 kW or less in any of the previous 12 months. Buildings must be located in New Jersey and served by one of the state's public, regulated electric utility companies.

Direct Install is funded through New Jersey's Clean Energy Program and is designed to provide capital for building energy upgrade projects to fast track implementation. The program will pay up to 70% of the costs for lighting, HVAC, motors, refrigeration, and other equipment upgrades with higher efficiency alternatives. If a building is eligible for this funding, the Direct Install Program can reduce the implementation cost of energy conservation projects.

The Direct Install program has specific HVAC equipment and lighting requirements and is generally applicable only to smaller package HVAC units, small boilers and lighting retrofits.

The program pays a maximum amount of \$75,000 per building, and up to \$250,000 per customer per year. Installations must be completed by an approved Direct Install participating contractor, a list of which can be found on the New Jersey Clean Energy Website. Contractors will coordinate with the applicant to arrange installation of recommended measures identified in a previous energy assessment, such as this energy audit. The incentive is reimbursed to the Owner upon successful replacement and payment of the equipment.

The building does not qualify for this program because its electrical demand is greater than the maximum peak electrical demand of 200 kW for the last 12 month period.

Refer to Appendix D for more information on this program.

6.1.3 New Jersey Pay For Performance Program (P4P)

This building may be eligible for incentives from the New Jersey Office of Clean Energy. The most significant incentives are available from the New Jersey Pay for Performance (P4P) Program. The P4P program is designed to offset the cost of energy conservation projects for facilities that pay the Societal Benefits Charge (SBC) and whose demand (kW) in any of the preceding 12 months exceeds 100 kW. This demand minimum has been waived for buildings owned by local governments or municipalities and non-profit organizations and *is not applicable to public schools*. Facilities that meet this criterion must also achieve a minimum performance target of 15% energy reduction by using the EPA Portfolio Manager benchmarking tool before and after implementation of the measure(s). Additionally, the overall return on investment (ROI) must exceed 10%. If the participant is a municipal electric company customer, and a customer of a regulated gas New Jersey Utility, only gas measures will be eligible under the Program. Available incentives are as follows:

Incentive #1: Energy Reduction Plan – This incentive is designed to offset the cost of services associated with the development of the Energy Reduction Plan (ERP). The ERP must include a detailed energy audit of the desired ECMs, energy savings calculations (using building modeling software) and inputting of all utility bills into the EPA Portfolio Manager website.

- Incentive Amount: \$0.10/SF
- Minimum incentive: \$5,000
- Maximum Incentive: \$50,000 or 50% of Facility annual energy cost

The standard incentive pays \$0.10 per square foot, up to a maximum of \$50,000, not to exceed 50% of facility annual energy cost, paid after approval of application. For building audits funded by the New Jersey Board of Public Utilities, which receive an initial 75% incentive toward performance of the energy audit, facilities are only eligible for an additional \$0.05 per square foot, up to a maximum of \$25,000, rather than the standard incentive noted above. The ERP must be completed by a Certified Energy Manager (CEM) and submitted along with the project application.

Incentive #2: Installation of Recommended Measures – This incentive is based on projected energy savings as determined in Incentive #1 (Minimum 15% savings must be achieved), and is paid upon successful installation of recommended measures.

Electric

- Base incentive based on 15% savings: \$0.09/ per projected kWh saved.
- For each % over 15% add: \$0.005 per projected kWh saved.
- Maximum incentive: \$0.11/ kWh per projected kWh saved.

Gas

- Base incentive based on 15% savings: \$0.90/ per projected Therm saved.
- For each % over 15% add: \$0.05 per projected Therm saved.
- Maximum incentive: \$1.25 per projected Therm saved.

Incentive cap: 25% of total project cost

Incentive #3: Post-Construction Benchmarking Report – This incentive is paid after acceptance of a report proving energy savings over one year utilizing the Environmental Protection Agency (EPA) Portfolio Manager benchmarking tool.

Electric

- Base incentive based on 15% savings: \$0.09/ per projected kWh saved.
- For each % over 15% add: \$0.005 per projected kWh saved.
- Maximum incentive: \$0.11/ kWh per projected kWh saved.

Gas

- Base incentive based on 15% savings: \$0.90/ per projected Therm saved.
- For each % over 15% add: \$0.05 per projected Therm saved.
- Maximum incentive: \$1.25 per projected Therm saved.

Combining Incentives #2 and #3 will provide a total of \$0.18/ kWh and \$1.8/therm not to exceed 50% of total project cost. Additional Incentives for #2 and #3 are increased by \$0.005/kWh and \$0.05/therm for each percentage increase above the 15% minimum target to 20%, calculated with the EPA Portfolio Manager benchmarking tool, not to exceed 50% of total project cost.

For the purpose of demonstrating the eligibility of the ECM's to meet the minimum savings requirement of 15% annual savings and 10% ROI for the Pay for Performance Program, all ECM's identified in this report have been included in the incentive calculations. The results for the building are shown in Appendix C, with more detailed program information in Appendix D.

6.1.4 Energy Savings Improvement Plan

The Energy Savings Improvement Program (ESIP) allows government agencies to make energy related improvements to their facilities and pay for the costs using the value of energy savings that result from the improvements. Under the recently enacted Chapter 4 of the Laws of 2009 (the law), the ESIP provides all government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources.

ESIP allows local units to use “energy savings obligations” (ESO) to pay for the capital costs of energy improvements to their facilities. ESIP loans have a maximum loan term of 15 year. ESOs are not considered “new general obligation debt” of a local unit and do not count against debt limits or require voter approval. They may be issued as refunding bonds

or leases. Savings generated from the installation of energy conservation measures pay the principal of and interest on the bonds; for that reason, the debt service created by the ESOs is not paid from the debt service fund, but is paid from the general fund.

For local governments interested in pursuing an ESIP, the first step is to perform an energy audit. Pursuing a Local Government Energy Audit through New Jersey's Clean Energy Program is a valuable first step to the ESIP approach. The "Local Finance Notice" outlines how local governments can develop and implement an ESIP for their facilities. The ESIP can be prepared internally if the entity has qualified staff. If not, the ESIP must be implemented by an independent contractor and not by the energy savings company producing the Energy Reduction Plan.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Local units should carefully consider all alternatives to develop an approach that best meets their needs. Refer to Appendix D for more information on this program.

6.1.5 Renewable Energy Incentive Program

The Renewable Energy Incentive Program (REIP) is part of New Jersey's efforts to reach its Energy Master Plan goals of striving to use 30 percent of electricity from renewable sources by 2020.

Incentives for sustainable bio-power projects and for energy storage projects are currently under development, with competitive solicitations for each of those technologies expected to begin in the first quarter of 2014. The wind program is currently on hold.

New solar projects are no longer eligible for REIP incentives, but can register for Solar Renewable Energy Certificates (SRECs) through the SREC Registration Program (SRP).

7.0 ALTERNATIVE ENERGY SCREENING EVALUATION

7.1 Solar

7.1.1 ECM-S1 Photovoltaic Rooftop Solar Power Generation

The building was evaluated for the potential to install rooftop photovoltaic (PV) solar panels for power generation. Present technology incorporates the use of solar cell arrays that produce direct current (DC) electricity. This DC current is converted to alternating current (AC) with the use of an electrical device known as an inverter. The amount of available roof area determines how large of a solar array can be installed on any given roof. The table below summarizes the approximate roof area available on the building and the associated solar array size that can be installed.

Available Roof Area (Ft ²)	Potential PV Array Size (kW)
1,499	10

The PVWATTS solar power generation model was utilized to calculate PV power generation; this model is provided in Appendix E.

Installation of (PV) arrays in the state New Jersey will allow the owner to participate in the New Jersey Solar Renewable Energy Certificates Program (SREC). This is a program that has been set up to allow entities with large amounts of environmentally unfriendly emissions to purchase credits from zero emission (PV) solar-producers. An alternative compliance penalty (ACP) is paid for by the high emission producers and is set each year on a declining scale of 3% per year. One SREC credit is equivalent to 1000 kilowatt hours of PV electrical production; these credits can be traded for period of 15 years from the date of installation. Payments that will be received by the PV producer (school) will change from year to year dependent upon supply and demand. There is no definitive way to calculate an exact price that will be received by the PV producer for SREC credits over the next 15 years. Renewable Energy Consultants estimates an average of \$155/SREC for 2014 and this number was utilized in the cash flow for this report.

The system costs for PV installations were derived from recent solar contractor budgetary pricing in the state of New Jersey and include the total cost of the system installation (PV panels, inverters, wiring, ballast, controls). The cost of installation is currently about \$4.00 per watt or \$4,000 per kW of installed system, for a typical system. There are other considerations that have not been included in this pricing, such as the condition of the roof and need for structural reinforcement. Photovoltaic systems can be ground mounted if the roof is not suitable, however, this installation requires a substantial amount of open property (not wooded) and underground wiring, which adds more cost. PV panels have an approximate 20 year life span; however, the inverter device that converts DC electricity to AC has a life span of 10 to 12 years and will most likely need to be replaced during the useful life of the PV system.

The implementation cost and savings related to this ECM are presented in Appendix E and summarized as follows:

Photovoltaic (PV) Rooftop Solar Power Generation – 10 kW System

Budgetary Cost	Annual Utility Savings			Total Savings	New Jersey Renewable SREC	Payback (without SREC)	Payback (with SREC)	Recommended
	Electricity		Natural Gas					
\$	kW	kWh	Therms	\$	\$	Years	Years	
40,000	10.0	12,749	0	1,912	2,167	20.9	9.8	FS

Note: CHA typically recommends a more detailed evaluation be conducted for the installation of PV Solar arrays when the screening evaluation shows a payback of less than 20 years. Therefore, this ECM is recommended for further study. Before implementation is pursued, the school district should consult with a certified solar PV contractor.

7.1.2 Solar Thermal Hot Water Generation

Active solar thermal systems use solar collectors to gather the sun's energy to heat a fluid. An absorber in the collector (usually black colored piping) converts the sun's energy into heat. The heat is transferred to circulating water, antifreeze, or air for immediate use or is storage for later utilization. Applications for active solar thermal energy include supplementing domestic hot water, heating swimming pools, space heating or preheating air in residential and commercial buildings.

A standard solar hot water system is typically composed of solar collectors, heat storage vessel, piping, circulators, and controls. Systems are typically integrated to work alongside a conventional heating system that provides heat when solar resources are not sufficient. The solar collectors are usually placed on the roof of the building, oriented south, and tilted at the same angle as the site's latitude, to maximize the amount of solar radiation collected on a yearly basis.


Several options exist for using active solar thermal systems for space heating. The most common method is called a passive solar hot water system involves using glazed collectors to heat a liquid held in a storage tank (similar to an active solar hot water system described above which requires pumping). The most practical system would transfer the heat from the panels to thermal storage tanks and then use the pre-heated water for domestic hot water production. DHW is presently produced by natural gas fired water heaters and, therefore, this measure would offer natural gas utility savings. Unfortunately, the amount of domestic hot water that is currently used by this building is very small. Installing a solar domestic hot water system is not recommended due to the limited amount of domestic hot water presently consumed by the building.

This measure is not recommended due to the relatively low domestic hot water usage.

7.2 Wind Powered Turbines

Wind power is the conversion of kinetic energy from wind into mechanical power that is used to drive a generator which creates electricity by means of a wind turbine. A wind turbine consists of rotor and blades connected to a gearbox and generator that are mounted onto a tower. Newer wind turbines also use advanced technology to generate electricity at a variety of frequencies depending on the wind speed, convert it to DC and

then back to AC before sending it to the grid. Wind turbines range from 50 – 750 kW for utility scale turbines down to below 50 kW for residential use. On a scale of 1 (the lowest) to 7 (the highest), Class 3 and above (wind speeds of 13 mph or greater) are generally considered “good wind resource” according to the Wind Energy Development Programmatic EIS Information Center hosted by the Bureau of Land Management. According to the map below, published by NREL, Carteret, NJ is classified as Class 1 at 50m, meaning the city would not be a good candidate for wind power.



This measure is not recommended due to the location of the building.

7.3 Combined Heat and Power Plant

Combined heat and power (CHP), cogeneration, is self-production of electricity on-site with beneficial recovery of the heat byproduct from the electrical generator. Common CHP equipment includes reciprocating engine-driven, micro turbines, steam turbines, and fuel cells. Typical CHP customers include industrial, commercial, institutional, educational institutions, and multifamily residential facilities. CHP systems that are commercially viable at the present time are sized approximately 50 kW and above, with numerous options in blocks grouped around 300 kW, 800 kW, 1,200 kW and larger. Typically, CHP systems are used to produce a portion of the electricity needed by a facility some or all of the time, with the balance of electric needs satisfied by purchase from the grid.

Any proposed CHP project will need to consider many factors, such as existing system load, use of thermal energy produced, system size, natural gas fuel availability, and proposed plant location. The building has sufficient need for electrical generation and the ability to use most of the thermal byproduct during the winter; however thermal usage during the summer months does not exist. Thermal energy produced by the CHP plant in the warmer months will be wasted. An absorption chiller could be installed to utilize the heat to produce chilled water; however, there is no chilled water distribution system in the building. CHP is not recommended due to the building's limited summer thermal demand.

This measure is not recommended due to the absence of year-round thermal loads which are needed for efficiency CHP operation.

7.4 Demand Response Curtailment

Presently, electricity is delivered by PSE&G, which receives the electricity from regional power grid RFC. PSE&G is the regional transmission organization (RTO) that coordinates the movement of wholesale electricity in all or parts of 13 states and the District of Columbia including the State of New Jersey.

Utility Curtailment is an agreement with the utility provider's regional transmission organization and an approved Curtailment Service Provider (CSP) to shed electrical load by either turning major equipment off or energizing all or part of a facility utilizing an emergency generator; therefore, reducing the electrical demand on the utility grid. This program is to benefit the utility company during high demand periods and utility provider offers incentives to the CSP to participate in this program. Enrolling in the program will require program participants to drop electrical load or turn on emergency generators during high electrical demand conditions or during emergencies. Part of the program also will require that program participants reduce their required load or run emergency generators with notice to test the system.

A pre-approved CSP will require a minimum of 100 kW of load reduction to participate in any curtailment program. From January 2013 through December 2013 the following table summarizes the electricity load profile for the building.

Building Electric Load Profile

Peak Demand kW	Min Demand kW	Avg Demand kW	Onsite Generation Y/N	Eligible? Y/N
67.2	32.8	50.3	N	N

This measure is not recommended for further review because the building is not eligible for the program.

8.0 CONCLUSIONS & RECOMMENDATIONS

The following section summarizes the LGEA energy audit conducted by CHA for the Carteret Board Office.

The following projects should be considered for implementation:

- Insulate the Attic
- Replace the Windows in the Rear Addition
- Install Window A/C Unit Controllers
- Install Low Flow Plumbing Fixtures
- Lighting Replacements with Controls (Occupancy Sensors)

The potential annual energy and cost savings for the recommended ECMs are shown in the following table.

Electric Savings (kWh)	Natural Gas Savings (therms)	Total Savings (\$)	Payback (years)
44,389	2,084	9,623	16.8

If the recommended ECMs are implemented, energy savings would be as follows:

	Existing Conditions	Post Recommended ECMs	Percent Savings
Costs (\$)	35,188	25,565	27%
Electricity (kWh)	170,960	126,571	26%
Natural Gas (therms)	7,685	5,601	27%
Site EUI (kbtu/SF/Yr)	78.4	57.5	

Next Steps: This energy audit has identified several areas of potential energy savings. Carteret Board of Education can use this information to pursue incentives offered by the NJBPU's NJ Clean Energy Program.

APPENDIX A

Utility Usage Analysis and Alternate Utility Suppliers

**Carteret School District
Carteret Board Office
599 Roosevelt Ave. Carteret, NJ 07008**

Utility Bills: Account Numbers


<u>Account Number</u>	<u>Building</u>	<u>Meter Location</u>	<u>Type</u>	<u>Notes</u>
69 908 745 03	Carteret Board Office	599 Roosevelt Ave. Carteret, NJ 07008	Electric	
4607346130	Carteret Board Office	599 Roosevelt Ave. Carteret, NJ 07008	Gas	
5544300000	Carteret Board Office	599 Roosevelt Ave. Carteret, NJ 07008	Water	

Carteret School District
Carteret Board Office
599 Roosevelt Ave. Carteret, NJ 07008


Annual Utilities
12-month Summary

Electric		
Annual Usage	170,960	kWh/yr
Annual Cost	25,614	\$
Blended Rate	0.150	\$/kWh
Consumption Rate	0.128	\$/kWh
Demand Rate	5.22	\$/kW
Peak Demand	67.2	kW
Min. Demand	32.8	kW
Avg. Demand	50.3	kW
Natural Gas		
Annual Usage	7,685	Therms/yr
Annual Cost	9,574	\$
Rate	1.246	\$/therm
Water		
Annual Usage	42,636	Gallons
Annual Cost	1,559	\$
Rate	0.037	\$/Gallon
Energy Summary		
Building Area	17,248	SF
Energy Usage Intensity (EUI)	78	KBtu/SF/yr
Energy Cost Index (ECI)	2.13	\$/SF/yr
Total Annual Utility Costs	36,747	\$

Utility	KBtu	%
Electric	583,340	43%
Natural Gas	768,277	57%
	1,351,616	100%



Utility	\$	%
Electric	25,614	73%
Natural Gas	9,574	27%
	35,188	100%



Carteret School District
Carteret Board Office
599 Roosevelt Ave. Carteret, NJ 07008

Electric Service

For Service at: 599 Roosevelt Ave. Carteret, NJ 07008

Account No.: 69 908 745 03

Meter No.: 9200294


Delivery: PSE&G


Supply: Direct Energy

Month	Consump. (kWh)	Demand (kW)	Provider Charges			Usage (kWh) vs. Demand (kW) Charges		Unit Costs				
			Delivery (\$)	Supplier (\$)	Total (\$)	Consumption (\$)	Demand (\$)	Delivery (\$/kWh)	Supplier (\$/kWh)	Consumption Rate (\$/kWh)	Demand (\$/kW)	Blended Rate (\$/kWh)
April-14	15,920	32.8	659.79	1,086.36	1,746.15	1605.75	140.40	0.041	0.068	0.101	4.280	0.110
May-14	12,000	32.8	532.95	1,071.88	1,604.83	1464.43	140.40	0.044	0.089	0.122	4.280	0.134
June-14	11,840	38.4	930.07	1,267.42	2,197.49	1728.57	468.92	0.079	0.107	0.146	12.211	0.186
July-14	16,160	53.6	1,259.39	1,462.96	2,722.35	2068.51	653.84	0.078	0.091	0.128	12.199	0.168
August-14	15,680	53.6	1,253.71	1,419.51	2,673.22	2440.83	232.39	0.080	0.091	0.156	4.336	0.170
September-14	15,680	53.6	1,253.73	1,419.51	2,673.24	2440.84	232.40	0.080	0.091	0.156	4.336	0.170
October-14	12,960	53.6	635.63	1,173.27	1,808.90	1576.51	232.39	0.049	0.091	0.122	4.336	0.140
November-14	12,160	53.6	605.33	1,100.84	1,706.17	1473.78	232.39	0.050	0.091	0.121	4.336	0.140
December-14	14,240	53.6	668.39	1,289.15	1,957.54	1725.15	232.39	0.047	0.091	0.121	4.336	0.137
January-15	15,680	53.6	712.23	1,419.51	2,131.74	1899.35	232.39	0.045	0.091	0.121	4.336	0.136
February-15	14,480	53.6	676.56	1,310.87	1,987.43	1755.04	232.39	0.047	0.091	0.121	4.336	0.137
March-15	13,920	67.2	572.88	1,386.92	1,959.80	1814.09	145.71	0.041	0.100	0.130	2.168	0.141
April-15	16,160	53.6	727.95	1,462.96	2,190.91	1958.25	232.66	0.045	0.091	0.121	4.341	0.136
Total (All)	186,880	67.20	\$10,488.61	\$16,871.16	\$27,359.77	\$23,951.10	\$3,408.67	\$0.06	\$0.09	\$0.13	\$5.22	\$0.15
Total (last 12-months)	170,960	67.20	\$9,828.82	\$15,784.80	\$25,613.62	\$22,345.35	\$3,268.27	\$0.06	\$0.09	\$0.13	\$5.26	\$0.15
Notes	1	2	3	4	5			6	7			8

- 1.) Number of kWh of electric energy used per month
- 2.) Number of kW of power measured
- 3.) Electric charges from Delivery provider
- 4.) Electric charges from Supply provider - note, includes 8.875% tax
- 5.) Total charges (Delivery + Supplier)
- 6.) Delivery Charges (\$) / Consumption (kWh)
- 7.) Supplier Charges (\$) / Consumption (kWh)
- 8.) Total Charges (\$) / Consumption (kWh)
- 9.) Values highlighted are estimated

Carteret Board Office - Electric Usage



Carteret Board Office - Electric Rates

**Carteret School District
Carteret Board Office
599 Roosevelt Ave. Carteret, NJ 07008**

Natural Gas Service

For Service at: 599 Roosevelt Ave. Carteret, NJ 07008


Account No.: 4607346130

Meter No: 00338312

Delivery: Elizabethtown Gas

Supply: Woodruff Energy

Month	Consumption (Therms)	Delivery Charges (\$)	Supply Charges (\$)	Total Charges (\$)	Rate (\$/Therm)
May-14	0.00	20.00	2.80	22.80	N/A
June-14	0.00	20.00	2.80	22.80	N/A
July-14	0.00	20.00	2.80	22.80	N/A
August-14	0.00	20.00	2.80	22.80	N/A
September-14	10.30	23.06	1.96	25.02	2.43
October-14	21.70	26.51	12.53	39.04	1.80
November-14	655.20	224.23	329.72	553.95	0.85
December-14	1,162.30	392.48	566.15	958.63	0.82
January-15	1,689.00	564.20	1,388.85	1,953.05	1.16
February-15	2,049.20	680.25	1,820.85	2,501.10	1.22
March-15	1,615.00	491.25	1,784.80	2,276.05	1.41
April-15	481.90	154.70	1,021.38	1,176.08	2.44
Total (12 Months)	7,685	\$ 2,636.68	\$ 6,937.44	\$ 9,574.12	\$ 1.25



**Carteret School District
Carteret Board Office
599 Roosevelt Ave. Carteret, NJ 07008**

For Service at: 599 Roosevelt Ave. Carteret, NJ 07008

Account No.: 5544300000


Meter No.: 60276074

Water & Sewer Service Delivery - Middlesex Water Company

Month	Total (\$)	Gallons	\$/Gallon
Jun-14	\$ 371.03	9,724.00	\$ 0.04
Sep-14	\$ 366.83	13,464.00	\$ 0.03
Jan-15	\$ 400.09	8,976.00	\$ 0.04
Apr-15	\$ 420.89	10,472.00	\$ 0.04
Total	\$ 1,558.84	42,636.00	\$ 0.04

Carteret Board Office - Water Usage

Gallons



PSE&G ELECTRIC SERVICE TERRITORY

Last Updated: 12/11/14

***CUSTOMER CLASS - R – RESIDENTIAL C – COMMERCIAL I –INDUSTRIAL**

Supplier	Telephone & Web Site	*Customer Class
Abest Power & Gas of NJ, LLC 202 Smith Street Perth Amboy, NJ 08861	(888)987-6937 www.AbestPower.com	R/C/I ACTIVE
AEP Energy, Inc. f/k/a BlueStar Energy Services 309 Fellowship Road, Fl. 2 Mount Laurel, NJ 08054	(866) 258-3782 www.aepenergy.com	R/C/I ACTIVE
Alpha Gas and Electric, LLC 641 5 th Street Lakewood, NJ 08701	(855) 553-6374 www.alphagasandelectric.com	R/C ACTIVE
Ambit Northeast, LLC d/b/a Ambit Energy 103 Carnegie Center Suite 300 Princeton, NJ 08540	877-282-6284 www.ambitenergy.com	R/C ACTIVE
American Powernet Management, LP 437 North Grove St. Berlin, NJ 08009	(877) 977-2636 www.americanpowernet.com	C/I ACTIVE
Amerigreen Energy, Inc. 333Sylvan Avenue Englewood Cliffs, NJ 07632	888-559-4567 www.amerigreen.com	R/C ACTIVE
AP Gas & Electric, (NJ) LLC 10 North Park Place, Suite 420 Morristown, NJ 07960	(855) 544-4895 www.apgellc.com	R/C/I ACTIVE
Astral Energy LLC 16 Tyson Place Bergenfield, NJ 07621	(888)850-1872 www.AstralEnergyLLC.com	R/C/I ACTIVE
Barclays Capital Services, Inc. 70 Hudson Street Jersey City, NJ 07302-4585	(800) 526-7000 www.barclays.com	C ACTIVE
BBPC, LLC d/b/a Great Eastern Energy	(888) 651-4121	C

116 Village Blvd. Suite 200 Princeton, NJ 08540	www.greateasternenergy.com	ACTIVE
Berkshire Energy Partners, LLC 9 Berkshire Road Landenberg, PA 19350 Attn: Dana A. LeSage, P.E.	(610) 255-5070 www.berkshireenergypartners.com	C/I ACTIVE
Blue Pilot Energy, LLC 197 State Rte. 18 South Ste. 3000 East Brunswick, NJ 08816	(800) 451-6356 www.bluepilotenergy.com	R/C ACTIVE
Brick Standard, LLC 235 Hudson Street Suite 1 Hoboken, NJ 07030	(201)706-8101 www.standardalternative.com	C/I ACTIVE
CCES LLC dba Clean Currents Energy Services 566 Terhune Street Teaneck, NJ 07666	(877) 933-2453 www.cleancurrents.com	R/C ACTIVE
Champion Energy Services, LLC 1200 Route 22 Bridgewater, NJ 08807	(888) 653-0093 www.championenergyservices.com	R/C/I ACTIVE
Choice Energy, LLC 4257 US Highway 9, Suite 6C Freehold, NJ 07728	(888) 565-4490 www.4choiceenergy.com	R/C ACTIVE
Clearview Electric, Inc. 1744 Lexington Avenue Pennsauken, NJ 08110	(888) CLR-VIEW (800) 746- 4702 www.clearviewenergy.com	R/C/I ACTIVE
Commerce Energy, Inc. 7 Cedar Terrace Ramsey, NJ 07446	1-866-587-8674 www.commerceenergy.com	R/C ACTIVE
Community Energy Inc. 51 Sandbrook Headquarters Road Stockton, NJ 08559	(866)946-3123 www.communityenergyinc.com	R/C/I ACTIVE
ConEdison Solutions Cherry Tree Corporate Center 535 State Highway Suite 180 Cherry Hill, NJ 08002	(888) 665-0955 www.conedsolutions.com	C/I ACTIVE

ConocoPhillips Company 224 Strawbridge Drive Suite 107 Moorestown, NJ 08057	(800) 646-4427 www.conocophillips.com	C/I ACTIVE
Constellation NewEnergy, Inc. 900A Lake Street, Suite 2 Ramsey, NJ 07446	(888) 635-0827 www.constellation.com	R/C/I ACTIVE
Constellation Energy 900A Lake Street, Suite 2 Ramsey, NJ 07446	(877) 997-9995 www.constellation.com	R ACTIVE
Credit Suisse, (USA) Inc. 700 College Road East Princeton, NJ 08450	(212) 538-3124 www.creditsuisse.com	C ACTIVE
Direct Energy Business, LLC 120 Wood Avenue, Suite 611 Iselin, NJ 08830	(888) 925-9115 http://www.business.directenergy.com/	R ACTIVE
Direct Energy Business Marketing, LLC (fka Hess Energy Marketing) 1 Hess Plaza Woodbridge, NJ 07095	(800) 437-7872 http://www.business.directenergy.com/	C/I ACTIVE
Direct Energy Services, LLC 120 Wood Avenue, Suite 611 Iselin, NJ 08830	(888) 925-9115 www.directenergy.com	R ACTIVE
Direct Energy Small Business, LLC (fka Hess Small Business Services, LLC) One Hess Plaza Woodbridge, NJ 07095	(888) 464-4377 http://www.business.directenergy.com/	C/I ACTIVE
Discount Energy Group, LLC 811 Church Road, Suite 149 Cherry Hill, New Jersey 08002	(800) 282-3331 www.discountenergygroup.com	R/C ACTIVE
DTE Energy Supply, Inc. One Gateway Center, Suite 2600 Newark, NJ 07102	(877) 332-2450 www.dtesupply.com	C/I ACTIVE

Energy.me Midwest LLC 90 Washington Blvd Bedminster, NJ 07921	(855) 243-7270 www.energy.me	R/C/I ACTIVE
Energy Plus Holdings LLC 309 Fellowship Road East Gate Center, Suite 200 Mt. Laurel, NJ 08054	(877) 866-9193 www.energypluscompany.com	R/C ACTIVE
Ethical Electric Benefit Co. d/b/a Ethical Electric 100 Overlook Center, 2 nd Fl. Princeton, NJ 08540	(888) 444-9452 www.ethicalelectric.com	R/C ACTIVE
Energy Service Providers, Inc., d/b/a New Jersey Gas & Electric 1 Bridge Plaza fl. 2 Fort Lee, NJ 07024	(866) 568-0290 www.njgande.com	R/C ACTIVE
FirstEnergy Solutions 150 West State Street Trenton, NJ 08608	(866) 625-7318 www.fes.com	C/I ACTIVE
Gateway Energy Services Corp. 120 Wood Avenue Suite 611 Iselin, NJ 08830	(866)348-4193 www.directenergybusiness.com	R/C ACTIVE
GDF SUEZ Energy Resources NA, Inc. 333 Thornall Street Sixth Floor Edison, NJ 08837	(866) 999-8374 www.gdfsuezenergyresources.com	C/I ACTIVE
GDF Suez Retail Energy Solutions LLC d/b/a THINK ENERGY 333 Thornall St. Sixth Floor Edison, NJ 08819	1-866-252-0078 www.mythinkenergy.com	R/C/I ACTIVE
Glacial Energy of New Jersey, Inc. 21 Pine Street, Suite 237 Rockaway, NJ 07866	(888) 452-2425 www.glacialenergy.com	C/I ACTIVE
Global Energy Marketing LLC 129 Wentz Avenue Springfield, NJ 07081	(800) 542-0778 www.globalp.com	R/C/I ACTIVE

Green Mountain Energy Company 211 Carnegie Center Drive Princeton, NJ 08540	(866) 767-5818 www.greenmountain.com/commercial-home	C/I ACTIVE
Harborside Energy LLC 101 Hudson Street Suite 2100 Jersey City, NJ 07302	(877) 940-3835 www.harborsideenergynj.com	R/C ACTIVE
Hess Corporation 1 Hess Plaza Woodbridge, NJ 07095	(800) 437-7872 www.hess.com	C/I ACTIVE
HIKO Energy, LLC 655 Suffern Road Teaneck, NJ 07666	(888) 264-4908 www.hikoenergy.com	R/C/I ACTIVE
Hudson Energy Services, LLC 7 Cedar Street Ramsey, New Jersey 07446	(877) Hudson 9 www.hudsonenergyservices.com	C ACTIVE
IDT Energy, Inc. 550 Broad Street Newark, NJ 07102	(877) 887-6866 www.idtenergy.com	R/C ACTIVE
Independence Energy Group, LLC 211 Carnegie Center Princeton, NJ 08540	(877) 235-6708 www.chooseindependence.com	R/C ACTIVE
Inspire Energy Holdings LLC 923 Haddonfield Road 3rd Fl. Building B2 Cherry Hill, NJ 08002	(866) 403-2620 www.inspireenergy.com	R/C/I
Integrus Energy Services, Inc. 33 Wood Ave, South, Suite 610 Iselin, NJ 08830	(800) 536-0151 www.integrusenergy.com	C/I ACTIVE
Jsynergy, LLC 445 Central Ave. Suite 204 Cedarhurst, NY 11516	(516) 331-2020 Jsynergylc.com	R/C/I ACTIVE
Kuehne Chemical Company, Inc. 86 North Hackensack Avenue South Kearney, NJ 07032	(973) 589-0700 kuehnechemical@comcast.net	I

Liberty Power Delaware, LLC 1973 Highway 34, Suite 211 Wall, NJ 07719	(866) 769-3799 www.libertypowercorp.com	C/I ACTIVE
Liberty Power Holdings, LLC 1973 Highway 34, Suite 211 Wall, NJ 07719	(866) 769-3799 www.libertypowercorp.com	R/C/I ACTIVE
Linde Energy Services 575 Mountain Avenue Murray Hill, NJ 07974	(800) 247-2644 www.linde.com	C/I ACTIVE
Marathon Power LLC 302 Main Street Paterson, NJ 07505	(888) 779-7255 www.mecny.com	R/C/I ACTIVE
MP2 Energy NJ, LLC 111 River Street, Suite 1204 Hoboken, NJ 07030	(877) 238-5343 www.mp2energy.com	R/C/I ACTIVE
Natures Current, LLC 95 Fairmount Avenue Philadelphia, Pennsylvania 19123	(215) 464-6000 www.naturescurrent.com	R/C/I ACTIVE
MPower Energy NJ LLC One University Plaza, Suite 507 Hackensack, NJ 07601	(877) 286-7693 www.mpowerenergy.com	R/C/I ACTIVE
NATGASCO, Inc. (Supreme Energy, Inc.) 532 Freeman St. Orange, NJ 07050	(800) 840-4427 www.supremeenergyinc.com	R/C/I ACTIVE
New Jersey Gas & Electric 10 North Park Place Suite 420 Morristown, NJ 07960	(866) 568-0290 www.njgande.com	R/C/ ACTIVE
NextEra Energy Services New Jersey, LLC 651 Jernee Mill Road Sayreville, NJ 08872	(877) 528-2890 Commercial (800) 882-1276 Residential www.nexteraenergyservices.com	R/C/I ACTIVE
Noble Americas Energy Solutions The Mac-Cali Building 581 Main Street, 8th Floor Woodbridge, NJ 07095	(877) 273-6772 www.noblesolutions.com	C/I ACTIVE

Nordic Energy Services, LLC 50 Tice Boulevard, Suite 340 Woodcliff Lake, NJ 07677	(877) 808-1027 www.nordiceenergy.us.com	R/C/I ACTIVE
North American Power and Gas, LLC 222 Ridgedale Avenue Cedar Knolls, NJ 07927	(888) 313-9086 www.napower.com	R/C/I ACTIVE
North Eastern States, Inc. d/b/a Entrust Energy 90 Washington Valley Road Bedminster, NJ 07921	(888) 535-6340 www.entrustenergy.com	R/C/I ACTIVE
Oasis Power, LLC d/b/a Oasis Energy 11152 Westheimer, Suite 901 Houston, TX 77042	(800)324-3046 www.oasisenergy.com	R/C ACTIVE
Palmco Power NJ, LLC One Greentree Centre 10,000 Lincoln Drive East, Suite 201 Marlton, NJ 08053	(877) 726-5862 www.PalmcoEnergy.com	R/C/I ACTIVE
Park Power, LLC 1200 South Church St. Suite 23 Mount Laurel, NJ 08054	(856) 778-0079 www.parkpower.com	R/C/I ACTIVE
Plymouth Rock Energy, LLC 338 Maitland Avenue Teaneck, NJ 07666	(855) 32-POWER (76937) www.plymouthenergy.com	R/C/I ACTIVE
Power Management Co., LLC b/b/a PMC Lightsavers Limited Liability Company 1600 Moseley Road Victor, NY 14564	(585) 249-1360 www.powermanagementco.com	C/I ACTIVE
PPL Energy Plus, LLC 811 Church Road Cherry Hill, NJ 08002	(800) 281-2000 www.pplenergyplus.com	C/I ACTIVE
PPL EnergyPlus Retail, LLC 788 Shrewsbury Avenue, Suite 220 Tinton Falls, NJ 07724	(732) 741-0505 – 2000 www.pplenergyplus.com	C/I ACTIVE
Progressive Energy Consulting, LLC	(917) 837-7400	R/C/I

PO Box 4582 Wayne, New Jersey 07474	Progressivenrg@optionline.net	ACTIVE
Prospect Resources, Inc. 208 W. State Street Trenton, NJ 08608-1002	(847) 673-1959 www.prospectresources.com	C ACTIVE
Public Power & Utility of New Jersey, LLC One International Blvd, Suite 400 Mahwah, NJ 07495	(888) 354-4415 www.ppandu.com	R/C/I ACTIVE
Reliant Energy 211 Carnegie Center Princeton, NJ 08540	(877) 297-3795 (877) 297-3780 www.reliant.com	R/C/I ACTIVE
ResCom Energy LLC 18C Wave Crest Ave. Winfield Park, NJ 07036	(888) 238-4041 http://rescomenergy.com	R/C/I ACTIVE
Residents Energy, LLC 550 Broad Street Newark, NJ 07102	(888) 828-7374 www.residentsenergy.com	R/C
Respond Power LLC 1001 East Lawn Drive Teaneck, NJ 07666	(877) 973-7763 www.majorenergy.com	R/C/I ACTIVE
Save on Energy, LLC 1101 Red Ventures Drive Fort Mill, SC 29707	1 (877)-658-3183 www.saveonenergy.com	R/C
SFE Energy One Gateway Center Suite 2600 Newark, NJ 07012	1 (877) 316-6344 www.sfeenergy.com	R/C/I ACTIVE
S.J. Energy Partners, Inc. 208 White Horse Pike, Suite 4 Barrington, NJ 08007	(800) 695-0666 www.sjnaturalgas.com	C ACTIVE
SmartEnergy Holdings, LLC 100 Overlook Center 2nd Floor Princeton, NJ NJ 08540 United States of America	(800) 443-4440 www.smartenergy.com	R/C/I ACTIVE
South Jersey Energy Company 1 South Jersey Plaza, Route 54 Folsom, NJ 08037	(800) 266-6020 www.southjerseyenergy.com	R/C/I ACTIVE

Spark Energy Gas, LP/ Spark Energy 2105 City West Blvd. Suite 100 Houston, TX 77042	(713)600-2600 www.sparkenergy.com	R/C/I ACTIVE
Sperian Energy Corp. 1200 Route 22 East, Suite 2000 Bridgewater, NJ 08807	(888) 682-8082 www.sperianenergy.com	R/C/I ACTIVE
Starion Energy PA Inc. 101 Warburton Avenue Hawthorne, NJ 07506	(800) 600-3040 www.starionenergy.com	R/C/I ACTIVE
Stream Energy New Jersey, LLC 309 Fellowship Rd., Suite 200 Mt. Laurel, NJ 08054	(877) 369-8150 www.streamenergy.net	R/C ACTIVE
Summit Energy Services, Inc. 10350 Ormsby Park Place Suite 400 Louisville, KY 40223	1 (800) 90-SUMMIT www.summitenergy.com	C/I ACTIVE
Texas Retail Energy LLC Park 80 West Plaza II, Suite 200 Saddle Brook, NJ 07663 Attn: Chris Hendrix	(866) 532-0761 Texasretailenergy.com	C/I ACTIVE
TransCanada Power Marketing Ltd. 190 Middlesex Essex Turnpike, Suite 200 Iselin, NJ 08830	(877) MEGAWAT www.transcanada.com/powermarketing	C/I ACTIVE
TriEagle Energy, LP 90 Washington Valley Rd Bedminster, NJ 07921	(877) 933-2453 www.trieagleenergy.com	R/C/I ACTIVE
UGI Energy Services, Inc. dba UGI Energy Link 224 Strawbridge Drive Suite 107 Moorestown, NJ 08057	(800) 427-8545 www.ugienergylink.com	C/I ACTIVE
Verde Energy USA, Inc. 2001 Route 46 Waterview Plaza Suite 301 Parsippany, NJ 07054	(800) 388-3862 www.lowcostpower.com	R/C ACTIVE

Viridian Energy 2001 Route 46, Waterview Plaza Suite 310 Parsippany, NJ 07054	(866) 663-2508 www.viridian.com	R/C/I ACTIVE
XOOM Energy New Jersey, LLC 744 Broad Street. 16 th Floor Newark, NJ 07102	(888) 997-8979 www.xoomenergy.com	R/C/I ACTIVE
YEP Energy 89 Headquarters Plaza North #1463 Morristown, NJ 07960	(855) 363-7736 www.yepenergyNJ.com	R/C/I ACTIVE
Your Energy Holdings, LLC One International Boulevard Suite 400 Mahwah, NJ 07495-0400	(855) 732-2493 www.thisisyourenergy.com	R/C/I ACTIVE

[Back to the main supplier page](#)

PSE&G GAS SERVICE TERRITORY
Last Updated: 12/11/14

***CUSTOMER CLASS - R – RESIDENTIAL C – COMMERCIAL I - INDUSTRIAL**

Supplier	Telephone & Web Site	*Customer Class
Ambit Northeast, LLC d/b/a Ambit Energy 103 Carnegie Center Suite 300 Princeton, NJ 08540	877-282-6284 www.ambitenergy.com	R/C ACTIVE
Amerigreen Energy, Inc. 333 Sylvan Avenue Suite 206 Englewood Cliffs, NJ 07632	(888)559-4567 www.amerigreen.com	R/C/I ACTIVE
Astral Energy LLC 16 Tyson Place Bergenfield, NJ 07621	888-850-1872 www.AstralEnergyLLC.com	R/C/I ACTIVE
BBPC, LLC Great Eastern Energy 116 Village Blvd. Suite 200 Princeton, NJ 08540	888-651-4121 www.greateasternenergy.com	C ACTIVE
Choice Energy, LLC 4257 US Highway 9, Suite 6C Freehold, NJ 07728	(888) 565-4490 www.4choiceenergy.com	R/C/I
Clearview Electric Inc. d/b/a Clearview Gas 1744 Lexington Ave. Pennsauken, NJ 08110	800-746-4720 www.clearviewenergy.com	R/C ACTIVE
Colonial Energy, Inc. 83 Harding Road Wyckoff, NJ 07481	845-429-3229 www.colonialgroupinc.com	C/I ACTIVE
Commerce Energy, Inc. 7 Cedar Terrace Ramsey, NJ 07746	888 817-8572 www.commerceenergy.com	R ACTIVE
Compass Energy Services, Inc. 33 Wood Avenue South, 610 Iselin, NJ 08830	866-867-8328 www.compassenergy.net	C/I ACTIVE

Compass Energy Gas Services, LLC 33 Wood Avenue South Suite 610 Iselin, NJ 08830	866-867-8328 www.compassenergy.net	C/I ACTIVE
ConocoPhillips Company 224 Strawbridge Drive, Suite 107 Moorestown, NJ 08057	800-646-4427 www.conocophillips.com	C/I ACTIVE
Consolidated Edison Energy, Inc. d/b/a Con Edison Solutions 535 State Highway 38, Suite 140 Cherry Hill, NJ 08002	888-686-1383 x2130 www.conedenergy.com	
Consolidated Edison Solutions, Inc. Cherry Tree Corporate Center 535 State Highway 38, Suite 140 Cherry Hill, NJ 08002	888-665-0955 www.conedsolutions.com	C/I ACTIVE
Constellation NewEnergy-Gas Division, LLC 116 Village Boulevard, Suite 200 Princeton, NJ 08540	800-785-4373 www.constellation.com	C/I ACTIVE
Constellation Energy Gas Choice, Inc. 116 Village Blvd., Suite 200 Princeton, NJ 08540	800-785-4373 www.constellation.com	R/C/I ACTIVE
Direct Energy Business, LLC 120 Wood Avenue, Suite 611 Iselin, NJ 08830	888-925-9115 http://www.business.directenergy.com/	R ACTIVE
Direct Energy Business Marketing, LLC (fka Hess Energy Marketing) One Hess Plaza Woodbridge, NJ 07095	(800) 437-7872 http://www.business.directenergy.com/	C/I ACTIVE
Direct Energy Services, LLC 120 Wood Avenue, Suite 611 Iselin, NJ 08830	(888) 925-9115 www.directenergy.com	R ACTIVE

Direct Energy Small Business, LLC (fka Hess Small Business Services, LLC) One Hess Plaza Woodbridge, NJ 07095	(888) 464-4377 http://www.business.directenergy.com/	C/I ACTIVE
Gateway Energy Services Corp. 120 Wood Avenue Suite 611 Iselin, NJ 08830	(866) 348-4193 www.gesc.com	R/C ACTIVE
Glacial Energy of New Jersey, Inc. 21 Pine Street, Suite 237 Rockaway, NJ 07866	888-452-2425 www.glacialenergy.com	C/I ACTIVE
Global Energy Marketing, LLC 129 Wentz Avenue Springfield, NJ 07081	800-542-0778 www.globalp.com	C/I ACTIVE
Great Eastern Energy 116 Village Blvd., Suite 200 Princeton, NJ 08540	888-651-4121 www.greateastern.com	C/I ACTIVE
Greenlight Energy 330 Hudson Street, Suite 4 Hoboken, NJ 07030	718-204-7467 www.greenlightenergy.us	C ACTIVE
Harborside Energy LLC 101 Hudson Street, Suite 2100 Jersey City, NJ 07302	877-940-3835 www.harborsideenergynj.com	R/C ACTIVE
Hess Energy, Inc. One Hess Plaza Woodbridge, NJ 07095	800-437-7872 www.hess.com	C/I ACTIVE
HIKO Energy, LLC 655 Suffern Road Teaneck, NJ 07666	888 264-4908 www.hikoenergy.com	R/C/I ACTIVE
Hudson Energy Services, LLC 7 Cedar Street Ramsey, NJ 07446	877- Hudson 9 www.hudsonenergyservices.com	C ACTIVE
IDT Energy, Inc. 550 Broad Street Newark, NJ 07102	877-887-6866 www.idtenergy.com	R/C ACTIVE

Infinite Energy dba Intelligent Energy 1200 Route 22 East Suite 2000 Bridgewater, NJ 08807-2943	(800) 927-9794 www.InfiniteEnergy.com	R/C/I ACTIVE
Integrlys Energy Services-Natural Gas, LLC 101 Eisenhower Parkway Suite 300 Roseland, NJ 07068	(800) 536-0151 www.integrlysenergy.com	C/I ACTIVE
Jsynergy LLC 445 Cental Ave. Suite 204 Cedarhurst, NY 11516	(516) 331-2020 www.Jsnergylc.com	R/C/I ACTIVE
Major Energy Services, LLC 1001 East Lawn Drive Teaneck NJ 07666	888-625-6760 www.majorenergy.com	R/C/I ACTIVE
Marathon Power LLC 302 Main Street Paterson, NJ 07505	888-779-7255 www.mecny.com	R/C/I ACTIVE
Metromedia Energy, Inc. 6 Industrial Way Eatontown, NJ 07724	1-877-750-7046 www.metromediaenergy.com	C/I ACTIVE
Metro Energy Group, LLC 14 Washington Place Hackensack, NJ 07601	888-53-Metro www.metroenergy.com	R/C ACTIVE
MPower Energy NJ LLC One University Plaza, Suite 507 Hackensack, NJ 07601	877-286-7693 www.mpowerenergy.com	R/C/I ACTIVE
NATGASCO (Supreme Energy, Inc.) 532 Freeman Street Orange, NJ 07050	800-840-4427 www.supremeenergyinc.com	R/C/I ACTIVE
New Energy Services LLC 101 Neptune Avenue Deal, New Jersey 07723	800-660-3643 www.newenergyservicesllc.com	R/C/I ACTIVE
New Jersey Gas & Electric 10 North Park Place Suite 420 Morristown, NJ 07960	866-568-0290 www.njgande.com	R/C ACTIVE

Noble Americas Energy Solutions The Mac-Cali Building 581 Main Street, 8th fl. Woodbridge, NJ 07095	877-273-6772 www.noblesolutions.com	C/I ACTIVE
North American Power & Gas, LLC d/b/a North American Power 197 Route 18 South Ste. 300 New Brunswick, NJ 08816	888- 313-8086 www.napower.com	R/C/I ACTIVE
North Eastern States, Inc. d/b/a Entrust Energy 90 Washington Valley Road Bedminster, NJ 07921	(888) 535-6340 www.entrustenergy.com	R/C/I ACTIVE
Oasis Power, LLC d/b/a Oasis Energy 11152 Westheimer, Suite 901 Houston, TX 77042	(800)324-3046 www.oasisenergy.com	R/C ACTIVE
Palmco Energy NJ, LLC One Greentree Centre 10,000 Lincoln Drive East, Suite 201 Marlton, NJ 08053	877-726-5862 www.PalmcoEnergy.com	R/C/I ACTIVE
Plymouth Rock Energy, LLC 338 Maitland Avenue Teaneck, NJ 07666	855-32-POWER (76937) www.plymouthenergy.com	R/C/I ACTIVE
PPL EnergyPlus, LLC Shrewsbury Executive Offices 788 Shrewsbury Avenue Suite 2200 Tinton Falls, NJ 07724	(732) 741-0505 www.pplenergyplus.com	C/I ACTIVE
PPL EnergyPlus Retail, LLC Shrewsbury Executive Offices 788 Shrewsbury Avenue, Suite 220 Tinton Falls, NJ 07724	(732) 741-0505 – 2000 www.pplenergyplus.com	C/I ACTIVE
Public Power & Utility of New Jersey, LLC One International Blvd, Suite 400 Mahwah, NJ 07495	(888) 354-4415 www.ppandu.com	R/C/I ACTIVE

Residents Energy, LLC 550 Broad Street Newark, NJ 07102	(888) 828-7374 www.residentsenergy.com	R/C
Respond Power LLC 1001 East Lawn Drive Teaneck, NJ 07666	(877) 973-7763 www.respondpower.com	R/C/I ACTIVE
Save on Energy, LLC 1101 Red Ventures Drive Fort Mill, SC 29707	1 (877) 658-3183 www.saveonenergy.com	R/C ACTIVE
SFE Energy One Gateway Center Suite 2600 Newark, NJ 07012	1 (877) 316-6344 www.sfeenergy.com	R/C/I ACTIVE
S.J. Energy Partners, Inc. 208 White Horse Pike, Suite 4 Barrington, NJ 08007	(800) 695-0666 www.sjnaturalgas.com	C ACTIVE
South Jersey Energy Company 1 South Jersey Plaza, Route 54 Folsom, NJ 08037	800-266-6020 www.southjerseyenergy.com	R/C/I ACTIVE
SouthStar Energy d/b/a New Jersey Energy 1085 Morris Avenue, Suite 155 Union, NJ 07083	(866) 477-8823 www.newjerseyenergy.com	R/C ACTIVE
Spark Energy Gas, LP/ Spark Energy 2105 City West Blvd. Suite 100 Houston, TX 77042	(713)600-2600 www.sparkenergy.com	R/C/I ACTIVE
Sperian Energy Corp. Bridgewater Center 1200 Route 22 East Bridgewater, NJ 08807	888-682-8082 www.sperianenergy.com	R/C/I ACTIVE
Sprague Energy Corp. 12 Ridge Road Chatham Township, NJ 07928	855-466-2842 www.spragueenergy.com	C/I ACTIVE
Stuyvesant Energy LLC 10 West Ivy Lane, Suite 4 Englewood, NJ 07631	800-640-6457 www.stuyfuel.com	C ACTIVE

Stream Energy New Jersey, LLC 309 Fellowship Road Suite 200 Mt. Laurel, NJ 08054	(877) 369-8150 www.streamenergy.net	R/C ACTIVE
Summit Energy Services, Inc. 10350 Ormsby Park Place Suite 400 Louisville, KY 40223	1 (800) 90-SUMMIT www.summitenergy.com	C/I ACTIVE
Systrum Energy 1 Bergen Blvd. Fairview, NJ 07022	877-797-8786 www.systrumenergy.com	R/C/I ACTIVE
Tiger Natural Gas, Inc. dba Tiger, Inc. 234 20th Avenue Brick, NJ 008724	888-875-6122 www.tignaturalgas.com	R/C/I ACTIVE
UGI Energy Services, Inc. dba UGI Energy Link 224 Strawbridge Drive, Suite 107 Moorestown, NJ 08057	800-427-8545 www.ugienergylink.com	C/I ACTIVE
UGI Energy Services, Inc. d/b/a GASMARK 224 Strawbridge Drive, Suite 107 Moorestown, NJ 08057	856-273-9995 www.ugienergylink.com	C/I ACTIVE
Verde Energy USA, Inc. 2001 Route 46 Waterview Plaza, Suite 301 Parsippany, NJ 07054	800-388-3862 www.lowcostpower.com	R/C ACTIVE
Viridian Energy PA LLC 2001 Route 46, Waterview Plaza Suite 230 Parsippany, NJ 07054	866-663-2508 www.viridian.com	R/C ACTIVE
Vista Energy Marketing, L.P. 197 State Route 18 South, Suite 3000 South Wing East Brunswick, NJ 08816	888-508-4782 www.vistaenergymarketing.com	R/C/I ACTIVE
Woodruff Energy 73 Water Street Bridgeton, NJ 08302	800-557-1121 www.woodruffenergy.com	R/C/I ACTIVE

Woodruff Energy US LLC 73 Water Street, P.O. Box 777 Bridgeton, NJ 08302	856-455-1111 800-557-1121 www.woodruffenergy.com	C/I ACTIVE
XOOM Energy New Jersey, LLC 744 Broad Street. 16th Floor Newark, NJ 07102	888-997-8979 www.xoomenergy.com	R/C/I ACTIVE
Your Energy Holdings, LLC One International Boulevard Suite 400 Mahwah, NJ 07495-0400	855-732-2493 www.thisisyourenergy.com	R/C/I ACTIVE

[Back to main supplier information page](#)

APPENDIX B

Equipment Inventory

Carteret School District
CHA Project# 30201
Carteret Board Office


Description	QTY	Manufacturer Name	Model No.	Serial No.	Equipment Type / Utility	Capacity/Size	Efficiency	Location	Areas/Equipment Served	Date Installed	Remaining Useful Life (years)	Other Info.
CU-1	1	Fujitsu	AOU36CX	BBN 001895	Split Type Air Cond.	33,000 BTU/hr	N/A	Outside	Building	N/A	N/A	
CU-2	1	Fujitsu	AOU36CX	BBN 001896	Split Type Air Cond.	33,000 BTU/hr	N/A	Outside	Building	N/A	N/A	
CU-3	1	Fujitsu	AOU24CL	DDN009644	Split Type Air Cond.	24,200 BTU/hr	N/A	Outside	Building	2009	6	
CU-4	1	Fujitsu	AOU24CL	DDN009669	Split Type Air Cond.	24,200 BTU/hr	N/A	Outside	Building	2009	6	
GEN-1	1	Kohler	Not Available	Not Available	Generator	Not Available	N/A	Outside	Building	N/A	N/A	
CU-5	1	Fujitsu	ASU24CL	DDA007736	Split Type Air Cond.	24,200 BTU/hr	N/A	Office	Room	2007	8	
B-1	1	Weil-McLain	1088R	Not Available	Steam Boiler	2,887,000 BTU/hr	N/A	Boiler Room	Building	2008	7	
Burner-1	1	Powerflame	WCR2-G-20B	70830215	Gas Burner	2887 MBH	N/A	Boiler Room	Building	2008	7	
DHW-1	1	Rheem	21V50-2	0694A16052	Water Heater	36,000 BTU/hr	N/A	Boiler Room	Building	1994	0	
AHU-1	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Above ceiling Storage Rm	Rear addition	N/A	N/A	

APPENDIX C

ECM Calculations

Carteret Board of Education
CHA Project Number: 30201
Carteret Board Office

	Existing Conditions	Post Recommended ECMs	Percent Savings
Costs (\$)	35,188	25,565	27%
Electricity (kWh)	170,960	126,571	26%
Natural Gas (therms)	7,685	5,601	27%
Site EUI (kbtu/SF/Yr)	78.4	57.5	



Carteret Board of Education
CHA Project Number: 30201
Carteret Board Office

Summary of Energy Conservation Measures							
Energy Conservation Measure		Approx. Costs (\$)	Approx. Savings (\$/year)	Payback (Years) w/o Incentive	Potential Incentive (\$)*	Payback (Years) w/ Incentive	Recommended For Implementation
1	Install Attic Insulation to R-38	17,452	1,700	10.3	0	10.3	Y
2	Replace Windows in the rear Single Story Wing	56,100	1,032	54.3	0	54.3	Y
3	Steam to Hot Water Conversion	740,969	3,717	199.3	2,000	198.8	N
4	Install Window A/C Unit Controllers	3,500	2,225	1.6	0	1.6	Y
5	Replace Gas DHW Heater w/ Condensing DHW Heater	8,848	178	49.8	300	48.1	N
6	Install Low Flow Plumbing Fixtures	32,387	871	37.2	0	37.2	Y
L1	Lighting Replacements / Upgrades	47,185	3,161	14.9	4,830	13.4	N
L2	Install Lighting Controls (Add Occupancy Sensors)	5,130	1,194	4.3	400	4.0	N
L3	Lighting Replacements with Controls (Occupancy Sensors)	52,315	3,795	13.8	5,230	12.4	Y

Total	911,570	13,518	67.4	7,530	66.9
Total (Recommended)	161,753	9,623	16.8	5,230	16.3

* Incentive shown is per the New Jersey SmartStart Program

Carteret Board of Education
CHA Project Number: 30201
Carteret Board Office

ECM Summary Sheet

* Incentive shown is per the New Jersey SmartStart Program

ECM-1 Install Attic Insulation to R-38

Budgetary Cost	Annual Utility Savings				ROI	Incentive *	Payback (without incentive)	Payback (with incentive)
	Electric kW	Electric kWh	Nat Gas Therms	Total \$				
\$						\$	Years	Years
17,452	0.0	1,013	1,243	1,700	1.4	0	10.3	10.3

ECM-2 Replace Windows in the rear Single Story Wing

Budgetary Cost	Annual Utility Savings				ROI	Incentive *	Payback (without incentive)	Payback (with incentive)
	Electric kW	Electric kWh	Nat Gas Therms	Total \$				
\$						\$	Years	Years
56,100	0.0	0	828	1,032	(0.7)	0	54.3	54.3

ECM-3 Steam to Hot Water Conversion

Budgetary Cost	Annual Utility Savings				ROI	Incentive *	Payback (without incentive)	Payback (with incentive)
	Electric kW	Electric kWh	Nat Gas Therms	Total \$				
\$						\$	Years	Years
740,969	0.0	0	2,857	3,717	(0.9)	2,000	199.3	198.8

ECM-4 Install Window A/C Unit Controllers

Budgetary Cost	Annual Utility Savings				ROI	Incentive *	Payback (without incentive)	Payback (with incentive)
	Electric kW	Electric kWh	Nat Gas Therms	Total \$				
\$						\$	Years	Years
3,500	0.0	14,835	0	2,225	5.4	0	1.6	1.6

ECM-5 Replace Gas DHW Heater w/ Condensing DHW Heater

Budgetary Cost	Annual Utility Savings				ROI	Incentive *	Payback (without incentive)	Payback (with incentive)
	Electric kW	Electric kWh	Nat Gas Therms	Total \$				
\$						\$	Years	Years
8,848	0.0	0	143	178	(0.7)	300	49.8	48.1

ECM-6 Install Low Flow Plumbing Fixtures

Budgetary Cost	Annual Utility Savings					ROI	Incentive *	Payback (without incentive)	Payback (with incentive)
	Electric kW	Electric kWh	Nat Gas Therms	Water kGal	Total \$				
\$							\$	Years	Years
32,387	0.0	0	13	23	871	(1.0)	0	37.2	37.2

ECM-L1 Lighting Replacements / Upgrades

Budgetary Cost	Annual Utility Savings				ROI	Incentive *	Payback (without incentive) Years	Payback (with incentive) Years
	Electric kW	Electric kWh	Nat Gas Therms	Total \$				
\$						\$		
47,185	7.8	23,386	0	3,161	(0.2)	4,830	14.9	13.4

ECM-L2 Install Lighting Controls (Add Occupancy Sensors)

Budgetary Cost	Annual Utility Savings				ROI	Incentive *	Payback (without incentive) Years	Payback (with incentive) Years
	Electric kW	Electric kWh	Nat Gas Therms	Total \$				
\$						\$		
5,130	0.0	9,707	0	1,194	1.8	400	4.3	4.0

ECM-L3 Lighting Replacements with Controls (Occupancy Sensors)

Budgetary Cost	Annual Utility Savings				ROI	Incentive *	Payback (without incentive) Years	Payback (with incentive) Years
	Electric kW	Electric kWh	Nat Gas Therms	Total \$				
\$						\$		
52,315	7.8	28,541	0	3,795	(0.1)	5,230	13.8	12.4

Carteret Board of Education
CHA Project Number: 30201

Rate of Discount (used for NPV) 3.0%

Utility Costs		Yearly Usage	Metric Ton Carbon Dioxide Equivalent	Building Area	Annual Utility Cost		
\$	0.150	\$/kWh blended		17,248	Electric	Natural Gas	Fuel Oil
\$	0.128	\$/kWh supply	170,960	0.000420205	\$	25,614	\$ 9,574
\$	5.22	\$/kW	67.2				
\$	1.25	\$/Therm	7,685	0.00533471			
\$	37.00	\$/kgals	42,636	0			
		\$/Gal					

Carteret Board Office

Recommend?		Item	Savings					Cost	Simple Payback	Life Expectancy	Equivalent CO ₂ (Metric tons)	NJ Smart Start Incentives	Direct Install Eligible (Y/N)	Payback w/ Incentives	Simple Projected Lifetime Savings					ROI	NPV	IRR		
			kW	kWh	therms	No. 2 Oil gal	Water kgal								\$	kW	kWh	therms	kgal/yr				\$	
Y or N																								
Y	ECM-1	Install Attic Insulation to R-38	0.0	1,013	1,243	0	0	1,700	\$ 17,452	10.3	25.0	7.1		N	10.3	0.0	25,324	31,064	0	\$ 42,504	1.4	\$12,153	8.5%	
Y	ECM-2	Replace Windows in the rear Single Story Wing	0.0	0	828	0	0	1,032	\$ 56,100	54.3	15.0	4.4		N	54.3	0.0	0	12,427	0	\$ 15,484	(0.7)	(\$43,777)	-13.0%	
N	ECM-3	Steam to Hot Water Conversion	0.0	0	2,857	0	4	3,717	\$ 740,969	199.3	20.0	15.2	\$ 2,000	N	198.8	0.0	0	57,134	85	\$ 74,344	(0.9)	(\$683,666)	-16.0%	
Y	ECM-4	Install Window A/C Unit Controllers	0.0	14,835	0	0	0	2,225	\$ 3,500	1.6	10.0	6.2	\$ -	N	1.6	0.0	148,347	0	0	\$ 22,252	5.4	\$15,481	63.1%	
N	ECM-5	Replace Gas DHW Heater w/ Condensing DHW Heater	0.0	0	143	0	0	178	\$ 8,848	49.8	15.0	0.8	\$ 300	N	48.1	0.0	0	2,140	0	\$ 2,666	(0.7)	(\$6,426)	-12.0%	
Y	ECM-6	Install Low Flow Plumbing Fixtures	0.0	0	13	0	23	871	\$ 32,387	37.2	0.0	0.1		N	37.2	0.0	0	0	0	\$ -	(1.0)	(\$32,387)	#NUM!	
N	ECM-L1	Lighting Replacements / Upgrades	7.8	23,386	0	0	0	3,161	\$ 47,185	14.9	10.0	9.8	\$ 4,830	N	13.4	78.0	233,860	0	0	\$ 39,965	(0.2)	(\$15,391)	-5.0%	
N	ECM-L2	Install Lighting Controls (Add Occupancy Sensors)	0.0	9,707	0	0	0	1,194	\$ 5,130	4.3	10.0	4.1	\$ 400	N	4.0	0.0	97,070	0	0	\$ 14,561	1.8	\$5,455	21.7%	
Y	ECM-L3	Lighting Replacements with Controls (Occupancy Sensors)	7.8	28,541	0	0	0	3,795	\$ 52,315	13.8	10.0	12.0	\$ 5,230	N	12.4	78.0	285,410	0	0	\$ 47,697	(0.1)	(\$14,713)	-3.7%	
Total (Not Including ECMs L1, L2)			7.8	44,389	5,083	0	27	\$ 13,518	\$ 911,570	67.4	10.6	68	\$ 7,530		66.9	78	459,081	102,765	85	\$ 204,948	(0.8)	(\$788,727)	-25.0%	
Recommended Measures (highlighted green above)			7.8	44,389	2,084	0	23	\$ 9,623	\$ 161,753	16.8	8.6	30	\$ 5,230	0	16.3	78	459,081	43,491	-	\$ 127,938	(0.2)	(\$88,971)	-13.5%	
% of Existing			12%	25.96%	27.12%	0	54%																	

City:		Newark, NJ				
Occupied Hours/Week		70	70	70	70	50
		Building Operating Hours	Auditorium Occupied Hours	Gymnasium Occupied Hours	Library Occupied Hours	Classrooms Occupied Hours
Temp	Enthalpy h (Btu/lb)	Bin Hours				
102.5						
97.5	35.4	6	3	3	3	2
92.5	37.4	31	13	13	13	9
87.5	35.0	131	55	55	55	39
82.5	33.0	500	208	208	208	149
77.5	31.5	620	258	258	258	185
72.5	29.9	664	277	277	277	198
67.5	27.2	854	356	356	356	254
62.5	24.0	927	386	386	386	276
57.5	20.3	600	250	250	250	179
52.5	18.2	730	304	304	304	217
47.5	16.0	491	205	205	205	146
42.5	14.5	656	273	273	273	195
37.5	12.5	1,023	426	426	426	304
32.5	10.5	734	306	306	306	218
27.5	8.7	334	139	139	139	99
22.5	7.0	252	105	105	105	75
17.5	5.4	125	52	52	52	37
12.5	3.7	47	20	20	20	14
7.5	2.1	34	14	14	14	10
2.5	1.3	1	0	0	0	0
-2.5						
-7.5						

Multipliers	
Material:	1.027
Labor:	1.246
Equipment:	1.124

Heating System Efficiency	80%
Cooling Eff (kW/ton)	1.2



Heating	
Hours	4,427 Hrs
Weighted Avg	40 F
Avg	28 F

Cooling	
Hours	4,333 Hrs
Weighted Avg	68 F
Avg	78 F

Utility End Use Analysis		
Electricity Use (kWh):		Notes/Comments:
170,960	Total	Based on utility analysis
63,329	Lighting	From Lighting Calculations
12,121	Motors	Calculated
75,000	A/C	Estimated
13,000	Plug Load	Estimated
-	Heating	
6,000	Computers	Estimated
1,510	Other	Remaining
Natural Gas Use (Therms):		Notes/Comments:
7,685	Total	Based on utility analysis
7,210	Boilers	Therms/SF x Square Feet Served
475	DHW	Based on utility analysis
0	Kitchen	Based on utility analysis

37.04%
7.09% motor calc
43.87%
7.60%
0.00%
3.51%
0.88%
100.00%

0.938191282
0.061808718
0



Carteret Board of Education
CHA Project Number: 30201
Carteret Board Office

ECM-1 Add Attic Insulation to R-38

Existing: roof insulation is approximately R-9 based on site observations.

Proposed: Install R-30 or 9" fiberglass insulation between joists of the old ceiling to bring total R-value up to R-38

Area of roof	5,200 SF	Cooling System Efficiency	1.2 kW/ton	Heating System Efficiency	80%
Existing Infiltration Factor	0.06 cfm/SF	Ex Occupied Clng Temp.	74 °F	Heating On Point	55 °F
Proposed Infiltration Factor	0.02 cfm/SF	Ex Unoccupied Clng Temp.	74 °F	Ex Occupied Htg Temp.	72 °F
Existing U Value	0.111 Btuh/SF/°f	Cooling Occ Enthalpy Setpoi	27.5 Btu/lb	Ex Unoccupied Htg Temp.	72 °F
Proposed U Value	0.026 Btuh/SF/°f	Cooling Unocc Enthalpy Setp	27.5 Btu/lb	Cooling Electricity	\$ 0.685 \$/kWh
				Heating NG Cost	\$ 1.25 \$/Therm

Avg Ext Wall Temp. Bins °F	Avg Outdoor Air Enthalpy	Existing Equipment Bin Hours	Occupied Equipment Bin Hours	Unoccupied Equipment Bin Hours	EXISTING LOADS		PROPOSED LOADS		COOLING ENERGY		HEATING ENERGY	
					Occupied	Unoccupied	Occupied	Unoccupied	Existing Cooling Energy kWh	Proposed Cooling Energy kWh	Existing Heating Energy Therms	Proposed Heating Energy Therms
					Infiltration & Heat Load BTUH	Infiltration & Heat Load BTUH	Infiltration & Heat Load BTUH	Infiltration & Heat Load BTUH				
A		B	C	D	E	F	G	H	I	J	K	L
97.5	35.4	6	3	4	-24,666	-24,666	-6,878	-6,878	15	4	0	0
92.5	37.4	31	13	18	-24,581	-24,581	-7,135	-7,135	76	22	0	0
87.5	35.0	131	55	76	-18,301	-18,301	-5,328	-5,328	240	70	0	0
82.5	33.0	500	208	292	-12,694	-12,694	-3,745	-3,745	635	187	0	0
77.5	31.5	620	258	362	-7,703	-7,703	-2,368	-2,368	478	147	0	0
72.5	29.9	664	277	387	0	0	0	0	0	0	0	0
67.5	27.2	854	356	498	0	0	0	0	0	0	0	0
62.5	24.0	927	386	541	0	0	0	0	0	0	0	0
57.5	20.3	600	250	350	0	0	0	0	0	0	0	0
52.5	18.2	730	304	426	17,826	17,826	4,827	4,827	0	0	163	44
47.5	16.0	491	205	286	22,397	22,397	6,064	6,064	0	0	137	37
42.5	14.5	656	273	383	26,968	26,968	7,302	7,302	0	0	221	60
37.5	12.5	1,023	426	597	31,539	31,539	8,539	8,539	0	0	403	109
32.5	10.5	734	306	428	36,109	36,109	9,777	9,777	0	0	331	90
27.5	8.7	334	139	195	40,680	40,680	11,015	11,015	0	0	170	46
22.5	7.0	252	105	147	45,251	45,251	12,252	12,252	0	0	143	39
17.5	5.4	125	52	73	49,822	49,822	13,490	13,490	0	0	78	21
12.5	3.7	47	20	27	54,393	54,393	14,727	14,727	0	0	32	9
7.5	2.1	34	14	20	58,963	58,963	15,965	15,965	0	0	25	7
2.5	1.3	1	0	1	63,534	63,534	17,203	17,203	0	0	1	0
TOTALS		8,760	3,650	5,110					1443	430	1,704	461

Existing Roof Infiltration	312 cfm
Existing Roof Heat Transfer	577 Btuh/°f
Proposed Roof Infiltration	104 cfm
Proposed Roof Heat Transfer	135 Btuh/°f

Savings	1,243 Therms	\$ 1,548
	1,013 kWh	\$ 694
		\$ 2,242

Carteret Board of Education
CHA Project Number: 30201
Carteret Board Office

ECM-1 Add Attic Insulation - Cost

Multipliers	
Material:	1.03
Labor:	1.25
Equipment:	1.12

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
						\$ -	\$ -	\$ -	\$ -	
R-30 9" fiberglass insulation	5,200	SF	\$ 1,200	\$ 1,000	\$ -	\$ 6,427	\$ 6,500	\$ -	\$ 12,927	Vendor quote
						\$ -	\$ -	\$ -	\$ -	

Note: Cost estimates are for energy savings calculations only, do not use for procurement

\$ 12,927	Subtotal
\$ 4,525	35% Contingency
\$ 17,452	Total

ECM-2: Window Replacement

Existing: Windows in the rear wing are single pane and have leaking seals. This can lead to increased energy consumption due to infiltration/exfiltration and heat loss.
Proposed: Install new double pane windows. Note: the rear wing is not air-conditioned

Linear Feet of window Edge	572.0 LF	Cooling System Efficiency	0 kW/ton	Heating System Efficiency	80%
Area of window glass	462.0 SF	Ex Occupied Cing Temp.	74 °F	Heating On Temp.	55 °F
Existing Infiltration Factor	0.20 cfm/LF	Ex Unoccupied Cing Temp.	74 °F	Ex Occupied Htg Temp.	72 °F
Proposed Infiltration Factor	0.10 cfm/LF	Cooling Occ Enthalpy Setpoint	27.5 Btu/lb	Ex Unoccupied Htg Temp.	72 °F
Existing U Value	1.13 Btuh/SF°F	Cooling Unocc Enthalpy Setpoint	27.5 Btu/lb	Electricity	\$ 0.150 \$/kWh
Proposed U Value	0.45 Btuh/SF°F			Natural Gas	\$ 1.25 \$/therm

					EXISTING LOADS		PROPOSED LOADS		COOLING ENERGY		HEATING ENERGY	
					Occupied	Unoccupied	Occupied	Unoccupied				
					Window Infiltration & Heat Load BTUH	Window Infiltration & Heat Load BTUH	Window Infiltration & Heat Load BTUH	Window Infiltration & Heat Load BTUH				
Avg Outdoor Air Temp. Bins °F	Avg Outdoor Air Enthalpy	Existing Equipment Bin Hours	Occupied Equipment Bin Hours	Unoccupied Equipment Bin Hours	Window Infiltration & Heat Load BTUH	Window Infiltration & Heat Load BTUH	Window Infiltration & Heat Load BTUH	Window Infiltration & Heat Load BTUH	Existing Cooling Energy kWh	Proposed Cooling Energy kWh	Existing Heating Energy Therms	Proposed Heating Energy Therms
A		B	C	D	E	F	G	H	I	J	K	L
102.5	50.1	0	0	0	-26,513	-26,513	-11,742	-11,742	0	0	0	0
97.5	42.5	6	2	4	-19,990	-19,990	-8,747	-8,747	0	0	0	0
92.5	39.5	45	16	29	-15,836	-15,836	-6,935	-6,935	0	0	0	0
87.5	36.6	146	52	94	-11,732	-11,732	-5,149	-5,149	0	0	0	0
82.5	34.0	298	106	192	-7,784	-7,784	-3,440	-3,440	0	0	0	0
77.5	31.6	476	170	306	-3,938	-3,938	-1,783	-1,783	0	0	0	0
72.5	29.2	662	237	426	0	0	0	0	0	0	0	0
67.5	27.0	740	264	476	0	0	0	0	0	0	0	0
62.5	24.5	765	273	492	0	0	0	0	0	0	0	0
57.5	21.4	733	262	471	0	0	0	0	0	0	0	0
52.5	18.7	668	239	430	12,589	12,589	5,259	5,259	0	0	105	44
47.5	16.2	659	235	424	15,817	15,817	6,607	6,607	0	0	130	54
42.5	14.4	685	245	441	19,046	19,046	7,955	7,955	0	0	163	68
37.5	12.6	739	264	475	22,274	22,274	9,304	9,304	0	0	206	86
32.5	10.7	717	256	461	25,502	25,502	10,652	10,652	0	0	229	96
27.5	8.6	543	194	349	28,730	28,730	12,001	12,001	0	0	195	81
22.5	6.8	318	114	205	31,958	31,958	13,349	13,349	0	0	127	53
17.5	5.5	245	88	158	35,186	35,186	14,697	14,697	0	0	108	45
12.5	4.1	156	56	100	38,414	38,414	16,046	16,046	0	0	75	31
7.5	2.6	92	33	59	41,642	41,642	17,394	17,394	0	0	48	20
2.5	1.0	36	13	23	44,870	44,870	18,742	18,742	0	0	20	8
-2.5	0.0	19	7	12	48,098	48,098	20,091	20,091	0	0	11	5
-7.5	-1.5	8	3	5	51,326	51,326	21,439	21,439	0	0	5	2
TOTALS		8,760	3,129	5,631					0	0	1,423	594

Existing Window Infiltration	114 cfm	Savings	828 Therms	\$ 1,032
Existing Window Heat Transfer	522 Btuh/°F		0 kWh	\$ -
Proposed Window Infiltration	57 cfm			\$ 1,032
Proposed Window Heat Transfer	208 Btuh/°F			

Window ID	Location	Quantity	Width (ft)	Height (ft)	Linear Feet (LF)	Area (SF)	Infiltration Rate (CFM/LF)	U Value (Btuh/SF°F)	Infiltration (CFM)	Heat Transfer (Btuh/°F)
1	building	22	3	5.5	374.0	363.0	0.2	1.13	74.8	410.2
2	building	22	3	1.5	198.0	99.0	0.2	1.13	39.6	111.9
Total		44	6	7	572.0	462.0	0.20	1.13	114.4	522.1

Carteret Board of Education
CHA Project Number: 30201
Carteret Board Office

Multipliers	
Material:	1.03
Labor:	1.35
Equipment:	1.10

ECM-2: Replace Windows - Cost

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
Window Replacement	462	sq.ft.	\$ 45	\$ 45	\$ -	\$ 20,790	\$ 20,790	\$ -	\$ 41,580	Vendor Est per SF

*Cost estimated are for Energy Savings only- do not use for procurement

\$ 41,580	Subtotal
\$ 14,553	35% Contingency
\$ 56,100	Total

Carteret Board of Education
CHA Project Number: 30201
Carteret Board Office

ECM-3: Steam to Hot Water Conversion

Description: This ECM evaluates the replacement of an existing steam boiler system with high efficiency condensing gas boiler and hydronic heating system. The existing boiler efficiency is 80% (per NJBPU protocols) and the proposed boiler efficiency is 90% (average seasonal efficiency).

Item	Value	Units	Formula/Comments
Baseline Fuel Cost	\$ 1.25	/ Therm	Natural Gas
Baseline Fuel Cost		/ Gal	No. 2 Oil
FORMULA CONSTANTS			
Oversize Factor	0.8		
Hours per Day	24		
Design Outdoor Temp	14	F	
Infrared Conversion Factor	1.0		1.0 if Boiler, 0.8 if Infrared Heater
EXISTING			
Capacity	2,887,000	btu/hr	
Heating Combustion Efficiency	80%		
Heating Degree-Day	2,783	Degree-day	
Design Temperature Difference	75	F	
Fuel Conversion	100,000	btu/therm	
Existing Bldg Water usage	42,636	gallons/yr	from utility data
PROPOSED			
Capacity	2,887,000	btu/hr	
Efficiency	90%		Operates in shoulder months only
Proposed Water usage	38372	gallons/yr	See Note below
SAVINGS			
Fuel Savings	2,857	Therms	NJ Protocols Calculation
Water Savings	4	kgal/yr	

Savings calculation formulas are taken from NJ Protocols document for Occupancy Controlled Thermostats

Note: water savings associated with converting from steam to hot water conservatively 10% - ASHRAE May 2010 article

Algorithms

Gas Savings (Therms)

$$= \frac{OF \times ((CAPY_{Bi} \times EFF_Q) - (CAPY_{Qi} \times EFF_B \times ICF)) \times HDD_{mod} \times 24}{\Delta T \times HC_{fuel} \times EFF_B \times ICF \times EFF_Q}$$

Definition of Variables

OF = Oversize factor of standard boiler or furnace (OF=0.8)

CAPY_{Bi} = Total input capacity of the baseline furnace, boiler or heater in Btu/hour

CAPY_{Qi} = Total input capacity of the qualifying furnace, boiler or heater in Btu/hour

HDD_{mod} = HDD by zone and building type

24 = Hours/Day

ΔT = design temperature difference

HC_{fuel} = Conversion from Btu to therms of gas or gallons of oil or propane (100,000 btu/therm; 138,700 btu/gal of #2 oil; 92,000 btu/gal of propane)

EFF_Q = Efficiency of qualifying heater(s) (AFUE %)

EFF_B = Efficiency of baseline heaters (AFUE %)

ICF = Infrared Compensation Factor (ICF = 0.8 for IR Heaters, 1.0 for furnaces/boilers)²

Furnaces and Boilers

Component	Type	Value	Source
$AFUE_q$	Variable		Application
$AFUE_b$	Fixed	Furnaces: 78% Boilers: 80% Infrared: 78%	EPACT Standard for furnaces and boilers
$CAPY_{in}$	Variable		Application
ΔT	Variable	See Table Below	1
HDD_{mod}	Fixed	See Table Below	1

Sources:

1. KEMA, *Smartstart Program Protocol Review*. 2009.
2. http://www.spaceray.com/1_space-ray_faqs.php

Adjusted Heating Degree Days by Building Type

Building Type	Heating Energy Density (kBtu/sf)	Degree Day Adjustment Factor	Atlantic City (HDD)	Newark (HDD)	Philadelphia (HDD)	Monticello (HDD)
Education	29.5	0.55	2792	2783	2655	3886
Food Sales	35.6	0.66	3369	3359	3204	4689
Food Service	39.0	0.73	3691	3680	3510	5137
Health Care	53.6	1.00	5073	5057	4824	7060
Lodging	15.0	0.28	1420	1415	1350	1976
Retail	29.3	0.55	2773	2764	2637	3859
Office	28.1	0.52	2660	2651	2529	3701
Public Assembly	33.8	0.63	3199	3189	3042	4452
Public Order/Safety	24.1	0.45	2281	2274	2169	3174
Religious Worship	29.1	0.54	2754	2745	2619	3833
Service	47.8	0.89	4524	4510	4302	6296
Warehouse/Storage	20.2	0.38	1912	1906	1818	2661

Heating Degree Days and Outdoor Design Temperature by Zone

Weather Station	HDD	Outdoor Design Temperature (F)
Atlantic City	5073	13
Newark	5057	14
Philadelphia, PA	4824	15
Monticello, NY	7060	8

Carteret Board of Education
CHA Project Number: 30201
Carteret Board Office

ECM-3: Steam to Hot Water Conversion - Cost

Multipliers	
Material:	1.03
Labor:	1.25
Equipment:	1.12

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
Hydronic Heating System (boiler, piping, radiators & UVs)	17248	S.F.	\$ 14	\$ 14		\$ 247,992	\$ 300,874		\$ 548,866	2012 RS Means Square Foot Constructi
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

\$ 548,866	Subtotal
\$ 192,103	35% Contingency
\$ 740,969	Total

Carteret Board of Education
CHA Project Number: 30201
Carteret Board Office

EQUIPMENT	AREA/EQUIPMENT SERVED	COOLING CAPACITY (btu/h)
Window AC unit	Building	12,000
Total Quantity: 17		

Total btu/h of all window A/C Units: 204,000
btu/h

ECM-4: Window A/C Controller

ECM Description : Window A/C units are currently controlled manually by the occupants and are not turned off when the room is unoccupied. This ECM evaluates implementation of a digital timer device that will automatically turn the window A/C unit off at a preset time .

ASSUMPTIONS		Comments
Electric Cost	\$0.150 / kWh	
Average run hours per Week	80 Hours	
Space Balance Point	55 F	
Space Temperature Setpoint	65 deg F	Setpoint.
BTU/Hr Rating of existing DX equipment	204,000 Btu / Hr	Total BTU/hr of DX cooling equipment to be replaced.
Average EER	10.7	
Existing Annual Electric Usage	25,475 kWh	

Item	Value	Units	Comments
Proposed Annual Electric Usage	10,640	kWh	Unit will cycle on w/ temp of room. Possible operating time shown below

ANNUAL SAVINGS	
Annual Electrical Usage Savings	14,835 kWh
Annual Cost Savings	\$2,225
Total Project Cost	\$3,500
Simple Payback	2 years

OAT - DB Bin Temp F	Annual Hours	Existing Hours of Operation	Proposed % of time of operation	Proposed hrs of Operation
102.5	0	0	100%	0
97.5	6	3	89%	3
92.5	31	15	79%	12
87.5	131	62	68%	43
82.5	500	238	58%	138
77.5	620	295	47%	140
72.5	664	316	37%	116
67.5	854	407	26%	107
62.5	927	0	0%	0
57.5	600	0	0%	0
52.5	730	0	0%	0
47.5	491	0	0%	0
42.5	656	0	0%	0
37.5	1,023	0	0%	0
32.5	734	0	0%	0
27.5	334	0	0%	0
22.5	252	0	0%	0
17.5	125	0	0%	0
12.5	47	0	0%	0
7.5	34	0	0%	0
2.5	1	0	0%	0
-2.5	0	0	0%	0
-7.5	0	0	0%	0

Total	8,760	1,336	42%	558
--------------	-------	-------	-----	-----

Carteret Board of Education
CHA Project Number: 30201
Carteret Board Office

ECM-4: Window A/C Controller - Cost

Multipliers	
Material:	1.03
Labor:	1.25
Equipment:	1.12

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
						0	\$ -	\$ -	\$ -	
Window AC Controller	17	EA	\$ 150	\$ -	\$ -	2618.85	\$ -	\$ -	\$ 2,619	Estimated
						\$ -	\$ -	\$ -	\$ -	

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

\$ 2,619	Subtotal
\$ 917	35% Contingency
\$ 3,500	Total

Carteret Board of Education
CHA Project Number: 30201
Carteret Board Office

ECM-5: Replace Gas-Fired DHW Heater w/ Tankless Condensing Gas-Fired DHW Heater

Description: This ECM evaluates the energy savings associated with replacing a gas fired tank type water heater with an equivalent capacity instantaneous water heater.

Item	Value	Units	Formula/Comments
Avg. Monthly Utility Demand by Water Heater	39	Therms/month	Calculated from utility bill
Total Annual Utility Demand by Water Heater	46,800	MBTU/yr	1therm = 100 MBTU
Existing DHW Heater Efficiency	80%		Per manufacturer nameplate
Total Annual Hot Water Demand (w/ standby losses)	37,440	MBTU/yr	
Existing Tank Size	50	Gallons	Per manufacturer nameplate
Hot Water Piping System Capacity	30	Gallons	Estimated Per existing system (includes HWR piping)
Hot Water Temperature	140	°F	Per building personnel
Room Temperature	72	°F	
Standby Losses (% by Volume)	2.5%		(2.5% of stored capacity per hour, per U.S. Department of Energy)
Standby Losses (Heat Loss)	1.1	MBH	
Annual Standby Hot Water Load	9,928	MBTU/yr	
New Tank Size	0	Gallons	Based on Takagi Flash T-H1 instantaneous, condensing DHW Heater
Hot Water Piping System Capacity	30	Gallons	Estimated Per existing system (includes HWR piping)
Hot Water Temperature	140	°F	
Room Temperature	72	°F	
Standby Losses (% by Volume)	2.5%		(2.5% of stored capacity per hour, per U.S. Department of Energy)
Standby Losses (Heat Loss)	0.4	MBH	
Annual Standby Hot Water Load	3,723	MBTU/yr	
Total Annual Hot Water Demand	31,235	MBTU/yr	
Proposed Avg. Hot water heater efficiency	96%		Based on Takagi Flash T-H1 instantaneous, condensing DHW Heater
Proposed Fuel Use	325	Therms	Standby Losses and inefficient DHW heater eliminated
Utility Cost	\$1.25	\$/Therm	
Existing Operating Cost of DHW	\$583	\$/yr	
Proposed Operating Cost of DHW	\$405	\$/yr	

Savings Summary:

Utility	Energy Savings	Cost Savings
Therms/yr	143	\$178

Carteret Board of Education
CHA Project Number: 30201
Carteret Board Office

Multipliers	
Material:	1.03
Labor:	1.25
Equipment:	1.12

ECM-5: Replace N.G. Water Heaters with Condensing DHW Heaters - Cost

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
DHW Heater Removal	1	LS		\$ 250		\$ -	\$ 312	\$ -	\$ 312	RS Means 2012
High Efficiency Gas-Fired DHW Heater	1	EA	\$ 4,000	\$ 280		\$ 4,108	\$ 349	\$ -	\$ 4,457	RS Means 2012
Miscellaneous Electrical	1	LS	\$ 300			\$ 308	\$ -	\$ -	\$ 308	RS Means 2012
Venting Kit	1	EA	\$ 450	\$ 650		\$ 462	\$ 810	\$ -	\$ 1,272	RS Means 2012
Miscellaneous Piping and Valves	1	LS	\$ 200			\$ 205	\$ -	\$ -	\$ 205	RS Means 2012

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

\$ 6,554	Subtotal
\$ 2,294	35% Contingency
\$ 8,848	Total

Carteret Board of Education
CHA Project Number: 30201
Carteret Board Office

ECM-6: Replace faucets with low flow

Description; This ECM evaluates the water savings resulting from replacing/ upgrading faucets to 0.5 gallon per minute flow

EXISTING CONDITIONS		
Cost of Water / 1000 Gallons	\$37.00	\$ / kGal
Faucets in Building	7	
Average Uses / Faucet (per day)	2	Based on # of occupants
Average Time of Use	10.0	seconds
Average Flowrate	2.5	gpm

PROPOSED CONDITIONS		
Proposed Faucets to be Replaced	7	
Proposed Flowrate	0.5	gpm

HEATING SAVINGS		
Fuel Cost	\$ 1.00	/Therm
Number of Faucets	7	
Hours per Day of Usage	0.5	hrs
Days per Year of Facility Usage	365	days
Average Flowrate	2.5	gpm
Proposed Flowrate	0.5	gpm
Heat Content of Water	8.33	Btu/gal/F
Temperature Difference (Intake and Output)	50	F
Water Heating Equipment Efficiency	80%	
Conversion Factor	100,000	Btu/Therm
SAVINGS		
Current Faucet Water Use	2.13	kGal / year
Proposed Faucet Water Use	0.43	kGal / year
Water Savings	1.70	kGal / year
Heating Savings	13	Therms
Cost Savings	\$76	/ year

Savings calculation formulas are taken from NJ Protocols document for Faucet

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

Carteret Board of Education
CHA Project Number: 30201
Carteret Board Office

ECM-6: Replace urinals and flush valves with low flow

Description: This ECM evaluates the water savings associated with replacing/ upgrading urinals with waterless urinals.

EXISTING CONDITIONS		
Cost of Water / 1000 Gallons	\$37.00	\$ / kGal
Urinals in Building to be replaced	8	
Average Flushes / Urinal (per Day)	2	Based on # of occupants
Average Gallons / Flush	1.0	Gal

PROPOSED CONDITIONS		
Proposed Urinals to be Replaced	8	
Proposed Gallons / Flush	0.000	Gal
Proposed Material Cost of new urinal & valve	\$1,200	RS Means 2012
Proposed Installation Cost of new urinal & valve	\$1,000	RS Means 2012
Total cost of new urinals & valves		

SAVINGS		
Current Urinal Water Use	4.38	kGal / year
Proposed Urinal Water Use	0.00	kGal / year
Water Savings	4.38	kGal / year
Cost Savings	\$162	/ year

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

Carteret Board of Education
CHA Project Number: 30201
Carteret Board Office

ECM-6: Replace toilets and flush valves with low flow

Description: This ECM evaluates the water savings associated with replacing/upgrading toilets to 1.28 GPF fixtures and/or flush valves.

EXISTING CONDITIONS		
Cost of Water / 1000 Gallons	\$37.00	\$ / kGal
Toilets in Building	14	
Average Flushes / Toilet (per Day)	2	Based on # of occupants
Average Gallons / Flush	3.5	Gal

PROPOSED CONDITIONS		
Proposed Toilets to be Replaced	14	
Proposed Gallons / Flush	1.28	Gal

SAVINGS		
Current Toilet Water Use	26.83	kGal / year
Proposed Toilet Water Use	9.81	kGal / year
Water Savings	17.02	kGal / year
Cost Savings	\$630	/ year

Carteret Board of Education
CHA Project Number: 30201
Carteret Board Office

Multipliers	
Material:	1.03
Labor:	1.25
Equipment:	1.12

ECM-6: Replace Plumbing Fixtures - Cost

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
									\$ -	
Waterless Urinal	8	EA	\$ 450	\$ 500	\$ -	\$ 3,697	\$ 4,984	\$ -	\$ 8,681	Vendor Estimate
Existing urinal demolition & modification of existing walls	2	EA	\$ 2,000	\$ 2,000		\$ 4,108	\$ 4,984	\$ -	\$ 9,092	Engineering Estimate
Install Dual-Flush flushometers	14	EA	\$ 300	\$ 100	\$ -	\$ 4,313	\$ 1,744	\$ -	\$ 6,058	Vendor Estimate
Low-Flow Faucet-- add aerator	7	EA	\$ 10	\$ 10	\$ -	\$ 72	\$ 87	\$ -	\$ 159	Vendor Estimate
						\$ -	\$ -	\$ -	\$ -	

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

\$ 23,990	Subtotal
\$ 8,397	35% Contingency
\$ 32,387	Total

Carteret Board of Education
CHA Project Number: 30201
Carteret Board Office

New Jersey Pay For Performance Incentive Program

Note: The following calculation is based on the New Jersey Pay For Performance Incentive Program per April, 2012. Building must have a minimum average electric demand of 100 kW. This minimum is waived for buildings owned by local governments or non-profit organizations.

At a minimum, all recommended measures were used for this calculation. To qualify for P4P incentives, the following P4P requirements must be met:

- At least 15% source energy savings
- No more than 50% savings from lighting measures
- Scope includes more than one measure
- Project has at least a 10% internal rate of return
- At least 50% of the source energy savings must come from investor-owned electricity and/or natural gas (note: exemption for fuel conversions)

Total Building Area (Square Feet)	17,248
Is this audit funded by NJ BPU (Y/N)	Yes

Board of Public Utilities (BPU)

Incentive #1		
Audit is funded by NJ BPU	\$0.05	\$/sqft

	Annual Utilities	
	kWh	Therms
Existing Cost (from utility)	\$25,614	\$9,574
Existing Usage (from utility)	170,960	7,685
Proposed Savings	44,389	2,084
Existing Total MMBtus	1,352	
Proposed Savings MMBtus	360	
% Energy Reduction	26.6%	
Proposed Annual Savings	\$9,623	

	Min (Savings = 15%)		Increase (Savings > 15%)		Max Incentive		Achieved Incentive	
	\$/kWh	\$/therm	\$/kWh	\$/therm	\$/kWh	\$/therm	\$/kWh	\$/therm
Incentive #2	\$0.09	\$0.90	\$0.005	\$0.05	\$0.11	\$1.25	\$0.11	\$1.25
Incentive #3	\$0.09	\$0.90	\$0.005	\$0.05	\$0.11	\$1.25	\$0.11	\$1.25

	Incentives \$		
	Elec	Gas	Total
Incentive #1	\$0	\$0	\$5,000
Incentive #2	\$4,883	\$2,605	\$7,488
Incentive #3	\$4,883	\$2,605	\$7,488
Total All Incentives	\$9,766	\$5,209	\$19,975

Total Project Cost	\$161,753
--------------------	-----------

		Allowable Incentive
% Incentives #1 of Utility Cost*	14.2%	\$5,000
% Incentives #2 of Project Cost**	4.6%	\$7,488
% Incentives #3 of Project Cost**	4.6%	\$7,488
Total Eligible Incentives***	\$19,975	
Project Cost w/ Incentives	\$141,778	

Project Payback (years)	
w/o Incentives	w/ Incentives
16.8	14.7

* Maximum allowable incentive is 50% of annual utility cost if not funded by NJ BPU, and %25 if it is.

** Maximum allowable amount of Incentive #2 is 25% of total project cost.

Maximum allowable amount of Incentive #3 is 25% of total project cost.

*** Maximum allowable amount of Incentive #1 is \$50,000 if not funded by NJ BPU, and \$25,000 if it is.

Maximum allowable amount of Incentive #2 & #3 is \$1 million per gas account and \$1 million per electric account; maximum 2 million per project

Energy Audit of Carteret Board Office
CHA Project No. 30201

ECM-L1 Lighting Replacements

Budgetary	Annual Utility Savings				Estimated	Total	New Jersey	Payback	Payback
Cost					Maintenance	Savings	Incentive	(without incentive)	(with incentive)
					Savings				
\$	kW	kWh	therms	\$	\$	\$	\$	Years	Years
\$47,185	7.8	23,386	0	\$3,161	0	\$3,161	\$4,830	14.9	13.4

*Incentive based on New Jersey Smart Start Prescriptive Lighting Measures

ECM-L2 Install Occupancy Sensors

Budgetary	Annual Utility Savings				Estimated	Total	New Jersey	Payback	Payback
Cost					Maintenance	Savings	Incentive	(without incentive)	(with incentive)
					Savings				
\$	kW	kWh	therms	\$	\$	\$	\$	Years	Years
\$5,130	0.0	9,707	0	\$1,194	0	\$1,194	\$400	4.3	4.0

*Incentive based on New Jersey Smart Start Prescriptive Lighting Measures

ECM-L3 Lighting Replacements with Occupancy Sensors

Budgetary	Annual Utility Savings				Estimated	Total	New Jersey	Payback	Payback
Cost					Maintenance	Savings	Incentive	(without incentive)	(with incentive)
					Savings				
\$	kW	kWh	therms	\$	\$	\$	\$	Years	Years
\$52,315	7.8	28,541	0	\$3,795	0	\$3,795	\$5,230	13.8	12.4

*Incentive based on New Jersey Smart Start Prescriptive Lighting Measures

Cost of Electricity:

\$0.123	\$/kWh
\$3.03	\$/kW

			EXISTING CONDITIONS								Retrofit Control	
	Area Description	Usage	No. of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/Space	Exist Control	Annual Hours	Annual kWh		
Field Code	Unique description of the location - Room number/Room name: Floor number (if applicable)	Describe Usage Type using Operating Hours	No. of fixtures before the retrofit	Lighting Fixture Code	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Fixt No.)	Pre-inst. control device	Estimated annual hours for the usage group	(kW/space) * (Annual Hours)	Retrofit control device	Notes
196LED	Storage (Old Gymnasium)	Storage Areas	16	W 32 C F 4 (ELE)	F44ILL	112	1.79	SW	2016	3,613	OCC	
196LED	Maintenance Shop (Old Gymnasium)	Storage Areas	6	W 32 C F 4 (ELE)	F44ILL	112	0.67	SW	2016	1,355	OCC	
196LED	Storage (Old Gymnasium)	Storage Areas	2	W 32 C F 4 (ELE)	F44ILL	112	0.22	SW	2016	452	OCC	
65	Closet (Inaccessible)	Storage Areas	1	I 100	I100/1	100	0.10	SW	2016	202	OCC	
35LED	Lobby (Old Stage Area)	Hallways	1	T 32 R F 3 (ELE)	F43ILL/2	90	0.09	SW	3360	302	NONE	
35LED	Lobby (Old Stage Area)	Hallways	1	T 32 R F 3 (ELE)	F43ILL/2	90	0.09	SW	3360	302	NONE	
35LED	Restroom (Old Stage Area)	Restrooms	1	T 32 R F 3 (ELE)	F43ILL/2	90	0.09	OCC	2688	242	OCC	
40LED	Copy Room (Old Stage Area)	Storage Areas	2	T 32 R F 2 (ELE)	F42LL	60	0.12	OCC	2016	242	OCC	
44	Restroom (Old Stage Area)	Restrooms	1	DC 26 W CF 2	CFQ26/2-L	50	0.05	SW	2688	134	OCC	
55LED	Stairs (First Floor)	Hallways	4	2T 17 R F 3 (ELE)	F23ILL	47	0.19	SW	3360	632	NONE	
218LED	Stairway	Hallways	6	W 32 C F 3 (ELE)	F43ILL/2	90	0.54	SW	3360	1,814	NONE	
40LED	Hallway	Hallways	6	T 32 R F 2 (ELE)	F42LL	60	0.36	SW	3360	1,210	NONE	
40LED	Office (Old Room 600)	Offices	10	T 32 R F 2 (ELE)	F42LL	60	0.60	OCC	3024	1,814	OCC	
46	Elevator Machine Room	Storage Areas	1	W 32 C F 2 (ELE)	F42LL	60	0.06	SW	2016	121	OCC	
35LED	Storage	Storage Areas	1	T 32 R F 3 (ELE)	F43ILL/2	90	0.09	SW	2016	181	OCC	
4LED	Closet	Storage Areas	1	2B 34 R F 2 (u) (MAG)	FU2EE	72	0.07	SW	2016	145	OCC	
40LED	Conference Room	Offices	2	T 32 R F 2 (ELE)	F42LL	60	0.12	OCC	3024	363	OCC	
40LED	Office (Old Room 648)	Offices	5	T 32 R F 2 (ELE)	F42LL	60	0.30	OCC	3024	907	OCC	
40LED	Office	Offices	10	T 32 R F 2 (ELE)	F42LL	60	0.60	OCC	3024	1,814	OCC	
40LED	Office	Offices	2	T 32 R F 2 (ELE)	F42LL	60	0.12	OCC	3024	363	OCC	
40LED	Office	Offices	8	T 32 R F 2 (ELE)	F42LL	60	0.48	OCC	3024	1,452	OCC	
40LED	Restroom (2)	Restrooms	4	T 32 R F 2 (ELE)	F42LL	60	0.24	SW	2688	645	OCC	
40LED	B&G Manager's Office	Offices	4	T 32 R F 2 (ELE)	F42LL	60	0.24	OCC	3024	726	OCC	
70	Closets (2) in B&G Managers Office (Inaccessible)	Storage Areas	2	W 32 C F 1	F41LL	32	0.06	SW	2016	129	OCC	
63	Entrance Lobby	Hallways	1	S 32 R F 1	F41LL	32	0.03	SW	3360	108	NONE	
70	Entrance Lobby	Hallways	1	W 32 C F 1	F41LL	32	0.03	SW	3360	108	NONE	
40LED	Office	Offices	2	T 32 R F 2 (ELE)	F42LL	60	0.12	OCC	3024	363	OCC	
43	Closet	Storage Areas	1	DC 26 P CF 2	CFQ26/2-L	50	0.05	SW	2016	101	OCC	
43	Closet	Storage Areas	2	DC 26 P CF 2	CFQ26/2-L	50	0.10	SW	2016	202	OCC	
43	Closet	Storage Areas	1	DC 26 P CF 2	CFQ26/2-L	50	0.05	SW	2016	101	OCC	
40LED	Superintendent's Office	Offices	8	T 32 R F 2 (ELE)	F42LL	60	0.48	OCC	3024	1,452	OCC	
40LED	Superintendent's Office	Offices	4	T 32 R F 2 (ELE)	F42LL	60	0.24	OCC	3024	726	OCC	
40LED	Stairs (Second Floor)	Hallways	4	T 32 R F 2 (ELE)	F42LL	60	0.24	SW	3360	806	NONE	
18LED	Hallway	Hallways	6	T 32 R F 4 (ELE)	F44ILL	112	0.67	SW	3360	2,258	NONE	
40LED	Old Faculty Room	Offices	2	T 32 R F 2 (ELE)	F42LL	60	0.12	OCC	3024	363	OCC	
35LED	Old Basic Skills Room	Offices	6	T 32 R F 3 (ELE)	F43ILL/2	90	0.54	SW	3024	1,633	OCC	
35LED	Old Basic Skills Room	Offices	6	T 32 R F 3 (ELE)	F43ILL/2	90	0.54	SW	3024	1,633	OCC	
46LED	Old Room 648	Offices	6	W 32 P F 2 (ELE)	F42ILL	59	0.35	SW	3024	1,070	OCC	
46LED	Old Room 648	Offices	4	W 32 P F 2 (ELE)	F42ILL	59	0.24	SW	3024	714	OCC	
46LED	Old Grade 1 Classroom	Offices	6	W 32 P F 2 (ELE)	F42ILL	59	0.35	SW	3024	1,070	OCC	
46LED	Old Grade 1 Classroom	Offices	4	W 32 P F 2 (ELE)	F42ILL	59	0.24	SW	3024	714	OCC	
40LED	Restroom	Restrooms	1	T 32 R F 2 (ELE)	F42LL	60	0.06	SW	2688	161	OCC	
18LED	Old Room 367	Offices	6	T 32 R F 4 (ELE)	F44ILL	112	0.67	SW	3024	2,032	OCC	
18LED	Old Room 367	Offices	4	T 32 R F 4 (ELE)	F44ILL	112	0.45	SW	3024	1,355	OCC	
43	Closet	Storage Areas	1	DC 26 P CF 2	CFQ26/2-L	50	0.05	SW	2016	101	OCC	
40LED	Restroom	Restrooms	1	T 32 R F 2 (ELE)	F42LL	60	0.06	SW	2688	161	OCC	
46LED	Closet	Storage Areas	1	W 32 P F 2 (ELE)	F42ILL	59	0.06	SW	2016	119	OCC	
18LED	Old Classroom Grade 2	Offices	6	T 32 R F 4 (ELE)	F44ILL	112	0.67	SW	3024	2,032	OCC	
18LED	Old Classroom Grade 2	Offices	4	T 32 R F 4 (ELE)	F44ILL	112	0.45	SW	3024	1,355	OCC	
142LED	Exterior Lights	Outdoor Lighting	10	MH 100	MH100/1	128	1.28	SW	4032	5,161	PHC	
258	Exterior Lights	Outdoor Lighting	1	CFS100	CFS100/1	100	0.10	SW	4032	403	PHC	
64LED	Exterior Lights	Outdoor Lighting	2	175 MH	MH175/1	215	0.43	SW	4032	1,734	PHC	
Total			198				15.98			47,194		

EXISTING CONDITIONS										RETROFIT CONDITIONS										COST & SAVINGS ANALYSIS						
	Area Description	No. of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/Space	Exist Control	Annual Hours	Annual kWh		Standard Fixture Code	Fixture Code	Watts per Fixture	kW/Space	Retrofit Control	Annual Hours	Annual kWh	Annual kWh Saved	Annual kW Saved	Annual \$ Saved	Retrofit Cost	NJ Smart Start Lighting Incentive	Simple Payback			
Field Code	Unique description of the location - Room number/Room name: Floor number (if applicable)	No. of fixtures before the retrofit	"Lighting Fixture Code" Example 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Fixt No.)	Pre-inst. control device	Estimated daily hours for the usage group	(kW/Space) * (Annual Hours)	No. of fixtures after the retrofit	"Lighting Fixture Code" Example 2T 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Number of Fixtures)	Retrofit control device	Estimated annual hours for the usage group	(kW/Space) * (Annual Hours)	(Original Annual kWh) - (Retrofit Annual kWh)	(Original Annual kW) - (Retrofit Annual kW)	(kWh Saved) * (\$/kWh)	Cost for renovations to lighting system	Prescriptive Lighting Measures	Length of time for renovations cost to be recovered	Simple Payback		
196LED	Storage (Old Gymnasium	16	W 32 C F 4 (ELE)	F441LL	112	1.8	SW	2016	3,613	16	T 50 R LED	RTLED50	50	0.8	SW	2,016	1,613	2,000	1.0	\$ 282.05	\$ 3,780.00	\$800	13.4	10.6		
196LED	Maintenance Shop (Old Gymnasium	6	W 32 C F 4 (ELE)	F441LL	112	0.7	SW	2016	1,355	6	T 50 R LED	RTLED50	50	0.3	SW	2,016	605	750	0.4	\$ 105.77	\$ 1,417.50	\$300	13.4	10.6		
196LED	Storage (Old Gymnasium	2	W 32 C F 4 (ELE)	F441LL	112	0.2	SW	2016	452	2	T 50 R LED	RTLED50	50	0.1	SW	2,016	202	250	0.1	\$ 35.26	\$ 472.50	\$100	13.4	10.6		
65	Closet (Inaccessible)	1	I 100	I100/1	100	0.1	SW	2016	202	1	CF 26	CFQ26/1-L	27	0.0	SW	2,016	54	147	0.1	\$ 20.76	\$ 40.50	\$0	2.0	2.0		
35LED	Lobby (Old Stage Area	1	T 32 R F 3 (ELE)	F431LL/2	90	0.1	SW	3360	302	1	T 59 R LED	RTLED38	38	0.0	SW	3,360	128	175	0.1	\$ 23.38	\$ 236.25	\$25	10.1	9.0		
35LED	Lobby (Old Stage Area	1	T 32 R F 3 (ELE)	F431LL/2	90	0.1	SW	3360	302	1	T 59 R LED	RTLED38	38	0.0	SW	3,360	128	175	0.1	\$ 23.38	\$ 236.25	\$25	10.1	9.0		
35LED	Restroom (Old Stage Area	1	T 32 R F 3 (ELE)	F431LL/2	90	0.1	OCC	2688	242	1	T 59 R LED	RTLED38	38	0.0	OCC	2,688	102	140	0.1	\$ 19.08	\$ 236.25	\$25	12.4	11.1		
40LED	Copy Room (Old Stage Area	2	T 32 R F 2 (ELE)	F421LL	60	0.1	OCC	2016	242	2	T 38 R LED	RTLED38	38	0.1	OCC	2,016	153	89	0.0	\$ 12.51	\$ 472.50	\$50	37.8	33.8		
44	Restroom (Old Stage Area	1	DC 26 W CF 2	CFQ26/2-L	50	0.1	SW	2688	134	1	DC 26 W CF 2	CFQ26/2-L	50	0.1	SW	2,688	134	-	0.0	\$ -	\$ -	\$0	#DIV/0!	15.4		
55LED	Stairs (First Floor)	4	2T 17 R F 3 (ELE)	F231LL	47	0.2	SW	3360	632	4	2T 25 R LED	2RTLED	25	0.1	SW	3,360	336	296	0.1	\$ 39.57	\$ 810.00	\$200	20.5	15.4		
218LED	Stairway	6	W 32 C F 3 (ELE)	F431LL/2	90	0.5	SW	3360	1,814	6	STLED4	STLED4	40	0.2	SW	3,360	806	1,008	0.3	\$ 134.89	\$ 2,140.20	\$90	15.9	15.2		
40LED	Hallway	6	T 32 R F 2 (ELE)	F421LL	60	0.4	SW	3360	1,210	6	T 38 R LED	RTLED38	38	0.2	SW	3,360	766	444	0.1	\$ 59.35	\$ 1,417.50	\$150	23.9	21.4		
40LED	Office (Old Room 600)	10	T 32 R F 2 (ELE)	F421LL	60	0.6	OCC	3024	1,814	10	T 38 R LED	RTLED38	38	0.4	OCC	3,024	1,149	665	0.2	\$ 89.83	\$ 2,362.50	\$250	26.3	23.5		
46	Elevator Machine Room	1	W 32 C F 2 (ELE)	F421LL	60	0.1	SW	2016	121	1	W 32 C F 2 (ELE)	F421LL	60	0.1	SW	2,016	121	-	0.0	\$ -	\$ -	\$0	#DIV/0!	14.3		
35LED	Storage	1	T 32 R F 3 (ELE)	F431LL/2	90	0.1	SW	2016	181	1	T 59 R LED	RTLED38	38	0.0	SW	2,016	77	105	0.1	\$ 14.79	\$ 236.25	\$25	16.0	14.3		
4LED	Closet	1	2B 34 R F 2 (u) (MAG)	FU2EE	72	0.1	SW	2016	145	1	2T 25 R LED	2RTLED	25	0.0	SW	2,016	50	95	0.0	\$ 13.36	\$ 202.50	\$50	15.2	11.4		
40LED	Conference Room	2	T 32 R F 2 (ELE)	F421LL	60	0.1	OCC	3024	363	2	T 38 R LED	RTLED38	38	0.1	OCC	3,024	230	133	0.0	\$ 17.97	\$ 472.50	\$50	26.3	23.5		
40LED	Office (Old Room 648)	5	T 32 R F 2 (ELE)	F421LL	60	0.3	OCC	3024	907	5	T 38 R LED	RTLED38	38	0.2	OCC	3,024	575	333	0.1	\$ 44.91	\$ 1,181.25	\$125	26.3	23.5		
40LED	Office	10	T 32 R F 2 (ELE)	F421LL	60	0.6	OCC	3024	1,814	10	T 38 R LED	RTLED38	38	0.4	OCC	3,024	1,149	665	0.2	\$ 89.83	\$ 2,362.50	\$250	26.3	23.5		
40LED	Office	2	T 32 R F 2 (ELE)	F421LL	60	0.1	OCC	3024	363	2	T 38 R LED	RTLED38	38	0.1	OCC	3,024	230	133	0.0	\$ 17.97	\$ 472.50	\$50	26.3	23.5		
40LED	Office	8	T 32 R F 2 (ELE)	F421LL	60	0.5	OCC	3024	1,452	8	T 38 R LED	RTLED38	38	0.3	OCC	3,024	919	532	0.2	\$ 71.86	\$ 1,890.00	\$200	26.3	23.5		
40LED	Restroom (2)	4	T 32 R F 2 (ELE)	F421LL	60	0.2	SW	2688	645	4	T 38 R LED	RTLED38	38	0.2	SW	2,688	409	237	0.1	\$ 32.29	\$ 945.00	\$100	29.3	26.2		
40LED	B&G Manager's Office	4	T 32 R F 2 (ELE)	F421LL	60	0.2	OCC	3024	726	4	T 38 R LED	RTLED38	38	0.2	OCC	3,024	460	266	0.1	\$ 35.93	\$ 945.00	\$100	26.3	23.5		
70	Closets (2) in B&G Manager's Office (Inaccessible)	2	W 32 C F 1	F411LL	32	0.1	SW	2016	129	2	W 32 C F 1	F411LL	32	0.1	SW	2,016	129	-	0.0	\$ -	\$ -	\$0	#DIV/0!	14.3		
63	Entrance Lobby	1	S 32 R F 1	F411LL	32	0.0	SW	3360	108	1	S 32 R F 1	F411LL	32	0.0	SW	3,360	108	-	0.0	\$ -	\$ -	\$0	#DIV/0!	14.3		
70	Entrance Lobby	1	W 32 C F 1	F411LL	32	0.0	SW	3360	108	1	W 32 C F 1	F411LL	32	0.0	SW	3,360	108	-	0.0	\$ -	\$ -	\$0	#DIV/0!	14.3		
40LED	Office	2	T 32 R F 2 (ELE)	F421LL	60	0.1	OCC	3024	363	2	T 38 R LED	RTLED38	38	0.1	OCC	3,024	230	133	0.0	\$ 17.97	\$ 472.50	\$50	26.3	23.5		
43	Closet	1	DC 26 P CF 2	CFQ26/2-L	50	0.1	SW	2016	101	1	DC 26 P CF 2	CFQ26/2-L	50	0.1	SW	2,016	101	-	0.0	\$ -	\$ -	\$0	#DIV/0!	14.3		
43	Closet	2	DC 26 P CF 2	CFQ26/2-L	50	0.1	SW	2016	202	2	DC 26 P CF 2	CFQ26/2-L	50	0.1	SW	2,016	202	-	0.0	\$ -	\$ -	\$0	#DIV/0!	14.3		
43	Closet	1	DC 26 P CF 2	CFQ26/2-L	50	0.1	SW	2016	101	1	DC 26 P CF 2	CFQ26/2-L	50	0.1	SW	2,016	101	-	0.0	\$ -	\$ -	\$0	#DIV/0!	14.3		
40LED	Superintendent's Office	8	T 32 R F 2 (ELE)	F421LL	60	0.5	OCC	3024	1,452	8	T 38 R LED	RTLED38	38	0.3	OCC	3,024	919	532	0.2	\$ 71.86	\$ 1,890.00	\$200	26.3	23.5		
40LED	Superintendent's Office	4	T 32 R F 2 (ELE)	F421LL	60	0.2	OCC	3024	726	4	T 38 R LED	RTLED38	38	0.2	OCC	3,024	460	266	0.1	\$ 35.93	\$ 945.00	\$100	26.3	23.5		
40LED	Stairs (Second Floor)	4	T 32 R F 2 (ELE)	F421LL	60	0.2	SW	3360	806	4	T 38 R LED	RTLED38	38	0.2	SW	3,360	511	296	0.1	\$ 39.57	\$ 945.00	\$100	23.9	21.4		
18LED	Hallway	6	T 32 R F 4 (ELE)	F441LL	112	0.7	SW	3360	2,258	6	T 74 R LED	RTLED50	50	0.3	SW	3,360	1,008	1,250	0.4	\$ 167.27	\$ 1,417.50	\$0	8.5	8.5		
40LED	Old Faculty Room	2	T 32 R F 2 (ELE)	F421LL	60	0.1	OCC	3024	363	2	T 38 R LED	RTLED38	38	0.1	OCC	3,024	230	133	0.0	\$ 17.97	\$ 472.50	\$50	26.3	23.5		
35LED	Old Basic Skills Room	6	T 32 R F 3 (ELE)	F431LL/2																						

EXISTING CONDITIONS											RETROFIT CONDITIONS											COST & SAVINGS ANALYSIS						
Field Code	Area Description Unique description of the location - Room number/Room name: Floor number (if applicable)	No. of Fixtures before the retrofit	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/Space	Exist Control	Annual Hours	Annual kWh	Number of Fixtures after the retrofit	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/Space	Retrofit Control device	Annual Hours	Annual kWh	Annual kWh Saved	Annual kWh Saved	Annual \$ Saved	Retrofit Cost	NJ Smart Start Lighting Incentive	Simple Payback With Out Incentive	Simple Payback				
			Lighting Fixture Code	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Fixt No.)	Pre-inst. control device	Estimated annual hours for the usage group	(kW/Space) * (Annual Hours)		'Lighting Fixture Code' Example 2T 40 R F (U) = 2x2' Troff 40 w Recess. Floor 2 lamps U shape	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Number of Fixtures)		Estimated annual hours for the usage group	(kW/Space) * (Annual Hours)	(Original Annual kWh) - (Retrofit Annual kWh)	(Original Annual kWh) - (Retrofit Annual kWh)	(kW Saved) * (\$/kWh)	Cost for renovating system		Length of time for renovations cost to be recovered	Length of time for renovations cost to be recovered				
196LED	Storage (Old Gymnasium	16	W 32 C F 4 (ELE)	F44ILL	112	1.8	SW	2016	3,612.7	16	W 32 C F 4 (ELE)	F44ILL	112	1.8	OCC	1411.2	2,528.9	1,083.8	0.0	\$133.31	\$128.25	\$10.00	1.0	0.9				
196LED	Maintenance Shop (Old Gymnasium	6	W 32 C F 4 (ELE)	F44ILL	112	0.7	SW	2016	1,354.8	6	W 32 C F 4 (ELE)	F44ILL	112	0.7	OCC	1411.2	948.3	406.4	0.0	\$49.99	\$128.25	\$10.00	2.6	2.4				
196LED	Storage (Old Gymnasium	2	W 32 C F 4 (ELE)	F44ILL	112	0.2	SW	2016	451.6	2	W 32 C F 4 (ELE)	F44ILL	112	0.2	OCC	1411.2	316.1	135.5	0.0	\$16.66	\$128.25	\$10.00	7.7	7.1				
65	Closet (Inaccessible)	1	I 100	I100/1	100	0.1	SW	2016	201.6	1	I 100	I100/1	100	0.1	OCC	1411.2	141.1	60.5	0.0	\$7.44	\$128.25	\$10.00	17.2	15.9				
35LED	Lobby (Old Stage Area	1	T 32 R F 3 (ELE)	F43ILL/2	90	0.1	SW	3360	302.4	1	T 32 R F 3 (ELE)	F43ILL/2	90	0.1	NONE	3360	302.4	0.0	0.0	\$0.00	\$0.00	\$0.00		#DIV/0!				
35LED	Lobby (Old Stage Area	1	T 32 R F 3 (ELE)	F43ILL/2	90	0.1	SW	3360	302.4	1	T 32 R F 3 (ELE)	F43ILL/2	90	0.1	NONE	3360	302.4	0.0	0.0	\$0.00	\$0.00	\$0.00		#DIV/0!				
35LED	Restroom (Old Stage Area	1	T 32 R F 3 (ELE)	F43ILL/2	90	0.1	OCC	2688	241.9	1	T 32 R F 3 (ELE)	F43ILL/2	90	0.1	OCC	1881.6	169.3	72.6	0.0	\$8.93	\$128.25	\$10.00	14.4	13.2				
40LED	Copy Room (Old Stage Area	2	T 32 R F 2 (ELE)	F42LL	60	0.1	OCC	2016	241.9	2	T 32 R F 2 (ELE)	F42LL	60	0.1	OCC	1411.2	169.3	72.6	0.0	\$8.93	\$128.25	\$10.00	14.4	13.2				
44	Restroom (Old Stage Area	1	DC 26 W CF 2	CFQ26/2-L	50	0.1	SW	2688	134.4	1	DC 26 W CF 2	CFQ26/2-L	50	0.1	OCC	1881.6	94.1	40.3	0.0	\$4.96	\$128.25	\$10.00	25.9	23.8				
55LED	Stairs (First Floor)	4	2T 17 R F 3 (ELE)	F23ILL	47	0.2	SW	3360	631.7	4	2T 17 R F 3 (ELE)	F23ILL	47	0.2	NONE	3360	631.7	0.0	0.0	\$0.00	\$0.00	\$0.00		#DIV/0!				
218LED	Stairway	6	W 32 C F 3 (ELE)	F43ILL/2	90	0.5	SW	3360	1,814.4	6	W 32 C F 3 (ELE)	F43ILL/2	90	0.5	NONE	3360	1,814.4	0.0	0.0	\$0.00	\$0.00	\$0.00		#DIV/0!				
40LED	Hallway	6	T 32 R F 2 (ELE)	F42LL	60	0.4	SW	3360	1,209.6	6	T 32 R F 2 (ELE)	F42LL	60	0.4	NONE	3360	1,209.6	0.0	0.0	\$0.00	\$0.00	\$0.00		#DIV/0!				
40LED	Office (Old Room 600)	10	T 32 R F 2 (ELE)	F42LL	60	0.6	OCC	3024	1,814.4	10	T 32 R F 2 (ELE)	F42LL	60	0.6	OCC	2116.8	1,270.1	544.3	0.0	\$66.95	\$128.25	\$10.00	1.9	1.8				
46	Elevator Machine Room	1	W 32 C F 2 (ELE)	F42LL	60	0.1	SW	2016	121.0	1	W 32 C F 2 (ELE)	F42LL	60	0.1	OCC	1411.2	94.7	36.3	0.0	\$4.46	\$128.25	\$10.00	28.7	26.9				
35LED	Storage	1	T 32 R F 3 (ELE)	F43ILL/2	90	0.1	SW	2016	181.4	1	T 32 R F 3 (ELE)	F43ILL/2	90	0.1	OCC	1411.2	127.0	54.4	0.0	\$6.70	\$128.25	\$10.00	19.2	17.7				
4LED	Closet	1	2B 34 R F 2 (u) (MAG)	FU2EE	72	0.1	SW	2016	145.2	1	2B 34 R F 2 (u) (MAG)	FU2EE	72	0.1	OCC	1411.2	101.6	43.5	0.0	\$5.36	\$128.25	\$10.00	23.9	22.1				
40LED	Conference Room	2	T 32 R F 2 (ELE)	F42LL	60	0.1	OCC	3024	362.9	2	T 32 R F 2 (ELE)	F42LL	60	0.1	OCC	2116.8	254.0	108.9	0.0	\$13.39	\$128.25	\$10.00	9.6	8.8				
40LED	Office (Old Room 648)	5	T 32 R F 2 (ELE)	F42LL	60	0.3	OCC	3024	907.2	5	T 32 R F 2 (ELE)	F42LL	60	0.3	OCC	2116.8	635.0	272.2	0.0	\$33.48	\$128.25	\$10.00	3.8	3.5				
40LED	Office	10	T 32 R F 2 (ELE)	F42LL	60	0.6	OCC	3024	1,814.4	10	T 32 R F 2 (ELE)	F42LL	60	0.6	OCC	2116.8	1,270.1	544.3	0.0	\$66.95	\$128.25	\$10.00	1.9	1.8				
40LED	Office	2	T 32 R F 2 (ELE)	F42LL	60	0.1	OCC	3024	362.9	2	T 32 R F 2 (ELE)	F42LL	60	0.1	OCC	2116.8	254.0	108.9	0.0	\$13.39	\$128.25	\$10.00	9.6	8.8				
40LED	Office	8	T 32 R F 2 (ELE)	F42LL	60	0.5	OCC	3024	1,451.5	8	T 32 R F 2 (ELE)	F42LL	60	0.5	OCC	2116.8	1,016.1	435.5	0.0	\$53.56	\$128.25	\$10.00	2.4	2.2				
40LED	Restroom (2)	4	T 32 R F 2 (ELE)	F42LL	60	0.2	SW	2688	645.1	4	T 32 R F 2 (ELE)	F42LL	60	0.2	OCC	1881.6	451.6	193.5	0.0	\$23.80	\$128.25	\$10.00	5.4	5.0				
40LED	B&G Manager's Office	4	T 32 R F 2 (ELE)	F42LL	60	0.2	OCC	3024	725.8	4	T 32 R F 2 (ELE)	F42LL	60	0.2	OCC	2116.8	508.0	217.7	0.0	\$26.78	\$128.25	\$10.00	4.8	4.4				
70	Closets (2) in B&G Manager's Office (Inaccessible	2	W 32 C F 1	F41LL	32	0.1	SW	2016	128.0	2	W 32 C F 1	F41LL	32	0.1	OCC	1411.2	80.3	38.7	0.0	\$4.76	\$128.25	\$10.00	26.9	24.8				
63	Entrance Lobby	1	S 32 R F 1	F41LL	32	0.0	SW	3360	107.5	1	S 32 R F 1	F41LL	32	0.0	NONE	3360	107.5	0.0	0.0	\$0.00	\$0.00	\$0.00		#DIV/0!				
70	Entrance Lobby	1	W 32 C F 1	F41LL	32	0.0	SW	3360	107.5	1	W 32 C F 1	F41LL	32	0.0	NONE	3360	107.5	0.0	0.0	\$0.00	\$0.00	\$0.00		#DIV/0!				
40LED	Office	2	T 32 R F 2 (ELE)	F42LL	60	0.1	OCC	3024	362.9	2	T 32 R F 2 (ELE)	F42LL	60	0.1	OCC	2116.8	254.0	108.9	0.0	\$13.39	\$128.25	\$10.00	9.6	8.8				
43	Closet	1	DC 26 P CF 2	CFQ26/2-L	50	0.1	SW	2016	100.8	1	DC 26 P CF 2	CFQ26/2-L	50	0.1	OCC	1411.2	70.6	30.2	0.0	\$3.72	\$128.25	\$10.00	34.5	31.8				
43	Closet	2	DC 26 P CF 2	CFQ26/2-L	50	0.1	SW	2016	201.6	2	DC 26 P CF 2	CFQ26/2-L	50	0.1	OCC	1411.2	141.1	60.5	0.0	\$7.44	\$128.25	\$10.00	17.2	15.9				
43	Closet	1	DC 26 P CF 2	CFQ26/2-L	50	0.1	SW	2016	100.8	1	DC 26 P CF 2	CFQ26/2-L	50	0.1	OCC	1411.2	70.6	30.2	0.0	\$3.72	\$128.25	\$10.00	34.5	31.8				
40LED	Superintendent's Office	8	T 32 R F 2 (ELE)	F42LL	60	0.5	OCC	3024	1,451.5	8	T 32 R F 2 (ELE)	F42LL	60	0.5	OCC	2116.8	1,016.1	435.5	0.0	\$53.56	\$128.25	\$10.00	2.4	2.2				
40LED	Superintendent's Office	4	T 32 R F 2 (ELE)	F42LL	60	0.2	OCC	3024	725.8	4	T 32 R F 2 (ELE)	F42LL	60	0.2	OCC	2116.8	508.0	217.7	0.0	\$26.78	\$128.25	\$10.00	4.8	4.4				
40LED	Stairs (Second Floor)	4	T 32 R F 2 (ELE)	F42LL	60	0.2	SW	3360	806.4	4	T 32 R F 2 (ELE)	F42LL	60	0.2	NONE	3360	806.4	0.0	0.0	\$0.00	\$0.00	\$0.00		#DIV/0!				
18LED	Hallway	6	T 32 R F 4 (ELE)	F44ILL	112	0.7	SW	3360	2,257.9	6	T 32 R F 4 (ELE)	F44ILL	112	0.7	NONE	3360	2,257.9	0.0	0.0	\$0.00	\$0.00	\$0.00		#DIV/0!				
40LED	Old Faculty Room	2	T 32 R F 2 (ELE)	F42LL	60	0.1	OCC	3024	362.9	2	T 32 R F 2 (ELE)	F42LL	60	0.1	OCC	2116.8	254.0	10										

		EXISTING CONDITIONS								RETROFIT CONDITIONS					COST & SAVINGS ANALYSIS									
	Area Description	No. of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/Space	Exist Control	Annual Hours	Annual kWh	Number of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/Space	Retrofit Control device	Annual Hours	Annual kWh	Annual kWh Saved	Annual kW Saved	Annual \$ Saved	Retrofit Cost	NJ Smart Start Lighting Incentive	Simple Payback With Out Incentive	Simple Payback
Field Code	Unique description of the location - Room number/Room name: Floor number (if applicable)	No. of fixtures before the retrofit	Lighting Fixture Code	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Fixt No.)	Pre-inst. control device	Estimated annual hours for the usage group	(kW/Space) * (Annual Hours)	No. of fixtures after the retrofit	"Lighting Fixture Code" Example 2T 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Number of Fixtures)	Retrofit control device	Estimated annual hours for the usage group	Annual kWh (Original Annual kWh) - (Retrofit Annual kWh)	Annual kW Saved (Original Annual kW) - (Retrofit Annual kW)	(kW Saved) * (\$/kWh)	Cost for renovations to lighting system		Length of time for renovations cost to be recovered	Simple Payback Length of time for renovations cost to be recovered	
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#VALUE!	#VALUE!
															0	#N/A	#VALUE!	#VALUE!	#N/A	#VALUE!			#	

EXISTING CONDITIONS										RETROFIT CONDITIONS										COST & SAVINGS ANALYSIS						
Area Description		No. of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/Space	Exist Control	Annual Hours	Annual kWh	Standard Fixture Code		Fixture Code	Watts per Fixture	kW/Space	Retrofit Control	Annual Hours	Annual kWh	Annual kWh Saved	Annual kW Saved	Annual \$ Saved	Retrofit Cost	NJ Smart Start	Simple Payback			
Field Code	Unique description of the location - Room number/Room name: Floor number (if applicable)	before the retrofit	Lighting Fixture Code	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Fixt No.)	Pre-inst. control device	Estimated daily hours for the usage group	(kWh/Space) * (Annual Hours)	No. of fixtures after the retrofit	Lighting Fixture Code	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Number of Fixtures)	Retrofit control device	Estimated annual hours for the usage group	(kWh/Space) * (Annual Hours)	(Original Annual kWh) - (Retrofit Annual kWh)	(Original Annual kW) - (Retrofit Annual kW)	(kWh Saved) * (\$/kWh)	Cost for renovations to lighting system	Prescriptive Lighting Measures	Length of time for renovations cost to be recovered	Simple Payback		
196LED	Storage (Old Gymnasium	16	W 32 C F 4 (ELE)	F44ILL		112	1.8	SW	2016	3,613	16	T 50 R LED	RTLED50	50	0.8	OCC	1,411	1,129	2,484	1.0	\$ 341.57	\$ 3,908.25	\$ 810	11.4	9.1	
196LED	Maintenance Shop (Old Gymnasium	6	W 32 C F 4 (ELE)	F44ILL		112	0.7	SW	2016	1,355	6	T 50 R LED	RTLED50	50	0.3	OCC	1,411	423	931	0.4	\$ 128.09	\$ 1,545.75	\$ 310	12.1	9.6	
196LED	Storage (Old Gymnasium	2	W 32 C F 4 (ELE)	F44ILL		112	0.2	SW	2016	452	2	T 50 R LED	RTLED50	50	0.1	OCC	1,411	141	310	0.1	\$ 42.70	\$ 600.75	\$ 110	14.1	11.5	
65	Closet (Inaccessible)	1	T100	T100/1		100	0.1	SW	2016	202	1	CFQ26/2-L	CFQ26/2-L	27	0.0	OCC	1,411	38	163	0.1	\$ 22.76	\$ 168.75	\$ 10	7.4	7.0	
35LED	Lobby (Old Stage Area	1	T 32 R F 3 (ELE)	F43ILL/2		90	0.1	SW	3360	302	1	T 59 R LED	RTLED38	38	0.0	NONE	3,360	128	175	0.1	\$ 23.38	\$ 236.25	\$ 25	10.1	9.0	
35LED	Lobby (Old Stage Area	1	T 32 R F 3 (ELE)	F43ILL/2		90	0.1	SW	3360	302	1	T 59 R LED	RTLED38	38	0.0	NONE	3,360	128	175	0.1	\$ 23.38	\$ 236.25	\$ 25	10.1	9.0	
35LED	Restroom (Old Stage Area	1	T 32 R F 3 (ELE)	F43ILL/2		90	0.1	OCC	2688	242	1	T 59 R LED	RTLED38	38	0.0	OCC	1,882	72	170	0.1	\$ 22.85	\$ 364.50	\$ 35	16.0	14.4	
40LED	Copy Room (Old Stage Area	2	T 32 R F 2 (ELE)	F42LL		60	0.1	OCC	2016	242	2	T 38 R LED	RTLED38	38	0.1	OCC	1,411	107	135	0.0	\$ 18.16	\$ 600.75	\$ 60	33.1	29.8	
44	Restroom (Old Stage Area	1	DC 26 W CF 2	CFQ26/2-L		50	0.1	SW	2688	134	1	DC 26 W CF 2	CFQ26/2-L	50	0.1	OCC	1,882	94	40	0.0	\$ 4.96	\$ 128.25	\$ 10	25.9	23.8	
55LED	Stairs (First Floor)	4	2T 17 R F 3 (ELE)	F23ILL		47	0.2	SW	3360	632	4	2T 25 R LED	2RTLLED	25	0.1	NONE	3,360	336	296	0.1	\$ 39.57	\$ 810.00	\$ 200	20.5	15.4	
218LED	Stairway	6	W 32 C F 3 (ELE)	F43ILL/2		90	0.5	SW	3360	1,814	6	STLED4	STLED4	40	0.2	NONE	3,360	806	1,008	0.3	\$ 134.89	\$ 2,140.20	\$ 90	15.9	15.2	
40LED	Hallway	6	T 32 R F 2 (ELE)	F42LL		60	0.4	SW	3360	1,210	6	T 38 R LED	RTLED38	38	0.2	NONE	3,360	766	444	0.1	\$ 59.35	\$ 1,417.50	\$ 150	23.9	21.4	
40LED	Office (Old Room 600)	10	T 32 R F 2 (ELE)	F42LL		60	0.6	OCC	3024	1,814	10	T 38 R LED	RTLED38	38	0.4	OCC	2,117	804	1,010	0.2	\$ 132.23	\$ 2,490.75	\$ 260	18.8	16.9	
46	Elevator Machine Room	1	W 32 C F 2 (ELE)	F42LL		60	0.1	SW	2016	121	1	W 32 C F 2 (ELE)	F42LL	60	0.1	OCC	1,411	85	446	0.0	\$ 4.46	\$ 128.25	\$ 10	28.7	26.5	
35LED	Storage	1	T 32 R F 3 (ELE)	F43ILL/2		90	0.1	SW	2016	181	1	T 59 R LED	RTLED38	38	0.0	OCC	1,411	54	128	0.1	\$ 17.61	\$ 364.50	\$ 35	20.7	18.7	
4LED	Closet	1	2B 34 R F 2 (u) (MAG)	FU2EE		72	0.1	SW	2016	145	1	2T 25 R LED	2RTLLED	25	0.0	OCC	1,411	35	110	0.0	\$ 15.22	\$ 330.75	\$ 60	21.7	17.8	
40LED	Conference Room	2	T 32 R F 2 (ELE)	F42LL		60	0.1	OCC	3024	363	2	T 38 R LED	RTLED38	38	0.1	OCC	2,117	161	202	0.0	\$ 26.45	\$ 600.75	\$ 60	22.7	20.4	
40LED	Office (Old Room 648)	5	T 32 R F 2 (ELE)	F42LL		60	0.3	OCC	3024	907	5	T 38 R LED	RTLED38	38	0.2	OCC	2,117	402	505	0.1	\$ 66.12	\$ 1,309.50	\$ 135	19.8	17.8	
40LED	Office	10	T 32 R F 2 (ELE)	F42LL		60	0.6	OCC	3024	1,814	10	T 38 R LED	RTLED38	38	0.4	OCC	2,117	804	1,010	0.2	\$ 132.23	\$ 2,490.75	\$ 260	18.8	16.9	
40LED	Office	2	T 32 R F 2 (ELE)	F42LL		60	0.1	OCC	3024	363	2	T 38 R LED	RTLED38	38	0.1	OCC	2,117	161	202	0.0	\$ 26.45	\$ 600.75	\$ 60	22.7	20.4	
40LED	Office	8	T 32 R F 2 (ELE)	F42LL		60	0.5	OCC	3024	1,452	8	T 38 R LED	RTLED38	38	0.3	OCC	2,117	644	808	0.2	\$ 105.78	\$ 2,018.25	\$ 210	19.1	17.1	
40LED	Restroom (2)	4	T 32 R F 2 (ELE)	F42LL		60	0.2	SW	2688	645	4	T 38 R LED	RTLED38	38	0.2	OCC	1,882	286	359	0.1	\$ 47.37	\$ 1,073.25	\$ 110	22.7	20.3	
40LED	B&G Manager's Office	4	T 32 R F 2 (ELE)	F42LL		60	0.2	OCC	3024	726	4	T 38 R LED	RTLED38	38	0.2	OCC	2,117	322	404	0.1	\$ 52.89	\$ 1,073.25	\$ 110	20.3	18.2	
70	Closets (2) in B&G Manager's Office (Inaccessible	2	W 32 C F 1	F41LL		32	0.1	SW	2016	129	2	W 32 C F 1	F41LL	32	0.1	OCC	1,411	90	39	0.0	\$ 4.76	\$ 128.25	\$ 10	26.9	24.8	
63	Entrance Lobby	1	S 32 R F 1	F41LL		32	0.0	SW	3360	108	1	S 32 R F 1	F41LL	32	0.0	NONE	3,360	108	-	0.0	\$ -	\$ -	\$ -	-	-	
70	Entrance Lobby	1	W 32 C F 1	F41LL		32	0.0	SW	3360	108	1	W 32 C F 1	F41LL	32	0.0	NONE	3,360	108	-	0.0	\$ -	\$ -	\$ -	-	-	
40LED	Office	2	T 32 R F 2 (ELE)	F42LL		60	0.1	OCC	3024	363	2	T 38 R LED	RTLED38	38	0.1	OCC	2,117	161	202	0.0	\$ 26.45	\$ 600.75	\$ 60	22.7	20.4	
43	Closet	1	DC 26 P CF 2	CFQ26/2-L		50	0.1	SW	2016	101	1	DC 26 P CF 2	CFQ26/2-L	50	0.1	OCC	1,411	71	30	0.0	\$ 3.72	\$ 128.25	\$ 10	34.5	31.8	
43	Closet	2	DC 26 P CF 2	CFQ26/2-L		50	0.1	SW	2016	202	2	DC 26 P CF 2	CFQ26/2-L	50	0.1	OCC	1,411	141	60	0.0	\$ 7.44	\$ 128.25	\$ 10	17.2	15.9	
43	Closet	1	DC 26 P CF 2	CFQ26/2-L		50	0.1	SW	2016	101	1	DC 26 P CF 2	CFQ26/2-L	50	0.1	OCC	1,411	71	30	0.0	\$ 3.72	\$ 128.25	\$ 10	34.5	31.8	
40LED	Superintendent's Office	8	T 32 R F 2 (ELE)	F42LL		60	0.5	OCC	3024	1,452	8	T 38 R LED	RTLED38	38	0.3	OCC	2,117	644	808	0.2	\$ 105.78	\$ 2,018.25	\$ 210	19.1	17.1	
40LED	Superintendent's Office	4	T 32 R F 2 (ELE)	F42LL		60	0.2	OCC	3024	726	4	T 38 R LED	RTLED38	38	0.2	OCC	2,117	322	404	0.1	\$ 52.89	\$ 1,073.25	\$ 110	20.3	18.2	
40LED	Stairs (Second Floor)	4	T 32 R F 2 (ELE)	F42LL		60	0.2	SW	3360	806	4	T 38 R LED	RTLED38	38	0.2	NONE	3,360	511	296	0.1	\$ 39.57	\$ 945.00	\$ 100	23.9	21.4	
18LED	Hallway	6	T 32 R F 4 (ELE)	F44ILL		112	0.7	SW	3360	2,258	6	T 74 R LED	RTLED50	50	0.3	NONE	3,360	1,008	1,250	0.4	\$ 167.27	\$ 1,417.50	\$ 70	12.9	8.5	
40LED	Old Faculty Room	2	T 32 R F 2 (ELE)	F42LL		60	0.1	OCC	3024	363	2	T 38 R LED	RTLED38	38	0.1	OCC	2,117	161	202	0.0	\$ 26.45	\$ 600.75	\$ 60	22.7	20.4	
35LED	Old Basic Skills Room	6	T 32 R F 3 (ELE)	F43ILL/2		90	0.5	SW	3024	1,633	6	T 59 R LED	RTLED38	38	0.2	OCC	2,117	483	1,150	0.3	\$ 152.83	\$ 1,545.75	\$ 160	10.1	9.1	
35LED	Old Basic Skills Room	6	T 32 R F 3 (ELE)	F43ILL/2		90	0.5	SW	3024	1,633	6	T 59 R LED	RTLED38	38	0.2	OCC	2,117	483	1,150	0.3	\$ 152.83	\$ 1,545.75	\$ 160	10.1	9.1	
46LED	Old Room 648	6	W 32 P F 2 (ELE)	F42ILL		59	0.4	SW	3024	1,070	6	4 ft LED Tube	200732x2													

[illegible]

APPENDIX D

New Jersey Board of Public Utilities Incentives

- i. Smart Start**
 - ii. Direct Install**
 - iii. Pay for Performance (P4P)**
 - iv. Energy Savings Improvement Plan (ESIP)**
-

I. SMART START




[About Us](#) | [Press Room](#) | [Library](#) | [FAQs](#) | [Calendar](#) | [Newsletters](#) | [Contact Us](#) | [Site Map](#)

HOME

RESIDENTIAL

COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

RENEWABLE ENERGY

COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT
HURRICANE SANDY

PROGRAMS

NJ SMARTSTART BUILDINGS

EQUIPMENT INCENTIVES

FOOD SERVICE EQUIPMENT

APPLICATION FORMS

TOOLS AND RESOURCES

PAY FOR PERFORMANCE

COMBINED HEAT & POWER AND FUEL CELLS

LOCAL GOVERNMENT ENERGY AUDIT

LARGE ENERGY USERS PROGRAM

ENERGY SAVINGS IMPROVEMENT PROGRAM

DIRECT INSTALL

ENERGY BENCHMARKING

OIL, PROPANE, MUNICIPAL & COOP ELECTRIC CUSTOMERS

EDA PROGRAMS

SBC CREDIT PROGRAM

PAST PROGRAMS

TOOLS AND RESOURCES

PROGRAM UPDATES

CONTACT US

[Home » Commercial & Industrial » Programs](#)

NJ SmartStart Buildings

Program Overview



With New Jersey SmartStart Buildings ...

... A smart start now means better performance later! Whether you're starting a project from the ground up, renovating existing space, or upgrading equipment, you have unique opportunities to upgrade the energy efficiency of the project.

New Jersey SmartStart Buildings can provide a range of support — at no cost to you — to yield substantial energy savings, both now and for the future. Learn more about:

- [Project Categories](#)
- [SmartStart Applications](#)
- [Program Terms and Conditions](#)
- [Find a Trade Ally](#)

Incentives for Qualifying Equipment and Projects

Financial incentives are available for size projects which can offset some - or maybe even all - of the added cost to purchase qualifying energy-efficient equipment.

Support for Custom Energy-Efficiency Measures

Custom measures gives you the opportunity to receive an incentive for unique energy-efficiency measures that are not on the prescriptive equipment list, but are new/innovative or project/facility specific.

Application and Eligibility Process

We have made it even easier to participate! Pre-approval is no longer required for prescriptive measures, with the exception of prescriptive & performance lighting and lighting controls. Please note that anyone who purchases and installs equipment without Market Manager approval does so at his/her own risk.

Program Updates

- [Notice of Fiscal Year 2016 Program Changes](#)

[Other updates posted.](#)

Program Literature



Applications and Brochures
Download the Latest Program Materials

Success Stories



Panasonic Corporation of North America
Continued Commitment to Saving Energy

Local Govt and Schools



Find out what financial incentives are available today!

Business Energy Advisor



Learn more about energy use & savings in your industry

Subscribe to eNewsletter





E-Newsletter
Subscribe for the Latest Rebate News

Follow Us:






[Home](#) | [Residential](#) | [Commercial & Industrial](#) | [Renewable Energy](#)
[About Us](#) | [Press Room](#) | [Library](#) | [FAQs](#) | [Calendar](#) | [Newsletters](#) | [Contact Us](#) | [Privacy](#) | [Site Map](#)

[About Us](#) | [Press Room](#) | [Library](#) | [FAQs](#) | [Calendar](#) | [Newsletters](#) | [Contact Us](#) | [Site Map](#)

HOME

RESIDENTIAL

COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

RENEWABLE ENERGY

COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

HURRICANE SANDY

PROGRAMS

NJ SMARTSTART BUILDINGS

EQUIPMENT INCENTIVES

FOOD SERVICE EQUIPMENT

APPLICATION FORMS

TOOLS AND RESOURCES

PAY FOR PERFORMANCE

COMBINED HEAT & POWER AND FUEL CELLS

LOCAL GOVERNMENT ENERGY AUDIT

LARGE ENERGY USERS PROGRAM

ENERGY SAVINGS IMPROVEMENT PROGRAM

DIRECT INSTALL

ENERGY BENCHMARKING

OIL, PROPANE, MUNICIPAL & COOP ELECTRIC CUSTOMERS

EDA PROGRAMS


SBC CREDIT PROGRAM

PAST PROGRAMS

TOOLS AND RESOURCES

PROGRAM UPDATES

CONTACT US




Home » Commercial & Industrial » Programs » NJ SmartStart Buildings

Equipment Incentives

More reasons for a smart start on your next project!

New Jersey SmartStart Buildings provides **financial incentives for qualifying equipment**. These incentives help offset some of the added cost to purchase qualifying energy-efficient equipment, which provides significant long-term energy savings. A wide range of incentives are available for qualifying equipment (depending on type, size and efficiency)



Application and Eligibility Process

For all Prescriptive measures with the exception of Prescriptive & Performance Lighting and Lighting Controls, pre-approval is not required prior to installation, however any customer and/or agent who purchases and installs equipment without Market Manager approval does so at their own risk.

Eligibility: in order to be eligible for program incentives, a customer, or an agent (contractor/vendor) authorized by a customer, must submit a properly completed application package. A complete application package should include:

- Completed application forms signed by the customer
- Manufacturer specification sheets and supporting documentation of qualifications.
- Recent copy of a full utility bill from a participating utility (gas or electric depending on technology) showing societal benefits charge.
 - Name of the customer listed on the application must match the name of the customer listed on the utility bill.
 - For new construction projects where a utility account has not yet been established, the customer will be required to submit a utility bill prior to incentive payment however it does not need to be included with the initial application submission.
- W-9 form completed for incentive payee.

For completed projects that do not require program pre-approval (excluding Prescriptive Lighting, Prescriptive Lighting Controls, Performance Lighting and Custom Measures) the application must be submitted to the Market Manager within 12 months of equipment purchase. Sufficient documentation must be provided confirming the date of equipment purchase (material invoice, purchase order, etc.). Customers may choose to submit additional documentation to allow the program to process payment including a valid Tax Clearance Certificate for the customer (see tax clearance requirements) and final invoice documentation. All projects are subject to post-inspection to confirm equipment installation prior to payment.

Pre-Inspections: the Market Manager reserves the right to conduct a pre-inspection of the facility prior to the installation of lighting, lighting control equipment and custom measures. This will be done prior to the issuance of the approval letter. Work must not begin prior to formal program approval.

Tax Clearance Requirements: the name of the customer listed on the certificate must match the customer name listed on the utility bill and application. In addition, the customer tax ID listed on the application must agree with the tax ID on the Certificate. Certificates are valid for 180 days and must be valid on the date the Market Manager signs off on the incentive.

Utility account: Each utility account requires a complete, separate application. Projects for the same utility account that are being done at the same time must be submitted on one application. Applications for measures that are self-installed by customers must be signed by the customer and not the sales vendor of the measure, however, the customer may elect to assign payment of the incentive to the sales vendor. This application package must be received by the Market Manager on or before June 30, 2016 in order to be eligible for the fiscal year program (July 1, 2015 - June 30, 2016) incentives.


Expirations: Pre-approved projects are given a one year approval in which the proposed measure is to be installed and operational. When a project has expired the customer will have 30 days to either submit a request for an extension OR submit final project paperwork. Extension requests must be in writing from the customer and include the circumstances that led to the extension request, and the percentage of the project completed. Extension requests may be granted for a period no longer than six (6) months. The Market Manager may provide up to two, six month extensions from the original approval expiration date. If the project has not started and the applicant is still interested in installing the equipment, the existing application will be cancelled and a new application must be submitted and approved

Program Updates

- Notice of Fiscal Year 2016 Program Changes


Other updates posted.

Program Literature



Applications and Brochures
Download the Latest Program Materials

Success Stories




Rutgers University
Continued Commitment to Saving Energy

Local Govt and Schools




Find out what financial incentives are available today!

Business Energy Advisor




Learn more about energy use & savings in your industry

Subscribe to eNewsletter



E-Newsletter
Subscribe for the Latest Rebate News

Follow Us:

prior to installation. The incentive amount will be based upon the program guidelines in effect at the time of the new submission. If no response is received within 30 days of expiration the project will be cancelled.

Listed below are the types of qualifying equipment and ranges of incentives. For details on equipment requirements and full listings of incentives, refer to the [online application forms](#).

Electric Chillers

Gas Cooling

Electric Unitary HVAC

Ground Source Heat Pumps

Gas Heating

Variable Frequency Drives

Gas Water Heating

Prescriptive lighting Application

Lighting Controls

Performance Lighting

Refrigeration Doors

Refrigeration Controls

Food Service Equipment

Refrigerator/Freezer Motors

Custom Measures

*Equipment incentives are calculated based on type, efficiency, size, and application and are evaluated on a case-by-case basis. [Contact us for details](#).

[Home](#) | [Residential](#) | [Commercial & Industrial](#) | [Renewable Energy](#)
[About Us](#) | [Press Room](#) | [Library](#) | [FAQs](#) | [Calendar](#) | [Newsletters](#) | [Contact Us](#) | [Privacy](#) | [Site Map](#)

II. DIRECT INSTALL




[About Us](#) | [Press Room](#) | [Library](#) | [FAQs](#) | [Calendar](#) | [Newsletters](#) | [Contact Us](#) | [Site Map](#)

HOME

RESIDENTIAL

COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

RENEWABLE ENERGY

COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

HURRICANE SANDY

PROGRAMS

NJ SMARTSTART BUILDINGS

PAY FOR PERFORMANCE

COMBINED HEAT & POWER AND FUEL CELLS

LOCAL GOVERNMENT ENERGY AUDIT

LARGE ENERGY USERS PROGRAM

ENERGY SAVINGS IMPROVEMENT PROGRAM

DIRECT INSTALL

PARTICIPATION STEPS

PARTICIPATING CONTRACTORS

SUSTAINABLE JERSEY

ENERGY BENCHMARKING

OIL, PROPANE, MUNICIPAL & COOP ELECTRIC CUSTOMERS

EDA PROGRAMS

SBC CREDIT PROGRAM

PAST PROGRAMS

TOOLS AND RESOURCES

PROGRAM UPDATES

CONTACT US

Home » Commercial & Industrial » Programs

Direct Install



Let us pay up to 70% of your energy efficiency upgrade.

Sometimes, the biggest challenge to improving energy efficiency is knowing where to start and how to get through the process. Created specifically for existing small to medium-sized facilities, Direct Install is a turnkey solution that makes it easy and affordable to upgrade to high efficiency equipment. Direct Install is designed to cut your facility's energy costs by replacing lighting, HVAC and other outdated operational equipment with energy efficiency alternatives. The program pays up to 70% of retrofit costs, dramatically improving your payback on the project. There is a \$125,000 incentive cap on each project.

ELIGIBILITY



Existing small to mid-sized commercial and industrial facilities with a peak electric demand that did not exceed 200 kW in any of the preceding 12 months are eligible to participate in Direct Install. Applicants will submit the last 12 months of electric utility bills indicating that they are below the demand threshold and have occupied the building during that time. Buildings must be located in New Jersey and served by one of the state's public, regulated electric or natural gas utility companies.

SYSTEMS & EQUIPMENT ADDRESSED BY THE PROGRAM

- Lighting
- Heating, Cooling & Ventilation (HVAC)
- Refrigeration
- Motors
- Natural Gas
- Variable Frequency Drives



Measures eligible for Direct Install are limited to specific equipment categories, types and capacities. Boilers may not exceed 1,500,000 Btuh and furnaces may not exceed 140,000 Btuh. Limitations on packaged HVAC, motors and other equipment also apply. Larger capacity equipment may be eligible for financial incentives through [NJ SmartStart Buildings](#).

See how other [small businesses owners](#) have saved!

BENEFITS OF DIRECT INSTALL



Turnkey Process - A network of selected [participating contractors](#) address your project from start to finish, beginning with an assessment of your facility, and ending with the installation of eligible energy-efficient equipment.

Minimal Cost - Your share of the project's cost will be approximately 30%, the program pays the remaining 70%. With incentives so dramatic, your upgrade project can very quickly pay for itself.

Fast Turnaround Time - Project installations are typically completed within 90 days from the time of scheduling your energy assessment.

Ongoing Savings - Your new energy-efficient equipment will provide savings for years to come through dramatically reduced energy costs on your monthly utility bills.

Program Updates

- Notice of Fiscal Year 2016 Program Changes

Other updates posted.

Program Literature



Applications and Brochures
Download the Latest Program Materials

Success Stories



Rutgers University
Continued Commitment to Saving Energy

Local Govt and Schools



Find out what financial incentives are available today!

Business Energy Advisor



Learn more about energy use & savings in your industry

Subscribe to eNewsletter



E-Newsletter
Subscribe for the Latest Rebate News

Follow Us:




<http://www.njcleanenergy.com/commercial-industrial/programs/direct-install>

7/29/2015



STEPS TO PARTICIPATION

[View a step-by-step description of the program.](#)

[Program Participants](#)

[Home](#) | [Residential](#) | [Commercial & Industrial](#) | [Renewable Energy](#)
[About Us](#) | [Press Room](#) | [Library](#) | [FAQs](#) | [Calendar](#) | [Newsletters](#) | [Contact Us](#) | [Privacy](#) | [Site Map](#)

III. PAY FOR PERFORMANCE (P4P)

[About Us](#) | [Press Room](#) | [Library](#) | [FAQs](#) | [Calendar](#) | [Newsletters](#) | [Contact Us](#) | [Site Map](#)

HOME

RESIDENTIAL

COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

RENEWABLE ENERGY

COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT
HURRICANE SANDY

PROGRAMS

NJ SMARTSTART BUILDINGS

PAY FOR PERFORMANCE

EXISTING BUILDINGS

NEW CONSTRUCTION

FAQS

BECOME A PARTNER

COMBINED HEAT & POWER AND FUEL CELLS

LOCAL GOVERNMENT ENERGY AUDIT

LARGE ENERGY USERS PROGRAM

ENERGY SAVINGS IMPROVEMENT PROGRAM

DIRECT INSTALL

ENERGY BENCHMARKING

OIL, PROPANE, MUNICIPAL & COOP ELECTRIC CUSTOMERS

EDA PROGRAMS

SBC CREDIT PROGRAM

PAST PROGRAMS


TOOLS AND RESOURCES

PROGRAM UPDATES

CONTACT US

Home » Commercial & Industrial » Programs


Pay for Performance



Pay for Performance is a comprehensive energy efficiency program that provides incentives towards whole-building energy improvements. Choose the component that best describes your building.


EXISTING BUILDINGS

The [Existing Buildings](#) component is designed for commercial and industrial buildings with a peak demand in excess of 200 kW in any of the preceding twelve months, and 100kW for select multifamily buildings. Save 15% or more on the energy consumption in your buildings with the help of our approved partners and receive incentives along the way.




NEW CONSTRUCTION


The [New Construction](#) component is designed for new commercial, industrial, and multifamily buildings with 50,000 square feet or more of planned space, as well as buildings undergoing substantial renovation. Construct your building to achieve energy costs 15% below the current energy code with the help of our approved partners and receive incentives.





Program Updates


- [Notice of Fiscal Year 2016 Program Changes](#)
- [Other updates posted.](#)



Program Literature

Applications and Brochures
Download the Latest Program Materials


Success Stories

Jersey Shore University Medical Center
Co-generation units at the center of major expansion

Local Govt and Schools

Find out what financial incentives are available today!



Business Energy Advisor

Learn more about energy use & savings in your industry

Subscribe to eNewsletter

E-Newsletter
Subscribe for the Latest Rebate News

Follow Us:





[Home](#) | [Residential](#) | [Commercial & Industrial](#) | [Renewable Energy](#)
[About Us](#) | [Press Room](#) | [Library](#) | [FAQs](#) | [Calendar](#) | [Newsletters](#) | [Contact Us](#) | [Privacy](#) | [Site Map](#)

[About Us](#) | [Press Room](#) | [Library](#) | [FAQs](#) | [Calendar](#) | [Newsletters](#) | [Contact Us](#) | [Site Map](#)

HOME

RESIDENTIAL

COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

RENEWABLE ENERGY

COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

HURRICANE SANDY

PROGRAMS

NJ SMARTSTART BUILDINGS

PAY FOR PERFORMANCE

EXISTING BUILDINGS

PARTICIPATION STEPS

APPLICATIONS AND FORMS

APPROVED PARTNERS

NEW CONSTRUCTION

FAQS

BECOME A PARTNER

COMBINED HEAT & POWER AND FUEL CELLS

LOCAL GOVERNMENT ENERGY AUDIT

LARGE ENERGY USERS PROGRAM

ENERGY SAVINGS IMPROVEMENT PROGRAM

DIRECT INSTALL

ENERGY BENCHMARKING

OIL, PROPANE, MUNICIPAL & COOP ELECTRIC CUSTOMERS

EDA PROGRAMS

SBC CREDIT PROGRAM

PAST PROGRAMS

TOOLS AND RESOURCES

PROGRAM UPDATES


CONTACT US

Home » [Commercial & Industrial](#) » [Programs](#) » [Pay for Performance](#) » [Existing Buildings](#)

Pay for Performance - Existing Buildings - Participation Steps

Participating in the Pay for Performance Program is easy. Just follow this step-by-step process...


- Select a program partner from this list of [approved partners](#). Be sure to [download this flyer](#) for tips on how to select a partner as well as ideas for what to expect from your working relationship.
- Submit [Application Package](#) - With your assistance, your partner will download and complete the Application and Participation Agreement and submit the forms and required documentation according to the Instructions section of the application.
- Receive Approval Notice - Program representatives will review your application package and if approved, will send a notice to proceed. A case manager will be assigned to your project.
- Develop Benchmarks and Goals. Your partner will benchmark your building, identify performance goals and create an energy reduction plan to achieve no less than 15% energy savings.
- Submit Your Plan - Your partner will submit your energy reduction plan, a complete benchmarking report and partner-participant contract with a request for [Incentive #1](#) as defined in the participation agreement. When the energy reduction plan is approved, you will receive Incentive #1.
- Implement Your Project - Your partner will help you with the bidding process and will monitor construction to ensure that the appropriate steps are being taken to achieve the expected performance goals.
- Submit Request for Second Incentive - Your partner will submit a request for [Incentive #2](#) along with the material and labor invoices when the project is complete. When approved, you will receive Incentive #2.
- Submit Request for Final Incentive - Within approximately 12 months after the project is completed, your partner will re-benchmark the building and submit a request for [Incentive #3](#) along with the post-construction benchmarking report. If the building performance goal is met, you will receive Incentive #3.



A detailed Incentive Structure document is available on the [applications and forms](#) page.

Program Updates

- Notice of Fiscal Year 2016 Program Changes
- Other updates posted.

Program Literature

Applications and Brochures
Download the Latest Program Materials

Success Stories


Rutgers University
Continued Commitment to Saving Energy

Local Govt and Schools

Find out what financial incentives are available today!


Business Energy Advisor

Learn more about energy use & savings in your industry

Subscribe to eNewsletter

E-Newsletter
Subscribe for the Latest Rebate News

Follow Us:





[Home](#) | [Residential](#) | [Commercial & Industrial](#) | [Renewable Energy](#)
[About Us](#) | [Press Room](#) | [Library](#) | [FAQs](#) | [Calendar](#) | [Newsletters](#) | [Contact Us](#) | [Privacy](#) | [Site Map](#)




[About Us](#) | [Press Room](#) | [Library](#) | [FAQs](#) | [Calendar](#) | [Newsletters](#) | [Contact Us](#) | [Site Map](#)

HOME

RESIDENTIAL

COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

RENEWABLE ENERGY

COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT
HURRICANE SANDY
PROGRAMS
NJ SMARTSTART BUILDINGS
PAY FOR PERFORMANCE
EXISTING BUILDINGS
PARTICIPATION STEPS
APPLICATIONS AND FORMS
APPROVED PARTNERS
NEW CONSTRUCTION
FAQS
BECOME A PARTNER
COMBINED HEAT & POWER AND FUEL CELLS
LOCAL GOVERNMENT ENERGY AUDIT
LARGE ENERGY USERS PROGRAM
ENERGY SAVINGS IMPROVEMENT PROGRAM
DIRECT INSTALL
ENERGY BENCHMARKING
OIL, PROPANE, MUNICIPAL & COOP ELECTRIC CUSTOMERS
EDA PROGRAMS
SBC CREDIT PROGRAM
PAST PROGRAMS
TOOLS AND RESOURCES
PROGRAM UPDATES
CONTACT US

[Home » Commercial & Industrial » Programs » Pay for Performance » Existing Buildings](#)

Pay for Performance - Existing Buildings - Applications and Forms

Forms should be completed with the assistance of your program partner. The forms are available in electronic (eForms) format, which allows you to complete the forms on your computer and save them at your convenience. Acrobat Reader 5.0 or greater is required to use eForms.

[Incentive Structure](#)

- [Program Application](#)
- [Incentive Request Form One](#)
- [Incentive Request Form Two](#)
- [Incentive Request Form Three](#)
- [Installation Agreement](#)
- [Building Performance with ENERGY STAR Participation Agreement](#)

Program Updates

- [Notice of Fiscal Year 2016 Program Changes](#)
- [Other updates posted.](#)

Program Literature



Applications and Brochures
Download the Latest Program Materials

Success Stories



Flying Fish Brewing Company
NJ's largest craft brewery supports local expansion with energy saving technologies

Local Govt and Schools




Find out what financial incentives are available today!

Business Energy Advisor



Learn more about energy use & savings in your industry


Subscribe to eNewsletter




E-Newsletter
Subscribe for the Latest Rebate News

Follow Us:



[Home](#) | [Residential](#) | [Commercial & Industrial](#) | [Renewable Energy](#)
[About Us](#) | [Press Room](#) | [Library](#) | [FAQs](#) | [Calendar](#) | [Newsletters](#) | [Contact Us](#) | [Privacy](#) | [Site Map](#)



How did you learn about this Energy Efficiency Program?

- ☐ Advertisement ☐ Internet Search ☐ Mailer ☐ Video
☐ Tradeshow/Event ☐ Word of Mouth ☐ Radio ☐ Contractor
☐ Other _____

PAY FOR PERFORMANCE APPLICATION FORM

July 1, 2015 – June 30, 2016

Utility Serving Applicant:

- ☐ Atlantic City Electric ☐ Jersey Central Power & Light ☐ PSE&G
☐ New Jersey Natural Gas ☐ Elizabethtown Gas ☐ Rockland Electric Co. ☐ South Jersey Gas
☐ Other Electric Service Provider (please specify): _____
☐ Other Fuel Provider: _____ ☐ Oil: _____ ☐ Other (Please specify): _____

Instructions

1. Read the Participation Agreement (pages 3,4) and sign where indicated.
 2. Fill out all applicable spaces on this form. Note Customer/Owner Information must be listed for the utility rate payer of the Project facility.
 3. Provide a copy of the customer's company W-9 form.
 4. Provide the most recent (within 2 years) consecutive 12 month period of utility bills for the project for all accounts, organized in chronological order and separated by account. Utilize Utility Tool for applications with multiple accounts to organize data.
 5. Provide brief description of facility, noting any special or unusual circumstances and/or site conditions.
 6. Partner must submit the application package via e-mail, mail or fax DIRECTLY to the Market Manager – see back of this form.
- Approval of this Application is not an approval of the project's scope of work. Scope of work is only approved upon approval of the Energy Reduction Plan. See application and program guidelines for more information.

Customer/Owner Information (payment will be made to entity entered here)

Company Name		Project Contact/Title	
Company Address		City	State
			Zip
Phone/Fax	E-mail	Federal ID/SSN	NAICS Code

Partner Information

Company Name		Project Contact/Title	
Company Address		City	State
			Zip
Phone	Fax	E-mail	

Project Information

Project Name			
Building Address		City	State
			Zip
Utility Account Number(s): Electric		Gas	
* Note: Please use the back of this page for additional utility accounts if quantity exceeds space allotment.			
Annual Peak kW Demand	Building Type		Number of Buildings
Size of Building(s) (gross sq/ft)		Direct, Master or Sub Metered	

Funding

- ☐ Check the box if an Energy Savings Improvement Program (ESIP) will be a source of funding. ESIP allows government agencies to pay for energy related improvements using the value of the resulting energy savings.
- Do you expect to receive funding under any other efficiency programs? ☐ No ☐ Yes If Yes, please specify below:
- Utility Program – Utility: _____ Program Name: _____
- Federal Program – Organization: _____ Program Name: _____
- Other Program – Organization: _____ Program Name: _____

Additional Project information

Additional Utility Account(s)

Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number
Account type	Account number

Additional Comments:

Complete this application form and send it directly to the Commercial/Industrial Market Manager by e-mail, mail or fax.

New Jersey's Clean Energy Program
c/o TRC Energy Services-P4P
900 Route 9 North, Suite 404 • Woodbridge, NJ 07095

Phone: 866-657-6278 • Fax: 732-855-0422
E-mail: P4P@NJCleanEnergy.com

Visit our website: NJCleanEnergy.com/P4P

New Jersey SmartStart Buildings[®] is a registered trademark. Use of the mark without the permission of the New Jersey Board of Public Utilities, Office of Clean Energy is prohibited.

*Incentives/Requirements subject to change.



001-FY16-07/15

Pay For Performance-Existing Buildings

Participation Agreement

Definitions:

ADMINISTRATOR – New Jersey Board of Public Utilities (NJBPUB)

APPLICATION PROCESS – The Program pays incentives in phases upon satisfactory completion of each of three Program milestones - approval of a complete Energy Reduction Plan, installation of all recommended measures per the Energy Reduction Plan, completion of Post-Construction Benchmarking Report (for incentive amounts, please refer to Incentive Amounts). In order to be eligible for Program Incentives, a Participating Customer or an agent authorized by a Customer, must submit to the Market Manager a properly completed application package – application form, Participating Customer's company W-9, twelve consecutive months of the project's utility bills and executed Participation Agreement. All components of the application package must be filled out completely, truthfully and accurately. This application package must be received on or before June 30, 2016 in order to be eligible for the Fiscal Year 2016 Incentives. The Market Manager will review the application package to determine if the project is eligible for a Program Incentive. When approved, the Participating Customer will receive an approval letter from their Case Manager with the estimated authorized first incentive amount and the date by which the Energy Reduction Plan must be submitted. Upon receipt of the approval letter, the Participating Customer and Partner may proceed with work on the Energy Reduction Plan. The Market Manager or agent thereof reserves the right to conduct a pre-inspection of the facility prior to the installation of equipment. This will be done prior to the issuance of the Energy Reduction Plan approval letter. Approval of this Application is not an approval of the project's scope of work. Scope of work is only approved upon approval of the Energy Reduction Plan. See application and program guidelines for more information.

CHANGES TO THE PROGRAM – The Program and Participation Agreements may be changed by the Market Manager at any time without notice. Approved applications, however, will be processed to completion under the agreements in effect at the time of the Market Manager's approval.

ELIGIBILITY - Program Incentives are available to existing commercial and industrial buildings with peak kilowatt demand usage of more than 200 kW in any of the most recent preceding twelve months of utility bills, 100 kW for multifamily buildings, and a customer of the New Jersey Utilities. Market Manager has the discretion to approve applications that fall below the 200 kW minimum, 100 kW for multifamily, by no more than 10%. If the Participant is a municipal electric company customer, and a customer of an investor-owned gas New Jersey Utility, only gas measures will be eligible for incentives under the Program. Similarly, if the Participant is an oil/propane customer and a customer of an investor-owned electric New Jersey Utility, only electricity measures will be eligible for incentives under the Program.

Projects may not participate or apply for incentives for energy efficient measures through other New Jersey's Clean Energy Programs while participating in this Program. Equipment procured by participating Customer through another program offered by New Jersey Utilities, as applicable, is not eligible for incentives through this Program. Customers who, from July 1, 2014 - June 30, 2015, have not contributed to the Societal Benefits Charge of the applicable New Jersey Utility, may not be eligible for incentives offered through this program.

ENDORSEMENT – The Market Manager and Administrator do not endorse, support or recommend any particular manufacturer, product or system design in promoting this Program.

ENERGY-EFFICIENT MEASURES – Any device eligible to receive a Program Incentive payment through the New Jersey's Clean Energy Commercial and Industrial Program

ENERGY REDUCTION PLAN – A document created by the Participating Customer's selected Partner that defines several key aspects of the project including (but not limited to) existing conditions as a result of a whole-building technical analysis, benchmarking summaries, recommended measures, financing plan and implementation schedule.

ENERGY REDUCTION PLAN APPROVAL – After application approval, the Participating Customer and Partner must work together to finalize and submit an Energy Reduction Plan which incorporates a work scope that will achieve the minimum 15% reduction in source energy performance target in accordance with the Program rules and policies along with the Benchmarking Tool, modeling software file, a copy of the executed Partner and Participating Customer contract, a copy of the executed Installation Agreement and a Request for Incentive #1 Payment form. All components of the submittal package must be filled out completely, truthfully and accurately. The Market Manager, agents thereof and/or the selected Partner must be provided reasonable access to the Participating Customer's facility, staff, tenants and/or others necessary to develop an Energy Reduction Plan that will achieve the minimum 15% performance target as well as the necessary utility billing data as dictated by the Program. The Energy Reduction Plan submittal package will be reviewed and must be approved by the Market Manager prior to payment of Incentive #1. Upon approval of the submittal package, the Customer will receive an Incentive #1 approval letter indicating the date by which all measures in the Energy Reduction Plan must be installed (no later than twelve months following the Energy Reduction Plan submittal approval date, up to twenty four months with extension approvals).

INCENTIVE AMOUNTS – Incentive #1 - \$0.10 per square foot of the project with a maximum amount of \$50,000 and minimum of \$5,000, not to exceed 50% of the project's annual energy cost and contingent on installation of measures in the Energy Reduction Plan and receipt of a signed Installation Agreement. If installation does not commence within the required timeframe, Incentive #1 may be required to be returned to the program. In the event the project is cancelled and Incentive #1 is not returned, the project may reapply to the program in the future but another Incentive #1 will not be paid. Incentive #2 – 50% of the total performance-based incentive (combination of Incentives #2 and #3) calculated per Program's incentive structure; Incentive #3 – remaining amount based on the realized energy savings of the project. For customers that have successfully participated in the Local Government Energy Audit Program, Incentive #1 will be reduced by 50% to \$0.05 per square foot up to \$25,000. Actual Incentive #1 paid shall not be higher than 5% over the committed amount. Actual Incentive #2 paid shall not be higher than the committed amount, unless the Energy Reduction Plan has been resubmitted due to changes in the work scope. Actual Incentive #3 paid shall be higher or lower than the committed amount based on actual energy savings but shall not be greater than program Incentive Caps.

The Market Manager will provide incentives according to those described in this section or as modified upon notice to Participating Customer. All incentive payments are paid directly to the Participating Customer as indicated on the application form. The Program is not bound to pay any incentive unless the submittal package associated with the incentive payment is approved by the Market Manager who reserves the sole discretion of approving or disapproving the submittal packages.

INCENTIVE CAP – Program Incentives #2 and #3 will be capped not to exceed 50% of the total project cost, lesser of estimated or actual. Incentive #1 will be capped not to exceed 50% of the project's annual energy cost. Program Incentives (Incentive #1, #2 and #3) are restricted to \$1M per gas and electric account (limited to \$2M per project) in a program year. Campus style facilities, which are master-metered, are subject to the annual incentive cap of \$1 million per gas and electric account. The Participating Customer will also be subject to an annual Entity Cap of \$4M or \$5M if a Combined Heat and Power/Fuel Cell Application is approved for the same facility (Definition of an Entity can be found in the Board Order Docket No. EO07030203).

INSTALLATION AGREEMENT – The Participating Customer must submit an executed Installation Agreement as part of the Request for Incentive #1 Form. By executing the Installation Agreement, the Customer agrees to install all of the measures in the Energy Reduction Plan, which are estimated to result in meeting or exceeding the minimum 15% performance target. The Customer agrees to the performance-based incentives (Incentives #2 & #3) as indicated in the document which are based on the results of the Energy Reduction Plan. Implementation of the measures must commence in the time period twelve months following the approval date of the Energy Reduction Plan, up to twenty four months with extension approvals. Failure to complete the installation of the measures in the Energy Reduction Plan may result in the repayment of Incentive #1, and the forfeiting of Incentives #2 and #3. In the event the project is cancelled and Incentive #1 is not returned, the project may reapply to the program in the future but another Incentive #1 will not be paid.

LIMITATION OF LIABILITY – By virtue of participating in this Program, Participating Customers agree to waive any and all claims or damages against TRC Energy Services, the Market Manager, and the Administrator, except the receipt of the Program Incentive. Participating Customers agree that the Market Manager's and Administrator's liability, in connection with this Program, is limited to paying the Program Incentive specified. Under no circumstances shall the Market Manager, its representatives, or subcontractors, or the Administrator be liable for any lost profits, special, punitive, consequential or incidental damages or for any other damages or claims connected with or resulting from participation in this Program. Further, any liability attributed to the Market Manager under this Program shall be individual, and not joint and/or several.

The Market Manager's review and approval of the Energy Reduction Plan cannot be construed to be a determination as to performance, applicability, dollar savings, energy savings, or any other aspect of the proposed project. The Market Manager and Administrator offer no guarantee or warranty of performance of the project's equipment or system. The participant assumes full responsibility and liability for the installation of all equipment, including but not limited to design, specification, all permits, installation, maintenance, performance and financing. By participating in the program and accepting incentive dollars, you agree to hold harmless the Market Manager and Administrator and their respective staffs with respect to the Project

MARKET MANAGER – TRC Energy Services is responsible for managing the New Jersey Clean Energy Commercial & Industrial Programs.

MEASUREMENT & VERIFICATION APPROVAL – Twelve months subsequent to the Incentive #2 Payment Submittal package approval date, measurement and verification of the projected energy reduction will be conducted by the Participating Customer's Partner using the project's post-installation utility data (supplied by the Customer). The Participating Customer must work with their Partner to submit the Incentive #3 Payment Submittal, consisting of the Post-Construction Benchmarking Report, Benchmarking Tool, and Request for Incentive #3 form. All components of the submittal package must be filled out completely, truthfully and accurately.

Upon review of the submittal package (by the Market Manager or agent thereof), the remaining 50% of the total performance-based incentive (Incentives #2 & #3) will be released to the Participating Customer. If the Post-Construction Benchmarking Report indicates that the project did not meet the minimum performance target, the post-installation completion period may be extended to up to twenty-four months subsequent to the Incentive Payment #2 package approval date. If after this time the minimum performance target is still not met, the final Incentive #3 will not be paid.

NEW JERSEY UTILITIES – The investor-owned electric and/or gas utilities in the State of New Jersey. They are: Atlantic City Electric, Jersey Central Power & Light, Rockland Electric Company, New Jersey Natural Gas, Elizabethtown Gas, PSE&G, and South Jersey Gas.

PARTICIPATING CUSTOMERS – Those non-residential electric and/or gas service customers of the New Jersey Utilities who participate in this Program.

PARTICIPATING CUSTOMER'S CERTIFICATION – Participating Customer agrees that all information is true and that he/she has conformed to all of the Program and equipment requirements per the Program Guidelines. Participating Customer certifies that he/she purchased and installed the equipment listed in the Energy Reduction Plan at their defined New Jersey project location.

PARTNER – An approved professional who provides technical building performance services to Participating Customers, acting as their “energy efficiency expert”. Participating Customers are required to hire an approved Pay for Performance Partner to develop the Energy Reduction Plan and facilitate installation of the recommended package of Energy-Efficient Measures. Participants are required to enter into a contractual agreement with a selected Partner which outlines the set of minimum services the Partner will provide to the Participating Customer throughout the life of the project. It is strongly recommended that Participating Customers perform due diligence in selecting a Pay for Performance Partner. Fees charged by the Partner are not regulated by the Program and could vary between Partners. Incentives may cover some, or potentially all, of the Partner fees.

PERFORMANCE-BASED INCENTIVES – The combination of Incentives #2 and #3, which are based on the projected and actual energy reduction performance of the project.

PERFORMANCE TARGET – A minimum of a 15% annual source energy savings must be achieved in order to participate. The performance target is based on reducing the total energy consumption for the facility. No more than 50% of the total source energy savings may be derived from lighting measures; up to 70% lighting savings may be considered but performance target will increase by 1% for each percent over 50% (e.g. project with 60% savings from lighting will have a minimum performance target of 25%). A 4% performance target may be offered to customers whose annual energy consumption is heavily weighted to manufacturing and process loads, as well as hospitals. This approach will be reviewed on a case-by-case basis and must be pre-approved by the Market Manager. In order to be considered, the project must involve: A manufacturing facility, including such industries as plastics and packaging, chemicals, petrochemicals, metals, paper and pulp, transportation, biotechnology, pharmaceutical, food and beverage, mining and mineral processing, general manufacturing, equipment manufacturers and data centers; and manufacturing and/or process-related loads, including data center consumption, consume 50% or more of total facility energy consumption. For hospitals, 50% or more of the gross floor area must be used for general medical and surgical services and 50% or more of the licensed beds must provide acute care services. The total energy savings may not come from a single measure. No more than 50% of the total source energy savings may be derived from non-investor owned utilities or fuels.

POST-INSTALLATION APPROVAL – After the complete installation of all measures in the Energy Reduction Plan, the Customer and their Partner must finalize and submit the Incentive #2 Payment Submittal, consisting of the Installation Report, invoices, and Request for Incentive #2 Payment form. All components of the submittal package must be filled out completely, truthfully and accurately. Upon review of the submittal package and verification of the complete installation of all measures in the Energy Reduction Plan (via inspection by the Market Manager or agent thereof), 50% of the total performance based incentive (Incentives #2 & #3) will be released to the Participating Customer. Upon approval of the submittal package, the Customer will receive an Incentive #2 approval letter indicating the date by which the post-installation Measurement & Verification phase began and will end (twelve to twenty four months in length).

The Market Manager reserves the right to verify sales transactions and to have reasonable access to Participating Customer's facility to inspect both pre-existing products or equipment (if applicable) and the Energy-Efficient Measures installed under this Program, either prior to issuing incentives or at a later time. Energy-Efficient Measures must be installed in buildings located within the service territory of one of the New Jersey Utilities (as defined by the Program) as designated on the Participating Customer's Pay for Performance application. Program Incentives are available for qualified Energy-Efficient Measures as listed and described in the Program Guidelines. The Participating Customer must ultimately own the equipment, either through an up-front purchase or at the end of a short-term lease.

PRE-INSTALLED MEASURES - An Energy Reduction Plan must be approved by the program and an approval letter sent to the customer in order for incentives to be committed. Upon receipt of an Energy Reduction Plan, all project facilities must be pre-inspected. Measures installed prior to pre-inspection of the facility shall not be included as part of the ERP scope of work and will not be eligible for incentive

Measure installation undertaken prior to ERP approval, but after pre-inspection, is done at the customer's own risk. In the event that an Energy Reduction Plan is rejected by the program, the customer will not receive any incentives.

PRODUCT INSTALLATION OR EQUIPMENT INSTALLATION – Installation of the Energy-Efficient Measures. Projects with a contract threshold of \$15,444 are required to pay no less than prevailing wage rate to workers employed in the performance of any construction undertaken in connection with Board of Public Utilities financial assistance, or undertaken to fulfill any condition of receiving Board of Public Utilities financial assistance, including the performance of any contract to construct, renovate or otherwise prepare a facility, the operations of which are necessary for the receipt of Board of Public Utilities financial assistance. By submitting an application, or accepting program incentives, applicant agrees to adhere to New Jersey Prevailing Wage requirements, as applicable.

PROGRAM – New Jersey's Clean Energy Pay for Performance Program offered herein by the New Jersey Board of Public Utilities pursuant to state regulatory approval under the New Jersey Electric Discount and Energy Competition Act, NJSA 48:3-49, et seq.

PROGRAM GUIDELINES – See Pay for Performance Program Guidelines available from your Partner.

PROGRAM INCENTIVES – Refers to the amount or level of incentive that the Program provides to participating customers pursuant to the Program offered herein (see the description under “Incentive Amount” heading).

PROGRAM OFFER – The Program covers products purchased and/or services rendered on or after July 1, 2015.

PROJECT – A commercial or industrial existing building with peak demand in excess of 200 kW in any of the most recent preceding twelve months of electric usage, 100 kW for multifamily buildings. Multifamily building(s) must be four (4) stories or greater or three (3) stories and under having central heating, cooling, or metering serving more than one building. Refer to Multifamily Decision Tree.

TAX CLEARANCE CERTIFICATION – Businesses must apply for and receive a Tax Clearance Certificate from the New Jersey Division of Taxation before they can receive any incentive, grant or other financial assistance from the Program.

TAX LIABILITY – The Market Manager will not be responsible for any tax liability that may be imposed on any Participating Customer as a result of the payment of Program Incentives. All Participating Customers must supply their federal tax identification number or social security number on the application form in addition to providing a copy of their W-9 form as part of the application package in order to receive a Program Incentive.

TERMINATION – New Jersey's Clean Energy Program reserves the right to extend, modify (this includes modification of Program Incentive levels) or terminate this Program without prior or further notice.

WARRANTIES – THE MARKET MANAGER AND ADMINISTRATOR DO NOT WARRANT THE PERFORMANCE OF INSTALLED EQUIPMENT, AND/OR SERVICES RENDERED AS PART OF THIS PROGRAM, EITHER EXPRESSLY OR IMPLICITLY. NO WARRANTIES OR REPRESENTATIONS OF ANY KIND, WHETHER STATUTORY, EXPRESSED, OR IMPLIED, INCLUDING, WITHOUT LIMITATIONS, WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE REGARDING EQUIPMENT OR SERVICES PROVIDED BY A MANUFACTURER OR VENDOR. CONTACT YOUR VENDOR/ SERVICES PROVIDER FOR DETAILS REGARDING PERFORMANCE AND WARRANTIES.

ACKNOWLEDGEMENT – I have read, understood and am in compliance with all rules and regulations concerning this incentive program. I certify that all information provided is correct to the best of my knowledge, and I give the Market Manager permission to share my records with the New Jersey Board of Public Utilities, and contractors it selects to manage, coordinate or evaluate the Pay For Performance Program, including the release of electric and natural gas utility billing information, as well as make available to the public non-sensitive information. I allow reasonable access to my property to inspect the installation and performance of the technologies and installations that are eligible for incentives under the guidelines of New Jersey's Clean Energy Program. This arrangement supersedes all other communications and representations.

CUSTOMER'S SIGNATURE

PARTNER SIGNATURE

By signing, I certify that I have read, understand and agree to the Participation Agreement listed above.

IV. ENERGY SAVINGS IMPROVEMENT PLAN (ESIP)




[About Us](#) | [Press Room](#) | [Library](#) | [FAQs](#) | [Calendar](#) | [Newsletters](#) | [Contact Us](#) | [Site Map](#)

HOME

RESIDENTIAL

COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

RENEWABLE ENERGY

COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT
HURRICANE SANDY

PROGRAMS

NJ SMARTSTART BUILDINGS

PAY FOR PERFORMANCE

COMBINED HEAT & POWER AND FUEL CELLS

LOCAL GOVERNMENT ENERGY AUDIT

LARGE ENERGY USERS PROGRAM

ENERGY SAVINGS IMPROVEMENT PROGRAM

DIRECT INSTALL

ENERGY BENCHMARKING

OIL, PROPANE, MUNICIPAL & COOP ELECTRIC CUSTOMERS

EDA PROGRAMS

SBC CREDIT PROGRAM

PAST PROGRAMS

TOOLS AND RESOURCES

PROGRAM UPDATES

CONTACT US

[Home » Commercial & Industrial » Programs](#)

Energy Savings Improvement Program

A new State law allows government agencies to make energy related improvements to their facilities and pay for the costs using the value of energy savings that result from the improvements. Under Chapter 4 of the Laws of 2009 (the law), the "Energy Savings Improvement Program" (ESIP), provides all government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources.

Please review the [New Jersey's Clean Energy Program \(NJCEP\) and ESIP Interaction memo](#) and flow chart for recommendations on when to submit incentive applications to various NJCEP programs relative to the ESIP timeframe.

This [Local Finance Notice](#) outlines how local governments can develop and implement an ESIP for their facilities. Below are two sample RFPs:

- Local Government
- School Districts (K-12)

All RFPs and final Energy Savings Plan (ESP) must be submitted to the Board for approval at ESIP@bpu.state.nj.us.

The Board also adopted protocols to measure energy savings:

- Measuring Energy Savings
- Procedures for Implementation

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Local units should carefully consider all alternatives to develop an approach that best meets their needs. Local units considering an ESIP should carefully review the Local Finance Notice, the law, and consult with qualified professionals to determine how they should approach the task.

The NJ Board of Public Utilities sponsored Sustainable Jersey in the creation of an [ESIP Guidebook](#) that explains how to implement the program. The guidebook also includes case studies of successful projects and a list of helpful resources.

FIRST STEP - ENERGY AUDIT

For local governments interested in pursuing an ESIP, the first step is to perform an energy audit, as prescribed in [P.L.2012 c.55](#).

ENERGY SAVINGS PLANS

If you have an ESIP plan that needs to be submitted to the Board of Public Utilities, please email it to ESIP@bpu.state.nj.us. Please limit the file size to 3MB (or break it into smaller files).

- Ocean Township Board of Education:
 - Part 1
 - Part 2
 - Part 3
 - Part 4
- Tabernacle Board of Education
- Robbinsville Board of Education
- Frankford Township School District
- Northern Hunterdon-Voorhees Regional High School
- Manalapan Township (**180 MB** - Right Click, Save As)

Program Updates

- Notice of Fiscal Year 2016 Program Changes

[Other updates posted.](#)

Program Literature

Applications and Brochures
Download the Latest Program Materials

Success Stories

Panasonic Corporation of North America
Continued Commitment to Saving Energy

Local Govt and Schools

Find out what financial incentives are available today!

Business Energy Advisor

Learn more about energy use & savings in your industry

Subscribe to eNewsletter

E-Newsletter
Subscribe for the Latest Rebate News

Follow Us:





[Home](#) | [Residential](#) | [Commercial & Industrial](#) | [Renewable Energy](#)
[About Us](#) | [Press Room](#) | [Library](#) | [FAQs](#) | [Calendar](#) | [Newsletters](#) | [Contact Us](#) | [Privacy](#) | [Site Map](#)

APPENDIX E

Photovoltaic Analysis

Photovoltaic (PV) Solar Power Generation - Screening Assessment

Carteret Board of Education Carteret Board Office

Cost of Electricity	\$0.150	/kWh
Electricity Usage	170,960	kWh/yr
System Unit Cost	\$4,000	/kW

Note: this is equal to the annual kWh consumption for the bldg.

Photovoltaic (PV) Solar Power Generation - Screening Assessment

Budgetary	Annual Utility Savings				Estimated	Total		New Jersey	Payback	Payback
Cost					Maintenance	Savings	Federal Tax	Renewable	(without	(with
					Savings		Credit	** SREC	incentive)	incentive)
\$	kW	kWh	therms	\$	\$	\$	\$	\$	Years	Years
\$40,000	10.0	12,749	0	\$1,912	0	\$1,912	\$0	\$2,167	20.9	9.8

** Estimated Solar Renewable Energy Certificate Program (SREC) SREC for 15 Years= \$170 /1000kwh

Area Output*

704 m²
7,578 ft²

Perimeter Output*

177 m
581 ft

Available Roof Space for PV:

(Area Output - 10 ft x Perimeter) x 85%
1,499 ft²

Approximate System Size:

Is the roof flat? (Yes/No) Yes

8 watt/ft²
11,995 DC watts
10 kW Enter into PV Watts

PV Watts Inputs***

Enter into PV Watts (always 20 if flat, if
Array Tilt Angle 20 pitched - enter estimated roof angle)
Array Azimuth 180 Enter into PV Watts (default)
Zip Code 07008 Enter into PV Watts
DC/AC Derate Factor 0.83 Enter into PV Watts



PV Watts Output

12,749 annual kWh calculated in PV Watts program

% Offset Calc

Usage 170,960 (from utilities)
PV Generation 12,749 (generated using PV Watts)
% offset 7%

* <http://www.freemaptools.com/area-calculator.htm>

** <http://www.flettexchange.com>

*** http://gisatnrel.nrel.gov/PVWatts_Viewer/index.html



Cautions: Photovoltaic system performance predictions calculated by PVWatts® include many inherent assumptions and uncertainties and do not reflect variations between PV technologies nor site-specific characteristics except as represented by PVWatts® inputs. For example, PV modules with better performance are not differentiated within PVWatts® from lesser performing modules. Both NREL and private companies provide more sophisticated PV modeling tools (such as the System Advisor Model at <http://sam.nrel.gov/>) that allow for more precise and complex modeling of PV systems.

Disclaimer: The PVWatts® Model ("Model") is provided by the National Renewable Energy Laboratory ("NREL"), which is operated by the Alliance for Sustainable Energy, LLC ("Alliance") for the U.S. Department Of Energy ("DOE") and may be used for any purpose whatsoever.

The names DOE/NREL/ALLIANCE shall not be used in any representation, advertising, publicity or other manner whatsoever to endorse or promote any entity that adopts or uses the Model. DOE/NREL/ALLIANCE shall not provide

any support, consulting, training or assistance of any kind with regard to the use of the Model or any updates, revisions or new versions of the Model.

YOU AGREE TO INDEMNIFY DOE/NREL/ALLIANCE, AND ITS AFFILIATES, OFFICERS, AGENTS, AND EMPLOYEES AGAINST ANY CLAIM OR DEMAND, INCLUDING REASONABLE ATTORNEYS' FEES, RELATED TO YOUR USE, RELIANCE, OR ADOPTION OF THE MODEL FOR ANY PURPOSE WHATSOEVER. THE MODEL IS PROVIDED BY DOE/NREL/ALLIANCE "AS IS" AND ANY EXPRESS OR IMPLIED WARRANTIES, INCLUDING BUT NOT LIMITED TO THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE ARE EXPRESSLY DISCLAIMED. IN NO EVENT SHALL DOE/NREL/ALLIANCE BE LIABLE FOR ANY SPECIAL, INDIRECT OR CONSEQUENTIAL DAMAGES OR ANY DAMAGES WHATSOEVER, INCLUDING BUT NOT LIMITED TO CLAIMS ASSOCIATED WITH THE LOSS OF DATA OR PROFITS, WHICH MAY RESULT FROM ANY ACTION IN CONTRACT, NEGLIGENCE OR OTHER TORTIOUS CLAIM THAT ARISES OUT OF OR IN CONNECTION WITH THE USE OR PERFORMANCE OF THE MODEL.

RESULTS

12,749 kWh per Year *

Month	Solar Radiation (kWh / m ² / day)	AC Energy (kWh)	Energy Value (\$)
January	2.78	753	113
February	3.52	852	128
March	4.34	1,133	170
April	4.95	1,207	181
May	5.69	1,392	209
June	5.86	1,352	203
July	5.73	1,350	202
August	5.47	1,278	192
September	4.91	1,141	171
October	3.99	991	149
November	2.68	674	101
December	2.35	626	94
Annual	4.36	12,749	\$ 1,913

Location and Station Identification

Requested Location	599 Roosevelt Ave., Carteret, NJ 07008
Weather Data Source	(TMY2) NEWARK, NJ 9.4 mi
Latitude	40.7° N
Longitude	74.17° W

PV System Specifications (Commercial)

DC System Size	10 kW
Module Type	Standard
Array Type	Fixed (open rack)
Array Tilt	20°
Array Azimuth	180°
System Losses	14%
Inverter Efficiency	96%
DC to AC Size Ratio	1.1

Initial Economic Comparison

Average Cost of Electricity Purchased from Utility	0.15 \$/kWh
Initial Cost	4.00 \$/Wdc
Cost of Electricity Generated by System	0.18 \$/kWh

Selected Incentives

Capacity Based Incentives (CBI)	New Jersey Renewable Energy Incentive Program Rate: \$0.75 - Maximum Amount: \$5,625.00
---------------------------------	--

These values can be compared to get an idea of the cost-effectiveness of this system. However, system costs, system financing options (including 3rd party ownership) and complex utility rates can significantly change the relative value of the PV system.

APPENDIX F

Photos



1: Carteret Board Office



2: Opportunity for attic insulation



2: Rear single story wing with older windows



4: Gas fired steam boiler



5: Rear of building showing window A/C units

APPENDIX G

EPA Benchmarking Report



ENERGY STAR[®] Statement of Energy Performance

63

ENERGY STAR[®]
Score¹

Carteret Board Office

Primary Property Function: Office
Gross Floor Area (ft²): 17,248
Built: 1939

For Year Ending: April 30, 2015
Date Generated: June 05, 2015

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information

Property Address
Carteret Board Office
599 Roosevelt Avenue
Carteret, New Jersey 07008

Property Owner

,
(____)____-____

Primary Contact

,
(____)____-____

Property ID: 4438955

Energy Consumption and Energy Use Intensity (EUI)

Site EUI	Annual Energy by Fuel		National Median Comparison	
78.4 kBtu/ft ²	Natural Gas (kBtu)	768,460 (57%)	National Median Site EUI (kBtu/ft ²)	91.3
	Electric - Grid (kBtu)	583,316 (43%)	National Median Source EUI (kBtu/ft ²)	178.1
			% Diff from National Median Source EUI	-14%
Source EUI	Annual Emissions			
153 kBtu/ft ²	Greenhouse Gas Emissions (Metric Tons CO ₂ e/year)		119	

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: _____ Date: _____

Licensed Professional

,
(____)____-____



Professional Engineer Stamp
(if applicable)