

**EAST HANOVER TOWNSHIP
SCHOOL DISTRICT**

BOARD OF EDUCATION OFFICE

**20 SCHOOL AVENUE
EAST HANOVER, NJ 07936**

FACILITY ENERGY REPORT

TABLE OF CONTENTS

I.	HISTORIC ENERGY CONSUMPTION/COST.....	2
II.	FACILITY DESCRIPTION	7
III.	MAJOR EQUIPMENT LIST	9
IV.	ENERGY CONSERVATION MEASURES.....	10
V.	ADDITIONAL RECOMMENDATIONS	13

Appendix A – ECM Cost & Savings Breakdown

Appendix B – New Jersey Smart Start® Program Incentives

Appendix C – Portfolio Manager “Statement of Energy Performance”

Appendix D – Major Equipment List

Appendix E – Investment Grade Lighting Audit

Appendix F – Renewable / Distributed Energy Measures Calculations

I. HISTORIC ENERGY CONSUMPTION/COST

The energy usage for the facility has been tabulated and plotted in graph form as depicted within this section. Each energy source has been identified and monthly consumption and cost noted per the information provided by the Owner.

Electric Utility Provider:	Jersey Central Power & Light
Electric Utility Rate Structure:	General Service Secondary
Third Party Supplier:	First Energy Solutions & Direct Energy Business
Natural Gas Utility Provider:	Public Service Electric & Gas
Utility Rate Structure:	General Service Gas (GSG)
Third Party Supplier:	Hess Corporation

The electric usage profile represents the actual electrical usage for the facility. The electric utility measures consumption in kilowatt-hours (KWH) and maximum demand in kilowatts (KW). One KWH usage is equivalent to 1000 watts running for one hour. One KW of electric demand is equivalent to 1000 watts running at any given time. The basic usage charges are shown as generation service and delivery charges along with several non-utility generation charges. Rates used in this report reflect the historical data received for the facility.

The gas usage profile within each facility report shows the actual natural gas energy usage for the facility. The gas utility measures consumption in cubic feet x 100 (CCF), and converts the quantity into Therms of energy. One Therm is equivalent to 100,000 BTUs of energy.

Table 1
Electricity Billing Data

ELECTRIC USAGE SUMMARY			
Utility Provider: JCP&L Rate: General Service Secondary 3 Phase Meter No: G79658928 / S34964497 Account No: 100 004 887 723 / 100 004 887 814 Third Party Utility Provider: Direct Energy TPS Meter / Acct No: -			
MONTH OF USE	CONSUMPTION KWH	DEMAND KW	TOTAL BILL
Dec-12	3,539	8.8	\$438
Jan-13	4,605	10.2	\$486
Feb-13	4,677	10.2	\$485
Mar-13	3,494	8.7	\$427
Apr-13	2,262	18.1	\$316
May-13	2,341	17.0	\$349
Jun-13	2,785	19.4	\$399
Jul-13	3,635	20.9	\$502
Aug-13	2,392	16.4	\$351
Sep-13	2,491	18.0	\$355
Oct-13	3,966	15.6	\$504
Nov-13	1,487	17.1	\$265
Totals	37,674	20.9 Max	\$4,877
AVERAGE DEMAND 15.0 KW average AVERAGE RATE \$0.129 \$/kWh			

Figure 1
Electricity Usage Profile





Table 2
Natural Gas Billing Data

NATURAL GAS USAGE SUMMARY		
Utility Provider: PSE&G Rate: GSG Meter No: 1792623 Account No: 66 562 352 04 Third Party Utility Provider: HESS TPS Meter No: 526148/526157		
MONTH OF USE	CONSUMPTION (THERMS)	TOTAL BILL
Dec-12	1,281.57	\$1,255.36
Jan-13	1,272.79	\$1,236.00
Feb-13	1,237.99	\$1,210.73
Mar-13	1,085.12	\$945.24
Apr-13	219.76	\$209.32
May-13	30.55	\$39.46
Jun-13	0.00	\$11.27
Jul-13	0.00	\$11.27
Aug-13	0.00	\$11.27
Sep-13	0.00	\$11.27
Oct-13	419.69	\$415.59
Nov-13	996.10	\$971.00
TOTALS	6,543.56	\$6,327.78
AVERAGE RATE:	\$0.97	\$/THERM

Figure 2
Natural Gas Usage Profile



II. FACILITY DESCRIPTION

The Board of Education office is located at 20 School Avenue in East Hanover, New Jersey. The 7,083 SF combined building was built at different times. The original building was built in 1930 and the addition in 1971. The original facility is a 2-story building comprised of the Superintendent's offices and the School District maintenance shops and storage in the basement. The 1971 addition is a one-story building that includes the secretary offices, Business Administrator's office, a conference room, special services offices, a boiler room, a lunch room, a work room, and Board Secretary's office.

Occupancy Profile

The typical hours of operation for the BOE offices are Monday through Friday between 8:00 am and 5:00 pm with custodial staff on site afterhours till approximately 8:00 pm. The Board of Education office operates continually throughout the year.

Building Envelope

Exterior walls for the original BOE office are stucco over wood, plaster walls with no insulation. The windows in the 1930 building are original, in very poor condition and leak. The use of thermal insulation in building walls and aluminum windows with Low-E high-performance insulating glass contribute in reducing the annual energy cost. Additionally, it helps in extending the periods of thermal comfort without reliance on mechanical air-conditioning especially during the fall and spring periods. The magnitude of energy savings as a result of using thermal insulation and high-performance window systems vary according to the building type, the climatic conditions at which the building is located as well as the type, thickness, and location of the insulating material used.

It is strongly recommended that the School District investigate the options for upgrading the window system and adding insulation to the exterior walls.

The exterior walls in the addition are concrete block with stucco finish and some wall insulation. The windows throughout the 1971 offices are in good condition and are double pane, operable, 1/4" glass with aluminum frames. The roof of the lower addition is a flat, built-up rubber roof where all of the mechanical rooftop equipment is placed. The roof of the two-story building is an A-frame with asphalt shingles. The amount of insulation below the roof is unknown.

HVAC Systems

The BOE offices are heated by a central hot water boiler plant located in the boiler room of the addition. Hot water is provided by a Weil-McLain Model HG-9 gas-fired, cast iron sectional boiler rated for an input capacity of 445 MBH and an output capacity of 356 MBH (new). The boiler was manufactured in 1971, is in very poor condition, and well beyond its service life along with using more gas than a high-efficiency modular unit. Hot water is pumped to the various fin-tube radiators in the 1971 addition via two (2) Bell & Gossett in-line pumps with 3/4 HP motors and the original 2-story building via two (2) Bell & Gossett in-line pumps with 1/2 HP motors.

The facility has four (4) packaged rooftop units as follows:

<u>Unit Tag</u>	<u>Area Served</u>	<u>Mfg.</u>	<u>Type</u>
RTU-1	Superintendent Offices	York	Electric Packaged
RTU-2	Secretaries Offices/BA Office	York	Electric Packaged
RTU-3	Large Conference Room	WeatherKing	Electric Packaged
RTU-4	Special Services	Luxaire	Gas/Electric Packaged

In addition, there is a new Energy Star rated window air-conditioning unit (10,000 BTUH) for the work room/server room with an EER = 10.8.

Exhaust System

Toilet exhaust air is relieved through roof mounted exhaust fans with small fractional horsepower fan motors.

HVAC System Controls

The boiler, hot water pumps, three-way valves are controlled by a Barber Colman electronic 2-input controller. The balance of the HVAC systems within the building are controlled by programmable thermostats except the Special Services and Maintenance Shops which do not have programmable thermostats.

Domestic Hot Water

Domestic hot water for the facility restrooms/janitor sink is provided by a Rheem 15-gallon electric water heater and several Rheem electric water heaters that have a storage capacity of 6 gallons for the individual restrooms.

Lighting

Refer to the Investment Grade lighting Audit Appendix for a detailed list of the lighting throughout the facility and estimated operating hours per space.

III. MAJOR EQUIPMENT LIST

The equipment list contains major energy consuming equipment that through implementation of energy conservation measures could yield substantial energy savings. The list shows the major equipment in the facility and all pertinent information utilized in energy savings calculations. An approximate age was assigned to the equipment in some cases if a manufactures date was not shown on the equipment's nameplate. The ASHRAE service life for the equipment along with the remaining useful life is also shown in the Appendix.

Refer to the **Major Equipment List Appendix** for this facility.

IV. ENERGY CONSERVATION MEASURES

Energy Conservation Measures are developed specifically for this facility. The energy savings and calculations are highly dependent on the information received from the site survey and interviews with operations personnel. The assumptions and calculations should be reviewed by the owner to ensure accurate representation of this facility. The following ECMs were analyzed:

Table 1
ECM Financial Summary

ENERGY CONSERVATION MEASURES (ECM's)					
ECM NO.	DESCRIPTION	NET INSTALLATION COST^A	ANNUAL SAVINGS^B	SIMPLE PAYBACK (Yrs)	SIMPLE LIFETIME ROI
ECM #1	Lighting Upgrade - General	\$11,445	\$612	18.7	-19.8%
ECM #2	Lighting Controls Upgrade	\$1,475	\$101	14.6	2.7%
ECM #3	Boiler OA Reset Controls	\$6,312	\$825	7.7	96.0%
ECM #4	Boiler Replacement	\$42,646	\$1,189	35.9	-30.3%
ECM #5	Programmable Thermostats	\$2,248	\$414	5.4	176.2%
ECM #6	Split System Replacement	\$8,724	\$236	37.0	-59.4%
ECM #7	Water Conservation	\$6,480	\$1,283	5.1	197.0%
RENEWABLE ENERGY MEASURES (REM's)					
ECM NO.	DESCRIPTION	NET INSTALLATION COST	ANNUAL SAVINGS	SIMPLE PAYBACK (Yrs)	SIMPLE LIFETIME ROI
REM #1	5.76 kW PV System	\$28,895	\$2,130	13.6	10.6%

Notes: A. Cost takes into consideration applicable NJ Smart StartTM incentives.

B. Savings takes into consideration applicable maintenance savings.

Table 2
ECM Energy Summary

ENERGY CONSERVATION MEASURES (ECM's)				
ECM NO.	DESCRIPTION	ANNUAL UTILITY REDUCTION		
		ELECTRIC DEMAND (KW)	ELECTRIC CONSUMPTION (KWH)	NATURAL GAS (THERMS)
ECM #1	Lighting Upgrade - General	1.86	4,742	0
ECM #2	Lighting Controls Upgrade	0.0	784	0
ECM #3	Boiler OA Reset Controls	0.0	0	851
ECM #4	Boiler Replacement	0.0	0	1,226
ECM #5	Programmable Thermostats	0.0	0	426
ECM #6	Split System Replacement	1.7	1,830	0
ECM #7	Water Conservation	0.0	5,059	0
RENEWABLE ENERGY MEASURES (REM's)				
ECM NO.	DESCRIPTION	ANNUAL UTILITY REDUCTION		
		ELECTRIC DEMAND (KW)	ELECTRIC CONSUMPTION (KWH)	NATURAL GAS (THERMS)
REM #1	5.76 kW PV System	5.8	6,656	0

Table 3
ECM Emissions Summary

ENERGY CONSERVATION MEASURES (ECM's)				
ECM NO.	DESCRIPTION	GREENHOUSE GAS EMISSIONS REDUCTION		
		CO₂ EMISSIONS (LBS)	NO_x EMISSIONS (LBS)	SO₂ EMISSIONS (LBS)
ECM #1	Lighting Upgrade - General	7,208	13	31
ECM #2	Lighting Controls Upgrade	1,192	2	5
ECM #3	Boiler OA Reset Controls	9,957	8	0
ECM #4	Boiler Replacement	14,344	11	0
ECM #5	Programmable Thermostats	9,793	8	0
ECM #6	Split System Replacement	2,782	5	12
ECM #7	Water Conservation	7,690	14	33

Notes: A. Emissions Reduction based on NJCEP published factors for electric & gas.

Table 4
Facility Project Summary

FACILITY PROJECT SUMMARY TABLE					
ENERGY CONSERVATION MEASURES	ANNUAL ENERGY SAVINGS (\$)	PROJECT COST (\$)	SMART START INCENTIVES	CUSTOMER COST	SIMPLE PAYBACK
Lighting Upgrade - General	\$612	\$11,445	\$0	\$11,445	18.7
Lighting Controls Upgrade	\$101	\$1,600	\$125	\$1,475	14.6
Boiler OA Reset Controls	\$825	\$6,312	\$0	\$6,312	7.7
Boiler Replacement	\$1,189	\$43,346	\$700	\$42,646	35.9
Programmable Thermostats	\$414	\$2,248	\$0	\$2,248	5.4
Split System Replacement	\$236	\$9,000	\$276	\$8,724	37.0
Water Conservation	\$1,283	\$6,480	\$0	\$6,480	5.1
Total Project	\$4,660	\$80,431	\$1,101	\$79,330	17.0

Note the measure totals in this table do not take into account interactive effects of measures; see Method of Analysis Section III in Executive Report for further explanation.

This project does not qualify for additional incentives through the Pay for Performance Program, please see the Installation Funding Options section for additional program options.

ECM #1: Lighting Upgrade – General

Description:

The majority of the interior lighting throughout the East Hanover Board Office is provided with fluorescent fixtures with older generation, 32W T8 lamps and electronic ballasts. These can be retrofitted to LED style lamps.

This ECM includes retrofitting the interior lighting with new LED type lamps and fixtures. It is recommended the District consult with a professional engineer prior to retrofitting fixtures to ensure code required minimum light levels will be met.

Energy Savings Calculations:

The **Investment Grade Lighting Audit Appendix** outlines the hours of operation, proposed retrofits, costs, savings, and payback periods for each set of fixtures in the each building.

LIGHTING UPGRADE SAVINGS SUMMARY	
DESCRIPTION	SAVINGS
Electric Demand Savings (kW)	1.9
Electric Usage Savings (kWh)	4,742
Electric Cost Savings (\$)	\$612

Energy Savings Summary:

ECM #1 - ENERGY SAVINGS SUMMARY	
Installation Cost (\$):	\$11,445
NJ Smart Start Equipment Incentive (\$):	\$0
Net Installation Cost (\$):	\$11,445
Maintenance Savings (\$/Yr):	\$0
Energy Savings (\$/Yr):	\$612
Total Yearly Savings (\$/Yr):	\$612
Estimated ECM Lifetime (Yr):	15
Simple Payback	18.7
Simple Lifetime ROI	-19.8%
Simple Lifetime Maintenance Savings	\$0
Simple Lifetime Savings	\$9,180
Internal Rate of Return (IRR)	-3%
Net Present Value (NPV)	(\$4,138.98)

ECM #2: Lighting Controls Upgrade – Occupancy Sensors

Description:

Some of the lights in the East Hanover BOE Office are left on unnecessarily. In many cases the lights are left on because of the inconvenience to manually switch lights off when a room is left or on when a room is first occupied. This is common in rooms that are occupied for only short periods and only a few times per day. In some instances lights are left on due to the misconception that it is better to keep the lights on rather than to continuously switch lights on and off. Although increased switching reduces lamp life, the energy savings outweigh the lamp replacement costs. The payback timeframe for when to turn the lights off is approximately two minutes. If the lights are expected to be off for at least a two minute interval, then it pays to shut them off.

Lighting controls come in many forms. Sometimes an additional switch is adequate to provide reduced lighting levels when full light output is not needed. Occupancy sensors detect motion and will switch the lights on when the room is occupied. Occupancy sensors can either be mounted in place of a current wall switch, or on the ceiling to cover large areas.

The U.S. Department of Energy sponsored a study to analyze energy savings achieved through various types of building system controls. The referenced savings is based on the “Advanced Sensors and Controls for Building Applications: Market Assessment and Potential R&D Pathways,” document posted for public use April 2005. The study has found that commercial buildings have the potential to achieve significant energy savings through the use of building controls. The average energy savings are as follows based on the report:

- Occupancy Sensors for Lighting Control 20% - 28% energy savings.

Savings resulting from the implementation of this ECM for energy management controls are estimated to be 20% of the total light energy controlled by occupancy sensors.

This ECM includes installation of ceiling or switch mount sensors for mostly offices. Sensors shall be manufactured by SensorSwitch, Watt Stopper or equivalent. The **Investment Grade Lighting Audit Appendix** of this report includes the summary of lighting controls implemented in this ECM and outlines the proposed controls, costs, savings, and payback periods. The calculations adjust the lighting power usage by the applicable percent savings for each area that includes lighting controls.

Energy Savings Calculations:

$$\text{Energy Savings} = (\% \text{ Savings} \times \text{Controlled Light Energy (kWh/Yr)})$$

$$\text{Savings} = \text{Energy Savings (kWh)} \times \text{Ave Elec Cost} \left(\frac{\$}{\text{kWh}} \right)$$

LIGHTING CONTROLS SAVINGS SUMMARY	
DESCRIPTION	SAVINGS
Electric Demand Savings (kW)	0.0
Electric Usage Savings (kWh)	784
Electric Cost Savings (\$)	\$101

Rebates and Incentives:

From the **NJ Smart Start[®] Program Incentives Appendix**, the installation of a lighting control device warrants the following incentive:

Smart Start Incentive

$$= (\# \text{ Wall mount sensors} \times \$20 \text{ per sensor}) \\ + (\# \text{ Ceiling mount sensors} \times \$35 \text{ per sensor})$$

Energy Savings Summary:

ECM #2 - ENERGY SAVINGS SUMMARY	
Installation Cost (\$):	\$1,600
NJ Smart Start Equipment Incentive (\$):	\$125
Net Installation Cost (\$):	\$1,475
Maintenance Savings (\$/Yr):	\$0
Energy Savings (\$/Yr):	\$101
Total Yearly Savings (\$/Yr):	\$101
Estimated ECM Lifetime (Yr):	15
Simple Payback	14.6
Simple Lifetime ROI	2.7%
Simple Lifetime Maintenance Savings	\$0
Simple Lifetime Savings	\$1,515
Internal Rate of Return (IRR)	0%
Net Present Value (NPV)	(\$269.27)

ECM #3: Boiler OA Reset Controls

Description:

Currently, the boiler at the BOE Building is staged on and off to maintain a fixed hot water set point. This temperature was most likely selected during engineering and was designed to meet the heat load for the building on the coldest days of the year. Maintaining this set point can result in wasted energy and improper heating of the spaces in the building. Controlling the temperature of the boiler supply water based on the temperature of the air outside the building can improve fuel use efficiency, as well as help maintain more accurate space temperatures.

This ECM replaces the existing Barber Colman boiler control with Heat Timer HWRQ Platinum controls and sensors. These sensors have the ability to stage the existing heating hot water boiler on and off and reset the heating water supply temperature based on outside air temperature.

Energy Savings Calculation:

The New Jersey Board of Public Utilities, in the Protocols to Measure Resource Savings, has set the savings associated with adding fuel use economizing controls to boilers at 13% of the annual heating fuel use.

OUTSIDE AIR RESET CONTROLS			
ECM INPUTS	EXISTING	PROPOSED	SAVINGS
ECM INPUTS	No Controller	OA Reset Controller	
Existing Boiler Usage (Therms)	6,544.00	6,544.00	
Estimated Savings (%)	0%	13%	
Natural Gas Cost (\$/Therm)	\$0.97	\$0.97	
ENERGY SAVINGS CALCULATIONS			
ECM RESULTS	EXISTING	PROPOSED	SAVINGS
Natural Gas Usage (Therms)	6,544	5,693	851
Natural Gas Savings (\$)	\$6,348	\$5,522	\$825
COMMENTS:	Estimated savings percentage obtained from NJBPU New Jersey Clean Energy Program Protocols.		

Energy Savings Summary:

ECM #3 - ENERGY SAVINGS SUMMARY	
Installation Cost (\$):	\$6,312
NJ Smart Start Equipment Incentive (\$):	\$0
Net Installation Cost (\$):	\$6,312
Maintenance Savings (\$/Yr):	\$0
Energy Savings (\$/Yr):	\$825
Total Yearly Savings (\$/Yr):	\$825
Estimated ECM Lifetime (Yr):	15
Simple Payback	7.7
Simple Lifetime ROI	96.0%
Simple Lifetime Maintenance Savings	\$0
Simple Lifetime Savings	\$12,375
Internal Rate of Return (IRR)	10%
Net Present Value (NPV)	\$3,536.50

ECM # 4: Boiler Replacement

Description:

The BOE offices are heated by a central hot water boiler plant located in the boiler room of the addition. Hot water is provided by a Weil-McLain Model HG-9 gas-fired, cast iron sectional boiler rated for an input capacity of 445 MBH and a rated output capacity of 356 MBH when new. The boiler was manufactured in 1971, is in very poor condition, and beyond its service life along with using more gas than a high-efficiency modular unit.

CEG recommends replacing this boiler with a 400 MBH high-efficiency condensing hot water boiler. Condensing boilers can substantially improve the operating efficiency of the heating system of the building. A condensing boiler's peak efficiency tops out at 99% depending on return water temperature. The natural gas to water efficiency for a 400 MBH boiler with digital burner controls is approximately 92% over its operating range and with the advanced controls and a 5:1 turn down ratio.

This energy conservation measure will replace the existing Weil-McLain gas-fired, cast iron, sectional boiler serving the facility with a high-efficiency, modular, condensing heating hot water boiler. Calculation is based on the following equipment: Lochinvar Knight XL, modular, condensing hot water boiler or equivalent.

Energy Savings Calculations:

Gas consumption of the boiler plant is gathered in order to calculate the estimated heat output of the existing boilers. It is confirmed that the boiler is for space heating only and does not provide domestic hot water heating.

The annual gas consumption is used in a reverse calculation in the below equations to obtain proposed annual gas consumption based on improved efficiency. Calculations are summarized in the table below.

$$\text{Annual Output, MMBTU} = \frac{\text{Consumption (Therms)} \times 100,000 \frac{\text{BTU}}{\text{Therm}} \times \text{Current Boiler Effc}}{1,000,000}$$

$$\text{Proposed Gas Consumption, Therms} = \frac{\text{Annual Output (MMBTU)} \times 1,000,000}{100,000 \frac{\text{BTU}}{\text{Therm}} \times \text{New Boiler Efficiency}}$$

HIGH EFFICIENCY BOILER CALCULATIONS			
ECM INPUTS	EXISTING	PROPOSED	SAVINGS
ECM INPUTS	Existing Cast Iron Boilers	New High Efficiency Boilers	
Existing Nat Gas (Therms)	5,126		
Boiler Efficiency (%)	70.0%	92.0%	22%
Nat Gas Heat Value (BTU/Therm)	100,000	100,000	
Equivalent Building Heat Usage (MMBTUs)	359	359	
Gas Cost (\$/Therm)	\$0.97	\$0.97	
ENERGY SAVINGS CALCULATIONS			
ECM RESULTS	EXISTING	PROPOSED	SAVINGS
Natural Gas Usage (Therms)	5,126	3,900	1,226
Energy Cost (\$)	\$4,973	\$3,783	\$1,189
COMMENTS:	Boiler Efficiency Based on age of boiler, and average of both boilers		

Energy Savings Summary:

ECM #4 - ENERGY SAVINGS SUMMARY	
Installation Cost (\$):	\$43,346
NJ Smart Start Equipment Incentive (\$):	\$700
Net Installation Cost (\$):	\$42,646
Maintenance Savings (\$/Yr):	\$0
Energy Savings (\$/Yr):	\$1,189
Total Yearly Savings (\$/Yr):	\$1,189
Estimated ECM Lifetime (Yr):	25
Simple Payback	35.9
Simple Lifetime ROI	-30.3%
Simple Lifetime Maintenance Savings	\$0
Simple Lifetime Savings	\$29,725
Internal Rate of Return (IRR)	-3%
Net Present Value (NPV)	(\$21,941.93)

ECM #5: Four (4) Additional 7-Day Programmable Thermostats

Description:

The Special Services Department offices and Maintenance Shop are not properly controlled. The two (2) thermostats in the perimeter offices which control the hot water fin-tube radiators are not working properly since they are old, out of calibration, and do not have programmable capabilities. The hot water radiators that heat the Maintenance Shop run continuously even when the space is not occupied. Also, the thermostats in the Maintenance Shop are old, not calibrated, and also do not have programmable capabilities.

This ECM would install four high-end, 7-day programmable thermostats with nighttime temperature setback capabilities.

Energy Savings Calculations:

Energy savings calculations are derived from the annual energy consumption of the system based on total heating capacity and efficiency of the system. The calculation uses the number of annual heating degree days and the estimated hours of setback during the unoccupied period on each day. Energy savings is the difference between the energy consumption of the unit at always occupied mode and partly occupied mode.

Heating design day temperature conditions: $T_i = 65^{\circ}\text{F}$
 $T_o = 60^{\circ}\text{F}$

$$\text{Non Set Back Heating Energy} = \frac{\text{Heat Load} \times \text{HDD}_{65^{\circ}\text{F}} \times 24 \frac{\text{Hr}}{\text{Day}}}{(T_i) \times 100,000 \frac{\text{BTU}}{\text{Therm}}} \times \frac{\text{Non Set Back Hrs/ Week}}{168 \text{ Hrs per Week}}$$

$$\text{Set Back Heating Energy} = \frac{\text{Heat Load} \times \text{HDD}_{60^{\circ}\text{F}} \times 24 \frac{\text{Hr}}{\text{Day}}}{(T_o) \times 100,000 \frac{\text{BTU}}{\text{Therm}}} \times \frac{\text{Set Back Hrs per Week}}{168 \text{ Hrs per Week}}$$

$$\text{Heating Cost Savings} = \text{Energy Savings (Therms)} \times \text{Cost of Gas} \left(\frac{\$}{\text{Therm}} \right)$$

HEATING ENERGY CALCULATIONS			
ECM INPUTS	EXISTING	PROPOSED	SAVINGS
ECM INPUTS	Standard Controls	Programmable TStat (5°F Setback)	
Area of the Space (SF)	7,083	7,083	
Estimated Unit Heat Load (BTU/SF)	40	40	
Estimated Total Heat Load (BTU)	283,320	283,320	
Design Day Interior Temp. (°F)	65	60	
Design Day Ambient Temp. (°F)	15	15	
Heating Degree Days (65°F Base)	4,889	4,889	
Heating Degree Days (60°F Base)	3,778	3,778	
Hours of setback per week	0	128	
Heating Fuel Value	100,000	100,000	
Gas Cost (\$/Therm)	\$0.97	\$0.97	
ENERGY SAVINGS CALCULATIONS			
ECM RESULTS	EXISTING	PROPOSED	SAVINGS
Total Heating Energy Consumption (Therms)	4,092	3,665	426
Heating Energy Cost (\$)	\$3,969	\$3,555	\$414
COMMENTS:	Degree Days based on Newark Int Airport		

Energy Savings Summary:

ECM #5 - ENERGY SAVINGS SUMMARY	
Installation Cost (\$):	\$2,248
NJ Smart Start Equipment Incentive (\$):	\$0
Net Installation Cost (\$):	\$2,248
Maintenance Savings (\$/Yr):	\$0
Energy Savings (\$/Yr):	\$414
Total Yearly Savings (\$/Yr):	\$414
Estimated ECM Lifetime (Yr):	15
Simple Payback	5.4
Simple Lifetime ROI	176.2%
Simple Lifetime Maintenance Savings	\$0
Simple Lifetime Savings	\$6,210
Internal Rate of Return (IRR)	17%
Net Present Value (NPV)	\$2,694.31

ECM #6: Replace York Split System Unit with High Efficiency Unit

Description:

The BOE Building has a York Model DCHB-T036 packaged rooftop air conditioning only unit which serves some of the interior spaces and is in very poor condition. The estimated existing unit efficiency is 8.5 SEER. This 3-Ton split unit has surpassed its ASHRAE service life expectancy of 15 years. Replacing this unit with a newer more efficient unit would result in significant energy savings.

The unit currently installed has lower efficiency compared to a modern high-efficiency unit. New units provide higher full load and part load efficiencies due to advances in inverter motor technologies, higher efficiency refrigerants such as R410A which would be used in place of R22 that is currently used in the unit.

This ECM includes replacement of this older rooftop unit with a new higher efficiency rooftop. It is recommended to fully evaluate the capacity needed for the new rooftop unit prior to moving forward with this ECM. A summary of the unit replacement for this ECM can be found in the table below:

IMPLEMENTATION SUMMARY					
ECM INPUTS	SERVICE FOR	NUMBER OF UNITS	COOLING CAPACITY, BTU/HR	TOTAL CAPACITY, TONS	REPLACE UNIT WITH
RTU	Packaged Rooftop	1	36,000	3.0	Trane 4TCY4036B
Total		1	36,000	3.0	

The high-efficiency rooftop used as the basis for the calculation is a Trane Model 4TCY4036B with a SEER=14. The unit pricing and install cost were estimated based on current rates quotes and labor rates. The payback may change based on actual unit pricing and installed costs if the ECM is implemented.

Energy Savings Calculations:

Cooling Energy Savings:

Seasonal energy consumption of the air conditioners at the cooling mode is calculated with the equation below:

$$\text{Energy Savings, kWh} = \text{Cooling Capacity, } \frac{\text{BTU}}{\text{Hr}} \times \left(\frac{1}{\text{SEER}_{\text{Old}}} - \frac{1}{\text{SEER}_{\text{New}}} \right) \times \frac{\text{Operation Hours}}{1000 \frac{\text{W}}{\text{kWh}}}$$

$$\text{Demand Savings, kW} = \frac{\text{Energy Savings (kWh)}}{\text{Hours of Cooling}}$$

$$\text{Cooling Cost Savings} = \text{Energy Savings, kWh} \times \text{Cost of Electricity} \left(\frac{\$}{\text{kWh}} \right)$$

ENERGY SAVINGS CALCULATIONS							
ECM INPUTS	EXISTING COOLING CAPACITY, BTU/Hr	ANNUAL COOLING HOURS	EXISTING UNIT SEER	NEW UNIT SEER	# OF UNITS	ENERGY SAVINGS kWh	DEMAND SAVINGS kW
RTU	36,000	1,100	8.5	14	1	1,830	1.7
Total					1	1,830	1.7

Project Cost, Incentives and Maintenance Savings

From the NJ Smart Start[®] Program appendix, the replacement of split system AC units and unitary systems with high efficiency AC systems falls under the category “Unitary HVAC Split System” and warrants an incentive based on efficiency (EER/SEER). The program incentives are calculated as follows:

$$\text{Smart Start}^{\text{®}} \text{ Incentive} = (\text{Cooling Tons} \times \$/\text{Ton Incentive})$$

AC UNITS REBATE SUMMARY				
UNIT DESCRIPTION	UNIT EFFICIENCY	REBATE \$/TON	PROPOSED CAPACITY TONS	TOTAL REBATE \$
5.4 tons or less Unitary AC and Split System	≥14 SEER	\$92	3.0	\$276
TOTAL			3	\$276

Summary of cost, savings and payback for this ECM is below.

COST & SAVINGS SUMMARY							
ECM INPUTS	INSTALLED COST	# OF UNITS	TOTAL COST	REBATES	NET COST	ENERGY SAVINGS	PAY BACK YEARS
RTU	\$9,000	1	\$9,000	\$276	\$8,724	\$236	37.0
Total	\$9,000	1	\$9,000	\$276	\$8,724	\$236	37.0

Energy Savings Summary:

ECM #6 - ENERGY SAVINGS SUMMARY	
Installation Cost (\$):	\$9,000
NJ Smart Start Equipment Incentive (\$):	\$276
Net Installation Cost (\$):	\$8,724
Maintenance Savings (\$/Yr):	\$0
Energy Savings (\$/Yr):	\$236
Total Yearly Savings (\$/Yr):	\$236
Estimated ECM Lifetime (Yr):	15
Simple Payback	37.0
Simple Lifetime ROI	-59.4%
Simple Lifetime Maintenance Savings	0
Simple Lifetime Savings	\$3,540
Internal Rate of Return (IRR)	-10%
Net Present Value (NPV)	(\$5,906.65)

ECM #7: Water Conservation

Description:

The BOE Building utilizes standard plumbing fixtures. The typical sink aerator consumption is 2.2 gallons per minute. New fixtures and aerators are available that use less water that can add up to significant water reduction over a long period.

This ECM includes the replacement of the existing restroom sinks with new low flow sinks rated at 0.5 gallons per minute and fitted with time based automatic shut off. The existing quantity of sink estimated is based off observed quantity in the field.

Equipment Basis of Design

- Moen Model 8886 (Chrome)

Energy Savings Calculations:

Energy savings calculations are based on NJ BPU Protocols to Measure Resource Savings. Hot water savings are based on a 50% mix of hot water to cold water. Savings for installation of automatic shut off based on a 10% reduction of use per day.

Faucets:

$$\text{Water Use (Gallons)} = \text{Fixture Qty} \times \frac{\text{Hours}}{\text{Day}} \times \frac{\text{Days}}{\text{Year}} \times \text{Flow Rate} \left(\frac{\text{Gal}}{\text{Min}} \right) \times 60 \frac{\text{Min}}{\text{hr}}$$

$$\begin{aligned} \text{Water Heating Usage (kWh)} \\ = \frac{\text{Gallons}}{\text{year}} \times 8.33 \frac{\text{Btu}}{\text{gal}} \times \Delta T (50^\circ\text{F}) \times \frac{1}{\text{Heater Eff (95\%)}} \times \frac{\text{kW}}{3412 \text{ Btu}} \end{aligned}$$

$$\begin{aligned} \text{Water Heating Usage (therm)} \\ = \frac{\text{Gallons}}{\text{year}} \times 8.33 \frac{\text{Btu}}{\text{gal}} \times \Delta T (50^\circ\text{F}) \times \frac{1}{\text{Heater Eff (80\%)}} \times \frac{\text{therm}}{100,000 \text{ Btu}} \end{aligned}$$

LOW FLOW WATER SAVING DEVICES			
ECM INPUTS	EXISTING	PROPOSED	SAVINGS
Quantity of Sinks	6	6	
Flow Rate (GPM)	2.2	0.5	1.7
Device Usage (min per day)	30	27	
Facility Operation (days / year)	250	250	
Heat Content of Water (Btu/gal/°F)	8.33	8.33	
Temperature Rise (°F)	50.0	50.0	
Water Heater Type	Electric	Electric	
Efficiency of Heating System (%)	95%	95%	
Conversion Factor for Electric	3,412	3,412	
Conversion Factor for Gas	100,000	100,000	
Electric Rate (\$/kWh)	\$0.129	\$0.129	
Natural Gas Rate (\$/therm)	\$0.970	\$0.970	
Water/Sewer Rate (\$/1000gal)	\$8.000	\$8.000	
ENERGY SAVINGS CALCULATIONS			
Electric Usage (kWh)	6,360	1,301	5,059
Natural Gas Usage (Therm)	0	0	0
Water Usage (gallons)	99,000	20,250	78,750
Energy Cost (\$)	\$1,612	\$330	\$1,283
COMMENTS:	Heating Savings based on 50% Hot Cold Mix. Assume a 10% reduction based on timed faucet controls		

Energy Savings Summary:

ECM #7 - ENERGY SAVINGS SUMMARY	
Installation Cost (\$):	\$6,480
NJ Smart Start Equipment Incentive (\$):	\$0
Net Installation Cost (\$):	\$6,480
Maintenance Savings (\$/Yr):	\$0
Energy Savings (\$/Yr):	\$1,283
Total Yearly Savings (\$/Yr):	\$1,283
Estimated ECM Lifetime (Yr):	15
Simple Payback	5.1
Simple Lifetime ROI	197.0%
Simple Lifetime Maintenance Savings	\$0
Simple Lifetime Savings	\$19,245
Internal Rate of Return (IRR)	18%
Net Present Value (NPV)	\$8,836.37

REM #1: 5.76 kW Solar System**Description:**

The East Hanover Board of Education Office has available roof space that could accommodate solar arrays. Based on the available area a 5.76 kilowatt solar array could be installed. The array will produce approximately 6,656 kilowatt-hours annually that will reduce the overall electric usage of the facility by 17.67%. The owner should consult a structural engineer prior to installing any solar array to insure the roof can accommodate the additional weight.

Energy Savings Calculations:

See **Renewable / Distributed Energy Measures Calculations Appendix** for detailed financial summary and proposed solar layout areas. Financial results in table below are based on 100% financing of the system over a fifteen year period.

Energy Savings Summary:

REM #1 - ENERGY SAVINGS SUMMARY	
System Size (KW_{DC}):	5.76
Electric Generation (KWH/Yr):	6,656
Installation Cost (\$):	\$28,895
SREC Revenue (\$/Yr):	\$1,272
Energy Savings (\$/Yr):	\$859
Total Yearly Savings (\$/Yr):	\$2,130
ECM Analysis Period (Yr):	15
Simple Payback (Yrs):	13.6
Analysis Period Electric Savings (\$):	\$15,969
Analysis Period SREC Revenue (\$):	\$18,424
Net Present Value (NPV)	(\$7,315.41)

V. ADDITIONAL RECOMMENDATIONS

The following recommendations include no cost/low cost measures, Operation & Maintenance (O&M) items, and water conservation measures with attractive paybacks. These measures are not eligible for the Smart Start Buildings incentives from the office of Clean Energy but save energy none the less.

- A. The School District should investigate improvement to the 1930 section of the BOE building including upgrading the windows and adding thermal insulation to the exterior walls.
- B. Chemically clean the condenser and evaporator coils periodically to optimize efficiency. Poorly maintained heat transfer surfaces can reduce efficiency 5-10%.
- C. Maintain all weather stripping on windows and doors.
- D. Clean all light fixtures to maximize light output.
- E. Provide more frequent air filter changes to decrease overall system power usage and maintain better IAQ.
- F. Turn off computers when not in use. Ensure computers are not running in screen saver mode.
- G. Replace any old CRT Monitors with LED/LCD Type Monitors, which can draw as much as a quarter the power of an equivalent CRT monitor.
- H. Ensure outside air dampers are functioning properly and only open during occupied mode.

APPENDIX A

ECM COST & SAVINGS BREAKDOWN

CONCORD ENGINEERING GROUP

East Hanover Township School District - Board Office

ECM ENERGY AND FINANCIAL COSTS AND SAVINGS SUMMARY

ECM NO.	DESCRIPTION	INSTALLATION COST				YEARLY SAVINGS			ECM LIFETIME	LIFETIME ENERGY SAVINGS	LIFETIME MAINTENANCE SAVINGS	LIFETIME ROI	SIMPLE PAYBACK	INTERNAL RATE OF RETURN (IRR)	NET PRESENT VALUE (NPV)
		MATERIAL	LABOR	REBATES, INCENTIVES	NET INSTALLATION COST	ENERGY	MAINT. / SREC	TOTAL		(Yearly Saving * ECM Lifetime)	(Yearly Maint Saving * ECM Lifetime)	(Lifetime Savings - Net Cost) / (Net Cost)	(Net cost / Yearly Savings)	$\sum_{n=0}^N \frac{C_n}{(1+IRR)^n}$	$\sum_{n=0}^N \frac{C_n}{(1+DR)^n}$
		(\$)	(\$)	(\$)	(\$)	(\$/Yr)	(\$/Yr)	(\$/Yr)		(\$)	(\$)	(%)	(Yr)	(\$)	(\$)
ECM #1	Lighting Upgrade - General	\$5,165	\$6,280	\$0	\$11,445	\$612	\$0	\$612	15	\$9,180	\$0	-19.8%	18.7	-2.64%	(\$4,138.98)
ECM #2	Lighting Controls Upgrade	\$1,250	\$350	\$125	\$1,475	\$101	\$0	\$101	15	\$1,515	\$0	2.7%	14.6	0.34%	(\$269.27)
ECM #3	Boiler OA Reset Controls	\$3,239	\$3,073	\$0	\$6,312	\$825	\$0	\$825	15	\$12,375	\$0	96.0%	7.7	9.90%	\$3,536.50
ECM #4	Boiler Replacement	\$18,342	\$25,004	\$700	\$42,646	\$1,189	\$0	\$1,189	25	\$29,725	\$0	-30.3%	35.9	-2.60%	(\$21,941.93)
ECM #5	Programmable Thermostats	\$960	\$1,288	\$0	\$2,248	\$414	\$0	\$414	15	\$6,210	\$0	176.2%	5.4	16.57%	\$2,694.31
ECM #6	Split System Replacement	\$4,000	\$5,000	\$276	\$8,724	\$236	\$0	\$236	15	\$3,540	\$0	-59.4%	37.0	-9.61%	(\$5,906.65)
ECM #7	Water Conservation	\$2,700	\$3,780	\$0	\$6,480	\$1,283	\$0	\$1,283	15	\$19,245	\$0	197.0%	5.1	18.18%	\$8,836.37
REM RENEWABLE ENERGY AND FINANCIAL COSTS AND SAVINGS SUMMARY															
REM #1	5.76 kW PV System	\$28,895	\$0	\$0	\$28,895	\$859	\$1,272	\$2,130	15	\$31,957	\$19,078	10.6%	13.6	1.29%	(\$3,461.17)

- Notes:**
- 1) The variable Cn in the formulas for Internal Rate of Return and Net Present Value stands for the cash flow during each period.
 - 2) The variable DR in the NPV equation stands for Discount Rate
 - 3) For NPV and IRR calculations: From n=0 to N periods where N is the *lifetime of ECM* and Cn is the *cash flow during each period*.

APPENDIX B

Concord Engineering Group, Inc.

520 BURNT MILL ROAD
VOORHEES, NEW JERSEY 08043
PHONE: (856) 427-0200
FAX: (856) 427-6508



SmartStart Building Incentives

The NJ SmartStart Buildings Program offers financial incentives on a wide variety of building system equipment. The incentives were developed to help offset the initial cost of energy-efficient equipment. The following tables show the current available incentives from July 1, 2013 to June 30, 2014:

Electric Chillers

Water-Cooled Chillers	\$16 - \$170 per ton
Air-Cooled Chillers	\$8 - \$52 per ton

Energy Efficiency must comply with ASHRAE 90.1-2007

Gas Cooling

Gas Absorption Chillers	\$185 - \$450 per ton
Gas Engine-Driven Chillers	Calculated through custom measure path)

Desiccant Systems

\$1.00 per cfm – gas or electric

Electric Unitary HVAC

Unitary AC and Split Systems	\$73 - \$92 per ton
Air-to-Air Heat Pumps	\$73 - \$92 per ton
Water-Source Heat Pumps	\$81 per ton
Packaged Terminal AC & HP	\$65 per ton
Central DX AC Systems	\$40- \$72 per ton
Dual Enthalpy Economizer Controls	\$250
Occupancy Controlled Thermostat (Hospitality & Institutional Facility)	\$75 per thermostat
A/C Economizing Controls	≤ 5 tons \$85/unit; >5 tons \$170/unit

Energy Efficiency must comply with ASHRAE 90.1-2007

Gas Heating

Gas Fired Boilers < 300 MBH	\$2.00 per MBH, but not less than \$300 per unit
Gas Fired Boilers ≥ 300 - 1500 MBH	\$1.75 per MBH
Gas Fired Boilers ≥1500 - ≤ 4000 MBH	\$1.00 per MBH
Gas Fired Boilers > 4000 MBH	(Calculated through Custom Measure Path)
Gas Furnaces	\$400 per unit, AFUE ≥ 95%
Boiler Economizing Controls	\$1,200 - \$2,700
Low Intensity Infrared Heating	\$300 - \$500 per unit

Ground Source Heat Pumps

Closed Loop	\$450 per ton, EER \geq 16 \$600 per ton, EER \geq 18 \$750 per ton, EER \geq 20
-------------	--

Energy Efficiency must comply with ASHRAE 90.1-2007

Variable Frequency Drives

Variable Air Volume	\$65 - \$155 per hp
Chilled-Water Pumps \geq 20 hp	\$60 per VFD rated hp
Rotary Screw Air Compressors \geq 25 hp	\$5,250 to \$12,500 per drive
Cooling Towers \geq 10 hp	\$60 per VFD rated hp
Boiler Fans \geq 5 HP	\$65 to \$155 per hp
Boiler Feed Water Pumps \geq 5 HP	\$60 to \$155 per hp
Commercial Kitchen Hood up to 50 HP	Retrofit \$55 – \$300 per hp New Hood \$55 - \$250 per hp

Natural Gas Water Heating

Gas Water Heaters \leq 50 gallons, 0.67 energy factor or better	\$50 per unit
Gas-Fired Water Heaters $>$ 50 gallons	\$1.00 - \$2.00 per MBH
Gas-Fired Booster Water Heaters	\$17 - \$35 per MBH
Gas Fired Tankless Water Heaters	\$300 per unit

Prescriptive Lighting

T-8 reduced Wattage (28w/25w 4', 1-4 lamps) Lamp & ballast replacement	\$10 per fixture
For retrofit of T-8 fixtures by permanent de-lamping & new reflectors (Electronic ballast replacement required)	\$15 per fixture
T-5 and T-8 High Bay Fixtures	\$16 - \$200 per fixture
Metal Halide w/Pulse Start Including Parking Lot (For fixtures \geq 150w)	\$25 per fixture
HID \geq 100w Replace with new induction fixture. (must be 30% less watts/fixture than HID system)	\$70 per fixture
HID \geq 100w Retrofit with induction lamp, power coupler and generator (must be 30% less watts/fixture than HID system)	\$50 per fixture

Prescriptive Lighting - LED

LED Display Case Lighting	\$30 per display case
LED Shelf-Mtd. Display & Task Lights	\$15 per linear foot
LED Portable Desk Lamp	\$20 per fixture
LED Wall-wash Lights	\$30 per fixture
LED Recessed Down Lights	\$35 per fixture
LED Outdoor Pole/Arm-Mounted Area and Roadway Luminaries	\$175 per fixture
LED Outdoor Pole/Arm-Mounted Decorative Luminaries	\$175 per fixture
LED Outdoor Wall-Mounted Area Luminaries	\$100 per fixture
LED Parking Garage Luminaries	\$100 per fixture
LED Track or Mono-Point Directional Lighting Fixtures	\$50 per fixture
LED High-Bay and Low-Bay Fixtures for Commercial & Industrial Bldgs.	\$150 per fixture
LED High-Bay-Aisle Lighting	\$150 per fixture
LED Stairwell and Passageway Luminaires	\$40 per fixture
LED Bollard Fixtures	\$50 per fixture
Luminaires for Ambient Lighting of Interior Commercial Spaces (1x4, 2x2, 2x4)	\$50 per fixture
LED Fuel Pump Canopy	\$100 per fixture
LED Screw-based & Pin-based (PAR, MR, BR, R) Standards (A-Style) and Decorative Lamps	\$10 per lamp for R/PAR20,MR/PAR16,Globe,Candelabra or Misc \$20 per lamp for R/BR/PAR 30, R/BR/PAR 38-40, A-Lamp
LED Refrigerator/Freezer case lighting replacement of fluorescent in medium and low temperature display case	\$30 per 4 foot \$42 per 5 foot \$65 per 6 foot
LED Retrofit Kits	To be evaluated through the customer measure path

Lighting Controls – Occupancy Sensors

Wall Mounted (Existing Facilities Only)	\$20 per control
Remote Mounted (Existing Facilities Only)	\$35 per control
Daylight Dimming Controls	\$45 per fixture controlled
Occupancy Based hi-low Dimming Control	\$35 per fixture controlled
Occupancy Sensor Remote Mounted	\$35 per control

Refrigeration Doors/Covers

Energy-Efficient Doors/Covers for Installation on Open Refrigerated Cases	\$100 per door
Aluminum Night Curtains for Installation on Open Refrigerated Cases	\$3.50 per linear foot

Refrigeration Controls

Door Heater Controls	\$50 per control
Electric Defrost Controls	\$50 per control
Evaporator Fan Controls	\$75 per control
Novelty Cooler Shutoff	\$50 per control

Other Equipment Incentives

Performance Lighting	\$1.00 per watt per SF below program incentive threshold, currently 5% more energy efficient than ASHRAE 90.1- 2007 for New Construction and Complete Renovation
Custom Electric and Gas Equipment Incentives	not prescriptive
Custom Measures	\$0.16 KWh and \$1.60/Therm of 1st year savings, or a buy down to a 1 year payback on estimated savings. Minimum required savings of 75,000 KWh or 1,500 Therms and an IRR of at least 10%.

APPENDIX C



ENERGY STAR[®] Statement of Energy Performance

46

ENERGY STAR[®]
Score¹

East Hanover Board Office

Primary Property Function: Office
Gross Floor Area (ft²): 7,083
Built: 1930

For Year Ending: November 30, 2013
Date Generated: April 16, 2014

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information

Property Address

East Hanover Board Office
20 School Avenue
East Hanover, New Jersey 07936

Property Owner

East Hanover Township School District
20 School Avenue
East Hanover, NJ 07936
(____)____-____

Primary Contact

Deborah Muscara
20 School Avenue
East Hanover, NJ 07936
973-887-2112
dmuscara@easthanoverschools.org

Property ID: 4037207

Energy Consumption and Energy Use Intensity (EUI)

Site EUI

110.5 kBtu/ft²

Annual Energy by Fuel

Natural Gas (kBtu)	654,357 (84%)
Electric - Grid (kBtu)	128,544 (16%)

National Median Comparison

National Median Site EUI (kBtu/ft ²)	105.9
National Median Source EUI (kBtu/ft ²)	147.6
% Diff from National Median Source EUI	4%

Source EUI

154 kBtu/ft²

Annual Emissions

Greenhouse Gas Emissions (MtCO ₂ e/year)	51
---	----

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: _____ Date: _____

Licensed Professional

Michael Fischette
520 South Burnt Mill Road
Voorhees, NJ 0843
856-427-0200
mfischette@concord-engineering.com



Professional Engineer Stamp
(if applicable)

APPENDIX D

MAJOR EQUIPMENT LIST

Concord Engineering Group

BOE OFFICE

Rooftop Units

Tag	RTU-1	RTU-2	RTU-3	RTU-4
Unit Type	Packaged	Packaged	Packaged	Gas/Electric Packaged
Qty	1	1	1	1
Location	Roof	Roof	Roof	Roof
Area Served	Superintendent's Offices	Secretaries Offices	Conference Room	Special Services Offices
Manufacturer	York	York	WeatherKing	Luxaire
Model #	DCHB-T036AB	D4CE036A06ECA	13AJA60A01	ZS-03N11AFAAA1A
Serial #	NKEM066399	NFMM066556	7282N390602796	N1A2532734
Cooling Type	DX Coil	DX Coil	DX Coil	DX Coil
Cooling Capacity (Tons)	3	3	5	3
Cooling Efficiency (SEER/EER)	SEER=8.5	SEER=12.1	SEER=13.0	SEER=13.0
Heating Type	N/A	N/A	N/A	Heat Exchanger
Heating Input (MBH)	N/A	N/A	N/A	100
Efficiency	N/A	N/A	N/A	81% AFUE
Fuel	N/A	N/A	N/A	Natural Gas
Approx Age	18	10	7	2
ASHRAE Service Life	15	15	15	15
Remaining Life	(3)	5	8	13
Comments	Very Poor Condition			

Note:

"N/A" = Not Applicable.

"-" = Info Not Available

MAJOR EQUIPMENT LIST

Concord Engineering Group

BOE OFFICE

Domestic Water Heaters

Tag	DHW-1	DHW-2 thru 4	
Unit Type	Electric Water Heater	Electric Water Heater	
Qty	1	2	
Location	Custodian Closet	Mechanical Room	
Area Served	Sink and Rest Room	Various Rest Rooms	
Manufacturer	Vanguard	Rheem	
Model #	6E731	81VP68	
Serial #	VG 0599310693	RH 0304217828	
Size (Gallons)	15	6	
Input Capacity (MBH/KW)	2000 Watts	2000 Watts	
Recovery (Gal/Hr)	N/A	N/A	
Efficiency %	95%	95%	
Fuel	Electric	Electric	
Approx Age	15	10	
ASHRAE Service Life	15	15	
Remaining Life	0	5	
Comments			

Note:

"N/A" = Not Applicable.

"-" = Info Not Available

MAJOR EQUIPMENT LIST

Concord Engineering Group

BOE OFFICE

Boilers

Tag	B-1	
Unit Type	Cast Iron Sectional	
Qty	1	
Location	Boiler Room	
Area Served	Entire Facility	
Manufacturer	Weil-McLain	
Model #	HG-9	
Serial #	N/A	
Rated Input Capacity (Btu/Hr)	445,200 BTUH	
Rated Output Capacity (Btu/Hr)	356,000 BTUH (New)	
Approx. Efficiency %	70% (Present Age, Condition)	
Fuel	Natural Gas	
Approx Age	43	
ASHRAE Service Life	35	
Remaining Life	(8)	
Comments	Electronic Barber Coleman controls are outdated	

Note:

"N/A" = Not Applicable.

"-" = Info Not Available

MAJOR EQUIPMENT LIST

Concord Engineering Group

BOE OFFICE

Pumps

Tag	P-1 & P-2	P-3 & P-4
Unit Type	In-Line Pump	In-Line Pump
Qty	2	2
Location	Boiler Room	Boiler Room
Area Served	1971 Addition	Original building
Manufacturer	Bell & Gossett	Bell & Gossett
Model #	"_"	"_"
Serial #	"_"	"_"
Horse Power	3/4	1/2
Flow	"_"	"_"
Motor Info	Marathon	Bell & Gossett
Electrical Power	208-230/460 Three Phase	208-230/460 Three Phase
RPM	1725	1750
Motor Efficiency %	N/A	N/A
Approx Age	10	10
ASHRAE Service Life	20	20
Remaining Life	10	10
Comments		

Note:

"N/A" = Not Applicable.

"_" = Info Not Available

APPENDIX E


CEG Project #: 1C13496
 Facility Name: Board Office
 Address: 20 School Avenue
 City, State, Zip: East Hanover, NJ 07936

Fixture Reference #	Location	Average Burn Hours	EXISTING FIXTURES						PROPOSED FIXTURE RETROFIT						RETROFIT ENERGY SAVINGS				PROPOSED LIGHTING CONTROLS					
			Description	Lamps per Fixture	Watts per Fixture	Qty of Fixtures	Total kW	Usage kWh/Yr	Work Description	Equipment Description	Lamps per Fixture	Watts per Fixture	Qty of Fixtures	Total kW	Usage kWh/Yr	Energy Savings, kW	Energy Savings, kWh	Energy Savings, \$	Control Ref #	Controls Description	Qty of Controls	Hour Reduction %	Energy Savings, kWh	Energy Savings, \$
100	Main Hallway & Entrance Vestibule	3120	2x2, 2 Lamp, 17w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	2	33	11	0.36	1,133	Bypass Ballast, Relamp	2' LED 11w; Retrofit	2	22	11	0.24	755	0.12	378	\$49	0	No New Controls	0	0.0%	0	\$0
2.21	Secretaries	3120	2x4 2 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	2	58	14	0.81	2,533	Bypass Ballast, Relamp	4' 18w LED Tube	2	36	14	0.50	1,572	0.31	961	\$124	0	No New Controls	0	0.0%	0	\$0
2.21	Business Admin Office	3120	2x4 2 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	2	58	3	0.17	543	Bypass Ballast, Relamp	4' 18w LED Tube	2	36	3	0.11	337	0.07	206	\$27	5	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	67	\$9
101	Business Admin Restroom	400	2x2, 1 Lamp, 17w T8, Elect. Ballast, Surface Mnt., Prismatic Lens	1	18	2	0.04	14	Bypass Ballast, Relamp	2' LED 11w; Retrofit	1	11	2	0.02	9	0.01	6	\$1	0	No New Controls	0	0.0%	0	\$0
4.21	Lunch Room	3120	2x4 4 Lamp, 32w T8, Elect. Ballast, Recessed, Prismatic	4	109	2	0.22	680	Bypass Ballast, Relamp	4' 18w LED Tube	4	72	2	0.14	449	0.07	231	\$30	5	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	90	\$12
10	Boiler Room	400	1x4 1 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	1	28	2	0.06	22	Bypass Ballast, Relamp	4' 18w LED Tube	1	18	2	0.04	14	0.02	8	\$1	0	No New Controls	0	0.0%	0	\$0
2.21	Special Services	3120	2x4 2 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	2	58	3	0.17	543	Bypass Ballast, Relamp	4' 18w LED Tube	2	36	3	0.11	337	0.07	206	\$27	5	Dual Technology Occupancy Sensor - Remote Mnt.	0.5	20.0%	67	\$9
100		3120	2x2, 2 Lamp, 17w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	2	33	5	0.17	515	Bypass Ballast, Relamp	2' LED 11w; Retrofit	2	22	5	0.11	343	0.06	172	\$22	5	Dual Technology Occupancy Sensor - Remote Mnt.	0.5	20.0%	69	\$9
1.11	Record Storage	200	1x4 2 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic	2	58	1	0.06	12	Bypass Ballast, Relamp	4' 18w LED Tube	2	36	1	0.04	7	0.02	4	\$1	0	No New Controls	0	0.0%	0	\$0
2.21	Conference Room	1200	2x4 2 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	2	58	8	0.46	557	Bypass Ballast, Relamp	4' 18w LED Tube	2	36	8	0.29	346	0.18	211	\$27	5	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	69	\$9
102	Exit Signs	8760	(2) 7w CFL Exit Sign	2	16	3	0.05	420	Replace Fixture	LED Exit Sign	1	2	3	0.01	53	0.04	368	\$47	0	No New Controls	0	0.0%	0	\$0
2.21	Board Secretary	1200	2x4 2 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	2	58	2	0.12	139	Bypass Ballast, Relamp	4' 18w LED Tube	2	36	2	0.07	86	0.04	53	\$7	5	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	17	\$2
103	Work Room	3120	2x4 4 Lamp, 32w T8, Elect. Ballast, Surface Mnt., Prismatic Lens	4	109	1	0.11	340	Bypass Ballast, Relamp	4' 18w LED Tube	4	72	1	0.07	225	0.04	115	\$15	6	Dual Technology Occupancy Sensor - Switch Mnt.	1	20.0%	45	\$6
101	Custodial Closet	400	2x2, 1 Lamp, 17w T8, Elect. Ballast, Surface Mnt., Prismatic Lens	1	18	1	0.02	7	Bypass Ballast, Relamp	2' LED 11w; Retrofit	1	11	1	0.01	4	0.01	3	\$0	0	No New Controls	0	0.0%	0	\$0
104	Mens Restroom	3120	1x4 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., Prismatic	2	58	2	0.12	362	Bypass Ballast, Relamp	4' 18w LED Tube	2	36	2	0.07	225	0.04	137	\$18	0	No New Controls	0	0.0%	0	\$0
104	Womens Restroom	3120	1x4 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., Prismatic	2	58	2	0.12	362	Bypass Ballast, Relamp	4' 18w LED Tube	2	36	2	0.07	225	0.04	137	\$18	0	No New Controls	0	0.0%	0	\$0
105	Maintenance Shops	1200	1x4 2 Lamp, 32w T8, Elect. Ballast, Industrial, No Lens	2	58	10	0.58	696	Bypass Ballast, Relamp	4' 18w LED Tube	2	36	10	0.36	432	0.22	264	\$34	0	No New Controls	0	0.0%	0	\$0
106		1200	1x4 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	2	58	4	0.23	278	Bypass Ballast, Relamp	4' 18w LED Tube	2	36	4	0.14	173	0.09	106	\$14	0	No New Controls	0	0.0%	0	\$0
6.11		1200	6"x4 1 Lamp, 32w T8, Elect. Ballast, Surface Mnt., Prismatic	1	28	3	0.08	101	Bypass Ballast, Relamp	4' 18w LED Tube	1	18	3	0.05	65	0.03	36	\$5	0	No New Controls	0	0.0%	0	\$0
2.21	Superintendent's Office	3120	2x4 2 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	2	58	16	0.93	2,895	Bypass Ballast, Relamp	4' 18w LED Tube	2	36	16	0.58	1,797	0.35	1,098	\$142	5	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	359	\$46

Fixture Reference #	Location	Average Burn Hours	EXISTING FIXTURES						PROPOSED FIXTURE RETROFIT							RETROFIT ENERGY SAVINGS			PROPOSED LIGHTING CONTROLS					
			Description	Lamps per Fixture	Watts per Fixture	Qty of Fixtures	Total kW	Usage kWh/Yr	Work Description	Equipment Description	Lamps per Fixture	Watts per Fixture	Qty of Fixtures	Total kW	Usage kWh/Yr	Energy Savings, kW	Energy Savings, kWh	Energy Savings, \$	Control Ref #	Controls Description	Qty of Controls	Hour Reduction %	Energy Savings, kWh	Energy Savings, \$
2.21	Restroom	400	2x4 2 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	2	58	1	0.06	23	Bypass Ballast, Relamp	4' 18w LED Tube	2	36	1	0.04	14	0.02	9	\$1	0	No New Controls	0	0.0%	0	\$0
100	Top of Stairway	3120	2x2, 2 Lamp, 17w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	2	33	1	0.03	103	Bypass Ballast, Relamp	2' LED 11w; Retrofit	2	22	1	0.02	69	0.01	34	\$4	0	No New Controls	0	0.0%	0	\$0
TOTAL						97	5	12,279					97	3	7,537	1.86	4,742	\$612			7	2	784	\$101

APPENDIX F

Location Description	Area (Sq FT)	Panel	Qty	Panel Sq Ft	Panel Total Sq Ft	Total KW _{DC}	Total Annual kWh	Total KW _{AC}	Panel Weight (41.9 lbs)	W/SQFT
Board Office	600	SHARP ND-240QCJ	24	17.5	421	5.76	6,656	4.7	1,006	13.68



= Proposed PV Roof Layout

Notes:

1. Estimated kWh based on the National Renewable Energy Laboratory PVWatts Version 1 Calculator Program.

Project Name: LGEA Solar PV Project - Board Office									
Location:									
Description: Photovoltaic System 100% Financing - 15 year									
Simple Payback Analysis									
		Photovoltaic System 100% Financing - 15 year							
Total Construction Cost		\$28,895							
Annual kWh Production		6,656							
Annual Energy Cost Reduction		\$859							
Average Annual SREC Revenue		\$1,272							
Simple Payback:		13.56						Years	
Life Cycle Cost Analysis									
Analysis Period (years):		15				Financing %:		100%	
Discount Rate:		3%				Maintenance Escalation Rate:		3.0%	
Average Energy Cost (\$/kWh)		\$0.129				Energy Cost Escalation Rate:		3.0%	
Financing Rate:		6.00%				Average SREC Value (\$/kWh)		\$0.191	
Period	Additional Cash Outlay	Energy kWh Production	Energy Cost Savings	Additional Maint Costs	SREC Revenue	Interest Expense	Loan Principal	Net Cash Flow	Cumulative Cash Flow
0	\$0	0	0	0	\$0	0	0	0	0
1	\$0	6,656	\$859	\$0	\$1,664	\$1,700	\$1,226	(\$403)	(\$403)
2	\$0	6,623	\$884	\$0	\$1,656	\$1,625	\$1,301	(\$386)	(\$789)
3	\$0	6,590	\$911	\$0	\$1,647	\$1,544	\$1,381	(\$368)	(\$1,157)
4	\$0	6,557	\$938	\$0	\$1,639	\$1,459	\$1,467	(\$349)	(\$1,505)
5	\$0	6,524	\$966	\$67	\$1,631	\$1,369	\$1,557	(\$396)	(\$1,901)
6	\$0	6,491	\$995	\$67	\$1,298	\$1,273	\$1,653	(\$699)	(\$2,600)
7	\$0	6,459	\$1,025	\$67	\$1,292	\$1,171	\$1,755	(\$675)	(\$3,276)
8	\$0	6,427	\$1,056	\$66	\$1,285	\$1,063	\$1,863	(\$651)	(\$3,927)
9	\$0	6,394	\$1,088	\$66	\$1,279	\$948	\$1,978	(\$625)	(\$4,552)
10	\$0	6,362	\$1,120	\$66	\$954	\$826	\$2,100	(\$917)	(\$5,469)
11	\$0	6,331	\$1,154	\$65	\$950	\$696	\$2,230	(\$888)	(\$6,357)
12	\$0	6,299	\$1,189	\$65	\$945	\$559	\$2,367	(\$857)	(\$7,214)
13	\$0	6,267	\$1,224	\$65	\$940	\$413	\$2,513	(\$826)	(\$8,040)
14	\$0	6,236	\$1,261	\$64	\$624	\$258	\$2,668	(\$1,106)	(\$9,146)
15	\$0	6,205	\$1,299	\$64	\$620	\$93	\$2,833	(\$1,071)	(\$10,217)
Totals:		96,420	\$15,969	\$721	\$18,424	\$14,995	\$28,895	(\$10,217)	(\$66,553)
Net Present Value (NPV)							(\$7,315)		