

CITY OF EAST ORANGE

SOVEREL PARK

110 North Park Street, East Orange, NJ, 07017

**LOCAL GOVERNMENT ENERGY AUDIT PROGRAM
FOR
NEW JERSEY
BOARD OF PUBLIC UTILITIES**

May 2016

Prepared by:



6 Campus Drive
Parsippany, NJ 07054
(973) 538-2120

CHA PROJECT NO. 30993

TABLE OF CONTENTS

1.0 EXECUTIVE SUMMARY	1
2.0 BUILDING INFORMATION AND EXISTING CONDITIONS	4
3.0 UTILITIES.....	7
4.0 BENCHMARKING.....	11
5.0 ENERGY CONSERVATION MEASURES.....	12
5.1 ECM-1 Window Replacement	13
5.2 ECM-2 Replace the Boiler with a Condensing Boiler	13
5.3 ECM-3 Replace the Old AHU Furnace with High Efficiency Furnace	14
5.4 ECM-4 Upgrade the Plumbing Fixtures with Low Flow Fixtures.....	14
5.5 ECM-L1 Lighting Replacements with Controls (Occupancy Sensors).....	15
5.6 Additional O&M Opportunities.....	16
6.0 PROJECT INCENTIVES	17
6.1 Incentives Overview.....	17
6.1.1 New Jersey Smart Start Program.....	17
6.1.2 Direct Install Program	17
6.1.3 New Jersey Pay For Performance Program (P4P).....	18
6.1.4 Energy Savings Improvement Plan	19
6.1.5 Renewable Energy Incentive Program.....	20
7.0 ALTERNATIVE ENERGY SCREENING EVALUATION	21
7.1 Solar	21
7.1.1 Photovoltaic Rooftop Solar Power Generation	21
7.1.2 Solar Thermal Hot Water Generation.....	21
7.2 Wind Powered Turbines	21
7.3 Combined Heat and Power Plant.....	22
7.4 Demand Response Curtailment	23
8.0 CONCLUSIONS & RECOMMENDATIONS.....	24

APPENDICES

- A Utility Usage Analysis and List of Third Party Energy Suppliers
- B Equipment Inventory
- C ECM Calculations and Cost Estimates
- D Photovoltaic (PV) Solar Power Generation Analysis
- E Photos
- F EPA Benchmarking Report

REPORT DISCLAIMER

This audit was conducted in accordance with the standards developed by the American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) for a Level II audit. Cost and savings calculations for a given measure were estimated to within $\pm 20\%$, and are based on data obtained from the owner, data obtained during site observations, professional experience, historical data, and standard engineering practice. Cost data does not include soft costs such as engineering fees, legal fees, project management fees, financing, etc.

A thorough walkthrough of the building was performed, which included gathering nameplate information and operating parameters for all accessible equipment and lighting systems. Unless otherwise stated, model, efficiency, and capacity information included in this report were collected directly from equipment nameplates and /or from documentation provided by the owner during the site visit. Typical operation and scheduling information was obtained from interviewing staff and spot measurements taken in the field.

List of Common Energy Audit Abbreviations

- A/C – Air Conditioning
- AHS – Air Handling Unit
- BMS – Building Management System
- Btu – British thermal unit
- CDW – Condenser Water
- CFM – Cubic feet per minute
- CHW – Chilled Water
- DCV – Demand Control Ventilation
- DDC – Direct Digital Control
- DHW – Domestic Hot Water
- DX – Direct Expansion
- EER – Energy Efficiency Ratio
- EF – Exhaust Fan
- EUI – Energy Use Intensity
- Gal – Gallon
- GPD – Gallons per day
- GPF – Gallons Per Flush
- GPH – Gallons per hour
- GPM – Gallons per minute
- GPS – Gallons per second
- HHW – Heating Hot Water
- HID – High Intensity Discharge
- HP – Horsepower
- HRU – Heat Recovery Unit
- HVAC – Heating, Ventilation, Air Conditioning
- HX – Heat Exchanger
- kbtu/mbtu – One thousand (1,000) Btu
- kW – Kilowatt (1,000 watts)
- kWh – Kilowatt-hours
- LED – Light Emitting Diode
- mbh – Thousand Btu per hour
- mmbtu – One million (1,000,000) Btu
- OCC – Occupancy Sensor
- PSI – Pounds per square inch
- RTU – Rooftop Unit
- SBC – System Benefits Charge
- SF – Square foot
- UH – Unit Heater
- V – Volts
- VAV – Variable Air Volume
- VSD – Variable Speed Drive
- W – Watt

1.0 EXECUTIVE SUMMARY

This report summarizes the energy audit performed by CHA for City of East Orange in connection with the New Jersey Board of Public Utilities (NJBPU) Local Government Energy Audit (LGEA) Program. The purpose of this report is to identify energy savings opportunities associated with major energy consumers and inefficient practices. Low-cost and no-cost energy conservation measures (ECMs) have also been identified in this study. This report details the results of the energy audit conducted for the building listed below:

Building Name	Address	Square Feet	Construction Date
Soverel Park	110 North Park Street, East Orange, NJ, 07017	5,334	1960

The potential total annual energy and cost savings for the recommended energy conservation measures (ECM) identified in the survey are shown below:

City Hall	Electric Savings (kWh)	Fuel Oil#2 (gallons)	Total Savings (\$)	Payback (years)
Soverel Park	62,433	61	22,704	2.5

Each individual measure's annual savings are dependent on that measure alone, there are no interactive effects calculated. There are three options shown for lighting ECM savings; only one option can be chosen. The incentives shown (if any) are based only on the SmartStart Incentive Program. Other NJBPU or local utility incentives may also be available/applicable and are further discussed in Section 6.0.

Each measure recommended by CHA typically has a stand-alone simple payback period of 15 years or less. However, if the owner chooses to pursue an Energy Savings Improvement Plan (ESIP), high payback measures could be bundled with lower payback measures which ultimately can result in a payback which is favorable for an ESIP project to proceed. Occasionally, we will recommend an ECM that has a longer payback period. This decision is generally based on the need to replace the piece(s) of equipment due to its age, such as a boiler.

The following table provides a detailed summary of each ECM for the building surveyed, including costs, savings, SmartStart incentives and payback.

Summary of Energy Conservation Measures


ECM #	Energy Conservation Measure	Est. Costs (\$)	Est. Savings (\$/year)	Payback w/o Incentive	Potential Incentive (\$)*	Payback w/ Incentive	Recommended
ECM-1	Replace Single Pane Windows with Double Pane Windows	6,800	137	49.7	0	49.7	Y
ECM-2	Replace the Boiler with a High Efficiency Boiler	35,406	102	346.9	0	346.9	N
ECM-3	Replace the Oil Furnace with High Efficiency Furnace	30,257	84	362.3	0	362.3	N
ECM-4	Replace Old Plumbing Fixtures with Low Flow Plumbing Fixtures	21,987	52	419.9	0	419.9	N
ECM-L1	Lighting Replacements with Controls (Occupancy Sensors)	55,640	22,567	2.5	5,855	2.2	Y
Total**		150,089	22,942	6.5	5,855	6.3	
Total(Recommended)		62,440	22,704	2.8	5,855	2.5	

* Incentive shown is per the New Jersey SmartStart Program.

By implementing the recommended ECMs, a LIFETIME reduction of 26 metric tons of greenhouse gas (GHG) could be obtained.

If the City of East Orange implements the recommended ECMs, energy savings would be as follows:

	Existing Conditions	Post Recommended ECMs	Percent Savings
Costs (\$)	55,364	32,660	41%
Electricity (kWh)	107,340	44,907	58%
Oil (gallon)	5,000	4,939	1%
Site EUI (kbtu/SF/Yr)	162.4	121.3	



2.0 BUILDING INFORMATION AND EXISTING CONDITIONS

The following is a summary of the building information related to HVAC, plumbing, building envelope, lighting, kitchen equipment and domestic hot water systems as observed during CHA's site visit. See appendix B for detailed information on mechanical equipment, including capacities, model numbers and age. See appendix F for representative photos of some of the existing conditions observed while onsite.

Building Name: Soverel Park

Address: 110 North Park Street, East Orange, NJ, 07017

Gross Floor Area: 5,334

Number of Floors: One Floor for both Field House and Garage

Year Built: 1960



General

Description of Spaces: The Soverel Park has two buildings: the Field House is used as the gathering place which includes a large multipurpose room, boiler room and restrooms; the Garage houses a garage shop which includes the garage shop and a restroom.

Description of Occupancy: The facility has approximately 8 staff working during the office hours.

Number of Computers: The building has no computers.

Building Usage: The regular hours are typically 40 hours per week except holidays.

Construction Materials: Both of the buildings are built with concrete masonry units (CMU).

Roof: The Field House has a pitched roof covered with shingles. The garage has a flat roof which is constructed of steel truss and covered with a white membrane. The roofs are in good condition and therefore no ECMs associated with roof improvements were evaluated.

Windows: The windows are single pane windows and appear to be in poor condition. An ECM associated with window replacements is evaluated.

Exterior Doors: The Field House has a wooden door and the garage has two roll garage doors. In discussions with facility staff, these doors are still in good condition, however, the seals around the doors degrade with time. Therefore an O&M associated with exterior doors seals was included in the O&M section.

Heating Ventilation & Air Conditioning (HVAC) Systems

Heating: The field house is heated by a Weil-McLain boiler which has a rated energy input of 175MBH while operating on No.2 fuel oil. The facility does not have natural gas supply. The heating hot water is circulated by a 1/6HP Bell & Gossett pump to the baseboard heaters throughout the building and to a small unit ventilator in the multipurpose room. The garage is heated by a UTC oil fired furnace. This UTC furnace has a rated energy input of 140 MBH and energy output of 112MBH which results in a nameplate efficiency of 80%. This furnace appears to be old and in poor condition. ECMs related to replacing the boiler and the furnace are evaluated.

Cooling: Neither of the buildings are cooled.

Ventilation: The field house is ventilated by the unit ventilator in the multipurpose room. It is assumed that this unit ventilator brings in the minimum amount of fresh air needed and the fan is typically turned off when the building is unoccupied. The garage has no mechanical ventilation available. No ECMs associated with the ventilation systems are evaluated.

Exhaust: Both of the buildings have a fractional horsepower exhaust fans on the roof serving the restrooms. The exhaust fans appear to be in good condition and are controlled therefore no ECMs associated with exhaust system were evaluated.

Controls Systems

Currently, the heating units are controlled by manual thermostats on the wall. According to the facility staff, the temperature setting is typically set between 60°F and 65 °F. The temperature setting is relatively low. Therefore, no ECMs related to the control were evaluated.

Domestic Hot Water Systems

Each of the buildings has an electric Rheem DHW heater located in the restroom. The water heaters have a rated capacity of 2 kW each. A minimal amount of domestic hot water is used by the lavatory sinks, therefore, no ECMs associated with upgrading the electric water heaters are evaluated.

Kitchen Equipment

The building does not have a kitchen.

Plug Load

This garage has some shop tools which contribute to the plug load. As the plug load is a relatively small portion of the total electrical load, no ECMs are recommend, however we have included and O & M measure to replace the small appliances with Energy Star rated appliances when the old ones reach the end of their useful life span

Plumbing Systems

The plumbing fixtures are old and appear to be in poor condition. Therefore an ECM associated with upgrading the plumbing fixtures with low flow plumbing fixtures is recommended.

Lighting Systems

This building has 40W T-12 fluorescent lighting, incandescent lights and metal halide pole lights. There are about fifty (50) exterior metal halides pole lights. All of the interior lights are controlled by manual switches. An ECM is included for replacing all for the lighting with LED equivalents and adding occupancy sensors to the new lights.

3.0 UTILITIES

Electricity, fuel oil and water are delivered to this building. Utilities used by the building are delivered and supplied by the following utility companies:

	Electric	Fuel Oil
Deliverer	PSE&G	Finch Fuel
Supplier	PSE&G	Finch Fuel

For the 12-month period ending in October 2014, the utilities usages and costs for the building were as follows:


Electric		
Annual Usage	107,340	kWh/yr
Annual Cost	44,064	\$
Blended Rate	0.411	\$/kWh
Peak Demand	118.8	kW
Min. Demand	30.0	kW
Avg. Demand	89.0	kW
Fuel Oil#2		
Annual Usage	1,414	Gallons/yr
Annual Cost	2,934	\$
Rate	2.075	\$/Gallon
Energy Summary		
Building Area	5,334	SF
Energy Usage Intensity (EUI)	69	KBtu/SF/yr
Energy Cost Index (ECI)	8.81	\$/SF/yr
Total Annual Utility Costs	46,998	\$

Blended Rate: Average rate charged determined by the annual cost / annual usage


Supply Rate: Actual rate charged for electricity usage in kWh (based on most recent electric bill)

Demand Rate: Rate charged for actual electrical demand in kW (based on most recent electric bill)

*Some months that do not have utility data and the missing demand usage are estimated and highlighted in the utility spreadsheet



The electric usage is pretty consistent throughout the year except June and July. It is possible that the facility was not used as often during those two months.



The fuel oil usage in this building is used for heating only and is correlated to the heating load of the building. Fuel oil is not metered, therefore no monthly consumption data is available.

See Appendix A for utility analysis.

Under New Jersey's energy deregulation law, the supply portion of the electric (or natural gas) bill is separated from the delivery portion. The supply portion is open to competition, and customers can shop around for the best price for their energy suppliers. The electric and natural gas distribution utilities will still deliver the gas/electric supplies through their wires and pipes and respond to emergencies, should they arise regardless of where those supplies are purchased. Purchasing the energy supplies from a company other than your electric or gas utility is purely an economic decision; it has no impact on the reliability or safety of the service.

Comparison of Utility Rates to NJ State Average Rates*				Recommended to Shop for Third Party Supplier?
Utility	Units	Average Rate	NJ Average Rate	
Electricity	\$/kWh	\$0.410	\$0.13	N
Natural Gas	\$/Therm	N/A	\$0.96	N/A

* Per U.S. Energy Information Administration (2013 data – Electricity and Natural Gas, 2012 data – Fuel Oil)



Additional information on selecting a third party energy supplier is available here:

<http://www.state.nj.us/bpu/commercial/shopping.html>.

See Appendix A for a list of third-party energy suppliers licensed by the Board of Public Utilities to sell within the building's service area.

The charts below represent estimated utility end-use utility profiles for the building. The values used within the charts were estimated from a review of the utility analysis and the energy savings calculations.

Site End-Use Utility Profile



4.0 BENCHMARKING

The EPA Portfolio Manager benchmarking tool provides a site and source Energy Use Intensity (EUI), as well as, an Energy Star performance rating for qualifying building types. The EUIs are provided in kBtu/ft²/year, and the performance rating represents how energy efficient a building is on a scale of 1 to 100; with 100 being the most efficient. In order for a building to receive an Energy Star label, the energy benchmark rating must be at least 75. As energy use decreases from implementation of the proposed measures, the Energy Star rating will increase. However, the EPA does not have scores for all buildings types. The buildings that do not have energy ratings now are compared with national median EUI.

The sites EUI is the amount of heat and electricity consumed by a building as reflected in its utility bills. Site energy may be delivered to a facility in the form of primary energy, which is raw fuel burned to create heat or electricity; such as natural gas or oil; or as secondary energy, which is the product created from a raw fuel such as electricity or district steam. To provide an equitable comparison for different buildings with varying proportions of primary and secondary energy consumption, Portfolio Manager uses the convention of source EUIs. The source energy also accounts for losses incurred in production, storage, transmission, and delivery of energy to the site; which provides an equivalent measure for various types of buildings with differing energy sources. The results of the benchmarking is contained in the table below. Copies of the benchmarking report are available in Appendix F.

Site EUI kBtu/ft ² /yr	Source EUI (kBtu/ft ² /yr)	Energy Star Rating (1-100)
105.3	252.6	N/A

The national median site EUI is 35.5kBtu/ft²/yr and source EUI is 85.1 kBtu/ft²/yr. The building has 197% higher than the national median source EUI. It is believed that the daily usage of the fifty outdoor pole lights contribute to the higher EUI. It is expected that the EUI will be reduced by implementing the measures discussed in this report.

████████████████████
████████████████████

5.0 ENERGY CONSERVATION MEASURES

The following types of energy savings opportunities are identified in this section of the report:

- Energy conservation measures (ECMs) are energy savings recommendations that typically require a financial investment. For these areas of opportunity, CHA prepared detailed calculations, as summarized in this section and in Appendix C. In general, additional savings may exist from reductions in maintenance activities associated with new equipment or better controls; however, for conservatism, maintenance savings are not accounted for in this report; instead the only savings which are reported are those derived directly from reductions in energy which can be tracked by the utility bills.
- Operational and Maintenance measures (O&M) consist of low-cost or no-cost operational opportunities, which if implemented would have positive impacts on overall building operation, comfort levels, and/or energy usage. There are no estimated savings, costs or paybacks associated with the O&M measures included as part of this study.

Energy savings were quantified in the form of:

- Electrical usage (kWh=Kilowatt-hour),
- Electrical demand (kW=kilowatts),
- Natural gas (therms=100,000 Btu),
- Propane gas (gallons=91,650 Btu),
- Fuel oil (gallons =138,700 Btu), and
- Water (kgal=1,000 gallons).

These recommendations are influenced by the time period that it takes for a proposed project to “break even” referred to as “Simple Payback”. Simple payback is calculated by dividing the estimated cost of implementing the ECM by the energy cost savings (in dollars) of that ECM.

Another financial indicator of the performance of a particular ECM is the Return on Investment (ROI), which represents the benefit (annual savings over the life of a project) of an investment divided by the cost of the investment. The result is expressed as a percentage or ratio.

Two other financial analyses included in this report are Internal Rate of Return (IRR) and Net Present Value (NPV). Internal Rate of Return is the discount rate at which the present value of a project costs equals the present value of the project savings. Net Present Value is the difference between present value of an investment’s future net cash flows and the initial investment. If the NPV equals “0”, the project would equate to investing the same amount of dollars at the desired rate. NPV is sometimes referred to as Net Present Worth. These values are provided in the Summary Tab in Appendix C.

5.1 ECM-1 Window Replacement

This measure evaluates the energy savings for replacing the single pane windows in the office section of the field house building with double pane windows that have better seals and insulation value. Replacement of these windows will result in a reduction of the buildings' heating and cooling loads, therefore resulting in fuel oil savings.

Energy savings for this measure were calculated by estimating the reduction in the heat transfer loss and the infiltration rate through the windows. The U value of the windows will be reduced from 1.13 Btuh/SF/F to 0.50 Btuh/SF/F and the infiltration factor is reduced from 0.30 CFM/LF to 0.15CFM/LF after upgrading the windows to double glazed windows with better seals.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-1 Window Replacement

Budgetary Cost	Annual Utility Savings			ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Fuel Oil				
\$	kW	kWh	gallon	\$	\$	Years	Years
6,800	0	0	61	137	(1.0)	0	49.7

* Does not qualify for Incentive from the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities

This measure is recommended due condition and total payback period remaining below 15 year maximum.

5.2 ECM-2 Replace the Boiler with a High Efficiency Boiler

The field house is heated by a Weil-McLain boiler which has a rated energy input of 175MBH. The facility does not have natural gas supply. Therefore, the boiler is fuel oil #2 fired. The boiler is old and the efficiency is believed to drop to be less than 80%. There are high efficiency boilers available that have better efficiencies, therefore, it is suggested one high efficiency boiler be added. New high efficiency oil boilers are available that operate at 85%. It is suggested that City of East Orange find out the natural gas supply gas pressure to this building and see if there are any condensing boilers viable to run at the natural gas supply pressure. New modulating condensing gas boilers are available that minimally operate at 88%, and can operate as high as 96%. This fuel change could save an additional \$327.89 per year.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-2 Replace the Boiler with a High Efficiency Boiler

Budgetary Cost	Annual Utility Savings			ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Fuel Oil				
\$	kW	kWh	gallon	\$	\$	Years	Years
35,406	0	0	45	102	(1.0)	0	346.9

* Incentive shown is per the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities.

This measure is not recommended.

5.3 ECM-3 Replace the Oil Furnace with High Efficiency Furnace

The garage is heated by an oil fired furnace. This UTC furnace has a rated energy input of 140 MBH and energy output of 112MBH which results in a nameplate efficiency of 80%. There are high efficiency furnaces available that have better efficiencies, therefore, it is suggested one high efficiency furnace be added. New high efficiency oil furnaces are available that operate at 85%. It is suggested that City of East Orange find out the natural gas supply gas pressure to this building and see if there are any condensing furnace viable to run at the natural gas supply pressure. New modulating condensing gas boilers are available that minimally operate at 88%, and can operate as high as 96%. This fuel change could save an additional \$232.27 per year.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-3 Replace the Oil Furnace with High Efficiency Furnace

Budgetary Cost	Annual Utility Savings			ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Fuel Oil				
\$	kW	kWh	gallon	\$	\$	Years	Years
30,257	0	0	37	84	(1.0)	362.3	362.3

* Incentive shown is per the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities.

This measure is not recommended.

5.4 ECM-4 Upgrade the Plumbing Fixtures with Low Flow Fixtures

This building contains older style high flow water toilets (3.5 GPF), urinals (1.5 GPF), and high flow faucets (2.0 GPM). Waterless urinals and low-flow toilets/faucets are recommended to replace the existing plumbing fixtures.

The water savings associated from replacing existing high flow fixtures with low-flow/no-flow fixtures was calculated by taking the difference of the annual water usage for the proposed and base case. The basis of this calculation is the estimate usage of each fixture, gallons per use, and number of fixtures. Replacing the existing fixtures in the restrooms with 1.28 Gals/flush toilets, waterless urinals, and 0.5 gpm faucets will conserve water which will result in lower annual water and sewer charges. Faucets with low-flow push valves were not considered for replacement.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-4 Upgrade the Plumbing Fixtures with Low Flow Fixtures

Budgetary Cost	Annual Utility Savings			ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Water	Natural Gas	Total				
\$	kGal	Therms	\$		\$	Years	Years
21,987	4	0	52	(1.0)	0	419.9	419.9

* Does not qualify for Incentive from the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities

This measure is not recommended due to long payback period, however should there be plans for replacing the plumbing fixtures in the future, low flow fixtures should be considered.

5.5 ECM-L1 Lighting Replacements with Controls (Occupancy Sensors)

This building has 40W T-12 fluorescent lighting, incandescent lights and metal halide pole lights. There are about fifty exterior metal halides pole lights. All of the interior lights are controlled by manual switches. The review of the comprehensive lighting survey determined that lighting in some areas could benefit from installation of occupancy sensors to turn off lights when they are unoccupied. This measure looks at replacing the lights with LED and installing occupancy sensors.

Overall energy consumption can be reduced by replacing inefficient bulbs and linear fluorescent bulbs with more efficient LED technology. To compute the annual savings for this ECM, the energy consumption of the current lighting fixtures was established and compared to the proposed fixture power requirement with the same annual hours of operation. The difference between the existing and proposed annual energy consumption was the energy savings. These calculations are based on 1 to 1 replacements of the fixtures, and do not take into account lumen output requirements for a given space. A more comprehensive engineering study should be performed to determine correct lighting levels.

Supporting calculations, including assumptions for lighting hours and annual energy usage for each fixture, are provided in Appendix C and summarized below:

ECM-L1 Lighting Replacements with Controls (Occupancy Sensors)

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
\$	kW	kWh	Therms	\$		\$	Years	Years
55,640	20	62,433	0	22,567	4.0	5,855	2.5	2.2

* LED new fixtures are still qualified for prescribed incentives, however, LED retrofits must go through the custom incentive which is not calculated in LGEA study therefore, the potential incentive shown in the table is the possible prescribed incentive.

This measure is recommended.

5.6 Additional O&M Opportunities

This list of operations and maintenance (O&M) type measures represent low-cost or no-cost opportunities; which if implemented will have a positive impact on the overall building operations, comfort, and/or energy consumption. The recommended O&M measures for this building are as follows:

- Purchase ENERGY STAR® appliances when needed
- Repair Door seals

6.0 PROJECT INCENTIVES

6.1 Incentives Overview

The following sections give detailed information on available incentive programs including New Jersey Smart Start, Direct Install, New Jersey Pay for Performance (P4P) and Energy Savings Improvement Plan (ESIP). If the facility wishes to and is eligible to participate in the Energy Savings Improvement Plan (ESIP) program and/or the Pay for Performance Incentive Program (P4P), it cannot participate in either the Smart Start or Direct Install Programs.

Web URL: <http://www.njcleanenergy.com/commercial-industrial/home/home/>

6.1.1 New Jersey Smart Start Program

For this energy audit, The New Jersey Smart Start Incentives are used in the energy savings calculations, where applicable. This program is intended for medium and large energy users and provides incentives for:

- Electric Chillers
- Gas Chillers
- Gas Heating
- Unitary HVAC
- Ground Source Heat Pumps
- Variable Frequency Drives/Motors
- Refrigeration
- Prescriptive and Performance Lighting and Lighting Controls

The equipment is procured using a typical bid-build method. It is then installed, paid for and then the incentives are reimbursed to the owner.

6.1.2 Direct Install Program

The Direct Install Program applies to smaller facilities that have a peak electrical demand of 200 kW or less in any of the previous 12 months. Buildings must be located in New Jersey and served by one of the state's public, regulated electric utility companies.

Direct Install was funded through New Jersey's Clean Energy Program and is designed to provide capital for building energy upgrade projects to fast track implementation. The program will pay up to 70% of the costs for lighting, HVAC, motors, refrigeration, and other equipment upgrades with higher efficiency alternatives. If a building is eligible for this funding, the Direct Install Program can reduce the implementation cost of energy conservation projects.

The Direct Install program has specific HVAC equipment and lighting requirements and is generally applicable only to smaller package HVAC units, small boilers and lighting retrofits.

The program pays a maximum amount of \$75,000 per building, and up to \$250,000 per customer per year. Installations must be completed by an approved Direct Install participating contractor, a list of which can be found on the New Jersey Clean Energy Website. Contractors will coordinate with the applicant to arrange installation of recommended measures identified in a previous energy assessment, such as this energy audit. The incentive is reimbursed to the owner upon successful replacement and payment of the equipment.

The building does qualify for this program.

6.1.3 New Jersey Pay For Performance Program (P4P)

This building may be eligible for incentives from the New Jersey Office of Clean Energy. The most significant incentives are available from the New Jersey Pay for Performance (P4P) Program. The P4P program is designed to offset the cost of energy conservation projects for facilities that pay the Societal Benefits Charge (SBC) and whose demand (kW) in any of the preceding 12 months exceeds 200 kW. Facilities that meet this criterion must also achieve a minimum performance target of 15% energy reduction by using the EPA Portfolio Manager benchmarking tool before and after implementation of the measure(s). Additionally, the overall return on investment (ROI) must exceed 10%. If the participant is a municipal electric company customer, and a customer of a regulated gas New Jersey Utility, only gas measures will be eligible under the Program. Available incentives are as follows:

Incentive #1: Energy Reduction Plan – This incentive is designed to offset the cost of services associated with the development of the Energy Reduction Plan (ERP). The ERP must include a detailed energy audit of the desired ECMs, energy savings calculations (using building modeling software) and inputting of all utility bills into the EPA Portfolio Manager website.

- Incentive Amount: \$0.10/SF
- Minimum incentive: \$5,000
- Maximum Incentive: \$50,000 or 50% of Facility annual energy cost

The standard incentive pays \$0.10 per square foot, up to a maximum of \$50,000, not to exceed 50% of facility annual energy cost, paid after approval of application. For building audits funded by the New Jersey Board of Public Utilities, which receive an initial 75% incentive toward performance of the energy audit, facilities are only eligible for an additional \$0.05 per square foot, up to a maximum of \$25,000, rather than the standard incentive noted above. The ERP must be completed by a Certified Energy Manager (CEM) and submitted along with the project application.

Incentive #2: Installation of Recommended Measures – This incentive is based on projected energy savings as determined in Incentive #1 (Minimum 15% savings must be achieved), and is paid upon successful installation of recommended measures.

Electric

- Base incentive based on 15% savings: \$0.09/ per projected kWh saved.
- For each % over 15% add: \$0.005 per projected kWh saved.

- Maximum incentive: \$0.11/ kWh per projected kWh saved.

Gas

- Base incentive based on 15% savings: \$0.90/ per projected Therm saved.
- For each % over 15% add: \$0.05 per projected Therm saved.
- Maximum incentive: \$1.25 per projected Therm saved.

Incentive cap: 25% of total project cost

Incentive #3: Post-Construction Benchmarking Report – This incentive is paid after acceptance of a report proving energy savings over one year utilizing the Environmental Protection Agency (EPA) Portfolio Manager benchmarking tool.

Electric

- Base incentive based on 15% savings: \$0.09/ per projected kWh saved.
- For each % over 15% add: \$0.005 per projected kWh saved.
- Maximum incentive: \$0.11/ kWh per projected kWh saved.

Gas

- Base incentive based on 15% savings: \$0.90/ per projected Therm saved.
- For each % over 15% add: \$0.05 per projected Therm saved.
- Maximum incentive: \$1.25 per projected Therm saved.

Combining Incentives #2 and #3 will provide a total of \$0.18/ kWh and \$1.8/therm not to exceed 50% of total project cost. Additional Incentives for #2 and #3 are increased by \$0.005/kWh and \$0.05/therm for each percentage increase above the 15% minimum target to 20%, calculated with the EPA Portfolio Manager benchmarking tool, not to exceed 50% of total project cost.

For the purpose of demonstrating the eligibility of the ECM's to meet the minimum savings requirement of 15% annual savings and 10% ROI for the Pay for Performance Program, all ECM's identified in this report have been included in the incentive calculations. The results for the building are shown in Appendix C.

The electric demand of this building does not meet the 200kW requirement for P4P program.

6.1.4 Energy Savings Improvement Plan

The Energy Savings Improvement Program (ESIP) allows government agencies to make energy related improvements to their facilities and pay for the costs using the value of energy savings that result from the improvements. Under the recently enacted Chapter 4 of the Laws of 2009 (the law), the ESIP provides all government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources.

ESIP allows local units to use “energy savings obligations” (ESO) to pay for the capital costs of energy improvements to their facilities. ESIP loans have a maximum loan term of 15 year. ESOs are not considered “new general obligation debt” of a local unit and do not count against debt limits or require voter approval. They may be issued as refunding bonds

or leases. Savings generated from the installation of energy conservation measures pay the principal of and interest on the bonds; for that reason, the debt service created by the ESOs is not paid from the debt service fund, but is paid from the general fund.

For local governments interested in pursuing an ESIP, the first step is to perform an energy audit. Pursuing a Local Government Energy Audit through New Jersey's Clean Energy Program is a valuable first step to the ESIP approach. The "Local Finance Notice" outlines how local governments can develop and implement an ESIP for their facilities. The ESIP can be prepared internally if the entity has qualified staff. If not, the ESIP must be implemented by an independent contractor and not by the energy savings company producing the Energy Reduction Plan.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Local units should carefully consider all alternatives to develop an approach that best meets their needs.

6.1.5 Renewable Energy Incentive Program

The Renewable Energy Incentive Program (REIP) is part of New Jersey's efforts to reach its Energy Master Plan goals of striving to use 30 percent of electricity from renewable sources by 2020.

Incentives for sustainable bio-power projects and for energy storage projects are currently under development, with competitive solicitations for each of those technologies expected to begin in the first quarter of 2014. The wind program is currently on hold.

New solar projects are no longer eligible for REIP incentives, but can register for Solar Renewable Energy Certificates (SRECs) through the SREC Registration Program (SRP).

7.0 ALTERNATIVE ENERGY SCREENING EVALUATION

7.1 Solar

7.1.1 Photovoltaic Rooftop Solar Power Generation

The buildings were shadowed by tree around them and do not have sufficient space on the roof or the ground to install PV solar panels. Therefore, PV solar panels were not evaluated for this facility.

7.1.2 Solar Thermal Hot Water Generation

Active solar thermal systems use solar collectors to gather the sun's energy to heat a fluid. An absorber in the collector (usually black colored piping) converts the sun's energy into heat. The heat is transferred to circulating water, antifreeze, or air for immediate use or is storage for later utilization. Applications for active solar thermal energy include supplementing domestic hot water, heating swimming pools, space heating or preheating air in residential and commercial buildings.

A standard solar hot water system is typically composed of solar collectors, heat storage vessel, piping, circulators, and controls. Systems are typically integrated to work alongside a conventional heating system that provides heat when solar resources are not sufficient. The solar collectors are usually placed on the roof of the building, oriented south, and tilted at the same angle as the site's latitude, to maximize the amount of solar radiation collected on a yearly basis.


Several options exist for using active solar thermal systems for space heating. The most common method is called a passive solar hot water system involves using glazed collectors to heat a liquid held in a storage tank (similar to an active solar hot water system described above which requires pumping). The most practical system would transfer the heat from the panels to thermal storage tanks and then use the pre-heated water for domestic hot water production. DHW is presently produced by natural gas fired water heaters and, therefore, this measure would offer natural gas utility savings. Unfortunately, the amount of domestic hot water that is currently used by this building is very small. Installing a solar domestic hot water system is not recommended due to the limited amount of domestic hot water presently consumed by the building.

This measure is not recommended due to the relatively low domestic hot water usage.

7.2 Wind Powered Turbines

Wind power is the conversion of kinetic energy from wind into mechanical power that is used to drive a generator which creates electricity by means of a wind turbine. A wind turbine consists of rotor and blades connected to a gearbox and generator that are mounted onto a tower. Newer wind turbines also use advanced technology to generate electricity at a variety of frequencies depending on the wind speed, convert it to DC and then back to AC before sending it to the grid. Wind turbines range from 50 – 750 kW for utility scale turbines down to below 50 kW for residential use. On a scale of 1 (the lowest) to 7 (the highest), Class 3 and above (wind speeds of 13 mph or greater) are generally considered "good wind resource" according to the Wind Energy Development

Programmatic EIS Information Center hosted by the Bureau of Land Management. According to the map below, published by NREL, Newark, NJ is classified as Class 1 at 50m, meaning the city would not be a good candidate for wind power.



This measure is not recommended due to the location of the building.

7.3 Combined Heat and Power Plant

Combined heat and power (CHP), cogeneration, is self-production of electricity on-site with beneficial recovery of the heat byproduct from the electrical generator. Common CHP equipment includes reciprocating engine-driven, micro turbines, steam turbines, and fuel cells. Typical CHP customers include industrial, commercial, institutional, educational institutions, and multifamily residential facilities. CHP systems that are commercially viable at the present time are sized approximately 50 kW and above, with numerous options in blocks grouped around 300 kW, 800 kW, 1,200 kW and larger. Typically, CHP systems are used to produce a portion of the electricity needed by a facility some or all of the time, with the balance of electric needs satisfied by purchase from the grid.

Any proposed CHP project will need to consider many factors, such as existing system load, use of thermal energy produced, system size, natural gas fuel availability, and proposed plant location. This building has sufficient need for electrical generation and the ability to use most of the thermal byproduct during the winter; however thermal usage during the summer months does not exist. Thermal energy produced by the CHP plant in the warmer months will be wasted. An absorption chiller could be installed to utilize the heat to produce chilled water; however, there is no chilled water distribution system in the building. CHP is not recommended due to the building's limited summer thermal demand.

This measure is not recommended due to the absence of year-round thermal loads which are needed for efficiency CHP operation. However, a mini-size CHP could be an option

for the facility to consider. The sizing and energy savings of the mini-size CHP require further study.

7.4 Demand Response Curtailment

Presently, electricity is delivered by PSE&G, which receives the electricity from regional power grid RFC. PSE&G is the regional transmission organization (RTO) that coordinates the movement of wholesale electricity in all or parts of 13 states and the District of Columbia including the State of New Jersey.

Utility Curtailment is an agreement with the utility provider's regional transmission organization and an approved Curtailment Service Provider (CSP) to shed electrical load by either turning major equipment off or energizing all or part of a facility utilizing an emergency generator; therefore, reducing the electrical demand on the utility grid. This program is to benefit the utility company during high demand periods and the utility provider offers incentives to the CSP to participate in this program. Enrolling in the program will require program participants to drop electrical load or turn on emergency generators during high electrical demand conditions or during emergencies. Part of the program also will require that program participants reduce their required load or run emergency generators with notice to test the system.

A pre-approved CSP will require a minimum of 100 kW of load reduction to participate in any curtailment program. From October 2014 through September 2014 the following table summarizes the electricity load profile for the building.

Building Electric Load Profile

Peak Demand kW	Min Demand kW	Avg Demand kW	Onsite Generation Y/N	Eligible? Y/N
118.8	30	89.0	N	N

*the demand is estimated from one month bill

This measure is not recommended due to not meeting the minimum requirement.

8.0 CONCLUSIONS & RECOMMENDATIONS

The following section summarizes the LGEA energy audit conducted by CHA for City of East Orange.

The following projects should be considered for implementation:


- Replace Single Pane Windows with Double Pane Windows
- Replace the Old Boiler with a high efficiency Boiler
- Replace the Oil Furnace with High Efficiency Furnace
- Lighting Replacements with LED and add Controls (Occupancy Sensors)

The potential annual energy and cost savings for the recommended ECMs are shown in the following table.

Electric Savings (kWh)	Fuel Oil Savings (gallons)	Total Savings (\$)	Payback (years)
62,433	61	22,704	2.5

If the city implements the recommended ECMs, energy savings would be as follows:

	Existing Conditions	Post Recommended ECMs	Percent Savings
Costs (\$)	55,364	32,660	41%
Electricity (kWh)	107,340	44,907	58%
Oil (gallon)	5,000	4,939	1%
Site EUI (kbtu/SF/Yr)	162.4	121.3	



Next Steps: This energy audit has identified several areas of potential energy savings. City of East Orange can use this information to pursue incentives offered by the NJBPU's NJ Clean Energy Program. Additional meetings will be scheduled with city staff members to review possible options.

APPENDIX A


Utility Usage Analysis and Alternate Utility Suppliers

**East Orange NJBPU LGEA
Fire House at Soverel Park**


Annual Utilities
12-month Summary

Electric		
Annual Usage	107,340	kWh/yr
Annual Cost	44,064	\$
Blended Rate	0.411	\$/kWh
Peak Demand	118.8	kW
Min. Demand	30.0	kW
Avg. Demand	89.0	kW
Oil		
Annual Usage	1,414	Gallon/yr
Annual Cost	2,934	\$
Rate	2.075	\$/Gallon
Energy Summary		
Building Area	5,334	SF
Energy Usage Intensity (EUI)	69	KBtu/SF/yr
Energy Cost Index (ECI)	8.81	\$/SF/yr
Total Annual Utility Costs	46,998	\$

Utility	KBtu	%
Electric	366,259	99%
Natural Gas	1,923	1%
	368,183	100%



Utility	\$	%
Electric	44,064	94%
Natural Gas	2,934	6%
	46,998	100%



East Orange NJBPU LGEA
Fire House at Soverel Park

Electric Service

Account No.: 7005019709
Meter No.: 298001083

Delivery: PSE&G
Rate GLP

Month	Consump. (kWh)*	Demand (kW)**	Provider Charges			Usage (kWh) vs. Demand (kW) Charges		Unit Costs				
			Delivery (\$)*	Supplier (\$)	Total (\$)	Consumption (\$)	Demand (\$)	Delivery (\$/kWh)	Supplier (\$/kWh)	Consumption Rate (\$/kWh)	Demand (\$/kW)	Blended Rate (\$/kWh)
October-13	10,680	62	633	1,440.10	2,073.06	1578.66	494.40	0.059	0.135	0.148	8.000	0.194
November-13	11,460	60	652	1,477.39	2,129.68	1649.68	480.00	0.057	0.129	0.144	8.000	0.186
December-13	11,460	62	660	1,479.07	2,139.06	1644.66	494.40	0.058	0.129	0.144	8.000	0.187
January-14	11,760	119	901	1,411	2,312.31	1361.91	950.40	0.077	0.120	0.116	8.000	0.197
February-14	10,200	119	843	1,290	2,133.38	1182.98	950.40	0.083	0.127	0.116	8.000	0.209
March-14	10,200	119	843.02	1,290.36	2,133.38	1182.98	950.40	0.083	0.127	0.116	8.000	0.209
April-14	10,200	119	843.02	1,290.36	2,133.38	1182.98	950.40	0.083	0.127	0.116	8.000	0.209
May-14	10,200	119	843.02	1,290.36	2,133.38	1182.98	950.40	0.083	0.127	0.116	8.000	0.209
June-14	360	30	383	477	860.50	620.50	240.00	1.064	1.326	1.724	8.000	2.390
July-14	420	30	389	398	787.42	547.42	240.00	0.927	0.948	1.303	8.000	1.875
August-14	10,200	112	3,776	8,838	12,614.14	11721.34	892.80	0.370	0.866	1.149	8.000	1.237
September-14	10,200	119	3,776.42	8,837.72	12,614.14	11663.74	950.40	0.370	0.866	1.144	8.000	1.237
Total (All)	107,340	118.80	\$8,871.55	\$29,520.42	\$44,063.83	\$35,519.83	\$8,544.00	\$0.08	\$0.28	\$0.33	\$8.00	\$0.41
Notes	1	2	3	4	5			6	7			8

1.) Number of kWh of electric energy used per month

2.) Number of kW of power measured

3.) Electric charges from Delivery provider

4.) Electric charges from Supply provider - note, includes 8.875% tax

5.) Total charges (Delivery + Supplier)


6.) Delivery Charges (\$) / Consumption (kWh)

7.) Supplier Charges (\$) / Consumption (kWh)

8.) Total Charges (\$) / Consumption (kWh)

* Based on combined numbers provided by client

** Addition of two accounts provided by client

Fire House at Soverel Park

**East Orange NJBPU LGEA
Fire House at Soverel Park**

Fuel Service


Account No.:

Meter No:

Delivery: Finch Fuel

Rate GSG

Month	Consumption (Gallons)	Total Charges (\$)	Rate (\$/Gallon)
January-15	432.00	763.92	1.77
February-15	332.00	648.63	1.95
March-15	268.23	996.61	3.72
October-15	170.00	252.47	1.49
December-15	212.00	272.44	1.29
Total (12 Months)	1,414	\$ 2,934.07	\$ 2.07



PSE&G ELECTRIC SERVICE TERRITORY

Last Updated: 7/21/15

***CUSTOMER CLASS - R – RESIDENTIAL C – COMMERCIAL I –INDUSTRIAL**

Supplier	Telephone & Web Site	*Customer Class
Abest Power & Gas of NJ, LLC 202 Smith Street Perth Amboy, NJ 08861	(888)987-6937 www.AbestPower.com	R/C/I ACTIVE
AEP Energy, Inc. f/k/a BlueStar Energy Services 309 Fellowship Road, Fl. 2 Mount Laurel, NJ 08054	(866) 258-3782 www.aepenergy.com	R/C/I ACTIVE
Agera Energy, LLC 115 route 46, Building F Parsippany, NJ 07054	(844) 692-4372 www.ageraenergy.com	R/C/I
Alpha Gas and Electric, LLC 641 5 th Street Lakewood, NJ 08701	(855) 553-6374 www.alphagasandelectric.com	R/C ACTIVE
Ambit Northeast, LLC d/b/a Ambit Energy 103 Carnegie Center Suite 300 Princeton, NJ 08540	877-282-6284 www.ambitenergy.com	R/C ACTIVE
American Power & Gas of NJ, LLC - 10000 Lincoln Drive East – Suite 201 Marlton, NJ 08053	(800) 205-7491 www.GoAPG.com	R/C/I
American Powernet Management, LP 437 North Grove St. Berlin, NJ 08009	(877) 977-2636 www.americanpowernet.com	C/I ACTIVE
Amerigreen Energy, Inc. 333 Sylvan Avenue, Suite 305 Englewood Cliffs, NJ 07632	888-559-4567 www.amerigreen.com	C/I ACTIVE
AP Gas & Electric, (NJ) LLC 10 North Park Place, Suite 420 Morristown, NJ 07960	(855) 544-4895 www.apgellc.com	R/C/I ACTIVE
Astral Energy LLC 16 Tyson Place Bergenfield, NJ 07621	(888)850-1872 www.AstralEnergyLLC.com	R/C/I ACTIVE

Barclays Capital Services, Inc. 70 Hudson Street Jersey City, NJ 07302-4585	(800) 526-7000 www.barclays.com	C ACTIVE
BBPC, LLC d/b/a Great Eastern Energy 116 Village Blvd. Suite 200 Princeton, NJ 08540	(888) 651-4121 www.greateasternenergy.com	C ACTIVE
Berkshire Energy Partners, LLC 9 Berkshire Road Landenberg, PA 19350 Attn: Dana A. LeSage, P.E.	(610) 255-5070 www.berkshireenergypartners.com	C/I ACTIVE
Blue Pilot Energy, LLC 197 State Rte. 18 South Ste. 3000 East Brunswick, NJ 08816	(800) 451-6356 www.bluepilotenergy.com	R/C ACTIVE
Brick Standard, LLC 235 Hudson Street Suite 1 Hoboken, NJ 07030	(201)706-8101 www.standardalternative.com	C/I ACTIVE
CCES LLC dba Clean Currents Energy Services 566 Terhune Street Teaneck, NJ 07666	(877) 933-2453 www.cleancurrents.com	R/C ACTIVE
Champion Energy Services, LLC 1200 Route 22 Bridgewater, NJ 08807	(888) 653-0093 www.championenergyservices.com	R/C/I ACTIVE
Choice Energy, LLC 4257 US Highway 9, Suite 6C Freehold, NJ 07728	(888) 565-4490 www.4choiceenergy.com	R/C ACTIVE
Clearview Electric, Inc. 1744 Lexington Avenue Pennsauken, NJ 08110	(888) CLR-VIEW (800) 746- 4702 www.clearviewenergy.com	R/C/I ACTIVE
Commerce Energy, Inc. 7 Cedar Terrace Ramsey, NJ 07446	1-866-587-8674 www.commerceenergy.com	R/C ACTIVE
Community Energy Inc. 51 Sandbrook Headquarters Road Stockton, NJ 08559	(866)946-3123 www.communityenergyinc.com	R/C/I ACTIVE

ConEdison Solutions Cherry Tree Corporate Center 535 State Highway Suite 180 Cherry Hill, NJ 08002	(888) 665-0955 www.conedsolutions.com	C/I ACTIVE
ConocoPhillips Company 224 Strawbridge Drive Suite 107 Moorestown, NJ 08057	(800) 646-4427 www.conocophillips.com	C/I ACTIVE
Constellation New Energy, Inc. 900A Lake Street, Suite 2 Ramsey, NJ 07446	(888) 635-0827 www.constellation.com	R/C/I ACTIVE
Constellation Energy 900A Lake Street, Suite 2 Ramsey, NJ 07446	(877) 997-9995 www.constellation.com	R ACTIVE
Constellation Energy Services, Inc. 116 Village Boulevard Suite 200 Princeton, NJ 08540	1 (800) 536-0151 www.integrityenergy.com	R/C/I
Corporate Services Support Corp. 665 Howard Avenue Somerset, NJ 08873	1(800) 761-4000 www.morganstanley.com	C
Credit Suisse, (USA) Inc. 700 College Road East Princeton, NJ 08450	(800) 325-2000 www.creditsuisse.com	C ACTIVE
Direct Energy Business, LLC 1 Hess Plaza Woodbridge	(888) 925-9115 http://www.business.directenergy.com/	C/I ACTIVE
Direct Energy Business Marketing, LLC (fka Hess Energy Marketing) 1 Hess Plaza Woodbridge, NJ 07095	(800) 437-7872 http://www.business.directenergy.com/	C/I ACTIVE
Direct Energy Small Business, LLC (fka Hess Small Business Services, LLC) One Hess Plaza Woodbridge, NJ 07095	(888) 925-9115 http://www.business.directenergy.com/small-business	C/I ACTIVE

Direct Energy Services, LLC 1 Hess Plaza Woodbridge, NJ 07095	1 (866) 348-4193 www.directenergy.com	C/I INACTIVE
Discount Energy Group, LLC 811 Church Road, Suite 149 Cherry Hill, New Jersey 08002	(800) 282-3331 www.discountenergygroup.com	R/C ACTIVE
DTE Energy Supply, Inc. One Gateway Center, Suite 2600 Newark, NJ 07102	(877) 332-2450 www.dtesupply.com	C/I ACTIVE
EDF Energy Services, LLC 1 Meadowlands Plaza Suite 200, Office No. 246 East Rutherford, NJ 07073	1 (877) 432-4530 www.edfenergyservices.com	C/I
Energy.me Midwest LLC 90 Washington Blvd Bedminster, NJ 07921	(855) 243-7270 www.energy.me	R/C/I ACTIVE
Energy Plus Holdings LLC 309 Fellowship Road East Gate Center, Suite 200 Mt. Laurel, NJ 08054	(877) 866-9193 www.energypluscompany.com	R/C ACTIVE
EnerPenn d/b/a YEP Energy 89 Headquarters Plaza North #1463 Morristown, NJ 07960	(855) 363-7736 www.yepenergyNJ.com	R/C/I ACTIVE
Ethical Electric Benefit Co. d/b/a Ethical Electric/d/b/a Clean Energy Option 100 Overlook Center, 2 nd Fl. Princeton, NJ 08540	(888) 444-9452 www.ethicalelectric.com	R/C ACTIVE
Energy Service Providers, Inc., d/b/a New Jersey Gas & Electric 1 Bridge Plaza fl. 2 Fort Lee, NJ 07024	(866) 568-0290 www.njgande.com	R/C ACTIVE
Everyday Energy, LLC One International Blvd., Suite 400 Mahwah, NJ 07495-0400	844-684-5506 www.energyrewards.comcast.com	R/I

FirstEnergy Solutions 150 West State Street Trenton, NJ 08608	(888) 254-63590- www.fes.com	C/I ACTIVE
First Point Power, LLC 90 Washington Valley Road Bedminster, NJ 07921	(888) 875-1711 www.firstpointpower.com	R/C/I
Frontier Utilities Northeast, LLC 199 New Road, Suite 61-187 Linwood, NJ 08221	(877) 437-6930 www.frontierutilities.com	R/C/I
Gateway Energy Services Corporation 1 Hess Plaza Woodbridge, NJ 07095	(800) 805-8586 www.gesc.com	R/C ACTIVE
GDF SUEZ Energy Resources NA, Inc. 333 Thornall Street Sixth Floor Edison, NJ 08837	(866) 999-8374 www.gdfsuezenergyresources.com	C/I ACTIVE
GDF Suez Retail Energy Solutions LLC d/b/a THINK ENERGY 333 Thornall St. Sixth Floor Edison, NJ 08819	1-866-252-0078 www.mythinkenergy.com	R/C/I ACTIVE
Glacial Energy of New Jersey, Inc. 21 Pine Street, Suite 237 Rockaway, NJ 07866	(888) 452-2425 www.glacialenergy.com	C/I ACTIVE
Global Energy Marketing LLC 129 Wentz Avenue Springfield, NJ 07081	(800) 542-0778 www.globalp.com	R/C/I ACTIVE
Greenlight Energy, Inc. 2608 25th Road Astoria, NY 11102	(888) 453-4427 www.greenlightenergy.us	R
Green Mountain Energy Company 211 Carnegie Center Drive Princeton, NJ 08540	(866) 767-5818 www.greenmountain.com/commercial-home	C/I ACTIVE

Harborside Energy LLC 101 Hudson Street Suite 2100 Jersey City, NJ 07302	(877) 940-3835 www.harborsideenergynj.com	R/C ACTIVE
Hess Corporation 1 Hess Plaza Woodbridge, NJ 07095	(800) 437-7872 www.hess.com	C/I ACTIVE
HIKO Energy, LLC 655 Suffern Road Teaneck, NJ 07666	(888) 264-4908 www.hikoenergy.com	R/C/I ACTIVE
Holcim (US) Inc. 595 Morgan Boulevard Camden, NJ 08104	(800) 831-9507 ext. 4354 www.holcim.us	I
Hudson Energy Services, LLC 7 Cedar Street Ramsey, New Jersey 07466	(877) Hudson 9 www.hudsonenergyservices.com	C ACTIVE
IDT Energy, Inc. 550 Broad Street Newark, NJ 07102	(877) 887-6866 www.idtenergy.com	R/C ACTIVE
Independence Energy Group, LLC 211 Carnegie Center Princeton, NJ 08540	(877) 235-6708 www.chooseindependence.com	R/C ACTIVE
Inspire Energy Holdings LLC 923 Haddonfield Road 3rd Fl. Building B2 Cherry Hill, NJ 08002	(866) 403-2620 www.inspireenergy.com	R/C/I
Integrus Energy Services, Inc. 33 Wood Ave, South, Suite 610 Iselin, NJ 08830	(800) 536-0151 www.integrusenergy.com	C/I ACTIVE
Jsynergy, LLC 445 Central Ave. Suite 204 Cedarhurst, NY 11516	(516) 331-2020 Jsynergylc.com	R/C/I ACTIVE
Kuehne Chemical Company, Inc. 86 North Hackensack Avenue South Kearney, NJ 07032	(973) 589-0700 kuehnechemical@comcast.net	I

Liberty Power Delaware, LLC 1973 Highway 34, Suite 211 Wall, NJ 07719	(866) 769-3799 www.libertypowercorp.com	C/I ACTIVE
Liberty Power Holdings, LLC 1973 Highway 34, Suite 211 Wall, NJ 07719	(866) 769-3799 www.libertypowercorp.com	R/C/I ACTIVE
Linde Energy Services 575 Mountain Avenue Murray Hill, NJ 07974	(800) 247-2644 www.linde.com	C/I ACTIVE
Marathon Power LLC 302 Main Street Paterson, NJ 07505	(888) 779-7255 www.mecny.com	R/C/I ACTIVE
MP2 Energy NJ, LLC 111 River Street, Suite 1204 Hoboken, NJ 07030	(877) 238-5343 www.mp2energy.com	R/C/I ACTIVE
Natures Current, LLC 95 Fairmount Avenue Philadelphia, Pennsylvania 19123	(215) 464-6000 www.naturescurrent.com	R/C/I ACTIVE
MPower Energy NJ LLC One University Plaza, Suite 507 Hackensack, NJ 07601	(877) 286-7693 www.mpowerenergy.com	R/C/I ACTIVE
NATGASCO, Inc. (Supreme Energy, Inc.) 532 Freeman St. Orange, NJ 07050	(800) 840-4427 www.supremeenergyinc.com	R/C/I ACTIVE
New Jersey Gas & Electric 10 North Park Place Suite 420 Morristown, NJ 07960	(866) 568-0290 www.njgande.com	R/C/ ACTIVE
NextEra Energy Services New Jersey, LLC 651 Jernee Mill Road Sayreville, NJ 08872	(877) 528-2890 Commercial (800) 882-1276 Residential www.nexteraenergyservices.com	R/C/I ACTIVE
Noble Americas Energy Solutions The Mac-Cali Building 581 Main Street, 8th Floor Woodbridge, NJ 07095	(877) 273-6772 www.noblesolutions.com	C/I ACTIVE

Nordic Energy Services, LLC 50 Tice Boulevard, Suite 340 Woodcliff Lake, NJ 07677	(877) 808-1027 www.nordiceenergy.us.com	R/C/I ACTIVE
North American Power and Gas, LLC 222 Ridgedale Avenue Cedar Knolls, NJ 07927	(888) 313-9086 www.napower.com	R/C/I ACTIVE
North Eastern States, Inc. d/b/a Entrust Energy 90 Washington Valley Road Bedminster, NJ 07921	(888) 521-5861 www.entrustenergy.com	R/C/I ACTIVE
Oasis Power, LLC d/b/a Oasis Energy 11152 Westheimer, Suite 901 Houston, TX 77042	(800)324-3046 www.oasisenergy.com	R/C ACTIVE
Palmco Power NJ, LLC One Greentree Centre 10,000 Lincoln Drive East, Suite 201 Marlton, NJ 08053	(877) 726-5862 www.PalmcoEnergy.com	R/C/I ACTIVE
Park Power, LLC 1200 South Church St. Suite 23 Mount Laurel, NJ 08054	(856) 778-0079 www.parkpower.com	R/C/I ACTIVE
Plymouth Rock Energy, LLC 338 Maitland Avenue Teaneck, NJ 07666	(855) 32-POWER (76937) www.plymouthenergy.com	R/C/I ACTIVE
Power Management Co., LLC b/b/a PMC Lightsavers Limited Liability Company 1600 Moseley Road Victor, NY 14564	(585) 249-1360 www.powermanagementco.com	C/I ACTIVE
PPL Energy Plus, LLC Shrewsbury Executive Offices 788 Shrewsbury Ave., Suite 2178 Tinton Falls, NJ 07724	(800) 281-2000 www.pplenergyplus.com	C /I ACTIVE
Progressive Energy Consulting, LLC PO Box 4582 Wayne, New Jersey 07474	(917) 837-7400 Progressivenrg@optionline.net	R/C/I ACTIVE

Prospect Resources, Inc. 208 W. State Street Trenton, NJ 08608-1002	(847) 673-1959 www.prospectresources.com	C ACTIVE
Public Power & Utility of New Jersey, LLC One International Blvd, Suite 400 Mahwah, NJ 07495	(888) 354-4415 www.ppandu.com	R/C/I ACTIVE
Reliant Energy 211 Carnegie Center Princeton, NJ 08540	(877) 297-3795 (877) 297-3780 www.reliant.com	R/C/I ACTIVE
ResCom Energy LLC 18C Wave Crest Ave. Winfield Park, NJ 07036	(888) 238-4041 http://rescom-energy.com	R/C/I ACTIVE
Residents Energy, LLC 550 Broad Street Newark, NJ 07102	(888) 828-7374 www.residentsenergy.com	R/C
Respond Power LLC 1001 East Lawn Drive Teaneck, NJ 07666	(888) 625-6760 www.majorenergy.com	R/C/I ACTIVE
Save on Energy, LLC 1101 Red Ventures Drive Fort Mill, SC 29707	1 (877)-658-3183 www.saveonenergy.com	R/C
SFE Energy One Gateway Center Suite 2600 Newark, NJ 07012	1 (877) 316-6344 www.sfeenergy.com	R/C/I ACTIVE
S.J. Energy Partners, Inc. 208 White Horse Pike, Suite 4 Barrington, NJ 08007	(800) 695-0666 www.sjnaturalgas.com	C ACTIVE
SmartEnergy Holdings, LLC 100 Overlook Center 2nd Floor Princeton, NJ NJ 08540 United States of America	(800) 443-4440 www.smartenergy.com	R/C/I ACTIVE
South Jersey Energy Company 1 South Jersey Plaza, Route 54 Folsom, NJ 08037	(800) 266-6020 www.southjerseyenergy.com	R/C/I ACTIVE
Spark Energy Gas, LP/ Spark Energy	(713)600-2600	R/C/I

2105 City West Blvd. Suite 100 Houston, TX 77042	www.sparkenergy.com	ACTIVE
Sperian Energy Corp. 1200 Route 22 East, Suite 2000 Bridgewater, NJ 08807	(888) 682-8082 www.sperianenergy.com	R/C/I ACTIVE
Sprague Energy Corp. 12 Ridge Road Chatham Township, NJ 07928	855-466-2842 www.spragueenergy.com	C/I ACTIVE
Starion Energy PA Inc. 101 Warburton Avenue Hawthorne, NJ 07506	(800) 600-3040 www.starionenergy.com	R/C/I ACTIVE
Stream Energy New Jersey, LLC 309 Fellowship Rd., Suite 200 Mt. Laurel, NJ 08054	(877) 369-8150 www.streamenergy.net	R/C ACTIVE
Summit Energy Services, Inc. 10350 Ormsby Park Place Suite 400 Louisville, KY 40223	1 (800) 90-SUMMIT www.summitenergy.com	C/I ACTIVE
Talen Energy Marketing, LLC 788 Shrewsbury Avenue, Suite 2178 Tinton Falls, NJ 07724	(888) 289-7693 www.pplenergyplus.com/*	R/C
Texas Retail Energy LLC Park 80 West Plaza II, Suite 200 Saddle Brook, NJ 07663 Attn: Chris Hendrix	(866) 532-0761 Texasretailenergy.com	C/I ACTIVE
TransCanada Power Marketing Ltd. 190 Middlesex Essex Turnpike, Suite 200 Iselin, NJ 08830	(877) MEGAWAT www.transcanada.com/powermarketing	C/I ACTIVE
TriEagle Energy, LP 90 Washington Valley Rd Bedminster, NJ 07921	(877) 933-2453 www.trieagleenergy.com	R/C/I ACTIVE

UGI Energy Services, Inc. dba UGI Energy Link 224 Strawbridge Drive Suite 107 Moorestown, NJ 08057	(800) 427-8545 www.ugienergylink.com	C/I ACTIVE
Verde Energy USA, Inc. 2001 Route 46 Waterview Plaza Suite 301 Parsippany, NJ 07054	(800) 388-3862 www.lowcostpower.com	R/C ACTIVE
Viridian Energy 2001 Route 46, Waterview Plaza Suite 310 Parsippany, NJ 07054	(866) 663-2508 www.viridian.com	R/C/I ACTIVE
XOOM Energy New Jersey, LLC 744 Broad Street. 16 th Floor Newark, NJ 07102	(888) 997-8979 www.xoomenergy.com	R/C/I ACTIVE
Your Energy Holdings, LLC One International Boulevard Suite 400 Mahwah, NJ 07495-0400	(855) 732-2493 www.thisisyourenergy.com	R/C/I ACTIVE

[Back to the main supplier page](#)

PSE&G GAS SERVICE TERRITORY
Last Updated 7/21/15

***CUSTOMER CLASS - R – RESIDENTIAL C – COMMERCIAL I - INDUSTRIAL**

Supplier	Telephone & Web Site	*Customer Class
Agera Energy, LLC 115 route 46, Building F Parsippany, NJ 07054	(844) 692-4372 www.ageraenergy.com	R/C/I
Ambit Northeast, LLC d/b/a Ambit Energy 103 Carnegie Center Suite 300 Princeton, NJ 08540	877-282-6284 www.ambitenergy.com	R/C ACTIVE
American Power & Gas of NJ, LLC 10000 Lincoln Drive East – Suite 201 Marlton, NJ 08053	(800) 2057491 www.GoAPG.com	R/C/I
Amerigreen Energy, Inc. 333 Sylvan Avenue Suite 305 Englewood Cliffs, NJ 07632	(888)559-4567 www.amerigreen.com	C/I ACTIVE
Astral Energy LLC 16 Tyson Place Bergenfield, NJ 07621	888-850-1872 www.AstralEnergyLLC.com	R/C/I ACTIVE
BBPC, LLC Great Eastern Energy 116 Village Blvd. Suite 200 Princeton, NJ 08540	888-651-4121 www.greateasternenergy.com	C ACTIVE
Choice Energy, LLC 4257 US Highway 9, Suite 6C Freehold, NJ 07728	(888) 565-4490 www.4choiceenergy.com	R/C/I
Clearview Electric Inc. d/b/a Clearview Gas 1744 Lexington Ave. Pennsauken, NJ 08110	800-746-4720 www.clearviewenergy.com	R/C ACTIVE

Colonial Energy, Inc. 83 Harding Road Wyckoff, NJ 07481	845-429-3229 www.colonialgroupinc.com	C/I ACTIVE
Commerce Energy, Inc. 7 Cedar Terrace Ramsey, NJ 07746	888 817-8572 www.commerceenergy.com	R ACTIVE
Compass Energy Services, Inc. 33 Wood Avenue South, 610 Iselin, NJ 08830	866-867-8328 www.compassenergy.net	C/I ACTIVE
Compass Energy Gas Services, LLC 33 Wood Avenue South Suite 610 Iselin, NJ 08830	866-867-8328 www.compassenergy.net	C/I ACTIVE
ConocoPhillips Company 224 Strawbridge Drive, Suite 107 Moorestown, NJ 08057	800-646-4427 www.conocophillips.com	C/I ACTIVE
Consolidated Edison Energy, Inc. d/b/a Con Edison Solutions 535 State Highway 38, Suite 140 Cherry Hill, NJ 08002	888-686-1383 x2130 www.conedenergy.com	
Consolidated Edison Solutions, Inc. Cherry Tree Corporate Center 535 State Highway 38, Suite 140 Cherry Hill, NJ 08002	888-665-0955 www.conedsolutions.com	C/I ACTIVE
Constellation NewEnergy-Gas Division, LLC 116 Village Boulevard, Suite 200 Princeton, NJ 08540	800-785-4373 www.constellation.com	C/I ACTIVE
Constellation Energy Gas Choice, Inc. 116 Village Blvd., Suite 200 Princeton, NJ 08540	800-785-4373 www.constellation.com	R/C/I ACTIVE
Constellation Energy Services Natural Gas, LLC 116 Village Boulevard	1 (800) 536-0151	C/I

Suite 200 Princeton, NJ 08540	www.integrysenergy.com	
Direct Energy Business, LLC 1 Hess Plaza Woodbridge, NJ 07095	888-925-9115 http://www.business.directenergy.com/	C/I ACTIVE
Direct Energy Business Marketing, LLC (fka Hess Energy Marketing) One Hess Plaza Woodbridge, NJ 07095	(800) 437-7872 http://www.business.directenergy.com/	C/I ACTIVE
Direct Energy Small Business, LLC (fka Hess Small Business Services, LLC) One Hess Plaza Woodbridge, NJ 07095	(888) 925-9115 http://www.business.directenergy.com/small-business	C/I ACTIVE
Direct Energy Services, LLC 1 Hess Plaza Woodbridge, NJ 07095	1 (866) 348-4193 www.directenergy.com	C/I INACTIVE
Dominion Retail, Inc. d/b/a Dominion Energy Solutions 395 Route #70 West, Suite 125 Lakewood, NJ 08701	(866)237-4765 www.dominionenergy.com	R/C
Everyday Energy, LLC One International Blvd., Suite 400 Mahwah, NJ 07495-0400	844-684-5506 www.energyrewards.comcast.com	R/I
Frontier Utilities Northeast, LLC 199 New Road, Suite 61-187 Linwood, NJ 08221	(877) 437-6930 www.frontierutilities.com	R/C/I
Glacial Energy of New Jersey, Inc. 21 Pine Street, Suite 237 Rockaway, NJ 07866	888-452-2425 www.glacialenergy.com	C/I ACTIVE
Gateway Energy Services Corporation 1 Hess Plaza Woodbridge, NJ 07095	(800) 805-8586 www.gesc.com	R/C ACTIVE

Global Energy Marketing, LLC 129 Wentz Avenue Springfield, NJ 07081	800-542-0778 www.globalp.com	C/I ACTIVE
Great Eastern Energy 116 Village Blvd., Suite 200 Princeton, NJ 08540	888-651-4121 www.greateastern.com	C/I ACTIVE
Greenlight Energy 2608 25 th Road Astoria, NY 11102	(888) 453-4427 www.greenlightenergy.us	R ACTIVE
Harborside Energy LLC 101 Hudson Street, Suite 2100 Jersey City, NJ 07302	877-940-3835 www.harborsideenergynj.com	R/C ACTIVE
Hess Energy, Inc. One Hess Plaza Woodbridge, NJ 07095	800-437-7872 www.hess.com	C/I ACTIVE
HIKO Energy, LLC 655 Suffern Road Teaneck, NJ 07666	888 264-4908 www.hikoenergy.com	R/C/I ACTIVE
Hudson Energy Services, LLC 7 Cedar Street Ramsey, NJ 07466	877- Hudson 9 www.hudsonenergyservices.com	C ACTIVE
IDT Energy, Inc. 550 Broad Street Newark, NJ 07102	877-887-6866 www.idtenergy.com	R/C ACTIVE
Infinite Energy dba Intelligent Energy 1200 Route 22 East Suite 2000 Bridgewater, NJ 08807-2943	(800) 927-9794 www.InfiniteEnergy.com	R/C/I ACTIVE
Integrlys Energy Services-Natural Gas, LLC 101 Eisenhower Parkway Suite 300 Roseland, NJ 07068	(800) 536-0151 www.integrlysenergy.com	C/I ACTIVE
Jsynergy LLC 445 Cental Ave. Suite 204 Cedarhurst, NY 11516	(516) 331-2020 www.Jsnergylc.com	R/C/I ACTIVE
Major Energy Services, LLC 1001 East Lawn Drive Teaneck NJ 07666	888-625-6760 www.majorenergy.com	R/C/I ACTIVE

Marathon Power LLC 302 Main Street Paterson, NJ 07505	888-779-7255 www.mecny.com	R/C/I ACTIVE
Metromedia Energy, Inc. 6 Industrial Way Eatontown, NJ 07724	1-877-750-7046 www.metromediaenergy.com	C/I ACTIVE
Metro Energy Group, LLC 14 Washington Place Hackensack, NJ 07601	888-53-Metro www.metroenergy.com	R/C ACTIVE
MPower Energy NJ LLC One University Plaza, Suite 507 Hackensack, NJ 07601	877-286-7693 www.mpowerenergy.com	R/C/I ACTIVE
NATGASCO (Supreme Energy, Inc.) 532 Freeman Street Orange, NJ 07050	800-840-4427 www.supremeenergyinc.com	R/C/I ACTIVE
New Energy Services LLC 101 Neptune Avenue Deal, New Jersey 07723	800-660-3643 www.newenergyservicesllc.com	R/C/I ACTIVE
New Jersey Gas & Electric 10 North Park Place Suite 420 Morristown, NJ 07960	866-568-0290 www.njgande.com	R/C ACTIVE
Noble Americas Energy Solutions The Mac-Cali Building 581 Main Street, 8th fl. Woodbridge, NJ 07095	877-273-6772 www.noblesolutions.com	C/I ACTIVE
North American Power & Gas, LLC d/b/a North American Power 197 Route 18 South Ste. 300 New Brunswick, NJ 08816	888- 313-8086 www.napower.com	R/C/I ACTIVE
North Eastern States, Inc. d/b/a Entrust Energy 90 Washington Valley Road Bedminster, NJ 07921	(888) 521-5861 www.entrustenergy.com	R/C/I ACTIVE
Oasis Power, LLC d/b/a Oasis Energy 11152 Westheimer, Suite 901 Houston, TX 77042	(800)324-3046 www.oasisenergy.com	R/C ACTIVE

Palmco Energy NJ, LLC One Greentree Centre 10,000 Lincoln Drive East, Suite 201 Marlton, NJ 08053	877-726-5862 www.PalmcoEnergy.com	R/C/I ACTIVE
Plymouth Rock Energy, LLC 338 Maitland Avenue Teaneck, NJ 07666	855-32-POWER (76937) www.plymouthenergy.com	R/C/I ACTIVE
PPL EnergyPlus, LLC Shrewsbury Executive Offices 788 Shrewsbury Avenue Suite 2200 Tinton Falls, NJ 07724	(732) 741-0505 www.pplenergyplus.com	C/I ACTIVE
Public Power & Utility of New Jersey, LLC One International Blvd, Suite 400 Mahwah, NJ 07495	(888) 354-4415 www.ppandu.com	R/C/I ACTIVE
Residents Energy, LLC 550 Broad Street Newark, NJ 07102	(888) 828-7374 www.residentsenergy.com	R/C
Respond Power LLC 1001 East Lawn Drive Teaneck, NJ 07666	(877) 973-7763 www.respondpower.com	R/C/I ACTIVE
Save on Energy, LLC 1101 Red Ventures Drive Fort Mill, SC 29707	1 (877) 658-3183 www.saveonenergy.com	R/C ACTIVE
SFE Energy One Gateway Center Suite 2600 Newark, NJ 07012	1 (877) 316-6344 www.sfeenergy.com	R/C/I ACTIVE
S.J. Energy Partners, Inc. 208 White Horse Pike, Suite 4 Barrington, NJ 08007	(800) 695-0666 www.sjnaturalgas.com	C ACTIVE
Star Energy Partners, LLC CEO Corporate Center 1812 Front Street Scotch Plains, NJ 07076	(855) 427-7827 www.starenergypartners.com	R/C/I
South Jersey Energy Company 1 South Jersey Plaza, Route 54	800-266-6020 www.southjerseyenergy.com	R/C/I ACTIVE

Folsom, NJ 08037		
SouthStar Energy d/b/a New Jersey Energy 1085 Morris Avenue, Suite 155 Union, NJ 07083	(866) 477-8823 www.newjerseyenergy.com	R/C ACTIVE
Spark Energy Gas, LP/ Spark Energy 2105 City West Blvd. Suite 100 Houston, TX 77042	(713)600-2600 www.sparkenergy.com	R/C/I ACTIVE
Sperian Energy Corp. Bridgewater Center 1200 Route 22 East Bridgewater, NJ 08807	888-682-8082 www.sperianenergy.com	R/C/I ACTIVE
Sprague Energy Corp. 12 Ridge Road Chatham Township, NJ 07928	855-466-2842 www.spragueenergy.com	C/I ACTIVE
Stuyvesant Energy LLC 10 West Ivy Lane, Suite 4 Englewood, NJ 07631	800-640-6457 www.stuyfuel.com	C ACTIVE
Stream Energy New Jersey, LLC 309 Fellowship Road Suite 200 Mt. Laurel, NJ 08054	(877) 369-8150 www.streamenergy.net	R/C ACTIVE
Summit Energy Services, Inc. 10350 Ormsby Park Place Suite 400 Louisville, KY 40223	1 (800) 90-SUMMIT www.summitenergy.com	C/I ACTIVE
Systrum Energy 1 Bergen Blvd. Fairview, NJ 07022	877-797-8786 www.systrumenergy.com	R/C/I ACTIVE
Talen Energy Marketing, LLC 788 Shrewsbury Avenue, Suite 2178 Tinton Falls, NJ 07724	(888) 289-7693 www.pplenergyplus.com/*	R/C
Tiger Natural Gas, Inc. dba Tiger, Inc. 234 20th Avenue Brick, NJ 008724	888-875-6122 www.tignaturalgas.com	R/C/I ACTIVE

UGI Energy Services, Inc. dba UGI Energy Link 224 Strawbridge Drive, Suite 107 Moorestown, NJ 08057	800-427-8545 www.ugienergylink.com	C/I ACTIVE
UGI Energy Services, Inc. d/b/a GASMAR 224 Strawbridge Drive, Suite 107 Moorestown, NJ 08057	856-273-9995 www.ugienergylink.com	C/I ACTIVE
Verde Energy USA, Inc. 2001 Route 46 Waterview Plaza, Suite 301 Parsippany, NJ 07054	800-388-3862 www.lowcostpower.com	R/C ACTIVE
Viridian Energy PA LLC 2001 Route 46, Waterview Plaza Suite 230 Parsippany, NJ 07054	866-663-2508 www.viridian.com	R/C ACTIVE
Vista Energy Marketing, L.P. 197 State Route 18 South, Suite 3000 South Wing East Brunswick, NJ 08816	888-508-4782 www.vistaenergymarketing.com	R/C/I ACTIVE
Woodruff Energy 73 Water Street PO Box 777 Bridgeton, NJ 08302	800-557-1121 www.woodruffenergy.com	R/C/I ACTIVE
Woodruff Energy US LLC 73 Water Street P.O. Box 777 Bridgeton, NJ 08302	800-457-1121 www.woodruffenergy.com	C/I ACTIVE
XOOM Energy New Jersey, LLC 744 Broad Street. 16th Floor Newark, NJ 07102	888-997-8979 www.xoomenergy.com	R/C/I ACTIVE
Your Energy Holdings, LLC One International Boulevard Suite 400 Mahwah, NJ 07495-0400	855-732-2493 www.thisisyourenergy.com	R/C/I ACTIVE

[Back to main supplier information page](#)

APPENDIX B

Equipment Inventory

CHA Project # 30993
City of East Orange
Soverel Park

Description	QTY	Manufacturer Name	Model No.	Serial No.	Equipment Type/ Utility	Capacity/Size /Efficiency	Efficiency	Location	Areas/Equipment Served	Date Installed	Remaining Useful Life (years)	Other Info.	Current year	Years Old	ASHRAE life expectancy
DHW Heater	1	Rheem	81VP6S	R	DHW Heater	2kW	100%	Bathroom	Garage	1990	-6		2016	26	20
Boiler	1	Weil-McLain	A/B-800-5	3	fired by fuel oil#2 HHW Boiler	175MBH heating input	~80%	Field House MR	Field House	1960	-36		2016	56	20
Furnace	1	UTC	LBO145	N/A	Oil Fired furnace	140MBH energy input and 112MBH energy output	~80%	Garage	Garage	1960	-36		2016	56	20
HHW Pump Motor	1	Bell&Gossett	N/A	N/A	pump	1/6HP	N/A	Field House MR	Field House	1950	-46	name plate faded	2016	66	20
DHW Heater	1	Rheem	81VP6S	R	DHW Heater	2kW	100%	Bathroom	Field House	1990	-6		2016	26	20

Cost of Electricity:

\$0.330	\$/kWh
\$8.00	\$/kW

EXISTING CONDITIONS												Retrofit Control
Field Code	Area Description Unique description of the location - Room number/Room name: Floor number (if applicable)	Usage Describe Usage Type using Operating Hours	No. of Fixtures No. of fixtures before the retrofit	Standard Fixture Code Lighting Fixture Code	Fixture Code Code from Table of Standard Fixture Wattages	Watts per Fixture Value from Table of Standard Fixture Wattages	kW/Space (Watts/Fixt) * (Fixt No.)	Exist Control Pre-inst. control device	Annual Hours Estimated annual hours for the usage group	Annual kWh (kW/space) * (Annual Hours)	Retrofit control device	
41LED	Main entrance	Hallways	1	1B 40 R F 2 (MAG)	F42SS	94	0.09	SW	8736	821	NONE	
64LED	Main Area	Multi Purpose	6	175 MH	MH175/1	215	1.29	SW	480	619	C-OCC	
41LED	Main Area	Multi Purpose	2	1B 40 R F 2 (MAG)	F42SS	94	0.19	SW	480	90	C-OCC	
41LED	Storage	Storage Areas	3	1B 40 R F 2 (MAG)	F42SS	94	0.28	SW	480	135	C-OCC	
41LED	Restroom	Restroom	1	1B 40 R F 2 (MAG)	F42SS	94	0.09	SW	480	45	C-OCC	
41LED	Restroom	Restroom	2	1B 40 R F 2 (MAG)	F42SS	94	0.19	SW	480	90	C-OCC	
71LED	Power Room	Mechanical Room	1	I 60	I60/1	60	0.06	SW	480	29	NONE	
41LED	Restroom	Restroom	1	1B 40 R F 2 (MAG)	F42SS	94	0.09	SW	480	45	C-OCC	
41LED	Restroom	Restroom	2	1B 40 R F 2 (MAG)	F42SS	94	0.19	SW	480	90	C-OCC	
146LED	Outdoor Pole light	Outdoor Lighting	50	High Bay MH 400	MH400/1	458	22.90	Breaker	3276	75,020	NONE	
185LED	Garage	Garage	2	T 40 R F 4 (ELE)	F44SE	172	0.34	SW	1920	660	NONE	
41LED	Garage	Garage	2	1B 40 R F 2 (MAG)	F42SS	94	0.19	SW	1920	361	NONE	
41LED	Garage	Garage	4	1B 40 R F 2 (MAG)	F42SS	94	0.38	SW	1920	722	NONE	
185LED	Garage	Garage	1	T 40 R F 4 (ELE)	F44SE	172	0.17	SW	1920	330	NONE	
71LED	Restroom	Restroom	1	I 60	I60/1	60	0.06	SW	480	29	C-OCC	
71LED	Storage	Storage Areas	1	I 60	I60/1	60	0.06	SW	480	29	C-OCC	
Total			80				26.58			79,117		


APPENDIX C

ECM Calculations

EXISTING CONDITIONS										RETROFIT CONDITIONS								COST & SAVINGS ANALYSIS						
Field Code	Area Description Unique description of the location - Room number/Room name: Floor number (if applicable)	No. of Fixtures before the retrofit	Standard Fixture Code	Fixture Code Code from Table of Standard Fixture Wattages	Watts per Fixture Value from Table of Standard Fixture Wattages	kW/Space (Watts/Fixt) * (Fixt No.)	Exist Control Pre-inst. control device	Annual Hours Estimated daily hours for the usage group	Annual kWh (kW/Space) * (Annual Hours)	Number of Fixtures No. of fixtures after the retrofit	Standard Fixture Code	Fixture Code Code from Table of Standard Fixture Wattages	Watts per Fixture Value from Table of Standard Fixture Wattages	kW/Space (Watts/Fixt) *	Retrofit Control device	Annual Hours Estimated annual hours for the usage group	Annual kWh (kW/Space) * (Annual Hours)	Annual kWh Saved (Original Annual kWh) - (Retrofit Annual kWh)	Annual kW Saved (Original Annual kW) - (Retrofit Annual kW)	Annual \$ Saved (kWh Saved) *	Retrofit Cost Cost for renovations to lighting system	NJ Smart Start Lighting Incentive Prescriptive Lighting Measures	Simple Payback With Out Incentive Length of time for renovations cost to be recovered	Simple Payback Length of time for renovations cost to be recovered
41LED	Main entrance	1	1B 40 R F 2 (MAG)	F42SS	94	0.1	SW	8736	821	1	STLED4	STLED4	40	0.0	NONE	8,736	349	472	0.1	\$ 160.86	\$ 356.70	\$ -	2.2	2.2
64LED	Main Area	6	175 MH	MH175/1	215	1.3	SW	480	619	6	BAYLED78W	BAYLED78W	93	0.6	C-OCC	336	187	432	0.7	\$ 212.74	\$ 5,200.17	\$ 620	24.4	21.5
41LED	Main Area	2	1B 40 R F 2 (MAG)	F42SS	94	0.2	SW	480	90	2	STLED4	STLED4	40	0.1	C-OCC	336	27	63	0.1	\$ 31.28	\$ 848.40	\$ 20	27.1	26.5
41LED	Storage	3	1B 40 R F 2 (MAG)	F42SS	94	0.3	SW	480	135	3	STLED4	STLED4	40	0.1	C-OCC	336	40	95	0.2	\$ 46.92	\$ 1,205.10	\$ 20	25.7	25.3
41LED	Restroom	1	1B 40 R F 2 (MAG)	F42SS	94	0.1	SW	480	45	1	STLED4	STLED4	40	0.0	C-OCC	336	13	32	0.1	\$ 15.64	\$ 491.70	\$ 20	31.4	30.2
41LED	Restroom	2	1B 40 R F 2 (MAG)	F42SS	94	0.2	SW	480	90	2	STLED4	STLED4	40	0.1	C-OCC	336	27	63	0.1	\$ 31.28	\$ 848.40	\$ 20	27.1	26.5
71LED	Power Room	1	I 60	I60/1	60	0.1	SW	480	29	1	LED15W	LED15W	15	0.0	NONE	480	7	22	0.0	\$ 11.45	\$ 6.75	\$ -	0.6	0.6
41LED	Restroom	1	1B 40 R F 2 (MAG)	F42SS	94	0.1	SW	480	45	1	STLED4	STLED4	40	0.0	C-OCC	336	13	32	0.1	\$ 15.64	\$ 491.70	\$ 20	31.4	30.2
41LED	Restroom	2	1B 40 R F 2 (MAG)	F42SS	94	0.2	SW	480	90	2	STLED4	STLED4	40	0.1	C-OCC	336	27	63	0.1	\$ 31.28	\$ 848.40	\$ 20	27.1	26.5
146LED	Outdoor Pole ligh	50	High Bay MH 400	MH400/1	458	22.9	Breaker	3276	75,020	50	BAYLED78W	BAYLED78W	93	4.7	NONE	3,276	15,233	59,797	18.3	\$ 21,481.71	\$ 42,209.78	\$ 5,000	2.0	1.7
185LED	Garage	2	T 40 R F 4 (ELE)	F44SE	172	0.3	SW	1920	660	2	T 50 R LED	RTLED50	50	0.1	NONE	1,920	192	468	0.2	\$ 178.02	\$ 472.50	\$ 50	2.7	2.4
41LED	Garage	2	1B 40 R F 2 (MAG)	F42SS	94	0.2	SW	1920	361	2	STLED4	STLED4	40	0.1	NONE	1,920	154	207	0.1	\$ 78.80	\$ 713.40	\$ -	9.1	9.1
41LED	Garage	4	1B 40 R F 2 (MAG)	F42SS	94	0.4	SW	1920	722	4	STLED4	STLED4	40	0.2	NONE	1,920	307	415	0.2	\$ 157.59	\$ 1,426.80	\$ -	9.1	9.1
185LED	Garage	1	T 40 R F 4 (ELE)	F44SE	172	0.2	SW	1920	336	1	T 50 R LED	RTLED50	50	0.1	NONE	1,920	96	89.01	0.1	\$ 236.25	\$ 236.25	\$ 25	2.7	2.4
71LED	Restroom	1	I 60	I60/1	60	0.1	SW	480	29	1	LED15W	LED15W	15	0.0	C-OCC	336	5	24	0.0	\$ 12.16	\$ 141.75	\$ 20	11.7	10.0
71LED	Storage	1	I 60	I60/1	60	0.1	SW	480	29	1	LED15W	LED15W	15	0.0	C-OCC	336	5	24	0.0	\$ 12.16	\$ 141.75	\$ 20	11.7	10.0
S	Total	80				26.6			79,117	80			6.1				16,684		20.5	22,567	55,640	\$5,855		
S																		Demand Savings	20.5		\$1,964			
S																		kWh Savings		62,433	\$20,603			
S																		Total Savings			\$22,567		2.5	2.2

City of East Orange
CHA Project Number: 30993
Soverel Park

	Existing Conditions	Post Recommended ECMs	Percent Savings
Costs (\$)	55,364	32,660	41%
Electricity (kWh)	107,340	44,907	58%
Oil (gallon)	5,000	4,939	1%
Site EUI (kbtu/SF/Yr)	162.4	121.3	



City of East Orange
CHA Project Number: 30993

Rate of Discount (used for NPV) 3.0%

Utility Costs		Yearly Usage	Metric Ton Carbon Dioxide Equivalent	Building Area	Annual Utility Cost		
\$ 0.410	\$/kWh blended		0.000420205		Electric	Natural Gas	Fuel Oil
\$ 0.330	\$/kWh supply	107,340	0.000420205	5,334	\$ 44,064	\$ -	\$ 11,300
\$ 8.00	\$/kW	118.8	0				
	\$/Therm		0.00533471				
\$ 5.00	\$/kgals		0				
\$ 2.26	\$/Gal	5,000					

water

Soverel Park																							
Recommend?		Item	Savings					Cost	Simple Payback	Life Expectancy	GHG Reduction (Metric tons)	NJ Smart Start Incentives	Direct Install Eligible (Y/N)	Payback w/ Incentives	Simple Projected Lifetime Savings					ROI	NPV	IRR	
Y or N			kW	kWh	therms	No. 2 Oil gal	Water kgal	\$							kW	kWh	therms	kgal/yr	\$				
Y	ECM-1	Replace Single Pane Windows with Double Pane Windows	0.0	0	0	61	0	137	\$ 6,800	49.7	15	0.0	\$ -	N	49.7	0.0	0	0	0	\$ -	(1.0)	(\$5,167)	-12.2%
N	ECM-2	Replace the Old Boiler with a High Efficiency Boiler	0.0	0	0	45	0	102	\$ 35,406	346.9	25	0.0	\$ -	N	346.9	0.0	0	0	0	\$ -	(1.0)	(\$33,628)	-14.6%
N	ECM-3	Replace the Old Furnace with High Efficiency Furnace	0.0	0	0	37	0	84	\$ 30,257	362.3	15	0.0	\$ -	N	362.3	0.0	0	0	0	\$ -	(1.0)	(\$29,260)	-26.2%
N	ECM-4	Replace Old Plumbing Fixtures with Low Flow Plumbing Fixtures	0.0	0	0	4	9	52	\$ 21,987	419.9	10	0.0	\$ -	N	419.9	0.0	0	0	85	\$ 426	(1.0)	(\$21,540)	#NUM!
Y	ECM-L1	Lighting Replacements with Controls (Occupancy Sensors)	20.5	62,433	0	0	0	22,567	55,640	2.5	10	26.2	\$ 5,855	N	2.2	204.6	624,330	0	0	\$ 275,617	4.0	\$142,717	44.2%
Total			20.5	62,433	0	147	9	\$ 22,942	\$ 150,089	6.5	15.0	26	\$ 5,855		6.3	205	624,330	-	85	\$ 276,042	0.8	53,121	13.5%
Recommended Measures (highlighted green above)			20.5	62,433	0	61	0	\$ 22,704	\$ 62,440	2.8	12.5	26	\$ 5,855	0	2.5	205	624,330	-	-	\$ 275,617	3.4	137,550	39.4%
% of Existing			17%	58%	0%	1%	0%																

City:			Newark, NJ				
Occupied Hours/Week			168				
			Building	Auditorium	Gymnasium	Library	Classrooms
			Operating	Occupied	Occupied	Occupied	Occupied
Temp	Enthalpy h (Btu/lb)	Bin Hours	Hours	Hours	Hours	Hours	Hours
102.5							
97.5	35.4	6	6	0	0	0	0
92.5	37.4	31	31	0	0	0	0
87.5	35.0	131	131	0	0	0	0
82.5	33.0	500	500	0	0	0	0
77.5	31.5	620	620	0	0	0	0
72.5	29.9	664	664	0	0	0	0
67.5	27.2	854	854	0	0	0	0
62.5	24.0	927	927	0	0	0	0
57.5	20.3	600	600	0	0	0	0
52.5	18.2	730	730	0	0	0	0
47.5	16.0	491	491	0	0	0	0
42.5	14.5	656	656	0	0	0	0
37.5	12.5	1,023	1,023	0	0	0	0
32.5	10.5	734	734	0	0	0	0
27.5	8.7	334	334	0	0	0	0
22.5	7.0	252	252	0	0	0	0
17.5	5.4	125	125	0	0	0	0
12.5	3.7	47	47	0	0	0	0
7.5	2.1	34	34	0	0	0	0
2.5	1.3	1	1	0	0	0	0
-2.5							
-7.5							

Multipliers	
Material:	1.027
Labor:	1.246
Equipment:	1.124

Heating System Efficiency	78%
Cooling Eff (kW/ton)	1.2



Heating		
Hours	9,454	Hrs
Weighted Avg	2	F
Avg	25	F

Cooling		
Hours	4,333	Hrs
Weighted Avg	68	F
Avg	78	F

Utility End Use Analysis		
Electricity Use (kWh):		Notes/Comments:
107,340	Total	Based on utility analysis
80,000	Lighting	From Lighting Calculations
10,000	Motors	Estimated
10,000	DHW Heating	Estimated
6,340	Plug Load	Estimated
Fuel Oil (Gallons):		Notes/Comments:
1,414	Total	Based on utility analysis
778	Boilers	
636	Furnace	

75%
9%
9%
6%

55%
45%



City of East Orange
CHA Project Number: 30993
Soverel Park

Note: pricing is for energy calculations only -do not use for procurement

ECM-1 Replace Single Pane Windows with Double Pane Windows

Existing: The windows in this building are still single pane windows which needs to be upgraded to reduce heating load
Proposed: Replace single pane windows with double pane windows

Linear Feet of Windows	80.0 LF	Cooling System Efficiency	0 kW/ton	Heating System Efficiency	78%
Area of Windows	48.0 SF	Ex Occupied Cng Temp.	74 °F	Heating On Temp.	55 °F
Existing Infiltration Factor	0.30 cfm/LF	Ex Unoccupied Cng Temp.	80 °F	Ex Occupied Htg Temp.	70 °F
Proposed Infiltration Factor	0.15 cfm/LF	Cooling Occ Enthalpy Setpoint	27.5 Btu/lb	Ex Unoccupied Htg Temp.	65 °F
Existing U Value	1.13 Btuh/SF°F	Cooling Unocc Enthalpy Setpoint	27.5 Btu/lb	Electricity	\$ 0.410 \$/kWh
Proposed U Value	0.50 Btuh/SF°F			Natural Gas	\$ - \$/therm

					EXISTING LOADS		PROPOSED LOADS		COOLING ENERGY		HEATING ENERGY	
					Occupied	Unoccupied	Occupied	Unoccupied	Existing	Proposed	Existing Heating	Proposed
Avg Outdoor Air Temp. Bins °F	Avg Outdoor Air Enthalpy	Existing Equipment Bin Hours	Occupied Equipment Bin Hours	Unoccupied Equipment Bin Hours	Panel Infiltration & Heat Load BTUH	Panel Infiltration & Heat Load BTUH	Panel Infiltration & Heat Load BTUH	Panel Infiltration & Heat Load BTUH	Cooling Energy kWh	Cooling Energy kWh	Energy Therms	Energy Therms
A		B	C	D	E	F	G	H	I	J	K	L
102.5	50.1	0	0	0	-3,987	-3,661	-1,904	-1,760	0	0	0	0
97.5	42.5	6	2	4	-2,895	-2,569	-1,374	-1,230	0	0	0	0
92.5	39.5	45	16	29	-2,299	-1,974	-1,092	-948	0	0	0	0
87.5	36.6	146	52	94	-1,715	-1,390	-815	-671	0	0	0	0
82.5	34.0	298	106	192	-1,163	-838	-555	-411	0	0	0	0
77.5	31.6	476	170	306	-633	0	-305	0	0	0	0	0
72.5	29.2	662	237	426	0	0	0	0	0	0	0	0
67.5	27.0	740	264	476	0	0	0	0	0	0	0	0
62.5	24.5	765	273	492	0	0	0	0	0	0	0	0
57.5	21.4	733	262	471	0	0	0	0	0	0	0	0
52.5	18.7	668	239	430	1,403	1,002	647	462	0	0	10	5
47.5	16.2	659	235	424	1,804	1,403	832	647	0	0	13	6
42.5	14.4	685	245	441	2,204	1,804	1,016	832	0	0	17	8
37.5	12.6	739	264	475	2,605	2,204	1,201	1,016	0	0	22	10
32.5	10.7	717	256	461	3,006	2,605	1,386	1,201	0	0	25	12
27.5	8.6	543	194	349	3,407	3,006	1,571	1,386	0	0	22	10
22.5	6.8	318	114	205	3,808	3,407	1,756	1,571	0	0	14	7
17.5	5.5	245	88	158	4,208	3,808	1,940	1,756	0	0	12	6
12.5	4.1	156	56	100	4,609	4,208	2,125	1,940	0	0	9	4
7.5	2.6	92	33	59	5,010	4,609	2,310	2,125	0	0	6	3
2.5	1.0	36	13	23	5,411	5,010	2,495	2,310	0	0	2	1
-2.5	0.0	19	7	12	5,812	5,411	2,680	2,495	0	0	1	1
-7.5	-1.5	8	3	5	6,212	5,812	2,864	2,680	0	0	1	0
TOTALS		8,760	3,129	5,631					0	0	155	71

Existing Panel Infiltration	24 cfm	Savings	61 Gallon		\$ 137
Existing Panel Heat Transfer	54 Btuh/°F		0 kWh		\$ -
Proposed Panel Infiltration	12 cfm				\$ 137
Proposed Panel Heat Transfer	24 Btuh/°F				

Panel ID	Location	Quantity	Width (ft)	Height (ft)	Linear Feet (LF)	Area (SF)	Infiltration Rate (CFM/LF)	U Value (Btuh/SF/°F)	Infiltration (CFM)	Heat Transfer (Btuh/°F)
1	whole building	8	3	2	80.0	48.0	0.3	1.13	24.0	54.2
Total		8	3	2	80	48	0.30	1.13	24.0	54.2

*the number of the windows suitable for replacement is estimated based on facility staff and field observation. The final counts should be conducted by the window contractor for the actual replacement amount

ECM-1 Replace Single Pane Windows with Double Pane Windows - Cost

Multipliers	
Material:	1.10
Labor:	1.35
Equipment:	1.10

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
Window Replacement	48	sqft	\$ 65	\$ 40	\$ -	\$ 3,120	\$ 1,920	\$ -	\$ 5,040	Vendor Est per SF

Cost estimated are for Energy Savings only- do not use for procurement

\$ 5,040	Subtotal
\$ 1,764	35% Contingency
\$ 6,800	Total

City of East Orange
CHA Project Number: 30993
Soverel Park

ECM-2 Replace the Old Boiler with a High Efficiency Boiler

Description: This ECM evaluates replacing the existing boiler with a high efficiency boiler.

Item	Value	Units	Formula/Comments
Baseline Fuel Cost	\$ -	/ Therm	Natural Gas
Baseline Fuel Cost	\$ 2.26	/ Gal	No. 2 Oil
FORMULA CONSTANTS			
Oversize Factor	0.8		
Hours per Day	24		
Infrared Conversion Factor	1.0		1.0 if Boiler, 0.8 if Infrared Heater
EXISTING			
Capacity	62,967	btu/hr	Estimated Boiler Load % and Capacity
Heating Combustion Efficiency	78%		Estimated averaged Efficiency
Heating Degree-Day	2,783	Degree-day	
Design Temperature Difference	57	F	
Fuel Conversion	100,000	btu/therm	
PROPOSED			
Capacity	62,967	btu/hr	
Efficiency	85%		
SAVINGS			
Fuel Savings	45	Gallon	NJ Protocols Calculation
Fuel Cost Savings	\$ 102		

City of East Orange
CHA Project Number: 30993
Soverel Park

ECM-2 Replace the Old Boiler with a High Efficiency Boiler-Cost

Multipliers	
Material:	1.03
Labor:	1.25
Equipment:	1.12

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
600 MBH NG Condensing Boiler	1	EA	\$ 16,500	\$ 3,800		\$ 16,946	\$ 4,735	\$ -	\$ 21,680	Vendor Estimate
Flue Installation	1	LS	\$ 500.0	\$ 500.0		\$ 514	\$ 623	\$ -	\$ 1,137	Estimated
controls	1	EA	\$ 500.0	\$ 500.0		\$ 514	\$ 623	\$ -	\$ 1,137	Estimated
Miscellaneous Electrical	1	LS	\$ 500.0	\$ 500.0		\$ 514	\$ 623	\$ -	\$ 1,137	Estimated
Miscellaneous HW Piping	1	LS	\$ 500.0	\$ 500.0		\$ 514	\$ 623	\$ -	\$ 1,137	Estimated
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

\$ 26,226	Subtotal
\$ 9,179	35% Contingency
\$ 35,406	Total

City of East Orange
CHA Project Number: 30993
Soverel Park

ECM-3 Replace the Old Furnace with High Efficiency Furnace

Description: This ECM evaluates replacing the existing boiler with a high efficiency boiler.

Item	Value	Units	Formula/Comments
Baseline Fuel Cost	\$ -	/ Therm	Natural Gas
Baseline Fuel Cost	\$ 2.26	/ Gal	No. 2 Oil
FORMULA CONSTANTS			
Oversize Factor	0.8		
Hours per Day	24		
Infrared Conversion Factor	1.0		1.0 if Boiler, 0.8 if Infrared Heater
EXISTING			
Capacity	51,519	btu/hr	Estimated Boiler Load % and Capacity
Heating Combustion Efficiency	78%		Estimated averaged Efficiency
Heating Degree-Day	2,783	Degree-day	
Design Temperature Difference	57	F	
Fuel Conversion	100,000	btu/therm	
PROPOSED			
Capacity	51,519	btu/hr	
Efficiency	85%		
SAVINGS			
Fuel Savings	37	Gallon	NJ Protocols Calculation
Fuel Cost Savings	\$ 84		

Savings calculation formulas are taken from NJ Protocols document for Occupancy Controlled Thermostats

Algorithms

Gas Savings (Therms)

$$= \frac{OF \times ((CAPY_{Bi} \times EFF_Q) - (CAPY_{Qi} \times EFF_B \times ICF)) \times HDD_{mod} \times 24}{\Delta T \times HC_{fuel} \times EFF_B \times ICF \times EFF_Q}$$

Definition of Variables

OF = Oversize factor of standard boiler or furnace (OF=0.8)

CAPY_{Bi} = Total input capacity of the baseline furnace, boiler or heater in Btu/hour

CAPY_{Qi} = Total input capacity of the qualifying furnace, boiler or heater in Btu/hour

HDD_{mod} = HDD by zone and building type

24 = Hours/Day

ΔT = design temperature difference

HC_{fuel} = Conversion from Btu to therms of gas or gallons of oil or propane (100,000 btu/therm; 138,700 btu/gal of #2 oil; 92,000 btu/gal of propane)

EFF_Q = Efficiency of qualifying heater(s) (AFUE %)

EFF_B = Efficiency of baseline heaters (AFUE %)

ICF = Infrared Compensation Factor (ICF = 0.8 for IR Heaters, 1.0 for furnaces/boilers)²

Furnaces and Boilers

Component	Type	Value	Source
AFUE _q	Variable		Application
AFUE _b	Fixed	Furnaces: 78% Boilers: 80% Infrared: 78%	EPACT Standard for furnaces and boilers
CAPY _{in}	Variable		Application
ΔT	Variable	See Table Below	1
HDD _{mod}	Fixed	See Table Below	1

Sources:

1. KEMA, *Smartstart Program Protocol Review*. 2009.
2. http://www.spaceray.com/1_space-ray_faqs.php

Adjusted Heating Degree Days by Building Type

Building Type	Heating Energy Density (kBtu/sf)	Degree Day Adjustment Factor	Atlantic City (HDD)	Newark (HDD)	Philadelphia (HDD)	Monticello (HDD)
Education	29.5	0.55	2792	2783	2655	3886
Food Sales	35.6	0.66	3369	3359	3204	4689
Food Service	39.0	0.73	3691	3680	3510	5137
Health Care	53.6	1.00	5073	5057	4824	7060
Lodging	15.0	0.28	1420	1415	1350	1976
Retail	29.3	0.55	2773	2764	2637	3859
Office	28.1	0.52	2660	2651	2529	3701
Public Assembly	33.8	0.63	3199	3189	3042	4452
Public Order/Safety	24.1	0.45	2281	2274	2169	3174
Religious Worship	29.1	0.54	2754	2745	2619	3833
Service	47.8	0.89	4524	4510	4302	6296
Warehouse/Storage	20.2	0.38	1912	1906	1818	2661

Heating Degree Days and Outdoor Design Temperature by Zone

Weather Station	HDD	Outdoor Design Temperature (F)
Atlantic City	5073	13
Newark	5057	14
Philadelphia, PA	4824	15
Monticello, NY	7060	8

City of East Orange
CHA Project Number: 30993
Soverel Park

ECM-3 Replace the Old Furnace with High Efficiency Furnace-Cost

Multipliers	
Material:	1.03
Labor:	1.25
Equipment:	1.12

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
Oil fired Condensing Furnace	1	EA	\$ 15,000	\$ 3,800		\$ 15,405	\$ 4,735	\$ -	\$ 20,140	Estimated
Flue Installation	1	LS	\$ 500.0	\$ 500.0		\$ 514	\$ 623	\$ -	\$ 1,137	Estimated
Miscellaneous Electrical	1	LS	\$ 500.0	\$ 500.0		\$ 514	\$ 623	\$ -	\$ 1,137	Estimated
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

\$ 22,413	Subtotal
\$ 7,844	35% Contingency
\$ 30,257	Total

City of East Orange
 CHA Project Number: 30993
 Soverel Park

ECM: Replace urinals and flush valves with low flow

Description: This ECM evaluates the water savings associated with replacing/ upgrading urinals with 0.125 GPF urinals and or flush valves.

EXISTING CONDITIONS		
Cost of Water / 1000 Gallons	\$5.00	\$ / kGal
Urinals in Building to be replaced	2	
Average Flushes / Urinal (per Day)	2	
Average Gallons / Flush	1.5	Gal

PROPOSED CONDITIONS		
Proposed Urinals to be Replaced	2	
Proposed Gallons / Flush	0.125	Gal
Proposed Material Cost of new urinal & valve	\$1,200	RS Means 2012
Proposed Installation Cost of new urinal & valve	\$1,000	RS Means 2012
Total cost of new urinals & valves		

SAVINGS		
Current Urinal Water Use	2.19	kGal / year
Proposed Urinal Water Use	0.18	kGal / year
Water Savings	2.01	kGal / year
Cost Savings	\$10	/ year

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

City of East Orange
CHA Project Number: 30993
Soverel Park

ECM: Replace toilets and flush valves with low flow

Description: This ECM evaluates the water savings associated with repalcing/
upgrading toilets to 1.28 GPF fixtures and/or flush valves.

EXISTING CONDITIONS		
Cost of Water / 1000 Gallons	\$5.00	\$ / kGal
Toilets in Building	3	
Average Flushes / Toilet (per Day)	2	
Average Gallons / Flush	3.5	Gal

PROPOSED CONDITIONS		
Proposed Toilets to be Replaced	3	
Proposed Gallons / Flush	1.28	Gal

SAVINGS		
Current Toilet Water Use	7.67	kGal / year
Proposed Toilet Water Use	2.80	kGal / year
Water Savings	4.86	kGal / year
Cost Savings	\$24	/ year

City of East Orange
CHA Project Number: 30993
Soverel Park

ECM: Replace faucets and shower with low flow

Description; This ECM evaluates the water savings resulting from replacing/ upgrading faucets to 0.5 gallon per minute flow

EXISTING CONDITIONS		
Cost of Water / 1000 Gallons	\$5.00	\$ / kGal
Faucets in Building	3	
Average Uses / Faucet (per day)	1	# Uses
Average Time of Use	60.0	seconds
Average Flowrate	2.0	gpm

PROPOSED CONDITIONS		
Proposed Faucets to be Replaced	3	
Proposed Flowrate	0.5	gpm

HEATING SAVINGS		
Fuel Cost	\$ -	/kWh
Number of Faucets	3	
Hours per Day of Usage	0.0	hrs
Days per Year of Facility Usage	365	days
Average Flowrate	2.0	gpm
Proposed Flowrate	0.5	gpm
Heat Content of Water	8.33	Btu/gal/F
Temperature Difference (Intake and Output)	35	F
Water Heating Equipment Efficiency	80%	
Conversion Factor	100,000	Btu/Therm
SAVINGS		
Current Faucet Water Use	2.19	kGal / year
Proposed Faucet Water Use	0.55	kGal / year
Water Savings	1.64	kGal / year
Heating Savings	4	Gallon of Oil
Cost Savings	\$8	/ year

Savings calculation formulas are taken from NJ Protocols document for Faucet

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

City of East Orange
CHA Project Number: 30993
Soverel Park

#REF!

Multipliers	
Material:	1.03
Labor:	1.25
Equipment:	1.12

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
									\$ -	
Low-Flow Urinal	2	EA	\$ 1,200	\$ 1,000	\$ -	\$ 2,465	\$ 2,492	\$ -	\$ 4,957	Vendor Estimate
Low-Flow Toilet	3	EA	\$ 1,400	\$ 1,000	\$ -	\$ 4,313	\$ 3,738	\$ -	\$ 8,051	Vendor Estimate
Low-Flow Faucet	3	EA	\$ 700	\$ 300	\$ -	\$ 2,157	\$ 1,121	\$ -	\$ 3,278	Vendor Estimate
						\$ -	\$ -	\$ -	\$ -	

\$ 16,286	Subtotal
\$ 5,700	35% Contingency
\$ 21,987	Total

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

City of East Orange
CHA Project Number: 30993
Soverel Park

New Jersey Pay For Performance Incentive Program

Note: The following calculation is based on the New Jersey Pay For Performance Incentive Program per April, 2012.
Building must have a minimum average electric demand of 200 kW and minimum area of building is 50,000 ft to be most cost-effective for commercial and industrial buildings. However, multifamily buildings with peak demand over 100kW are still eligible. Market manager has the discretion to approve applications that fall below 200kW minimum.

At a minimum, all recommended measures were used for this calculation. To qualify for P4P incentives, the following P4P requirements must be met:

- At least 15% source energy savings
- No more than 50% savings from lighting measures
- up to 70% of lighting savings may be considered but performance target will increase by 1% for each percent over 50%
- Scope should includes two or more unique measures
- Project has at least a 10% internal rate of return
- At least 50% of the source energy savings must come from investor-owned electricity and/or natural gas (note: exemption for fuel conversions)

Incentive #1		
Audit is funded by NJ BPU	\$0.05	\$/sqft
Total Building Area (Square Feet)	5,334	
Is this audit funded by NJ BPU (Y/N)	Yes	

Board of Public Utilites (BPU)

	Annual Utilities	
	kWh	Therms
Existing Cost (from utility)	\$44,064	\$0
Existing Usage (from utility)	107,340	0
Proposed Savings	62,433	0
Existing Total MMBtus	366	
Proposed Savings MMBtus	213	
% Energy Reduction	58.2%	
Proposed Annual Savings	\$22,704	

	Min (Savings = 15%)		Increase (Savings > 15%)		Max Incentive		Achieved Incentive	
	\$/kWh	\$/therm	\$/kWh	\$/therm	\$/kWh	\$/therm	\$/kWh	\$/therm
Incentive #2	\$0.09	\$0.90	\$0.005	\$0.05	\$0.11	\$1.25	\$0.11	\$1.25
Incentive #3	\$0.09	\$0.90	\$0.005	\$0.05	\$0.11	\$1.25	\$0.11	\$1.25

	Incentives \$		
	Elec	Gas	Total
Incentive #1	\$0	\$0	\$5,000
Incentive #2	\$6,868	\$0	\$6,868
Incentive #3	\$6,868	\$0	\$6,868
Total All Incentives	\$13,735	\$0	\$18,735

Total Project Cost	\$62,440
--------------------	----------

		Allowable Incentive
% Incentives #1 of Utility Cost*	11.3%	\$5,000
% Incentives #2 of Project Cost**	11.0%	\$6,868
% Incentives #3 of Project Cost**	11.0%	\$6,868
Total Eligible Incentives***	\$18,735	
Project Cost w/ Incentives	\$43,705	

Project Payback (years)	
w/o Incentives	w/ Incentives
2.8	1.9

* Maximum allowable incentive is 50% of annual utility cost if not funded by NJ BPU, and %25 if LGEA is funded by NJBPU.
** Maximum allowable amount of Incentive #2 is 50% of total project cost.
**Maximum allowable amount of Incentive #3 is 50% of total project cost.
*** Maximum allowable amount of Incentive #1 is \$50,000 if not funded by NJ BPU, and \$25,000 if it is.
Maximum allowable amount of Incentive #2 & #3 is \$1 million per gas account and \$1 million per electric account; maximum 2 million per project

APPENDIX E

Photos



Existing windows



Existing plumbing fixtures



Existing Boiler



Existing furnace

APPENDIX F

EPA Benchmarking Report



ENERGY STAR[®] Statement of Energy Performance

N/A

Soverel Park

Primary Property Type: Other - Entertainment/Public Assembly
Gross Floor Area (ft²): 5,334
Built: 1960

ENERGY STAR[®]
Score¹

For Year Ending: October 31, 2014
Date Generated: April 20, 2016

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information

Property Address

Soverel Park
110 North Park Street
East Orange, New Jersey 07017

Property Owner

,
(____)____-____

Primary Contact

,
(____)____-____

Property ID: 4940289

Energy Consumption and Energy Use Intensity (EUI)

Site EUI

105.3 kBtu/ft²

Annual Energy by Fuel

Electric - Grid (kBtu) 366,244 (65%)
Fuel Oil (No. 2) (kBtu) 195,164 (35%)

National Median Comparison

National Median Site EUI (kBtu/ft²) 35.5
National Median Source EUI (kBtu/ft²) 85.1
% Diff from National Median Source EUI 197%

Source EUI

252.6 kBtu/ft²

Annual Emissions

Greenhouse Gas Emissions (Metric Tons CO₂e/year) 64

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: _____ Date: _____

Licensed Professional

,
(____)____-____



Professional Engineer Stamp
(if applicable)