

**BERGEN COUNTY  
WILLIAMS CENTER FOR THE ARTS**

**15 SYLVAN ST  
RUTHERFORD, NJ, 07070**

**FACILITY ENERGY REPORT**

## TABLE OF CONTENTS

I.	HISTORIC ENERGY CONSUMPTION/COST.....	2
II.	FACILITY DESCRIPTION .....	7
III.	MAJOR EQUIPMENT LIST .....	9
IV.	ENERGY CONSERVATION MEASURES.....	10
V.	ADDITIONAL RECOMMENDATIONS .....	37

Appendix A – ECM Cost & Savings Breakdown

Appendix B – New Jersey Smart Start<sup>®</sup> Program Incentives

Appendix C – Portfolio Manager “Statement of Energy Performance”

Appendix D – Major Equipment List

Appendix E – Investment Grade Lighting Audit

Appendix F – Renewable / Distributed Energy Measures Calculations

**I. HISTORIC ENERGY CONSUMPTION/COST**

The energy usage for the facility has been tabulated and plotted in graph form as depicted within this section. Each energy source has been identified and monthly consumption and cost noted per the information provided by the Owner.

Electric Utility Provider:	Public Service Electric & Gas
Electric Utility Rate Structure:	General Lighting & Power (GLP)
Third Party Supplier:	None

Natural Gas Utility Provider:	Public Service Electric & Gas
Utility Rate Structure:	Large Volume Gas (LVG)
Third Party Supplier:	None


The electric usage profile represents the actual electrical usage for the facility. The electric utility measures consumption in kilowatt-hours (KWH) and maximum demand in kilowatts (KW). One KWH usage is equivalent to 1000 watts running for one hour. One KW of electric demand is equivalent to 1000 watts running at any given time. The basic usage charges are shown as generation service and delivery charges along with several non-utility generation charges. Rates used in this report reflect the historical data received for the facility.

The gas usage profile within each facility report shows the actual natural gas energy usage for the facility. The gas utility measures consumption in cubic feet x 100 (CCF), and converts the quantity into Therms of energy. One Therm is equivalent to 100,000 BTUs of energy.

**Table 1**  
**Electricity Billing Data**

<b>ELECTRIC USAGE SUMMARY</b>			
Utility Provider: PSE&G Rate: GLP Meter No: 278003797, 778013328 Account # 67 528 602 03, 66 369 000 08 Third Party Utility Provider: None TPS Meter / Acct No: -			
<b>MONTH OF USE</b>	<b>CONSUMPTION KWH</b>	<b>DEMAND</b>	<b>TOTAL BILL</b>
Mar-10	30,480	152.2	\$5,160
Apr-10	27,810	185.8	\$5,028
May-10	28,760	161.6	\$5,346
Jun-10	40,090	279.3	\$8,401
Jul-10	53,250	220.6	\$10,588
Aug-10	59,230	224.0	\$11,565
Sep-10	56,150	185.5	\$10,445
Oct-10	45,430	172.4	\$7,593
Nov-10	56,430	216.1	\$10,155
Dec-10	35,640	106.6	\$5,607
Jan-11	31,370	104.9	\$5,183
Feb-11	32,380	113.1	\$5,564
<b>Totals</b>	<b>497,020</b>	<b>279.3</b> <b>Max</b>	<b>\$90,635</b>
<p align="center"> <b>AVERAGE DEMAND      176.8 KW average</b>  <b>AVERAGE RATE      \$0.182    \$/kWh</b> </p>			


**Figure 1**  
**Electricity Usage Profile**



**Table 2**  
**Natural Gas Billing Data**

<b>NATURAL GAS USAGE SUMMARY</b>		
Utility Provider: PSE&G Rate: LVG Meter No: 3499913 Point of Delivery ID: 66 369 000 08 Third Party Utility Provider: None TPS Meter No: -		
<b>MONTH OF USE</b>	<b>CONSUMPTION (THERMS)</b>	<b>TOTAL BILL</b>
Mar-10	2,746.57	\$2,823.47
Apr-10	890.56	\$914.61
May-10	311.70	\$319.18
Jun-10	3.04	\$3.10
Jul-10	0.00	\$0.00
Aug-10	0.00	\$0.00
Sep-10	92.09	\$94.49
Oct-10	972.53	\$997.82
Nov-10	2,751.63	\$2,814.92
Dec-10	6,389.77	\$6,523.95
Jan-11	6,065.93	\$6,199.38
Feb-11	5,726.91	\$5,870.08
<b>TOTALS</b>	<b>25,950.72</b>	<b>\$26,560.98</b>
<b>AVERAGE RATE:</b>	<b>\$1.02</b>	<b>\$/THERM</b>

**Figure 2**  
**Natural Gas Usage Profile**



## II. FACILITY DESCRIPTION

The 39144 SF William Center for the Arts is a three story facility comprised of a live stage, four (4) movie theatres, administrative offices, concession area, bathrooms, mechanical rooms and storage areas.

The center opens everyday at 9:00 AM. On weekdays the movie theaters operate during the evening between the hours of 6:00 PM and 9 PM. On weekends the movie theatres operate day and night sessions with the last one ending at 11:30 PM. In addition, the live stage is used occasionally for various events including a church gathering on Sunday mornings.

Exterior walls of the facility are brick construction. The amount of insulation within the wall is unknown. The facility consists of a glass atrium which houses the lobby and the ticketing area. The atrium is comprised of single pane tinted windows with metal frames. The atrium windows are in very poor condition with several cracks and leaks. There are minimal amount of windows in the rest of the facility.

The main structure has a fairly new slightly pitched built-up roof with asphalt shingle covering. The amount of insulation below the roofing is unknown. The facility was originally built in 1920s. In 1970, the building suffered severe fire damage and it was rebuilt. Finally, in 2009 new HVAC units were installed.

The capacities of the William Center theaters are as follows:

Theatre #1:	192 People
Theatre #2:	90 People
Theatre #3:	60 People
Theatre #4:	125 People
Live Stage:	641 People (+200 Standing)

### HVAC Systems

The central heating system consists of two (2) Paterson Kelley 1900 series water tube, gas fired, standard hot water boilers with a total input capacity of 3,800 MBH. The boilers produce heating hot water for the air handling units. The boiler water is pumped throughout the facility by two (2) constant volume 10 HP base mounted end suction pumps (one operating / one standby) made by Taco. The pumps are coupled with standard efficiency motors.

The central cooling system consists of a 200-ton air cooled, standard efficiency, packaged water chiller made by TRANE. The chiller was installed during the recent renovation in performed in 2009 and it appears to be in excellent condition. Chilled water is distributed throughout the building to the air handling units via two (2) constant volume 20 HP base mounted end suction pumps. The pumps are driven by high efficiency motors made by Baldor.

The air side systems include air handling units feeding the theatres, concession area, offices, projector rooms and lobby. The air handling units provide heating and cooling to the building year round. All of the air handling units utilize 2-way control valves for both the heating and



cooling coils. Ventilation air for the theatres is provided by outside air dampers at each air handling unit.

The air handling units AC#1-5 feeding the concession area, theatres #1, 2 and 2A are pre-existing McQuay units before the 2009 renovation. In addition, a larger air handling unit, AC-14 made by Trane feeds the Newman Theatre. Each unit is equipped with hot and chilled water coils, constant volume supply fans and standard efficiency motors. The units are in good condition.

The air handling units AC#6, 7 and 8 feeding the offices, theater #3, mezzanine and the lobby are new units installed during the 2009 renovation. These units are suspended in the ceiling of the third floor mechanical room. Similarly, these units are constant volume units with hot and chilled water coils for primary air heating and cooling.

### Exhaust System

Air is exhausted from the toilet rooms, boiler rooms and projector rooms through the roof exhausters. The exhaust fans are operated based on the facility occupancy schedule.

### HVAC System Controls

The HVAC system includes a central control system made by Honeywell. The system integrates into the majority of the equipment including boilers, chillers, pumps and air handling units. The system includes all electronic controls for actuators and control valves. The front end controller has the capability to monitor and control all schedules, thermostat temperatures and set points. The control system also automates the night time temperature setback based on occupancy schedules.

### Domestic Hot Water

Domestic hot water for the stage restrooms is provided by a 40 gallon Rheem electric hot water heater with 4500 Watts of heating capacity. The domestic hot water piping insulation appeared to be in good condition.

### Lighting

The lighting throughout the Williams Center is provided with variety of lighting technologies including outdated fixtures with T12 lamps, newer fixtures with T8 lamps, incandescent lamps and high intensity discharge lights such as quartz lights in the main assembly area.

### III. MAJOR EQUIPMENT LIST

The equipment list contains major energy consuming equipment that through implementation of energy conservation measures could yield substantial energy savings. The list shows the major equipment in the facility and all pertinent information utilized in energy savings calculations. An approximate age was assigned to the equipment in some cases if a manufactures date was not shown on the equipment's nameplate. The ASHRAE service life for the equipment along with the remaining useful life is also shown in the Appendix.

Refer to the **Major Equipment List Appendix** for this facility.

#### IV. ENERGY CONSERVATION MEASURES

Energy Conservation Measures are developed specifically for this facility. The energy savings and calculations are highly dependent on the information received from the site survey and interviews with operations personnel. The assumptions and calculations should be reviewed by the owner to ensure accurate representation of this facility. The following ECMs were analyzed:

**Table 3**  
**ECM Financial Summary**

<b>ENERGY CONSERVATION MEASURES (ECM's)</b>					
<b>ECM NO.</b>	<b>DESCRIPTION</b>	<b>NET INSTALLATION COST<sup>A</sup></b>	<b>ANNUAL SAVINGS<sup>B</sup></b>	<b>SIMPLE PAYBACK (Yrs)</b>	<b>SIMPLE LIFETIME ROI</b>
ECM #1	Lighting Equipment Upgrade	\$13,787	\$8,644	1.6	840.5%
ECM #2	Lighting Controls Upgrade	\$3,570	\$1,912	1.9	703.2%
ECM #3	Premium Efficiency Motors	\$10,768	\$597	18.1	-16.9%
ECM #4	Variable Frequency Drives on Pump Motors	\$33,550	\$5,249	6.4	212.9%
ECM #5	Window Replacement	\$133,500	\$3,265	40.9	-63.3%
ECM #6	Demand Controlled Ventilation	\$128,000	\$9,191	13.9	7.7%
<b>RENEWABLE ENERGY MEASURES (REM's)</b>					
<b>ECM NO.</b>	<b>DESCRIPTION</b>	<b>NET INSTALLATION COST</b>	<b>ANNUAL SAVINGS</b>	<b>SIMPLE PAYBACK (Yrs)</b>	<b>SIMPLE LIFETIME ROI</b>
REM #1	Solar Photovoltaic System	\$101,430	\$7,546	13.4	11.6%

**Notes:** A. Cost takes into consideration applicable NJ Smart Start<sup>TM</sup> incentives.

B. Savings takes into consideration applicable maintenance savings.

**Table 4**  
**ECM Energy Summary**

<b>ENERGY CONSERVATION MEASURES (ECM's)</b>				
<b>ECM NO.</b>	<b>DESCRIPTION</b>	<b>ANNUAL UTILITY REDUCTION</b>		
		<b>ELECTRIC DEMAND (KW)</b>	<b>ELECTRIC CONSUMPTION (KWH)</b>	<b>NATURAL GAS (THERMS)</b>
ECM #1	Lighting Equipment Upgrade	19.3	45,722	0
ECM #2	Lighting Controls Upgrade	0	10,504	0
ECM #3	Premium Efficiency Motors	0.8	3,509	0
ECM #4	Variable Frequency Drives on Pump Motors	0	45,969	0
ECM #5	Window Replacement	1.7	4,747	2,354
ECM #6	Demand Controlled Ventilation	0	24,485	4,642
<b>RENEWABLE ENERGY MEASURES (REM's)</b>				
<b>ECM NO.</b>	<b>DESCRIPTION</b>	<b>ANNUAL UTILITY REDUCTION</b>		
		<b>ELECTRIC DEMAND (KW)</b>	<b>ELECTRIC CONSUMPTION (KWH)</b>	<b>NATURAL GAS (THERMS)</b>
REM #1	Solar Photovoltaic System	11.3	14,185	0

**Table 5**  
**Facility Project Summary**

<b>ENERGY SAVINGS IMPROVEMENT PROGRAM - POTENTIAL PROJECT</b>					
<b>ENERGY CONSERVATION MEASURES</b>	<b>ANNUAL ENERGY SAVINGS (\$)</b>	<b>PROJECT COST (\$)</b>	<b>SMART START INCENTIVES</b>	<b>CUSTOMER COST</b>	<b>SIMPLE PAYBACK</b>
Lighting Equipment Upgrade	\$8,644	\$15,837	\$2,050	\$13,787	1.6
Lighting Controls Upgrade	\$1,912	\$3,750	\$180	\$3,570	1.9
Premium Efficiency Motors	\$597	\$11,163	\$395	\$10,768	18.1
Variable Frequency Drives on Pump Motors	\$5,249	\$34,000	\$450	\$33,550	6.4
Window Replacement	\$3,265	\$133,500	\$0	\$133,500	40.9
Demand Controlled Ventilation	\$9,191	\$128,000	\$0	\$128,000	13.9
<i>Design / Construction Extras (15%)</i>		<i>\$48,938</i>		<i>\$48,938</i>	
<b>Total Project</b>	<b>\$28,857</b>	<b>\$375,188</b>	<b>\$2,500</b>	<b>\$372,113</b>	<b>12.9</b>

Design / Construction Extras is shown as an additional cost for the facility project summary. This cost is included to estimate the costs associated with construction management fees for a larger combined project.

## **ECM #1: Lighting Equipment Upgrade**

### **Description:**

The lighting throughout the Williams Center is provided with variety of lighting technologies including outdated fixtures with T12 lamps, newer fixtures with T8 lamps, incandescent lamps and high intensity discharge lights such as quartz lights in the main assembly area.

This ECM includes re-lamping and re-ballasting of the existing T12 fluorescent fixtures and 700 series fluorescent T8 fixtures with 800 series, 28W T8 lamps. The new, energy efficient fixtures with supersaver T8 lamps will provide adequate lighting and will save on electrical costs due to better performance of the lamp and ballasts. This ECM also includes maintenance savings through the reduced number of lamps replaced per year. The expected lamp life of a T8 lamp is approximately 30,000 burn-hours, in comparison to the existing T12 lamps which is approximately 20,000 burn-hours. The facility will need approximately 33% less lamps replaced per year for each one for one fixture replaced.

The ECM also includes replacement of any incandescent lamps with compact fluorescent lamps. Compact fluorescent lamps (CFL's) were designed to be direct replacements for the standard incandescent lamps which are common to table lamps, spot lights, hi-hats, bathroom vanity lighting, etc. The energy usage of an incandescent lamp compared to a compact fluorescent lamp is approximately 3 to 4 times greater. In addition to the energy savings, compact fluorescent fixtures burn-hours are 8 to 15 times longer than incandescent fixtures ranging from 6,000 to 15,000 burn-hours compared to incandescent fixtures ranging from 750 to 1000 burn-hours. However, the maintenance savings due to reduced lamp replacement is offset by the higher cost of the CFL's compared to the incandescent lamps.

This ECM also includes replacement of some of the dimmable incandescent bulbs to LED bulbs. Self contained LED fixtures with dimmable power supplies provide controllable light with four times less energy use. LED bulbs are available in a variety of temperatures to produce different light colors. In addition to the energy savings, dimmable LED bulbs burn-hours are approximately 24 times longer than incandescent fixtures.

### **Energy Savings Calculations:**

The **Investment Grade Lighting Audit Appendix** outlines the hours of operation, proposed retrofits, costs, savings, and payback periods for each set of fixtures in the each building.

**Rebates and Incentives:**

NJ Smart Start<sup>®</sup> Program Incentives are calculated using the **Smart Start<sup>®</sup> Incentive Appendix** as follows:

Retrofit of T-12 fixtures to T-5 or T-8 with electric ballasts	\$10 per fixture (1-4 lamp retrofits)
---	---------------------------------------

$$\text{Smart Start}^{\circledR} \text{ Incentive} = (\# \text{ of fixtures} \times \$10) = 44 \times \$10 = \$440$$

LED Screw-based & Pin-based (PAR, MR, BR, R) Standards (A-Style) and Decorative (globe, candelabra, etc.) Lamps	\$20 per lamp
---	---------------

$$\text{Smart Start}^{\circledR} \text{ Incentive} = (\# \text{ of lamps} \times \$20) = 63 \times \$20 = \$1260$$

\$50 per HID ( $\geq 100\text{w}$ ) fixture retrofitted with induction lamp	\$50 per HID ( $\geq 100\text{w}$ ) fixture retrofitted with induction lamp, power coupler and generator.
--	--

$$\text{Smart Start}^{\circledR} \text{ Incentive} = (\# \text{ of fixture} \times \$50) = 7 \times \$50 = \$350$$

Replacement and Maintenance Savings are calculated as follows:

Due to replacing T12 lamps with T8s

$$\text{Savings} = (\text{reduction in T8 lamps replaced per year}) \times (\text{repacment \$ per lamp} + \text{Labor \$ per lamp})$$

$$\text{Savings} = 2.91 \times (\$2 \text{ per lamp} + \$5 \text{ per lamp}) = \$20$$

Due to replacing incandescent lamps with LEDs

$$\text{Savings} = (\text{reduction in lamps replaced per year}) \times (\text{repacment \$ per lamp} + \text{Labor \$ per lamp})$$

$$\text{Savings} = 60.48 \times (\$2 \text{ per lamp} + \$3 \text{ per lamp}) = \$302$$

**Energy Savings Summary:**

<b>ECM #1 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$15,837
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$2,050
<b>Net Installation Cost (\$):</b>	\$13,787
<b>Maintenance Savings (\$/Yr):</b>	\$323
<b>Energy Savings (\$/Yr):</b>	\$8,321
<b>Total Yearly Savings (\$/Yr):</b>	\$8,644
<b>Estimated ECM Lifetime (Yr):</b>	15
<b>Simple Payback</b>	1.6
<b>Simple Lifetime ROI</b>	840.5%
<b>Simple Lifetime Maintenance Savings</b>	\$4,841
<b>Simple Lifetime Savings</b>	\$129,661
<b>Internal Rate of Return (IRR)</b>	63%
<b>Net Present Value (NPV)</b>	\$89,405.50



## ECM #2: Lighting Controls Upgrade – Occupancy Sensors

### Description:

Some of the lights in this facility are left on unnecessarily. In many cases the lights are left on because of the inconvenience to manually switch lights off when a room is left or on when a room is first occupied. This is common in rooms that are occupied for only short periods and only a few times per day. In some instances lights are left on due to the misconception that it is better to keep the lights on rather than to continuously switch lights on and off. Although increased switching reduces lamp life, the energy savings outweigh the lamp replacement costs. The payback timeframe for when to turn the lights off is approximately two minutes. If the lights are expected to be off for at least a two minute interval, then it pays to shut them off.

Lighting controls come in many forms. Sometimes an additional switch is adequate to provide reduced lighting levels when full light output is not needed. Occupancy sensors detect motion and will switch the lights on when the room is occupied. Occupancy sensors can either be mounted in place of a current wall switch, or on the ceiling to cover large areas.

The U.S. Department of Energy sponsored a study to analyze energy savings achieved through various types of building system controls. The referenced savings is based on the “Advanced Sensors and Controls for Building Applications: Market Assessment and Potential R&D Pathways,” document posted for public use April 2005. The study has found that commercial buildings have the potential to achieve significant energy savings through the use of building controls. The average energy savings are as follows based on the report:

- Occupancy Sensors for Lighting Control                      20% - 28% energy savings.

Savings resulting from the implementation of this ECM for energy management controls are estimated to be 25% of the total light energy controlled by occupancy sensors and daylight sensors (The majority of the savings is expected to be after school hours when rooms are left with lights on)

This ECM includes installation of ceiling or switch mount sensors for individual offices, classrooms, large bathrooms, and libraries. Sensors shall be manufactured by Sensorswitch, Watt Stopper or equivalent. The **Investment Grade Lighting Audit Appendix** of this report includes the summary of lighting controls implemented in this ECM and outlines the proposed controls, costs, savings, and payback periods. The calculations adjust the lighting power usage by the applicable percent savings for each area that includes lighting controls.

### Energy Savings Calculations:

$$\text{Energy Savings} = (\% \text{ Savings} \times \text{Controlled Light Energy (kWh/Yr)})$$

$$\text{Savings} = \text{Energy Savings (kWh)} \times \text{Ave Elec Cost} \left( \frac{\$}{\text{kWh}} \right)$$

**Cost and Incentives:**

Installation cost per dual-technology sensors (Basis: Sensor switch or equivalent) are as follows:

Dual Technology Occupancy Sensor - Switch Mount	\$125 per installation
Dual Technology Occupancy Sensor - Remote Mount	\$450 per installation
Dual Tech. Occupancy Sensor w/2 Pole Relay - Remote Mount	\$500 per installation
Daylight Sensor (Sensor switch PP-20 & CM-PC or equal)	\$400 per installation

Cost includes material and labor.

From the **NJ Smart Start® Program Incentives Appendix**, the installation of a lighting control device warrants the following incentive:

Occupancy Sensor Fixture Mounted (existing facility only) = \$20 per sensor

Occupancy Sensor Remote Mounted (existing facility only) = \$35 per sensor

Smart Start® Incentive = (# of wall mount × \$ 20) + (# of ceiling mount × \$35)

Smart Start® Incentive = (2 wall mount × \$ 20) + (4 ceiling mount × \$35) = \$180

**Energy Savings Summary:**

<b>ECM #2 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$3,750
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$180
<b>Net Installation Cost (\$):</b>	\$3,570
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$1,912
<b>Total Yearly Savings (\$/Yr):</b>	\$1,912
<b>Estimated ECM Lifetime (Yr):</b>	15
<b>Simple Payback</b>	1.9
<b>Simple Lifetime ROI</b>	703.2%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$28,676
<b>Internal Rate of Return (IRR)</b>	53%
<b>Net Present Value (NPV)</b>	\$19,251.91

### ECM #3: Install NEMA Premium® Efficiency Motors

#### Description:

The improved efficiency of the NEMA Premium® efficient motors is primarily due to better designs with use of better materials to reduce losses. Surprisingly, the electricity used to power a motor represents 95 % of its total lifetime operating cost. Because many motors operate continuously 24 hours a day, even small increases in efficiency can yield substantial energy and dollar savings.

The electric motors driving the air handling unit supply fan motors are the candidates for replacing with premium efficiency motors. These standard efficiency motors run considerable amount of time over a year.

This energy conservation measure replaces existing electric motors over 5 HP or more with NEMA Premium® efficiency motors. NEMA Premium® is the most efficient motor designation in the marketplace today.

IMPLEMENTATION SUMMARY					
EQMT ID	FUNCTION	MOTOR HP	HOURS OF OPERATION	EXISTING EFFICIENCY	NEMA PREMIUM EFFICIENCY
AC-1	Supply Fan Motor *	5	4,380	87.5%	90.2%
AC-2	Supply Fan Motor *	5	4,380	87.5%	90.2%
AC-7	Supply Fan Motor *	5	4,380	87.5%	90.2%
AC-8	Supply Fan Motor *	7.5	4,380	89.5%	91.7%
AC-14	Supply Fan Motor *	20	4,380	91.0%	93.0%
* Motor efficiency N/A. Estimated based on EPA Act of 1992					

#### Energy Savings Calculations:

$$\text{Electric usage, kWh} = \frac{\text{HP} \times \text{LF} \times 0.746 \times \text{Hours of Operation}}{\text{Motor Efficiency}}$$

where, HP = Motor Nameplate Horsepower Rating

LF = Load Factor

Motor Efficiency = Motor Nameplate Efficiency

$$\text{Electric Usage Savings, kWh} = \text{Electric Usage}_{\text{Existing}} - \text{Electric Usage}_{\text{Proposed}}$$

$$\text{Electric Usage Savings, kWh} = \text{Electric Usage}_{\text{Existing}} - \text{Electric Usage}_{\text{Proposed}}$$

$$\text{Electric cost savings} = \text{Electric Usage Savings} \times \text{Electric Rate} \left( \frac{\$}{\text{kWh}} \right)$$

The calculations were carried out and the results are tabulated in the table below:

<b>PREMIUM EFFICIENCY MOTOR CALCULATIONS</b>							
<b>EQMT ID</b>	<b>MOTOR HP</b>	<b>LOAD FACTOR</b>	<b>EXISTING EFFICIENCY</b>	<b>NEMA PREMIUM EFFICIENCY</b>	<b>POWER SAVINGS kW</b>	<b>ENERGY SAVINGS kWh</b>	<b>COST SAVINGS</b>
AC-1	5	90%	87.5%	90.2%	0.11	506	\$86
AC-2	5	90%	87.5%	90.2%	0.11	506	\$86
AC-7	5	90%	87.5%	90.2%	0.11	506	\$86
AC-8	7.5	90%	89.5%	91.7%	0.13	594	\$101
AC-14	20	90%	91.0%	93.0%	0.32	1,397	\$238
<b>TOTAL</b>					<b>0.8</b>	<b>3,509</b>	<b>\$597</b>

### Equipment Cost and Incentives

Below is a summary of SmartStart Building® incentives for premium efficiency motors on chilled water pumps:

<b>INCENTIVES</b>	
<b>HORSE POWER</b>	<b>NJ SMART START INCENTIVE</b>
5	\$60
7.5	\$90
10	\$100
15	\$115
20	\$125
25	\$130

The following table outlines the summary of motor replacement costs and incentives:

<b>MOTOR REPLACEMENT SUMMARY</b>						
<b>EQMT ID</b>	<b>MOTOR POWER HP</b>	<b>INSTALLED COST</b>	<b>SMART START INCENTIVE</b>	<b>NET COST</b>	<b>TOTAL SAVINGS</b>	<b>SIMPLE PAYBACK</b>
AC-1	5	\$1,519	\$60	\$1,459	\$86	17.0
AC-2	5	\$1,519	\$60	\$1,459	\$86	17.0
AC-7	5	\$1,519	\$60	\$1,459	\$86	17.0
AC-8	7.5	\$1,971	\$90	\$1,881	\$101	18.6
AC-14	20	\$4,635	\$125	\$4,510	\$238	19.0
<b>TOTAL</b>	<b>Totals:</b>	<b>\$11,163</b>	<b>\$395</b>	<b>\$10,768</b>	<b>\$597</b>	<b>18.1</b>

**Energy Savings Summary:**

<b>ECM #3 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$11,163
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$395
<b>Net Installation Cost (\$):</b>	\$10,768
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$597
<b>Total Yearly Savings (\$/Yr):</b>	\$597
<b>Estimated ECM Lifetime (Yr):</b>	15
<b>Simple Payback</b>	18.1
<b>Simple Lifetime ROI</b>	-16.9%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$8,948
<b>Internal Rate of Return (IRR)</b>	-2%
<b>Net Present Value (NPV)</b>	(\$3,646.91)

## ECM #4: Install VFDs and Premium Efficiency Motors for Pumps

### Description:

The air handling units in this facility utilize a constant speed pumping design. The air handling units have 2-way control valves which allow variable amount of flow through the piping loop. As a result the pumping head and the energy vary as the load in the building changes.

2-way control valves provide flow through the heat exchanger equipment only when there is a call for heating or cooling, unlike 3-way control valves that allow constant flow of the water loop. 3-way control valves require full pumping energy continuously, while 2-way control valves allow the system to reduce flow when it is not needed. Variable frequency drives allow the pumps to slow down in response to a reduction in overall system flow. The reduction in operating flow allows the pumps to reduce energy consumption for all hours that the heating system is not at its peak load.

This ECM includes the installation of Variable Frequency Drives on the existing hot water and chilled water pumps without any modifications to the piping. The VFD's would be controlled by a differential pressure sensor in each water loop to measure demand for water. The furthest air handling unit from the loop pumps would remain as 3-way control valves (constant flow) to eliminate dead heading potential. In addition, a minimum flow amount should be set based on air cooled chiller unloading capability.

This ECM also includes replacement of the existing pump motors with inverter duty motors that meet NEMA Premium Efficiency Standard, which also helps to reduce energy consumption.

Energy and cost savings calculations are based on calculation software "PumpSave v4.2," provided by ABB. The PumpSave calculation software is used to estimate the pumping energy for variable speed pump systems. The hot and chilled water loop pump operations are estimated to be 4,380 Hrs per year since each system is used for about 6 months total. The pump flow, HD, and resultant energy are calculated based on the existing pump horse power installed.

### Energy Savings Calculations:

$$\text{Cons. Volume Power (HP)} = \frac{\text{Specific Gravity} \times \text{Flow Rate} \left( \frac{\text{Gal}}{\text{min}} \right) \times \text{Head (Ft)}}{3960 \times \text{Pump Efficiency}(\%) \times \text{Motor Efficiency}(\%)}$$

$$\text{Energy Cons. (kWh)} = \text{Power (HP)} \times 0.746 \left( \frac{\text{KW}}{\text{HP}} \right) \times \text{Operation (Hrs.)}$$

$$\text{Energy Cost} = \text{Energy Usage (kWh)} \times \text{Ave Electric Cost} \left( \frac{\$}{\text{kWh}} \right)$$

Chilled Water VFD Pumping Energy:

**PumpSave 4.2 Energy saving calculator for pumps**

**System Data**  
Liquid density: 62 lb/ft³ Static head: 1 ft

**Pump Data**  
Nominal volume flow: 440 gpm Efficiency: 80%  
Nominal head: 115 ft Max head: 200 ft

**Existing Flow Control**  
Throttling control

**Motor and Supply Data**  
Supply voltage: 460 V 440/460/480 V  
Motor power: 20 Hp Required motor power: 17.6 Hp including 10% safety margin  
Motor efficiency: 93.0 % ?

**Operating Profile**  
Annual running time: 4,320 h

**Measurement Units**  
Metric US

Calculated by: E.G.  
Calculated for: Chilled water pumps  
Pump ID: #1, 2

Improved Control by ABB Drive :  
ACS550  
ACS550-U1-031A-4 Copy to clipboard

**Energy Consumption**  
Bar chart showing Energy Consumed (kWh) for Throttling and VSD. Throttling is approximately 55,000 kWh, and VSD is approximately 25,000 kWh.

**Results**  
Saving percentage: 53.8 %  
Annual energy consumption:  
with existing control method: 55 MWh  
with improved control method: 25 MWh  
Annual energy saving: 29 MWh  
Annual CO<sub>2</sub> reduction: 15 t  
CO<sub>2</sub> emission/unit: 0.5 lb/kWh

**Economic Data**  
Currency unit: \$  
Energy price: 0 \$/kWh  
Investment cost: 0 \$  
Interest rate: 4%  
Service life: 10 years

**Economic Results**  
Annual saving: \$  
Payback period: 0.0 years  
Net present value: \$

**Power (kW)**  
Line graph showing Power (kW) vs Flow rate (gpm) for Throttling and VSD. Throttling is a straight line, while VSD is a curve that increases with flow rate.

**Flow (gpm)**  
Bar chart showing Flow (gpm) for various percentages of flow. The y-axis ranges from 80.0 to 440.0 gpm. The x-axis shows percentages from 0% to 100%.

100

Auto-adjust screen size Save calculation Send to default printer Close program

**ABB**

<b>CHILLED WATER PUMPS VFD CALULATION</b>			
<b>ECM INPUTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>ECM INPUTS</b>	CV Pumps	VFD Pumps	
<b>Flow Control</b>	Throttling Valves-2Way	VFD	-
<b>Flow* (GPM)</b>	440	440	-
<b>Head* (Ft)</b>	115	115	-
<b>Pump Efficiency (%)</b>	80%	80%	-
<b>Motor Efficiency (%)</b>	91.7%	93.0%	1.3%
<b>Operating Hrs</b>	4320	4320	-
<b>Estimated Power (HP)</b>	17.4	17.2	0.24
<b>Elec Cost (\$/kWh)</b>	0.170	0.170	-
<b>ENERGY SAVINGS CALCULATIONS</b>			
<b>ECM RESULTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>Electric Energy (kWh)</b>	56,133	25,259	30,874
<b>Electric Energy Cost (\$)</b>	\$9,543	\$4,294	\$5,249
<b>COMMENTS:</b>	- VFD pump energy is based on ABB energy savings calculator for pumps, "Pump Save," version 4.2. Flow rate for VFD Pump calculation is summarized in the operating profile shown in the Pump Save output. - Hot water flow & head estimated based on boiler capacity		



## Hot Water VFD Pumping Energy:

**PumpSave 4.2 Energy saving calculator for pumps**

**System Data**  
 Liquid density: 62 lb/ft³ Static head: 1 ft

**Pump Data**  
 Nominal volume flow: 200 gpm Efficiency: 80%  
 Nominal head: 115 ft Max head: 200 ft

**Existing Flow Control**  
 Throttling control

**Motor and Supply Data**  
 Supply voltage: 460 V 440/460/480 V  
 Motor power: 10 Hp Required motor power: 8 Hp including 10% safety margin  
 Motor efficiency: 91.7 %

**Operating Profile**  
 Annual running time: 4,320 h

**Measurement Units**  
 Metric US

**Calculated by:** E.G.  
**Calculated for:** Hot water pumps  
**Pump ID:** #3, 4

**Improved Control by ABB Drive:**  
 ACS550  
 ACS550-U1-015A-4 Copy to clipboard

**Energy Consumption**  
 Energy Consumed (kWh)  
 Throttling: ~25,000 kWh  
 VSD: ~12,000 kWh

**Results**  
 Saving percentage: 53.8 %  
 Annual energy consumption:  
 with existing control method: 25 MWh  
 with improved control method: 12 MWh  
 Annual energy saving: 14 MWh  
 Annual CO<sub>2</sub> reduction: 7 t  
 CO<sub>2</sub> emission/unit: 0.5 lb/kWh

**Economic Data**  
 Currency unit: \$  
 Energy price: 0 \$/kWh  
 Investment cost: 0 \$  
 Interest rate: 4%  
 Service life: 10 years

**Economic Results**  
 Annual saving: \$  
 Payback period: 0.0 years  
 Net present value: \$

**Power (kW)**  
 Flow rate (gpm)  
 Throttling: ~5.5 kW  
 #REF!: ~6.5 kW

**Flow (gpm)**  
 0 20 40  
 2000 1800 1600 1400 1200 1000 800 600 400 200 0

**DEF AULT**  
 5% = 216 h at nom. flow  
 15% = 648 h at 90% flow  
 20% = 864 h at 80% flow  
 30% = 1296 h at 70% flow  
 20% = 864 h at 60% flow  
 10% = 432 h at half flow  
 0% = 0 h at 40% flow  
 0% = 0 h at 30% flow  
 0% = 0 h at 20% flow

100

Auto-adjust screen size Save calculation Send to default printer Close program

**ABB**

HOT WATER PUMPS VFD CALCULATION			
ECM INPUTS	EXISTING	PROPOSED	SAVINGS
ECM INPUTS	CV Pumps	VFD Pumps	
Flow Control	Throttling Valves-2Way	VFD	-
Flow* (GPM)	200	200	-
Head* (Ft)	115	115	-
Pump Efficiency (%)	80%	80%	-
Motor Efficiency (%)	87.5%	91.7%	4.2%
Operating Hrs	4320	4320	-
Estimated Power (HP)	8.3	7.9	0.38
Elec Cost (\$/kWh)	0.170	0.170	-
ENERGY SAVINGS CALCULATIONS			
ECM RESULTS	EXISTING	PROPOSED	SAVINGS
Electric Energy (kWh)	26,740	11,644	15,096
Electric Energy Cost (\$)	\$4,546	\$1,980	\$2,566
COMMENTS:	- VFD pump energy is based on ABB energy savings calculator for pumps, "Pump Save," version 4.2. Flow rate for VFD Pump calculation is summarized in the operating profile shown in the Pump Save output. - Hot water flow & head estimated based on boiler capacity		

Total installation cost for four (4) VFDs and controls is estimated to be \$34,000.

Currently there are no **NJ Smart Start® Program Incentives** for installation of hot water pump Variable Frequency Drives. The incentives are for chilled water pump Frequency Drives over 20HP and above. Therefore, this ECM does not qualify rebates related to Variable Frequency Drives.

Below is a summary of SmartStart Building® incentives for premium efficiency motors for the hot water and chilled water pumps.

<b>INCENTIVES</b>	
<b>HORSE POWER</b>	<b>NJ SMART START INCENTIVE</b>
5	\$60
7.5	\$90
10	\$100
15	\$115
20	\$125
25	\$130

Total incentives = 2 x \$100 + 2 x \$125 = \$450

Below table summarizes the total cost and savings due to implementation of this ECM.

<b>VARIABLE SPEED PUMPING SUMMARY</b>			
<b>ECM RESULTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>Electric Energy (kWh)</b>	82,873	36,903	45,969
<b>Electric Energy Cost (\$)</b>	\$9,543	\$4,294	\$5,249
<b>COMMENTS:</b>			

**Energy Savings Summary:**

<b>ECM #4 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$34,000
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$450
<b>Net Installation Cost (\$):</b>	\$33,550
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$5,249
<b>Total Yearly Savings (\$/Yr):</b>	\$5,249
<b>Estimated ECM Lifetime (Yr):</b>	20
<b>Simple Payback</b>	6.4
<b>Simple Lifetime ROI</b>	212.9%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$104,971
<b>Internal Rate of Return (IRR)</b>	15%
<b>Net Present Value (NPV)</b>	\$44,535.45

## ECM #5: Window Replacement

### Description:

The Williams Center Lobby is enclosed with an architectural glass atrium. The atrium is made up of single pane windows in aluminum frames. The atrium windows are in poor condition with draft issues several water leaks.

The windows account for significant energy use through leakage heat loss and conductive heat loss. The age and condition of the windows contribute to the leakage rate of the building. The single pane construction allows higher thermal (conductive) energy loss. These factors lead to increased energy use in the heating season. The heating loss due to single pane glass is combined with heat loss due to poor seals at each operable window. New double pane windows with low E glazing offer a substantial improvement in thermal performance in the summer months.

This ECM includes the replacement of the glass atrium windows and the older single pane windows in the facility with double pane windows with low emissivity glass. The proposed windows include reduced outside air leakage. In addition the double pane structure will significantly increase the insulation value compared to the existing single pane window structure.

The basis for this ECM is Anderson Windows at \$100 per SF of window installed. Below is a list of areas with older and inefficient windows:

WINDOW REPLACEMENT SUMMARY			
ECM INPUTS	NUMBER OF WINDOWS	SIZE	AREA
Atrium Face	Custom	72'x12'	432
Atrium Face		40.5'x12'	486
Atrium Face		12'x12'	144
Atrium Roof		38'x30'	570
Cinema #4 door	1	7'x4'	28
Other	10	3'x4'	120
<b>TOTAL</b>	<b>11</b>	<b>-</b>	<b>1780</b>

### Energy Savings Calculations:

$$\text{Infiltration} \left( \frac{\text{Ft}^3}{\text{Min.}} \right) = \text{Window Area} (\text{Ft}^2) \times \text{Estimated Infiltration per SF of Window} \left( \frac{\text{CFM}}{\text{Ft}^2} \right)$$

$$\text{Heat Load} \left( \frac{\text{Btu}}{\text{Hr.}} \right) = 1.1 \times \text{Infiltration} \left( \frac{\text{Ft}^3}{\text{Min}} \right) \times \text{Design Temperature Difference} (^\circ\text{F})$$

$$\text{Cooling Load (Ton)} = \text{Infiltration} \left( \frac{\text{Ft}^3}{\text{Min}} \right) \times \frac{1 \text{ Ton Cooling}}{400 \left( \frac{\text{Ft}^3}{\text{Min}} \right)}$$

$$\text{Heating Leakage Energy (Therms)} = \frac{\text{Heat Load} \left( \frac{\text{Btu}}{\text{Hr.}} \right) \times \text{HDD}(\text{Day } ^\circ\text{F}) \times 24 \left( \frac{\text{Hr.}}{\text{Day}} \right) \times (0.60)}{65(^{\circ}\text{F}) \times \text{Fuel Heat Value} \left( \frac{\text{Btu}}{\text{Therms}} \right) \times \text{Heating Efficiency}(\%)}$$

$$\text{Cooling Leakage Energy (kWh)} = \frac{\text{Cooling Load}(\text{Ton}) \times \left( \frac{12,000 \text{ Btu}}{\text{Ton Hr.}} \right) \times \text{Full Load Cooling Hours}}{\frac{1000 \text{ W.h}}{\text{kWh}} \times \text{Cooling Efficiency (EER)}}$$

$$\text{Conductive Energy (Therms)} = \frac{\text{U - Value} \times \text{Area}(\text{Ft}^2) \times \text{HDD}(\text{Day } ^\circ\text{F}) \times 24 \left( \frac{\text{Hr.}}{\text{Day}} \right) \times (0.60)}{65(^{\circ}\text{F}) \times \text{Fuel Heat Value} \left( \frac{\text{Btu}}{\text{Therms}} \right) \times \text{Heating Efficiency}(\%)}$$

$$\text{Heating Energy Cost} = \text{Total Heating Energy}(\text{Therms}) \times \text{Ave Fuel Cost} \left( \frac{\$}{\text{Therms}} \right)$$

$$\text{Cooling Energy Cost} = \text{Total Cooling Energy}(\text{kWh}) \times \text{Ave Fuel Cost} \left( \frac{\$}{\text{kWh}} \right)$$

WINDOW REPLACEMENT CALCULATIONS			
ECM INPUTS	EXISTING	PROPOSED	SAVINGS
<b>Description:</b>	Existing Single Pane Windows	Double Pane Low-E Windows	-
<b>Window (SF)</b>	1,780	1,780	-
<b>U-Value (BTU/HR/SF*°F)</b>	0.8	0.45	0.35
<b>Estimated Infiltration, CFM per SF Window</b>	3	2	-
<b>Total Infiltration, CFM</b>	5340	3560	1,780
<b>Heating System Efficiency (%)</b>	75%	75%	-
<b>Heating Degree Days (HDD)</b>	4,750	4,750	-
<b>Design Day Temp Diff (°F)</b>	65	65	-
<b>Heating Hrs Per Day (Hrs)</b>	24	24	-
<b>Full Load Cooling Hours</b>	800	800	-
<b>Average Cooling Efficiency, EER</b>	9.0	9.0	-
<b>Gas Cost (\$/Therm)</b>	1.02	1.02	-
<b>Electric Cost (\$/kWh)</b>	0.182	0.182	-
<b>Gas Heat Value (BTU/Therm)</b>	100,000	100,000	-
ENERGY SAVINGS CALCULATIONS			
ECM RESULTS	EXISTING	PROPOSED	SAVINGS
<b>Heat Load (BTU/Hr)</b>	381,810	254,540	127,270
<b>Leakage Energy (Therms)</b>	5,357	3,571	1,786
<b>Conductive Energy (Therms)</b>	1,299	731	568
<b>Total Heating Energy (Therms)</b>	6,656	4,302	2,354
<b>Cooling Load (Ton)</b>	13	9	4
<b>Cooling Demand (kW)</b>	5.1	3.4	1.7
<b>Total Cooling Energy (kWh)</b>	14,240	9,493	4,747
<b>Gas Energy Cost (\$)</b>	\$6,789	\$4,388	\$2,401
<b>Electric Energy Cost (\$)</b>	\$2,592	\$1,728	\$864
<b>Comments:</b>	1. Proposed window U-value Based on ASHRAE 90.1 - 2007		

Estimated cost for replacing the inefficient windows at the Williams Center for the Arts is \$133,500.

**Energy Savings Summary:**

<b>ECM #5 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$133,500
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$0
<b>Net Installation Cost (\$):</b>	\$133,500
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$3,265
<b>Total Yearly Savings (\$/Yr):</b>	\$3,265
<b>Estimated ECM Lifetime (Yr):</b>	15
<b>Simple Payback</b>	40.9
<b>Simple Lifetime ROI</b>	-63.3%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$48,973
<b>Internal Rate of Return (IRR)</b>	-11%
<b>Net Present Value (NPV)</b>	(\$94,524.52)



## ECM #6: Demand Controlled Ventilation

Demand Controlled Ventilation (DCV) is a means to provide active, zone level control of ventilation for spaces within a facility. The basic premise behind DCV is monitoring indoor CO<sub>2</sub> levels versus outdoor CO<sub>2</sub> levels in order to provide proper ventilation to the spaces within the facility as well as saving costly dollars treating unconditioned ventilation air. Carbon dioxide ventilation control or demand controlled ventilation (DCV) allows for the measurement and control of outside air ventilation levels to a target cfm/person ventilation rate in the space (i.e., 15 cfm/person) based on the number of people in the space. It is a direct measure of ventilation effectiveness and is a method whereby buildings can regain active and automatic zone level ventilation control, without having to open windows. The fixed ventilation approach depends on a set-it-and-forget-it methodology that is completely unresponsive to changes in the way spaces are utilized/occupied or how equipment is maintained. A DCV system utilizes various control algorithms to maintain a base ventilation rate. The system monitors space CO<sub>2</sub> levels and the algorithm automatically adjusts the outdoor and return air dampers to provide the quantity of outdoor air to maintain the required CO<sub>2</sub> level in the space. System designs are normally designed for maximum occupancy and the ventilation rates are designed for this (maximum) occupancy. In areas where occupancy swings are prevalent there is ample opportunity to reduce outdoor air quantity to satisfy the needs of the actual number of occupants present. By installing the DCV controls, energy savings are realized by the reduced quantities of outdoor air that do not require heating and cooling energy from the steam and chilled water plants.

The air handling units serving the lobby areas, theatres and the concession areas are standard air conditioning systems with constant minimum outside air setup. When these units are on unoccupied mode, the outside air dampers shut. The outside air volume is typically based on the maximum occupancy of the space conditioned. When a given space is not fully occupied the outside air quantity delivered to the space is greater than the amount actually needed for adequate ventilation, which results in waste of heating or air conditioning energy.

This ECM includes the installation integrated demand control ventilation systems with CO<sub>2</sub> sensors, for the units mentioned above. This system allows the air handling unit to respond to changes in occupancy and therefore reduce the amount of outside air that has to be conditioned. Outside air accounts for a large portion of the energy consumption in the HVAC system, especially in high occupancy spaces. The U.S. Department of Energy sponsored a study to analyze energy savings achieved through various types of building system controls. The referenced savings is based on the “Advanced Sensors and Controls for Building Applications: Market Assessment and Potential R&D Pathways,” document posted for public use April 2005. The study has found that commercial buildings have the potential to achieve significant energy savings through the use of building controls. The average energy savings are as follows based on the report:

- Demand Control Ventilation - 10% - 15%.

Energy savings achieved through “Demand Control Ventilation” average 10%-15%. Savings resulting from the implementation of this ECM for energy management controls are estimated to be 15% of the total HVAC energy cost for this system.

The components included to install for a demand control ventilation system include damper actuators (if not exist), Variable Frequency Drives (if not exist), CO2 sensors, wiring, Energy Management System equipment expansion and programming. Each occupied zone would require minimum one CO<sub>2</sub> sensor installed to monitor occupancy levels.

IMPLEMENTATION SUMMARY						
INPUTS	HVAC Unit	Service	Total Flow Capacity CFM	Min # of CO2 SENSORS	Cooling Capacity, Tons	Heating Capacity, MBH
DCV-1	AC-1	Concession Area	4,000	1	10.2	114
DCV-2	AC-2	Concession Area	2,000	1	6.9	58
DCV-3	AC-3	Theatre #2	5,700	2	17.5	182
DCV-4	AC-4	Theatre #1	4,410	2	10.4	91
DCV-5	AC-5	Theatre #2A	1,850	2	5.2	53
DCV-7	AC-7	Theatre #3	3,300	2	9.9	170
DCV-8	AC-8	Mezz, Lobby	5,700	2	13.0	270
DCV-14	AC-14	Main Theatre	23,000	2	79.8	1,340
<b>Total</b>				<b>14</b>	<b>153</b>	<b>2,278</b>

### Energy Savings Calculations:

$$\text{Cooling Energy Usage} = \frac{\text{Cooling (Tons)} \times 12,000 \left( \frac{\text{Btu}}{\text{Ton hr}} \right) \times \text{Annual Full Load Cooling Hrs.}}{1000 \left( \frac{\text{Wh}}{\text{kWh}} \right) \times \text{EER} \left( \frac{\text{Btu}}{\text{Wh}} \right)}$$

$$\text{Energy Savings} = \text{Cooling Energy (kWh)} \times 15\%$$

$$\text{Cooling Cost} = \text{Energy Usage (kWh)} \times \text{Ave Electric Cost} \left( \frac{\$}{\text{kWh}} \right)$$

$$\text{Heating Energy (Therms)} = \frac{\text{Heating Capacity} \left( \frac{\text{Btu}}{\text{Hr.}} \right) \times \text{HDD (Day } ^\circ\text{F)} \times 24 \left( \frac{\text{Hr.}}{\text{Day}} \right) \times (0.60)}{65(^{\circ}\text{F}) \times \text{Fuel Heat Value} \left( \frac{\text{Btu}}{\text{Therms}} \right) \times \text{Heating Efficiency (\%)}}$$

$$\text{Heating Cost} = \text{Heating Energy (Therms)} \times \text{Ave Fuel Cost} \left( \frac{\$}{\text{Therms}} \right)$$

$$\text{Energy Savings} = \text{Heating Energy (Therms)} \times 15\%$$

Results of the energy savings calculations are summarized in the table below:

<b>DEMAND CONTROLLED VENTILATION</b>	
<b>ECM INPUTS</b>	<b>DCV-1-8, 14</b>
<b>Equipment</b>	AHUs
<b>Total Cooling Capacity, Tons</b>	153
<b>Efficiency (EER)</b>	9
<b>Annual Full Load Cooling Hours</b>	800
<b>Total Heating Capacity, MBh</b>	2278
<b>Heating Efficiency (Gas)</b>	75%
<b>Heating Degree Days (65°F)</b>	4599
<b>Energy Savings</b>	15.0%
<b>Elec Cost (\$/kWh)</b>	\$0.182
<b>Natural Gas Cost (\$/Therm)</b>	\$1.02
<b>ENERGY SAVINGS</b>	
<b>ECM RESULTS</b>	<b>DCV-1-8, 14</b>
<b>Cooling Energy Cnsmption, kWh</b>	163,236
<b>Heating Energy (Therms)</b>	30,946
<b>Cooling Energy Savings kWh</b>	24,485
<b>Heating Energy Savings (Therms)</b>	4,642
<b>Electric Energy Cost Savings (\$)</b>	\$4,456
<b>Total Gas Cost Savings (\$)</b>	\$4,735
<b>Total Cost Savings (\$)</b>	\$9,191
<b>COMMENTS:</b>	HDD estimated based on Newark,NJ.

### Cost and Incentives:

Estimated installed cost for demand controlled ventilation for the air handling units serving the lobby areas, theatres and the concession areas is \$128,000. Estimated cost includes CO2 sensors, control wiring, electrical wiring, VFDs, control system equipment expansion and programming. There are currently no Smart Start ® incentives available for a Demand Control Ventilation System.

**Energy Savings Summary:**

<b>ECM #6 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$128,000
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$0
<b>Net Installation Cost (\$):</b>	\$128,000
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$9,191
<b>Total Yearly Savings (\$/Yr):</b>	\$9,191
<b>Estimated ECM Lifetime (Yr):</b>	15
<b>Simple Payback</b>	13.9
<b>Simple Lifetime ROI</b>	7.7%
<b>Simple Lifetime Maintenance Savings</b>	0
<b>Simple Lifetime Savings</b>	\$137,866
<b>Internal Rate of Return (IRR)</b>	1%
<b>Net Present Value (NPV)</b>	(\$18,277.56)

## REM #1: 11.3 kW Rooftop Solar Array

### Description:

The Williams Center has approximately 800 square-foot of available roof space that can accommodate an 11.3 kilowatt solar array, assuming the existing roof structure is capable of supporting an array.

The array will produce approximately 14,185 kilowatt-hours annually that will reduce the overall electric usage of the facility by 3%.

### Energy Savings Calculations:

See **Renewable / Distributed Energy Measures Calculations Appendix** for detailed financial summary and proposed solar layout areas.

### Energy Savings Summary:

REM #1 - ENERGY SAVINGS SUMMARY	
Installation Cost (\$):	\$101,430
NJ Smart Start Equipment Incentive (\$):	\$0
Net Installation Cost (\$):	\$101,430
Maintenance Savings (\$/Yr):	\$4,965
Energy Savings (\$/Yr):	\$2,582
Total Yearly Savings (\$/Yr):	\$7,546
Estimated ECM Lifetime (Yr):	15
Simple Payback	13.4
Simple Lifetime ROI	11.6%
Simple Lifetime Maintenance Savings	\$74,471
Simple Lifetime Savings	\$113,196
Internal Rate of Return (IRR)	1%
Net Present Value (NPV)	(\$11,341.33)

## **V. ADDITIONAL RECOMMENDATIONS**

The following recommendations include no cost/low cost measures, Operation & Maintenance (O&M) items, and water conservation measures with attractive paybacks. These measures are not eligible for the Smart Start Buildings incentives from the office of Clean Energy but save energy none the less.

- A. Chemically clean the condenser and evaporator coils periodically to optimize efficiency. Poorly maintained heat transfer surfaces can reduce efficiency 5-10%.
- B. Maintain all weather stripping on windows and doors.
- C. Clean all light fixtures to maximize light output.
- D. Provide more frequent air filter changes to decrease overall system power usage and maintain better IAQ.
- E. Ensure outside air dampers are functioning properly and only open during occupied mode.

**ECM COST & SAVINGS BREAKDOWN**

CONCORD ENGINEERING GROUP

Bergen County - Williams Center for the Arts

ECM ENERGY AND FINANCIAL COSTS AND SAVINGS SUMMARY															
ECM NO.	DESCRIPTION	INSTALLATION COST				YEARLY SAVINGS			ECM LIFETIME	LIFETIME ENERGY SAVINGS	LIFETIME MAINTENANCE SAVINGS	LIFETIME ROI	SIMPLE PAYBACK	INTERNAL RATE OF RETURN	NET PRESENT VALUE (NPV)
		MATERIAL	LABOR	REBATES, INCENTIVES	NET INSTALLATION COST	ENERGY	MAINT. / SREC	TOTAL		(Yearly Saving * ECM Lifetime)	(Yearly Maint Saving * ECM Lifetime)	(Lifetime Savings - Net Cost) / (Net Cost)	(Net cost / Yearly Savings)	$\sum_{n=0}^N \frac{C_n}{(1 + IRR)^n}$	$\sum_{n=0}^N \frac{C_n}{(1 + DR)^n}$
		(\$)	(\$)	(\$)	(\$)	(\$/Yr)	(\$/Yr)	(\$/Yr)		(\$)	(\$)	(%)	(Yr)	(\$)	(\$)
ECM #1	Lighting Equipment Upgrade	\$6,335	\$9,502	\$2,050	\$13,787	\$8,321	\$323	\$8,644	15	\$129,661	\$4,841	840.5%	1.6	62.65%	\$89,405.50
ECM #2	Lighting Controls Upgrade	\$1,500	\$2,250	\$180	\$3,570	\$1,912	\$0	\$1,912	15	\$28,676	\$0	703.2%	1.9	53.46%	\$19,251.91
ECM #3	Premium Efficiency Motors	\$11,163	\$0	\$395	\$10,768	\$597	\$0	\$597	15	\$8,948	\$0	-16.9%	18.1	-2.23%	(\$3,646.91)
ECM #4	Variable Frequency Drives on Pump Motors	\$13,600	\$20,400	\$450	\$33,550	\$5,249	\$0	\$5,249	20	\$104,971	\$0	212.9%	6.4	14.62%	\$44,535.45
ECM #5	Window Replacement	\$133,500	\$0	\$0	\$133,500	\$3,265	\$0	\$3,265	15	\$48,973	\$0	-63.3%	40.9	-10.53%	(\$94,524.52)
ECM #6	Demand Controlled Ventilation	\$128,000	\$0	\$0	\$128,000	\$9,191	\$0	\$9,191	15	\$137,866	\$0	7.7%	13.9	0.94%	(\$18,277.56)
REM RENEWABLE ENERGY AND FINANCIAL COSTS AND SAVINGS SUMMARY															
REM #1	Solar Photovoltaic System	\$101,430	\$0	\$0	\$101,430	\$2,582	\$4,965	\$7,546	15	\$113,196	\$74,471	11.6%	13.4	1.40%	(\$11,341.33)

Notes: 1) The variable Cn in the formulas for Internal Rate of Return and Net Present Value stands for the cash flow during each period.  
2) The variable DR in the NPV equation stands for Discount Rate  
3) For NPV and IRR calculations: From n=0 to N periods where N is the lifetime of ECM and Cn is the cash flow during each period.



# Concord Engineering Group, Inc.

520 BURNT MILL ROAD  
VOORHEES, NEW JERSEY 08043  
PHONE: (856) 427-0200  
FAX: (856) 427-6508

## SmartStart Building Incentives

The NJ SmartStart Buildings Program offers financial incentives on a wide variety of building system equipment. The incentives were developed to help offset the initial cost of energy-efficient equipment. The following tables show the current available incentives as of February 15, 2011:

### **Electric Chillers**

Water-Cooled Chillers	\$12 - \$170 per ton
Air-Cooled Chillers	\$8 - \$52 per ton

Energy Efficiency must comply with ASHRAE 90.1-2007

### **Gas Cooling**

Gas Absorption Chillers	\$185 - \$400 per ton
Gas Engine-Driven Chillers	Calculated through custom measure path)

### **Desiccant Systems**

\$1.00 per cfm – gas or electric
----------------------------------

### **Electric Unitary HVAC**

Unitary AC and Split Systems	\$73 - \$92 per ton
Air-to-Air Heat Pumps	\$73 - \$92 per ton
Water-Source Heat Pumps	\$81 per ton
Packaged Terminal AC & HP	\$65 per ton
Central DX AC Systems	\$40- \$72 per ton
Dual Enthalpy Economizer Controls	\$250
Occupancy Controlled Thermostat (Hospitality & Institutional Facility)	\$75 per thermostat

Energy Efficiency must comply with ASHRAE 90.1-2007

### **Gas Heating**

Gas Fired Boilers < 300 MBH	\$300 per unit
Gas Fired Boilers ≥ 300 - 1500 MBH	\$1.75 per MBH
Gas Fired Boilers ≥1500 - ≤ 4000 MBH	\$1.00 per MBH
Gas Fired Boilers > 4000 MBH	(Calculated through Custom Measure Path)
Gas Furnaces	\$300 - \$400 per unit, AFUE ≥ 92%



### Ground Source Heat Pumps

Closed Loop	\$450 per ton, EER $\geq$ 16 \$600 per ton, EER $\geq$ 18 \$750 per ton, EER $\geq$ 20
-------------	--

Energy Efficiency must comply with ASHRAE 90.1-2007

### Variable Frequency Drives

Variable Air Volume	\$65 - \$155 per hp
Chilled-Water Pumps	\$60 per VFD rated hp
Compressors	\$5,250 to \$12,500 per drive
Cooling Towers $\geq$ 10 hp	\$60 per VFD rated hp

### Natural Gas Water Heating

Gas Water Heaters $\leq$ 50 gallons, 0.67 energy factor or better	\$50 per unit
Gas-Fired Water Heaters $>$ 50 gallons	\$1.00 - \$2.00 per MBH
Gas-Fired Booster Water Heaters	\$17 - \$35 per MBH
Gas Fired Tankless Water Heaters	\$300 per unit

### Prescriptive Lighting

Retro fit of T12 to T-5 or T-8 Lamps w/Electronic Ballast in Existing Facilities	\$10 per fixture (1-4 lamps)
Replacement of T12 with new T-5 or T-8 Lamps w/Electronic Ballast in Existing Facilities	\$25 per fixture (1-4 lamps)
Replacement of incandescent with screw-in PAR 38 or PAR 30 (CFL) bulb	\$7 per bulb
T-8 reduced Wattage (28w/25w 4', 1-4 lamps) Lamp & ballast replacement	\$10 per fixture
Hard-Wired Compact Fluorescent	\$25 - \$30 per fixture
Metal Halide w/Pulse Start Including Parking Lot	\$25 per fixture
T-5 and T-8 High Bay Fixtures	\$16 - \$200 per fixture
HID $\geq$ 100w Retrofit with induction lamp, power coupler and generator (must be 30% less watts/fixture than HID system)	\$50 per fixture
HID $\geq$ 100w Replacement with new HID $\geq$ 100w	\$70 per fixture

### Prescriptive Lighting - LED

LED New Exit Sign Fixture Existing Facility < 75 kw Existing Facility > 75 kw	\$20 per fixture \$10 per fixture
LED Display Case Lighting	\$30 per display case
LED Shelf-Mtd. Display & Task Lights	\$15 per linear foot
LED Portable Desk Lamp	\$20 per fixture
LED Wall-wash Lights	\$30 per fixture
LED Recessed Down Lights	\$35 per fixture
LED Outdoor Pole/Arm-Mounted Area and Roadway Luminaries	\$175 per fixture
LED Outdoor Pole/Arm-Mounted Decorative Luminaries	\$175 per fixture
LED Outdoor Wall-Mounted Area Luminaries	\$100 per fixture
LED Parking Garage Luminaries	\$100 per fixture
LED Track or Mono-Point Directional Lighting Fixtures	\$50 per fixture
LED High-Bay and Low-Bay Fixtures for Commercial & Industrial Bldgs.	\$150 per fixture
LED High-Bay-Aisle Lighting	\$150 per fixture
LED Bollard Fixtures	\$50 per fixture
LED Linear Panels (2x2 Troffers only)	\$100 per fixture
LED Fuel Pump Canopy	\$100 per fixture
LED Refrigerator/Freezer case lighting replacement of fluorescent in medium and low temperature display case	\$42 per 5 foot \$65 per 6 foot

### Lighting Controls – Occupancy Sensors

Wall Mounted	\$20 per control
Remote Mounted	\$35 per control
Daylight Dimmers	\$25 per fixture
Occupancy Controlled hi-low Fluorescent Controls	\$25 per fixture controlled

### Lighting Controls – HID or Fluorescent Hi-Bay Controls

Occupancy hi-low	\$75 per fixture controlled
Daylight Dimming	\$75 per fixture controlled
Daylight Dimming - office	\$50 per fixture controlled

### Premium Motors

Three-Phase Motors	\$45 - \$700 per motor
Fractional HP Motors Electronic Communicated Motors (replacing shaded pole motors in refrigerator/freezer cases)	\$40 per electronic communicated motor

### Other Equipment Incentives

Performance Lighting	\$1.00 per watt per SF below program incentive threshold, currently 5% more energy efficient than ASHRAE 90.1- 2007 for New Construction and Complete Renovation
Custom Electric and Gas Equipment Incentives	not prescriptive
Custom Measures	\$0.16 KWh and \$1.60/Therm of 1st year savings, or a buy down to a 1 year payback on estimated savings. Minimum required savings of 75,000 KWh or 1,500 Therms and a IRR of at least 10%.
Multi Measures Bonus	15%



# STATEMENT OF ENERGY PERFORMANCE

## Williams Center for the Arts

Building ID: 2610915

For 12-month Period Ending: February 28, 2011<sup>1</sup>

Date SEP becomes ineligible: N/A

Date SEP Generated: May 16, 2011

**Facility**

Williams Center for the Arts  
17 Sylvan St.  
Rutherford, NJ 07070

**Facility Owner**

County of Bergen  
One Bergen Plaza  
Hackensack, NJ 07601

**Primary Contact for this Facility**

Thomas Connolly  
One Bergen Plaza  
Hackensack, NJ 07601

**Year Built:** 1920**Gross Floor Area (ft<sup>2</sup>):** 39,144**Energy Performance Rating<sup>2</sup>** (1-100) N/A**Site Energy Use Summary<sup>3</sup>**

Electricity - Grid Purchase(kBtu)	1,588,171
Natural Gas (kBtu) <sup>4</sup>	2,497,163
Total Energy (kBtu)	4,085,334

**Energy Intensity<sup>5</sup>**

Site (kBtu/ft <sup>2</sup> /yr)	104
Source (kBtu/ft <sup>2</sup> /yr)	202

**Emissions** (based on site energy use)

Greenhouse Gas Emissions (MtCO <sub>2</sub> e/year)	358
---	-----

**Electric Distribution Utility**

Public Service Electric &amp; Gas Co

**National Average Comparison**

National Average Site EUI	95
National Average Source EUI	265
% Difference from National Average Source EUI	-24%
Building Type	Entertainment/Culture

Stamp of Certifying Professional

Based on the conditions observed at the time of my visit to this building, I certify that the information contained within this statement is accurate.

**Meets Industry Standards<sup>6</sup> for Indoor Environmental Conditions:**

Ventilation for Acceptable Indoor Air Quality	N/A
Acceptable Thermal Environmental Conditions	N/A
Adequate Illumination	N/A

**Certifying Professional**

Michael Fischette  
520 S. Burnt Mill Rd.  
Voorhees, NJ 08043

**Notes:**

1. Application for the ENERGY STAR must be submitted to EPA within 4 months of the Period Ending date. Award of the ENERGY STAR is not final until approval is received from EPA.
2. The EPA Energy Performance Rating is based on total source energy. A rating of 75 is the minimum to be eligible for the ENERGY STAR.
3. Values represent energy consumption, annualized to a 12-month period.
4. Values represent energy intensity, annualized to a 12-month period.
5. Based on Meeting ASHRAE Standard 62 for ventilation for acceptable indoor air quality, ASHRAE Standard 55 for thermal comfort, and IESNA Lighting Handbook for lighting quality.

## ENERGY STAR® Data Checklist for Commercial Buildings

In order for a building to qualify for the ENERGY STAR, a Professional Engineer (PE) or a Registered Architect (RA) must validate the accuracy of the data underlying the building's energy performance rating. This checklist is designed to provide an at-a-glance summary of a property's physical and operating characteristics, as well as its total energy consumption, to assist the PE or RA in double-checking the information that the building owner or operator has entered into Portfolio Manager.

**Please complete and sign this checklist and include it with the stamped, signed Statement of Energy Performance.**

NOTE: You must check each box to indicate that each value is correct, OR include a note.

CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
<b>Building Name</b>	Williams Center for the Arts	Is this the official building name to be displayed in the ENERGY STAR Registry of Labeled Buildings?		<input type="checkbox"/>
<b>Type</b>	Entertainment/Culture	Is this an accurate description of the space in question?		<input type="checkbox"/>
<b>Location</b>	17 Sylvan St. , Rutherford, NJ 07070	Is this address accurate and complete? Correct weather normalization requires an accurate zip code.		<input type="checkbox"/>
<b>Single Structure</b>	Single Facility	Does this SEP represent a single structure? SEPs cannot be submitted for multiple-building campuses (with the exception of acute care or children's hospitals) nor can they be submitted as representing only a portion of a building		<input type="checkbox"/>
Theatre (Other)				
CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
<b>Gross Floor Area</b>	39,144 Sq. Ft.	Does this square footage include all supporting functions such as kitchens and break rooms used by staff, storage areas, administrative areas, elevators, stairwells, atria, vent shafts, etc. Also note that existing atriums should only include the base floor area that it occupies. Interstitial (plenum) space between floors should not be included in the total. Finally gross floor area is not the same as leasable space. Leasable space is a subset of gross floor area.		<input type="checkbox"/>
<b>Number of PCs</b>	5(Optional)	Is this the number of personal computers in the space?		<input type="checkbox"/>
<b>Weekly operating hours</b>	80Hours(Optional)	Is this the total number of hours per week that the space is 75% occupied? This number should exclude hours when the facility is occupied only by maintenance, security, or other support personnel. For facilities with a schedule that varies during the year, "operating hours/week" refers to the total weekly hours for the schedule most often followed.		<input type="checkbox"/>
<b>Workers on Main Shift</b>	10(Optional)	Is this the number of employees present during the main shift? Note this is not the total number of employees or visitors who are in a building during an entire 24 hour period. For example, if there are two daily 8 hour shifts of 100 workers each, the Workers on Main Shift value is 100.		<input type="checkbox"/>

# ENERGY STAR® Data Checklist for Commercial Buildings

## Energy Consumption

**Power Generation Plant or Distribution Utility:** Public Service Electric & Gas Co

Fuel Type: Electricity		
<b>Meter: 278003797 (kWh (thousand Watt-hours))</b> <b>Space(s):</b> Entire Facility <b>Generation Method:</b> Grid Purchase		
Start Date	End Date	Energy Use (kWh (thousand Watt-hours))
01/06/2011	02/03/2011	1,170.00
12/04/2010	01/05/2011	2,640.00
11/03/2010	12/03/2010	1,830.00
10/05/2010	11/02/2010	1,230.00
09/04/2010	10/04/2010	750.00
08/05/2010	09/03/2010	1,230.00
07/07/2010	08/04/2010	1,050.00
06/05/2010	07/06/2010	2,490.00
05/06/2010	06/04/2010	1,560.00
04/08/2010	05/05/2010	810.00
03/05/2010	04/07/2010	1,080.00
<b>278003797 Consumption (kWh (thousand Watt-hours))</b>		<b>15,840.00</b>
<b>278003797 Consumption (kBtu (thousand Btu))</b>		<b>54,046.08</b>
<b>Meter: 778013328 (kWh (thousand Watt-hours))</b> <b>Space(s):</b> Entire Facility <b>Generation Method:</b> Grid Purchase		
Start Date	End Date	Energy Use (kWh (thousand Watt-hours))
01/06/2011	02/03/2011	30,200.00
12/04/2010	01/05/2011	33,000.00
10/05/2010	12/03/2010	54,600.00
09/04/2010	10/04/2010	44,200.00
08/05/2010	09/03/2010	55,400.00
07/07/2010	08/04/2010	58,000.00
06/05/2010	07/06/2010	52,200.00
05/06/2010	06/04/2010	37,600.00
04/07/2010	05/05/2010	27,200.00
03/06/2010	04/06/2010	27,000.00
<b>778013328 Consumption (kWh (thousand Watt-hours))</b>		<b>419,400.00</b>
<b>778013328 Consumption (kBtu (thousand Btu))</b>		<b>1,430,992.80</b>
<b>Total Electricity (Grid Purchase) Consumption (kBtu (thousand Btu))</b>		<b>1,485,038.88</b>

Is this the total Electricity (Grid Purchase) consumption at this building including all Electricity meters?		<input type="checkbox"/>
<b>Fuel Type: Natural Gas</b>		
<b>Meter: 3499913 (therms)</b> <b>Space(s): Entire Facility</b>		
<b>Start Date</b>	<b>End Date</b>	<b>Energy Use (therms)</b>
01/06/2011	02/03/2011	6,065.93
12/04/2010	01/05/2011	6,389.77
11/03/2010	12/03/2010	2,751.63
10/05/2010	11/02/2010	972.53
09/04/2010	10/04/2010	92.09
08/05/2010	09/03/2010	0.00
07/07/2010	08/04/2010	0.00
06/05/2010	07/06/2010	3.04
05/06/2010	06/04/2010	311.70
04/07/2010	05/05/2010	890.56
03/05/2010	04/06/2010	2,746.57
<b>3499913 Consumption (therms)</b>		<b>20,223.82</b>
<b>3499913 Consumption (kBtu (thousand Btu))</b>		<b>2,022,382.00</b>
<b>Total Natural Gas Consumption (kBtu (thousand Btu))</b>		<b>2,022,382.00</b>
Is this the total Natural Gas consumption at this building including all Natural Gas meters?		<input type="checkbox"/>

<b>Additional Fuels</b>	
Do the fuel consumption totals shown above represent the total energy use of this building? Please confirm there are no additional fuels (district energy, generator fuel oil) used in this facility.	<input type="checkbox"/>

<b>On-Site Solar and Wind Energy</b>	
Do the fuel consumption totals shown above include all on-site solar and/or wind power located at your facility? Please confirm that no on-site solar or wind installations have been omitted from this list. All on-site systems must be reported.	<input type="checkbox"/>

## Certifying Professional

(When applying for the ENERGY STAR, the Certifying Professional must be the same PE or RA that signed and stamped the SEP.)

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Signature: \_\_\_\_\_

Signature is required when applying for the ENERGY STAR.

# FOR YOUR RECORDS ONLY. DO NOT SUBMIT TO EPA.

Please keep this Facility Summary for your own records; do not submit it to EPA. Only the Statement of Energy Performance (SEP), Data Checklist and Letter of Agreement need to be submitted to EPA when applying for the ENERGY STAR.

## Facility

Williams Center for the Arts  
17 Sylvan St.  
Rutherford, NJ 07070

## Facility Owner

County of Bergen  
One Bergen Plaza  
Hackensack, NJ 07601

## Primary Contact for this Facility

Thomas Connolly  
One Bergen Plaza  
Hackensack, NJ 07601

## General Information

Williams Center for the Arts	
Gross Floor Area Excluding Parking: (ft <sup>2</sup> )	39,144
Year Built	1920
For 12-month Evaluation Period Ending Date:	February 28, 2011

## Facility Space Use Summary

Theatre	
Space Type	Other - Entertainment/Culture
Gross Floor Area(ft <sup>2</sup> )	39,144
Number of PCs <sup>o</sup>	5
Weekly operating hours <sup>o</sup>	80
Workers on Main Shift <sup>o</sup>	10

## Energy Performance Comparison

Performance Metrics	Evaluation Periods		Comparisons		
	Current (Ending Date 02/28/2011)	Baseline (Ending Date 02/28/2011)	Rating of 75	Target	National Average
Energy Performance Rating	N/A	N/A	75	N/A	N/A
Energy Intensity					
Site (kBtu/ft <sup>2</sup> )	104	104	0	N/A	95
Source (kBtu/ft <sup>2</sup> )	202	202	0	N/A	265
Energy Cost					
\$/year	\$ 110,790.63	\$ 110,790.63	N/A	N/A	\$ 100,844.21
\$/ft <sup>2</sup> /year	\$ 2.83	\$ 2.83	N/A	N/A	\$ 2.58
Greenhouse Gas Emissions					
MtCO <sub>2</sub> e/year	358	358	0	N/A	326
kgCO <sub>2</sub> e/ft <sup>2</sup> /year	9	9	0	N/A	8

More than 50% of your building is defined as Entertainment/Culture. This building is currently ineligible for a rating. Please note the National Average column represents the CBECS national average data for Entertainment/Culture. This building uses X% less energy per square foot than the CBECS national average for Entertainment/Culture.

### Notes:

o - This attribute is optional.

d - A default value has been supplied by Portfolio Manager.



# **MAJOR EQUIPMENT LIST**

**Concord Engineering Group**

**Bergen County - Williams Center**

## **Boilers**

<b>Tag</b>	<b>Boiler-1 &amp; 2</b>		
<b>Unit Type</b>	Gas fired, water tube		
<b>Qty</b>	2		
<b>Location</b>	Boiler room		
<b>Area Served</b>	Air handling units		
<b>Manufacturer</b>	Paterson Kelley		
<b>Model #</b>	N-1900-2		
<b>Serial #</b>	CY12-09-33386, CY12-09-33387		
<b>Input Capacity (MBH)</b>	1,900		
<b>Rated Output Capacity (MBH)</b>	1,615		
<b>Approx. Efficiency %</b>	85%		
<b>Fuel</b>	Natural Gas		
<b>Approx Age</b>	2		
<b>ASHRAE Service Life</b>	30		
<b>Remaining Life</b>	28		
<b>Comments</b>	High efficiency non-condensing HW boilers		

# **MAJOR EQUIPMENT LIST**

## **Concord Engineering Group**

### **Bergen County - Williams Center**

#### **Chiller**

<b>Tag</b>	<b>CH-1</b>		
<b>Unit Type</b>	Air cooled water chiller with helical rotary screw compressors		
<b>Qty</b>	1		
<b>Location</b>	Platform		
<b>Area Served</b>	Air Handling Units		
<b>Manufacturer</b>	TRANE		
<b>Model #</b>	RTAC 2004 UR0N UAFN N1TY 1DDN NN0E N10A R0EX N		
<b>Serial #</b>	U09E04117		
<b>Refrigerant</b>	R143A		
<b>Cooling Capacity (Tons)</b>	200		
<b>Cooling Efficiency (KW/Ton)</b>	1.241 kW/Ton, 9.7 EER (Full Load)		
<b>Volts / Phase / Hz</b>	460/3/60		
<b>Fuel</b>	Electricity		
<b>Chilled Water GPM / <math>\Delta T</math></b>	-		
<b>Condenser Water GPM / <math>\Delta T</math></b>	-		
<b>Approx Age</b>	2		
<b>ASHRAE Service Life</b>	20		
<b>Remaining Life</b>	18		
<b>Comments</b>	Standard efficiency unit		

# **MAJOR EQUIPMENT LIST**

## **Concord Engineering Group**

### **Bergen County - Williams Center**

#### **Pumps**

<b>Tag</b>	<b>P #1 &amp; 2</b>	<b>#3 &amp; 4</b>	<b>P-5 &amp; 6</b>
<b>Unit Type</b>	Base mounted, constant volume, chilled water pump	Base mounted, constant volume, hot water pump secondary loop	Pipe mounted, primary hot water loop pumps
<b>Qty</b>	2	2	2
<b>Location</b>	3rd Floor MER (Icebox room)	Boiler room	Boiler room
<b>Area Served</b>	Air handling units	Secondary hot water loop - AHUs	Primary hot water loop AHUs
<b>Manufacturer</b>	Taco	Taco	Emerson
<b>Model #</b>	C13013E2LAAB7010	SD40030-4	-
<b>Serial #</b>	EC49371/6	-	-
<b>Horse Power</b>	20	10	3/4
<b>Flow</b>	440	-	-
<b>Motor Info</b>	-	Baldor Motor	Emerson
<b>Electrical Power</b>	460 / 3 / 60	460 / 3 / 60	-
<b>RPM</b>	1760	1755	1725
<b>Motor Efficiency %</b>	91.7%	87.5%	-
<b>Approx Age</b>	2	2	2
<b>ASHRAE Service Life</b>	20	20	20
<b>Remaining Life</b>	18	18	18
<b>Comments</b>		Standard efficiency motors	

# **MAJOR EQUIPMENT LIST**

## **Concord Engineering Group**

### **Bergen County - Williams Center**

#### **Domestic Water Heaters**

<b>Tag</b>	<b>HWH-1</b>		
<b>Unit Type</b>	Electric hot water heater		
<b>Qty</b>	1		
<b>Location</b>	Stage bathrooms		
<b>Area Served</b>	Stage bathrooms		
<b>Manufacturer</b>	Rheem		
<b>Model #</b>	81V40D		
<b>Serial #</b>	0591Z06947		
<b>Size (Gallons)</b>	40		
<b>Input Capacity (MBH/KW)</b>	4.5 kW		
<b>Recovery (Gal/Hr)</b>	-		
<b>Efficiency %</b>	-		
<b>Fuel</b>	Electricity		
<b>Approx Age</b>	2		
<b>ASHRAE Service Life</b>	12		
<b>Remaining Life</b>	10		
<b>Comments</b>			

# **MAJOR EQUIPMENT LIST**

## **Concord Engineering Group**

### **Bergen County - Williams Center**

#### **Air Handling Units**

<b>Tag</b>	<b>AC-1</b>	<b>AC-2</b>	<b>AC-3</b>
<b>Unit Type</b>	AHU with Hot and Chilled Water Coils	AHU with Hot and Chilled Water Coils	AHU with Hot and Chilled Water Coils
<b>Qty</b>	1	1	1
<b>Location</b>	Air Handler Room	Air Handler Room	Air Handler Room
<b>Area Served</b>	Concession Area	Concession Area	Theatre #2
<b>Manufacturer</b>	McQuay	McQuay	McQuay
<b>Model #</b>	LSL111CH	LSL106CH	LSL111CV
<b>Serial #</b>	3LA00077-04	3LA00076-04	3LA00078-04
<b>Flow Capacity (CFM)</b>	4000	2000	5700
<b>Outside Air Flow (CFM)</b>	650	490	1425
<b>Cooling Type</b>	Chilled Water	Chilled Water	Chilled Water
<b>Cooling Capacity (Tons)</b>	122.6 MBH	82.4 MBH	210.5 MBH
<b>Cooling Efficiency (SEER/EER)</b>	-	-	-
<b>Heating Type</b>	Hot Water	Hot Water	Hot Water
<b>Heating Input (MBH)</b>	114 MBH	58 MBH	182 MBH
<b>Approx Age</b>	15+	15+	15+
<b>ASHRAE Service Life</b>	15	15	15
<b>Remaining Life</b>	0	0	0
<b>Comments</b>	5 HP Motor (Estimated)	5 HP Motor (Estimated)	3 HP Standard Eff. Motor, 82.5 % Eff

## **MAJOR EQUIPMENT LIST**

### **Concord Engineering Group**

#### **Bergen County - Williams Center**

### **Air Handling Units**

<b>Tag</b>	<b>AC-4</b>	<b>AC-5</b>	<b>AC-6</b>
<b>Unit Type</b>	AHU with Hot and Chilled Water Coils	AHU with Hot and Chilled Water Coils	AHU with Hot and Chilled Water Coils
<b>Qty</b>	1	1	1
<b>Location</b>	Air Handler Room	Air Handler Room	Icebox Room
<b>Area Served</b>	Theatre #1	Theatre #2A	Offices
<b>Manufacturer</b>	McQuay	McQuay	McQuay
<b>Model #</b>	LSL111CV	LSL108CV	-
<b>Serial #</b>	3LA00079-04	3LA00080-04	-
<b>Flow Capacity (CFM)</b>	4410	1850	800
<b>Outside Air Flow (CFM)</b>	1100	415	60
<b>Cooling Type</b>	Chilled Water	Chilled Water	Chilled Water
<b>Cooling Capacity (Tons)</b>	125 MBH	62.5 MBH	20 MBH
<b>Cooling Efficiency (SEER/EER)</b>	-	-	-
<b>Heating Type</b>	Hot Water	Hot Water	Hot Water
<b>Heating Input (MBH)</b>	91 MBH	53 MBH	23 MBH
<b>Approx Age</b>	15+	15+	2
<b>ASHRAE Service Life</b>	15	15	15
<b>Remaining Life</b>	0	0	13
<b>Comments</b>	Small Motor (Info N/A)	2 HP Standard Eff. Motor, 80% Eff	1/2 HP motor

## **MAJOR EQUIPMENT LIST**

### **Concord Engineering Group**

### **Bergen County - Williams Center**

#### **Air Handling Units**

<b>Tag</b>	<b>AC-7</b>	<b>AC-8</b>	<b>AC-14</b>
<b>Unit Type</b>	AHU with Hot and Chilled Water Coils	AHU with Hot and Chilled Water Coils	AHU with Hot and Chilled Water Coils
<b>Qty</b>	1	1	1
<b>Location</b>	Icebox Room	Icebox Room	Icebox Room
<b>Area Served</b>	Theatre #3	Mezz, Lobby	Main Theatre
<b>Manufacturer</b>	McQuay	McQuay	Trane
<b>Model #</b>	-	-	CCDB35MNEM V5A5L11LLAP
<b>Serial #</b>	-	-	K92H39452
<b>Flow Capacity (CFM)</b>	3300	5700	23000
<b>Outside Air Flow (CFM)</b>	825	850	5720
<b>Cooling Type</b>	Chilled Water	Chilled Water	Chilled Water
<b>Cooling Capacity (Tons)</b>	119 MBH	156.4 MBH	958 MBH
<b>Cooling Efficiency (SEER/EER)</b>	-	-	-
<b>Heating Type</b>	Hot Water	Hot Water	Hot Water
<b>Heating Input (MBH)</b>	170 MBH	270 MBH	1340 MBH
<b>Approx Age</b>	2	2	19 (Est)
<b>ASHRAE Service Life</b>	15	15	15
<b>Remaining Life</b>	13	13	0
<b>Comments</b>	5 HP Motor (info N/A)	7.5 HP Motor (info N/A)	20 HP Standard Eff. PTFE Motor

# Investment Grade Lighting Audit

APPENDIX E  
1 of 7

CEG Job #: 9C10088

Project: Williams Center

15 Sylvan St

Rutherford NJ

Bldg. Sq. Ft. 39,144

Williams Center

KWH COST: \$0.182

## ECM #1: Lighting Upgrade - General

EXISTING LIGHTING										PROPOSED LIGHTING										SAVINGS					
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Lamps	Retro-Unit Description	Watts Used	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback			
626	Atrium	3000	10	8	Strip Light, (8) 40w G40 Lamp	320	3.20	9,600.0	\$1,747.20	10	8	14w G40 CFL Lamp	112	1.12	3360	\$611.52	\$100.00	\$1,000.00	2.08	6240	\$1,135.68	0.88			
626	2nd Floor Concourse	3000	11	8	Strip Light, (8) 40w G40 Lamp	320	3.52	10,560.0	\$1,921.92	11	8	14w G40 CFL Lamp	112	1.23	3696	\$672.67	\$100.00	\$1,100.00	2.29	6864	\$1,249.25	0.88			
555	Movie Theater	2000	20	1	Recessed Down Light, 65w BR30 Lamp	65	1.30	2,600.0	\$473.20	20	1	Energy Star Rated Dimmable 26w CFL Lamp	26	0.52	1040	\$189.28	\$20.00	\$400.00	0.78	1560	\$283.92	1.41			
227.21	Stairwell	3000	1	2	2x2, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.07	195.0	\$35.49	1	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.05	147	\$26.75	\$24.00	\$24.00	0.02	48	\$8.74	2.75			
122.21	Maintenance	1000	3	2	2x4, 2-Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	78	0.23	234.0	\$42.59	3	2	Reballast & Relamp; Sylvania Lamp FO28/841/SS/ECO	50	0.15	150	\$27.30	\$80.00	\$240.00	0.08	84	\$15.29	15.70			
142.21	Boiler Room	1200	2	4	2x4, 4 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	156	0.31	374.4	\$68.14	2	3	3 Lamp , 28w T8, Elect. Ballast, Specular Reflector; retrofit	72	0.14	172.8	\$31.45	\$100.00	\$200.00	0.17	201.6	\$36.69	5.45			
221.11		1200	2	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.12	148.8	\$27.08	2	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.10	120	\$21.84	\$14.00	\$28.00	0.02	28.8	\$5.24	5.34			
232.22	Office	2600	8	3	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Parabolic Lens	86	0.69	1,788.8	\$325.56	8	3	Relamp - Sylvania Lamp FO28/841/SS/ECO	72	0.58	1497.6	\$272.56	\$21.00	\$168.00	0.11	291.2	\$53.00	3.17			
247.22		2600	1	4	2x2, 4 Lamp, 17w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	68	0.07	176.8	\$32.18	1	0	No Change	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00			
612	Mech Room	1000	4	1	Pendant Mnt., 100w A19 Lamp	100	0.40	400.0	\$72.80	4	1	(1) 26w CFL Lamp	26	0.10	104	\$18.93	\$20.00	\$80.00	0.30	296	\$53.87	1.49			
555	Small Office	2600	6	1	Recessed Down Light, 65w BR30 Lamp	65	0.39	1,014.0	\$184.55	6	1	Energy Star Rated Dimmable 26w CFL Lamp	26	0.16	405.6	\$73.82	\$20.00	\$120.00	0.23	608.4	\$110.73	1.08			
564		2600	4	1	Track Head, 50w R20	50	0.20	520.0	\$94.64	4	1	13w R20 CFL Lamp	13	0.05	135.2	\$24.61	\$20.00	\$80.00	0.15	384.8	\$70.03	1.14			
121.14	Elevator Car	8760	1	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Surface Mnt., No Lens	78	0.08	683.3	\$124.36	1	2	Reballast & Relamp; Sylvania Lamp FO28/841/SS/ECO	50	0.05	438	\$79.72	\$80.00	\$80.00	0.03	245.28	\$44.64	1.79			
609	Men's Restroom	3000	1	10	Strip Light, (10) 40w G40 Lamp	400	0.40	1,200.0	\$218.40	1	2	Wall Mnt., 2 Lamp T8 28w, Prismatic lens	50	0.05	150	\$27.30	\$200.00	\$200.00	0.35	1050	\$191.10	1.05			
555		3000	5	1	Recessed Down Light, 65w BR30 Lamp	65	0.33	975.0	\$177.45	5	1	Energy Star Rated Dimmable 26w CFL Lamp	26	0.13	390	\$70.98	\$20.00	\$100.00	0.20	585	\$106.47	0.94			
609	Women's Restroom	3000	1	10	Strip Light, (10) 40w G40 Lamp	400	0.40	1,200.0	\$218.40	1	2	Wall Mnt., 2 Lamp T8 28w, Prismatic lens	50	0.05	150	\$27.30	\$200.00	\$200.00	0.35	1050	\$191.10	1.05			
555		3000	5	1	Recessed Down Light, 65w BR30 Lamp	65	0.33	975.0	\$177.45	5	1	Energy Star Rated Dimmable 26w CFL Lamp	26	0.13	390	\$70.98	\$20.00	\$100.00	0.20	585	\$106.47	0.94			
122.11	Dressing Area	1200	2	2	2x4, 2-Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	78	0.16	187.2	\$34.07	2	2	Reballast & Relamp; Sylvania Lamp FO28/841/SS/ECO	50	0.10	120	\$21.84	\$80.00	\$160.00	0.06	67.2	\$12.23	13.08			
142.11	Dressing Area Restroom	1200	1	4	2x4, 4 Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	156	0.16	187.2	\$34.07	1	3	3 Lamp , 28w T8, Elect. Ballast, Specular Reflector; retrofit	72	0.07	86.4	\$15.72	\$100.00	\$100.00	0.08	100.8	\$18.35	5.45			
627		1200	1	3	Strip Light, (3) 40w G40 Lamp	120	0.12	144.0	\$26.21	1	3	14w G40 CFL Lamp	42	0.04	50.4	\$9.17	\$60.00	\$60.00	0.08	93.6	\$17.04	3.52			
142.11	Prop Room	1200	3	4	2x4, 4 Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	156	0.47	561.6	\$102.21	3	3	3 Lamp , 28w T8, Elect. Ballast, Specular Reflector; retrofit	72	0.22	259.2	\$47.17	\$100.00	\$300.00	0.25	302.4	\$55.04	5.45			
628		2000	4	1	500w Quartz Light	500	2.00	4,000.0	\$728.00	4	1	175w Pulse Start Metal Halide Flood Light	185	0.74	1480	\$269.36	\$220.00	\$880.00	1.26	2520	\$458.64	1.92			



## Investment Grade Lighting Audit

APPENDIX E  
2 of 7

### ECM #1: Lighting Upgrade - General

EXISTING LIGHTING										PROPOSED LIGHTING										SAVINGS			
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Lamps	Retro-Unit Description	Watts Used	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback	
629	Assembly Area	2000	7	1	Step Light 20w	20	0.14	280.0	\$50.96	7	1	5w LED Lamp	5	0.04	70	\$12.74	\$24.00	\$168.00	0.11	210	\$38.22	4.40	
630		2000	1	48	Hanging Chandelier, (48) 75w A Lamp	3600	3.60	7,200.0	\$1,310.40	1	48	9w LED Lamp	432	0.43	864	\$157.25	\$2,800.00	\$2,800.00	3.17	6336	\$1,153.15	2.43	
628	Stage	2000	2	1	500w Quartz Light	500	1.00	2,000.0	\$364.00	2	1	175w Pulse Start Metal Halide Flood Light	185	0.37	740	\$134.68	\$220.00	\$440.00	0.63	1260	\$229.32	1.92	
629	Ramp/Walkway	2000	8	1	Step Light 20w	20	0.16	320.0	\$58.24	8	1	5w LED Lamp	5	0.04	80	\$14.56	\$24.00	\$192.00	0.12	240	\$43.68	4.40	
555		2000	7	1	Recessed Down Light, 65w BR30 Lamp	65	0.46	910.0	\$165.62	7	1	Energy Star Rated Dimmable 26w CFL Lamp	26	0.18	364	\$66.25	\$20.00	\$140.00	0.27	546	\$99.37	1.41	
628		2000	1	1	500w Quartz Light	500	0.50	1,000.0	\$182.00	1	1	175w Pulse Start Metal Halide Flood Light	185	0.19	370	\$67.34	\$220.00	\$220.00	0.32	630	\$114.66	1.92	
555	Control Room	2000	2	1	Recessed Down Light, 65w BR30 Lamp	65	0.13	260.0	\$47.32	2	1	Energy Star Rated Dimmable 26w CFL Lamp	26	0.05	104	\$18.93	\$20.00	\$40.00	0.08	156	\$28.39	1.41	
611	Seating Area	2000	10	1	Wall Mnt. Globe, (1) 100w A19 Lamps	100	1.00	2,000.0	\$364.00	10	1	Energy Star Rated, Dimmable 26w CFL Lamp	26	0.26	520	\$94.64	\$20.00	\$200.00	0.74	1480	\$269.36	0.74	
555		2000	2	1	Recessed Down Light, 65w BR30 Lamp	65	0.13	260.0	\$47.32	2	1	Energy Star Rated Dimmable 26w CFL Lamp	26	0.05	104	\$18.93	\$20.00	\$40.00	0.08	156	\$28.39	1.41	
121.21	Old Dressing Room - Lower	1200	5	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	78	0.39	468.0	\$85.18	5	2	Reballast & Relamp; Sylvania Lamp FO28/841/SS/ECO	50	0.25	300	\$54.60	\$80.00	\$400.00	0.14	168	\$30.58	13.08	
121.21		1200	2	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	78	0.16	187.2	\$34.07	2	2	Reballast & Relamp; Sylvania Lamp FO28/841/SS/ECO	50	0.10	120	\$21.84	\$80.00	\$160.00	0.06	67.2	\$12.23	13.08	
142.11	Old Dressing Room - Upper	1200	3	4	2x4, 4 Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	156	0.47	561.6	\$102.21	3	3	3 Lamp , 28w T8, Elect. Ballast, Specular Reflector; retrofit	72	0.22	259.2	\$47.17	\$100.00	\$300.00	0.25	302.4	\$55.04	5.45	
142.11	Restroom	1200	1	4	2x4, 4 Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	156	0.16	187.2	\$34.07	1	3	3 Lamp , 28w T8, Elect. Ballast, Specular Reflector; retrofit	72	0.07	86.4	\$15.72	\$100.00	\$100.00	0.08	100.8	\$18.35	5.45	
555	Stairway to Dressing Rooms	1200	2	1	Recessed Down Light, 65w BR30 Lamp	65	0.13	156.0	\$28.39	2	1	Energy Star Rated Dimmable 26w CFL Lamp	26	0.05	62.4	\$11.36	\$20.00	\$40.00	0.08	93.6	\$17.04	2.35	
227.21	Lower Level Common Area	3000	4	2	2x2, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.26	780.0	\$141.96	4	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.20	588	\$107.02	\$24.00	\$96.00	0.06	192	\$34.94	2.75	
227.21	Hall	3000	3	2	2x2, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.20	585.0	\$106.47	3	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.15	441	\$80.26	\$24.00	\$72.00	0.05	144	\$26.21	2.75	
227.21	Concession	2000	5	2	2x2, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.33	650.0	\$118.30	5	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.25	490	\$89.18	\$24.00	\$120.00	0.08	160	\$29.12	4.12	
227.21	Eating Area	2000	3	2	2x2, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.20	390.0	\$70.98	3	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.15	294	\$53.51	\$24.00	\$72.00	0.05	96	\$17.47	4.12	
121.21	Kitchen	2000	5	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	78	0.39	780.0	\$141.96	5	2	Reballast & Relamp; Sylvania Lamp FO28/841/SS/ECO	50	0.25	500	\$91.00	\$80.00	\$400.00	0.14	280	\$50.96	7.85	
127.15	Stairway to Lower Theaters	3000	1	2	2x2, 2 Lamp, 34w T12, Mag. Ballast, Surface Mnt., White Lens	65	0.07	195.0	\$35.49	1	2	2x2, 2 Lamp, 14w T5, Indirect; Fixture	31	0.03	93	\$16.93	\$215.00	\$215.00	0.03	102	\$18.56	11.58	
609	Men's Restroom	3000	1	10	Strip Light, (10) 40w G40 Lamp	400	0.40	1,200.0	\$218.40	1	2	Wall Mnt., 2 Lamp T8 28w, Prismatic lens	50	0.05	150	\$27.30	\$200.00	\$200.00	0.35	1050	\$191.10	1.05	
555		3000	5	1	Recessed Down Light, 65w BR30 Lamp	65	0.33	975.0	\$177.45	5	1	Energy Star Rated Dimmable 26w CFL Lamp	26	0.13	390	\$70.98	\$20.00	\$100.00	0.20	585	\$106.47	0.94	
609	Women's Restroom	3000	1	10	Strip Light, (10) 40w G40 Lamp	400	0.40	1,200.0	\$218.40	1	2	Wall Mnt., 2 Lamp T8 28w, Prismatic lens	50	0.05	150	\$27.30	\$200.00	\$200.00	0.35	1050	\$191.10	1.05	
555		3000	5	1	Recessed Down Light, 65w BR30 Lamp	65	0.33	975.0	\$177.45	5	1	Energy Star Rated Dimmable 26w CFL Lamp	26	0.13	390	\$70.98	\$20.00	\$100.00	0.20	585	\$106.47	0.94	
555	Cinema 3	2000	8	1	Recessed Down Light, 65w BR30 Lamp	65	0.52	1,040.0	\$189.28	8	1	Energy Star Rated Dimmable 26w CFL Lamp	26	0.21	416	\$75.71	\$20.00	\$160.00	0.31	624	\$113.57	1.41	
555	Projector Room	2000	2	1	Recessed Down Light, 65w BR30 Lamp	65	0.13	260.0	\$47.32	2	1	Energy Star Rated Dimmable 26w CFL Lamp	26	0.05	104	\$18.93	\$20.00	\$40.00	0.08	156	\$28.39	1.41	
555	Cinema 2	2000	2	1	Recessed Down Light, 65w BR30 Lamp	65	0.13	260.0	\$47.32	2	1	Energy Star Rated Dimmable 26w CFL Lamp	26	0.05	104	\$18.93	\$20.00	\$40.00	0.08	156	\$28.39	1.41	

## Investment Grade Lighting Audit

APPENDIX E  
3 of 7

### ECM #1: Lighting Upgrade - General

EXISTING LIGHTING										PROPOSED LIGHTING										SAVINGS			
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Lamps	Retro-Unit Description	Watts Used	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback	
555.1	Cinema 2	2000	7	1	Industrial Reflector, Down Light, 65w BR30 Lamp	65	0.46	910.0	\$165.62	7	1	Energy Star Rated Dimmable 26w CFL Lamp	26	0.18	364	\$66.25	\$20.00	\$140.00	0.27	546	\$99.37	1.41	
121.11	Projector Room	2000	3	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	78	0.23	468.0	\$85.18	3	2	Reballast & Relamp; Sylvania Lamp FO28/841/SS/ECO	50	0.15	300	\$54.60	\$100.00	\$300.00	0.08	168	\$30.58	9.81	
555.1	Cinema 1	2000	13	1	Industrial Reflector, Down Light, 65w BR30 Lamp	65	0.85	1,690.0	\$307.58	13	1	Energy Star Rated Dimmable 26w CFL Lamp	26	0.34	676	\$123.03	\$20.00	\$260.00	0.51	1014	\$184.55	1.41	
555		2000	2	1	Recessed Down Light, 65w BR30 Lamp	65	0.13	260.0	\$47.32	2	1	Energy Star Rated Dimmable 26w CFL Lamp	26	0.05	104	\$18.93	\$20.00	\$40.00	0.08	156	\$28.39	1.41	
227.21	Maintenance Corridor	3000	13	2	2x2, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.85	2,535.0	\$461.37	13	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.64	1911	\$347.80	\$24.00	\$312.00	0.21	624	\$113.57	2.75	
121.34	Boiler Room	1200	8	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Pendant Mnt., No Lens	78	0.62	748.8	\$136.28	8	2	Reballast & Relamp; Sylvania Lamp FO28/841/SS/ECO	50	0.40	480	\$87.36	\$80.00	\$640.00	0.22	268.8	\$48.92	13.08	
128.14	Storage 1	1200	1	2	8' Channel, 2 Lamp, 75w T12, Mag. Ballast, Surface Mnt., No Lens	142	0.14	170.4	\$31.01	1	4	(2) 8' Lamps to (4) 4' Lamps - 28w T8, Elect Ballast; retrofit	98	0.10	117.6	\$21.40	\$100.00	\$100.00	0.04	52.8	\$9.61	10.41	
128.14	Storage 2	1200	1	2	8' Channel, 2 Lamp, 75w T12, Mag. Ballast, Surface Mnt., No Lens	142	0.14	170.4	\$31.01	1	4	(2) 8' Lamps to (4) 4' Lamps - 28w T8, Elect Ballast; retrofit	98	0.10	117.6	\$21.40	\$100.00	\$100.00	0.04	52.8	\$9.61	10.41	
121.31		1200	2	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Pendant Mnt., Prismatic Lens	78	0.16	187.2	\$34.07	2	2	Reballast & Relamp; Sylvania Lamp FO28/841/SS/ECO	50	0.10	120	\$21.84	\$80.00	\$160.00	0.06	67.2	\$12.23	13.08	
622	Exterior	4400	6	1	Double Head Flood, (2) 90w PAR Lamps	180	1.08	4,752.0	\$864.86	6	1	70w MH Wallpack	80	0.48	2112	\$384.38	\$185.00	\$1,110.00	0.60	2640	\$480.48	2.31	
Totals			250	197				74,697	\$13,595	250	160			12.3	28,798	\$5,241		\$15,837	19.3	45,722	\$8,321	1.90	

CEG Job #: 9C10088  
Project: Williams Center  
Address: 15 Sylvan St  
Rutherford NJ  
Building SF: 39,144

Williams Center

KWH COST: \$0.182

## ECM #2: Lighting Controls

EXISTING LIGHTING										PROPOSED LIGHTING CONTROLS												SAVINGS			
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Cont.	Controls Description	Watts Used	Total kW	Reduction (%)	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback		
626	Atrium	3000	10	8	Strip Light, (8) 40w G40 Lamp	320	3.2	9600	\$1,747.20	10	1	Daylight Sensor (Sensorswitch PP-20 & CM-PC or equal)	320	1.92	40%	5760	\$1,048.32	\$400.00	\$400.00	1.28	3840	\$698.88	0.57		
626	2nd Floor Concourse	3000	11	8	Strip Light, (8) 40w G40 Lamp	320	3.52	10560	\$1,921.92	11	1	Daylight Sensor (Sensorswitch PP-20 & CM-PC or equal)	320	2.11	40%	6336	\$1,153.15	\$400.00	\$400.00	1.41	4224	\$768.77	0.52		
555	Movie Theater	2000	20	1	Recessed Down Light, 65w BR30 Lamp	65	1.3	2600	\$473.20	20	0	No Change	65	1.30	0%	2600	\$473.20	\$0.00	\$0.00	0.00	0	\$0.00	0.00		
227.21	Stairwell	3000	1	2	2x2, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.065	195	\$35.49	1	0	No Change	65	0.07	0%	195	\$35.49	\$0.00	\$0.00	0.00	0	\$0.00	0.00		
122.21	Maintenance	1000	3	2	2x4, 2-Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	78	0.234	234	\$42.59	3	0	No Change	78	0.23	0%	234	\$42.59	\$0.00	\$0.00	0.00	0	\$0.00	0.00		
142.21	Boiler Room	1200	2	4	2x4, 4 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	156	0.312	374.4	\$68.14	2	0	No Change	156	0.31	0%	374.4	\$68.14	\$0.00	\$0.00	0.00	0	\$0.00	0.00		
221.11		1200	2	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.124	148.8	\$27.08	2	0	No Change	62	0.12	0%	148.8	\$27.08	\$0.00	\$0.00	0.00	0	\$0.00	0.00		
232.22	Office	2600	8	3	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Parabolic Lens	86	0.688	1788.8	\$325.56	8	1	Dual Technology Occupancy Sensor - Switch Mnt.	86	0.55	20%	1431.04	\$260.45	\$125.00	\$125.00	0.14	357.76	\$65.11	1.75		
247.22		2600	1	4	2x2, 4 Lamp, 17w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	68	0.068	176.8	\$32.18	1			68	0.05	20%	141.44	\$25.74			0.01	35.36	\$6.44			
612	Mech Room	1000	4	1	Pendant Mnt., 100w A19 Lamp	100	0.4	400	\$72.80	4	0	No Change	100	0.40	0%	400	\$72.80	\$0.00	\$0.00	0.00	0	\$0.00	0.00		
555	Small Office	2600	6	1	Recessed Down Light, 65w BR30 Lamp	65	0.39	1014	\$184.55	6	1	Dual Technology Occupancy Sensor - Switch Mnt.	65	0.31	20%	811.2	\$147.64	\$125.00	\$125.00	0.08	202.8	\$36.91	2.24		
564		2600	4	1	Track Head, 50w R20	50	0.2	520	\$94.64	4			50	0.16	20%	416	\$75.71	\$125.00	\$0.00	0.04	104	\$18.93			
121.14	Elevator Car	8760	1	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Surface Mnt., No Lens	78	0.078	683.28	\$124.36	1	0	No Change	78	0.08	0%	683.28	\$124.36	\$0.00	\$0.00	0.00	0	\$0.00	0.00		
609	Men's Restroom	3000	1	10	Strip Light, (10) 40w G40 Lamp	400	0.4	1200	\$218.40	1	1	Dual Technology Occupancy Sensor	400	0.32	20%	960	\$174.72	\$450.00	\$450.00	0.08	240	\$43.68	5.68		

**ECM #2: Lighting Controls**

EXISTING LIGHTING										PROPOSED LIGHTING CONTROLS										SAVINGS			
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Cont.	Controls Description	Watts Used	Total kW	Reduction (%)	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback
555	Women's Restroom	3000	5	1	Recessed Down Light, 65w BR30 Lamp	65	0.325	975	\$177.45	5	1	Occupancy Sensor - Remote Mnt.	65	0.26	20%	780	\$141.96	\$450.00	\$0.00	0.07	195	\$35.49	5.68
609		3000	1	10	Strip Light, (10) 40w G40 Lamp	400	0.4	1200	\$218.40	1		Dual Technology Occupancy Sensor - Remote Mnt.	400	0.32	20%	960	\$174.72		\$450.00	0.08	240	\$43.68	
555		3000	5	1	Recessed Down Light, 65w BR30 Lamp	65	0.325	975	\$177.45	5			65	0.26	20%	780	\$141.96		\$0.00	0.07	195	\$35.49	
122.11	Dressing Area	1200	2	2	2x4, 2-Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	78	0.156	187.2	\$34.07	2	0	No Change	78	0.16	0%	187.2	\$34.07	\$0.00	\$0.00	0.00	0	\$0.00	0.00
142.11	Dressing Area Restroom	1200	1	4	2x4, 4 Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	156	0.156	187.2	\$34.07	1	0	No Change	156	0.16	0%	187.2	\$34.07	\$0.00	\$0.00	0.00	0	\$0.00	0.00
627		1200	1	3	Strip Light, (3) 40w G40 Lamp	120	0.12	144	\$26.21	1	0	No Change	120	0.12	0%	144	\$26.21	\$0.00	\$0.00	0.00	0	\$0.00	0.00
142.11	Prop Room	1200	3	4	2x4, 4 Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	156	0.468	561.6	\$102.21	3	0	No Change	156	0.47	0%	561.6	\$102.21	\$0.00	\$0.00	0.00	0	\$0.00	0.00
628	Assembly Area	2000	4	1	500w Quartz Light	500	2	4000	\$728.00	4	0	No Change	500	2.00	0%	4000	\$728.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
629		2000	7	1	Step Light 20w	20	0.14	280	\$50.96	7	0	No Change	20	0.14	0%	280	\$50.96	\$0.00	\$0.00	0.00	0	\$0.00	0.00
630		2000	1	48	Hanging Chandelier, (48) 75w A Lamp	3600	3.6	7200	\$1,310.40	1	0	No Change	3600	3.60	0%	7200	\$1,310.40	\$0.00	\$0.00	0.00	0	\$0.00	0.00
628	Stage	2000	2	1	500w Quartz Light	500	1	2000	\$364.00	2	0	No Change	500	1.00	0%	2000	\$364.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
629	Ramp/Walkway	2000	8	1	Step Light 20w	20	0.16	320	\$58.24	8	0	No Change	20	0.16	0%	320	\$58.24	\$0.00	\$0.00	0.00	0	\$0.00	0.00
555		2000	7	1	Recessed Down Light, 65w BR30 Lamp	65	0.455	910	\$165.62	7	0	No Change	65	0.46	0%	910	\$165.62	\$0.00	\$0.00	0.00	0	\$0.00	0.00
628		2000	1	1	500w Quartz Light	500	0.5	1000	\$182.00	1	0	No Change	500	0.50	0%	1000	\$182.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
555	Control Room	2000	2	1	Recessed Down Light, 65w BR30 Lamp	65	0.13	260	\$47.32	2	0	No Change	65	0.13	0%	260	\$47.32	\$0.00	\$0.00	0.00	0	\$0.00	0.00

**ECM #2: Lighting Controls**

EXISTING LIGHTING										PROPOSED LIGHTING CONTROLS								SAVINGS					
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Cont.	Controls Description	Watts Used	Total kW	Reduction (%)	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback
611	Seating Area	2000	10	1	Wall Mnt. Globe, (1) 100w A19 Lamps	100	1	2000	\$364.00	10	0	No Change	100	1.00	0%	2000	\$364.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
555		2000	2	1	Recessed Down Light, 65w BR30 Lamp	65	0.13	260	\$47.32	2	0	No Change	65	0.13	0%	260	\$47.32	\$0.00	\$0.00	0.00	0	\$0.00	0.00
121.21	Old Dressing Room - Lower	1200	5	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	78	0.39	468	\$85.18	5	0	No Change	78	0.39	0%	468	\$85.18	\$0.00	\$0.00	0.00	0	\$0.00	0.00
121.21		1200	2	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	78	0.156	187.2	\$34.07	2	0	No Change	78	0.16	0%	187.2	\$34.07	\$0.00	\$0.00	0.00	0	\$0.00	0.00
142.11	Old Dressing Room - Upper	1200	3	4	2x4, 4 Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	156	0.468	561.6	\$102.21	3	0	No Change	156	0.47	0%	561.6	\$102.21	\$0.00	\$0.00	0.00	0	\$0.00	0.00
142.11	Restroom	1200	1	4	2x4, 4 Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	156	0.156	187.2	\$34.07	1	0	No Change	156	0.16	0%	187.2	\$34.07	\$0.00	\$0.00	0.00	0	\$0.00	0.00
555	Stairway to Dressing Rooms	1200	2	1	Recessed Down Light, 65w BR30 Lamp	65	0.13	156	\$28.39	2	0	No Change	65	0.13	0%	156	\$28.39	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Lower Level Common Area	3000	4	2	2x2, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.26	780	\$141.96	4	0	No Change	65	0.26	0%	780	\$141.96	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Hall	3000	3	2	2x2, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.195	585	\$106.47	3	0	No Change	65	0.20	0%	585	\$106.47	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Concession	2000	5	2	2x2, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.325	650	\$118.30	5	0	No Change	65	0.33	0%	650	\$118.30	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Eating Area	2000	3	2	2x2, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.195	390	\$70.98	3	0	No Change	65	0.20	0%	390	\$70.98	\$0.00	\$0.00	0.00	0	\$0.00	0.00
121.21	Kitchen	2000	5	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	78	0.39	780	\$141.96	5	0	No Change	78	0.39	0%	780	\$141.96	\$0.00	\$0.00	0.00	0	\$0.00	0.00
127.15	Stairway to Lower Theaters	3000	1	2	2x2, 2 Lamp, 34w T12, Mag. Ballast, Surface Mnt., White Lens	65	0.065	195	\$35.49	1	0	No Change	65	0.07	0%	195	\$35.49	\$0.00	\$0.00	0.00	0	\$0.00	0.00
609	Men's Restroom	3000	1	10	Strip Light, (10) 40w G40 Lamp	400	0.4	1200	\$218.40	1	1	Dual Technology Occupancy Sensor - Remote Mnt.	400	0.32	20%	960	\$174.72	\$900.00	\$900.00	0.08	240	\$43.68	11.37
555		3000	5	1	Recessed Down Light, 65w BR30 Lamp	65	0.325	975	\$177.45	5			65	0.26	20%	780	\$141.96			0.07	195	\$35.49	

**ECM #2: Lighting Controls**

EXISTING LIGHTING										PROPOSED LIGHTING CONTROLS											SAVINGS			
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Cont.	Controls Description	Watts Used	Total kW	Reduction (%)	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback	
609	Women's Restroom	3000	1	10	Strip Light, (10) 40w G40 Lamp	400	0.4	1200	\$218.40	1	1	Dual Technology Occupancy Sensor - Remote Mnt.	400	0.32	20%	960	\$174.72	\$900.00	\$900.00	0.08	240	\$43.68	11.37	
555		3000	5	1	Recessed Down Light, 65w BR30 Lamp	65	0.325	975	\$177.45	5			65	0.26	20%	780	\$141.96			0.07	195	\$35.49		
555	Cinema 3	2000	8	1	Recessed Down Light, 65w BR30 Lamp	65	0.52	1040	\$189.28	8	0	No Change	65	0.52	0%	1040	\$189.28	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
555	Projector Room	2000	2	1	Recessed Down Light, 65w BR30 Lamp	65	0.13	260	\$47.32	2	0	No Change	65	0.13	0%	260	\$47.32	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
555	Cinema 2	2000	2	1	Recessed Down Light, 65w BR30 Lamp	65	0.13	260	\$47.32	2	0	No Change	65	0.13	0%	260	\$47.32	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
555.1		2000	7	1	Industrial Reflector, Down Light, 65w BR30 Lamp	65	0.455	910	\$165.62	7	0	No Change	65	0.46	0%	910	\$165.62	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
121.11	Projector Room	2000	3	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	78	0.234	468	\$85.18	3	0	No Change	78	0.23	0%	468	\$85.18	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
555.1	Cinema 1	2000	13	1	Industrial Reflector, Down Light, 65w BR30 Lamp	65	0.845	1690	\$307.58	13	0	No Change	65	0.85	0%	1690	\$307.58	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
555		2000	2	1	Recessed Down Light, 65w BR30 Lamp	65	0.13	260	\$47.32	2	0	No Change	65	0.13	0%	260	\$47.32	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
227.21	Maintenance Corridor	3000	13	2	2x2, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.845	2535	\$461.37	13	0	No Change	65	0.85	0%	2535	\$461.37	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
121.34	Boiler Room	1200	8	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Pendant Mnt., No Lens	78	0.624	748.8	\$136.28	8	0	No Change	78	0.62	0%	748.8	\$136.28	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
128.14	Storage 1	1200	1	2	8' Channel, 2 Lamp, 75w T12, Mag. Ballast, Surface Mnt., No Lens	142	0.142	170.4	\$31.01	1	0	No Change	142	0.14	0%	170.4	\$31.01	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
128.14	Storage 2	1200	1	2	8' Channel, 2 Lamp, 75w T12, Mag. Ballast, Surface Mnt., No Lens	142	0.142	170.4	\$31.01	1	0	No Change	142	0.14	0%	170.4	\$31.01	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
121.31		1200	2	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Pendant Mnt., Prismatic Lens	78	0.156	187.2	\$34.07	2	0	No Change	78	0.16	0%	187.2	\$34.07	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
622	Exterior	4400	6	1	Double Head Flood, (2) 90w PAR Lamps	180	1.08	4752	\$864.86	6	0	No Change	180	1.08	0%	4752	\$864.86	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
	Totals		250	197			31.7	74,696.9	\$13,595	250	8			28.1		64,193.0	\$11,683.12		\$3,750	3.54	10,504	\$1,912	1.96	

Project Name: LGEA Solar PV Project - Williams Center							
Location: Rutherford, NJ							
Description: Photovoltaic System - Direct Purchase							
Simple Payback Analysis							
		Photovoltaic System - Direct Purchase					
Total Construction Cost		\$101,430					
Annual kWh Production		14,185					
Annual Energy Cost Reduction		\$2,582					
Annual SREC Revenue		\$4,965					
First Cost Premium		\$101,430					
Simple Payback:		13.44					Years
Life Cycle Cost Analysis							
Analysis Period (years):		25		Financing %:		0%	
Financing Term (mths):		0		Maintenance Escalation Rate:		3.0%	
Average Energy Cost (\$/kWh)		\$0.182		Energy Cost Escalation Rate:		3.0%	
Financing Rate:		0.00%		SREC Value (\$/kWh)		\$0.350	
Period	Additional Cash Outlay	Energy kWh Production	Energy Cost Savings	Additional Maint Costs	SREC Revenue	Net Cash Flow	Cumulative Cash Flow
0	\$101,430	0	0	0	\$0	(101,430)	0
1	\$0	14,185	\$2,582	\$0	\$4,965	\$7,546	(\$93,884)
2	\$0	14,114	\$2,659	\$0	\$4,940	\$7,599	(\$86,285)
3	\$0	14,044	\$2,739	\$0	\$4,915	\$7,654	(\$78,630)
4	\$0	13,973	\$2,821	\$0	\$4,891	\$7,712	(\$70,919)
5	\$0	13,903	\$2,906	\$143	\$4,866	\$7,629	(\$63,290)
6	\$0	13,834	\$2,993	\$142	\$4,842	\$7,692	(\$55,598)
7	\$0	13,765	\$3,083	\$142	\$4,818	\$7,759	(\$47,839)
8	\$0	13,696	\$3,175	\$141	\$4,794	\$7,828	(\$40,012)
9	\$0	13,627	\$3,270	\$140	\$4,770	\$7,900	(\$32,112)
10	\$0	13,559	\$3,368	\$140	\$4,746	\$7,975	(\$24,137)
11	\$0	13,491	\$3,470	\$139	\$4,722	\$8,053	(\$16,085)
12	\$0	13,424	\$3,574	\$138	\$4,698	\$8,134	(\$7,951)
13	\$0	13,357	\$3,681	\$138	\$4,675	\$8,218	\$267
14	\$0	13,290	\$3,791	\$137	\$4,652	\$8,306	\$8,573
15	\$0	13,224	\$3,905	\$136	\$4,628	\$8,397	\$16,970
16	\$0	13,158	\$4,022	\$136	\$4,605	\$8,492	\$25,462
17	\$0	13,092	\$4,143	\$135	\$4,582	\$8,590	\$34,052
18	\$0	13,026	\$4,267	\$134	\$4,559	\$8,692	\$42,744
19	\$0	12,961	\$4,395	\$134	\$4,536	\$8,798	\$51,542
20	\$0	12,896	\$4,527	\$133	\$4,514	\$8,908	\$60,450
21	\$1	12,832	\$4,663	\$132	\$4,491	\$9,022	\$69,472
22	\$2	12,768	\$4,803	\$132	\$4,469	\$9,140	\$78,612
23	\$3	12,704	\$4,947	\$131	\$4,446	\$9,262	\$87,874
24	\$4	12,640	\$5,095	\$130	\$4,424	\$9,389	\$97,263
25	\$5	12,577	\$5,248	\$130	\$4,402	\$9,520	\$106,784
Totals:		334,141	\$94,126	\$2,862	\$116,949	\$208,214	\$63,324
Net Present Value (NPV)						\$106,809	
Internal Rate of Return (IRR)						6.2%	

Building	Roof Area (sq ft)	Panel	Qty	Panel Sq Ft	Panel Total Sq Ft	Total KW <sub>DC</sub>	Total Annual kWh	Panel Weight (33 lbs)	W/SQFT
Bergen County Williams Center	800	Sunpower SPR230	49	14.7	721	11.27	14,185	1,617	15.64



[Red Rectangle] = Proposed PV Layout

Notes:

1. Estimated kWh based on the National Renewable Energy Laboratory PVWatts Version 1 Calculator Program.





## AC Energy & Cost Savings



(Type comments here to appear on printout; maximum 1 row of 80 characters.)

Station Identification	
City:	Atlantic_City
State:	New_Jersey
Latitude:	39.45° N
Longitude:	74.57° W
Elevation:	20 m
PV System Specifications	
DC Rating:	11.3 kW
DC to AC Derate Factor:	0.810
AC Rating:	9.1 kW
Array Type:	Fixed Tilt
Array Tilt:	15.0°
Array Azimuth:	180.0°
Energy Specifications	
Cost of Electricity:	11.2 ¢/kWh

Results			
Month	Solar Radiation (kWh/m <sup>2</sup> /day)	AC Energy (kWh)	Energy Value (\$)
1	2.80	805	90.16
2	3.53	922	103.26
3	4.46	1248	139.78
4	5.28	1395	156.24
5	5.86	1572	176.06
6	6.10	1520	170.24
7	6.05	1542	172.70
8	5.60	1432	160.38
9	4.99	1255	140.56
10	3.97	1054	118.05
11	2.86	762	85.34
12	2.43	678	75.94
Year	4.50	14185	1588.72

Output Hourly Performance Data

[About the Hourly Performance Data](#)

Output Results as Text

[Saving Text from a Browser](#)

Run [PVWATTS v.1](#) for another US location or an International location  
Run [PVWATTS v.2](#) (US only)

Please send questions and comments regarding PVWATTS to [Webmaster](#)

[Disclaimer and copyright notice](#)