

**LOCAL GOVERNMENT  
ENERGY AUDIT PROGRAM:  
HIGHLAND HIGH SCHOOL  
ENERGY AUDIT REPORT**

**PREPARED FOR:**            **BLACK HORSE PIKE REGIONAL  
SCHOOL DISTRICT  
450 ERIAL ROAD  
BLACKWOOD, NJ 08012  
ATTN: MS. JEAN GRUBB, CPA, SBA**

**PREPARED BY:**            **CONCORD ENGINEERING GROUP**  
 **520 S. BURNT MILL ROAD  
VOORHEES, NJ 08043  
TELEPHONE: (856) 427-0200  
FACSIMILE: (856) 427-6529  
[WWW.CEG-INC.NET](http://WWW.CEG-INC.NET)**

**CEG CONTACT:**            **JAMES GARDLER  
COMMISSIONING PROJECT MANAGER  
EMAIL: JGARDLER@CEG-INC.NET**

**REPORT ISSUANCE:**    **FINAL - APRIL 04, 2011**

**PROJECT No:**            **9C10098**

---

**TABLE OF CONTENTS**

I.	EXECUTIVE SUMMARY .....	3
II.	INTRODUCTION .....	13
III.	METHOD OF ANALYSIS.....	14
IV.	HISTORIC ENERGY CONSUMPTION/COST.....	16
A.	ENERGY USAGE / TARIFFS .....	16
B.	ENERGY USE INDEX (EUI).....	21
C.	EPA ENERGY BENCHMARKING SYSTEM.....	23
V.	FACILITY DESCRIPTION .....	24
VI.	MAJOR EQUIPMENT LIST .....	27
VII.	ENERGY CONSERVATION MEASURES.....	28
VIII.	RENEWABLE/DISTRIBUTED ENERGY MEASURES .....	69
IX.	ENERGY PURCHASING AND PROCUREMENT STRATEGY .....	72
X.	INSTALLATION FUNDING OPTIONS.....	72
XI.	ADDITIONAL RECOMMENDATIONS .....	81

Appendix A – ECM Cost & Savings Breakdown

Appendix B – New Jersey Smart Start<sup>®</sup> Program Incentives

Appendix C – Portfolio Manager “Statement of Energy Performance”

Appendix D – Major Equipment List

Appendix E – Investment Grade Lighting Audit

Appendix F – Renewable / Distributed Energy Measures Calculations

Appendix G – Kitchen Hood Controls Calculations

## **REPORT DISCLAIMER**

The information contained within this report, including any attachment(s), is intended solely for use by the named addressee(s). If you are not the intended recipient, or a person designated as responsible for delivering such messages to the intended recipient, you are not authorized to disclose, copy, distribute or retain this report, in whole or in part, without written authorization from Concord Engineering Group, Inc., 520 S. Burnt Mill Road, Voorhees, NJ 08043.

This report may contain proprietary, confidential or privileged information. If you have received this report in error, please notify the sender immediately. Thank you for your anticipated cooperation.

## I. EXECUTIVE SUMMARY

This report presents the findings of the energy audit conducted for:

Highland Regional High School  
450 Erial Road  
Blackwood, NJ 08012

District Contact Person: Jean Grubb, CPA, SBA  
Facility Contact Person: Bill Collins

This audit is performed in connection with the New Jersey Clean Energy - Local Government Energy Audit Program. The energy audit is conducted to promote the mission of the office of Clean Energy, which is to use innovation and technology to solve energy and environmental problems in a way that improves the State's economy. This can be achieved through the wiser and more efficient use of energy.

The annual energy costs at this facility are as follows:

Electricity	\$ 235,319
Natural Gas	\$ 113,814
<hr/>	
Total	\$ 349,133

The potential annual energy cost savings for each energy conservation measure (ECM) and renewable energy measure (REM) are shown below in Table 1. Be aware that the ECM's and REM's are not additive because of the interrelation of some of the measures. This audit is consistent with an ASHRAE level 2 audit. The cost and savings for each measure is  $\pm 20\%$ . The evaluations are based on engineering estimations and industry standard calculation methods. More detailed analyses would require engineering simulation models, hard equipment specifications, and contractor bid pricing.

**Table 1**  
**Financial Summary Table**

<b>ENERGY CONSERVATION MEASURES (ECM's)</b>					
<b>ECM NO.</b>	<b>DESCRIPTION</b>	<b>NET INSTALLATION COST<sup>A</sup></b>	<b>ANNUAL SAVINGS<sup>B</sup></b>	<b>SIMPLE PAYBACK (Yrs)</b>	<b>SIMPLE LIFETIME ROI</b>
ECM #1	Lighting Upgrade	\$38,672	\$10,509	3.7	307.6%
ECM #2	Lighting Controls	\$36,645	\$10,847	3.4	344.0%
ECM #3	Computer Monitor Replacement	\$10,200	\$2,313	4.4	240.1%
ECM #4	Condensing Boiler Installation	\$410,428	\$16,953	24.2	23.9%
ECM #5	AC Unit Replacement	\$212,358	\$6,235	34.1	-56.0%
ECM #6	Library AC Unit Upgrade	\$72,181	\$6,196	11.6	28.8%
ECM #7	Cafeteria AC Unit Controls Upgrade	\$23,988	\$4,786	5.0	199.3%
ECM #8	Water Cooled CU Replacement	\$156,985	\$11,698	13.4	11.8%
ECM #9	Water Conservation	\$52,124	\$2,516	20.7	44.8%
ECM #10	Premium Efficiency Motors	\$12,806	\$1,441	8.9	102.5%
ECM #11	Valve Blanket Insulation	\$10,000	\$554	18.1	33.0%
ECM #12	Kitchen Hood Controls	\$10,671	\$564	18.9	-20.7%
<b>RENEWABLE ENERGY MEASURES (REM's)</b>					
<b>ECM NO.</b>	<b>DESCRIPTION</b>	<b>NET INSTALLATION COST</b>	<b>ANNUAL SAVINGS</b>	<b>SIMPLE PAYBACK (Yrs)</b>	<b>SIMPLE LIFETIME ROI</b>
REM #1	PV Solar	\$7,903,260	\$532,509	14.8	68.4%
<b>Notes:</b>	A. Cost takes into consideration applicable NJ Smart Start <sup>TM</sup> incentives.				
	B. Savings takes into consideration applicable maintenance savings.				

The estimated demand and energy savings for each ECM and REM is shown below in Table 2. The descriptions in this table correspond to the ECM's and REM's listed in Table 1.

**Table 2**  
**Estimated Energy Savings Summary Table**

<b>ENERGY CONSERVATION MEASURES (ECM's)</b>				
<b>ECM NO.</b>	<b>DESCRIPTION</b>	<b>ANNUAL UTILITY REDUCTION</b>		
		<b>ELECTRIC DEMAND (KW)</b>	<b>ELECTRIC CONSUMPTION (KWH)</b>	<b>NATURAL GAS (THERMS)</b>
ECM #1	Lighting Upgrade	25.8	77844.0	0.0
ECM #2	Lighting Controls	31.1	80350.0	0.0
ECM #3	Computer Monitor Replacement	0.0	17136.0	0.0
ECM #4	Condensing Boiler Installation	0.0	0.0	15697.0
ECM #5	AC Unit Replacement	46.2	46185.0	0.0
ECM #6	Library AC Unit Upgrade	1.0	40749.0	643.0
ECM #7	Cafeteria AC Unit Controls Upgrade	0.0	27360.0	1012.0
ECM #8	Water Cooled CU Replacement	7.0	5583.0	0.0
ECM #9	Water Conservation	0.0	0.0	0.0
ECM #10	Premium Efficiency Motors	2.5	10677.0	0.0
ECM #11	Valve Blanket Insulation	0.0	0.0	513.0
ECM #12	Kitchen Hood Controls	0.0	1339.0	355.0
<b>RENEWABLE ENERGY MEASURES (REM's)</b>				
<b>ECM NO.</b>	<b>DESCRIPTION</b>	<b>ANNUAL UTILITY REDUCTION</b>		
		<b>ELECTRIC DEMAND (KW)</b>	<b>ELECTRIC CONSUMPTION (KWH)</b>	<b>NATURAL GAS (THERMS)</b>
REM #1	PV Solar	878.1	1097957.0	0.0

### **Fast Payback Energy Conservation Measures:**

The Energy Conservation Measures (ECMs) identified within the report represent the potential annual energy and cost savings at the facility resulting from our energy audit. It is recommended to consider all ECMs as part of the School District's initiative to save energy, reduce emissions, and lower operating costs. Several ECMs shown within this report represent significant savings relative to the cost to implement. The ECMs shown with a simple payback of 10 years and less are considered very cost effective and should be considered a high priority for the District. The following ECMs are highly recommended:

- **Lighting Upgrades**

Lighting retrofits throughout the School District are a straight forward conservation measure that is prescriptive in nature and provides substantial savings for the investment. Lighting retrofits are a good example of ECMs that can be implemented with "in house" staff to reduce the installation cost and further reduce paybacks. Throughout most of the school the measure includes replacing existing 700 series T-8 fluorescent lamps with new higher efficiency T-8 lamps. This upgrade also includes installation of high bay T-5 fixtures to replace the existing metal halide fixtures found in the gymnasium and auditorium. In addition it is recommended to utilize CFL lamps in lieu of all existing incandescent lamps throughout the School District. Overall lighting upgrades represent one of the most easily implemented ECMs and are highly recommended for all facilities.

- **Lighting Controls**

Similar to lighting upgrades, lighting controls are very simple upgrades and can save considerable energy. Lighting controls do not require replacement of the fixture and typically can save more energy than lighting upgrades alone. For the purpose of this energy audit, each ECM is calculated as stand-alone ECMs. The maximum savings can be achieved through the implementation of both the lighting upgrades and lighting controls ECMs. Lighting controls will automatically turn off lights when spaces and rooms are not occupied. It is important to note that ECMs are calculated as stand-alone ECMs and therefore the total savings will be slightly less than the sum of both individual ECMs (Lighting Upgrade and Lighting Controls). The discrepancy between additive ECMs is within the tolerances for this level of analysis (+/- 20%). Lighting controls provide the maximum savings in spaces that have changing occupancy schedules throughout the day such as the classrooms after school hours, labs, music rooms, media centers, etc. Lighting controls is highly recommended in addition to the lighting upgrade ECMs.

- **Computer Monitor Replacement**

Plug loads within buildings are becoming a larger and larger portion of the total energy use in all types of facilities. Plug loads are most dominant in combination with computers and computer equipment. Modern computer monitors are flat screen LCD panels that are far more efficient than older style cathode ray-tube (CRT) monitors. Typical energy use of a flat screen monitor is approximately 1/3 of the energy used by a CRT monitor. A large portion of the computer

monitors throughout the District are CRT style monitors. This represents a significant energy savings potential. It is highly recommended to replace the existing CRT monitors with flat screen monitors to take advantage of the energy savings as well as other ergonomic benefits of modern LCD monitors.

- Cafeteria AC Units Controls Upgrade

A programmed schedule would provide energy savings by allowing the building automation system to setback the temperature setting when the space is not occupied and returning to the normal temperature setting when the space is occupied. The major benefit of this ECM is in the heating season since the outside temperature is the coldest during unoccupied periods. In night setback, the overall energy use is reduced since the inside temperature is kept closer to the outside temperature which limits heat loss.

- Premium Efficiency Motors

The improved efficiency of the NEMA Premium® efficient motors in comparison to standard efficiency type is primarily due to improved designs with use of better materials to reduce losses. The existing fans and pumps at the school are configured primarily with standard efficiency motors. These standard efficiency motors run a considerable amount of time over a one year time period. Replacing the existing standard efficiency motors with NEMA Premium® efficiency models yields significant energy savings. This ECM is a one-for-one style replacement with dependable savings that is based on a simple calculation. In addition to the savings, this ECM provides new motors for a variety of existing equipment.

### **Capital Improvement Energy Conservation Measures:**

The ECMs that have much longer paybacks are considered capital improvement ECMs. These ECMs typically have high installation costs that are more difficult to justify the savings based solely on the energy savings associated with the improvement. Despite the long paybacks, these ECMs in many cases provide valuable and much needed infrastructure improvements for the facility. These ECMs include boiler upgrades, HVAC equipment upgrades, etc. The savings identified for the following ECMs provides additional incentive for the district's capital improvement projects.

- Condensing Boilers

Boiler replacements are one of the most significant HVAC system upgrades for a facility. The installation of condensing boilers provides a heating efficiency increase ranging from 10% to 15% over boilers of non-condensing type and an even greater savings potential over existing equipment found in the School. Even with this significant increase in efficiency the simple payback for a condensing boiler ECM is still greater than 15 years, depending on the boiler capacity and installation difficulty, due to the complexity of upgrading a major infrastructure component of the School. This ECM represents the most substantial upfront cost which creates



long paybacks, but it is the most practical ECM to pursue due to the potential long term energy and maintenance savings that can be realized.

- AC Unit Upgrades

High efficiency AC unit installations will typically have high installation costs. However, the savings over time can be substantial. The simple payback for AC unit upgrades range between 25 years and 30 years depending on the existing equipment efficiency, runtime, and size / installation cost. Similar to most capital improvement projects, the energy savings alone does not justify the installation. The benefit of replacing the aging AC systems with new equipment provides value through avoided costs (i.e. maintenance, replacement, operational, refrigerant availability and disposal, etc.) that would otherwise burden the School District and should not be overlooked.

- Library AC Unit Upgrade

The library for this school is conditioned by a 50-Ton packaged rooftop unit. It is equipped with direct expansion cooling and hot water heat. The unit was originally designed to operate as a variable volume system with terminal boxes and electric reheat located above the ceiling serving independent zones. This system has since been overridden and the unit now operates as a constant volume system with the terminal boxes held in the full open position. This ECM would bring the packaged rooftop unit back to its original functionality by having it operate as a variable air volume system including the proper operation of the compressors. Demand controlled ventilation would be added to the sequences of operation to adjust the amount of outdoor air provided to the space based on actual occupancy. The existing terminal boxes with reheat would be removed and replaced with terminal boxes with hot water coils.

- Water Cooled CU Replacement

Portions of Corridor A at the high school are cooled by direct expansion, indoor, water-cooled condensing systems. The cooling media is from the domestic water supply and the waste water discharges to the sanitary system. Usually, energy savings derived from replacing condensing units does not justify a reasonable payback term. Nevertheless, as the equipment ages, it loses efficiency due to clogged condensers, internal parts wear and deposits of oil and other contaminants on the heat exchangers. Replacing an older condensing unit avoids these issues along with some energy savings. The new direct expansion system will not require the consumption of domestic water which yields considerable cost savings.

- Water Conservation

The typical water closet and urinal water consumption only meet the minimum federally required standard for water efficiency. The existing urinals are automatically flushed by a time clock device that cycle every 15 minutes for a total of 28 flushes per day per urinal. New fixtures are available that use less water than today's requirements and can add up to significant water reduction over a long period.

- Hot Water Valve Blanket Insulation

Hot Water piping insulation is a valuable asset to avoid the loss of heat from the boiler system. Large diameter bare steel pipe can account for significant energy loss over an entire heating system. Since the piping remains hot 24/7, bare pipe heat losses are multiplied by the entire operating hours of the heating system. Pipe & valve insulation reduces the loss compared to bare pipe by a factor of 10 or more. Pipe insulation becomes deteriorated over time due to the repair of pipe / fitting leaks and service of components.

- Kitchen Hood Controls

Kitchen hood controls allow the exhaust air through the commercial kitchen hood to reduce with respect to the level of heat and smoke produced by the kitchen cooking equipment. This ECM provides savings on fan motors as well as energy required to heat and cool the make-up air exhausted by the hood. The savings is extremely dependent on the operating hours of the kitchen hood exhaust fan. Based on the survey and discussions with the operating staff, it was determined that the kitchen exhaust was operating for many hours beyond the needs of the cooking equipment.

**Combined Project Approach:**

Although only individual projects with a simple payback of 10 years and less are considered financially self sustaining, it is important to consider how multiple projects can be combined together. When ECMs are aggregated into a single project, the lower cost ECMs provide valuable savings to offset the higher cost ECMs. Likewise when multiple facilities are aggregated together into a single entity energy efficiency project, the same benefits are seen on a larger scale.

**Table 3  
Combined Project Summary**

COMBINED PROJECT APPROACH SUMMARY TABLE						
ECM NO.	DESCRIPTION	ANNUAL ENERGY SAVINGS (\$)	PROJECT COST (\$)	SMART START INCENTIVES	CUSTOMER COST	SIMPLE PAYBACK
ECM #1	Lighting Upgrade	\$10,509	\$57,752	\$19,080	\$38,672	3.7
ECM #2	Lighting Controls	\$10,847	\$41,800	\$5,155	\$36,645	3.4
ECM #3	Computer Monitor Replacement	\$2,313	\$10,200	\$0	\$10,200	4.4
ECM #4	Condensing Boiler Installation	\$16,953	\$421,638	\$11,210	\$410,428	24.2
ECM #6	Library AC Unit Upgrade	\$6,196	\$72,181	\$0	\$72,181	11.6
ECM #7	Cafeteria AC Unit Controls Upgrade	\$4,786	\$23,988	\$0	\$23,988	5.0
ECM #8	Water Cooled CU Replacement	\$11,698	\$158,825	\$1,840	\$156,985	13.4
ECM #9	Water Conservation	\$2,516	\$52,124	\$0	\$52,124	20.7
ECM #10	Premium Efficiency Motors	\$1,441	\$13,271	\$465	\$12,806	8.9
ECM #11	Valve Blanket Insulation	\$554	\$10,000	\$0	\$10,000	18.1
ECM #12	Kitchen Hood Controls	\$564	\$10,671	\$0	\$10,671	18.9
	<i>Design / Construction Extras (15%)</i>		<i>\$130,868</i>		<i>\$130,868</i>	
	<b>Total Project</b>	<b>\$68,377</b>	<b>\$1,003,318</b>	<b>\$37,750</b>	<b>\$965,568</b>	<b>14.1</b>

	<b>Total Highland High School Energy Costs:</b>	<b>\$349,133</b>
	<b>Est. Total Highland High School Energy Savings:</b>	<b>\$68,377</b>
	<b>Overall Highland High School Percent Reduction:</b>	<b>19.6%</b>

A funding mechanism that is available for large scale, combined projects is the E.S.I.P, P.L. 2009, c.4. The Energy Savings Improvement Program (ESIP) allows for financing of any combination of energy efficiency projects across multiple facilities into one large project. The term of the financing must be under 15 years and the savings provides the revenue for the financing cost. The combination of ECMs provides Black Horse Pike Regional School District with the opportunity to implement a large portion of the ECMs identified within Highland High

School with an overall simple payback of 13.1 years. The program financing allows for the implementation with no upfront cost for Blackhorse Regional School District. Implementation of an ESIP provides significant benefits and should be strongly considered for Highland High School. The Total Entity Project Summary table below shows the savings, costs, incentive programs and paybacks for all ECMs at Highland High School. Implementation of all ECMs identified within the table represents a total annual savings of approximately \$73,836 for Black Horse Pike Regional School District which is a 21.1% reduction in overall annual utility costs.

**Other Considerations:**

- Renewable Energy Measures

Renewable Energy Measures (REMs) were also reviewed for implementation at Highland High School. CEG utilized a roof and ground mounted solar array to house a substantial PV system. The recommended 878.14 kW PV system will produce approximately 1,097,957 kWh of electricity annually and will reduce the schools electrical consumption from the grid by 63%. The system's calculated simple payback of 14.8 years is past the standard 10 year simple payback threshold; however, with alternative funding this payback could be lessened. CEG recommends the Owner review all funding options before deciding to not implement this renewable energy measure.

- Maintenance and Operational Measures

There are maintenance and operational measures that can provide significant energy savings and provide immediate benefit. The ECMs listed above represent investments that can be made to the facility which are justified by the savings seen overtime. However, the maintenance items and small operational improvements below are typically achievable with on site staff or maintenance contractors and in turn have the potential to provide substantial operational savings compared to the costs associated. The following are recommendations which should be considered a priority in achieving an energy efficient building:

- Chemically clean the condenser and evaporator coils periodically to optimize efficiency. Poorly maintained heat transfer surfaces can reduce efficiency 5-10%.
- Maintain all weather stripping on entrance doors.
- Clean all light fixtures to maximize light output.
- Provide more frequent air filter changes to decrease overall system power usage and maintain better IAQ.

- Retro-Commissioning

Based on the review of the facility's energy bills and discussions with the School District, the energy audit team recommends Retro-Commissioning of this facility to meet the following objectives:

- Bring existing HVAC equipment to its proper operational state including air and water distribution systems

- Reduce energy use and energy costs
- Improve indoor air quality
- Verify the installation and performance of identified system upgrades
- Address overall building energy use and demand and identify areas of highest energy use and demand
- Identify the location of the most comfort problems or trouble spots in the building
- Review current O&M practices

Through the implementation of a Retro-Commissioning Plan, the School District will be able to continue with their vision of reducing energy usage and operating efficient facilities.

**Overall Assessment:**

There are numerous ECMs that can be implemented to further reduce energy use and save on the facility's operating costs. The total energy cost of \$349,133 could be reduced by approximately 21.1% through the implementation of the ECMs recommended in this audit. Highland High School is in a unique position to implement energy efficiency improvements and still include large capital projects. When the total project is capable of being funded through the savings, CEG highly recommends the School to take advantage of this opportunity.

## II. INTRODUCTION

The comprehensive energy audit covers the 220,065 square foot Highland High School, which includes the following spaces: gymnasium, cafeteria, library, various trade shops, administration offices, auditorium, classrooms, maintenance, computer labs, music suites, and kitchen.

Electrical and natural gas utility information is collected and analyzed for one full year's energy use of the building. The utility information allows for analysis of the building's operational characteristics; calculate energy benchmarks for comparison to industry averages, estimated savings potential, and baseline usage/cost to monitor the effectiveness of implemented measures. A computer spreadsheet is used to calculate benchmarks and to graph utility information (see the utility profiles below).

The Energy Use Index (EUI) is established for the building. Energy Use Index (EUI) is expressed in British Thermal Units/square foot/year (BTU/ft<sup>2</sup>/yr), which is used to compare energy consumption to similar building types or to track consumption from year to year in the same building. The EUI is calculated by converting the annual consumption of all energy sources to BTU's and dividing by the area (gross square footage) of the building. Blueprints (where available) are utilized to verify the gross area of the facility. The EUI is a good indicator of the relative potential for energy savings. A low EUI indicates less potential for energy savings, while a high EUI indicates poor building performance therefore a high potential for energy savings.

Existing building architectural and engineering drawings (where available) are utilized for additional background information. The building envelope, lighting systems, HVAC equipment, and controls information gathered from building drawings allow for a more accurate and detailed review of the building. The information is compared to the energy usage profiles developed from utility data. Through the review of the architectural and engineering drawings a building profile can be defined that documents building age, type, usage, major energy consuming equipment or systems, etc.

The preliminary audit information is gathered in preparation for the site survey. The site survey provides critical information in deciphering where energy is spent and opportunities exist within a facility. The entire site is surveyed to inventory the following to gain an understanding of how each facility operates:

- Building envelope (roof, windows, etc.)
- Heating, ventilation, and air conditioning equipment (HVAC)
- Lighting systems and controls
- Facility-specific equipment

The building site visit is performed to survey all major building components and systems. The site visit includes detailed inspection of energy consuming components. Summary of building occupancy schedules, operating and maintenance practices, and energy management programs provided by the building manager are collected along with the system and components to determine a more accurate impact on energy consumption.

### III. METHOD OF ANALYSIS

Post site visit work includes evaluation of the information gathered, researching possible conservation opportunities, organizing the audit into a comprehensive report, and making recommendations on HVAC, lighting and building envelope improvements. Data collected is processed using energy engineering calculations to anticipate energy usage for each of the proposed energy conservation measures (ECMs). The actual building's energy usage is entered directly from the utility bills provided by the owner. The anticipated energy usage is compared to the historical data to determine energy savings for the proposed ECMs.

It is pertinent to note, that the savings noted in this report are not additive. The savings for each recommendation is calculated as standalone energy conservation measures. Implementation of more than one ECM may in some cases affect the savings of each ECM. The savings may in some cases be relatively higher if an individual ECM is implemented in lieu of multiple recommended ECMs. For example implementing reduced operating schedules for inefficient lighting will result in a greater relative savings. Implementing reduced operating schedules for newly installed efficient lighting will result in a lower relative savings, because there is less energy to be saved. If multiple ECM's are recommended to be implemented, the combined savings is calculated and identified appropriately.

ECMs are determined by identifying the building's unique properties and deciphering the most beneficial energy saving measures available that meet the specific needs of the facility. The building construction type, function, operational schedule, existing conditions, and foreseen future plans are critical in the evaluation and final recommendations. Energy savings are calculated base on industry standard methods and engineering estimations. Energy consumption is calculated based on manufacturer's cataloged information when new equipment is proposed.

Cost savings are calculated based on the actual historical energy costs for the facility. Installation costs include labor and equipment costs to estimate the full up-front investment required to implement a change. Costs are derived from Means Cost Data, industry publications, and local contractors and equipment suppliers. The NJ Smart Start Building® program incentives savings (where applicable) are included for the appropriate ECM's and subtracted from the installed cost. Maintenance savings are calculated where applicable and added to the energy savings for each ECM. The life-time for each ECM is estimated based on the typical life of the equipment being replaced or altered. The costs and savings are applied and a simple payback, simple lifetime savings, and simple return on investment are calculated. See below for calculation methods:

ECM Calculation Equations:

$$\text{Simple Payback} = \left( \frac{\text{Net Cost}}{\text{Yearly Savings}} \right)$$

$$\text{Simple Lifetime Savings} = (\text{Yearly Savings} \times \text{ECM Lifetime})$$

$$\text{Simple Lifetime ROI} = \frac{(\text{Simple Lifetime Savings} - \text{Net Cost})}{\text{Net Cost}}$$

$$\text{Lifetime Maintenance Savings} = (\text{Yearly Maintenance Savings} \times \text{ECM Lifetime})$$

$$\text{Internal Rate of Return} = \sum_{n=0}^N \left( \frac{\text{Cash Flow of Period}}{(1 + \text{IRR})^n} \right)$$

$$\text{Net Present Value} = \sum_{n=0}^N \left( \frac{\text{Cash Flow of Period}}{(1 + \text{DR})^n} \right)$$

Net Present Value calculations based on Interest Rate of 3%.



## IV. HISTORIC ENERGY CONSUMPTION/COST

### A. Energy Usage / Tariffs

The energy usage for the facility has been tabulated and plotted in graph form as depicted within this section. Each energy source has been identified and monthly consumption and cost noted per the information provided by the Owner.

The electric usage profile represents the actual electrical usage for the facility. The facilities receive electric distribution service through Atlantic City Electric on the Annual General Service (AGS) rate structure. The school has contracted South Jersey Energy, a Third Party Supplier (TPS), to provide electric commodity supply (generation) service. The electric utility measures consumption in kilowatt-hours (KWH) and maximum demand in kilowatts (KW). One KWH usage is equivalent to 1000 watts running for one hour. One KW of electric demand is equivalent to 1000 watts running at any given time. The basic usage charges are shown as generation service and delivery charges along with several non-utility generation charges. Rates used in this report reflect the historical data received for the facility.

The gas usage profile shows the actual natural gas energy usage for the facility. South Jersey Gas provides natural gas to the facility under the General Service Gas-LV rate structure. The Third Part Supplier (TPS) is Hess Corporation. The gas utility measures consumption in cubic feet x 100 (CCF), and converts the quantity into Therms of energy. One Therm is equivalent to 100,000 BTUs of energy.


The overall cost for utilities is calculated by dividing the total cost by the total usage. Based on the utility history provided, the average cost for utilities at this facility is as follows:

<u>Description</u>	<u>Average</u>
Electricity	13.5¢ / kWh
Natural Gas	\$1.08 / Therm

**Table 4**  
**Electricity Billing Data**

<b>ELECTRIC USAGE SUMMARY</b>			
Utility Provider: Atlantic City Electric Rate: Annual General Meter No: 86283945 Customer ID No: Third Party Utility S. J. Energy Co. TPS Meter / Acct No:			
<b>MONTH OF USE</b>	<b>CONSUMPTION KWH</b>	<b>DEMAND</b>	<b>TOTAL BILL</b>
Jan-09	145,440	408.0	\$19,182
Feb-09	131,200	446.4	\$18,055
Mar-09	148,960	430.4	\$19,582
Apr-09	168,640	417.6	\$21,777
May-09	141,600	420.8	\$18,591
Jun-09	160,960	449.6	\$21,580
Jul-09	115,520	276.8	\$16,119
Aug-09	124,160	347.2	\$16,954
Sep-09	143,360	422.4	\$19,615
Oct-09	150,080	459.2	\$20,727
Nov-09	152,160	430.4	\$20,549
Dec-09	167,040	406.4	\$22,587
<b>Totals</b>	<b>1,749,120</b>	<b>459.2 Max</b>	<b>\$235,319</b>
<b>AVERAGE DEMAND      409.6 KW average</b> <b>AVERAGE RATE      \$0.135 \$/kWh</b>			


**Figure 1**  
**Electricity Usage Profile**



**Table 5**  
**Natural Gas Billing Data**

<b>NATURAL GAS USAGE SUMMARY</b>		
Utility Provider: South Jersey Gas Rate: General Service Gas-LV Meter No: 259856 Point of Delivery ID: Third Party Utility Provider: Hess Corporation TPS Meter No:		
<b>MONTH OF USE</b>	<b>CONSUMPTION (THERMS)</b>	<b>TOTAL BILL</b>
Jan-09	22,742.58	\$29,226.95
Feb-09	21,724.92	\$25,211.15
Mar-09	15,500.64	\$14,786.55
Apr-09	8,629.47	\$7,844.44
May-09	2,665.14	\$2,849.09
Jun-09	2,411.55	\$2,744.83
Jul-09	1,304.10	\$1,812.10
Aug-09	1,238.40	\$1,725.95
Sep-09	1,486.25	\$1,794.90
Oct-09	4,485.12	\$4,176.93
Nov-09	7,943.75	\$7,521.46
Dec-09	15,374.19	\$14,119.42
<b>TOTALS</b>	<b>105,506.11</b>	<b>\$113,813.77</b>
<b>AVERAGE RATE:</b>	<b>\$1.08</b>	<b>\$/THERM</b>

**Figure 2**  
**Natural Gas Usage Profile**



**B. Energy Use Index (EUI)**

Energy Use Index (EUI) is a measure of a building's annual energy utilization per square foot of building. This calculation is completed by converting all utility usage consumed by a building for one year, to British Thermal Units (BTU) and dividing this number by the building square footage. EUI is a good measure of a building's energy use and is utilized regularly for comparison of energy performance for similar building types. The Oak Ridge National Laboratory (ORNL) Buildings Technology Center under a contract with the U.S. Department of Energy maintains a Benchmarking Building Energy Performance Program. The ORNL website determines how a building's energy use compares with similar facilities throughout the U.S. and in a specific region or state.

Source use differs from site usage when comparing a building's energy consumption with the national average. Site energy use is the energy consumed by the building at the building site only. Source energy use includes the site energy use as well as all of the losses to create and distribute the energy to the building. Source energy represents the total amount of raw fuel that is required to operate the building. It incorporates all transmission, delivery, and production losses, which allows for a complete assessment of energy efficiency in a building. The type of utility purchased has a substantial impact on the source energy use of a building. The EPA has determined that source energy is the most comparable unit for evaluation purposes and overall global impact. Both the site and source EUI ratings for the building are provided to understand and compare the differences in energy use.

The site and source EUI for this facility is calculated as follows:

$$\text{Building Site EUI} = \frac{(\text{Electric Usage in kBtu} + \text{Gas Usage in kBtu})}{\text{Building Square Footage}}$$


$$\text{Building Source EUI} = \frac{(\text{Electric Usage in kBtu} \times \text{SS Ratio} + \text{Gas Usage in kBtu} \times \text{SS Ratio})}{\text{Building Square Footage}}$$

**Table 6**  
**Facility Energy Use Index (EUI) Calculation**

ENERGY USE INTENSITY CALCULATION						
ENERGY TYPE	BUILDING USE			SITE ENERGY kBtu	SITE-SOURCE RATIO	SOURCE ENERGY kBtu
	kWh	Therms	Gallons			
ELECTRIC	1,749,120.0			5,971,496	3.340	19,944,796
NATURAL GAS		105,506.1		10,550,611	1.047	11,046,490
FUEL OIL			0.0	0	1.010	0
PROPANE			0.0	0	1.010	0
TOTAL				16,522,107		30,991,285
*Site - Source Ratio data is provided by the Energy Star Performance Rating Methodology for Incorporating Source Energy Use document issued Dec 2007.						
<b>BUILDING AREA</b>	220,065 SQUARE FEET					
<b>BUILDING SITE EUI</b>	75.08 kBtu/SF/YR					
<b>BUILDING SOURCE EUI</b>	140.83 kBtu/SF/YR					

Figure 3 below depicts a national EUI grading for the source use of High Schools.

**Figure 3**  
**Source Energy Use Intensity Distributions: High Schools**



### C. EPA Energy Benchmarking System

The United States Environmental Protection Agency (EPA) in an effort to promote energy management has created a system for benchmarking energy use amongst various end users. The benchmarking tool utilized for this analysis is entitled Portfolio Manager. The Portfolio Manager tool allows tracking and assessment of energy consumption via the template forms located on the ENERGY STAR website ([www.energystar.gov](http://www.energystar.gov)). The importance of benchmarking for local government municipalities is becoming more important as utility costs continue to increase and emphasis is being placed on carbon reduction, greenhouse gas emissions and other environmental impacts.

Based on information gathered from the ENERGY STAR website, Government agencies spend more than \$10 billion a year on energy to provide public services and meet constituent needs. Furthermore, energy use in commercial buildings and industrial facilities is responsible for more than 50 percent of U.S. carbon dioxide emissions. It is vital that local government municipalities assess facility energy usage, benchmark energy usage utilizing Portfolio Manager, set priorities and goals to lessen energy usage and move forward with priorities and goals.

In accordance with the Local Government Energy Audit Program, CEG has created an ENERGY STAR account for the municipality to access and monitoring the facility's yearly energy usage as it compares to facilities of similar type. The login page for the account can be accessed at the following web address; the username and password are also listed below:

<https://www.energystar.gov/istar/pmpam/index.cfm?fuseaction=login.login>

User Name: blackhorsepikeBOE  
Password: lgeaceg2010

Security Question: What city were you born in?  
Security Answer: "blackwood"

The utility bills and other information gathered during the energy audit process are entered into the Portfolio Manager. The following is a summary of the results for the facility:

**Table 7**  
**ENERGY STAR Performance Rating**

ENERGY STAR PERFORMANCE RATING		
FACILITY DESCRIPTION	ENERGY PERFORMANCE RATING	NATIONAL AVERAGE
Highland High School	52	50

Refer to **Statement of Energy Performance Appendix** for the detailed energy summary.



## V. FACILITY DESCRIPTION

The 220,065 square foot Highland High School is a two-story building located at 450 Erial Road in Blackwood, New Jersey. The facility is comprised of a gymnasium, weight room, cafeteria, library, various trade shops, administration offices, auditorium, classrooms, maintenance, computer labs, music suites, and kitchen.

The total occupancy at the Highland High School is approximately 1,390 including students, teachers and the custodial staff. The facility is open between the hours of 6:00AM and 11:00 PM for school hours, afterschool programs and custodial services. The school is heavily used in the summer for sports, summer camps and other activities. Therefore, occupied portions of the building are kept at occupied conditions to control temperature and humidity for staff and programs that may be occurring at the facility during the summer.

The facility was originally constructed in 1965 and has received additions in 1986, 1990 and 1999 with HVAC upgrades in 2008 and 2010. Exterior walls are brick/block construction with minimum insulation typical of the time period. The amount of insulation within the wall is unknown. The windows throughout the facility are in good condition and appear to be maintained. Typical windows throughout the facility are double pane, 1/4" insulated glass with vinyl frames. Blinds are utilized throughout the facility for occupant comfort. The blinds are valuable because they help to reduce heat loss in the winter and reduce solar heat in the summer. The majority of the roof is constructed of a built-up roof with light color stone covering that includes a 2-inch rigid insulation and 2-inch insulrock on bulb tees.

### HVAC Systems

The central heating system is located in the facility's original boiler room and consists of two (2) 1967 H. B. Smith cast iron sectional hot water boilers each rated at 6,522 MBH output. These boilers are approximately 70% efficient and are 13 years beyond their ASHRAE Service Life of 30 years. The heating hot water is distributed throughout the facility via several constant volume end suction pumps feeding three major zones in the facility and are located within the original boiler room. This system provides heating to all areas of the building except the 1986 Gym and the 1999 Weight Room Additions. The 1986 Gym Addition is heated by a 1988 Weil-McLain cast iron sectional hot water boiler located in the original boiler room and is rated at 810 MBH output that feeds two in-line hot water pumps. These pumps in turn feed the four (4) hot water coils in the Gym units and the H&V units in the basement locker rooms. The Weight Room addition is heated by a 1999 vintage packaged rooftop unit with gas-fired heating. The Library & Classroom Addition is heated by packaged rooftop units with hot water coils while the Auditorium and Cafeteria are heated by duct-mounted hot water heating coils. Typical smaller terminal heating equipment throughout the facility consists of vertical unit ventilators with fin-tube radiation in classrooms; hot water unit heaters for receiving, storage, and mechanical rooms; horizontal unit ventilators for the shops; and basic fin-tube radiation or cabinet heaters for entrances.

Cooling is provided for the 1990 Library & Classroom Addition, the 1999 Weight Room Addition, the 2008 Auditorium HVAC Replacement, and the 2010 Cafeteria Renovation. The original 1965 building is heating only except for the A Wing. Portions of Corridor A at the high

school are cooled by direct expansion, indoor, water-cooled condensing systems. The cooling media is from the domestic water supply and the waste water discharges to the sanitary system. This is a wasteful cooling process that costs the School District in both water and sewer charges. There are approximately 10 units of this style all serving interior zones.

The Library is cooled by a 50-Ton packaged rooftop air conditioning unit. The unit was originally designed to operate as a variable volume system with terminal boxes and electric reheat located above the ceiling serving independent zones. This system has since been overridden and the unit now operates as a constant volume system with the terminal boxes held in the full open position. It has been reported that there have been problems in the past with this unit maintaining proper humidity levels in the Library. The compressor sequences of operation have been manipulated to compensate for the humidity problems. CEG strongly recommends that this packaged rooftop unit be brought back to its original functionality by having it operate as a variable air volume system including the proper operation of the compressors. The 1990 Classroom Addition is cooled by self-contained heating and cooling unit ventilators with DX cooling. The 1999 Weight Room Addition is cooled by a 10-Ton packaged rooftop air conditioning unit with DX cooling. The Auditorium is cooled by two (2) 30-Ton packaged rooftop air conditioning units installed in 2008 while the Cafeteria is cooled by three (3) 15-Ton packaged rooftop units installed in 2010.

### Exhaust System

Air is exhausted from the building through the packaged rooftop units, unit ventilators and centrifugal roof exhausters. Dedicated exhaust is provided for toilet rooms, specialty rooms (such as art rooms, wood shop, chemistry rooms, and biology rooms, etc.) and large assembly areas (such as the auditorium and gymnasium). The exhaust for the specialty areas is manually controlled by the maintenance staff based on temperature and occupancy comfort. The toilet rooms exhaust fans are manually controlled by bath room wall switches. The commercial kitchen includes two 12 feet by 4 feet commercial exhaust hoods. The hoods are utilized for heat and smoke exhaust over cooking ovens steamers, and a gas fired range. The kitchen hood is manually controlled by a wall switch and operates approximately 8 hrs per day.

### HVAC System Controls

The hot water heating systems within the original 1965 facility, the 1986 Gym Addition and the 1990 Library/Classroom Addition are controlled via a pneumatic system located in the original boiler room that consists of day-auto-night controllers for the auditorium, 1<sup>st</sup> floor academic, 2<sup>nd</sup> floor academic, administration, library, cafeteria, shops, fin-tube radiation control, etc. In addition, this system has summer/winter changeover, outside air temperature reset and hot water pump setpoint controls. This pneumatic system is a 1965 vintage system that is long past the service life of 20 years per ASHRAE. Throughout the building there are pneumatic manual wall thermostats for various HVAC units and local pneumatic controls with adjustable settings on the heating units that were installed in 1965. All HVAC units in the older section of the school are controlled by local or remote pneumatic thermostats. We could not determine an actual level of accuracy of the pneumatic thermostats without calibrated instrumentation but there are certainly air leakage in the sensors, field devices and air lines. The noted air leakage leads to inefficient operation of the equipment the thermostat is controlling. These indoor temperature controls are

inaccurate due to temperature drift, age, cost of maintenance of pneumatics and not having been re-calibrated. In addition, pneumatic controls do not have the ability to maintain the temperature at setpoint under changing load conditions. The 1999 Weight Room Addition, Library and the Auditorium/Cafeteria renovations have newer HVAC units with Direct Digital Controls (DDC) features. During the detailed field inspection, CEG discovered that the Cafeteria rooftop units operate in occupied mode 24/7 due to value engineering of the local controls at the unit at the time of original installation. A programmed schedule would provide energy savings by allowing the building automation system to setback the temperature setting when the Cafeteria is not occupied.

### Domestic Hot Water

During the heating season, domestic hot water for the kitchen, restrooms, office lounge, etc., is provided by a 6-foot diameter by 12-foot long storage tank with an internal heat exchanger fed by the heating hot water boilers via two (2) in-line circulation pumps. In the summer time, the domestic hot water is produced by an H. B. Smith cast iron sectional boiler rated at 784 MBH output that feeds the same heat exchanger/tank. The domestic hot water is circulated throughout the building by a hot water re-circ pump. The circulation pump is controlled by an aqua stat. The domestic hot water piping insulation appeared to be in good condition.

### Lighting

Typical lighting throughout building is fluorescent tube lay-in fixtures with T-8 lamps and electronic ballasts. Storage rooms and closets are lit with compact fluorescent lamps. The exit signs use incandescent lamps and are a strong candidate for the LED lamp type exit sign fixture.

## VI. MAJOR EQUIPMENT LIST

The equipment list contains major energy consuming equipment that through implementation of energy conservation measures could yield substantial energy savings. The list shows the major equipment in the facility and all pertinent information utilized in energy savings calculations. An approximate age was assigned to the equipment in some cases if a manufactures date was not shown on the equipment's nameplate. The ASHRAE service life for the equipment along with the remaining useful life is also shown in the Appendix.

Refer to the **Major Equipment List Appendix** for this facility.

## VII. ENERGY CONSERVATION MEASURES

### ECM #1: Lighting Upgrade

#### Description:

The majority of the lighting throughout the Highland High School is provided by lighting fixtures consisting of standard 32-Watt, T-8 lamps and electronic ballasts. There are still some spaces that have 40-Watt, T-12 lighting fixtures and incandescent lamps. The existing Gymnasium and Auxiliary Gymnasium lighting systems comprise of a total of sixty (60) 400-Watt Metal-Halide (MH) fixtures which have poor lumen maintenance (approximately 30% reduction in lighting output at 40% of rated lamp life). Also, the fixture ballast can be very noisy, requiring up to 10 minutes for re-striking after shutdown, and there is a noticeable color shift as the lamp approaches the end of its life.

This ECM includes the replacement of all 32-Watt, T-8 and 40-Watt, T-12 lamps with 25-Watt, Super T-8 lamps throughout the entire facility. The new, energy efficient Super T-8 lamps will provide adequate lighting and will save on electrical costs due to better performance of these lamps. This ECM also includes maintenance savings through the reduced number of lamps replaced per year. The expected lamp life of a Super T-8 lamp is approximately 24,000 burn-hours, in comparison to the existing standard T-8 lamp which is approximately 20,000 burn-hours.

This ECM would also replace each of the existing Gymnasium and Auxiliary Gymnasium light fixtures with new T-5 high-bay light fixtures which would include six, 4-foot T-5 High Output (HO) lamps. The T-5 HO lamps are rated for 20,000 hours versus the 10,000 hours for the 400-Watt MH lamps so there would again be savings in replacement cost/labor. In addition, the T-5 HO lamps have better lighting quality and lumen maintenance.

The last part of this ECM involves replacing the seventy-five (75) existing exit signs that have 7-Watt Compact Fluorescent Lamps (CFLs) or incandescent bulbs with the newer LED technology units. In addition, the remainder of the incandescent lamps would be replaced with the appropriately sized CFL lamp.

#### Energy Savings Calculations:

The **Investment Grade Lighting Audit Appendix** outlines the hours of operation, proposed retrofits, costs, savings, and payback periods for each set of fixtures in the facility.

From the **NJ Smart Start<sup>®</sup> Program Incentives Appendix**, the following incentives are warranted:

For the LED Exit Sign: \$20/LED Exit sign ( $\leq 75\text{kW}$  facility connected load) and \$10/LED Exit sign ( $\geq 75\text{kW}$  facility connected load).

Smart Start<sup>®</sup> Incentive = (# of LED Exit fixtures x \$10 per fixture)

Smart Start ® Incentive = 75 fixtures x \$10 per fixture = \$750.

For replacement of T-8 lamps to Super T-8 lamps is \$10 per fixture.

Smart Start ® Incentive = (# of T-8 fixtures x \$10 per fixture)

Smart Start ® Incentive = 1,233 fixtures x \$10 per fixture = \$12,330

For replacement of 400-Watt MH fixtures to a T-5 lighting system

Smart Start ® Incentive = (# of T-5 fixtures x \$100 per fixture)

Smart Start ® Incentive = 60 fixtures x \$100 per fixture = \$6,000.

Total Smart Start ® Incentive Value = \$19,080.

### Energy Savings Summary:

<b>ECM #1 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$57,752
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$19,080
<b>Net Installation Cost (\$):</b>	\$38,672
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$10,509
<b>Total Yearly Savings (\$/Yr):</b>	\$10,509
<b>Estimated ECM Lifetime (Yr):</b>	15
<b>Simple Payback</b>	3.7
<b>Simple Lifetime ROI</b>	307.6%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$157,635
<b>Internal Rate of Return (IRR)</b>	26%
<b>Net Present Value (NPV)</b>	\$86,783.76

## ECM #2: Lighting Controls Upgrade

### Description:

Some of the lights in the school building are left on unnecessarily. In many cases the lights are left on because of the inconvenience to manually switch lights off when a room is left or on when a room is first occupied. This is common in rooms that are occupied for only short periods and only a few times per day. In some instances lights are left on due to the misconception that it is better to keep the lights on rather than to continuously switch lights on and off. Although increased switching reduces lamp life, the energy savings outweigh the lamp replacement costs. The payback timeframe for when to turn the lights off is approximately two minutes. If the lights are expected to be off for at least a two minute interval, then it pays to shut them off.

Lighting controls come in many forms. Sometimes an additional switch is adequate to provide reduced lighting levels when full light output is not needed. Occupancy sensors detect motion and body heat which will switch the lights on when the room is occupied. Occupancy sensors can either be mounted in place of a current wall switch, or on the ceiling to cover large areas.

The U.S. Department of Energy sponsored a study to analyze energy savings achieved through various types of building system controls. The referenced savings is based on the “Advanced Sensors and Controls for Building Applications: Market Assessment and Potential R&D Pathways,” document posted for public use April 2005. The study has found that commercial buildings have the potential to achieve significant energy savings through the use of building controls. The average energy savings are as follows based on the report:

- Occupancy Sensors for Lighting Control 20% - 28% energy savings.

Savings resulting from the implementation of this ECM for energy management controls are estimated to be 20% of the total light energy controlled by occupancy sensors and daylight sensors (the majority of the savings is expected to be after school hours when rooms are left with lights on).

This ECM includes installation of ceiling or switch mount sensors for individual offices, conference rooms, classrooms, large bathrooms, and library offices. Sensors shall be manufactured by SensorSwitch, Watt Stopper or equivalent. The **Investment Grade Lighting Audit Appendix** of this report includes the summary of lighting controls implemented in this ECM and outlines the proposed controls, costs, savings, and payback periods. The calculations adjust the lighting power usage by the applicable percent savings for each area that includes lighting controls.

**Energy Savings Calculations:**

$$\text{Energy Savings} = (\% \text{ Savings} \times \text{Controlled Light Energy (kWh/Yr)})$$

$$\text{Savings} = \text{Energy Savings (kWh)} \times \text{Ave Elec Cost} \left( \frac{\$}{\text{kWh}} \right)$$

**Cost and Incentives:**

Installation cost per dual-technology sensors (Basis: Sensor switch or equivalent) are as follows:

Dual Technology Occupancy Sensor - Remote Mount	\$250 per installation
Dual Technology Occupancy Sensor - Switch Mount	\$150 per installation
Dual Technology Occupancy Sensor with 2 Pole Powerpack Remote mount	\$300 per installation

Cost includes material and labor.

From the **NJ Smart Start® Program Incentives Appendix**, the installation of a lighting control device warrants the following incentive:

Occupancy Sensor Fixture Mounted (existing facility only) = \$20 per sensor

Occupancy Sensor Remote Mounted (existing facility only) = \$35 per sensor

$$\text{Smart Start® Incentive} = (\# \text{ of wall mount} \times \$20) + (\# \text{ of ceiling mount} \times \$35)$$

$$\text{Smart Start® Incentive} = (39 \text{ wall mount} \times \$20) + (125 \text{ ceiling mount} \times \$35) = \$5,155$$



**Energy Savings Summary:**

<b>ECM #2 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$41,800
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$5,155
<b>Net Installation Cost (\$):</b>	\$36,645
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$10,847
<b>Total Yearly Savings (\$/Yr):</b>	\$10,847
<b>Estimated ECM Lifetime (Yr):</b>	15
<b>Simple Payback</b>	3.4
<b>Simple Lifetime ROI</b>	344.0%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$162,705
<b>Internal Rate of Return (IRR)</b>	29%
<b>Net Present Value (NPV)</b>	\$92,845.78

### ECM #3: Computer Monitor Replacement

#### Description:

The computers throughout the facility utilize a mixture of CRT computer monitors and LCD computer monitors. Computers are located in the offices, computer labs, lounges, and classrooms. The CRT computer monitors are outdated and have several disadvantages such as significantly increased higher energy consumption, use large amounts of desk space, poor picture quality, distortions, flickering image, secular glare problems, high weight, and electromagnetic emissions. Many of these drawbacks are difficult to quantify except for the energy use. CRT monitors use considerably more energy than an alternative flat panel LCD monitor. Replacement of the existing CRT monitors with LCD monitors saves considerable energy as well as provides other ergonomic benefits.

Based on the site survey, it was noted that in some areas the computers were left on and allowed to run 24 / 7, while in other rooms the computers were shut down. Some of the monitors were left in screen saver mode, which is deceiving since this mode only saves the computer screen from image burn in, however it does not save on energy consumption. The average operating hours for all computers and monitors is estimated based on the site survey observations. Energy consumption of computer monitors is based on manufacture's specifications.

This ECM includes replacement of all existing CRT monitors with LCD flat panel monitors throughout the school. Installation costs were neglected for this ECM with the intention that this ECM would be replaced by the school employees. The calculations are based on the following operating assumptions:

#### Energy Savings Calculations:

No. of CRT Monitors:	102
Weeks per Yr:	40
Hrs per Week:	84 (12 hrs per day cumulative average)

$$\text{Electric Usage} = \frac{\# \text{ of Computers} \times \text{Monitor Power (W)} \times \text{Operation (Hrs)}}{1000 \left( \frac{\text{W}}{\text{KW}} \right)}$$

$$\text{Energy Cost} = \text{Electric Usage (kWh)} \times \text{Ave Elec Cost} \left( \frac{\$}{\text{kWh}} \right)$$

<b>COMPUTER MONITOR CALCULATIONS</b>			
<b>ECM INPUTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>ECM INPUTS</b>	CRT Monitors	LCD Monitor	
<b># of Computers</b>	102	102	
<b>Monitor Power Cons. (W)</b>	75	25	50
<b>Operating Hrs per Week</b>	84	84	
<b>Operating Weeks per Yr</b>	40	40	
<b>Elec Cost (\$/kWh)</b>	0.135	0.135	
<b>ENERGY SAVINGS CALCULATIONS</b>			
<b>ECM RESULTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>Electric Usage (kWh)</b>	25,704	8,568	17,136
<b>Energy Cost (\$)</b>	\$3,470	\$1,157	\$2,313
<b>COMMENTS:</b>	CRT Monitor consumption based on Dell CRT monitor M/N: CRT-E771MM. Operating hours based on estimated average.		

Installation cost of new monitors is estimated based on current pricing for a 17" LCD monitor on the market today. No labor costs were included for replacing the existing monitors with the new monitors. No incentives are available for installation of computer monitors. Net cost per monitor was estimated to be \$100.

Installation Costs:     # Monitors X Cost per Monitor  
                                  102 Monitors X \$100 per Monitor  
                                  \$10,200

**Energy Savings Summary:**

<b>ECM #3 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$10,200
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$0
<b>Net Installation Cost (\$):</b>	\$10,200
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$2,313
<b>Total Yearly Savings (\$/Yr):</b>	\$2,313
<b>Estimated ECM Lifetime (Yr):</b>	15
<b>Simple Payback</b>	4.4
<b>Simple Lifetime ROI</b>	240.1%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$34,695
<b>Internal Rate of Return (IRR)</b>	21%
<b>Net Present Value (NPV)</b>	\$17,412.44

## **ECM #4: Condensing Boiler Installation**

### **Description:**

The central heating system consists of two (2) 1967 H. B. Smith cast iron sectional hot water boilers each rated at 6,522 MBH output that serve the building's heating hot water loop. The boilers are fired by natural gas and are roughly 13 years past the ASHRAE service life for a typical cast iron boiler.

The 1986 Gym Addition is heated by a 1988 Weil-McLain cast iron sectional hot water natural gas boiler rated at 810 MBH output. The boiler has roughly 8 years of service life left for a typical cast iron boiler.

During the heating season, domestic hot water for the kitchen, restrooms, office lounge, etc. is provided by a 6-foot diameter by 12-foot long storage tank with an internal heat exchanger feed by the heating hot water boilers via two (2) in-line circulation pumps. The tank and heat exchanger are original to the building and are in poor condition. According to the maintenance staff the storage tank is constantly in need of repair. In the summer time, the domestic hot water is produced by an H. B. Smith cast iron sectional boiler rated at 784 MBH output that feeds the same heat exchanger/tank. The summer boiler has roughly 4 years of service life left for a typical cast iron boiler.

New condensing boilers could substantially improve the operating efficiency of the heating system of the building. The condensing boilers provide significantly higher efficiencies than standard boilers by significantly reducing the flue gas temperature and extracting the latent energy. Condensing boiler's peak efficiency tops out at 99% depending on return water temperature. Due to the operating conditions of the building, the annual average operating efficiency of the proposed condensing boiler is expected to be 88% for comfort heating and 95% for instantaneous domestic hot water heating. The larger original plant boilers and the existing summer domestic hot water boiler efficiencies are approximately 74% and the Gym boiler efficiency is approximately 80%, which makes the proposed new condensing modular boilers a 8% to 14% increase in efficiency. The new modular boiler sets also have the ability to be controlled by a digital boiler sequencer to optimize plant efficiency which could yield further savings than what is calculated in this ECM.

This ECM includes installation of three condensing, gas-fired modular boilers to replace three of the existing boilers located in the original boiler room. This consolidation would include one of the 6,522 MBH boilers, the 810 MBH Gym boiler, and the 784 MBH summer domestic hot water boiler. Domestic hot water would be provided by two condensing, gas-fired instantaneous domestic hot water modular boilers as a complete standalone system. The existing storage tank with exchanger would no longer be necessary and would be abandoned in place or demolished at the Owner's discretion. The existing second 6,522 MBH boiler will remain as a back-up. The basis for this ECM is Aerco model number BMK-3.0LN and BMK-1.5LN boilers or equivalent for the comfort heating and Aerco model number INN-1060 or equivalent for the domestic hot water. The basis of design for this ECM is based on variable supply water temperature adjusted

based on outdoor temperature. The boiler installation is based on a one-for-one replacement which takes into account the capacity of the existing boilers.

### Energy Savings Calculations:

The natural gas utility bills were utilized in the calculation of the energy savings. There is one meter for all gas-fired equipment in the facility. In order to extrapolate the natural gas consumption of the equipment analyzed in this ECM, engineering assumptions were made. In order to properly evaluate this ECM, further investigation into actual consumption should be pursued at the engineering and design phase before implementation.

*Equations Used:*

$$\text{Bldg Heat Required} = \text{Existing Nat Gas (Therms)} \times \text{Heating Eff. (\%)} \times \text{Fuel Heat Value} \left( \frac{\text{BTU}}{\text{Therm}} \right)$$

$$\text{Proposed Heating Gas Usage} = \frac{\text{Bldg Heat Required (BTU)}}{\text{Heating Eff. (\%)} \times \text{Fuel Heat Value} \left( \frac{\text{BTU}}{\text{Therm}} \right)}$$

$$\text{Energy Cost} = \text{Heating Gas Usage (Therms)} \times \text{Ave Fuel Cost} \left( \frac{\$}{\text{Therm}} \right)$$

CONDENSING BOILER CALCULATIONS - COMFORT HEATING			
ECM INPUTS	EXISTING	PROPOSED	SAVINGS
ECM INPUTS	Existing Cast Iron Sectional Boiler	New Condensing Boilers	
Consumed Nat Gas (Therms)	76,433	64,274	
Boiler Efficiency (%)	74%	88%	14%
Nat Gas Heat Value (BTU/Therm)	100,000	100,000	
Equivalent Building Heat Usage (MMBTUs)	5,656	5,656	
Gas Cost (\$/Therm)	1.08	1.08	
ENERGY SAVINGS CALCULATIONS			
ECM RESULTS	EXISTING	PROPOSED	SAVINGS
Natural Gas Usage (Therms)	76,433	64,274	12,160
Energy Cost (\$)	\$82,548	\$69,415	\$13,133
COMMENTS:	The majority of the consumption is assumed to be from the 74% efficient 6,522 MBH boiler. Therefore this efficiency was used as the baseline.		

CONDENSING BOILER CALCULATIONS - DOMESTIC HOT WATER			
ECM INPUTS	EXISTING	PROPOSED	SAVINGS
ECM INPUTS	Existing Cast Iron Sectional Boiler	New Condensing Boilers	
Consumed Nat Gas (Therms)	16,001	12,464	
Boiler Efficiency (%)	74%	95%	21%
Nat Gas Heat Value (BTU/Therm)	100,000	100,000	
Equivalent Building Heat Usage (MMBTUs)	1,184	1,184	
Gas Cost (\$/Therm)	1.08	1.08	
ENERGY SAVINGS CALCULATIONS			
ECM RESULTS	EXISTING	PROPOSED	SAVINGS
Natural Gas Usage (Therms)	16,001	12,464	3,537
Energy Cost (\$)	\$17,281	\$13,461	\$3,820
COMMENTS:	The majority of the consumption is assumed to be from the 74% efficient 6,522 MBH boiler. Therefore this efficiency was used as the baseline.		

Installation cost of the new condensing boilers, demolition, flue piping, boiler water piping modifications, gas piping modifications, electric, etc. is estimated to be \$421,638.

From the **NJ Smart Start® Program Incentives Appendix**, the installation of new condensing boilers warrants the following incentive: \$1.00 per MBH.

Gas Fired Boilers > 300 MBH – 1500 MBH

(2) Boilers at 1060 MBH each

$$\text{Smart Start}^{\circledR} \text{ Incentive} = (\text{Boiler MBH} \times \$1.75) = 2,120 \times 1.75 = \$3,710$$

Gas Fired Boilers > 1500 MBH – < 4000 MBH

(2) Boilers at 3000 MBH each and (1) Boiler at 1500 MBH

$$\text{Smart Start}^{\circledR} \text{ Incentive} = (\text{Boiler MBH} \times \$1.00) = 7,500 \times 1 = \$7,500$$

Total Smart Start® Incentive = \$11,210



**Energy Savings Summary:**

<b>ECM #4 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$421,638
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$11,210
<b>Net Installation Cost (\$):</b>	\$410,428
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$16,953
<b>Total Yearly Savings (\$/Yr):</b>	\$16,953
<b>Estimated ECM Lifetime (Yr):</b>	30
<b>Simple Payback</b>	24.2
<b>Simple Lifetime ROI</b>	23.9%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$508,590
<b>Internal Rate of Return (IRR)</b>	1%
<b>Net Present Value (NPV)</b>	(\$78,141.72)

## **ECM #5: AC Unit Replacement**

### **Description:**

Portions of the facility are cooled by direct expansion, outdoor, air-cooled condensing systems. Both packaged and split systems were discovered and analyzed. Some of the existing units have surpassed their useful life as outlined in Chapter 36 of the 2007 ASHRAE Applications Handbook. The estimated service life for a condensing unit is twenty (20) years and fifteen (15) years for a packaged rooftop unit. Other systems are within the useful life but are not as efficient as the latest technology available. Usually, energy savings derived from replacing condensing units does not justify a reasonable payback term. Nevertheless, as the equipment ages, it loses efficiency due to clogged condensers, internal parts wear and deposits of oil and other contaminants on the heat exchangers. Replacing an older condensing unit avoids these issues along with gaining energy savings.

This energy conservation measure includes replacement of the packaged and split system condensing units on the roof with new equipment at equal capacities to R-410a refrigerant and replacement of the DX coil in the matching air handlers as required to accommodate the higher pressure refrigerant. The cost of this ECM also includes running new refrigerant lines.

It must be noted that manufacturing of the refrigerant gas R-22 is being phased out gradually. After 2010, HVAC manufacturers will continue to produce condensers and heat pumps using R-22 only from pre-existing R-22 supplies. The availability of R-22 gas will decline and R-22 equipment will be more expensive to maintain. On the other hand, converting most R-22 refrigeration systems into an alternative R-410a system requires replacement of the condensing unit, evaporator coils in the air handling unit, refrigerant pipes and fittings.

The unit's cooling efficiencies and capacities are as shown below. This ECM includes a one-to-one replacement of the older air conditioning units with newer, high efficiency systems. It is recommended to fully evaluate the capacity needed for all new systems prior to moving forward with this ECM. A summary of this ECM can be found in the table below:

IMPLEMENTATION SUMMARY						
ECM INPUTS	SERVICE FOR	NUMBER OF UNITS	COOLING CAPACITY, BTU/HR	COOLING CAPACITY, TONS	TOTAL COOLING CAPACITY, TONS	REPLACEMENT BASED ON
SS-3	Conference Rm A203	1	15,000	1.3	1.3	Mitsubishi
SS-6	Nurse/Exam Rooms	3	18,000	1.5	4.5	Trane Equipment
SS-4	2nd Floor Admin Offices	1	22,000	1.8	1.8	Mitsubishi
RTU-2/RTU-3/RTU-7	Faculty Dining/Classroom F126/Librarian's Office	3	24,000	2.0	6.0	Trane Equipment
SS-5	2nd Floor Admin Offices	2	30,000	2.5	5.0	Mitsubishi
RTU-4/RTU-11	Kitchen (Room F128)/Science Rooms	3	36,000	3.0	9.0	Trane Equipment
SS-1	Three Offices near Room C103	1	36,000	3.0	3.0	Trane Equipment
RTU-9	Choral Room	1	48,000	4.0	4.0	Trane Equipment
SS-2	Room F211	1	48,000	4.0	4.0	Trane Equipment
RTU-8	Cafeteria	1	90,000	7.5	7.5	Trane Equipment
RTU-1	Weight Room (Sports Annex)	1	120,000	10.0	10.0	Trane Equipment
RTU-10	Auditorium	2	360,000	30.0	60.0	Trane Equipment
<b>Total</b>		<b>20</b>			<b>116.1</b>	

ECM INPUTS references the tag labeled in the major equipment list but may not necessarily represent the tag of the equipment in the field.

The basis is Trane equipment with R410a refrigerant. This ECM includes replacement of the indoor air handling units and outdoor condensing units.

### Energy Savings Calculations:

#### Cooling Energy Savings:

Seasonal energy consumption of the air conditioners in cooling mode is calculated with the equation below:

$$\text{Energy Savings, kWh} = \text{Cooling Capacity, } \frac{\text{BTU}}{\text{Hr}} \times \left( \frac{1}{\text{SEER}_{\text{Existing}}} - \frac{1}{\text{SEER}_{\text{Proposed}}} \right) \times \frac{\text{Full Load Hours}}{1000 \frac{\text{W}}{\text{kWh}}}$$

$$\text{Demand Savings, kW} = \frac{\text{Energy Savings (kWh)}}{\text{Hours of Cooling}}$$

$$\text{Cooling Cost Savings} = \text{Energy Savings, kWh} \times \text{Cost of Electricity} \left( \frac{\$}{\text{kWh}} \right)$$

ENERGY SAVINGS CALCULATIONS							
ECM INPUTS	COOLING CAPACITY, BTU/Hr	ANNUAL COOLING HOURS	EXISTING UNITS SEER/EER	PROPOSED SEER/EER	# OF UNITS	ENERGY SAVINGS kWh	DEMAND SAVINGS kW
SS-3	15,000	1,000	8	16	1	938	0.9
SS-6	18,000	1,000	9	13	3	1,846	1.8
SS-4	22,000	1,000	10	16	1	825	0.8
RTU-2/RTU-3/RTU-7	24,000	1,000	6	15	3	7,200	7.2
SS-5	30,000	1,000	10	16	2	2,250	2.3
RTU-4/RTU-11	36,000	1,000	6	15	3	10,800	10.8
SS-1	36,000	1,000	7	17.5	1	3,086	3.1
RTU-9	48,000	1,000	6	15	1	4,800	4.8
SS-2	48,000	1,000	6	17.5	1	5,257	5.3
RTU-8	90,000	1,000	10.1	13	1	1,988	2.0
RTU-1	120,000	1,000	11	12.5	1	1,309	1.3
RTU-10	360,000	1,000	9.5	10.3	2	5,887	5.9
<b>Total</b>					20	46,185	46.2

### Project Cost, Incentives and Maintenance Savings

From the **NJ Smart Start® Program Incentives Appendix**, the replacement AC units with high efficiency AC units falls under the category “Unitary HVAC Split System” and warrants an incentive based on efficiency (SEER) noted below. The program incentives are calculated as follows:

$$\text{SmartStart® Incentive} = (\text{CoolingTons} \times \$/\text{Ton Incentive})$$

SPLIT SYSTEM AC UNITS REBATE SUMMARY				
UNIT DESCRIPTION	UNIT EFFICIENCY	REBATE \$/TON	PROPOSED CAPACITY TONS	TOTAL REBATE \$
5.4 tons or less Unitary AC and Split System	≥14 SEER	\$92	38.6	\$3,550
5.4 tons to 11.25 tons Unitary AC and Split System	≥11.5 EER	\$73	17.5	\$1,278
20 tons to 30 tons Unitary AC and Split System	≥10.5 EER	\$79	60.0	\$4,740
<b>TOTAL</b>			<b>116.1</b>	<b>\$9,567</b>

Summary of cost, savings and payback for this ECM is below.

<b>COST &amp; SAVINGS SUMMARY</b>							
<b>ECM INPUTS</b>	<b>INSTALLED COST</b>	<b># OF UNITS</b>	<b>TOTAL COST</b>	<b>REBATES</b>	<b>NET COST</b>	<b>ENERGY SAVING</b>	<b>PAY BACK YEARS</b>
<b>SS-3</b>	\$2,700	1	\$2,700	\$115	\$2,585	\$127	20.4
<b>SS-6</b>	\$1,500	3	\$4,500	\$414	\$4,086	\$249	16.4
<b>SS-4</b>	\$5,700	1	\$5,700	\$169	\$5,531	\$111	49.7
<b>RTU-2/RTU-3/RTU-7</b>	\$8,850	3	\$26,550	\$552	\$25,998	\$972	26.7
<b>SS-5</b>	\$5,700	2	\$11,400	\$460	\$10,940	\$304	36.0
<b>RTU-4/RTU-11</b>	\$8,850	3	\$26,550	\$828	\$25,722	\$1,458	17.6
<b>SS-1</b>	\$9,000	1	\$9,000	\$276	\$8,724	\$417	20.9
<b>RTU-9</b>	\$9,600	1	\$9,600	\$368	\$9,232	\$648	14.2
<b>SS-2</b>	\$9,000	1	\$9,000	\$368	\$8,632	\$710	12.2
<b>RTU-8</b>	\$13,800	1	\$13,800	\$548	\$13,253	\$268	49.4
<b>RTU-1</b>	\$16,125	1	\$16,125	\$730	\$15,395	\$177	87.1
<b>RTU-10</b>	\$43,500	2	\$87,000	\$4,740	\$82,260	\$795	103.5
<b>Total</b>		20	\$221,925	\$9,567	\$212,358	\$6,235	34.1

There is no significant maintenance savings due to implementation of this ECM.

**Energy Savings Summary:**

<b>ECM #5 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$221,925
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$9,567
<b>Net Installation Cost (\$):</b>	\$212,358
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$6,235
<b>Total Yearly Savings (\$/Yr):</b>	\$6,235
<b>Estimated ECM Lifetime (Yr):</b>	15
<b>Simple Payback</b>	34.1
<b>Simple Lifetime ROI</b>	-56.0%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$93,525
<b>Internal Rate of Return (IRR)</b>	-9%
<b>Net Present Value (NPV)</b>	(\$137,924.97)

## ECM #6: Library AC Unit Upgrade

### Description:

The library for this school is conditioned by a 50-Ton packaged rooftop unit. It is equipped with direct expansion cooling and hot water heat. The unit was originally designed to operate as a variable volume system with terminal boxes and electric reheat located above the ceiling serving independent zones. This system has since been overridden and the unit now operates as a constant volume system with the terminal boxes held in the full open position. The unit is equipped with standalone controls integral to the Trane Intellipak system and operates on a simple programmable schedule. It has been reported that there have been problems in the past with this unit maintaining proper humidity levels in the Library. The compressor sequences of operation have been manipulated to compensate for the humidity problems. The existing system is equipped with full economizer however it is not equipped with demand controlled ventilation.

Air static pressure in a VAV air handling system is maintained by modulating the speed of the fan. Air is distributed throughout the building by ductwork, and VAV terminal boxes control the flow of cool air delivered to the space they serve. As the space cooling load increases, the flow of cold air likewise increases to maintain the space temperature. If space cooling loads decrease, the requirement for cold air flow to cool the space also decreases. The air flow to the VAV terminal boxes is delivered at a system static pressure. The static pressure level is established by the minimum pressure required for the terminal boxes to deliver full cooling flows. During the winter, air flow requirements drop to their minimum levels and the static pressure required at terminal boxes decreases. This reduced air flow requirement brings about an opportunity to reduce the system static pressure levels along with reducing energy usage.

When CO<sub>2</sub> sensors are used to maintain indoor air quality (IAQ), they continuously monitor the air in a conditioned space. Because people constantly exhale CO<sub>2</sub>, the difference between the indoor CO<sub>2</sub> concentration and the outdoor concentration indicates the occupancy or activity level in a space and thus its ventilation requirements. The CO<sub>2</sub> sensor readings are monitored at the air handling system control panel, which automatically increases ventilation when the CO<sub>2</sub> concentration in a zone rises above a specified level.

This ECM would bring the packaged rooftop unit back to its original functionality by having it operate as a variable air volume system including the proper operation of the compressors. This would include upgrading the existing controls at the unit and integrating into the existing building automation system at the school. Along with this controls upgrade, demand controlled ventilation would be added to the sequences of operation to adjust the amount of outdoor air provided to the space based on actual occupancy. The existing terminal boxes with reheat would be removed and replaced with terminal boxes with hot water coils piped from hot water piping passing through the Library ceiling.

In order to properly evaluate this ECM, further investigation into the humidity issues should be pursued at the engineering and design phase before implementation.

**Energy Savings Calculations:**Cooling & Heating Energy Savings:

Seasonal energy consumption of the system in the cooling and heating modes was calculated using Trane System Analyzer Software. The results are summarized below:

<b>ENERGY CALCULATIONS - ELECTRIC</b>			
<b>ECM INPUTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>ECM INPUTS</b>	CAV System	VAV System	
<b>RTU-6 Cooling Capacity (Tons)</b>	50	50	
<b>RTU-6 Efficiency (EER)</b>	10.0	10.0	
<b>RTU-6 SUPPLY FAN HP</b>	25	25	
<b>Cooling &amp; Fan Energy, Annual kWh</b>	148,064	107,315	
<b>Electric Cost (\$/kWh)</b>	\$0.135	\$0.135	
<b>ENERGY SAVINGS CALCULATIONS</b>			
<b>ECM RESULTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>Cooling &amp; Fan Energy Annual kWh</b>	148,064	107,315	40,749
<b>Electric Energy Cost (\$)</b>	\$19,989	\$14,488	\$5,501
<b>COMMENTS:</b> Existing and proposed kWh estimated using Trane System Analyzer software. ECM INPUTS references the tag labeled in the major equipment list but may not necessarily represent the tag of the equipment in the field.			



ENERGY CALCULATIONS - NATURAL GAS			
ECM INPUTS	EXISTING	PROPOSED	SAVINGS
ECM INPUTS	CAV System	VAV System	
RTU-6 Total Heating Energy (Therms)	1,787	1,144	
Boiler Efficiency (%)	74%	74%	
Heating Fuel Value	100,000	100,000	
Gas Cost (\$/Therm)	\$1.08	\$1.08	
ENERGY SAVINGS CALCULATIONS			
ECM RESULTS	EXISTING	PROPOSED	SAVINGS
Heating Energy, Therms	1,787	1,144	643
Heating Energy Cost (\$)	\$1,930	\$1,236	\$694
<b>COMMENTS:</b> Existing and proposed therms estimated using Trane System Analyzer software. ECM INPUTS references the tag labeled in the major equipment list but may not necessarily represent the tag of the equipment in the field.			

Installation cost of the new controls, demolition, terminal boxes, water piping modifications, ductwork modifications, electric, etc. is estimated to be \$72,181.

No incentives are available for the installation of this equipment.

#### Energy Savings Summary:

ECM #6 - ENERGY SAVINGS SUMMARY	
Installation Cost (\$):	\$72,181
NJ Smart Start Equipment Incentive (\$):	\$0
Net Installation Cost (\$):	\$72,181
Maintenance Savings (\$/Yr):	\$0
Energy Savings (\$/Yr):	\$6,196
Total Yearly Savings (\$/Yr):	\$6,196
Estimated ECM Lifetime (Yr):	15
Simple Payback	11.6
Simple Lifetime ROI	28.8%
Simple Lifetime Maintenance Savings	0
Simple Lifetime Savings	\$92,940
Internal Rate of Return (IRR)	3%
Net Present Value (NPV)	\$1,786.45

## **ECM #7: Cafeteria AC Unit Controls Upgrade**

### **Description:**

The cafeteria is conditioned by three (3) 15 ton York roof top units with direct expansion cooling and hot water heating coils mounted in the supply air duct. It was reported by the maintenance staff that these units operate in occupied mode 24/7 due to value engineering of the local controls at the unit at the time of original installation. Since these units are relatively new and in good condition, upgrading the controls and connecting into the main building automation system would yield energy savings.

A programmed schedule would provide energy savings by allowing the building automation system to setback the temperature setting when the space is not occupied and returning to the normal temperature setting when the space is occupied. The major benefit of this ECM is in the heating season since the outside temperature is the coldest during unoccupied periods. In night setback, the overall energy use is reduced since the inside temperature is kept closer to the outside temperature which limits heat loss.

This ECM includes installation of local direct digital controls at the three heating and cooling HVAC unit as well as integration with the existing building automation system. The recommended set point for the Cafeteria is as follows:

Occupied Heating =	70° F
Unoccupied Heating =	60° F
Occupied Cooling =	74° F
Unoccupied Cooling =	84° F

### **Energy Savings Calculations:**

Energy savings calculations are based on percent savings through heating degree days for standard base temperatures and set-back temperatures. The reduced heating degree days represents a lower heating load for the portion of hours that the thermostat is in night set-back.

Cooling energy savings is based on the capacity of the cooling equipment installed and the percent savings through the cooling degree days for standard base temperatures and set back temperatures. Since the night time cooling hours are typically at or below the occupied cooling set point, the cooling set back savings is based only on the estimated unoccupied daytime hours for the cafeteria.

Heating Energy Savings:

Total Hours per Week = 168

Available Setback Hours per Week = 128

$$\text{Set Back Heating Energy} = \text{Existing Gas (Therms)} \times \frac{\text{HDD}_{\text{SET}}}{\text{HDD}_{\text{65°F}}} \times \frac{\text{Set Back Hrs Per Week}}{168 \text{ Hrs per Week}}$$

$$\text{Non Set Back Heating Energy} = \text{Existing Gas (Therms)} \times \frac{\text{Non Set Back Hrs Per Week}}{168 \text{ Hrs per Week}}$$

$$\text{Heating Cost Savings} = \text{Energy Savings (Therms)} \times \text{Cost of Gas} \left( \frac{\$}{\text{Therm}} \right)$$

Energy savings calculations are summarized in the table below.

HEATING ENERGY CALCULATIONS			
ECM INPUTS	EXISTING	PROPOSED	SAVINGS
ECM INPUTS	Standard Controls	Integrated Controls	
Total Heating Energy (Therms)	4,074	4,074	
Heating Degree Days (70°F / 60°F)	6,029	4,064	
Hours of setback per week	0	128	
Heating Fuel Value	100,000	100,000	
Gas Cost (\$/Therm)	\$1.08	\$1.08	
ENERGY SAVINGS CALCULATIONS			
ECM RESULTS	EXISTING	PROPOSED	SAVINGS
Heating Energy, Therms	4,074	3,063	1,012
Heating Energy Cost (\$)	\$4,400	\$3,308	\$1,093
COMMENTS:	Degree Days based on McQuire AFB, NJ.		

Cooling Energy Savings:

$$\text{Cooling Energy kWh} = \text{Cooling Capacity, } \frac{\text{BTU}}{\text{Hr}} \times \left( \frac{1}{\text{EER}} \right) \times \frac{\text{Full Load Hrs}}{1000 \frac{\text{W}}{\text{kWh}}}$$

$$\text{Set Back Cooling Energy} = \text{Cooling Energy (kWh)} \times \frac{\text{HDD}_{82^{\circ}\text{F}}}{\text{HDD}_{72^{\circ}\text{F}}} \times \frac{\text{Set Back Hrs Per Week}}{168 \text{ Hrs per Week}}$$

$$\text{Non Set Back Cooling Energy} = \text{Cooling Energy (kWh)} \times \frac{\text{Non Set Back Hrs Per Week}}{168 \text{ Hrs per Week}}$$

$$\text{Cooling Cost Savings} = \text{Energy Savings, kWh} \times \text{Cost of Electricity} \left( \frac{\$}{\text{kWh}} \right)$$

COOLING ENERGY CALCULATIONS			
ECM INPUTS	EXISTING	PROPOSED	SAVINGS
ECM INPUTS	Standard Controls	Integrated Controls	
Tag RTU-5 Cooling Capacity (Tons) 3 Units	45	45	
Tag RTU-5 Total Efficiency (EER)	12.1	12.1	
Full Load Cooling Hrs	800	800	
Cooling Energy, kWh (Non Set Back)	45,302	45,302	
Cooling Degree Days (84°F / 74°F)	246	51	
Hours of setback per week	0	128	
Electric Cost (\$/kWh)	\$0.135	\$0.135	
ENERGY SAVINGS CALCULATIONS			
ECM RESULTS	EXISTING	PROPOSED	SAVINGS
Cooling Energy kWh	45,302	17,942	27,360
Electric Energy Cost (\$)	\$6,116	\$2,422	\$3,694
COMMENTS:	Degree Days based on McQuire AFB,NJ.		

Cost

The installed cost for this ECM is estimated at a total of \$23,988. No incentives are available for installation of HVAC controls.

**Energy Savings Summary:**

<b>ECM #7 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$23,988
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$0
<b>Net Installation Cost (\$):</b>	\$23,988
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$4,786
<b>Total Yearly Savings (\$/Yr):</b>	\$4,786
<b>Estimated ECM Lifetime (Yr):</b>	15
<b>Simple Payback</b>	5.0
<b>Simple Lifetime ROI</b>	199.3%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$71,790
<b>Internal Rate of Return (IRR)</b>	18%
<b>Net Present Value (NPV)</b>	\$33,146.96

## ECM #8: Water-Cooled Condensing Unit Replacement

### Description:

Portions of Corridor A at the high school are cooled by direct expansion, indoor, water-cooled condensing systems. The cooling media is from the domestic water supply and the waste water discharges to the sanitary system. There are approximately 10 units of this style all serving interior zones. These units are original to the building and they have surpassed their useful life as outlined in Chapter 36 of the 2007 ASHRAE Applications Handbook. The estimated service life for a water-cooled air conditioner is fifteen (15) years. Usually, energy savings derived from replacing condensing units does not justify a reasonable payback term. Nevertheless, as the equipment ages, it loses efficiency due to clogged condensers, internal parts wear and deposits of oil and other contaminants on the heat exchangers. Replacing an older condensing unit avoids these issues along with some energy savings. The new direct expansion system will not require the consumption of domestic water which yields considerable cost savings.

This energy conservation measure includes replacement of the water-cooled condensing systems with new variable refrigerant volume direct expansion air cooled condensing equipment at equal capacities with R-410a refrigerant. The cost of this ECM also includes running new refrigerant lines to a new condensing unit mounted on the roof.

It must be noted that manufacturing of the refrigerant R-22 is being gradually phased out. After 2010, HVAC manufacturers will continue to produce condensers and heat pumps using R-22 only from pre-existing R-22 supplies. The availability of R-22 gas will decline and R-22 equipment will be more expensive to maintain. On the other hand, converting most R-22 refrigeration systems into an alternative R-410a system requires replacement of the condensing unit, evaporator coils in the air handling unit, refrigerant pipes and fittings.

The unit's cooling efficiencies and capacities are as shown below. The owner should have a professional engineer verify cooling loads prior to moving forward with this ECM.

This ECM includes a one-to-one replacement of the older air conditioning units with newer, high efficiency systems. It is recommended to fully evaluate the capacity needed for all new systems prior to moving forward with this ECM. A summary of this ECM can be found in the table below:

IMPLEMENTATION SUMMARY						
ECM INPUTS	SERVICE FOR	NUMBER OF UNITS	COOLING CAPACITY, BTU/HR	COOLING CAPACITY, TONS	TOTAL COOLING CAPACITY, TONS	REPLACEMENT BASED ON
UV	Corridor A	10	24,000	2.0	20.0	Mitsubishi PURY-P240 and PFFY-P24

*ECM INPUTS references the tag labeled in the major equipment list but may not necessarily represent the tag of the equipment in the field.*

The basis of design is Mitsubishi equipment with R410a refrigerant.

**Energy Savings Calculations:**Cooling Energy Savings:

Seasonal energy consumption of the air conditioners during cooling mode is calculated with the equation below:

$$\text{Energy Savings, kWh} = \text{Cooling Capacity, } \frac{\text{BTU}}{\text{Hr}} \times \left( \frac{1}{\text{SEER}_{\text{Existing}}} - \frac{1}{\text{SEER}_{\text{Proposed}}} \right) \times \frac{\text{Full Load Hours}}{1000 \frac{\text{W}}{\text{kWh}}}$$

$$\text{Demand Savings, kW} = \frac{\text{Energy Savings (kWh)}}{\text{Hours of Cooling}}$$

$$\text{Cooling Cost Savings} = \text{Energy Savings, kWh} \times \text{Cost of Electricity} \left( \frac{\$}{\text{kWh}} \right)$$

ENERGY SAVINGS CALCULATIONS							
ECM INPUTS	COOLING CAPACITY, BTU/Hr	ANNUAL COOLING HOURS	EXISTING UNITS EER	PROPOSED EER	ENERGY SAVINGS kWh	DEMAND SAVINGS kW	COST SAVINGS \$
UV	24,000	800	10	14.1	5,583	7.0	\$754

Water Conservation Savings

Domestic water consumption of the air conditioners during cooling mode is calculated with the equation below:

$$\text{Water Cons} = \text{QtyUnits} \times \text{GPMperUnit} \times \text{CoolingLoadHours} \times 60\text{min}$$

$$\text{Water Cost} = \frac{\text{Water Cons (Gallons)} \times \text{Ave Cost} \left( \frac{\$}{1000 \text{ Gal}} \right)}{1000 (\text{Gal})}$$

WATER CONSERVATION CALCULATIONS			
ECM INPUTS	EXISTING	PROPOSED	SAVINGS
ECM INPUTS	Existing Water Cooled Units	Air Cooled Units	
Condenser Water GPM	40	0	40
Cooling Load Hours	800	800	
Water Cost (\$/1000)	\$5.70	\$5.70	
ENERGY SAVINGS CALCULATIONS			
ECM RESULTS	EXISTING	PROPOSED	SAVINGS
Water Consumption (Gal)	1,920,000	0	1,920,000
Water Cost (\$)	\$10,944	\$0	\$10,944
COMMENTS:			

From the **NJ Smart Start® Program Incentives Appendix**, the replacement AC units with high efficiency AC units falls under the category “Unitary HVAC Split System” and warrants an incentive based on efficiency (SEER) noted below. The program incentives are calculated as follows:

$$\text{SmartStart® Incentive} = (\text{CoolingTons} \times \$/\text{Ton Incentive})$$

AC UNITS REBATE SUMMARY				
UNIT DESCRIPTION	UNIT EFFICIENCY	REBATE \$/TON	PROPOSED CAPACITY TONS	TOTAL REBATE \$
5.4 tons or less Unitary AC and Split System	≥14 SEER	\$92	20.0	\$1,840



**Energy Savings Summary:**

<b>ECM #8 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$158,825
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$1,840
<b>Net Installation Cost (\$):</b>	\$156,985
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$11,698
<b>Total Yearly Savings (\$/Yr):</b>	\$11,698
<b>Estimated ECM Lifetime (Yr):</b>	15
<b>Simple Payback</b>	13.4
<b>Simple Lifetime ROI</b>	11.8%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$175,470
<b>Internal Rate of Return (IRR)</b>	1%
<b>Net Present Value (NPV)</b>	(\$17,335.04)

## ECM #9: Water Conservation

### Description:

The facility utilizes a mixture of old and new plumbing fixtures. The typical water closet and urinal water consumption only meet the minimum federally required standard for water efficiency. The existing urinals are automatically flushed by a time clock device that cycle every 15 minutes for a total of 28 flushes per day per urinal. New fixtures are available that use less water than today's requirements and can add up to significant water reduction over a long period of time.

This ECM includes the replacement of the existing water closets and urinals within the facility. The proposed retrofit includes installation of low flow flushometer style water closets that utilize 1.28 gallons per flush and ultra-low flushometer style urinals that utilize 1/8 gallons per flush. The time clock system for the urinals would also be disabled. For the basis of this calculation the LEED rating system was used to estimate the occupancy usage for students within the school. This ECM does not include private bathrooms for teachers use and is based solely on the large public bathrooms used by the students. When water consumption information was not available, the GPF values were estimated for the existing fixtures. The water cost per gallon was estimated based on other facilities served by the same municipality.

### Energy Savings Calculations:

$$Water\ Cons = Occupancy \left( \frac{Days}{Yr} \right) \times Use \left( \frac{Flush}{Person\ per\ Day} \right) \times Fixture \left( \frac{Gal}{Flush} \right)$$

$$Water\ Cost = \frac{Water\ Cons(Gallons) \times Ave\ Cost \left( \frac{\$}{1000\ Gal} \right)}{1000(Gal)}$$

<b>WATER CONSERVATION CALCULATIONS</b>			
<b>ECM INPUTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>ECM INPUTS</b>	Existing	Low Flow Fixtures	
<b>Total Number of Students</b>	1,169	1,169	
<b>% Male to Female</b>	50%	50%	
<b>Occupied Days Per Year</b>	180	180	
<b>WC Uses per Day per Person</b>	0.6	0.6	
<b>Urinal Uses per Day per Person</b>	NA	0.4	
<b>Total Urinal Flushes Per Day</b>	840	234	
<b>Total WC Flushes Per Day</b>	350.7	350.7	
<b>Urinal Gallons Per Flush (GPF)</b>	1.0	0.125	0.875
<b>WC Gallons Per Flush (GPF)</b>	3.5	1.28	2.22
<b>Water Cost (\$/1000)</b>	\$5.70	\$5.70	
<b>ENERGY SAVINGS CALCULATIONS</b>			
<b>ECM RESULTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>Water Consumption (Gal)</b>	527,541	86,062	441,479
<b>Water Cost (\$)</b>	\$3,007	\$491	\$2,516
<b>COMMENTS:</b>	*Savings are based on LEED Reference Guide for Green Building Design and Construction - 2009 Edition for WC and Urinal water usage.		

The cost for installation of 40 water closets and 30 low flow urinals throughout the facility is estimated to be \$52,124.

There are no Smart Start rebates for installation of low flow plumbing fixtures.

**Energy Savings Summary:**

<b>ECM #9 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$52,124
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$0
<b>Net Installation Cost (\$):</b>	\$52,124
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$2,516
<b>Total Yearly Savings (\$/Yr):</b>	\$2,516
<b>Estimated ECM Lifetime (Yr):</b>	30
<b>Simple Payback</b>	20.7
<b>Simple Lifetime ROI</b>	44.8%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$75,480
<b>Internal Rate of Return (IRR)</b>	3%
<b>Net Present Value (NPV)</b>	(\$2,809.29)

## ECM #10: Install NEMA Premium® Efficiency Motors

### Description:

The improved efficiency of the NEMA Premium® efficient motors is primarily due to better designs with use of better materials to reduce losses. Surprisingly, the electricity used to power a motor represents 95 % of its total lifetime operating cost. Because many motors operate continuously 24 hours a day, even small increases in efficiency can yield substantial energy and dollar savings.

The electric motors driving the hot water pumps in the old boiler room and supply fans in some of the heating and ventilating equipment are candidates for replacing with premium efficiency motors. These standard efficiency motors run considerable amount of time over a year.

This energy conservation measure replaces existing electric motors over 5 HP or more with NEMA Premium® efficiency motors. NEMA Premium® is the most efficient motor designation in the marketplace today.

IMPLEMENTATION SUMMARY								
EQMT ID	FUNCTION	MOTOR HP	POLE	RPM	FRAME TYPE	HOURS OF OPERATION	EXISTING EFFICIENCY	NEMA PREMIUM EFFICIENCY
Zone 1 (P-2)	Hot Water Pump	20	4	1750	TEFC	4,320	88.5%	93.0%
Zone 2	Hot Water Pump	10	4	1750	TEFC	4,320	89.5%	92.4%
HV-1	Supply Fan	5	4	1750	TEFC	4,320	82.0%	90.2%
HV-3	Supply Fan	5	4	1750	TEFC	4,320	82.0%	90.2%
HV-2	Supply Fan	5	4	1750	TEFC	4,320	82.0%	90.2%
HV-4	Supply Fan	5	4	1750	TEFC	4,320	82.0%	90.2%

### Energy Savings Calculations:

$$\text{Electric usage, kWh} = \frac{\text{HP} \times \text{LF} \times 0.746 \times \text{Hours of Operation}}{\text{Motor Efficiency}}$$

where, HP = Motor Nameplate Horsepower Rating

$$\text{LF} = \text{Load Factor} \quad \text{Motor Efficiency} = \text{Motor Nameplate Efficiency}$$

$$\text{Electric Usage Savings, kWh} = \text{Electric Usage}_{\text{Existing}} - \text{Electric Usage}_{\text{Proposed}}$$

$$\text{Electric Usage Savings, kWh} = \text{Electric Usage}_{\text{Existing}} - \text{Electric Usage}_{\text{Proposed}}$$

$$\text{Electric cost savings} = \text{Electric Usage Savings} \times \text{Electric Rate} \left( \frac{\$}{\text{kWh}} \right)$$

The calculations were carried out and the results are tabulated in the table below:

<b>PREMIUM EFFICIENCY MOTOR CALCULATIONS</b>							
<b>EQMT ID</b>	<b>MOTOR HP</b>	<b>LOAD FACTOR</b>	<b>EXISTING EFFICIENCY</b>	<b>NEMA PREMIUM EFFICIENCY</b>	<b>POWER SAVINGS kW</b>	<b>ENERGY SAVINGS kWh</b>	<b>COST SAVINGS</b>
Zone 1 (P-2)	20	90%	88.5%	93.0%	0.73	3,189	\$430
Zone 2	10	90%	89.5%	92.4%	0.24	1,023	\$138
HV-1	5	90%	82.0%	90.2%	0.37	1,616	\$218
HV-3	5	90%	82.0%	90.2%	0.37	1,616	\$218
HV-2	5	90%	82.0%	90.2%	0.37	1,616	\$218
HV-4	5	90%	82.0%	90.2%	0.37	1,616	\$218
<b>TOTAL</b>					<b>2.5</b>	<b>10,677</b>	<b>\$1,441</b>

### Project Cost, Incentives and Maintenance Savings

The Smart Start Incentives are calculated from the **NJ Smart Start® Program Incentives Appendix**. The results are listed below.

The following table outlines the summary of motor replacement costs and incentives:

<b>MOTOR REPLACEMENT SUMMARY</b>						
<b>EQMT ID</b>	<b>MOTOR POWER HP</b>	<b>INSTALLED COST</b>	<b>SMART START INCENTIVE</b>	<b>NET COST</b>	<b>TOTAL SAVINGS</b>	<b>SIMPLE PAYBACK</b>
Zone 1 (P-2)	20	\$4,635	\$125	\$4,510	\$430	10.5
Zone 2	10	\$2,560	\$100	\$2,460	\$138	17.8
HV-1	5	\$1,519	\$60	\$1,459	\$218	6.7
HV-3	5	\$1,519	\$60	\$1,459	\$218	6.7
HV-2	5	\$1,519	\$60	\$1,459	\$218	6.7
HV-4	5	\$1,519	\$60	\$1,459	\$218	6.7
<b>TOTAL</b>	<b>Totals:</b>	<b>\$13,271</b>	<b>\$465</b>	<b>\$12,806</b>	<b>\$1,441</b>	<b>8.9</b>

**Energy Savings Summary:**

<b>ECM #10 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$13,271
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$465
<b>Net Installation Cost (\$):</b>	\$12,806
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$1,441
<b>Total Yearly Savings (\$/Yr):</b>	\$1,441
<b>Estimated ECM Lifetime (Yr):</b>	18
<b>Simple Payback</b>	8.9
<b>Simple Lifetime ROI</b>	102.5%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$25,938
<b>Internal Rate of Return (IRR)</b>	9%
<b>Net Present Value (NPV)</b>	\$7,012.81

## ECM #11: Valve Blanket Insulation Installation

### Description:

The boiler plant supplies heating hot water to the facility for heating season. The piping remains heated at approximately 180°F continuously during this period (approximately 6 months). Un-insulated piping has significant heat losses due to the exposure of the steel piping to the surrounding air. Insulated piping has a heat loss which is a small fraction of the heat loss from un-insulated piping. It was noted that the majority of piping within the boiler room was insulated however numerous valves throughout the system have not been insulated.

Based on the site survey approximately 25 pipe valves were not insulated. Valve blankets are designed to provide insulation value over large hydronic valves that must remain accessible. This ECM includes installation of valve blankets on all exposed boiler system valves within the boiler room.

### Energy Savings Calculations:

Heat Loss for un-insulated steel piping is based on ASHRAE 2009 Fundamentals – “Insulation for Mechanical Systems”

Bare Steel Piping Heat Loss 6” pipe: 373 BTU/HR per Linear FT

$$\text{Heat Loss} \frac{\text{BTU}}{\text{HR}} \text{ per Linear FT} = \frac{1}{R - \text{Value}} \times \text{Pipe Dia (FT)} \times 3.14 \times (\text{Pipe Temp (°F)} - \text{Ambient Temp (°F)})$$

$$\text{Heat Loss} \frac{\text{BTU}}{\text{HR}} = \text{Heat Loss} \frac{\text{BTU}}{\text{HR}} \text{ per Linear FT} \times \text{Length of Uninsulated Pipe}$$

$$\text{Energy Use, Therms} = \frac{\text{Heat Loss} \frac{\text{BTU}}{\text{HR}} \times \text{Operating Hrs}}{\text{Heating System Eff. (\%)} \times \text{Fuel Heat Value} \frac{\text{BTU}}{\text{Therm}}}$$

$$\text{Heating Energy Cost Savings} = \text{Energy Use, Therms} \times \text{Cost of Nat Gas} \left( \frac{\$}{\text{Therm}} \right)$$



VALVE BLANKET INSULATION CALCULATIONS			
ECM INPUTS	EXISTING	PROPOSED	SAVINGS
ECM INPUTS	Bare Pipe	Insulation Blanket	
Length of Un-Insulated Pipe	25	25	
Pipe Diameter (In)	6	6	
Blanket Insulation R-value	0	6	6
Temperature Difference Pipe	100	100	
Pipe Heat Loss - 6" Pipe	373	26	347
Heat Loss (BTU/Hr)	9,325	654	8,671
Heating System Operating Hrs	4380	4380	
Energy Loss (kBtus)	40,844	2,865	37,978
Heating System Eff (%)	74%	74%	
Fuel Heat Value (BTU/Therm)	100,000	100,000	
Nat Gas Cost (\$/Therm)	1.08	1.08	
ENERGY SAVINGS CALCULATIONS			
ECM RESULTS	EXISTING	PROPOSED	SAVINGS
Nat Gas Usage Usage (Therms)	552	39	513
Energy Cost (\$)	\$596	\$42	\$554
COMMENTS:	Bare Pipe Heat Loss value is based on ASHRAE 2009 Fundamentals "Insulation for Mechanical Systems"		

There is no maintenance savings due to implementation of this ECM.

**Energy Savings Summary:**

<b>ECM #11 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$10,000
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$0
<b>Net Installation Cost (\$):</b>	\$10,000
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$554
<b>Total Yearly Savings (\$/Yr):</b>	\$554
<b>Estimated ECM Lifetime (Yr):</b>	24
<b>Simple Payback</b>	18.1
<b>Simple Lifetime ROI</b>	33.0%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$13,296
<b>Internal Rate of Return (IRR)</b>	2%
<b>Net Present Value (NPV)</b>	(\$617.71)

## **ECM #12: Kitchen Hood Controls**

### **Description:**

The Highland High School kitchen is equipped with two exhaust hood systems for the cooking ranges in the kitchen. The size of each range hood is 4'x20'. The kitchen exhaust fan is controlled manually by a switch on the kitchen hoods.

Standard kitchen hood controls consist of switches and relays that interlock the kitchen grease hood exhaust fan(s) with the 100% outside air unit that provides make-up air for this system. Normal occupation of kitchen hood system is limited to occupied hours. During the site inspection it was noted that the kitchen exhaust fan runs for approximately 4 hours a day. Based on the operation, there is great potential energy savings through better controls of the hood exhaust fan and make-up air unit. It should be noted that make up air is supplied via transfer air from the food line area and adjacent corridors.

This energy conservation measure involves installing a Melink Kitchen Hood Variable Air Volume Controller; variable frequency drive on the kitchen hood exhaust fan; and turn off all the kitchen hood exhaust systems when the kitchen is closed. When the cooking appliances are turned on, the hood exhaust fan speed will increase based on the hood exhaust temperature. During heavy cooking, the kitchen hood exhaust fan increases to 100% speed until the smoke/vapor is removed. Energy savings are also realized when the kitchen equipment is operating at less than full load due to minimal cooking operations. During these times the fan speed decreases, removing only the necessary amount of air, saving exhaust fan energy and make up air conditioning energy.

### **Energy Calculations Summary:**

It is pertinent to note that the calculation assumes the exhaust fans and make-up air unit are manually turned off for approximately 8 hours per day.

The calculations were carried out and the results are tabulated in the table below.

ENERGY CALCULATIONS - NATURAL GAS			
ECM INPUTS	EXISTING	PROPOSED	SAVINGS
ECM INPUTS	CAV System	VAV System	
Make up Air Unit Total Heating Energy (Therms)	1,365	1,010	
Boiler Efficiency (%)	74%	74%	
Heating Fuel Value	100,000	100,000	
Gas Cost (\$/Therm)	\$1.08	\$1.08	
ENERGY SAVINGS CALCULATIONS			
ECM RESULTS	EXISTING	PROPOSED	SAVINGS
Heating Energy, Therms	1,365	1,010	355
Heating Energy Cost (\$)	\$1,475	\$1,091	\$383
COMMENTS:			

ENERGY CALCULATIONS - ELECTRIC			
ECM INPUTS	EXISTING	PROPOSED	SAVINGS
ECM INPUTS	CAV System	VAV System	
Supply Fan HP	2	2	
Fan Energy, Annual kWh	2,652	1,314	
Electric Cost (\$/kWh)	\$0.135	\$0.135	
ENERGY SAVINGS CALCULATIONS			
ECM RESULTS	EXISTING	PROPOSED	SAVINGS
Fan Energy Annual kWh	2,652	1,314	1,339
Electric Energy Cost (\$)	\$358	\$177	\$181
COMMENTS:			

**Energy Savings Summary:**

<b>ECM #12 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$10,671
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$0
<b>Net Installation Cost (\$):</b>	\$10,671
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$564
<b>Total Yearly Savings (\$/Yr):</b>	\$564
<b>Estimated ECM Lifetime (Yr):</b>	15
<b>Simple Payback</b>	18.9
<b>Simple Lifetime ROI</b>	-20.7%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$8,460
<b>Internal Rate of Return (IRR)</b>	-3%
<b>Net Present Value (NPV)</b>	(\$3,938.00)

## VIII. RENEWABLE/DISTRIBUTED ENERGY MEASURES

Globally, renewable energy has become a priority affecting international and domestic energy policy. The State of New Jersey has taken a proactive approach, and has recently adopted in its Energy Master Plan a goal of 30% renewable energy by 2020. To help reach this goal New Jersey created the Office of Clean Energy under the direction of the Board of Public Utilities and instituted a Renewable Energy Incentive Program to provide additional funding to private and public entities for installing qualified renewable technologies. A renewable energy source can greatly reduce a building's operating expenses while producing clean environmentally friendly energy. CEG has assessed the feasibility of installing renewable energy measures (REM) for the municipality utilizing renewable technologies and concluded that there is potential for solar energy generation. The solar photovoltaic system calculation summary will be concluded as **REM#1** within this report.

### Solar Generation

Solar energy produces clean energy and reduces a building's carbon footprint. This is accomplished via photovoltaic panels which are mounted on all south and southwestern facades of the building. Flat roof, as well as sloped areas can be utilized; flat areas will have the panels turned to an optimum solar absorbing angle. (A structural survey of the roof would be necessary before the installation of PV panels is considered). Parking lots can also be utilized for the installation of a solar array. A truss system can be installed that is high enough to park vehicles under the array and no parking lot area is lost. The state of NJ has instituted a program in which one Solar Renewable Energy Certificate (SREC) is given to the Owner for every 1000 kWh of generation. SREC's can be sold anytime on the market at their current market value. The value of the credit varies upon the current need of the power companies. The average value per credit is around \$350, this value was used in our financial calculations. This equates to \$0.35 per kWh generated.

CEG has reviewed the existing roof area and parking lots of the facility being audited for the purposes of determining a potential for a roof and ground mounted photovoltaic system. A total roof and ground area of 62,378 S.F. can be utilized for a PV system. A depiction of the area utilized is shown in **Renewable / Distributed Energy Measures Calculation Appendix**. Using this square footage it was determined that a system size of 878.14 kilowatts could be installed. A system of this size has an estimated kilowatt hour production of 1,097,957 KWh annually, reducing the overall utility bill by approximately 63% percent. A detailed financial analysis can be found in the **Renewable / Distributed Energy Measures Calculation Appendix**. This analysis illustrates the payback of the system over a 25 year period. The eventual degradation of the solar panels and the price of accumulated SREC's are factored into the payback.

The proposed photovoltaic array layout is designed based on the specifications for the Sun Power SPR-230 panel. This panel has a "DC" rated full load output of 230 watts, and has a total panel conversion efficiency of 18%. Although panels rated at higher wattages are available through Sun Power and other various manufacturers, in general most manufacturers who produce commercially available solar panels produce a similar panel in the 200 to 250 watt range. This

provides more manufacturer options to the public entity if they wish to pursue the proposed solar recommendation without losing significant system capacity.

The array system capacity was sized on available roof space on the existing facility. Estimated solar array generation was then calculated based on the National Renewable Energy Laboratory PVWatts Version 1.0 Calculator. In order to calculate the array generation an appropriate location with solar data on file must be selected. In addition the system DC rated kilowatt (kW) capacity must be inputted, a DC to AC de-rate factor, panel tilt angle, and array azimuth angle. The DC to AC de-rate factor is based on the panel nameplate DC rating, inverter and transformer efficiencies (95%), mismatch factor (98%), diodes and connections (100%), dc and ac wiring(98%, 99%), soiling, (95%), system availability (95%), shading (if applicable), and age(new/100%). The overall DC to AC de-rate factor has been calculated at an overall rating of 81%. The PVWatts Calculator program then calculates estimated system generation based on average monthly solar irradiance and user provided inputs. The monthly energy generation and offset electric costs from the PVWatts calculator is shown in the **Renewable/Distributed Energy Measures Calculation Appendix**.

The proposed solar array is qualified by the New Jersey Board of Public Utilities Net Metering Guidelines as a Class I Renewable Energy Source. These guidelines allow onsite customer generation using renewable energy sources such as solar and wind with a capacity of 2 megawatts (MW) or less. This limits a customer system design capacity to being a net user and not a net generator of electricity on an annual basis. Although these guidelines state that if a customer does net generate (produce more electricity than they use), the customer will be credited those kilowatt-hours generated to be carried over for future usage on a month to month basis. Then, on an annual basis if the customer is a net generator the customer will then be compensated by the utility the average annual PJM Grid LMP price per kilowatt-hour for the over generation. Due to the aforementioned legislation, the customer is at limited risk if they generate more than they use at times throughout the year. With the inefficiency of today's energy storage systems, such as batteries, the added cost of storage systems is not warranted and was not considered in the proposed design.

Direct purchase involves the school paying for 100% of the total project cost upfront via one of the methods noted in the Installation Funding Options section below. Calculations include a utility inflation rate as well as the degradation of the solar panels over time. Based on our calculations the following is the payback period:

**Table 7**  
**Financial Summary – Photovoltaic System**

<b>FINANCIAL SUMMARY - PHOTOVOLTAIC SYSTEM</b>			
<b>PAYMENT TYPE</b>	<b>SIMPLE PAYBACK</b>	<b>SIMPLE ROI</b>	<b>INTERNAL RATE OF RETURN</b>
Direct Purchase	14.8 Years	68.4%	5%

\*The solar energy measure is shown for reference in the executive summary Renewable Energy Measure (REM) table

Given the large amount of capital required by the school to invest in a solar system through a Direct Purchase CEG does not recommend the school pursue this route. It would be more advantageous for the school to solicit Power Purchase Agreement (PPA) Providers who will own, operate, and maintain the system for a period of 15 years. During this time the PPA Provider would sell all of the electric generated by Solar Arrays to the school at a reduced rate compared to their existing electric rate.



## IX. ENERGY PURCHASING AND PROCUREMENT STRATEGY

### Load Profile:

Load Profile analysis was performed to determine the seasonal energy usage of the facility. Irregularities in the load profile will indicate potential problems within the facility. Consequently based on the profile a recommendation will be made to remedy the irregularity in energy usage. For this report, the facility's energy consumption data was gathered in table format and plotted in graph form to create the load profile. Refer to The Electric and Natural Gas Usage Profiles included within this report to reference the respective electricity and natural gas usage load profiles.

### Electricity:

The electricity usage profile demonstrates a steady year long load profile for facilities that have occupancy during the summer months. The average monthly usage for all accounts combined is 593,126 kWh.

The historical usage profile is beneficial and will allow for more competitive energy prices when shopping for alternative suppliers mainly due to the relatively flat load profile. Third Party Supplier (TPS) electric commodity contracts that offer's a firm, fixed price for 100% of the facilities electric requirements and are lower than the Atlantic City Electric's (AECO) BGS-FP and PSE&G's BGS-FP default rate are recommended.

### Natural Gas:

The Natural Gas Usage Profile demonstrates a very typical natural gas (heat load) profile. The summer months June through August have little consumption.

This load profile will yield less favorable natural gas pricing when shopping for alternative suppliers. This is because the higher winter month consumption will yield higher pricing which will not be offset by the summer month consumption. Nymex commodity pricing is generally higher in the winter months of November – March and lower in the summer months of April – October. Obtaining a flat load profile, (usage is similar each month), will yield optimum natural gas pricing when shopping for alternative suppliers. Third Party Supplier (TPS) natural gas commodity contracts that offer a product structure to include either 1) a fixed basis rate with a market based Nymex/commodity rate or 2) a fixed basis rate with fixed Nymex/commodity winter rate (Nov – March) and market based Nymex/commodity rate for the summer months (April – October) for 100% of the facilities **metered** natural gas requirements are both recommended due to current market pricing.

**Tariff Analysis:**Electricity:

The facilities receive electrical service through Atlantic City Electric (AECO) on AGS-Sec (Annual General Service Secondary) and PSE&G's GPL (General Power and Light) and LPLS (Large Power and Light Service). The facilities have contracted a Third Party Supplier (TPS) to provide electric commodity service. Current Third Party Supplier Terms and Conditions are unknown. For electric supply (generation) service, the client has a choice to either use AECO's or PSE&G's default service rate BGS-FP or contract with a Third Party Supplier (TPS) to supply electric.

Each year since 2002, the four New Jersey Electric Distribution Companies (EDCs) - Public Service Gas & Electric Company (PSE&G), Atlantic City Electric Company (ACE), Jersey Central Power & Light Company (JCP&L), and Rockland Electric Company (RECO) - have procured several billion dollars of electric supply to serve their Basic Generation Service (BGS) customers through a statewide auction process held in February.

BGS refers to the service of customers who are not served by a third party supplier or competitive retailer. This service is sometimes known as Standard Offer Service, Default Service, or Provider of Last Resort Service.

The Auction Process has consisted of two auctions that are held concurrently, one for larger customers on an hourly price plan (BGS-CIEP) and one for smaller commercial and residential customers on a fixed-price plan (BGS-FP). This facility's rate structure is based on the fixed-price plan (BGS-FP).

The utility's, Atlantic City Electric and PSE&G will continue to be responsible for maintaining the existing network of wires, pipes and poles that make up the delivery system, which will serve all consumers, regardless of whom they choose to purchase their electricity or natural gas from. AECO's delivery service rate includes the following charges: Customer Service Charge, Distribution Charge, Market Transition, Transition Bond Charge, Non Utility Generation Charge, Societal Benefits Charge (SBC), Infrastructure Investment Charge, System Control Charge, Regulatory Assets Recovery Charge, and Regional Greenhouse Gas Initiative Charge. PSE&G's delivery service rate includes the following charges: Customer Service Charge, Distribution Charge (kWh and Demand), Societal Benefits Charge (SBC), and Securitization Transition Charge.

Natural Gas:

The facilities currently receive natural gas distribution service through South Jersey Gas on rate schedules General Service Gas - Firm Transportation (GSG-FT). Hess Energy is the contracted Third Party Supplier (TPS) which provides natural gas commodity supply service. The terms and conditions of the natural gas contract with Hess Energy is not available.

South Jersey Gas provides basic gas supply service (BGSS) to customers who choose not to shop from a Third Party Supplier (TPS) for natural gas commodity. The option is essential to protect

the reliability of service to consumers as well as protecting consumers if a third party supplier defaults or fails to provide commodity service. Please refer to the link below for a recap of natural gas BGSS charges from South Jersey Gas for rate schedule GSG.

<http://www.southjerseygas.com/108/tariff/bgssrates.pdf>

The utility, South Jersey Gas is responsible for maintaining the existing network of wires, pipes and poles that make up the delivery system, which will serve all consumers, regardless of whom they choose to purchase their electricity or natural gas from. South Jersey Gas's delivery service rate includes the following charges: Customer Service Charge, Distribution Charge, & Societal Benefits Charge (SBC).

### **Electric and Natural Gas Commodities Market Overview:**

*Current electricity and natural gas market pricing has remained relatively stable over the last year. Commodity pricing in 2008 marked historical highs in both natural gas and electricity commodity. Commodity pricing commencing spring of 2009 continuing through 2011, has decreased dramatically over 2008 historic highs and continues to be favorable for locking in long term (2-5 year) contracts with 3<sup>rd</sup> Party Supplier's for both natural gas and electricity supply requirements.*

It is important to note that both natural gas and electric commodity market prices are moved by supply and demand, political conditions, market technicals and trader sentiment. This market is continuously changing Energy commodity pricing is also correlated to weather forecasts. Because weather forecasts are dependable only in the short-term, prolonged temperature extremes can really cause extreme price swings.


### **Short Term Energy Outlook - US Energy Information Administration (3/08/2011):**

**U.S. Natural Gas Prices.** *The Henry Hub spot price averaged \$4.09 per MMBtu in February 2011, \$0.40 per MMBtu less than the average spot price in January 2011. EIA expects that the Henry Hub spot price will average \$4.10 per MMBtu in 2011, a drop of \$0.29 per MMBtu from the 2010 average. EIA expects the natural gas market to begin to tighten in 2012, with the Henry Hub spot price increasing to an average of \$4.58 per MMBtu.*


*Uncertainty over future natural gas prices is slightly lower this year compared with last year at this time. Natural gas futures for May 2011 delivery (for the 5-day period ending March 3) averaged \$3.98 per MMBtu, and the average implied volatility over the same period was 33 percent. This produced lower and upper bounds for the 95-percent confidence interval for May 2011 contracts of \$3.09 per MMBtu and \$5.11 per MMBtu, respectively. At this time last year, the natural gas May 2010 futures contract averaged \$4.77 per MMBtu and implied volatility averaged 39 percent. The corresponding lower and upper limits of the 95-percent confidence interval were \$3.57 per MMBtu and \$6.39 per MMBtu.*


**U.S. Electricity Retail Prices.** *During 2010, retail prices for electricity distributed to the residential sector averaged 11.58 cents per kilowatthour, about the same level as in 2009. EIA expects residential prices to rise by 1.0 percent in 2011, followed by an increase of 0.5 percent in*

2012. The effect of lower generation fuel costs in 2011 should be more evident in retail prices for electricity distributed to the industrial sector, which EIA projects will fall 1.6 percent during 2011 and then rise 0.2 percent next year.



Annual Retail Price of Electricity in Commercial Sector, Middle Atlantic





*Pricing includes both utility distribution and energy commodity charges.*

### Recommendations:

1. CEG recommends an aggregated approach for 3<sup>rd</sup> party commodity supply procurement strategies for both electric and natural gas supply service. Aggregating the usage of all facilities for electricity and natural gas supply service, would allow the facilities to either continue to achieve or achieve a reduction in commodity supply costs. Energy commodities are among the most volatile of all commodities, however at this point and time, energy is extremely competitive and contract terms longer than 12 months are desirable. Contracts due to expire in the near term would continue to yield favorable pricing. It is important to aggregate usage where available and take advantage of these current market prices quickly, before energy increases.

*The below recommendations presented by CEG are based on current information provided by the school facilities for its utility usage. Any savings presented with these recommendations are estimates only based on that information. It is recommended that further analysis and review of more recent utility data and actual TPS contracts be performed prior to performing any of the presented recommendations.*

Overall, after review of the utility consumption, billing, and current commodity pricing outlook, CEG recommends that the facilities participate in the energy supply aggregation groups for both electricity and natural gas supply service for all facilities. Many aggregation groups utilize the advisement of a 3<sup>rd</sup> party unbiased Energy Consulting Firm experienced in the aggregation of and procurement of retail electricity and natural gas commodity. It is important to note that the Energy Consulting Firm should incorporate a

rational, defensible strategy for purchasing commodity in volatile markets based upon the following:

- Budgets that reflect sound market intelligence
  - An understanding of historical prices and trends
  - Awareness of seasonal opportunities (e.g. shoulder months)
  - Negotiation of fair contractual terms
  - An aggressive, market based price
2. CEG recommends that the school district consider utilizing a third party utility billing-auditing service to further analyze historical utility invoices such as water, sewer, natural gas and electric for incorrect billings and rate tariff optimization services. This service can be based on a shared savings model with no cost to the school district. The service could provide refunds on potential incorrect billings that may have been passed through by the utilities and paid by the school.

## X. INSTALLATION FUNDING OPTIONS

CEG has reviewed various funding options for the facility owner to utilize in subsidizing the costs for installing the energy conservation measures noted within this report. Below are a few alternative funding methods:

- i. *Energy Savings Improvement Program (ESIP)* – Public Law 2009, Chapter 4 authorizes government entities to make energy related improvements to their facilities and pay for the costs using the value of energy savings that result from the improvements. The “Energy Savings Improvement Program (ESIP)” law provides a flexible approach that can allow all government agencies in New Jersey to improve and reduce energy usage with minimal expenditure of new financial resources.
- ii. *Municipal Bonds* – Municipal bonds are a bond issued by a city or other local government, or their agencies. Potential issuers of municipal bonds include cities, counties, redevelopment agencies, school districts, publicly owned airports and seaports, and any other governmental entity (or group of governments) below the state level. Municipal bonds may be general obligations of the issuer or secured by specified revenues. Interest income received by holders of municipal bonds is often exempt from the federal income tax and from the income tax of the state in which they are issued, although municipal bonds issued for certain purposes may not be tax exempt.
- iii. *Power Purchase Agreement* – Public Law 2008, Chapter 3 authorizes contractor of up to fifteen (15) years for contracts commonly known as “power purchase agreements.” These are programs where the contracting unit (Owner) procures a contract for, in most cases, a third party to install, maintain, and own a renewable energy system. These renewable energy systems are typically solar panels, windmills or other systems that create renewable energy. In exchange for the third party’s work of installing, maintaining and owning the renewable energy system, the contracting unit (Owner) agrees to purchase the power generated by the renewable energy system from the third party at agreed upon energy rates.
- iv. *Pay For Performance* – The New Jersey Smart Start Pay for Performance program includes incentives based on savings resulted from implemented ECMs. The program is available for all buildings that were audited as part of the NJ Clean Energy’s Local Government Energy Audit Program. The facility’s participation in the program is assisted by an approved program partner. An “Energy Reduction Plan” is created with the facility and approved partner to show at least 15% reduction in the building’s current energy use. Multiple energy conservation measures implemented together are applicable toward the total savings of at least 15%. No more than 50% of the total energy savings can result from lighting upgrades / changes.

Total incentive is capped at 50% of the project cost. The program savings is broken down into three benchmarks; Energy Reduction Plan, Project Implementation, and Measurement and Verification. Each step provides additional incentives as the energy reduction project continues. The benchmark incentives are as follows:

1. Energy Reduction Plan – Upon completion of an energy reduction plan by an approved program partner, the incentive will grant \$0.10 per square foot between \$5,000 and \$50,000, and not to exceed 50% of the facility’s annual energy expense. (Benchmark #1 is not provided in addition to the local government energy audit program incentive.)
  2. Project Implementation – Upon installation of the recommended measures along with the “Substantial Completion Construction Report,” the incentive will grant savings per KWH or Therm based on the program’s rates. Minimum saving must be 15%. (Example \$0.11 / kWh for 15% savings, \$0.12/ kWh for 17% savings, ... and \$1.10 / Therm for 15% savings, \$1.20 / Therm for 17% saving, ...) Increased incentives result from projected savings above 15%.
  3. Measurement and Verification – Upon verification 12 months after implementation of all recommended measures, that actual savings have been achieved, based on a completed verification report, the incentive will grant additional savings per kWh or Therm based on the program’s rates. Minimum savings must be 15%. (Example \$0.07 / kWh for 15% savings, \$0.08/ kWh for 17% savings, ... and \$0.70 / Therm for 15% savings, \$0.80 / Therm for 17% saving, ...) Increased incentives result from verified savings above 15%.
- v. *Energy Efficiency and Conservation Block Grants* – The EECGB rebate provides supplemental funding up to \$20,000 for counties and local government entities to implement energy conservation measures. The EECGB funding is provided through the American Recovery and Reinvestment Act (ARRA). The local government must be among the eligible local government entities listed on the NJ Clean Energy website as follows - <http://njcleanenergy.com/commercial-industrial/programs/eeecbg-eligible-entities>. This program is limited to municipalities and counties that have not already received grants directly through the US department of Energy.

This incentive is provided in addition to the other NJ Clean Energy program funding. This program’s incentive is considered the entity’s capital and therefore can be applied to the LGEA program’s requirements to implement the recommended energy conservation measures totaling at least 25% of the energy audit cost. Additional requirements of this program are as follows:



1. The entity must utilize additional funding through one or more of the NJ Clean Energy programs such as Smart Start, Direct Install, and Pay for Performance.
2. The EECBG funding in combination with other NJ Clean Energy programs may not exceed the total cost of the energy conservation measures being implemented.
3. Envelope measures are applicable only if recommended by the LGEA energy audit and if the energy audit was completed within the past 12 months.
4. New construction and previously installed measures are not eligible for the EECBG rebate.
5. Energy conservation measures eligible for the EECBG must fall within the list of approved energy conservation measures. The complete list of eligible measures and other program requirements are included in the “EECBG Complete Application Package.” The application package is available on the NJ Clean Energy website - <http://njcleanenergy.com/commercial-industrial/programs/energy-efficiency-and-conservation-block-grants>.

CEG recommends the Owner review the use of the above-listed funding options in addition to utilizing their standard method of financing for facilities upgrades in order to fund the proposed energy conservation measures.

## **XI. ADDITIONAL RECOMMENDATIONS**

The following recommendations include no cost/low cost measures, Operation & Maintenance (O&M) items, and water conservation measures with attractive paybacks. These measures are not eligible for the Smart Start Buildings incentives from the office of Clean Energy but save energy none the less.

- A. Chemically clean the condenser and evaporator coils periodically to optimize efficiency. Poorly maintained heat transfer surfaces can reduce efficiency 5-10%.
- B. Maintain all weather stripping on windows and doors.
- C. Clean all light fixtures to maximize light output.
- D. Provide more frequent air filter changes to decrease overall system power usage and maintain better IAQ.
- E. Confirm that outside air economizers on the rooftop units are functioning properly to take advantage of free cooling and avoid excess outside air during occupied periods.

In addition to the recommendations above, implementing Retro-Commissioning would be beneficial for this facility. Retro-Commissioning is a means to verify your current equipment is operating at its designed efficiency, capacity, airflow, and overall performance. Retro-Commissioning provides valuable insight into systems or components not performing correctly or efficiently. The commissioning process defines the original system design parameters and recommends revisions to the current system operating characteristics.

## XII. ENERGY AUDIT ASSUMPTIONS

The assumptions utilized in this energy audit include but are not limited to following:

- A. Cost Estimates noted within this report are based on industry accepted costing data such as RS Means<sup>TM</sup> Cost Data, contractor pricing and engineering estimates. All cost estimates for this level of auditing are +/- 20%. Prevailing wage rates for the specified region has been utilized to calculate installation costs. The cost estimates indicated within this audit should be utilized by the owner for prioritizing further project development post the energy audit. Project development would include investment grade auditing and detailed engineering.
- B. Energy savings noted within this audit are calculated utilizing industry standard procedures and accepted engineering assumptions. For this level of auditing, energy savings are not guaranteed.
- C. Information gathering for each facility is strongly based on interviews with operations personnel. Information dependent on verbal feedback is used for calculation assumptions including but not limited to the following:
  - a. operating hours
  - b. equipment type
  - c. control strategies
  - d. scheduling
- D. Information contained within the major equipment list is based on the existing owner documentation where available (drawings, O&M manuals, etc.). If existing owner documentation is not available, catalog information is utilized to populate the required information.
- E. Equipment incentives and energy credits are based on current pricing and status of rebate programs. Rebate availability is dependent on the individual program funding and applicability.
- F. Equipment (HVAC, Plumbing, Electrical, & Lighting) noted within an ECM recommendation is strictly noted as a **basis for calculation** of energy savings. The owner should use this equipment information as a benchmark when pursuing further investment grade project development and detailed engineering for specific energy conservation measures.

Utility bill annual averages are utilized for calculation of all energy costs unless otherwise noted. Accuracy of the utility energy usage and costs are based on the information provided. Utility information including usage and costs is estimated where incomplete data is provided.

**ECM COST & SAVINGS BREAKDOWN**  
CONCORD ENGINEERING GROUP

Highland High School

ECM ENERGY AND FINANCIAL COSTS AND SAVINGS SUMMARY															
ECM NO.	DESCRIPTION	INSTALLATION COST				YEARLY SAVINGS			ECM LIFETIME	LIFETIME ENERGY SAVINGS	LIFETIME MAINTENANCE SAVINGS	LIFETIME ROI	SIMPLE PAYBACK	INTERNAL RATE OF RETURN	NET PRESENT VALUE (NPV)
		MATERIAL	LABOR	REBATES, INCENTIVES	NET INSTALLATION COST	ENERGY	MAINT. / SREC	TOTAL		(Yearly Saving * ECM Lifetime)	(Yearly Maint Saving * ECM Lifetime)	(Lifetime Savings - Net Cost) / (Net Cost)	(Net cost / Yearly Savings)	$\sum_{n=0}^N \frac{C_n}{(1 + IRR)^n}$	$\sum_{n=0}^N \frac{C_n}{(1 + DR)^n}$
		(\$)	(\$)	(\$)	(\$)	(\$/Yr)	(\$/Yr)	(\$/Yr)		(\$)	(\$)	(%)	(Yr)	(\$)	(\$)
ECM #1	Lighting Upgrade	\$28,876	\$28,876	\$19,080	\$38,672	\$10,509	\$0	\$10,509	15	\$157,635	\$0	307.6%	3.7	26.36%	\$86,783.76
ECM #2	Lighting Controls	\$31,350	\$10,450	\$5,155	\$36,645	\$10,847	\$0	\$10,847	15	\$162,705	\$0	344.0%	3.4	28.95%	\$92,845.78
ECM #3	Computer Monitor Replacement	\$10,200	\$0	\$0	\$10,200	\$2,313	\$0	\$2,313	15	\$34,695	\$0	240.1%	4.4	21.45%	\$17,412.44
ECM #4	Condensing Boiler Installation	\$179,800	\$241,838	\$11,210	\$410,428	\$16,953	\$0	\$16,953	30	\$508,590	\$0	23.9%	24.2	1.44%	(\$78,141.72)
ECM #5	AC Unit Replacement	\$89,550	\$132,375	\$9,567	\$212,358	\$6,235	\$0	\$6,235	15	\$93,525	\$0	-56.0%	34.1	-8.85%	(\$137,924.97)
ECM #6	Library AC Unit Upgrade	\$33,400	\$38,781	\$0	\$72,181	\$6,196	\$0	\$6,196	15	\$92,940	\$0	28.8%	11.6	3.34%	\$1,786.45
ECM #7	Cafeteria AC Unit Controls Upgrade	\$10,100	\$13,888	\$0	\$23,988	\$4,786	\$0	\$4,786	15	\$71,790	\$0	199.3%	5.0	18.36%	\$33,146.96
ECM #8	Water Cooled CU Replacement	\$71,800	\$87,025	\$1,840	\$156,985	\$11,698	\$0	\$11,698	15	\$175,470	\$0	11.8%	13.4	1.42%	(\$17,335.04)
ECM #9	Water Conservation	\$12,250	\$39,874	\$0	\$52,124	\$2,516	\$0	\$2,516	30	\$75,480	\$0	44.8%	20.7	2.58%	(\$2,809.29)
ECM #10	Premium Efficiency Motors	\$5,700	\$7,571	\$465	\$12,806	\$1,441	\$0	\$1,441	18	\$25,938	\$0	102.5%	8.9	8.78%	\$7,012.81
ECM #11	Valve Blanket Insulation	\$2,500	\$7,500	\$0	\$10,000	\$554	\$0	\$554	24	\$13,296	\$0	33.0%	18.1	2.42%	(\$617.71)
ECM #12	Kitchen Hood Controls	\$4,963	\$5,708	\$0	\$10,671	\$564	\$0	\$564	15	\$8,460	\$0	-20.7%	18.9	-2.77%	(\$3,938.00)
REM RENEWABLE ENERGY AND FINANCIAL COSTS AND SAVINGS SUMMARY															
REM #1	PV Solar	\$7,903,260	\$0	\$0	\$7,903,260	\$148,224	\$384,285	\$532,509	25	\$13,312,725	\$9,607,125	68.4%	14.8	4.49%	\$1,369,397.86

**Notes:** 1) The variable Cn in the formulas for Internal Rate of Return and Net Present Value stands for the cash flow during each period.  
2) The variable DR in the NPV equation stands for Discount Rate  
3) For NPV and IRR calculations: From n=0 to N periods where N is the *lifetime of ECM* and Cn is the *cash flow during each period*.



# Concord Engineering Group, Inc.

520 BURNT MILL ROAD  
VOORHEES, NEW JERSEY 08043  
PHONE: (856) 427-0200  
FAX: (856) 427-6508

## SmartStart Building Incentives

The NJ SmartStart Buildings Program offers financial incentives on a wide variety of building system equipment. The incentives were developed to help offset the initial cost of energy-efficient equipment. The following tables show the current available incentives as of February, 2010:

### **Electric Chillers**

Water-Cooled Chillers	\$12 - \$170 per ton
Air-Cooled Chillers	\$8 - \$52 per ton

Energy Efficiency must comply with ASHRAE 90.1-2004

### **Gas Cooling**

Gas Absorption Chillers	\$185 - \$400 per ton
Gas Engine-Driven Chillers	Calculated through custom measure path)

### **Desiccant Systems**

\$1.00 per cfm – gas or electric
----------------------------------

### **Electric Unitary HVAC**

Unitary AC and Split Systems	\$73 - \$93 per ton
Air-to-Air Heat Pumps	\$73 - \$92 per ton
Water-Source Heat Pumps	\$81 per ton
Packaged Terminal AC & HP	\$65 per ton
Central DX AC Systems	\$40- \$72 per ton
Dual Enthalpy Economizer Controls	\$250
Occupancy Controlled Thermostat (Hospitality & Institutional Facility)	\$75 per thermostat

Energy Efficiency must comply with ASHRAE 90.1-2004

### **Ground Source Heat Pumps**

Closed Loop & Open Loop	\$450 per ton, EER $\geq$ 16 \$600 per ton, EER $\geq$ 18 \$750 per ton, EER $\geq$ 20
-------------------------	--

Energy Efficiency must comply with ASHRAE 90.1-2004

### Gas Heating

Gas Fired Boilers < 300 MBH	\$300 per unit
Gas Fired Boilers $\geq$ 300 - 1500 MBH	\$1.75 per MBH
Gas Fired Boilers $\geq$ 1500 - $\leq$ 4000 MBH	\$1.00 per MBH
Gas Fired Boilers > 4000 MBH	(Calculated through Custom Measure Path)
Gas Furnaces	\$300 - \$400 per unit, AFUE $\geq$ 92%

### Variable Frequency Drives

Variable Air Volume	\$65 - \$155 per hp
Chilled-Water Pumps	\$60 per hp
Compressors	\$5,250 to \$12,500 per drive

### Natural Gas Water Heating

Gas Water Heaters $\leq$ 50 gallons	\$50 per unit
Gas-Fired Water Heaters > 50 gallons	\$1.00 - \$2.00 per MBH
Gas-Fired Booster Water Heaters	\$17 - \$35 per MBH
Gas Fired Tankless Water Heaters	\$300 per unit

### Prescriptive Lighting

Retro fit of T12 to T-5 or T-8 Lamps w/Electronic Ballast in Existing Facilities	\$10 per fixture (1-4 lamps)
Replacement of T12 with new T-5 or T-8 Lamps w/Electronic Ballast in Existing Facilities	\$25 per fixture (1-2 lamps) \$30 per fixture (3-4 lamps)
Replacement of incandescent with screw-in PAR 38 or PAR 30 (CFL) bulb	\$7 per bulb
T-8 reduced Wattage (28w/25w 4', 1-4 lamps) Lamp & ballast replacement	\$10 per fixture
Hard-Wired Compact Fluorescent	\$25 - \$30 per fixture
Metal Halide w/Pulse Start	\$25 per fixture
LED Exit Signs	\$10 - \$20 per fixture
T-5 and T-8 High Bay Fixtures	\$16 - \$284 per fixture
HID $\geq$ 100w Retrofit with induction lamp, power coupler and generator (must be 30% less watts/fixture than HID system)	\$50 per fixture
HID $\geq$ 100w Replacement with new HID $\geq$ 100w	\$70 per fixture
LED Refrigerator/Freezer case lighting replacement of fluorescent in medium and low temperature display case	\$42 per 5 foot \$65 per 6 foot

### Lighting Controls – Occupancy Sensors

Wall Mounted	\$20 per control
Remote Mounted	\$35 per control
Daylight Dimmers	\$25 per fixture
Occupancy Controlled hi-low Fluorescent Controls	\$25 per fixture controlled

### Lighting Controls – HID or Fluorescent Hi-Bay Controls

Occupancy hi-low	\$75 per fixture controlled
Daylight Dimming	\$75 per fixture controlled
Daylight Dimming - office	\$50 per fixture controlled

### Premium Motors

Three-Phase Motors	\$45 - \$700 per motor
Fractional HP Motors Electronic Communicated Motors (replacing shaded pole motors in refrigerator/freezer cases)	\$40 per electronic communicated motor

### Other Equipment Incentives

Performance Lighting	\$1.00 per watt per SF below program incentive threshold, currently 5% more energy efficient than ASHRAE 90.1- 2004 for New Construction and Complete Renovation
Custom Electric and Gas Equipment Incentives	not prescriptive
Custom Measures	\$0.16 KWh and \$1.60/Therm of 1st year savings, or a buy down to a 1 year payback on estimated savings. Minimum required savings of 75,000 KWh or 1,500 Therms and a IRR of at least 10%.
Multi Measures Bonus	15%



# STATEMENT OF ENERGY PERFORMANCE

## Highland High School

Building ID: 2598398  
For 12-month Period Ending: December 31, 2009<sup>1</sup>  
Date SEP becomes ineligible: N/A

Date SEP Generated: February 21, 2011

**Facility**  
Highland High School  
450 Erial Road  
Blackwood, NJ 08012

**Facility Owner**  
Black Horse Pike Regional School District  
580 Erial Road  
Blackwood, NJ 08012

**Primary Contact for this Facility**  
Jean Grubb  
580 Erial Road  
Blackwood, NJ 08012

**Year Built:** 1965  
**Gross Floor Area (ft<sup>2</sup>):** 220,065

**Energy Performance Rating<sup>2</sup>** (1-100) 52

### Site Energy Use Summary<sup>3</sup>

Electricity - Grid Purchase(kBtu)	5,967,997
Natural Gas (kBtu) <sup>4</sup>	10,550,611
Total Energy (kBtu)	16,518,608

### Energy Intensity<sup>5</sup>

Site (kBtu/ft <sup>2</sup> /yr)	75
Source (kBtu/ft <sup>2</sup> /yr)	141

**Emissions** (based on site energy use)  
Greenhouse Gas Emissions (MtCO<sub>2</sub>e/year) N/A

**Electric Distribution Utility**  
N/A

### National Average Comparison

National Average Site EUI	77
National Average Source EUI	144
% Difference from National Average Source EUI	-2%
Building Type	K-12 School

Stamp of Certifying Professional

Based on the conditions observed at the time of my visit to this building, I certify that the information contained within this statement is accurate.

### Meets Industry Standards<sup>6</sup> for Indoor Environmental Conditions:

Ventilation for Acceptable Indoor Air Quality	N/A
Acceptable Thermal Environmental Conditions	N/A
Adequate Illumination	N/A

### Certifying Professional

Michael Fischette  
520 south burnt mill road  
voorhees, NJ 08043

#### Notes:

1. Application for the ENERGY STAR must be submitted to EPA within 4 months of the Period Ending date. Award of the ENERGY STAR is not final until approval is received from EPA.
2. The EPA Energy Performance Rating is based on total source energy. A rating of 75 is the minimum to be eligible for the ENERGY STAR.
3. Values represent energy consumption, annualized to a 12-month period.
4. Natural Gas values in units of volume (e.g. cubic feet) are converted to kBtu with adjustments made for elevation based on Facility zip code.
5. Values represent energy intensity, annualized to a 12-month period.
6. Based on Meeting ASHRAE Standard 62 for ventilation for acceptable indoor air quality, ASHRAE Standard 55 for thermal comfort, and IESNA Lighting Handbook for lighting quality.




# Statement of Energy Performance

**2009**

Highland High School  
450 Erial Road  
Blackwood, NJ 08012

Portfolio Manager Building ID: 2598398

The energy use of this building has been measured and compared to other similar buildings using the Environmental Protection Agency's (EPA's) Energy Performance Scale of 1–100, with 1 being the least energy efficient and 100 the most energy efficient. For more information, visit [energystar.gov/benchmark](http://energystar.gov/benchmark).



This building uses 141 kBtu per square foot per year.\*

\*Based on source energy intensity for the 12 month period ending December 2009

**Buildings with a score of 75 or higher may qualify for EPA's ENERGY STAR.**

I certify that the information contained within this statement is accurate and in accordance with U.S. Environmental Protection Agency's measurement standards, found at [energystar.gov](http://energystar.gov)

Date of certification



## **MAJOR EQUIPMENT LIST**

**Concord Engineering Group**

**Highland High School**

### **Rooftop / AC Units**

<b>Tag</b>	<b>RTU-1</b>	<b>RTU-2</b>	<b>RTU-3</b>
<b>Unit Type</b>	Elec Cooling/Gas Heat	Elec Cooling/Gas Heat	Elec Cooling/Gas Heat
<b>Qty</b>	1	1	1
<b>Location</b>	Roof	Roof	Roof
<b>Area Served</b>	Weight Room (Sports Annex)	Faculty Dining	Classroom F126
<b>Manufacturer</b>	Trane	York	York
<b>Model #</b>	YCD120C4	D1NA024N05606C	No Tag
<b>Serial #</b>	N/A	NLHM140884	No Tag
<b>Cooling Type</b>	DX Coil	DX Coil	DX Coil
<b>Cooling Capacity (Tons)</b>	10 Tons	2 Tons	2 Tons
<b>Cooling Efficiency (SEER/EER)</b>	11.0 EER	10.0 SEER	6.0 SEER (Estimated)
<b>Heating Type</b>	Nat Gas	Nat Gas	Nat Gas
<b>Heating Input (MBH)</b>	120	70	N/A
<b>Efficiency</b>	80.0%	80%	N/A
<b>Fuel</b>	Natural Gas	Natural Gas	Natural Gas
<b>Approx Age</b>	10	11	20
<b>ASHRAE Service Life</b>	15	15	15
<b>Remaining Life</b>	5	4	(5)
<b>Comments</b>	Controlled by programmable Tstat	Controlled by programmable Tstat	Controlled by programmable Tstat

## **Rooftop / AC Units**

<b>Tag</b>	<b>RTU-4</b>	<b>RTU-5</b>	<b>RTU-6</b>
<b>Unit Type</b>	Elec Cooling/Gas Heat	Elec Cooling/HW Heat	Elec Cooling/HW Heat
<b>Qty</b>	1	3	1
<b>Location</b>	Roof	Cafeteria Roof	Library Roof
<b>Area Served</b>	Kitchen (Room F128)	Cafeteria	Library
<b>Manufacturer</b>	York	York	Trane
<b>Model #</b>	No Tag	J15ZRC00Q4HZZ100	SLHFC5042757C7B
<b>Serial #</b>	No Tag	N1K0303216, 217, & 218	C05F06010
<b>Cooling Type</b>	DX Coil	DX Coil	DX Coil
<b>Cooling Capacity (Tons)</b>	3-Tons	15-Tons	50-Tons
<b>Cooling Efficiency (SEER/EER)</b>	6.0 SEER (Estimated)	12.1 EER	10 EER
<b>Heating Type</b>	Nat Gas	Duct-Mounted Hot Water Heating Coils	Duct-Mounted Hot Water Heating Coils
<b>Heating Input (MBH)</b>	N/A	N/A	N/A
<b>Efficiency</b>	N/A	N/A	N/A
<b>Fuel</b>	Natural Gas	N/A	N/A
<b>Approx Age</b>	20	1	6
<b>ASHRAE Service Life</b>	15	15	15
<b>Remaining Life</b>	(5)	14	9
<b>Comments</b>	Controlled by programmable Tstat	Controlled by building automation system installed by CM3. System is overridden into occupied mode 24/7 due to communication problems at install that have not been resolved. Units are equipped with demand controlled ventilation.	Stand alone controls integral to the Trane Intellipak system. System is capable of operating as a VAV system however is presently set as a constant volume system with 3 abandoned terminal units with disconnected electric heat. Had problems with humidity due to being oversized when originally installed but the compressors have been staged accordingly along with the assistance of some hot gas bypass. System is not equipped with demand controlled ventilation.

### **Rooftop / AC Units**

<b>Tag</b>	<b>RTU-7</b>		<b>RTU-8</b>
<b>Unit Type</b>	Elec Cooling/Gas Heat	Heating and Ventilating	Cooling Only
<b>Qty</b>	1	2	1
<b>Location</b>	Library Roof	Trainer Office Roof	Roof
<b>Area Served</b>	Librarian's Office	Lockers	
<b>Manufacturer</b>	Trane	No Tag	York
<b>Model #</b>	No Tag	No Tag	D4CG090N13046A
<b>Serial #</b>	No Tag	No Tag	NBJM022269
<b>Cooling Type</b>	DX Coil	N/A	DX Coil
<b>Cooling Capacity (Tons)</b>	2-Tons	N/A	7.5-Tons
<b>Cooling Efficiency (SEER/EER)</b>	7.0 SEER (Estimated)	N/A	10.1 EER
<b>Heating Type</b>	Nat Gas	Nat Gas	N/A
<b>Heating Input (MBH)</b>	N/A	163	N/A
<b>Efficiency</b>	N/A	80%	N/A
<b>Fuel</b>	Natural Gas	Natural Gas	N/A
<b>Approx Age</b>	22	24	9
<b>ASHRAE Service Life</b>	15	15	15
<b>Remaining Life</b>	(7)	(9)	6
<b>Comments</b>	Controlled by building automation system.		Controlled by building automation system.

### **Rooftop / AC Units**

<b>Tag</b>	<b>RTU-9</b>	<b>SS-1</b>	<b>RTU-10</b>
<b>Unit Type</b>	Elec Cooling/Gas Heat	Cooling Only	Cooling Only
<b>Qty</b>	1	1	2
<b>Location</b>	Choral Roof	Roof over Room C103	Stage Roof
<b>Area Served</b>	Choral Room	Three (3) Offices	Auditorium
<b>Manufacturer</b>	York	Trane	Trane
<b>Model #</b>	No Tag	1CD036A400B	TCH360A40Y1B5BE
<b>Serial #</b>	No Tag	F431.....	C08K10380 & 10381
<b>Cooling Type</b>	DX Coil	DX Coil	DX Coil
<b>Cooling Capacity (Tons)</b>	4-Tons	3-Tons	30-Tons
<b>Cooling Efficiency (SEER/EER)</b>	6.0 SEER (Estimated)	7.0 SEER	9.5 EER
<b>Heating Type</b>	Nat Gas	N/A	N/A
<b>Heating Input (MBH)</b>	N/A	N/A	N/A
<b>Efficiency</b>	N/A	N/A	N/A
<b>Fuel</b>	Natural Gas	N/A	N/A
<b>Approx Age</b>	20	19	2
<b>ASHRAE Service Life</b>	15	15	15
<b>Remaining Life</b>	(5)	(4)	13
<b>Comments</b>	Controlled by programmable Tstat	Controlled by programmable Tstat	Controlled by building automation system installed by CM3. Unit is equipped with demand controlled ventilation.

## **Rooftop / AC Units**

<b>Tag</b>	<b>SS-2</b>	<b>SS-3</b>	<b>SS-4</b>
<b>Unit Type</b>	Cooling Only	Split Condenser	Split Heat Pumps
<b>Qty</b>	1	1	1
<b>Location</b>	Roof	Roof	Roof
<b>Area Served</b>	Room F211	Conference Rm A203	2nd Floor Admin Offices
<b>Manufacturer</b>	Trane	Mitsubishi	Mitsubishi
<b>Model #</b>	TTB727A100A0	MU15NN	MXZ-2A20NA-1
<b>Serial #</b>	B29248396	7000387T	8000299
<b>Cooling Type</b>	Heat Pump	DX Coil	Heat Pump
<b>Cooling Capacity (Tons)</b>	4-Ton	15,000 Btuh	22,000 Btuh
<b>Cooling Efficiency (SEER/EER)</b>	7.0 SEER (Estimated)	8.0 SEER	10.0 SEER
<b>Heating Type</b>	N/A	N/A	N/A
<b>Heating Input (MBH)</b>	N/A	N/A	N/A
<b>Efficiency</b>	N/A	N/A	N/A
<b>Fuel</b>	N/A	N/A	N/A
<b>Approx Age</b>	23	11	8
<b>ASHRAE Service Life</b>	15	15	15
<b>Remaining Life</b>	(8)	4	7
<b>Comments</b>	Controlled by non-programmable Tstat	Controlled by programmable Tstat	Controlled by programmable Tstat

## **Rooftop / AC Units**

<b>Tag</b>	<b>SS-5</b>	<b>SS-6</b>	<b>RTU-11</b>
<b>Unit Type</b>	Split Heat Pump	Split Condenser	Cooling Only
<b>Qty</b>	2	3	2
<b>Location</b>	Roof	Roof	Science Wing Roof
<b>Area Served</b>	2nd Floor Admin Offices	Nurse/Exam Rooms	Science Rooms
<b>Manufacturer</b>	Mitsubishi	Rheem	Trane
<b>Model #</b>	MXZ-3A30NA-1	RAKA-018JAZ	TCD 036 A400BA
<b>Serial #</b>	82902409 & 82901263	5460 M2496 12155, 12156, & 12159	N/A
<b>Cooling Type</b>	Heat Pump	DX Coil	DX Coil
<b>Cooling Capacity (Tons)</b>	30,000 Btuh	18,000 Btuh	3-Tons
<b>Cooling Efficiency (SEER/EER)</b>	10.0 SEER	9.0 SEER	6.0 SEER
<b>Heating Type</b>	N/A	N/A	N/A
<b>Heating Input (MBH)</b>	N/A	N/A	N/A
<b>Efficiency</b>	N/A	N/A	N/A
<b>Fuel</b>	N/A	N/A	N/A
<b>Approx Age</b>	7	10	20
<b>ASHRAE Service Life</b>	15	15	15
<b>Remaining Life</b>	8	5	(5)
<b>Comments</b>	Controlled by programmable Tstat	Controlled by programmable Tstat	Controlled by programmable Tstat

## **MAJOR EQUIPMENT LIST**

**Concord Engineering Group**

**Highland High School**

### **Boilers**

<b>Tag</b>	<b>Boiler-1 &amp; 2</b>	<b>Gym Addition</b>	
<b>Unit Type</b>	Cast Iron Sectional	Cast Iron Sectional	
<b>Qty</b>	2	1	
<b>Location</b>	Main Boiler Room	Main Boiler Room	
<b>Area Served</b>	Entire School	Gym	
<b>Manufacturer</b>	H B Smith	Weil-McLain	
<b>Model #</b>	640	BG-488-RS	
<b>Serial #</b>	State # 6313 - 1H & 2H	88-3056-H	
<b>Input Capacity (MBH)</b>	8,400	1,010	
<b>Rated Output Capacity (MBH)</b>	6,522	810	
<b>Approx. Efficiency %</b>	74%	80%	
<b>Fuel</b>	Natural Gas	Natural Gas	
<b>Approx Age</b>	43	22	
<b>ASHRAE Service Life</b>	30	30	
<b>Remaining Life</b>	(13)	8	
<b>Comments</b>			



# **MAJOR EQUIPMENT LIST**

## **Concord Engineering Group**

### **Highland High School**

#### **Domestic Water Heater**

<b>Tag</b>	<b>HWH-1</b>		
<b>Unit Type</b>	Cast Iron Sectional		
<b>Qty</b>	1		
<b>Location</b>	Main Boiler Room		
<b>Area Served</b>	Entire Facility		
<b>Manufacturer</b>	H B Smith		
<b>Model #</b>	84-177-H		
<b>Serial #</b>	N/A		
<b>Input Capacity (MBH)</b>	980		
<b>Rated Output Capacity (MBH)</b>	784		
<b>Efficiency %</b>	70%		
<b>Blower Motor</b>	1/3 HP		
<b>Fuel</b>	Natural Gas		
<b>Approx Age</b>	26		
<b>ASHRAE Service Life</b>	30		
<b>Remaining Life</b>	4		
<b>Comments</b>			

## **MAJOR EQUIPMENT LIST**

### **Concord Engineering Group**

#### **Highland High School**

### **Pumps**

<b>Tag</b>	<b>Admin Zone</b>	<b>Zone 1 (P-2)</b>	<b>Zone 2</b>
<b>Unit Type</b>	Centrifugal Split	Centrifugal Split	Centrifugal Split
<b>Qty</b>	2	1	1
<b>Location</b>	Main Boiler Room	Main Boiler Room	Main Boiler Room
<b>Area Served</b>	Admin Area	Zone 1	Zone 2
<b>Manufacturer</b>	Bell & Gossett	Armstrong	Bell & Gossett
<b>Model #</b>	185011	5x4x11.5 4030	U3B 8-7/8-BF
<b>Serial #</b>	N/A	N/A	N/A
<b>Horse Power</b>	3	20	10
<b>Flow</b>	50 GPM @ 72 FT HD	440 GPM @ 90FT HD	290 GPM @ 70FT HD
<b>Motor Info</b>		Marathon Electric	
<b>Electrical Power</b>	460 V/3 Phase	460 V/3 Phase	460 V / 3 Phase
<b>RPM</b>	1750	1750	1750
<b>Motor Efficiency %</b>	N/A	88.5%	N/A
<b>Approx Age</b>	Unknown	Unknown	Unknown
<b>ASHRAE Service Life</b>	20	20	20
<b>Remaining Life</b>	Unknown	Unknown	Unknown
<b>Comments</b>			

## **Pumps**

<b>Tag</b>	<b>Zone 1 &amp; 2 Spare</b>	<b>Gym Addition Pump</b>	<b>DHW Booster Pumps</b>
<b>Unit Type</b>	Centrifugal Split	In-Line	In-Line
<b>Qty</b>	1	2	2
<b>Location</b>	Main Boiler Room	Main Boiler Room	Main Boiler Room
<b>Area Served</b>	Zone 1 & 2	Gym	Entire Facility
<b>Manufacturer</b>	Armstrong	Armstrong	Armstrong
<b>Model #</b>	5x4x11.5 4030	N/A	N/A
<b>Serial #</b>	N/A	N/A	N/A
<b>Horse Power</b>	20	0.50	3/4
<b>Flow</b>	440 GPM @ 90FT HD	N/A	N/A
<b>Motor Info</b>	Marathon Electric	N/A	N/A
<b>Electrical Power</b>	460 V/3 Phase	208V/1 Phase	115V/1 Phase
<b>RPM</b>	1750	1725	1725
<b>Motor Efficiency %</b>	88.5%	N/A	N/A
<b>Approx Age</b>	Unknown	Unknown	Unknown
<b>ASHRAE Service Life</b>	20	20	20
<b>Remaining Life</b>	Unknown	Unknown	Unknown
<b>Comments</b>			

# **MAJOR EQUIPMENT LIST**

**Concord Engineering Group  
Highland High School**

## **Air Handling Units**

<b>Tag</b>	<b>HV-1 &amp; 3</b>	<b>HV-2 &amp; 4</b>	<b>HV-1 thru 4</b>
<b>Location</b>	Basement Mech Rm	Basement Mech Rm	Gym Ceiling
<b>Area Served</b>	Locker Rooms	Locker Rooms	Gym
<b>Manufacturer</b>	Nesbitt	Nesbitt	Trane
<b>Qty</b>	2	2	4
<b>Model #</b>	No tag	No tag	N/A
<b>Serial #</b>	H.P.H. 150	L.P.H. 85	N/A
<b>Supply Flow, CFM</b>	6,500	4,300	2,000
<b>Heating Type</b>	Hot Water	Hot Water	Hot Water
<b>Input (MBh)</b>	N/A	N/A	150
<b>Output (MBh)</b>	N/A	N/A	N/A
<b>Supply Motor HP</b>	5	5	3
<b>Supply Motor Efficiency</b>	82%	82%	86%
<b>Return Fan Motor HP</b>	N/A	N/A	N/A
<b>R/F Motor Efficiency</b>	N/A	N/A	N/A
<b>Approx. Age</b>	45	45	24
<b>ASHRAE Service Life</b>	20	20	20
<b>Remaining Life</b>	(25)	(25)	(4)
<b>Notes</b>	20 years for hot water coils, motors, dampers, pneumatics,etc.	20 years for hot water coils, motors, dampers, pneumatics,etc.	20 years for hot water coils, motors, dampers, pneumatics,etc.

# Investment Grade Lighting Audit

APPENDIX E-1  
1 of 26

CEG Job #: 9C10098

Project: Highland High School

450 Erial Road

Blackwood, NJ 08012

Bldg. Sq. Ft. 220,065

Highland High School

KWH COST: \$0.135

## ECM #1: Lighting Upgrade - General

ING LIGHTING										PROPOSED LIGHTING										SAVINGS					
CEG	Fixture	Yearly	No.	No.	Fixture	Fixt	Total	kWh/Yr	Yearly	No.	No.	Retro-Unit	Watts	Total	kWh/Yr	Yearly	Unit Cost	Total	kW	kWh/Yr	Yearly	Yearly Simple			
Type	Location	Usage	Fixts	Lamps	Type	Watts	kW	Fixtures	\$ Cost	Fixts	Lamps	Description	Used	kW	Fixtures	\$ Cost	(INSTALLED)	Cost	Savings	Savings	\$ Savings	Payback			
221.11	B217 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.12	2,901.6	\$391.72	18	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.01	2620.8	\$353.81	\$14.00	\$252.00	0.11	280.8	\$37.91	6.65			
221.11	B215 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.12	2,901.6	\$391.72	18	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.01	2620.8	\$353.81	\$14.00	\$252.00	0.11	280.8	\$37.91	6.65			
221.11	B213 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.12	2,901.6	\$391.72	18	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.01	2620.8	\$353.81	\$14.00	\$252.00	0.11	280.8	\$37.91	6.65			
211.11	B211 Faculty	2600	16	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.53	1,372.8	\$185.33	16	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.45	1164.8	\$157.25	\$7.00	\$112.00	0.08	208	\$28.08	3.99			
211.11	B211 Faculty Restroom	2600	3	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.10	257.4	\$34.75	3	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.08	218.4	\$29.48	\$7.00	\$21.00	0.02	39	\$5.27	3.99			
211.11	B209 Faculty Restroom	2600	3	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.10	257.4	\$34.75	3	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.08	218.4	\$29.48	\$7.00	\$21.00	0.02	39	\$5.27	3.99			
221.11	B207 Classroom	2600	12	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.74	1,934.4	\$261.14	12	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.67	1747.2	\$235.87	\$14.00	\$168.00	0.07	187.2	\$25.27	6.65			
221.11	B205 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.12	2,901.6	\$391.72	18	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.01	2620.8	\$353.81	\$14.00	\$252.00	0.11	280.8	\$37.91	6.65			
221.11	B203 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.12	2,901.6	\$391.72	18	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.01	2620.8	\$353.81	\$14.00	\$252.00	0.11	280.8	\$37.91	6.65			
211.11	Boys' Restroom	2600	3	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.10	257.4	\$34.75	3	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.08	218.4	\$29.48	\$7.00	\$21.00	0.02	39	\$5.27	3.99			
227.21		2600	1	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.07	169.0	\$22.82	1	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.05	127.4	\$17.20	\$24.00	\$24.00	0.02	41.6	\$5.62	4.27			
222.21	B Corridor	4400	14	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.87	3,819.2	\$515.59	14	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.78	3449.6	\$465.70	\$14.00	\$196.00	0.08	369.6	\$49.90	3.93			
602		8760	2	2	Incandescent Exit Sign	20	0.04	350.4	\$47.30	2	1	LED Exit Sign	2	0.00	35.04	\$4.73	\$65.00	\$130.00	0.04	315.36	\$42.57	3.05			
221.21	F Corridor	4400	10	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., Acrylic Lens	58	0.58	2,552.0	\$344.52	10	0	No Change	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00			

# Investment Grade Lighting Audit

APPENDIX E-1  
2 of 26

602		8760	3	2	Incandescent Exit Sign	20	0.06	525.6	\$70.96	3	1	LED Exit Sign	2	0.01	52.56	\$7.10	\$65.00	\$195.00	0.05	473.04	\$63.86	3.05
221.11	F212 Classroom	2600	30	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.86	4,836.0	\$652.86	30	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.68	4368	\$589.68	\$14.00	\$420.00	0.18	468	\$63.18	6.65
221.14	F210 Science Department	2600	7	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.41	1,055.6	\$142.51	7	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.39	1019.2	\$137.59	\$14.00	\$98.00	0.01	36.4	\$4.91	19.94
221.11	F208 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.12	2,901.6	\$391.72	18	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.01	2620.8	\$353.81	\$14.00	\$252.00	0.11	280.8	\$37.91	6.65
221.14	F206 Prep Room	2600	7	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.41	1,055.6	\$142.51	7	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.39	1019.2	\$137.59	\$14.00	\$98.00	0.01	36.4	\$4.91	19.94
221.11	F204 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.12	2,901.6	\$391.72	18	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.01	2620.8	\$353.81	\$14.00	\$252.00	0.11	280.8	\$37.91	6.65
221.11	F200 Classroom	2600	33	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	2.05	5,319.6	\$718.15	33	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.85	4804.8	\$648.65	\$14.00	\$462.00	0.20	514.8	\$69.50	6.65
221.11	F201 Storage	1200	6	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.37	446.4	\$60.26	6	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.34	403.2	\$54.43	\$14.00	\$84.00	0.04	43.2	\$5.83	14.40
221.11	F203 Classroom	2600	33	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	2.05	5,319.6	\$718.15	33	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.85	4804.8	\$648.65	\$14.00	\$462.00	0.20	514.8	\$69.50	6.65
221.11	F207 Classroom	2600	30	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.86	4,836.0	\$652.86	30	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.68	4368	\$589.68	\$14.00	\$420.00	0.18	468	\$63.18	6.65
221.14	F211 Electrical Room	1200	5	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.29	348.0	\$46.98	5	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.28	336	\$45.36	\$14.00	\$70.00	0.01	12	\$1.62	43.21
221.14	A200 Custodial Closet	1200	1	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.06	69.6	\$9.40	1	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.06	67.2	\$9.07	\$14.00	\$14.00	0.00	2.4	\$0.32	43.21
221.11	A200 Girls' Restroom	2600	3	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.19	483.6	\$65.29	3	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.17	436.8	\$58.97	\$14.00	\$42.00	0.02	46.8	\$6.32	6.65
221.11	A204 Classroom	2600	21	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.30	3,385.2	\$457.00	21	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.18	3057.6	\$412.78	\$14.00	\$294.00	0.13	327.6	\$44.23	6.65
221.11	A201 Year Book Office	2600	10	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.62	1,612.0	\$217.62	10	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.56	1456	\$196.56	\$14.00	\$140.00	0.06	156	\$21.06	6.65
221.11	A206 Classroom	2600	10	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.62	1,612.0	\$217.62	10	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.56	1456	\$196.56	\$14.00	\$140.00	0.06	156	\$21.06	6.65
221.11	Men's Restroom	2600	2	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.12	322.4	\$43.52	2	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.11	291.2	\$39.31	\$14.00	\$28.00	0.01	31.2	\$4.21	6.65

# Investment Grade Lighting Audit

APPENDIX E-1  
3 of 26

221.11	A208 Classroom	2600	10	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.62	1,612.0	\$217.62	10	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.56	1456	\$196.56	\$14.00	\$140.00	0.06	156	\$21.06	6.65
221.11	A210 Special Services	2600	27	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.67	4,352.4	\$587.57	27	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.51	3931.2	\$530.71	\$14.00	\$378.00	0.16	421.2	\$56.86	6.65
121.14	A212 Storage Closet	1200	1	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Surface Mnt., No Lens	78	0.08	93.6	\$12.64	1	2	2 Lamp, 32w T8, Elect. Ballast; retrofit	58	0.06	69.6	\$9.40	\$100.00	\$100.00	0.02	24	\$3.24	30.86
221.11	A214 VP Office	2600	8	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.50	1,289.6	\$174.10	8	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.45	1164.8	\$157.25	\$14.00	\$112.00	0.05	124.8	\$16.85	6.65
222.21	A207 Balcony	1200	3	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.19	223.2	\$30.13	3	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.17	201.6	\$27.22	\$14.00	\$42.00	0.02	21.6	\$2.92	14.40
221.11	Women's Restroom	2600	2	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.12	322.4	\$43.52	2	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.11	291.2	\$39.31	\$14.00	\$28.00	0.01	31.2	\$4.21	6.65
222.21	A Corridor	4400	14	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.87	3,819.2	\$515.59	14	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.78	3449.6	\$465.70	\$14.00	\$196.00	0.08	369.6	\$49.90	3.93
602		8760	3	2	Incandescent Exit Sign	20	0.06	525.6	\$70.96	3	1	LED Exit Sign	2	0.01	52.56	\$7.10	\$65.00	\$195.00	0.05	473.04	\$63.86	3.05
221.11	A216 Classroom	2600	27	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.67	4,352.4	\$587.57	27	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.51	3931.2	\$530.71	\$14.00	\$378.00	0.16	421.2	\$56.86	6.65
211.11	Boys' Restroom	2600	3	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.10	257.4	\$34.75	3	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.08	218.4	\$29.48	\$7.00	\$21.00	0.02	39	\$5.27	3.99
222.21	E Corridor	4400	7	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.43	1,909.6	\$257.80	7	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.39	1724.8	\$232.85	\$14.00	\$98.00	0.04	184.8	\$24.95	3.93
602		8790	2	2	Incandescent Exit Sign	20	0.04	351.6	\$47.47	2	1	LED Exit Sign	2	0.00	35.16	\$4.75	\$65.00	\$130.00	0.04	316.44	\$42.72	3.04
221.11	A220 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.12	2,901.6	\$391.72	18	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.01	2620.8	\$353.81	\$14.00	\$252.00	0.11	280.8	\$37.91	6.65
221.14	E201 World Languages	2600	3	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.17	452.4	\$61.07	3	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.17	436.8	\$58.97	\$14.00	\$42.00	0.01	15.6	\$2.11	19.94
221.11	E203 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.12	2,901.6	\$391.72	18	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.01	2620.8	\$353.81	\$14.00	\$252.00	0.11	280.8	\$37.91	6.65
221.11	E200 Book Room	2600	6	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.37	967.2	\$130.57	6	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.34	873.6	\$117.94	\$14.00	\$84.00	0.04	93.6	\$12.64	6.65
221.11	E202 Classroom	2600	20	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.24	3,224.0	\$435.24	20	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.12	2912	\$393.12	\$14.00	\$280.00	0.12	312	\$42.12	6.65
221.11	E205 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.12	2,901.6	\$391.72	18	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.01	2620.8	\$353.81	\$14.00	\$252.00	0.11	280.8	\$37.91	6.65

# Investment Grade Lighting Audit

APPENDIX E-1  
4 of 26

221.11	E206 Classroom	2600	10	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.62	1,612.0	\$217.62	10	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.56	1456	\$196.56	\$14.00	\$140.00	0.06	156	\$21.06	6.65
221.11	E207 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.12	2,901.6	\$391.72	18	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.01	2620.8	\$353.81	\$14.00	\$252.00	0.11	280.8	\$37.91	6.65
221.11	E208 Classroom	2600	10	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.62	1,612.0	\$217.62	10	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.56	1456	\$196.56	\$14.00	\$140.00	0.06	156	\$21.06	6.65
221.11	E209 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.12	2,901.6	\$391.72	18	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.01	2620.8	\$353.81	\$14.00	\$252.00	0.11	280.8	\$37.91	6.65
221.11	E210 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.12	2,901.6	\$391.72	18	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.01	2620.8	\$353.81	\$14.00	\$252.00	0.11	280.8	\$37.91	6.65
221.14	E213 Book Room	2600	2	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.12	301.6	\$40.72	2	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.11	291.2	\$39.31	\$14.00	\$28.00	0.00	10.4	\$1.40	19.94
221.11	B223 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.12	2,901.6	\$391.72	18	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.01	2620.8	\$353.81	\$14.00	\$252.00	0.11	280.8	\$37.91	6.65
221.11	E212 Office	2600	6	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.37	967.2	\$130.57	6	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.34	873.6	\$117.94	\$14.00	\$84.00	0.04	93.6	\$12.64	6.65
211.11	Custodial Closet	1200	1	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.03	39.6	\$5.35	1	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.03	33.6	\$4.54	\$7.00	\$7.00	0.01	6	\$0.81	8.64
211.11	Girls' Restroom	2600	3	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.10	257.4	\$34.75	3	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.08	218.4	\$29.48	\$7.00	\$21.00	0.02	39	\$5.27	3.99
211.11	Stairwell D1	4400	8	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.26	1,161.6	\$156.82	8	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.22	985.6	\$133.06	\$7.00	\$56.00	0.04	176	\$23.76	2.36
613	Mech. Room B212	1200	2	1	Industrial Fixture, 100w A19 Lamp	100	0.20	240.0	\$32.40	2	1	(1) 26w CFL Lamp	26	0.05	62.4	\$8.42	\$20.00	\$40.00	0.15	177.6	\$23.98	1.67
613	B208 Mech. Room	1200	2	1	Industrial Fixture, 100w A19 Lamp	100	0.20	240.0	\$32.40	2	1	(1) 26w CFL Lamp	26	0.05	62.4	\$8.42	\$20.00	\$40.00	0.15	177.6	\$23.98	1.67
222.21	Stairwell Near Elevator	4400	3	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.19	818.4	\$110.48	3	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.17	739.2	\$99.79	\$14.00	\$42.00	0.02	79.2	\$10.69	3.93
602		8760	1	2	Incandescent Exit Sign	20	0.02	175.2	\$23.65	1	1	LED Exit Sign	2	0.00	17.52	\$2.37	\$65.00	\$65.00	0.02	157.68	\$21.29	3.05
211.11	Stairwell A2	4400	8	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.26	1,161.6	\$156.82	8	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.22	985.6	\$133.06	\$7.00	\$56.00	0.04	176	\$23.76	2.36
211.11	Stairwell A4	4400	8	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.26	1,161.6	\$156.82	8	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.22	985.6	\$133.06	\$7.00	\$56.00	0.04	176	\$23.76	2.36
221.31	A128 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.12	2,901.6	\$391.72	18	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.01	2620.8	\$353.81	\$14.00	\$252.00	0.11	280.8	\$37.91	6.65



# Investment Grade Lighting Audit

APPENDIX E-1  
5 of 26

221.14	E101 Office	2600	3	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.17	452.4	\$61.07	3	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.17	436.8	\$58.97	\$14.00	\$42.00	0.01	15.6	\$2.11	19.94
221.31	E103 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.12	2,901.6	\$391.72	18	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.01	2620.8	\$353.81	\$14.00	\$252.00	0.11	280.8	\$37.91	6.65
221.31	E105 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.12	2,901.6	\$391.72	18	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.01	2620.8	\$353.81	\$14.00	\$252.00	0.11	280.8	\$37.91	6.65
221.31	E107 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.12	2,901.6	\$391.72	18	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.01	2620.8	\$353.81	\$14.00	\$252.00	0.11	280.8	\$37.91	6.65
221.31	E109 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.12	2,901.6	\$391.72	18	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.01	2620.8	\$353.81	\$14.00	\$252.00	0.11	280.8	\$37.91	6.65
221.14	E111 Book Room	2600	3	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.17	452.4	\$61.07	3	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.17	436.8	\$58.97	\$14.00	\$42.00	0.01	15.6	\$2.11	19.94
221.31	B127 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.12	2,901.6	\$391.72	18	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.01	2620.8	\$353.81	\$14.00	\$252.00	0.11	280.8	\$37.91	6.65
222.21	B Corridor	4400	8	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.50	2,182.4	\$294.62	8	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.45	1971.2	\$266.11	\$14.00	\$112.00	0.05	211.2	\$28.51	3.93
602		8760	2	2	Incandescent Exit Sign	20	0.04	350.4	\$47.30	2	1	LED Exit Sign	2	0.00	35.04	\$4.73	\$65.00	\$130.00	0.04	315.36	\$42.57	3.05
221.31	E112 Classroom	2600	10	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.62	1,612.0	\$217.62	10	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.56	1456	\$196.56	\$14.00	\$140.00	0.06	156	\$21.06	6.65
221.31	E110 Classroom	2600	10	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.62	1,612.0	\$217.62	10	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.56	1456	\$196.56	\$14.00	\$140.00	0.06	156	\$21.06	6.65
221.31	E108 VP Office	2600	9	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.56	1,450.8	\$195.86	9	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.50	1310.4	\$176.90	\$14.00	\$126.00	0.05	140.4	\$18.95	6.65
221.31	E106 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.12	2,901.6	\$391.72	18	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.01	2620.8	\$353.81	\$14.00	\$252.00	0.11	280.8	\$37.91	6.65
232.21	E104 Classroom	2600	12	3	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	86	1.03	2,683.2	\$362.23	12	3	Relamp - Sylvania Lamp FO28/841/SS/ECO	84	1.01	2620.8	\$353.81	\$21.00	\$252.00	0.02	62.4	\$8.42	29.91
227.21		2600	4	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.26	676.0	\$91.26	4	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.20	509.6	\$68.80	\$24.00	\$96.00	0.06	166.4	\$22.46	4.27
211.11	Women's Restroom	2600	2	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.07	171.6	\$23.17	2	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.06	145.6	\$19.66	\$7.00	\$14.00	0.01	26	\$3.51	3.99
105	A Corridor Display Case	4400	5	2	3' Channel, 2-Lamp, 30w T12, Mag. Ballast, Surface Mnt., No Lens	60	0.30	1,320.0	\$178.20	5	1	Reballast & Relamp; Sylvania Lamp FO28/841/SS/ECO	28	0.14	616	\$83.16	\$80.00	\$400.00	0.16	704	\$95.04	4.21

# Investment Grade Lighting Audit

APPENDIX E-1  
6 of 26

221.31	A127 Classroom	2600	16	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.99	2,579.2	\$348.19	16	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.90	2329.6	\$314.50	\$14.00	\$224.00	0.10	249.6	\$33.70	6.65
232.21		2600	1	3	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	86	0.09	223.6	\$30.19	1	3	Relamp - Sylvania Lamp FO28/841/SS/ECO	84	0.08	218.4	\$29.48	\$21.00	\$21.00	0.00	5.2	\$0.70	29.91
232.21	A125 Resource Officer	2600	2	3	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	86	0.17	447.2	\$60.37	2	3	Relamp - Sylvania Lamp FO28/841/SS/ECO	84	0.17	436.8	\$58.97	\$21.00	\$42.00	0.00	10.4	\$1.40	29.91
232.21	A123 Conference Room	2600	2	3	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	86	0.17	447.2	\$60.37	2	3	Relamp - Sylvania Lamp FO28/841/SS/ECO	84	0.17	436.8	\$58.97	\$21.00	\$42.00	0.00	10.4	\$1.40	29.91
221.31	A121 Classroom	2600	16	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.99	2,579.2	\$348.19	16	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.90	2329.6	\$314.50	\$14.00	\$224.00	0.10	249.6	\$33.70	6.65
232.21		2600	1	3	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	86	0.09	223.6	\$30.19	1	3	Relamp - Sylvania Lamp FO28/841/SS/ECO	84	0.08	218.4	\$29.48	\$21.00	\$21.00	0.00	5.2	\$0.70	29.91
221.14	A119 Elec. Room	1200	2	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.12	139.2	\$18.79	2	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.11	134.4	\$18.14	\$14.00	\$28.00	0.00	4.8	\$0.65	43.21
211.11	A117 Men's Restroom	2600	2	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.07	171.6	\$23.17	2	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.06	145.6	\$19.66	\$7.00	\$14.00	0.01	26	\$3.51	3.99
211.11	A115 Closet	1200	2	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.07	79.2	\$10.69	2	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.06	67.2	\$9.07	\$7.00	\$14.00	0.01	12	\$1.62	8.64
211.11	Women's Restroom	2600	2	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.07	171.6	\$23.17	2	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.06	145.6	\$19.66	\$7.00	\$14.00	0.01	26	\$3.51	3.99
221.14	A109 Elec. Room	1200	2	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.12	139.2	\$18.79	2	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.11	134.4	\$18.14	\$14.00	\$28.00	0.00	4.8	\$0.65	43.21
221.14	A107 Office	2600	3	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.17	452.4	\$61.07	3	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.17	436.8	\$58.97	\$14.00	\$42.00	0.01	15.6	\$2.11	19.94
221.31	A105 Classroom	2600	28	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.74	4,513.6	\$609.34	28	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.57	4076.8	\$550.37	\$14.00	\$392.00	0.17	436.8	\$58.97	6.65
221.31	A105 Storage	1200	2	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.12	148.8	\$20.09	2	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.11	134.4	\$18.14	\$14.00	\$28.00	0.01	14.4	\$1.94	14.40
221.14	A103 Storage/Elec. Room	1200	4	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.23	278.4	\$37.58	4	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.22	268.8	\$36.29	\$14.00	\$56.00	0.01	9.6	\$1.30	43.21
222.21	A100 Classroom	2600	9	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.56	1,450.8	\$195.86	9	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.50	1310.4	\$176.90	\$14.00	\$126.00	0.05	140.4	\$18.95	6.65
221.14	A102 Custodian Closet	1200	2	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.12	139.2	\$18.79	2	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.11	134.4	\$18.14	\$14.00	\$28.00	0.00	4.8	\$0.65	43.21
211.11	Men's Restroom	2600	3	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.10	257.4	\$34.75	3	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.08	218.4	\$29.48	\$7.00	\$21.00	0.02	39	\$5.27	3.99

# Investment Grade Lighting Audit

APPENDIX E-1  
7 of 26

221.21	A Corridor	4400	16	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., Acrylic Lens	58	0.93	4,083.2	\$551.23	16	0	No Change	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
602		8760	4	2	Incandescent Exit Sign	20	0.08	700.8	\$94.61	4	1	LED Exit Sign	2	0.01	70.08	\$9.46	\$65.00	\$260.00	0.07	630.72	\$85.15	3.05
221.31	A104 Conference Room	2600	4	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.25	644.8	\$87.05	4	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.22	582.4	\$78.62	\$14.00	\$56.00	0.02	62.4	\$8.42	6.65
221.31	Ms. Smith's Office	2600	6	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.37	967.2	\$130.57	6	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.34	873.6	\$117.94	\$14.00	\$84.00	0.04	93.6	\$12.64	6.65
221.31	Mrs. Vizoco's Office	2600	6	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.37	967.2	\$130.57	6	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.34	873.6	\$117.94	\$14.00	\$84.00	0.04	93.6	\$12.64	6.65
221.31	Guidance Receptionist, Area & Hall	2600	16	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.99	2,579.2	\$348.19	16	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.90	2329.6	\$314.50	\$14.00	\$224.00	0.10	249.6	\$33.70	6.65
221.31	Guidance Director Office	2600	6	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.37	967.2	\$130.57	6	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.34	873.6	\$117.94	\$14.00	\$84.00	0.04	93.6	\$12.64	6.65
221.31	Mrs. Hensel's Office	2600	4	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.25	644.8	\$87.05	4	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.22	582.4	\$78.62	\$14.00	\$56.00	0.02	62.4	\$8.42	6.65
221.31	Counselor	2600	4	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.25	644.8	\$87.05	4	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.22	582.4	\$78.62	\$14.00	\$56.00	0.02	62.4	\$8.42	6.65
221.31	Mrs. Papadinec's Office	2600	4	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.25	644.8	\$87.05	4	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.22	582.4	\$78.62	\$14.00	\$56.00	0.02	62.4	\$8.42	6.65
221.31	Mrs. Strauss' Office	2600	4	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.25	644.8	\$87.05	4	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.22	582.4	\$78.62	\$14.00	\$56.00	0.02	62.4	\$8.42	6.65
221.31	Copy Room/Files	2600	4	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.25	644.8	\$87.05	4	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.22	582.4	\$78.62	\$14.00	\$56.00	0.02	62.4	\$8.42	6.65
284.25	Lobby	4400	2	8	4x4, 8 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., White Diffuser	214	0.43	1,883.2	\$254.23	2	8	Relamp - Sylvania Lamp FO28/841/SS/ECO	192	0.38	1689.6	\$228.10	\$56.00	\$112.00	0.04	193.6	\$26.14	4.29
602		8760	2	2	Incandescent Exit Sign	20	0.04	350.4	\$47.30	2	1	LED Exit Sign	2	0.00	35.04	\$4.73	\$65.00	\$130.00	0.04	315.36	\$42.57	3.05
227.21	Vestibule	4400	3	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.20	858.0	\$115.83	3	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.15	646.8	\$87.32	\$24.00	\$72.00	0.05	211.2	\$28.51	2.53
227.21	Main Office Stairway	2600	1	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.07	169.0	\$22.82	1	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.05	127.4	\$17.20	\$24.00	\$24.00	0.02	41.6	\$5.62	4.27
221.31	Main Office	2600	14	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.87	2,256.8	\$304.67	14	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.78	2038.4	\$275.18	\$14.00	\$196.00	0.08	218.4	\$29.48	6.65
221.31	Principal's Office	2600	8	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.50	1,289.6	\$174.10	8	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.45	1164.8	\$157.25	\$14.00	\$112.00	0.05	124.8	\$16.85	6.65

# Investment Grade Lighting Audit

APPENDIX E-1  
8 of 26

221.31	Nurse	2600	9	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.56	1,450.8	\$195.86	9	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.50	1310.4	\$176.90	\$14.00	\$126.00	0.05	140.4	\$18.95	6.65
621	Auditorium	1200	64	1	Recessed Light, 300w Quartz Lamp	300	19.20	23,040.0	\$3,110.40	64	0	No Change	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
602		8760	6	2	Incandescent Exit Sign	20	0.12	1,051.2	\$141.91	6	1	LED Exit Sign	2	0.01	105.12	\$14.19	\$65.00	\$390.00	0.11	946.08	\$127.72	3.05
611		1200	4	1	1x1 Recessed, (1) 60w A19 Lamps	60	0.24	288.0	\$38.88	4	1	Energy Star Rated, Dimmable 13w CFL Lamp	13	0.05	62.4	\$8.42	\$20.00	\$80.00	0.19	225.6	\$30.46	2.63
211.11	Men's Restroom	2600	3	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.10	257.4	\$34.75	3	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.08	218.4	\$29.48	\$7.00	\$21.00	0.02	39	\$5.27	3.99
211.11	B123 Custodial Closet	1200	1	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.03	39.6	\$5.35	1	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.03	33.6	\$4.54	\$7.00	\$7.00	0.01	6	\$0.81	8.64
221.31	B121 Classroom	2600	15	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.93	2,418.0	\$326.43	15	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.84	2184	\$294.84	\$14.00	\$210.00	0.09	234	\$31.59	6.65
221.31	E113 Classroom	2600	15	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.93	2,418.0	\$326.43	15	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.84	2184	\$294.84	\$14.00	\$210.00	0.09	234	\$31.59	6.65
222.21	B Corridor	4400	12	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., No Lens	62	0.74	3,273.6	\$441.94	12	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.67	2956.8	\$399.17	\$14.00	\$168.00	0.07	316.8	\$42.77	3.93
602		8760	2	2	Incandescent Exit Sign	20	0.04	350.4	\$47.30	2	1	LED Exit Sign	2	0.00	35.04	\$4.73	\$65.00	\$130.00	0.04	315.36	\$42.57	3.05
221.31	B119 Classroom	2600	15	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.93	2,418.0	\$326.43	15	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.84	2184	\$294.84	\$14.00	\$210.00	0.09	234	\$31.59	6.65
221.31	B117 Classroom	2600	15	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.93	2,418.0	\$326.43	15	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.84	2184	\$294.84	\$14.00	\$210.00	0.09	234	\$31.59	6.65
221.31	B115 Classroom	2600	21	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.30	3,385.2	\$457.00	21	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.18	3057.6	\$412.78	\$14.00	\$294.00	0.13	327.6	\$44.23	6.65
221.14	B109 Elec. Room	1200	14	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.81	974.4	\$131.54	14	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.78	940.8	\$127.01	\$14.00	\$196.00	0.03	33.6	\$4.54	43.21
221.31	Faculty	2600	16	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.99	2,579.2	\$348.19	16	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.90	2329.6	\$314.50	\$14.00	\$224.00	0.10	249.6	\$33.70	6.65
211.11	Faculty Restroom	1200	6	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.20	237.6	\$32.08	6	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.17	201.6	\$27.22	\$7.00	\$42.00	0.03	36	\$4.86	8.64
221.14	B104 Elec. Room	1200	4	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.23	278.4	\$37.58	4	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.22	268.8	\$36.29	\$14.00	\$56.00	0.01	9.6	\$1.30	43.21
221.31	B106 Classroom	2600	25	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.55	4,030.0	\$544.05	25	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.40	3640	\$491.40	\$14.00	\$350.00	0.15	390	\$52.65	6.65
221.14	B108 School Store	2600	5	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.29	754.0	\$101.79	5	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.28	728	\$98.28	\$14.00	\$70.00	0.01	26	\$3.51	19.94
211.11	Women's Restroom	2600	4	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.23	603.2	\$81.43	4	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.22	582.4	\$78.62	\$14.00	\$56.00	0.01	20.8	\$2.81	19.94
222.21	Corridor F	4400	9	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.56	2,455.2	\$331.45	9	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.50	2217.6	\$299.38	\$14.00	\$126.00	0.05	237.6	\$32.08	3.93

# Investment Grade Lighting Audit

APPENDIX E-1  
9 of 26

602		8760	1	2	Incandescent Exit Sign	20	0.02	175.2	\$23.65	1	1	LED Exit Sign	2	0.00	17.52	\$2.37	\$65.00	\$65.00	0.02	157.68	\$21.29	3.05
222.21	F110 Classroom	2600	21	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	1.30	3,385.2	\$457.00	21	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.18	3057.6	\$412.78	\$14.00	\$294.00	0.13	327.6	\$44.23	6.65
221.31	F108 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.12	2,901.6	\$391.72	18	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.01	2620.8	\$353.81	\$14.00	\$252.00	0.11	280.8	\$37.91	6.65
221.31	F106 Classroom	2600	27	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.67	4,352.4	\$587.57	27	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.51	3931.2	\$530.71	\$14.00	\$378.00	0.16	421.2	\$56.86	6.65
221.31	F105 Classroom	2600	24	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.49	3,868.8	\$522.29	24	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.34	3494.4	\$471.74	\$14.00	\$336.00	0.14	374.4	\$50.54	6.65
221.31	F104 Classroom	2600	24	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.49	3,868.8	\$522.29	24	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.34	3494.4	\$471.74	\$14.00	\$336.00	0.14	374.4	\$50.54	6.65
221.31	F103 Classroom	2600	24	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.49	3,868.8	\$522.29	24	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.34	3494.4	\$471.74	\$14.00	\$336.00	0.14	374.4	\$50.54	6.65
221.31	F101 Classroom	2600	10	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.62	1,612.0	\$217.62	10	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.56	1456	\$196.56	\$14.00	\$140.00	0.06	156	\$21.06	6.65
222.21	Corridor G	4400	40	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	2.48	10,912.0	\$1,473.12	40	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	2.24	9856	\$1,330.56	\$14.00	\$560.00	0.24	1056	\$142.56	3.93
601		8760	8	2	(2) 7w CFL Exit Sign	16	0.13	1,121.3	\$151.37	8	1	LED Exit Sign	2	0.02	140.16	\$18.92	\$65.00	\$520.00	0.11	981.12	\$132.45	3.93
222.21	G101 Classroom	2600	28	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	1.74	4,513.6	\$609.34	28	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.57	4076.8	\$550.37	\$14.00	\$392.00	0.17	436.8	\$58.97	6.65
601		8760	3	2	(2) 7w CFL Exit Sign	16	0.05	420.5	\$56.76	3	1	LED Exit Sign	2	0.01	52.56	\$7.10	\$65.00	\$195.00	0.04	367.92	\$49.67	3.93
222.11	G100 Elec. Closet	1200	2	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Wall Mnt., Indirect	58	0.12	139.2	\$18.79	2	0	No Change	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
222.21	G102 Classroom	2600	28	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	1.74	4,513.6	\$609.34	28	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.57	4076.8	\$550.37	\$14.00	\$392.00	0.17	436.8	\$58.97	6.65
601		8760	3	2	(2) 7w CFL Exit Sign	16	0.05	420.5	\$56.76	3	1	LED Exit Sign	2	0.01	52.56	\$7.10	\$65.00	\$195.00	0.04	367.92	\$49.67	3.93
232.22	G104 Classroom	2600	8	3	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Parabolic Lens	86	0.69	1,788.8	\$241.49	8	3	Relamp - Sylvania Lamp FO28/841/SS/ECO	84	0.67	1747.2	\$235.87	\$21.00	\$168.00	0.02	41.6	\$5.62	29.91
222.21	G103 Classroom	2600	20	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	1.24	3,224.0	\$435.24	20	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.12	2912	\$393.12	\$14.00	\$280.00	0.12	312	\$42.12	6.65
222.21	G106 Classroom	2600	20	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	1.24	3,224.0	\$435.24	20	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.12	2912	\$393.12	\$14.00	\$280.00	0.12	312	\$42.12	6.65
227.211	Girls' Restroom	2600	6	2	2x2, 2 Lamp, 17w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	34	0.20	530.4	\$71.60	6	0	No Change	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00

# Investment Grade Lighting Audit

APPENDIX E-1  
10 of 26

222.21	G108 Classroom	2600	12	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.74	1,934.4	\$261.14	12	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.67	1747.2	\$235.87	\$14.00	\$168.00	0.07	187.2	\$25.27	6.65
227.211	Boys' Restroom	2600	6	2	2x2, 2 Lamp, 17w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	34	0.20	530.4	\$71.60	6	0	No Change	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
222.21	G111 Classroom	2600	12	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	34	0.41	1,060.8	\$143.21	12	0	No Change	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
222.21	G110 Classroom	2600	12	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.74	1,934.4	\$261.14	12	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.67	1747.2	\$235.87	\$14.00	\$168.00	0.07	187.2	\$25.27	6.65
222.21	G112 Classroom	2600	12	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.74	1,934.4	\$261.14	12	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.67	1747.2	\$235.87	\$14.00	\$168.00	0.07	187.2	\$25.27	6.65
222.21	G113 Classroom	2600	12	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.74	1,934.4	\$261.14	12	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.67	1747.2	\$235.87	\$14.00	\$168.00	0.07	187.2	\$25.27	6.65
222.21	G115 VP Office	2600	8	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.50	1,289.6	\$174.10	8	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.45	1164.8	\$157.25	\$14.00	\$112.00	0.05	124.8	\$16.85	6.65
222.21	C100-G	2600	8	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.50	1,289.6	\$174.10	8	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.45	1164.8	\$157.25	\$14.00	\$112.00	0.05	124.8	\$16.85	6.65
222.21	C100 Media Center	2600	134	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	8.31	21,600.8	\$2,916.11	134	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	7.50	19510.4	\$2,633.90	\$14.00	\$1,876.00	0.80	2090.4	\$282.20	6.65
601		8760	3	2	(2) 7w CFL Exit Sign	16	0.05	420.5	\$56.76	3	1	LED Exit Sign	2	0.01	52.56	\$7.10	\$65.00	\$195.00	0.04	367.92	\$49.67	3.93
221.31		2600	89	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	5.52	14,346.8	\$1,936.82	89	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	4.98	12958.4	\$1,749.38	\$14.00	\$1,246.00	0.53	1388.4	\$187.43	6.65
555		2600	10	1	Recessed Down Light, 50w R20 Lamp	50	0.50	1,300.0	\$175.50	10	1	18w PAR20 CFL Lamp	18	0.18	468	\$63.18	\$20.00	\$200.00	0.32	832	\$112.32	1.78
222.21	Periodicals	2600	5	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.31	806.0	\$108.81	5	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.28	728	\$98.28	\$14.00	\$70.00	0.03	78	\$10.53	6.65
221.31		2600	4	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.25	644.8	\$87.05	4	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.22	582.4	\$78.62	\$14.00	\$56.00	0.02	62.4	\$8.42	6.65
222.21	Library Office	2600	5	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.31	806.0	\$108.81	5	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.28	728	\$98.28	\$14.00	\$70.00	0.03	78	\$10.53	6.65
232.22	Library Staff	2600	10	3	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Parabolic Lens	86	0.86	2,236.0	\$301.86	10	3	Relamp - Sylvania Lamp FO28/841/SS/ECO	84	0.84	2184	\$294.84	\$21.00	\$210.00	0.02	52	\$7.02	29.91
222.21	Supervisor Special Services Office	2600	7	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.43	1,128.4	\$152.33	7	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.39	1019.2	\$137.59	\$14.00	\$98.00	0.04	109.2	\$14.74	6.65

# Investment Grade Lighting Audit

APPENDIX E-1  
11 of 26

222.21	Library Classroom	2600	12	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.74	1,934.4	\$261.14	12	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.67	1747.2	\$235.87	\$14.00	\$168.00	0.07	187.2	\$25.27	6.65
222.21	C-100-C TV	2600	12	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.74	1,934.4	\$261.14	12	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.67	1747.2	\$235.87	\$14.00	\$168.00	0.07	187.2	\$25.27	6.65
222.21	C Corridor	4400	17	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	1.05	4,637.6	\$626.08	17	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.95	4188.8	\$565.49	\$14.00	\$238.00	0.10	448.8	\$60.59	3.93
602		8760	2	2	Incandescent Exit Sign	20	0.04	350.4	\$47.30	2	1	LED Exit Sign	2	0.00	35.04	\$4.73	\$65.00	\$130.00	0.04	315.36	\$42.57	3.05
222.21	C102 Office	2600	4	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.25	644.8	\$87.05	4	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.22	582.4	\$78.62	\$14.00	\$56.00	0.02	62.4	\$8.42	6.65
222.21	C104 Office	2600	4	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.25	644.8	\$87.05	4	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.22	582.4	\$78.62	\$14.00	\$56.00	0.02	62.4	\$8.42	6.65
222.21	F Corridor	4400	18	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	1.12	4,910.4	\$662.90	18	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.01	4435.2	\$598.75	\$14.00	\$252.00	0.11	475.2	\$64.15	3.93
602		8760	2	2	Incandescent Exit Sign	20	0.04	350.4	\$47.30	2	1	LED Exit Sign	2	0.00	35.04	\$4.73	\$65.00	\$130.00	0.04	315.36	\$42.57	3.05
222.21	E Corridor	4400	15	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.93	4,092.0	\$552.42	15	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.84	3696	\$498.96	\$14.00	\$210.00	0.09	396	\$53.46	3.93
602		8760	2	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.12	1,086.2	\$146.64	2	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.11	981.12	\$132.45	\$14.00	\$28.00	0.01	105.12	\$14.19	1.97
222.21	D Corridor	4400	7	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.43	1,909.6	\$257.80	7	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.39	1724.8	\$232.85	\$14.00	\$98.00	0.04	184.8	\$24.95	3.93
602		8760	2	2	Incandescent Exit Sign	20	0.04	350.4	\$47.30	2	1	LED Exit Sign	2	0.00	35.04	\$4.73	\$65.00	\$130.00	0.04	315.36	\$42.57	3.05
222.21	F128 Classroom	2600	18	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	1.12	2,901.6	\$391.72	18	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.01	2620.8	\$353.81	\$14.00	\$252.00	0.11	280.8	\$37.91	6.65
602		8760	1	2	Incandescent Exit Sign	20	0.02	175.2	\$23.65	1	1	LED Exit Sign	2	0.00	17.52	\$2.37	\$65.00	\$65.00	0.02	157.68	\$21.29	3.05
222.21	F126 Classroom	2600	6	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.37	967.2	\$130.57	6	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.34	873.6	\$117.94	\$14.00	\$84.00	0.04	93.6	\$12.64	6.65
222.21	F124 Classroom	2600	12	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.74	1,934.4	\$261.14	12	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.67	1747.2	\$235.87	\$14.00	\$168.00	0.07	187.2	\$25.27	6.65
232.21	F120 Cafeteria	2600	34	3	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	86	2.92	7,602.4	\$1,026.32	34	3	Relamp - Sylvania Lamp FO28/841/SS/ECO	84	2.86	7425.6	\$1,002.46	\$21.00	\$714.00	0.07	176.8	\$23.87	29.91
602		8760	4	2	Incandescent Exit Sign	20	0.08	700.8	\$94.61	4	1	LED Exit Sign	2	0.01	70.08	\$9.46	\$65.00	\$260.00	0.07	630.72	\$85.15	3.05
222.11	Kitchen	2600	32	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Wall Mnt., Indirect	58	1.86	4,825.6	\$651.46	32	0	No Change	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
602		8760	1	2	Incandescent Exit Sign	20	0.02	175.2	\$23.65	1	1	LED Exit Sign	2	0.00	17.52	\$2.37	\$65.00	\$65.00	0.02	157.68	\$21.29	3.05
612	Compressor Room	1200	2	1	Pendant Mnt., 100w A19 Lamp	100	0.20	240.0	\$32.40	2	1	(1) 26w CFL Lamp	26	0.05	62.4	\$8.42	\$20.00	\$40.00	0.15	177.6	\$23.98	1.67

# Investment Grade Lighting Audit

APPENDIX E-1  
12 of 26

221.31	F114 Classroom	2600	24	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.49	3,868.8	\$522.29	24	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.34	3494.4	\$471.74	\$14.00	\$336.00	0.14	374.4	\$50.54	6.65
221.31	F112 Classroom	2600	24	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.49	3,868.8	\$522.29	24	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.34	3494.4	\$471.74	\$14.00	\$336.00	0.14	374.4	\$50.54	6.65
222.21	F111 Classroom	2600	24	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	1.49	3,868.8	\$522.29	24	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.34	3494.4	\$471.74	\$14.00	\$336.00	0.14	374.4	\$50.54	6.65
211.14	C101 Elec. Closet	1200	18	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.59	712.8	\$96.23	18	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.50	604.8	\$81.65	\$7.00	\$126.00	0.09	108	\$14.58	8.64
770	Gym	2600	48	1	400w MH, Prismatic Lens	465	22.32	58,032.0	\$7,834.32	48	6	2x4 54w T5HO 6 Lamp w/Reflector	354	16.99	44179.2	\$5,964.19	\$240.00	\$11,520.00	5.33	13852.8	\$1,870.13	6.16
602		8760	5	2	Incandescent Exit Sign	20	0.10	876.0	\$118.26	5	1	LED Exit Sign	2	0.01	87.6	\$11.83	\$65.00	\$325.00	0.09	788.4	\$106.43	3.05
211.11		2600	4	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.13	343.2	\$46.33	4	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.11	291.2	\$39.31	\$7.00	\$28.00	0.02	52	\$7.02	3.99
221.14	Locker Room Stairs (2)	4400	6	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.35	1,531.2	\$206.71	6	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.34	1478.4	\$199.58	\$14.00	\$84.00	0.01	52.8	\$7.13	11.78
221.14	Locker Room	2600	34	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	1.97	5,127.2	\$692.17	34	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.90	4950.4	\$668.30	\$14.00	\$476.00	0.07	176.8	\$23.87	19.94
602		8760	2	2	Incandescent Exit Sign	20	0.04	350.4	\$47.30	2	1	LED Exit Sign	2	0.00	35.04	\$4.73	\$65.00	\$130.00	0.04	315.36	\$42.57	3.05
613		2600	9	1	Industrial Fixture, 100w A19 Lamp	100	0.90	2,340.0	\$315.90	9	1	(1) 26w CFL Lamp	26	0.23	608.4	\$82.13	\$20.00	\$180.00	0.67	1731.6	\$233.77	0.77
211.14	Gym Office	2600	3	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.10	257.4	\$34.75	3	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.08	218.4	\$29.48	\$7.00	\$21.00	0.02	39	\$5.27	3.99
211.14	Gym Storage (2)	1200	28	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.92	1,108.8	\$149.69	28	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.78	940.8	\$127.01	\$7.00	\$196.00	0.14	168	\$22.68	8.64
211.11	Boys' Restroom	2600	5	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.17	429.0	\$57.92	5	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.14	364	\$49.14	\$7.00	\$35.00	0.03	65	\$8.78	3.99
211.11	Girls' Restroom	2600	5	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.17	429.0	\$57.92	5	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.14	364	\$49.14	\$7.00	\$35.00	0.03	65	\$8.78	3.99
221.14	D101 Classroom	2600	34	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	1.97	5,127.2	\$692.17	34	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.90	4950.4	\$668.30	\$14.00	\$476.00	0.07	176.8	\$23.87	19.94
221.14	D103 Classroom	2600	34	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	1.97	5,127.2	\$692.17	34	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.90	4950.4	\$668.30	\$14.00	\$476.00	0.07	176.8	\$23.87	19.94
221.14	D105 Classroom	2600	42	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	2.44	6,333.6	\$855.04	42	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	2.35	6115.2	\$825.55	\$14.00	\$588.00	0.08	218.4	\$29.48	19.94
766	Aux Gym	2600	12	1	400w MH, Prismatic Lens	465	5.58	14,508.0	\$1,958.58	12	4	2x4 54w T5HO 4 Lamp w/Reflective Lens, Wire Cage	236	2.83	7363.2	\$994.03	\$240.00	\$2,880.00	2.75	7144.8	\$964.55	2.99
222.21	AD Office	2600	10	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.62	1,612.0	\$217.62	10	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.56	1456	\$196.56	\$14.00	\$140.00	0.06	156	\$21.06	6.65



# Investment Grade Lighting Audit

APPENDIX E-1  
13 of 26

221.34	Boys' Team Room	2600	21	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Pendant Mnt., No Lens	58	1.22	3,166.8	\$427.52	21	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	1.18	3057.6	\$412.78	\$14.00	\$294.00	0.04	109.2	\$14.74	19.94
602		8760	1	2	Incandescent Exit Sign	20	0.02	175.2	\$23.65	1	1	LED Exit Sign	2	0.00	17.52	\$2.37	\$65.00	\$65.00	0.02	157.68	\$21.29	3.05
221.34	Athletic Trainer	2600	5	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Pendant Mnt., No Lens	58	0.29	754.0	\$101.79	5	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.28	728	\$98.28	\$14.00	\$70.00	0.01	26	\$3.51	19.94
221.34	Girls' Team Room	2600	16	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Pendant Mnt., No Lens	58	0.93	2,412.8	\$325.73	16	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.90	2329.6	\$314.50	\$14.00	\$224.00	0.03	83.2	\$11.23	19.94
602		8760	1	2	Incandescent Exit Sign	20	0.02	175.2	\$23.65	1	1	LED Exit Sign	2	0.00	17.52	\$2.37	\$65.00	\$65.00	0.02	157.68	\$21.29	3.05
227.21	Weight Room Hall	2600	6	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.39	1,014.0	\$136.89	6	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.29	764.4	\$103.19	\$24.00	\$144.00	0.10	249.6	\$33.70	4.27
602		8760	2	2	Incandescent Exit Sign	20	0.04	350.4	\$47.30	2	1	LED Exit Sign	2	0.00	35.04	\$4.73	\$65.00	\$130.00	0.04	315.36	\$42.57	3.05
242.31	Weight Room	2600	18	4	2x4, 4 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic	107	1.93	5,007.6	\$676.03	18	4	Relamp - Sylvania Lamp FO28/841/SS/ECO	112	2.02	5241.6	\$707.62	\$28.00	\$504.00	-0.09	-234	-\$31.59	-15.95
601		8760	2	2	(2) 7w CFL Exit Sign	16	0.03	280.3	\$37.84	2	1	LED Exit Sign	2	0.00	35.04	\$4.73	\$65.00	\$130.00	0.03	245.28	\$33.11	3.93
211.14	Maintenance	2600	19	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.63	1,630.2	\$220.08	19	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.53	1383.2	\$186.73	\$7.00	\$133.00	0.10	247	\$33.35	3.99
221.41	Maintenance Restroom	1200	1	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Wall Mnt., Prismatic	58	0.06	69.6	\$9.40	1	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.06	67.2	\$9.07	\$14.00	\$14.00	0.00	2.4	\$0.32	43.21
222.21	Maintenance Office	2600	1	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed	62	0.06	161.2	\$21.76	1	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.06	145.6	\$19.66	\$14.00	\$14.00	0.01	15.6	\$2.11	6.65
221.14	Maintenance Office	2600	2	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No	58	0.12	301.6	\$40.72	2	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.11	291.2	\$39.31	\$14.00	\$28.00	0.00	10.4	\$1.40	19.94
221.34	Boiler Room	4400	15	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Pendant Mnt., No Lens	58	0.87	3,828.0	\$516.78	15	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.84	3696	\$498.96	\$14.00	\$210.00	0.03	132	\$17.82	11.78
221.34	Electrical Room	1200	8	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Pendant Mnt., No Lens	58	0.46	556.8	\$75.17	8	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	0.45	537.6	\$72.58	\$14.00	\$112.00	0.02	19.2	\$2.59	43.21
221.31	C103 Band	2600	49	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	3.04	7,898.8	\$1,066.34	49	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	56	2.74	7134.4	\$963.14	\$14.00	\$686.00	0.29	764.4	\$103.19	6.65
211.11	C103 Storage	1200	18	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.59	712.8	\$96.23	18	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.50	604.8	\$81.65	\$7.00	\$126.00	0.09	108	\$14.58	8.64
211.11	Maintenance Storage	2600	21	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.69	1,801.8	\$243.24	21	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	28	0.59	1528.8	\$206.39	\$7.00	\$147.00	0.11	273	\$36.86	3.99
750	Exterior	4400	29	1	250w HPS Wallpack	295	8.56	37,642.0	\$5,081.67	29	0	No Change	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
710		4400	4	1	100w HPS Wallpack	125	0.50	2,200.0	\$297.00	4	0	No Change	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
725		4400	22	1	150w HPS Wallpack	188	4.14	18,198.4	\$2,456.78	22	0	No Change	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
767		4400	12	1	400w Probe Start MH "Shoebox" Parking Lot Light	460	5.52	24,288.0	\$3,278.88	12	1	Venture Lighting Optiwave Ballast V90U7421K and 320w MH Lamp	349	4.19	18427.2	\$2,487.67	\$240.00	\$2,880.00	1.33	5860.8	\$791.21	3.64
	<b>Totals</b>		2,898	456			226.11	620,580	\$83,778	2,898	418			163.6	447,934	\$60,471		\$57,752	25.8	77,844	\$10,509	5.50

CEG Job #: 9C10098  
Project: Highland High School  
Address: 450 Erial Road  
Blackwood, NJ 08012  
Building SF: 220,065

Highland High School

KWH COST: \$0.135

ECM #2: Lighting Controls

not rebate eligible

EXISTING LIGHTING										PROPOSED LIGHTING CONTROLS										SAVINGS				
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Cont.	Controls Description		Watts Used	Total kW	Reduction (%)	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback
221.11	B217 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.116	2901.6	\$391.72	18	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.89	20%	2321.28	\$313.37	\$300.00	\$300.00	0.22	580.32	\$78.34	3.83
221.11	B215 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.116	2901.6	\$391.72	18	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.89	20%	2321.28	\$313.37	\$300.00	\$300.00	0.22	580.32	\$78.34	3.83
221.11	B213 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.116	2901.6	\$391.72	18	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.89	20%	2321.28	\$313.37	\$300.00	\$300.00	0.22	580.32	\$78.34	3.83
211.11	B211 Faculty	2600	16	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.528	1372.8	\$185.33	16	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		33	0.42	20%	1098.24	\$148.26	\$300.00	\$300.00	0.11	274.56	\$37.07	8.09
211.11	B211 Faculty Restroom	2600	3	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.099	257.4	\$34.75	3	1	Dual Technology Occupancy Sensor - Switch Mnt.	not rebate eligible	33	0.08	20%	205.92	\$27.80	\$150.00	\$150.00	0.02	51.48	\$6.95	21.58
211.11	B209 Faculty Restroom	2600	3	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.099	257.4	\$34.75	3	1	Dual Technology Occupancy Sensor - Switch Mnt.	not rebate eligible	33	0.08	20%	205.92	\$27.80	\$150.00	\$150.00	0.02	51.48	\$6.95	21.58
221.11	B207 Classroom	2600	12	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.744	1934.4	\$261.14	12	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.60	20%	1547.52	\$208.92	\$300.00	\$300.00	0.15	386.88	\$52.23	5.74
221.11	B205 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.116	2901.6	\$391.72	18	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.89	20%	2321.28	\$313.37	\$300.00	\$300.00	0.22	580.32	\$78.34	3.83
221.11	B203 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.116	2901.6	\$391.72	18	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.89	20%	2321.28	\$313.37	\$300.00	\$300.00	0.22	580.32	\$78.34	3.83
211.11	Boys' Restroom	2600	3	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.099	257.4	\$34.75	3	1	Dual Technology Occupancy Sensor - Switch Mnt.	not rebate eligible	33	0.08	20%	205.92	\$27.80	\$150.00	\$150.00	0.02	51.48	\$6.95	21.58
227.21		2600	1	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.065	169	\$22.82	1	0	No Change		65	0.07	0%	169	\$22.82	\$0.00	\$0.00	0.00	0	\$0.00	0.00
222.21	B Corridor	4400	14	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.868	3819.2	\$515.59	14	0	No Change		62	0.87	0%	3819.2	\$515.59	\$0.00	\$0.00	0.00	0	\$0.00	0.00
602		8760	2	2	Incandescent Exit Sign	20	0.04	350.4	\$47.30	2	0	No Change		20	0.04	0%	350.4	\$47.30	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.21	F Corridor	4400	10	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., Acrylic Lens	58	0.58	2552	\$344.52	10	0	No Change		58	0.58	0%	2552	\$344.52	\$0.00	\$0.00	0.00	0	\$0.00	0.00
602		8760	3	2	Incandescent Exit Sign	20	0.06	525.6	\$70.96	3	0	No Change		20	0.06	0%	525.6	\$70.96	\$0.00	\$0.00	0.00	0	\$0.00	0.00

221.11	F212 Classroom	2600	30	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.86	4836	\$652.86	30	2	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	1.49	20%	3868.8	\$522.29	\$300.00	\$600.00	0.37	967.2	\$130.57	4.60
221.14	F210 Science Department	2600	7	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.406	1055.6	\$142.51	7	1	Dual Technology Occupancy Sensor - Remote Mnt.		58	0.32	20%	844.48	\$114.00	\$250.00	\$250.00	0.08	211.12	\$28.50	8.77
221.11	F208 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.116	2901.6	\$391.72	18	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.89	20%	2321.28	\$313.37	\$300.00	\$300.00	0.22	580.32	\$78.34	3.83
221.14	F206 Prep Room	2600	7	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.406	1055.6	\$142.51	7	1	Dual Technology Occupancy Sensor - Remote Mnt.		58	0.32	20%	844.48	\$114.00	\$250.00	\$250.00	0.08	211.12	\$28.50	8.77
221.11	F204 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.116	2901.6	\$391.72	18	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.89	20%	2321.28	\$313.37	\$300.00	\$300.00	0.22	580.32	\$78.34	3.83
221.11	F200 Classroom	2600	33	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	2.046	5319.6	\$718.15	33	2	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	1.64	20%	4255.68	\$574.52	\$300.00	\$600.00	0.41	1063.92	\$143.63	4.18
221.11	F201 Storage	1200	6	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.372	446.4	\$60.26	6	1	Dual Technology Occupancy Sensor - Switch Mnt.	not rebate eligible	62	0.30	20%	357.12	\$48.21	\$150.00	\$150.00	0.07	89.28	\$12.05	12.45
221.11	F203 Classroom	2600	33	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	2.046	5319.6	\$718.15	33	2	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	1.64	20%	4255.68	\$574.52	\$300.00	\$600.00	0.41	1063.92	\$143.63	4.18
221.11	F207 Classroom	2600	30	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.86	4836	\$652.86	30	2	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	1.49	20%	3868.8	\$522.29	\$300.00	\$600.00	0.37	967.2	\$130.57	4.60
221.14	F211 Electrical Room	1200	5	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.29	348	\$46.98	5	0	No Change		58	0.29	0%	348	\$46.98	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.14	A200 Custodial Closet	1200	1	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.058	69.6	\$9.40	1	0	No Change		58	0.06	0%	69.6	\$9.40	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.11	A200 Girls' Restroom	2600	3	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.186	483.6	\$65.29	3	1	Dual Technology Occupancy Sensor - Switch Mnt.	not rebate eligible	62	0.15	20%	386.88	\$52.23	\$150.00	\$150.00	0.04	96.72	\$13.06	11.49
221.11	A204 Classroom	2600	21	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.302	3385.2	\$457.00	21	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	1.04	20%	2708.16	\$365.60	\$300.00	\$300.00	0.26	677.04	\$91.40	3.28
221.11	A201 Year Book Office	2600	10	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.62	1612	\$217.62	10	1	Dual Technology Occupancy Sensor - Remote Mnt.		62	0.50	20%	1289.6	\$174.10	\$250.00	\$250.00	0.12	322.4	\$43.52	5.74
221.11	A206 Classroom	2600	10	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.62	1612	\$217.62	10	1	Dual Technology Occupancy Sensor - Remote Mnt.		62	0.50	20%	1289.6	\$174.10	\$250.00	\$250.00	0.12	322.4	\$43.52	5.74
221.11	Men's Restroom	2600	2	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.124	322.4	\$43.52	2	1	Dual Technology Occupancy Sensor - Switch Mnt.	not rebate eligible	62	0.10	20%	257.92	\$34.82	\$150.00	\$150.00	0.02	64.48	\$8.70	17.23
221.11	A208 Classroom	2600	10	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.62	1612	\$217.62	10	1	Dual Technology Occupancy Sensor - Remote Mnt.		62	0.50	20%	1289.6	\$174.10	\$250.00	\$250.00	0.12	322.4	\$43.52	5.74

221.11	A210 Special Services	2600	27	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.674	4352.4	\$587.57	27	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	1.34	20%	3481.92	\$470.06	\$300.00	\$300.00	0.33	870.48	\$117.51	2.55
121.14	A212 Storage Closet	1200	1	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Surface Mnt., No Lens	78	0.078	93.6	\$12.64	1	0	No Change		78	0.08	0%	93.6	\$12.64	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.11	A214 VP Office	2600	8	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.496	1289.6	\$174.10	8	1	Dual Technology Occupancy Sensor - Remote Mnt.		62	0.40	20%	1031.68	\$139.28	\$250.00	\$250.00	0.10	257.92	\$34.82	7.18
222.21	A207 Balcony	1200	3	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.186	223.2	\$30.13	3	0	No Change		62	0.19	0%	223.2	\$30.13	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.11	Women's Restroom	2600	2	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.124	322.4	\$43.52	2	1	Dual Technology Occupancy Sensor - Switch Mnt.	not rebate eligible	62	0.10	20%	257.92	\$34.82	\$150.00	\$150.00	0.02	64.48	\$8.70	17.23
222.21	A Corridor	4400	14	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.868	3819.2	\$515.59	14	0	No Change		62	0.87	0%	3819.2	\$515.59	\$0.00	\$0.00	0.00	0	\$0.00	0.00
602		8760	3	2	Incandescent Exit Sign	20	0.06	525.6	\$70.96	3	0	No Change		20	0.06	0%	525.6	\$70.96	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.11	A216 Classroom	2600	27	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.674	4352.4	\$587.57	27	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	1.34	20%	3481.92	\$470.06	\$300.00	\$300.00	0.33	870.48	\$117.51	2.55
211.11	Boys' Restroom	2600	3	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.099	257.4	\$34.75	3	1	Dual Technology Occupancy Sensor - Switch Mnt.	not rebate eligible	33	0.08	20%	205.92	\$27.80	\$150.00	\$150.00	0.02	51.48	\$6.95	21.58
222.21	E Corridor	4400	7	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.434	1909.6	\$257.80	7	0	No Change		62	0.43	0%	1909.6	\$257.80	\$0.00	\$0.00	0.00	0	\$0.00	0.00
602		8790	2	2	Incandescent Exit Sign	20	0.04	351.6	\$47.47	2	0	No Change		20	0.04	0%	351.6	\$47.47	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.11	A220 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.116	2901.6	\$391.72	18	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.89	20%	2321.28	\$313.37	\$300.00	\$300.00	0.22	580.32	\$78.34	3.83
221.14	E201 World Languages	2600	3	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.174	452.4	\$61.07	3	0	No Change		58	0.17	0%	452.4	\$61.07	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.11	E203 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.116	2901.6	\$391.72	18	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.89	20%	2321.28	\$313.37	\$300.00	\$300.00	0.22	580.32	\$78.34	3.83
221.11	E200 Book Room	2600	6	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.372	967.2	\$130.57	6	1	Dual Technology Occupancy Sensor - Switch Mnt.		62	0.30	20%	773.76	\$104.46	\$150.00	\$150.00	0.07	193.44	\$26.11	5.74
221.11	E202 Classroom	2600	20	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.24	3224	\$435.24	20	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.99	20%	2579.2	\$348.19	\$300.00	\$300.00	0.25	644.8	\$87.05	3.45
221.11	E205 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.116	2901.6	\$391.72	18	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.89	20%	2321.28	\$313.37	\$300.00	\$300.00	0.22	580.32	\$78.34	3.83
221.11	E206 Classroom	2600	10	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.62	1612	\$217.62	10	1	Dual Technology Occupancy Sensor - Remote Mnt.		62	0.50	20%	1289.6	\$174.10	\$250.00	\$250.00	0.12	322.4	\$43.52	5.74

221.11	E207 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.116	2901.6	\$391.72	18	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.89	20%	2321.28	\$313.37	\$300.00	\$300.00	0.22	580.32	\$78.34	3.83
221.11	E208 Classroom	2600	10	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.62	1612	\$217.62	10	1	Dual Technology Occupancy Sensor - Remote Mnt.		62	0.50	20%	1289.6	\$174.10	\$250.00	\$250.00	0.12	322.4	\$43.52	5.74
221.11	E209 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.116	2901.6	\$391.72	18	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.89	20%	2321.28	\$313.37	\$300.00	\$300.00	0.22	580.32	\$78.34	3.83
221.11	E210 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.116	2901.6	\$391.72	18	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.89	20%	2321.28	\$313.37	\$300.00	\$300.00	0.22	580.32	\$78.34	3.83
221.14	E213 Book Room	2600	2	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.116	301.6	\$40.72	2	1	Dual Technology Occupancy Sensor - Switch Mnt.		58	0.09	20%	241.28	\$32.57	\$150.00	\$150.00	0.02	60.32	\$8.14	18.42
221.11	B223 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	1.116	2901.6	\$391.72	18	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.89	20%	2321.28	\$313.37	\$300.00	\$300.00	0.22	580.32	\$78.34	3.83
221.11	E212 Office	2600	6	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.372	967.2	\$130.57	6	1	Dual Technology Occupancy Sensor - Switch Mnt.		62	0.30	20%	773.76	\$104.46	\$150.00	\$150.00	0.07	193.44	\$26.11	5.74
211.11	CustodialCloset	1200	1	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.033	39.6	\$5.35	1	0	No Change		33	0.03	0%	39.6	\$5.35	\$0.00	\$0.00	0.00	0	\$0.00	0.00
211.11	Girls' Restroom	2600	3	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.099	257.4	\$34.75	3	1	Dual Technology Occupancy Sensor - Switch Mnt.	not rebate eligible	33	0.08	20%	205.92	\$27.80	\$150.00	\$150.00	0.02	51.48	\$6.95	21.58
211.11	Stairwell D1	4400	8	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.264	1161.6	\$156.82	8	0	No Change		33	0.26	0%	1161.6	\$156.82	\$0.00	\$0.00	0.00	0	\$0.00	0.00
613	Mech. Room B212	1200	2	1	Industrial Fixture, 100w A19 Lamp	100	0.2	240	\$32.40	2	0	No Change		100	0.20	0%	240	\$32.40	\$0.00	\$0.00	0.00	0	\$0.00	0.00
613	B208 Mech. Room	1200	2	1	Industrial Fixture, 100w A19 Lamp	100	0.2	240	\$32.40	2	0	No Change		100	0.20	0%	240	\$32.40	\$0.00	\$0.00	0.00	0	\$0.00	0.00
222.21	Stairwell Near Elevator	4400	3	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.186	818.4	\$110.48	3	0	No Change		62	0.19	0%	818.4	\$110.48	\$0.00	\$0.00	0.00	0	\$0.00	0.00
602		8760	1	2	Incandescent Exit Sign	20	0.02	175.2	\$23.65	1	0	No Change		20	0.02	0%	175.2	\$23.65	\$0.00	\$0.00	0.00	0	\$0.00	0.00
211.11	Stairwell A2	4400	8	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.264	1161.6	\$156.82	8	0	No Change		33	0.26	0%	1161.6	\$156.82	\$0.00	\$0.00	0.00	0	\$0.00	0.00
211.11	Stairwell A4	4400	8	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.264	1161.6	\$156.82	8	0	No Change		33	0.26	0%	1161.6	\$156.82	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.31	A128 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.116	2901.6	\$391.72	18	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.89	20%	2321.28	\$313.37	\$300.00	\$300.00	0.22	580.32	\$78.34	3.83
221.14	E101 Office	2600	3	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.174	452.4	\$61.07	3	1	Dual Technology Occupancy Sensor - Switch Mnt.		58	0.14	20%	361.92	\$48.86	\$150.00	\$150.00	0.03	90.48	\$12.21	12.28
221.31	E103 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.116	2901.6	\$391.72	18	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.89	20%	2321.28	\$313.37	\$300.00	\$300.00	0.22	580.32	\$78.34	3.83

221.31	E105 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.116	2901.6	\$391.72	18	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.89	20%	2321.28	\$313.37	\$300.00	\$300.00	0.22	\$80.32	\$78.34	3.83
221.31	E107 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.116	2901.6	\$391.72	18	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.89	20%	2321.28	\$313.37	\$300.00	\$300.00	0.22	\$80.32	\$78.34	3.83
221.31	E109 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.116	2901.6	\$391.72	18	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.89	20%	2321.28	\$313.37	\$300.00	\$300.00	0.22	\$80.32	\$78.34	3.83
221.14	E111 Book Room	2600	3	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.174	452.4	\$61.07	3	1	Dual Technology Occupancy Sensor - Switch Mnt.		58	0.14	20%	361.92	\$48.86	\$150.00	\$150.00	0.03	90.48	\$12.21	12.28
221.31	B127 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.116	2901.6	\$391.72	18	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.89	20%	2321.28	\$313.37	\$300.00	\$300.00	0.22	\$80.32	\$78.34	3.83
222.21	B Corridor	4400	8	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.496	2182.4	\$294.62	8	0	No Change		62	0.50	0%	2182.4	\$294.62	\$0.00	\$0.00	0.00	0	\$0.00	0.00
602		8760	2	2	Incandescent Exit Sign	20	0.04	350.4	\$47.30	2	0	No Change		20	0.04	0%	350.4	\$47.30	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.31	E112 Classroom	2600	10	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.62	1612	\$217.62	10	1	Dual Technology Occupancy Sensor - Remote Mnt.		62	0.50	20%	1289.6	\$174.10	\$250.00	\$250.00	0.12	322.4	\$43.52	5.74
221.31	E110 Classroom	2600	10	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.62	1612	\$217.62	10	1	Dual Technology Occupancy Sensor - Remote Mnt.		62	0.50	20%	1289.6	\$174.10	\$250.00	\$250.00	0.12	322.4	\$43.52	5.74
221.31	E108 VP Office	2600	9	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.558	1450.8	\$195.86	9	1	Dual Technology Occupancy Sensor - Remote Mnt.		62	0.45	20%	1160.64	\$156.69	\$250.00	\$250.00	0.11	290.16	\$39.17	6.38
221.31	E106 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.116	2901.6	\$391.72	18	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.89	20%	2321.28	\$313.37	\$300.00	\$300.00	0.22	\$80.32	\$78.34	3.83
232.21	E104 Classroom	2600	12	3	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	86	1.032	2683.2	\$362.23	12	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		86	0.83	20%	2146.56	\$289.79	\$300.00	\$300.00	0.21	536.64	\$72.45	4.14
227.21		2600	4	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.26	676	\$91.26	4	0	No Change		65	0.26	0%	676	\$91.26	\$0.00	\$0.00	0.00	0	\$0.00	0.00
211.11	Women's Restroom	2600	2	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.066	171.6	\$23.17	2	0	No Change		33	0.07	0%	171.6	\$23.17	\$0.00	\$0.00	0.00	0	\$0.00	0.00
105	A Corridor Display Case	4400	5	2	3' Channel, 2-Lamp, 30w T12, Mag. Ballast, Surface Mnt., No Lens	60	0.3	1320	\$178.20	5	0	No Change		60	0.30	0%	1320	\$178.20	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.31	A127 Classroom	2600	16	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.992	2579.2	\$348.19	16	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.79	20%	2063.36	\$278.55	\$300.00	\$300.00	0.20	515.84	\$69.64	4.31
232.21		2600	1	3	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	86	0.086	223.6	\$30.19	1	0	No Change		86	0.09	0%	223.6	\$30.19	\$0.00	\$0.00	0.00	0	\$0.00	0.00
232.21	A125 Resource Officer	2600	2	3	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	86	0.172	447.2	\$60.37	2	1	Dual Technology Occupancy Sensor - Switch Mnt.		86	0.14	20%	357.76	\$48.30	\$150.00	\$150.00	0.03	89.44	\$12.07	12.42

232.21	A123 Conference Room	2600	2	3	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	86	0.172	447.2	\$60.37	2	1	Dual Technology Occupancy Sensor - Switch Mnt.		86	0.14	20%	357.76	\$48.30	\$150.00	\$150.00	0.03	89.44	\$12.07	12.42
221.31	A121 Classroom	2600	16	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.992	2579.2	\$348.19	16	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.79	20%	2063.36	\$278.55	\$300.00	\$300.00	0.20	515.84	\$69.64	4.31
232.21		2600	1	3	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	86	0.086	223.6	\$30.19	1	0	No Change		86	0.09	0%	223.6	\$30.19	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.14	A119 Elec. Room	1200	2	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.116	139.2	\$18.79	2	0	No Change		58	0.12	0%	139.2	\$18.79	\$0.00	\$0.00	0.00	0	\$0.00	0.00
211.11	A117 Men's Restroom	2600	2	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.066	171.6	\$23.17	2	0	No Change		33	0.07	0%	171.6	\$23.17	\$0.00	\$0.00	0.00	0	\$0.00	0.00
211.11	A115 Closet	1200	2	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.066	79.2	\$10.69	2	0	No Change		33	0.07	0%	79.2	\$10.69	\$0.00	\$0.00	0.00	0	\$0.00	0.00
211.11	Women's Restroom	2600	2	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.066	171.6	\$23.17	2	0	No Change		33	0.07	0%	171.6	\$23.17	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.14	A109 Elec. Room	1200	2	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.116	139.2	\$18.79	2	0	No Change		58	0.12	0%	139.2	\$18.79	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.14	A107 Office	2600	3	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.174	452.4	\$61.07	3	1	Dual Technology Occupancy Sensor - Switch Mnt.		58	0.14	20%	361.92	\$48.86	\$150.00	\$150.00	0.03	90.48	\$12.21	12.28
221.31	A105 Classroom	2600	28	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.736	4513.6	\$609.34	28	2	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	1.39	20%	3610.88	\$487.47	\$300.00	\$600.00	0.35	902.72	\$121.87	4.92
221.31	A105 Storage	1200	2	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.124	148.8	\$20.09	2	0	No Change		62	0.12	0%	148.8	\$20.09	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.14	A103 Storage/Elec. Room	1200	4	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.232	278.4	\$37.58	4	0	No Change		58	0.23	0%	278.4	\$37.58	\$0.00	\$0.00	0.00	0	\$0.00	0.00
222.21	A100 Classroom	2600	9	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.558	1450.8	\$195.86	9	1	Dual Technology Occupancy Sensor - Remote Mnt.		62	0.45	20%	1160.64	\$156.69	\$250.00	\$250.00	0.11	290.16	\$39.17	6.38
221.14	A102 Custodian Closet	1200	2	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.116	139.2	\$18.79	2	0	No Change		58	0.12	0%	139.2	\$18.79	\$0.00	\$0.00	0.00	0	\$0.00	0.00
211.11	Men's Restroom	2600	3	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.099	257.4	\$34.75	3	1	Dual Technology Occupancy Sensor - Switch Mnt.	not rebate eligible	33	0.08	20%	205.92	\$27.80	\$150.00	\$150.00	0.02	51.48	\$6.95	21.58
221.21	A Corridor	4400	16	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., Acrylic Lens	58	0.928	4083.2	\$551.23	16	0	No Change		58	0.93	0%	4083.2	\$551.23	\$0.00	\$0.00	0.00	0	\$0.00	0.00
602		8760	4	2	Incandescent Exit Sign	20	0.08	700.8	\$94.61	4	0	No Change		20	0.08	0%	700.8	\$94.61	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.31	A104 Conference Room	2600	4	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.248	644.8	\$87.05	4	1	Dual Technology Occupancy Sensor - Switch Mnt.		62	0.20	20%	515.84	\$69.64	\$150.00	\$150.00	0.05	128.96	\$17.41	8.62
221.31	Ms. Smith's Office	2600	6	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.372	967.2	\$130.57	6	1	Dual Technology Occupancy Sensor - Switch Mnt.		62	0.30	20%	773.76	\$104.46	\$150.00	\$150.00	0.07	193.44	\$26.11	5.74
221.31	Mrs. Vizoco's Office	2600	6	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.372	967.2	\$130.57	6	1	Dual Technology Occupancy Sensor - Switch Mnt.		62	0.30	20%	773.76	\$104.46	\$150.00	\$150.00	0.07	193.44	\$26.11	5.74

221.31	Guidance Receptionist, Area & Hall	2600	16	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.992	2579.2	\$348.19	16	0	No Change	62	0.99	0%	2579.2	\$348.19	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.31	Guidance Director Office	2600	6	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.372	967.2	\$130.57	6	1	Dual Technology Occupancy Sensor - Switch Mnt.	62	0.30	20%	773.76	\$104.46	\$150.00	\$150.00	0.07	193.44	\$26.11	5.74
221.31	Mrs. Hensel's Office	2600	4	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.248	644.8	\$87.05	4	1	Dual Technology Occupancy Sensor - Switch Mnt.	62	0.20	20%	515.84	\$69.64	\$150.00	\$150.00	0.05	128.96	\$17.41	8.62
221.31	Counselor	2600	4	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.248	644.8	\$87.05	4	1	Dual Technology Occupancy Sensor - Switch Mnt.	62	0.20	20%	515.84	\$69.64	\$150.00	\$150.00	0.05	128.96	\$17.41	8.62
221.31	Mrs. Papadinec's Office	2600	4	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.248	644.8	\$87.05	4	1	Dual Technology Occupancy Sensor - Switch Mnt.	62	0.20	20%	515.84	\$69.64	\$150.00	\$150.00	0.05	128.96	\$17.41	8.62
221.31	Mrs. Strauss' Office	2600	4	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.248	644.8	\$87.05	4	1	Dual Technology Occupancy Sensor - Switch Mnt.	62	0.20	20%	515.84	\$69.64	\$150.00	\$150.00	0.05	128.96	\$17.41	8.62
221.31	Copy Room/Files	2600	4	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.248	644.8	\$87.05	4	1	Dual Technology Occupancy Sensor - Switch Mnt.	62	0.20	20%	515.84	\$69.64	\$150.00	\$150.00	0.05	128.96	\$17.41	8.62
284.25	Lobby	4400	2	8	4x4, 8 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., White Diffuser	214	0.428	1883.2	\$254.23	2	0	No Change	214	0.43	0%	1883.2	\$254.23	\$0.00	\$0.00	0.00	0	\$0.00	0.00
602		8760	2	2	Incandescent Exit Sign	20	0.04	350.4	\$47.30	2	0	No Change	20	0.04	0%	350.4	\$47.30	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Vestibule	4400	3	2	2x2, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.195	858	\$115.83	3	0	No Change	65	0.20	0%	858	\$115.83	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Main Office Stairway	2600	1	2	2x2, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.065	169	\$22.82	1	0	No Change	65	0.07	0%	169	\$22.82	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.31	Main Office	2600	14	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.868	2256.8	\$304.67	14	0	No Change	62	0.87	0%	2256.8	\$304.67	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.31	Principal's Office	2600	8	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.496	1289.6	\$174.10	8	1	Dual Technology Occupancy Sensor - Switch Mnt.	62	0.40	20%	1031.68	\$139.28	\$150.00	\$150.00	0.10	257.92	\$34.82	4.31
221.31	Nurse	2600	9	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.558	1450.8	\$195.86	9	0	No Change	62	0.56	0%	1450.8	\$195.86	\$0.00	\$0.00	0.00	0	\$0.00	0.00
621	Auditorium	1200	64	1	Recessed Light, 300w Quartz Lamp	300	19.2	23040	\$3,110.40	64	0	No Change	300	19.20	0%	23040	\$3,110.40	\$0.00	\$0.00	0.00	0	\$0.00	0.00
602		8760	6	2	Incandescent Exit Sign	20	0.12	1051.2	\$141.91	6	0	No Change	20	0.12	0%	1051.2	\$141.91	\$0.00	\$0.00	0.00	0	\$0.00	0.00
611		1200	4	1	1x1 Recessed, (1) 60w A19 Lamps	60	0.24	288	\$38.88	4	0	No Change	60	0.24	0%	288	\$38.88	\$0.00	\$0.00	0.00	0	\$0.00	0.00
211.11	Men's Restroom	2600	3	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.099	257.4	\$34.75	3	1	Dual Technology Occupancy Sensor - Switch Mnt.	33	0.08	20%	205.92	\$27.80	\$150.00	\$150.00	0.02	51.48	\$6.95	21.58
211.11	B123 Custodial Closet	1200	1	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.033	39.6	\$5.35	1	0	No Change	33	0.03	0%	39.6	\$5.35	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.31	B121 Classroom	2600	15	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.93	2418	\$326.43	15	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount	62	0.74	20%	1934.4	\$261.14	\$300.00	\$300.00	0.19	483.6	\$65.29	4.60



221.31	E113 Classroom	2600	15	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.93	2418	\$326.43	15	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.74	20%	1934.4	\$261.14	\$300.00	\$300.00	0.19	483.6	\$65.29	4.60
222.21	B Corridor	4400	12	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.744	3273.6	\$441.94	12	0	No Change		62	0.74	0%	3273.6	\$441.94	\$0.00	\$0.00	0.00	0	\$0.00	0.00
602		8760	2	2	Incandescent Exit Sign	20	0.04	350.4	\$47.30	2	0	No Change		20	0.04	0%	350.4	\$47.30	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.31	B119 Classroom	2600	15	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.93	2418	\$326.43	15	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.74	20%	1934.4	\$261.14	\$300.00	\$300.00	0.19	483.6	\$65.29	4.60
221.31	B117 Classroom	2600	15	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.93	2418	\$326.43	15	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.74	20%	1934.4	\$261.14	\$300.00	\$300.00	0.19	483.6	\$65.29	4.60
221.31	B115 Classroom	2600	21	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.302	3385.2	\$457.00	21	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	1.04	20%	2708.16	\$365.60	\$300.00	\$300.00	0.26	677.04	\$91.40	3.28
221.14	B109 Elec. Room	1200	14	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.812	974.4	\$131.54	14	0	No Change		58	0.81	0%	974.4	\$131.54	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.31	Faculty	2600	16	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.992	2579.2	\$348.19	16	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.79	20%	2063.36	\$278.55	\$300.00	\$300.00	0.20	515.84	\$69.64	4.31
211.11	Faculty Restroom	1200	6	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.198	237.6	\$32.08	6	1	Dual Technology Occupancy Sensor - Switch Mnt.	not rebate eligible	33	0.16	20%	190.08	\$25.66	\$150.00	\$150.00	0.04	47.52	\$6.42	23.38
221.14	B104 Elec. Room	1200	4	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.232	278.4	\$37.58	4	1	Dual Technology Occupancy Sensor - Switch Mnt.		58	0.19	20%	222.72	\$30.07	\$150.00	\$150.00	0.05	55.68	\$7.52	19.96
221.31	B106 Classroom	2600	25	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.55	4030	\$544.05	25	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	1.24	20%	3224	\$435.24	\$300.00	\$300.00	0.31	806	\$108.81	2.76
221.14	B108 School Store	2600	5	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.29	754	\$101.79	5	1	Dual Technology Occupancy Sensor - Switch Mnt.		58	0.23	20%	603.2	\$81.43	\$150.00	\$150.00	0.06	150.8	\$20.36	7.37
211.11	Women's Restroom	2600	4	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.232	603.2	\$81.43	4	1	Dual Technology Occupancy Sensor - Switch Mnt.		58	0.19	20%	482.56	\$65.15	\$150.00	\$150.00	0.05	120.64	\$16.29	9.21
222.21	Corridor F	4400	9	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.558	2455.2	\$331.45	9	0	No Change		62	0.56	0%	2455.2	\$331.45	\$0.00	\$0.00	0.00	0	\$0.00	0.00
602		8760	1	2	Incandescent Exit Sign	20	0.02	175.2	\$23.65	1	0	No Change		20	0.02	0%	175.2	\$23.65	\$0.00	\$0.00	0.00	0	\$0.00	0.00
222.21	F110 Classroom	2600	21	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	1.302	3385.2	\$457.00	21	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	1.04	20%	2708.16	\$365.60	\$300.00	\$300.00	0.26	677.04	\$91.40	3.28
221.31	F108 Classroom	2600	18	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.116	2901.6	\$391.72	18	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.89	20%	2321.28	\$313.37	\$300.00	\$300.00	0.22	580.32	\$78.34	3.83
221.31	F106 Classroom	2600	27	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.674	4352.4	\$587.57	27	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	1.34	20%	3481.92	\$470.06	\$300.00	\$300.00	0.33	870.48	\$117.51	2.55

221.31	F105 Classroom	2600	24	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.488	3868.8	\$522.29	24	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	1.19	20%	3095.04	\$417.83	\$300.00	\$300.00	0.30	773.76	\$104.46	2.87
221.31	F104 Classroom	2600	24	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.488	3868.8	\$522.29	24	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	1.19	20%	3095.04	\$417.83	\$300.00	\$300.00	0.30	773.76	\$104.46	2.87
221.31	F103 Classroom	2600	24	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.488	3868.8	\$522.29	24	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	1.19	20%	3095.04	\$417.83	\$300.00	\$300.00	0.30	773.76	\$104.46	2.87
221.31	F101 Classroom	2600	10	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.62	1612	\$217.62	10	1	Dual Technology Occupancy Sensor - Remote Mnt.		62	0.50	20%	1289.6	\$174.10	\$250.00	\$250.00	0.12	322.4	\$43.52	5.74
222.21	Corridor G	4400	40	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	2.48	10912	\$1,473.12	40	0	No Change		62	2.48	0%	10912	\$1,473.12	\$0.00	\$0.00	0.00	0	\$0.00	0.00
601		8760	8	2	(2) 7w CFL Exit Sign	16	0.128	1121.28	\$151.37	8	0	No Change		16	0.13	0%	1121.28	\$151.37	\$0.00	\$0.00	0.00	0	\$0.00	0.00
222.21	G101 Classroom	2600	28	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	1.736	4513.6	\$609.34	28	2	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	1.39	20%	3610.88	\$487.47	\$300.00	\$600.00	0.35	902.72	\$121.87	4.92
601		8760	3	2	(2) 7w CFL Exit Sign	16	0.048	420.48	\$56.76	3	0	No Change		16	0.05	0%	420.48	\$56.76	\$0.00	\$0.00	0.00	0	\$0.00	0.00
222.11	G100 Elec. Closet	1200	2	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Wall Mnt., Indirect	58	0.116	139.2	\$18.79	2	0	No Change		58	0.12	0%	139.2	\$18.79	\$0.00	\$0.00	0.00	0	\$0.00	0.00
222.21	G102 Classroom	2600	28	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	1.736	4513.6	\$609.34	28	2	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	1.39	20%	3610.88	\$487.47	\$300.00	\$600.00	0.35	902.72	\$121.87	4.92
601		8760	3	2	(2) 7w CFL Exit Sign	16	0.048	420.48	\$56.76	3	0	No Change		16	0.05	0%	420.48	\$56.76	\$0.00	\$0.00	0.00	0	\$0.00	0.00
232.22	G104 Classroom	2600	8	3	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Parabolic Lens	86	0.688	1788.8	\$241.49	8	1	Dual Technology Occupancy Sensor - Remote Mnt.		86	0.55	20%	1431.04	\$193.19	\$250.00	\$250.00	0.14	357.76	\$48.30	5.18
222.21	G103 Classroom	2600	20	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	1.24	3224	\$435.24	20	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.99	20%	2579.2	\$348.19	\$300.00	\$300.00	0.25	644.8	\$87.05	3.45
222.21	G106 Classroom	2600	20	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	1.24	3224	\$435.24	20	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.99	20%	2579.2	\$348.19	\$300.00	\$300.00	0.25	644.8	\$87.05	3.45
227.211	Girls' Restroom	2600	6	2	2x2, 2 Lamp, 17w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	34	0.204	530.4	\$71.60	6	1	Dual Technology Occupancy Sensor - Remote Mnt.	not rebate eligible	34	0.16	20%	424.32	\$57.28	\$250.00	\$250.00	0.04	106.08	\$14.32	17.46
222.21	G108 Classroom	2600	12	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.744	1934.4	\$261.14	12	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.60	20%	1547.52	\$208.92	\$300.00	\$300.00	0.15	386.88	\$52.23	5.74
227.211	Boys' Restroom	2600	6	2	2x2, 2 Lamp, 17w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	34	0.204	530.4	\$71.60	6	1	Dual Technology Occupancy Sensor - Remote Mnt.	not rebate eligible	34	0.16	20%	424.32	\$57.28	\$250.00	\$250.00	0.04	106.08	\$14.32	17.46
222.21	G111 Classroom	2600	12	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	34	0.408	1060.8	\$143.21	12	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		34	0.33	20%	848.64	\$114.57	\$300.00	\$300.00	0.08	212.16	\$28.64	10.47
222.21	G110 Classroom	2600	12	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.744	1934.4	\$261.14	12	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	0.60	20%	1547.52	\$208.92	\$300.00	\$300.00	0.15	386.88	\$52.23	5.74

222.21	G112 Classroom	2600	12	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.744	1934.4	\$261.14	12	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount	62	0.60	20%	1547.52	\$208.92	\$300.00	\$300.00	0.15	386.88	\$52.23	5.74
222.21	G113 Classroom	2600	12	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.744	1934.4	\$261.14	12	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount	62	0.60	20%	1547.52	\$208.92	\$300.00	\$300.00	0.15	386.88	\$52.23	5.74
222.21	G115 VP Office	2600	8	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.496	1289.6	\$174.10	8	1	Dual Technology Occupancy Sensor - Remote Mnt.	62	0.40	20%	1031.68	\$139.28	\$250.00	\$250.00	0.10	257.92	\$34.82	7.18
222.21	C100-G	2600	8	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.496	1289.6	\$174.10	8	1	Dual Technology Occupancy Sensor - Remote Mnt.	62	0.40	20%	1031.68	\$139.28	\$250.00	\$250.00	0.10	257.92	\$34.82	7.18
222.21	C100 Media Center	2600	134	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	8.308	21600.8	\$2,916.11	134	6	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount	62	6.65	20%	17280.64	\$2,332.89	\$300.00	\$1,800.00	1.66	4320.16	\$583.22	3.09
601		8760	3	2	(2) 7w CFL Exit Sign	16	0.048	420.48	\$56.76	3	0	No Change	16	0.05	0%	420.48	\$56.76	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.31		2600	89	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	5.518	14346.8	\$1,936.82	89	0	No Change	62	5.52	0%	14346.8	\$1,936.82	\$0.00	\$0.00	0.00	0	\$0.00	0.00
555		2600	10	1	Recessed Down Light, 50w R20 Lamp	50	0.5	1300	\$175.50	10	0	No Change	50	0.50	0%	1300	\$175.50	\$0.00	\$0.00	0.00	0	\$0.00	0.00
222.21	Periodicals	2600	5	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.31	806	\$108.81	5	1	Dual Technology Occupancy Sensor - Remote Mnt.	62	0.25	20%	644.8	\$87.05	\$250.00	\$250.00	0.06	161.2	\$21.76	11.49
221.31		2600	4	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	0.248	644.8	\$87.05	4	1	Dual Technology Occupancy Sensor - Remote Mnt.	62	0.20	20%	515.84	\$69.64	\$250.00	\$250.00	0.05	128.96	\$17.41	14.36
222.21	Library Office	2600	5	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.31	806	\$108.81	5	1	Dual Technology Occupancy Sensor - Switch Mnt.	62	0.25	20%	644.8	\$87.05	\$150.00	\$150.00	0.06	161.2	\$21.76	6.89
232.22	Library Staff	2600	10	3	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Parabolic Lens	86	0.86	2236	\$301.86	10	1	Dual Technology Occupancy Sensor - Remote Mnt.	86	0.69	20%	1788.8	\$241.49	\$250.00	\$250.00	0.17	447.2	\$60.37	4.14
222.21	Supervisor Special Services Office	2600	7	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.434	1128.4	\$152.33	7	1	Dual Technology Occupancy Sensor - Remote Mnt.	62	0.35	20%	902.72	\$121.87	\$250.00	\$250.00	0.09	225.68	\$30.47	8.21
222.21	Library Classroom	2600	12	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.744	1934.4	\$261.14	12	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount	62	0.60	20%	1547.52	\$208.92	\$300.00	\$300.00	0.15	386.88	\$52.23	5.74
222.21	C-100-C TV	2600	12	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.744	1934.4	\$261.14	12	0	No Change	62	0.74	0%	1934.4	\$261.14	\$0.00	\$0.00	0.00	0	\$0.00	0.00
222.21	C Corridor	4400	17	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	1.054	4637.6	\$626.08	17	0	No Change	62	1.05	0%	4637.6	\$626.08	\$0.00	\$0.00	0.00	0	\$0.00	0.00
602		8760	2	2	Incandescent Exit Sign	20	0.04	350.4	\$47.30	2	0	No Change	20	0.04	0%	350.4	\$47.30	\$0.00	\$0.00	0.00	0	\$0.00	0.00
222.21	C102 Office	2600	4	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.248	644.8	\$87.05	4	0	No Change	62	0.25	0%	644.8	\$87.05	\$0.00	\$0.00	0.00	0	\$0.00	0.00
222.21	C104 Office	2600	4	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.248	644.8	\$87.05	4	0	No Change	62	0.25	0%	644.8	\$87.05	\$0.00	\$0.00	0.00	0	\$0.00	0.00


222.21	F Corridor	4400	18	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	1.116	4910.4	\$662.90	18	0	No Change	62	1.12	0%	4910.4	\$662.90	\$0.00	\$0.00	0.00	0	\$0.00	0.00
602		8760	2	2	Incandescent Exit Sign	20	0.04	350.4	\$47.30	2	0	No Change	20	0.04	0%	350.4	\$47.30	\$0.00	\$0.00	0.00	0	\$0.00	0.00
222.21	E Corridor	4400	15	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.93	4092	\$552.42	15	0	No Change	62	0.93	0%	4092	\$552.42	\$0.00	\$0.00	0.00	0	\$0.00	0.00
602		8760	2	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.124	1086.24	\$146.64	2	0	No Change	62	0.12	0%	1086.24	\$146.64	\$0.00	\$0.00	0.00	0	\$0.00	0.00
222.21	D Corridor	4400	7	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.434	1909.6	\$257.80	7	0	No Change	62	0.43	0%	1909.6	\$257.80	\$0.00	\$0.00	0.00	0	\$0.00	0.00
602		8760	2	2	Incandescent Exit Sign	20	0.04	350.4	\$47.30	2	0	No Change	20	0.04	0%	350.4	\$47.30	\$0.00	\$0.00	0.00	0	\$0.00	0.00
222.21	F128 Classroom	2600	18	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	1.116	2901.6	\$391.72	18	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount	62	0.89	20%	2321.28	\$313.37	\$300.00	\$300.00	0.22	580.32	\$78.34	3.83
602		8760	1	2	Incandescent Exit Sign	20	0.02	175.2	\$23.65	1	0	No Change	20	0.02	0%	175.2	\$23.65	\$0.00	\$0.00	0.00	0	\$0.00	0.00
222.21	F126 Classroom	2600	6	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.372	967.2	\$130.57	6	1	Dual Technology Occupancy Sensor - Remote Mnt.	62	0.30	20%	773.76	\$104.46	\$250.00	\$250.00	0.07	193.44	\$26.11	9.57
222.21	F124 Classroom	2600	12	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.744	1934.4	\$261.14	12	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount	62	0.60	20%	1547.52	\$208.92	\$300.00	\$300.00	0.15	386.88	\$52.23	5.74
232.21	F120 Cafeteria	2600	34	3	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	86	2.924	7602.4	\$1,026.32	34	2	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount	86	2.34	20%	6081.92	\$821.06	\$300.00	\$600.00	0.58	1520.48	\$205.26	2.92
602		8760	4	2	Incandescent Exit Sign	20	0.08	700.8	\$94.61	4	0	No Change	20	0.08	0%	700.8	\$94.61	\$0.00	\$0.00	0.00	0	\$0.00	0.00
222.11	Kitchen	2600	32	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Wall Mnt., Indirect	58	1.856	4825.6	\$651.46	32	2	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount	58	1.48	20%	3860.48	\$521.16	\$300.00	\$600.00	0.37	965.12	\$130.29	4.61
602		8760	1	2	Incandescent Exit Sign	20	0.02	175.2	\$23.65	1	0	No Change	20	0.02	0%	175.2	\$23.65	\$0.00	\$0.00	0.00	0	\$0.00	0.00
612	Compressor Room	1200	2	1	Pendant Mnt., 100w A19 Lamp	100	0.2	240	\$32.40	2	0	No Change	100	0.20	0%	240	\$32.40	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.31	F114 Classroom	2600	24	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.488	3868.8	\$522.29	24	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount	62	1.19	20%	3095.04	\$417.83	\$300.00	\$300.00	0.30	773.76	\$104.46	2.87
221.31	F112 Classroom	2600	24	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	1.488	3868.8	\$522.29	24	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount	62	1.19	20%	3095.04	\$417.83	\$300.00	\$300.00	0.30	773.76	\$104.46	2.87
222.21	F111 Classroom	2600	24	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	1.488	3868.8	\$522.29	24	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount	62	1.19	20%	3095.04	\$417.83	\$300.00	\$300.00	0.30	773.76	\$104.46	2.87
211.14	C101 Elec. Closet	1200	18	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.594	712.8	\$96.23	18	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount	33	0.48	20%	570.24	\$76.98	\$300.00	\$300.00	0.12	142.56	\$19.25	15.59
770	Gym	2600	48	1	400w MH, Prismatic Lens	465	22.32	58032	\$7,834.32	48	2	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount	465	17.86	20%	46425.6	\$6,267.46	\$300.00	\$600.00	4.46	11606.4	\$1,566.86	0.38
602		8760	5	2	Incandescent Exit Sign	20	0.1	876	\$118.26	5	0	No Change	20	0.10	0%	876	\$118.26	\$0.00	\$0.00	0.00	0	\$0.00	0.00




211.11		2600	4	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.132	343.2	\$46.33	4	0	No Change		33	0.13	0%	343.2	\$46.33	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.14	Locker Room Stairs (2)	4400	6	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.348	1531.2	\$206.71	6	0	No Change		58	0.35	0%	1531.2	\$206.71	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.14	Locker Room	2600	34	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	1.972	5127.2	\$692.17	34	2	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		58	1.58	20%	4101.76	\$553.74	\$300.00	\$600.00	0.39	1025.44	\$138.43	4.33
602		8760	2	2	Incandescent Exit Sign	20	0.04	350.4	\$47.30	2	0	No Change		20	0.04	0%	350.4	\$47.30	\$0.00	\$0.00	0.00	0	\$0.00	0.00
613		2600	9	1	Industrial Fixture, 100w A19 Lamp	100	0.9	2340	\$315.90	9	1	Dual Technology Occupancy Sensor - Remote Mnt.		100	0.72	20%	1872	\$252.72	\$250.00	\$250.00	0.18	468	\$63.18	3.96
211.14	Gym Office	2600	3	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.099	257.4	\$34.75	3	1	Dual Technology Occupancy Sensor - Switch Mnt.		33	0.08	20%	205.92	\$27.80	\$150.00	\$150.00	0.02	51.48	\$6.95	21.58
211.14	Gym Storage (2)	1200	28	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.924	1108.8	\$149.69	28	0	No Change		33	0.92	0%	1108.8	\$149.69	\$0.00	\$0.00	0.00	0	\$0.00	0.00
211.11	Boys' Restroom	2600	5	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.165	429	\$57.92	5	1	Dual Technology Occupancy Sensor - Switch Mnt.	not rebate eligible	33	0.13	20%	343.2	\$46.33	\$150.00	\$150.00	0.03	85.8	\$11.58	12.95
211.11	Girls' Restroom	2600	5	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.165	429	\$57.92	5	1	Dual Technology Occupancy Sensor - Switch Mnt.		33	0.13	20%	343.2	\$46.33	\$150.00	\$150.00	0.03	85.8	\$11.58	12.95
221.14	D101 Classroom	2600	34	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	1.972	5127.2	\$692.17	34	2	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		58	1.58	20%	4101.76	\$553.74	\$300.00	\$600.00	0.39	1025.44	\$138.43	4.33
221.14	D103 Classroom	2600	34	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	1.972	5127.2	\$692.17	34	2	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		58	1.58	20%	4101.76	\$553.74	\$300.00	\$600.00	0.39	1025.44	\$138.43	4.33
221.14	D105 Classroom	2600	42	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	2.436	6333.6	\$855.04	42	2	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		58	1.95	20%	5066.88	\$684.03	\$300.00	\$600.00	0.49	1266.72	\$171.01	3.51
766	Aux Gym	2600	12	1	400w MH, Prismatic Lens	465	5.58	14508	\$1,958.58	12	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		465	4.46	20%	11606.4	\$1,566.86	\$300.00	\$300.00	1.12	2901.6	\$391.72	0.77
222.21	AD Office	2600	10	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.62	1612	\$217.62	10	1	Dual Technology Occupancy Sensor - Remote Mnt.		62	0.50	20%	1289.6	\$174.10	\$250.00	\$250.00	0.12	322.4	\$43.52	5.74
221.34	Boys' Team Room	2600	21	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Pendant Mnt., No Lens	58	1.218	3166.8	\$427.52	21	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		58	0.97	20%	2533.44	\$342.01	\$300.00	\$300.00	0.24	633.36	\$85.50	3.51
602		8760	1	2	Incandescent Exit Sign	20	0.02	175.2	\$23.65	1	0	No Change		20	0.02	0%	175.2	\$23.65	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.34	Athletic Trainer	2600	5	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Pendant Mnt., No Lens	58	0.29	754	\$101.79	5	1	Dual Technology Occupancy Sensor - Switch Mnt.		58	0.23	20%	603.2	\$81.43	\$150.00	\$150.00	0.06	150.8	\$20.36	7.37
221.34	Girls' Team Room	2600	16	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Pendant Mnt., No Lens	58	0.928	2412.8	\$325.73	16	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		58	0.74	20%	1930.24	\$260.58	\$300.00	\$300.00	0.19	482.56	\$65.15	4.61
602		8760	1	2	Incandescent Exit Sign	20	0.02	175.2	\$23.65	1	0	No Change		20	0.02	0%	175.2	\$23.65	\$0.00	\$0.00	0.00	0	\$0.00	0.00

227.21	Weight Room Hall	2600	6	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.39	1014	\$136.89	6	0	No Change		65	0.39	0%	1014	\$136.89	\$0.00	\$0.00	0.00	0	\$0.00	0.00
602		8760	2	2	Incandescent Exit Sign	20	0.04	350.4	\$47.30	2	0	No Change		20	0.04	0%	350.4	\$47.30	\$0.00	\$0.00	0.00	0	\$0.00	0.00
242.31	Weight Room	2600	18	4	2x4, 4 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic	107	1.926	5007.6	\$676.03	18	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		107	1.54	20%	4006.08	\$540.82	\$300.00	\$300.00	0.39	1001.52	\$135.21	2.22
601		8760	2	2	(2) 7w CFL Exit Sign	16	0.032	280.32	\$37.84	2	0	No Change		16	0.03	0%	280.32	\$37.84	\$0.00	\$0.00	0.00	0	\$0.00	0.00
211.14	Maintenance	2600	19	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.627	1630.2	\$220.08	19	1	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		33	0.50	20%	1304.16	\$176.06	\$300.00	\$300.00	0.13	326.04	\$44.02	6.82
221.41	Maintenance Restroom	1200	1	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Wall Mnt., Prismatic	58	0.058	69.6	\$9.40	1	0	No Change		58	0.06	0%	69.6	\$9.40	\$0.00	\$0.00	0.00	0	\$0.00	0.00
222.21	Maintenance Office	2600	1	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.062	161.2	\$21.76	1	1	Dual Technology Occupancy Sensor - Switch Mnt.		62	0.05	20%	128.96	\$17.41	\$150.00	\$150.00	0.01	32.24	\$4.35	34.46
221.14	Maintenance Office	2600	2	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	58	0.116	301.6	\$40.72	2	1	Dual Technology Occupancy Sensor - Switch Mnt.		58	0.09	20%	241.28	\$32.57	\$150.00	\$150.00	0.02	60.32	\$8.14	18.42
221.34	Boiler Room	4400	15	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Pendant Mnt., No Lens	58	0.87	3828	\$516.78	15	0	No Change		58	0.87	0%	3828	\$516.78	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.34	Electrical Room	1200	8	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Pendant Mnt., No Lens	58	0.464	556.8	\$75.17	8	1	Dual Technology Occupancy Sensor - Switch Mnt.		58	0.37	20%	445.44	\$60.13	\$150.00	\$150.00	0.09	111.36	\$15.03	9.98
221.31	C103 Band	2600	49	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	62	3.038	7898.8	\$1,066.34	49	2	Dual Tech. Occupancy Sensor w/2 Pole Powerpack remote mount		62	2.43	20%	6319.04	\$853.07	\$300.00	\$600.00	0.61	1579.76	\$213.27	2.81
211.11	C103 Storage	1200	18	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.594	712.8	\$96.23	18	0	No Change		33	0.59	0%	712.8	\$96.23	\$0.00	\$0.00	0.00	0	\$0.00	0.00
211.11	Maintenance Storage	2600	21	1	1x4, 1 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	33	0.693	1801.8	\$243.24	21	0	No Change		33	0.69	0%	1801.8	\$243.24	\$0.00	\$0.00	0.00	0	\$0.00	0.00
750	Exterior	4400	29	1	250w HPS Wallpack	295	8.555	37642	\$5,081.67	29	0	No Change		295	8.56	0%	37642	\$5,081.67	\$0.00	\$0.00	0.00	0	\$0.00	0.00
710		4400	4	1	100w HPS Wallpack	125	0.5	2200	\$297.00	4	0	No Change		125	0.50	0%	2200	\$297.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
725		4400	22	1	150w HPS Wallpack	188	4.136	18198.4	\$2,456.78	22	0	No Change		188	4.14	0%	18198.4	\$2,456.78	\$0.00	\$0.00	0.00	0	\$0.00	0.00
767		4400	12	1	400w Probe Start MH "Shoebox" Parking Lot Light	460	5.52	24288	\$3,278.88	12	0	No Change		460	5.52	0%	24288	\$3,278.88	\$0.00	\$0.00	0.00	0	\$0.00	0.00
	Totals		2,898	456			226.1	620,579.7	\$83,778	2,898	164				195.0		\$40,229.6	\$72,930.99		\$41,800	31.10	80,350	\$10,847	3.85

Project Name: LGEA Solar PV Project - Highland HS							
Location: Blackwood, NJ							
Description: Photovoltaic System - Direct Purchase							
Simple Payback Analysis							
		Photovoltaic System - Direct Purchase					
Total Construction Cost		\$7,903,260					
Annual kWh Production		1,097,957					
Annual Energy Cost Reduction		\$148,224					
Annual SREC Revenue		\$384,285					
First Cost Premium		\$7,903,260					
Simple Payback:		14.84					Years
Life Cycle Cost Analysis							
Analysis Period (years):		25		Financing %:		0%	
Financing Term (mths):		0		Maintenance Escalation Rate:		3.0%	
Average Energy Cost (\$/kWh)		\$0.135		Energy Cost Escalation Rate:		3.0%	
Financing Rate:		0.00%		SREC Value (\$/kWh)		\$0.350	
Period	Additional Cash Outlay	Energy kWh Production	Energy Cost Savings	Additional Maint Costs	SREC Revenue	Net Cash Flow	Cumulative Cash Flow
0	\$7,903,260	0	0	0	\$0	(7,903,260)	0
1	\$0	1,097,957	\$148,224	\$0	\$384,285	\$532,509	(\$7,370,751)
2	\$0	1,092,467	\$152,671	\$0	\$382,364	\$535,034	(\$6,835,716)
3	\$0	1,087,005	\$157,251	\$0	\$380,452	\$537,703	(\$6,298,014)
4	\$0	1,081,570	\$161,969	\$0	\$378,549	\$540,518	(\$5,757,496)
5	\$0	1,076,162	\$166,828	\$11,084	\$376,657	\$532,400	(\$5,225,096)
6	\$0	1,070,781	\$171,832	\$11,029	\$374,773	\$535,577	(\$4,689,519)
7	\$0	1,065,427	\$176,987	\$10,974	\$372,900	\$538,913	(\$4,150,606)
8	\$0	1,060,100	\$182,297	\$10,919	\$371,035	\$542,413	(\$3,608,193)
9	\$0	1,054,800	\$187,766	\$10,864	\$369,180	\$546,081	(\$3,062,111)
10	\$0	1,049,526	\$193,399	\$10,810	\$367,334	\$549,923	(\$2,512,189)
11	\$0	1,044,278	\$199,201	\$10,756	\$365,497	\$553,942	(\$1,958,246)
12	\$0	1,039,057	\$205,177	\$10,702	\$363,670	\$558,144	(\$1,400,102)
13	\$0	1,033,861	\$211,332	\$10,649	\$361,851	\$562,535	(\$837,567)
14	\$0	1,028,692	\$217,672	\$10,596	\$360,042	\$567,119	(\$270,448)
15	\$0	1,023,549	\$224,202	\$10,543	\$358,242	\$571,902	\$301,454
16	\$0	1,018,431	\$230,928	\$10,490	\$356,451	\$576,889	\$878,343
17	\$0	1,013,339	\$237,856	\$10,437	\$354,669	\$582,087	\$1,460,431
18	\$0	1,008,272	\$244,992	\$10,385	\$352,895	\$587,502	\$2,047,933
19	\$0	1,003,231	\$252,342	\$10,333	\$351,131	\$593,139	\$2,641,072
20	\$0	998,214	\$259,912	\$10,282	\$349,375	\$599,005	\$3,240,077
21	\$1	993,223	\$267,709	\$10,230	\$347,628	\$605,107	\$3,845,185
22	\$2	988,257	\$275,741	\$10,179	\$345,890	\$611,452	\$4,456,637
23	\$3	983,316	\$284,013	\$10,128	\$344,161	\$618,045	\$5,074,682
24	\$4	978,399	\$292,533	\$10,078	\$342,440	\$624,896	\$5,699,577
25	\$5	973,507	\$301,309	\$10,027	\$340,728	\$632,010	\$6,331,587
Totals:		25,863,422	\$5,404,145	\$221,496	\$9,052,198	\$14,234,847	(\$17,999,075)
Net Present Value (NPV)						\$6,331,612	
Internal Rate of Return (IRR)						5.0%	

Building	Roof Area (sq ft)	Panel	Qty	Panel Sq Ft	Panel Total Sq Ft	Total KW <sub>DC</sub>	Total Annual kWh	Panel Weight (33 lbs)	W/SQFT
Highland HS	62378	Sunpower SPR230	3818	14.7	56,140	878.14	1,097,957	125,994	15.64



(Type comments here to appear on printout; maximum 1 row of 80 characters.)

Station Identification		Results			
City:	Atlantic City	Month	Solar Radiation (kWh/m <sup>2</sup> /day)	AC Energy (kWh)	Energy Value (\$)
State:	New Jersey				
Latitude:	39.45° N	1	3.61	78564	106.06
Longitude:	74.57° W	2	4.20	81822	110.46
Elevation:	20 m	3	4.78	98721	133.27
PV System Specifications		4	5.23	101383	136.87
DC Rating:	878.1 kW	5	5.44	106369	143.60
DC to AC Derate Factor:	0.770	6	5.48	99479	134.30
AC Rating:	676.2 kW	7	5.55	102860	138.86
Array Type:	Fixed Tilt	8	5.41	101427	136.93
Array Tilt:	39.5°	9	5.23	97121	131.11
Array Azimuth:	180.0°	10	4.60	90810	122.59
Energy Specifications		11	3.59	72104	97.34
Cost of Electricity:	0.1 \$/kWh	12	3.17	67299	90.85
		Year	4.69	1097957	1482.24

[Red Rectangle] = Proposed PV Layout

Notes:

1. Estimated kWh based on the National Renewable Energy Laboratory PVWatts Version 1 Calculator Program.



ENERGY CALCULATIONS - NATURAL GAS			
ECM INPUTS	EXISTING	PROPOSED	SAVINGS
ECM INPUTS	CAV System	VAV System	
Make up Air Unit Total Heating Energy (Therms)	1,365	1,010	
Boiler Efficiency (%)	74%	74%	
Heating Fuel Value	100,000	100,000	
Gas Cost (\$/Therm)	\$1.08	\$1.08	
ENERGY SAVINGS CALCULATIONS			
ECM RESULTS	EXISTING	PROPOSED	SAVINGS
Heating Energy, Therms	1,365	1,010	355
Heating Energy Cost (\$)	\$1,475	\$1,091	\$383
COMMENTS:			

ENERGY CALCULATIONS - ELECTRIC			
ECM INPUTS	EXISTING	PROPOSED	SAVINGS
ECM INPUTS	CAV System	VAV System	
Supply Fan HP	2	2	
Fan Energy, Annual kWh	2,652	1,314	
Electric Cost (\$/kWh)	\$0.135	\$0.135	
ENERGY SAVINGS CALCULATIONS			
ECM RESULTS	EXISTING	PROPOSED	SAVINGS
Fan Energy Annual kWh	2,652	1,314	1,339
Electric Energy Cost (\$)	\$358	\$177	\$181
COMMENTS:			