



**Steven Winter Associates, Inc.**  
Architects and Engineers

293 Route 18 South, Suite 330  
East Brunswick, NJ 08816  
[www.swinter.com](http://www.swinter.com)

Telephone: (866) 676-1972  
E-mail: [swinter@swinter.com](mailto:swinter@swinter.com)

*February 7, 2010*

**Local Government Energy Program  
Energy Audit Final Report**

*For*

***Livingston Riker Hill Elementary School  
Livingston, NJ 07039***

***Project Number: LGEA37***



## TABLE OF CONTENTS

<b>INTRODUCTION.....</b>	<b>3</b>
<b>EXECUTIVE SUMMARY.....</b>	<b>4</b>
<b>1. HISTORIC ENERGY CONSUMPTION.....</b>	<b>8</b>
1.1. ENERGY USAGE AND COST ANALYSIS .....	8
1.2. UTILITY RATE .....	10
1.3. ENERGY BENCHMARKING .....	11
<b>2. FACILITY AND SYSTEMS DESCRIPTION.....</b>	<b>13</b>
2.1. BUILDING CHARACTERISTICS .....	13
2.2. BUILDING OCCUPANCY PROFILES.....	13
2.3. BUILDING ENVELOPE.....	13
2.3.1. EXTERIOR WALLS .....	13
2.3.2. ROOF.....	14
2.3.3. BASE .....	15
2.3.4. WINDOWS .....	15
2.3.5. EXTERIOR DOORS .....	16
2.3.6. BUILDING AIR TIGHTNESS .....	16
2.4. HVAC SYSTEMS.....	16
2.4.1. HEATING.....	16
2.4.2. COOLING .....	18
2.4.3. VENTILATION.....	18
2.4.4. DOMESTIC HOT WATER.....	19
2.5. ELECTRICAL SYSTEMS .....	19
2.5.1. LIGHTING .....	19
2.5.2. APPLIANCES AND PROCESS .....	20
2.5.3. ELEVATORS.....	20
2.5.4. OTHERS ELECTRICAL SYSTEMS .....	20
<b>3. EQUIPMENT LIST .....</b>	<b>21</b>
<b>4. ENERGY CONSERVATION MEASURES .....</b>	<b>24</b>
<b>5. RENEWABLE AND DISTRIBUTED ENERGY MEASURES .....</b>	<b>45</b>
5.1. EXISTING SYSTEMS .....	45
5.2. WIND.....	45
5.3. SOLAR PHOTOVOLTAIC.....	45
5.4. SOLAR THERMAL COLLECTORS.....	45
5.5. COMBINED HEAT AND POWER.....	45
5.6. GEOTHERMAL .....	45
<b>6. ENERGY PURCHASING AND PROCUREMENT STRATEGIES.....</b>	<b>45</b>
6.1. LOAD PROFILES .....	45
6.2. TARIFF ANALYSIS.....	48
6.3. ENERGY PROCUREMENT STRATEGIES .....	48
<b>7. METHOD OF ANALYSIS .....</b>	<b>51</b>
7.1. ASSUMPTIONS AND TOOLS .....	51
7.2. DISCLAIMER.....	51
<b>APPENDIX A: LIGHTING STUDY .....</b>	<b>52</b>
<b>APPENDIX B: THIRD PARTY ENERGY SUPPLIERS (ESCOS) .....</b>	<b>55</b>

## INTRODUCTION

On October 13<sup>th</sup>, 15<sup>th</sup>, 16<sup>th</sup>, 20<sup>th</sup>, 21<sup>st</sup>, 22<sup>nd</sup>, 27<sup>th</sup> and 28<sup>th</sup> Steven Winter Associates, Inc. (SWA) performed an energy audit and assessment for the Livingston Public School buildings. The audit included a review of the:

- Administrative Offices
- Burnet Hill Elementary
- Collins Elementary
- Harrison Elementary
- Hillside Elementary
- Riker Hill Elementary
- Mount Pleasant Schools
- Heritage Middle School
- Livingston High School

The buildings are located in Livingston, NJ. A separate energy audit report is issued for each of the referenced buildings.

This report addresses the Livingston Riker Hill Elementary School building located at 31 Blackstone Drive, Livingston, NJ 07039. The current conditions and energy-related information were collected in order to analyze and facilitate the implementation of energy conservation measures for the building.

The single story Riker Hill Elementary School building was built in 1964 with renovations and additions in 1999 and 2002. It houses the school's administrative offices, classrooms, kindergarten, activity room, multipurpose room, media center, boiler and utility rooms. The building consists of 48,279 square feet of conditioned space. The building is occupied on weekdays by 57 teachers / staff employees and 403 students from 8:00 am to 2:30 pm with the YMCA running an afterschool program from 2:30 pm to 6:00pm and periodic evening meetings.

SWA was informed by the Livingston Board of Education that there is a plan for the Livingston Public Schools to upgrade the envelopes, interior spaces, mechanical and electrical systems, install photovoltaic systems and comply with ADA requirements, which will be presented in a two bond referendum for approval by the township voters on December 8, 2009.

The goal of this Local Government Energy Audit (LGEA) is to provide sufficient information to the Livingston Board of Education to make decisions regarding the implementation of the most appropriate and most cost effective energy conservation measures for the Riker Hill Elementary School building.

Launched in 2008, the LGEA Program provides subsidized energy audits for municipal and local government-owned facilities, including offices, courtrooms, town halls, police and fire stations, sanitation buildings, transportation structures, schools and community centers. The Program will subsidize 75% of the cost of the audit. If the net cost of the installed measures recommended by the audit, after applying eligible NJ SmartStart Buildings incentives, exceeds the remaining cost of the audit, then that additional 25% will also be paid by the program. The Board of Public Utilities (BPU's) Office of Clean Energy has assigned TRC Energy Services to administer the Program.

## EXECUTIVE SUMMARY

The energy audit performed by Steven Winter Associates (SWA) encompasses the Riker Hill Elementary School building located at 31 Blackstone Drive, Livingston, NJ 07039. The Riker Hill Elementary School building is a single story building with a floor area of 48,279 square feet. The original structure was built in 1964 with renovations and additions in 1999 and 2002.

Based on the field visits performed by the SWA staff on October 13<sup>th</sup>, 15<sup>th</sup>, 16<sup>th</sup>, 20<sup>th</sup>, 21<sup>st</sup>, 22<sup>nd</sup>, 27<sup>th</sup> and 28<sup>th</sup> and the results of a comprehensive energy analysis, this report describes the site's current conditions and recommendations for improvements. Suggestions for measures related to energy conservation and improved comfort are provided in the scope of work. Energy and resource savings are estimated for each measure that results in a reduction of heating, cooling, and electric usage.

From March 2008 to February 2009 the Riker Hill Elementary School building consumed 306,400 kWh or \$50,197 worth of electricity at an approximate rate of \$0.164/kWh and 26,821 therms or \$41,629 worth of natural gas at an approximate rate of \$1.552/therm. The joint energy consumption for the building, including both electricity and natural gas, was 3,728 MMBtu of energy that cost a total of \$91,826.

SWA has entered energy information about the Riker Hill Elementary School building in the U.S. Environmental Protection Agency's (EPA) *Energy Star Portfolio Manager* Energy benchmarking system. The building performance rating received is a score of 56 when compared to other buildings of its kind. This indicates that there are opportunities for the Riker Hill Elementary School building to decrease energy consumption (natural gas or electric use or a combination thereof) to reach a more favorable Energy Star benchmark rating. SWA encourages the Livingston Board of Education to continue entering utility data in *Energy Star Portfolio Manager* in order to track weather normalized source energy use over time.

The Site Energy Use Intensity is 79 kBtu/ft<sup>2</sup>yr compared to the national average of a school building consuming 84 kBtu/ft<sup>2</sup>yr. Implementing this report's recommendations will reduce use by approximately 50.9 kBtu/ft<sup>2</sup>yr, which when implemented would make the building energy consumption even. There may be procurement opportunities for the Riker Hill Elementary School to reduce annual utility costs, which are \$4,343 higher, when compared to the average estimated NJ commercial utility rates.

Based on the assessment of the Riker Hill Elementary School building, SWA has separated the recommendations into three categories (See Section 4 for more details). These are summarized as follows:

### **Category I Recommendations: Capital Improvement Measures**

- Replace unit ventilators
- Replace common area heating emitters
- Install a metal chimney liner
- Replace window air conditioners
- Upgrade Building Management System (BMS)
- Replace H&V unit serving the Multipurpose Room
- Replace H&V unit and return fan serving Activities Room
- Replace 85% efficiency DHW heater with 95% efficiency DHW heaters
- Replace windows
- Insulate exterior walls and roof
- Upgrade building per ADA requirements (to include a chair lift to / from the ground floor to the west wing level)
- Install premium motors when replacements are required

## Category II Recommendations: Operations and Maintenance

- Insulate boiler room and ceiling piping
- Check water levels in the expansion tanks
- Asbestos abatement
- Maintain roofs
- Maintain downspouts
- Provide weather stripping / air sealing, especially around window air conditioning units
- Repair / seal wall cracks and penetrations
- Provide water efficient fixtures and controls
- Use Energy Star labeled appliances
- Use smart power electric strips
- Create an energy educational program

## Category III Recommendations: Energy Conservation Measures - Upgrades with associated energy savings

At this time, SWA highly recommends a total of **4** Energy Conservation Measures (ECMs) for the Riker Hill Elementary School building that are summarized in the following Table 1. The total investment cost for these ECMs with incentives is **\$4,213**. SWA estimates a first year savings of **\$1,598** with a simple payback of **2.6 years**. SWA estimates that implementing the highly recommended ECMs will reduce the carbon footprint of the Riker Hill Elementary School building by **12,767 lbs of CO<sub>2</sub>**, which is equivalent to removing approximately 1 car from the roads each year or avoiding the need of 31 trees to absorb the annual CO<sub>2</sub> generated. SWA also recommends **2** ECM with a total first year savings of **\$839,679** that is summarized in Table 2 and **2** End of Life Cycle ECMs with a total first year savings of **\$23,980** that are summarized in Table 3.

There are various incentives that the Livingston Board of Education could apply for that could also help lower the cost of installing the ECMs. SWA recommends that the Livingston Board of Education apply for the NJ SmartStart program through the New Jersey Office of Clean Energy. This incentive can help provide technical assistance for the building in the implementation phase of any energy conservation project. A new NJ Clean Power program, Direct Install, to be rolled out soon, could also assist to cover 80% of the capital investment.

Renewable ECMs require application approval and negotiations with the utility and proof of performance. There is also a utility-sponsored loan program through PSE&G that would allow the building to pay for the installation of the PV system through a loan issued by PSE&G. When the Livingston Bond Proposal #2 referendum passes on December 2009, the state of NJ will aid the school by paying 40% of the debt service (interest and principal) for the PV system installation.

The following three tables summarize the proposed Energy Conservation Measures (ECM) and their economic relevance.

Table 1 - Highly Recommended 0-5 Year Payback ECMs																			
ECM #	ECM description	source	est. installed cost, \$	est. incentives, \$	net est. ECM cost with incentives, \$	kWh, 1st yr savings	kW, demand reduction/mo	therms, 1st yr savings	kBtu/sq ft, 1st yr savings	est. operating cost, 1st yr savings, \$	total 1st yr savings, \$	life of measure, yrs	est. lifetime energy cost savings, \$	simple payback, yrs	lifetime return on investment, %	annual return on investment, %	internal rate of return, %	net present value, \$	CO <sub>2</sub> reduced, lbs/yr
1	install Drinks / Snacks vending machine miser	www.usatech.com and established costs	279	none at this time	279	1,872	0.6	0	0.1	0	307	12	3,684	0.9	1220	102	110	2,777	2,565
2.1	replace (74) incandescent stage lamps with CFLs	RS Means, Lit Search, NJ Clean Energy Program	1,480	none at this time	1,480	2,826	0.9	0	0.2	70	533	7	3,244	2.8	152	22	30	1,844	3,872
2.2	install (6) six occupancy sensors	RS Means, Lit Search, NJ Clean Energy Program	1,320	120	1,200	2,555	0.8	0	0.2	0	419	12	5,028	2.9	319	27	34	2,971	3,500
3.1	replace (2) 5 Hp hot water circulator pump motors with Premium Efficiency	similar projects, DOE Motor Master + International	820	108	712	1,408	0.4	0	0.1	0	231	20	4,618	3.1	549	27	32	2,723	1,929
3.2	replace (2) 2 Hp hot water circulator pump motors with Premium Efficiency	similar projects, DOE Motor Master + International	650	108	542	658	0.2	0	0.0	0	108	20	2,158	5.0	298	15	19	1,063	901
	TOTALS		4,549	336	4,213	9,319	2.9	0	0.7	70	1,598	-	18,733	2.6	-	-	-	11,378	12,767

**Assumptions:** Discount Rate: 3% per DOE FEMP; Energy Price Escalation Rate: 0% per DOE FEMP Guidelines

**Note:** A 0.0 electrical demand reduction / month indicates that it is very low / negligible

Table 2 - Recommended 5-10 Year Payback ECMs																			
ECM #	ECM description	source	est. installed cost, \$	est. incentives, \$	net est. ECM cost with incentives, \$	kWh, 1st yr savings	kW, demand reduction/mo	therms, 1st yr savings	kBtu/sq ft, 1st yr savings	est. operating cost, 1st yr savings, \$	total 1st yr savings, \$	life of measure, yrs	est. lifetime energy cost savings, \$	simple payback, yrs	lifetime return on investment, %	annual return on investment, %	internal rate of return, %	net present value, \$	CO <sub>2</sub> reduced, lbs/yr
without additional state aid																			
4a	install 170 kW PV rooftop system with incentives	similar projects	1,319,000	0	1,319,000	193,078	170	N/A	13.6	0	147,465	25	791,621	8.9	91.7	3.7	8.1	614,797	264,517
renewable PV system below, with additional 40% state aid for debt service																			
4b	install 170 kW PV rooftop system with incentives	similar projects	1,319,000	527,600	791,400	193,078	170	N/A	13.6	0	147,465	25	791,621	5.4	219.5	8.8	17.2	1,142,397	264,517
5	retro commissioning	similar projects	48,279	none at this time	48,279	8,560	2.7	2,682	6.2	1,820	7,386	12	66,798	6.5	84	7	11	25,246	11,727
	<b>TOTALS</b>		<b>1,367,279</b>	<b>527,600</b>	<b>839,679</b>	<b>201,638</b>	<b>172.9</b>	<b>2,682</b>	<b>19.8</b>	<b>1,820</b>	<b>154,851</b>	<b>-</b>	<b>858,418</b>	<b>5.4</b>	<b>-</b>	<b>-</b>	<b>-</b>	<b>1,167,643</b>	<b>276,244</b>

Table 3 - Recommended End of Life Cycle ECMs																			
ECM #	ECM description	source	est. installed cost, \$	est. incentives, \$	net est. ECM cost with incentives, \$	kWh, 1st yr savings	kW, demand reduction/mo	therms, 1st yr savings	kBtu/sq ft, 1st yr savings	est. operating cost, 1st yr savings, \$	total 1st yr savings, \$	life of measure, yrs	est. lifetime energy cost savings, \$	simple payback, yrs	lifetime return on investment, %	annual return on investment, %	internal rate of return, %	net present value, \$	CO <sub>2</sub> reduced, lbs/yr
6	replace 5 exhaust fans with premium efficiency units	similar projects, DOE Motor Master + International	14,250	270	13,980	1,275	0.4	0	0.1	175	384	10	2,091	36.4	-73	-7	<0	-10,704	1,747
7	replace (1) reach-in stainless steel refrigerators with 42 cu ft Energy Star models	Energy Star purchasing and procurement site, similar projects	10,000	0	10,000	250	0.1	0	0.0	150	191	12	492	52.4	-77	-6	<0	-8,099	343
	<b>TOTALS</b>		<b>24,250</b>	<b>270</b>	<b>23,980</b>	<b>1,525</b>	<b>0.5</b>	<b>0</b>	<b>0.1</b>	<b>325</b>	<b>575</b>	<b>-</b>	<b>2,583</b>	<b>41.7</b>	<b>-</b>	<b>-</b>	<b>-</b>	<b>-18,802</b>	<b>2,089</b>



## 1. HISTORIC ENERGY CONSUMPTION


### 1.1. Energy usage and cost analysis

SWA analyzed utility bills from March 2007 through March 2009 that were received from the utility companies supplying the Riker Hill Elementary School building with electric and natural gas.

Electricity - The Riker Hill Elementary School building is currently served by one electric meter. The Riker Hill Elementary School building currently buys electricity from PSE&G at **an average rate of \$0.164/kWh** based on 12 months of utility bills from March 2008 to February 2009. The Riker Hill Elementary School building purchased **approximately 306,400kWh or \$50,197worth of electricity** in the previous year. The average monthly demand was 69 kW.


Natural gas - The Livingston Riker Hill Elementary School building is currently served by one meter for natural gas. The Livingston Riker Hill Elementary School building currently buys natural gas from PSE&G (supplied by the Hess Corporation) at **an average aggregated rate of \$1.552/therm** based on 12 months of utility bills for March 2008 to February 2009. The Livingston Riker Hill Elementary School building purchased **approximately 26,821 therms or \$41,629worth of natural gas** in the previous year.

The following chart shows electricity use for the Riker Hill Elementary School building based on utility bills for the 12 month period of March 2008 to February 2009.




The following chart shows the natural gas consumption for the Riker Hill Elementary School building based on natural gas bills for the 12 month period of March 2008 to February 2009.







The following chart shows combined natural gas and electric consumption in Btu/sq ft for the Riker Hill Elementary School building based on utility bills for the 12 month period of March 2008 to February 2009.



The following table and chart pies show energy use for the Riker Hill Elementary School building based on utility bills for the 12 month period of March 2008 to February 2009. Note electrical cost at \$48/MMBtu of energy is 3 times as expensive to use as natural gas at \$16/MMBtu.

2008 Annual Energy Consumption / Costs					
	MMBtu	% MMBtu	\$	% \$	\$/MMBtu
Electric Miscellaneous	243	7%	\$11,658	13%	48
Electric For Cooling	117	3%	\$5,636	6%	48
Electric For Heating	175	5%	\$8,388	9%	48
Lighting	511	14%	\$24,515	27%	48
Domestic Hot Water (Gas)	339	9%	\$5,260	6%	16
Building Space Heating	2,343	63%	\$36,369	40%	16
<b>Totals</b>	3,728	100%	\$91,826	100%	25
Total Electric Usage	1,046	28%	\$50,197	55%	48
Total Gas Usage	2,682	72%	\$41,629	45%	16
<b>Totals</b>	3,728	100%	\$91,826	100%	25



## 1.2. Utility rate

The Riker Hill Elementary School building currently purchases electricity from PSE&G at a general service market rate for electricity use (kWh) with a separate (kW) demand charge. The Riker Hill Elementary School building currently pays an average rate of approximately \$0.164/kWh based on the 12 months of utility bills of March 2008 to February 2009.

The Riker Hill Elementary School building currently purchases natural gas supply from the Hess Corporation at a general service market rate for natural gas (therms). PSE&G acts as the transport company. There is one gas meter that provides natural gas service to the Riker Hill Elementary School building currently. The average aggregated rate (supply and transport) for the meter is approximately \$1.552/therm based on 12 months of utility bills for March 2008 to February 2009.

Some of the minor unusual utility fluctuations that showed up for a couple of months on the utility bills may be due to adjustments between estimated and actual meter readings.

### 1.3. Energy benchmarking

SWA has entered energy information about the Riker Hill Elementary School building in the U.S. Environmental Protection Agency's (EPA) *Energy Star Portfolio Manager* Energy benchmarking system. The building performance rating received is a score of 56 when compared to other school buildings of its kind. This indicates that there are good opportunities for the Riker Hill Elementary School building to decrease energy (natural gas or electric use or a combination thereof) use to reach a more desirable Energy Star rating.

The Site Energy Use Intensity is 79 kBtu/sq ft yr compared to the national average of a School building consuming 84 kBtu/sq ft yr. Implementing this report's highly recommended Energy Conservations Measures (ECMs) will reduce use by approximately 0.7 kBtu/sqft yr, with an additional 19.8 kBtu/sq ft yr from the recommended ECMs, 0.1 kBtu/sq ft yr from the recommended End of Life Cycle ECMs, and 30.3 kBtu/sq ft yr from improved window and roof insulation upgrades. These recommendations could account for at least 50.9 kBtu/sq ft yr reduction, which when implemented would make the building energy consumption even better.

Per the LGEA program requirements, SWA has assisted the Livingston Board of Education to create an *Energy Star Portfolio Manager* account and share the Riker Hill Elementary School facilities information to allow future data to be added and tracked using the benchmarking tool. SWA has shared this Portfolio Manager site information with the Livingston Board of Education (user name: "livingstonboe", with same password administered by Steven K. Robinson, Business Administrator / Board Secretary - Livingston Public Schools) and TRC Energy Services (user name: TRC-LGEA).



# STATEMENT OF ENERGY PERFORMANCE

## Livingston BOE - Riker Hill Elementary

Building ID: 1877810

For 12-month Period Ending: December 31, 2008<sup>1</sup>

Date SEP becomes ineligible: N/A

Date SEP Generated: November 09, 2009

**Facility**

Livingston BOE - Riker Hill Elementary  
31 Blackstone Drive  
Livingston, NJ 07039

**Facility Owner**

N/A

**Primary Contact for this Facility**

N/A

Year Built: 1964

Gross Floor Area (ft<sup>2</sup>): 48,279Energy Performance Rating<sup>2</sup> (1-100): 56**Site Energy Use Summary<sup>3</sup>**

Electricity - Grid Purchase (kBtu)	1,044,345
Natural Gas (kBtu) <sup>4</sup>	2,779,873
Total Energy (kBtu)	3,824,218

**Energy Intensity<sup>5</sup>**

Site (kBtu/ft <sup>2</sup> /yr)	79
Source (kBtu/ft <sup>2</sup> /yr)	133

**Emissions (based on site energy use)**

Greenhouse Gas Emissions (MtCO <sub>2</sub> e/year)	307
---	-----

**Electric Distribution Utility**

Jersey Central Power &amp; Lt Co

**National Average Comparison**

National Average Site EUI	84
National Average Source EUI	140
% Difference from National Average Source EUI	-6%
Building Type	K-12 School

Stamp of Certifying Professional

Based on the conditions observed at the time of my visit to this building, I certify that the information contained within this statement is accurate.

**Meets Industry Standards<sup>6</sup> for Indoor Environmental Conditions:**

Ventilation for Acceptable Indoor Air Quality	N/A
Acceptable Thermal Environmental Conditions	N/A
Adequate Illumination	N/A

**Certifying Professional**

N/A

**Notes:**

1. Application for the ENERGY STAR must be submitted to EPA within 4 months of the Period Ending date. Award of the ENERGY STAR is not final until approval is received from EPA.
2. The EPA Energy Performance Rating is based on total source energy. A rating of 75 is the minimum to be eligible for the ENERGY STAR.
3. Values represent energy consumption, annualized to a 12-month period.
4. Natural Gas values in this form are converted to kBtu with adjustments made for elevation based on Facility zip code.
5. Values represent energy intensity, annualized to a 12-month period.
6. Based on Meeting ASHRAE Standard 62 for ventilation for acceptable indoor air quality, ASHRAE Standard 55 for thermal comfort, and IESNA Lighting Handbook for lighting quality.

The government estimates the average time needed to fill out this form is 6 hours (includes the time for entering energy data, PE facility inspection, and notarizing the SEP) and we become suggestions for reducing this burden. Send comments (including OMB control number) to the Director, Collection Strategies Division, U.S., EPA (2022), 1200 Pennsylvania Ave., NW, Washington, DC 20460.

EPA Form 5900-16

## 2. FACILITY AND SYSTEMS DESCRIPTION

### 2.1. Building Characteristics

The single story Riker Hill Elementary School building was originally built in 1964 with several additions built in 1999 and 2002. Currently the school consists of 48,279 square feet of conditioned space. Besides various types of classrooms and administrative offices, the building houses a multi-purpose room, an activity room and a media room.

### 2.2. Building occupancy profiles

Occupancy for the Riker Hill Elementary School building is approximately 403 students and 57 teachers and staff personnel. The school is in session from 8:00 am to 2:30 pm, while the YMCA afterschool program utilizes the building from 2:30 pm through 6:00 pm. During summer recess, approximately 30 part-time workers clean and perform annual maintenance on the building.

### 2.3. Building envelope

#### 2.3.1. Exterior Walls

The typical exterior wall system consists of a 4" brick veneer façade with either 8" or 12" CMU (Concrete Masonry Units). Interior wall finishes were a mix of painted concrete block and gypsum wall board. Exterior wall insulation levels could not be visually verified. It can be assumed, based on drawings there isn't any or little wall insulation on the 1964 section of the building.

During the next major construction, SWA recommends insulating the exterior walls of at least the original structure by adhering 2" polyiso boards (Polyisocyanurate) together with furring strips and gypsum wall boards to the inside of the painted CMU walls.



*Water infiltrated veneer caused by faulty flashing*

The above image shows damage to the exterior brick veneer due to uncontrolled roof water run-off. Noted in section 2.3.2, special attention should be given to roof drainage to avoid water damage to exterior wall assemblies. At the time of the audit the exterior walls appeared to be in age appropriate condition and there weren't other major visible issues such as cracked bricks or mortar joints.

Attention and maintenance should be given to these areas as water will find points of entry and cause future damage with freezing and thawing through the wintertime conditions.

### 2.3.2.Roof

The majority of the roof area is comprised of dark colored EPDM installed in 1989, 1992, and 2004. These roof sections are regularly maintained by a roofing contractor and due to the age of installation, SWA recommends replacement of the 1989 and 1992 roof sections.

The 1999 section of the building has the original built-up roof. The roofing tar used around the perimeter of the roof has melted due to high temperatures in gutters, onto exterior wall facades, and onto the walls in room 16. These areas need immediate attention and the roofing contractor should be responsible for extracting substances from the damaged areas.

Regular maintenance should be performed on all roof areas to prevent leaks such as the leak in classroom 16. SWA recommends replacement of the 1989 and 1992 roof sections with an Energy Star certified membrane and insulation (3" rigid) assembly.



*Roof tar melting on exterior and interior of building*



*Built up roof area showing tar run-off into and behind gutters*



SWA detected approximately 3.5” batt insulation in a plenum above the dropped ceiling throughout the building. The 1999 roof sections of the building include 2” of rigid insulation below the built up roof.

### **2.3.3.Base**

The building’s base is a 4” concrete slab-on grade with a perimeter footing and concrete block or poured concrete stem walls. No water seepage through the slab or other issues related to thermal performance was detected.

### **2.3.4.Windows**

Most of the building’s windows are original, aluminum, single glazed and in need of replacement. Due to the fact that the windows are non-thermal break single glazed with un-insulated panels above them, they are extremely energy inefficient. The building also contains some double glazed windows found to be in good condition.



*Older windows showing cracked and damaged caulk*



*Older aluminum window wall section*





*1999 building section with new windows*

SWA recommends replacing approximately 221 windows with double-glazed thermal break low-E aluminum framed windows. Regular maintenance should be performed, re-caulking around the perimeter of windows (exterior and interior) to ensure a tight air seal. Additionally, window AC units should be removed for winter conditions. If removal of these units is not feasible, SWA recommends airtight covers such as Chill Stop-R or a gasketed cover for optimal performance.

#### **2.3.5.Exterior doors**

The aluminum and vinyl exterior doors were inspected and observed to be in good condition except for some weather-stripping that started to show wear and tear at the time of the inspection. SWA recommends that the exterior doors of the building be weather-stripped in order to decrease the amount of conditioned air that is lost around each door. SWA also recommends checking the weather-stripping of each door on a regular basis and replacing any broken seals. Tight seals around doors will help ensure the building to be is kept continuously insulated.

#### **2.3.6.Building air tightness**

In addition to the above mentioned recommendations SWA suggests air sealing, caulking and/ or insulating around all plumbing, electrical, HVAC and structural envelope penetrations. This should include bottom and top plates, recessed light fixtures, electrical boxes, chimney walls and window, or sleeve air conditioner units. Special care and attention should be made to avoid the disturbance of asbestos throughout the building. SWA recommends removal of all asbestos-like material before air sealing the building.

### **2.4. HVAC Systems**

Riker Hill Elementary School is heated by a hot water system. All of the heating is provided by four (4) hot water boilers in the Boiler Room of the original building.

#### **2.4.1.Heating**

The original portion of the building and the early additions contain hot water heating terminal units in the form of unit ventilators in the classrooms, enclosed wall mounted and ceiling mounted finned tube radiation in the corridors, vestibules, toilet rooms. In total, these portions of the school contain approximately twenty two (22) AAF / Herman Nelson unit ventilators. With a few exceptions, most

unit ventilators look to be the same age as the wing of the building where they are located. This equipment is in fair to poor condition and SWA recommends that these units be replaced as part of a capital improvement project. The Multipurpose Room and Activities Room are heated by large air handlers each with a return fan in the basement below the Activities Room. These air handlers are original and appear to be in fair to good condition. The heating water pumps supply hot water for the original school. The two (2) base-mounted supply circulating pumps are located in the Boiler Room.

The 1999 additions contain hot water heating via Airedale Graduate floor mounted vertical unit ventilators or Airedale ceiling cassette type units in the SGI's, with remote condensing units. Similar to the older portions of the building, the additions are also served by enclosed wall mounted and ceiling mounted finned tube radiation in the corridors, vestibules, toilet rooms. There is also an Airedale graduate unit in the Computer Room. There are a total of five (5) vertical Airedale units and six (6) ceiling cassette style units. The heating water is pumped out to the additions by two (2) supply circulating pumps located at the ceiling of the Boiler Room.

Each unit ventilator contains a heating coil, fan assembly, damper, filter and controls within a metal cabinet. It is the intent of the equipment that it should introduce outdoor air via a grille and damper located on the outside wall. The units are designed to mix room air with outside air, condition the air as required, and delivered to the occupied space. The older wall mounted AAF / Herman Nelson unit ventilators deliver the air directly through a grille on the top of the unit. The Airedale units are ducted out the top of the equipment and discharged at the ceiling.

The heating hot water is produced by four (4) Raypak atmospheric boilers of equal capacity located in the boiler room. The boilers were installed in year 1999 approximately. According to their age, the boilers have about 20 years remaining on their expected service life of 30 years, as published in the 2007 ASHRAE HVAC Applications Handbook. The burners are integral to the boilers.



*Boilers*

It is assumed that the circulating pumps were installed as part of the 1999 installation of the boilers. The pump motors are about half way through their expected service life of 20 years. SWA recommends that the pumps are replaced with new pumps with premium efficiency motors.

The building contains a Johnson Controls Metasys EMS system to monitor the older equipment and control the newer equipment, which can communicate with the district-wide EMS system.

There weren't any complaints about the ability of the heating system to provide adequate heating to the building occupants. It was also observed that the air compressor serving the pneumatic controls system runs often. The expected service life of a pneumatic controls system is 20 years per 2007 ASHRAE HVAC Applications Handbook. Based on these facts, SWA recommends that the pneumatic controls system is replaced with an electronic controls system, including thermostats to control the hot water valves at the unit ventilators and the equipment in the boiler room and the remainder of the school. The new controls in the building should be an extension of the existing Johnson Controls Metasys EMS system.

#### **2.4.2. Cooling**

The majority of the cooling in the original and all early additions to the building is in the form of window air conditioning units in several of the classrooms and offices. According to the head custodian, most of the window air conditioning units are 1-5 years old, and they appear to be in operating condition. The Principal's Office no longer has a window air conditioner, which was removed due to noise, discomfort, and the desire of the occupant to have the use of the operable window restored.



*Typical Classroom Window Air Conditioning Unit*

The classrooms in the 1999 additions are cooled by self-contained DX cooling within the Airedale Graduate unit ventilators mentioned in the heating section above. The Airedale units reject heat via a wall plenum and louver that penetrates the outside wall. The SGI's contain split system condensing units outside with a ceiling cassette evaporator fan coil unit above the ceiling inside. The Airedale units are approximately 10 years old and are about two thirds of the way through their expected service life of 15 years.

#### **2.4.3. Ventilation**

As mentioned above, the grilles on the AAF / Herman Nelson unit ventilators provide fresh air to the occupied space. SWA recommends that this equipment is replaced as part of a capital improvement project, and that the new equipment is provided with a means of providing a code compliant level of outside air to the spaces.

The wall plenum and louver attached to the Airedale Graduate units also provide ventilation to the occupied spaces. The ventilation air to the cassette units appears to be provided through roof inlets. This equipment appears to be performing adequately.

The Multipurpose Room and Activities Room are ventilated by large air handlers, each with a return fan in the basement below the Activities Room.

The building has a number of exhaust fans that do not operate. SWA recommends that this equipment is replaced as part of an End of Life ECM#6, and that it is designed to provide code minimum ventilation rates.

#### **2.4.4.Domestic Hot Water**

The hot water boilers produce domestic hot water during the winter months.

There is one (1) gas fired floor-mounted Burkey type domestic water heater located in the boiler room that produces the domestic hot water in the summer months. The water heater utilizes an external storage tank and one (1) booster-type circulating pump. The heater was installed in 2003 and is in relatively good condition (it appears to have been a replacement for one similar that was originally installed). Based on the age and expected service life of 10-15 years, the Livingston Public Schools may wish to keep this heater until it is in need of replacement, and then replace it with a more efficient heater as part of a capital improvement plan and maintain use of the existing storage tank. The associated pumps appear to be operating adequately and are fractional horsepower, so replacement would not yield significant energy savings.



*Domestic Water Storage Tank with Expansion Tanks Above*

### **2.5. Electrical systems**

#### **2.5.1.Lighting**

*Interior Lighting* - The Riker Hill Elementary School building currently consists of mostly T8 fluorescent fixtures with electronic ballasts. Based on measurements of lighting levels for each space, there are not any vastly over-illuminated areas. SWA recommends installing occupancy sensors in bathrooms, closets, offices and areas that are occupied only part of the day and payback on savings are justified. Typically, occupancy sensors have an adjustable time delay that shuts down the lights automatically if no motion or sound is detected within a set time period. SWA recommends replacing

the Stage incandescent lamps with CFLs. See attached lighting schedule in Appendix A for a complete inventory of lighting throughout the building and estimated power consumption.

*Exit Lights* - Exit signs were found to be LED type.

*Exterior Lighting* - The exterior lighting surveyed during the building audit was found to be a mix of Metal Halide, High Pressure Sodium and CFL fixtures. Exterior lighting is controlled by astronomical timers. SWA does not recommend replacing this safety and security lighting at this time. Also, SWA is not recommending any upgrades to the exterior timers.

### **2.5.2.Appliances and process**

Appliances, such as refrigerators, that are over 10 years of age should be replaced with newer efficient models with the Energy Star label. For example, Energy Star refrigerators use as little as 315 kWh / yr. When compared to the average electrical consumption of older equipment, Energy Star equipment results in a large savings. Building management should select Energy Star label appliances and equipment when replacing: refrigerators, printers, computers, copy machines, etc. More information can be found in the “Products” section of the Energy Star website at: <http://www.energystar.gov>. Also, energy vending miser devices are now available for conserving energy usage by Drinks and Snacks vending machines. When equipped with the vending miser devices, vending machines use less energy and are comparable in daily energy performance to new ENERGY STAR qualified machines.

Computers left on in the building consume a lot of energy. A typical desk top computer uses 65 to 250 watts and uses the same amount of energy when the screen saver is left on. Televisions in meeting areas use approximately 3-5 watts of electricity when turned off. SWA recommends all computers and all appliances (i.e. fridges, coffee makers, televisions, etc) be plugged in to power strips and turned off each evening just as the lights are turned off. The Livingston Riker Hill Elementary School building computers are generally programmed for the power save mode, to shut down after a period of time that they have not been used.

### **Commercial Kitchen Equipment**

There is an electric reach-in commercial refrigeration unit located in the kitchen that is of unknown age, but appears to be in poor condition. SWA recommends that the unit is replaced based on potential energy savings.

### **2.5.3.Elevators**

The Riker Hill Elementary School building does not have any installed elevators. Under consideration is a chair lift to / from the ground floor to the west wing level.

### **2.5.4.Others electrical systems**

There are not currently any other significant energy impacting electrical systems installed at the Riker Hill Elementary School building.

### 3. EQUIPMENT LIST

#### Inventory

Building System	Description	Location	Model #	Fuel	Space Served	Year Installed	Estimated Remaining Useful Life %
Heating	(4) boilers, Hot water	Boiler Room	Raypak Model H31826 boiler 1,826 MBH input, 1,497 MBH output	Natural Gas	Building	1999	65%
Heating	(22) hot water unit ventilators	Class-rooms & Offices	Herman-Nelson (nameplate not accessible during survey)	Electric	classrooms & offices	circa 1965	0%, beyond expected useful life
Heating	(4) circulator pumps to boilers	Boiler Room	Grundfos (nameplate information not available at time of survey)	Electric	Building	1999	50%
Domestic hot water	Burkay hot water heater (summertime switch-over)	Boiler Room	A.O. Smith M# HW-160M 942	Natural Gas	Building (summer)	2003	50%
Heating	(2) Hot water supply pumps	Boiler Room	Bell & Gossett M# 1531 5 HP ea.	Electric	Addition	1999	50%
Heating	(2) Hot water supply pumps	Boiler Room	Bell & Gossett 2 HP ea.	Electric	Building	unknown	Est. 50%
Domestic hot water	Pump - domestic hot water	Boiler Room	unknown (illegible) < 1 HP	Electric	Building	unknown	Est. 50%
Heating	Pneumatic Controls	Boiler Room	Compressed Air Dayton M# 2N980G 3/4 HP	Electric	Building	circa 1965	0%, beyond expected useful life
Heating / Cooling	(5) Cassette Unit Ventilators w/ condensing units on grade	Ceiling / Grade	Airedale Cond. Units M# SCC24DFA0A0AA0A	Electric	Classroom addition	2002	65%

continued on the next page

continued from the previous page							
Building System	Description	Location	Model #	Fuel	Space Served	Year Installed	Estimated Remaining Useful Life %
Heating / Cooling	(3) self contained unit ventilators	Class-room addition, corner rooms	Airedale	Electric	Classroom addition (3) corner rooms	2002	65%
Heating / Cooling	(1) self contained unit ventilator	Kindergarten addition	Airedale	Electric	Kindergarten room	2002	65%
Heating / Cooling	(1) Cassette Unit Ventilator w/ condensing unit on grade	Music room addition	Airedale Cond. Unit M# SCC24DFA0A0AA0A	Electric	Music room (being used as conference room)	2002	65%
Heating / Cooling	(1) self contained unit ventilators	Computer room	Airedale	Electric	Computer room	2002	65%
Domestic hot water	Domestic hot water heating pump	Boiler Room	Bell & Gossett Series 100AB < 1 HP	Electric	Building	unknown	Est. 50%
Cooling	(11) window AC units throughout the building	Offices, classrooms	Varies, approx. 1-2 tons each	Electric	8-10 Classrooms & offices	Varies	varies, estimating 50%
Heating	Radiator: Finned tube	Classrooms, activity rm	Unknown	Electric	classrooms, activity room	circa 1965	0%, beyond expected useful life
Ventilation	(22) Rooftop exhaust fans; for general, toilet and kitchen exhaust	Roof	Varies	Electric	Varies	Varies	0-50%
Heating	(2) Cabinet unit heaters	Ceiling of hallways	Unknown	Electric	hallways	circa 1965	0%, beyond expected useful life
Heating	HV unit	Under stage/ activity room	illegible	Electric	multi-purpose room	circa 1964	0%, beyond expected useful life
continued on the next page							



continued from the previous page							
Building System	Description	Location	Model #	Fuel	Space Served	Year Installed	Estimated Remaining Useful Life %
Heating	HV unit	Under stage/ activity room	illegible	Electric	Activities room	circa 1964	0%, beyond expected useful life
Refrigerator	Reach-in stainless steel refrigerator	Kitchen	Traulsen	Electric	Kitchen	unknown	Est. 5%
Lighting	See details - Appendix A	Building	-	Electric	Building	varies	varies, average 60%

**Note:** The remaining useful life of a system (in %) is an estimate based on the system date of built and existing conditions derived from visual inspection.

#### 4. ENERGY CONSERVATION MEASURES

Based on the assessment of the Livingston Riker Hill Elementary School, SWA has separated the investment opportunities into three recommended categories:

1. Capital Improvements - Upgrades not directly associated with energy savings
2. Operations and Maintenance - Low Cost / No Cost Measures
3. Energy Conservation Measures - Higher cost upgrades with associated energy savings

##### **Category I Recommendations: Capital Improvements**

- Replace unit ventilators - The 22 AAF / Herman Nelson unit ventilators originally installed in the 1964 classrooms and offices are well beyond their expected service life. Considering the increased maintenance repair costs and that replacement parts are difficult to find, SWA recommends replacement of this equipment. There is better control offered by the newer, electronically controlled units, although energy savings are negligible.

The 22 AAF / Herman Nelson unit ventilators are operating beyond their useful operating lives. SWA evaluated replacement of all 22 units with new. The updated fan coils should be double inlet, forward curved of centrifugal variety; have a maximum speed of 1,000 rpm with permanent split capacitor motors. The fan housing should be constructed of heavy gauge metal to help reduce air noise during operation. Wheel motors are to be premium efficiency, single speed, permanent split capacitor with overload protection. Each fan should be equipped with a three speed switch for air balancing. An ultra-low leak, blade type outside air damper will ensure low leakage of the outside air when the equipment is not operating. The unit shall have a solid-state defrost control system and two separate filters. The provided air-to-air heat exchanger should be designed to support two air streams in a counter-flow direction. The heat exchanger matrix shall permit less than one percent of cross contamination between the air streams. The heat exchanger shall have an effectiveness of approximately 80% with equal airflow. The proposed unit will not be that much more energy efficient than the existing unit. The estimated budget installed cost of a 22 new fan coil ventilators is \$190,000. The recommended enhancements over the replacement in kind (with pneumatic controlled units) will offer negligible energy savings.

The Livingston Public Schools may wish to consider adding DX cooling as part of the equipment replacement as seen in the later additions to the school. In this case, it should be recognized that cooling will result in an increase in energy usage versus providing heating and ventilation only.

- Replace H&V unit and return fan serving Multipurpose Room - The heating only hot water ventilation system for the Multipurpose Room is operating beyond its expected service life. SWA recommends that this equipment is replaced in kind or with rooftop equipment as part of a capital improvement project, and that it is designed to provide code minimum ventilation rates. The Livingston Public Schools may wish to consider providing DX cooling as part of this system to make the room more functional in warm weather, but should recognize that this will increase energy usage versus providing a heating and ventilation system only. If cooling is desired, it is strongly recommended that a system is provided that utilizes a heat recovery wheel for pretreatment of the outside air. This is a replacement in kind recommendation which offers negligible energy savings.
- Replace H&V unit and return fan serving Activities Room - The heating only hot water ventilation system for the Activities Room is beyond its expected service life. SWA recommends that this equipment is replaced in kind or with rooftop equipment as part of a capital improvement project, and that it is designed to provide code minimum ventilation rates. The Livingston Public Schools may wish to consider

providing DX cooling as part of this system to make the room more functional in warm weather, but should recognize that this will increase energy usage versus providing a heating and ventilation system only. If cooling is desired, it is strongly recommended that a system is provided that utilizes a heat recovery wheel for pretreatment of the outside air. This is a replacement in kind recommendation which offers negligible energy savings.

- Replace common area heating emitters - such as finned tube radiation and cabinet unit heaters in the toilet rooms, vestibules and corridors. This equipment is in fair condition, but age and wear have reduced the heat transfer capacity. This equipment should be replaced with more modern equipment suited for the intended use. These changes cannot be justified based on energy savings alone. However, replacement is strongly recommended along with upgrades to other portions of the heating system. This is a replacement in kind recommendation which offers negligible energy savings.
- Install a metal chimney liner - to the existing chimney to ensure that the products of combustion do not inadvertently reenter the building. This upgrade will not result in energy savings but addresses a potential safety issue within the building. This upgrade can be made as part of a capital improvement project within the Livingston Public Schools.
- Replace window air conditioners - The existing window air conditioners and ceiling cassette type split systems still have some useful life remaining (on the average 5-10 years left) but replacement should be considered with more modern and energy efficient systems. The window air conditioners should be replaced with split systems to allow for closing up of the existing window penetrations. These upgrades cannot be justified by energy savings alone but will result in a decrease in energy usage versus the existing equipment. In addition, several of the existing systems utilize R-22 refrigerant, which is not an ozone-friendly refrigerant. Newer systems should be specified with R-410A refrigerant.
- Upgrade Building Management System (BMS) - Currently, the building is controlled by an antiquated, pneumatic temperature control system and only monitored and partly controlled (1999 and 2002 equipment) by a more modern Direct Digital Control (DDC) system. The digital BMS should be expanded and upgraded to control the new unit ventilators and other equipment replaced as part of the capital improvement recommendations. This upgrade will result in energy savings via improved temperature control and by the elimination of the air compressor. This recommendation will ensure that the retro-commissioning estimated savings (per ECM#5) are maintained and reproducible.
- Replace 85% efficiency DHW heater with 95% efficiency DHW heaters - There is one (1) gas fired floor-mounted domestic water heater located in the boiler room that produces the domestic hot water when the boilers are down. The water heater utilizes an external storage tank and one (1) fractional horsepower recirculating pump. The heater is in relatively good condition and was installed in 2003. Based on the age and expected service life of 10-15 years, the Livingston Public Schools may wish to replace this heater with two (2) more efficient, ASME-rated heaters and remove or disconnect the storage tank as part of a capital improvement plan. Aside from the higher efficiency of the heaters, there should be a savings due to reduced standby losses compared to the current insulated storage tanks. The estimated installed cost to make this change is \$13,200 (with incentives) based on similar projects, which would provide \$404 annual energy savings and a 33 year simple payback, which could reduce the building's energy requirements by at least 0.5 kBtu/sq ft yr. The associated pump appears to be operating adequately and replacement of the pump motor with a premium-efficiency motor would yield negligible savings.
- Replace windows - SWA evaluated, as part of a capital improvement plan, replacing approximately 221 single-pane windows with newer models with thermal breaks, dual glazing and a low-e rating. Proper flashing and caulking should be performed upon installation of the new windows.

Part of the building contains double glazed windows found to be in good condition. Sections of the building contain approximately 221 single-pane fixed and casement aluminum-framed windows with single-glazing. These windows appear to be original to the building. In context of other energy measures proposed in this report and in an effort to maximize the cost-benefit factor for improvements, SWA recommends that these 221 windows be replaced with the next major capital improvement / renovation project. Windows considered for replacement should have the following outline specifications besides conforming to local code and regulations: the windows shall be aluminum frame thermally manufactured as double hung commercial type modules. The clear, low-e, argon filled dual glazing should be 2 independent panes. The walls should be extruded aluminum with integral poured-in-place thermal barrier. All horizontal rails should be of tubular shape and joinery should be butted and coped with stainless steel screws. Air infiltration shall not exceed 0.10 cfm/sf of unit. The conductive thermal transmittance (U-Value) shall not be more than 0.51 Btu/hr sq ft °F.

An E-Quest model was performed to estimate energy savings with the new proposed windows. The assumptions made in the E-Quest model were that existing window U-Value is 1.09 Btu/hr sq ft °F vs. the improved thermally insulated window U-Value of 0.51 Btu/hr sq ft °F. The installed cost of approximately 221 replacement school building window units of the type outlined above is estimated to cost \$442,000, based on RS Means 2009 (Building Construction Cost Data) and similar projects, which would provide \$7,117 annual energy savings and a 62 year simple payback, which could reduce the building's energy requirements by at least 6.3 kBtu/sq ft yr. The Livingston Public Schools are eligible for a 40% state grant, which will decrease the new windows simple payback to 37 years when the December bond referendum passes. Window replacement rebates and tax incentives are available only for residential buildings at this time. This investment cannot be justified by energy savings alone and should be considered as part of a major renovation plan.

In the meanwhile, operable commercial grade blinds for more glair and thermal control can be an economical solution throughout the building where necessary, while selected window films are only effective on thermally manufactured window frames or tight vinyl frames.

- Insulate exterior walls and roof - During the next major construction, SWA recommends insulating the exterior walls of at least the original structure by adhering 2" polyiso boards (Polyisocyanurate) together with furring strips and gypsum wall boards to the inside of the painted CMU walls.

SWA recommends adding 10" of fiberglass insulation at the interior or 3" exterior XPS during future reroofing. SWA also recommends the EPDM areas of the roof to be replaced due to age and condition. Cracked seams were detected and overall it looks that the roof has reached its expectant life span. SWA recommends replacement of the 1989 and 1992 roof sections with an Energy Star certified membrane and insulation (3" rigid) assembly. Maintenance should be performed at regular intervals with a roofing contractor to prevent future roof leaks. It is also advisable to upgrade any questionable roof integrity areas before photovoltaics are installed, as any repairs after the system is installed will be costly.

An E-Quest model was performed to estimate energy savings with the new proposed roof. The assumptions made in the E-Quest model were that the existing roof U-Value is 0.475 Btu/hr sq ft °F vs. the new EPDM - 3" XPS insulated roof U-Value of 0.069 Btu/hr sq ft °F. The estimated 41,627 sq ft insulated roof replacement cost is approximately \$416,270, based on RS Means 2009 (Building Construction Cost Data) and similar projects, which would provide \$17,960 annual energy savings and a 23 year simple payback, which could reduce the building's energy requirements by at least 24

kBtu/sq ft yr. The Livingston Public Schools are eligible for a 40% state grant, which will decrease the new roof simple payback to 14 years when the December bond referendum passes.

- Upgrade building per ADA requirements - SWA recommends that the Livingston Board of Education do as much as possible to comply with the latest ADA regulations.
- Install premium motors when replacements are required - Select NEMA Premium motors when replacing motors that have reached the end of their useful operating lives.

## **Category II Recommendations: Operations and Maintenance**

- Boiler room and ceiling piping insulation - Insulate un-insulated hot water piping to efficiently deliver heat where required and provide personnel protection.
- Check water levels in the expansion tanks and the integrity of the tank bladder to confirm proper operation.
- Asbestos abatement - Abate asbestos insulating old piping and other building systems per local codes and regulations.
- Maintain roofs - SWA recommends regular maintenance to verify water is draining correctly.
- Maintain downspouts - Repair / install missing downspouts as needed to prevent water / moisture infiltration and insulation damage.
- Provide weather stripping / air sealing - SWA observed that exterior door weather-stripping in places was beginning to deteriorate. Doors and vestibules should be observed annually for deficient weather-stripping and replaced as needed. The perimeter of all window frames should also be regularly inspected and any missing or deteriorated caulking should be re-caulked to provide an unbroken seal around the window frames. Any other accessible gaps or penetrations in the thermal envelope penetrations should also be sealed with caulk or spray foam.
- Repair / seal wall cracks and penetrations - SWA recommends as part of the maintenance program to install weep holes, install proper flashing, correct masonry efflorescence and seal wall cracks and penetrations wherever necessary in order to keep insulation dry and effective.
- Provide water efficient fixtures and controls - Adding controlled on / off timers on all lavatory faucets is a cost-effective way to reduce domestic hot water demand and save water. Building staff can also easily install faucet aerators and / or low-flow fixtures to reduce water consumption. There are many retrofit options, which can be installed now or incorporated as equipment is replaced. Routine maintenance practices that identify and quickly address water leaks are a low-cost way to save water and energy. Retrofitting with more efficient water-consumption fixtures / appliances will save both energy and money through reduced energy consumption for water heating, while also decreasing water / sewer bills
- Use Energy Star labeled appliances - such as Energy Star refrigerators that should replace older energy inefficient equipment.
- Use smart power electric strips - in conjunction with occupancy sensors to power down computer equipment when left unattended for extended periods of time.

- Create an energy educational program - that teaches how to minimize their energy use. The US Department of Energy offers free information for hosting energy efficiency educational programs and plans, for more information please visit: <http://www1.eere.energy.gov/education/>

### Category III Recommendations: Energy Conservation Measures

#### Summary table

ECM#	Description of Highly Recommended 0-5 Year Payback ECMs
1	install vending misers on Drinks / Snacks vending machine
2.1 & 2.2	replace incandescent lamps with CFLs and install occupancy sensors
3.1 & 3.2	install Premium Efficiency motors on heating / hot water circulators
	Description of Recommended 5-10 Year Payback ECMs
4	install 170 kW PV rooftop system
5	retro-commission mechanical equipment
	Description of Recommended End of Life Cycle ECMs
6	replace exhaust fans with premium efficiency units
7	replace old commercial refrigerator with an Energy Star model

### ECM#1: *Install Vending Miser*

#### Description:

The Riker Hill Elementary School building has one Drinks / Snacks vending machines. Energy vending miser devices are now available for conserving energy with these vending machines. There isn't a need to purchase new machines to reduce operating costs and greenhouse gas emissions. When equipped with the vending miser devices, refrigerated beverage vending machines use less energy and are comparable in daily energy performance to new ENERGY STAR qualified machines. Vending miser devices incorporate innovative energy-saving technology into small plug-and-play devices that installs in minutes, either on the wall or on the vending machine. Vending miser devices use a Passive Infrared Sensor (PIR) to: Power down the machine when the surrounding area is vacant; Monitor the room's temperature; Automatically repower the cooling system at one- to three-hour intervals, independent of sales; Ensure the product stays cold.

Snacks vending miser devices can be used on Snacks vending machines to achieve maximum energy savings that result in reduced operating costs and decreased greenhouse gas emissions with existing machines. Snacks vending miser devices also use a Passive Infrared Sensor (PIR) to determine if there is anyone within 25 feet of the machine. It waits for 15 minutes of vacancy, then powers down the machine. If a customer approaches the machine while powered down, the snacks vending miser will sense the presence and immediately power up.

#### Installation cost:

Estimated installed cost: \$279

Source of cost estimate: [www.usatech.com](http://www.usatech.com) and established costs

#### Economics (without incentives):

ECM #	ECM description	source	est. installed cost, \$	est. incentives, \$	net est. ECM cost with incentives, \$	kWh, 1st yr savings	kW, demand reduction/mo	therms, 1st yr savings	kBtu/sq ft, 1st yr savings	est. operating cost, 1st yr savings, \$	total 1st yr savings, \$	life of measure, yrs	est. lifetime energy cost savings, \$	simple payback, yrs	lifetime return on investment, %	annual return on investment, %	internal rate of return, %	net present value, \$	CO <sub>2</sub> reduced, lbs/yr
1	install Drinks / Snacks vending machine miser	<a href="http://www.usatech.com">www.usatech.com</a> and established costs	279	none at this time	279	1,872	0.6	0	0.1	0	307	12	3,684	0.9	1220	102	110	2,777	2,565



**Assumptions:** SWA assumes energy savings based modeling calculator found at [www.usatech.com](http://www.usatech.com)  
or [http://www.usatech.com/energy\\_management/energy\\_calculator.php](http://www.usatech.com/energy_management/energy_calculator.php)

**Rebates/financial incentives:**

*This measure does not qualify for a rebate or other financial incentive at this time.*

**Options for funding ECM:**

*This project may benefit from enrolling in NJ SmartStart program with Technical Assistance to offset a portion of the cost of implementation*

<http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/nj-smartstart-buildings>

## ECM#2: Building Lighting Upgrades

### Description:

On the days of the site visits, SWA completed a lighting inventory of the Riker Hill Elementary School building (see Appendix A). The existing lighting consists of mostly T8 fluorescent fixtures with electronic ballasts. Many of the lights in the Riker Hill Elementary School building appear to have been upgraded to T8 fixtures. SWA has performed an evaluation of installing occupancy sensors in large spaces, offices and bathrooms that may be left unoccupied a considerable amount of time throughout the day and replacing incandescent lamps with CFLs. The labor in all these installations was evaluated using prevailing electrical contractor wages. The Livingston Board of Education may decide to perform this work with in-house resources from its Maintenance Department on a scheduled, longer timeline than otherwise performed by a contractor, to obtain savings. As a minimum, all incandescent lamps should be replaced with CFLs.

### Installation cost:

Estimated installed cost: \$2,680

Source of cost estimate: RS Means; Published and established costs, NJ Clean Energy Program

### Economics (Some of the options considered with incentives):

ECM #	ECM description	source	est. installed cost, \$	est. incentives, \$	net est. ECM cost with incentives, \$	kWh, 1st yr savings	kW, demand reduction/mo	therms, 1st yr savings	kBtu/sq ft, 1st yr savings	est. operating cost, 1st yr savings, \$	total 1st yr savings, \$	life of measure, yrs	est. lifetime energy cost savings, \$	simple payback, yrs	lifetime return on investment, %	annual return on investment, %	internal rate of return, %	net present value, \$	CO <sub>2</sub> reduced, lbs/yr
2.1	replace (74) incandescent stage lamps with CFLs	RS Means, Lit Search, NJ Clean Energy Program	1,480	none at this time	1,480	2,826	0.9	0	0.2	70	533	7	3,244	2.8	152	22	30	1,844	3,872
2.2	install (6) six occupancy sensors	RS Means, Lit Search, NJ Clean Energy Program	1,320	120	1,200	2,555	0.8	0	0.2	0	419	12	5,028	2.9	319	27	34	2,971	3,500

**Assumptions:** SWA calculated the savings for this measure using measurements taken the days of the field visits and using the billing analysis. SWA also assumed an aggregated 2 hrs/yr to replace aging burnt out lamps vs. newly installed.

**Rebates/financial incentives:**

*NJ Clean Energy - Wall Mounted occupancy sensors (\$20 per control)  
Maximum incentive amount is \$120.*

**Options for funding the Lighting ECM:** *This project may benefit from enrolling in NJ SmartStart program with Technical Assistance to offset a portion of the cost of implementation.*

<http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/nj-smartstart-buildings>

### ECM#3: *Install Premium Efficiency Motors on Heating / Hot Water Circulators*

#### Description:

The boiler room houses one set of two (2) floor-mounted circulator pumps and one set of two (2) pipe-mounted circulator pumps as part of the hot water heating system to serve the unit ventilators and other terminal units listed in this report. The pumps are in relatively good condition. The floor-mounted pumps are 5 Hp each, and the other two pumps are 2 Hp each, and each set operates in a lead-lag fashion. The pump motors are standard efficiency. The Riker Hill Elementary School will realize energy savings by utilizing premium efficiency motors for the pumps.

#### Installation cost:

Estimated installed cost: \$1,254

Source of cost estimate: Similar projects and DOE Motor Master International selection & savings analysis

#### Economics (with incentives):

ECM #	ECM description	source	est. installed cost, \$	est. incentives, \$	net est. ECM cost with incentives, \$	kWh, 1st yr savings	kW, demand reduction/mo	therms, 1st yr savings	kBtu/sq ft, 1st yr savings	est. operating cost, 1st yr savings, \$	total 1st yr savings, \$	life of measure, yrs	est. lifetime energy cost savings, \$	simple payback, yrs	lifetime return on investment, %	annual return on investment, %	internal rate of return, %	net present value, \$	CO <sub>2</sub> reduced, lbs/yr
3.1	replace (2) 5 Hp hot water circulator pump motors with Premium Efficiency	similar projects, DOE Motor Master + International	820	108	712	1,408	0.4	0	0.1	0	231	20	4,618	3.1	549	27	32	2,723	1,929
3.2	replace (2) 2 Hp hot water circulator pump motors with Premium Efficiency	similar projects, DOE Motor Master + International	650	108	542	658	0.2	0	0.0	0	108	20	2,158	5.0	298	15	19	1,063	901

**Assumptions:** SWA calculated the savings for this measure using nameplate data taken and using the billing analysis. The DOE Motor Master International selection and calculator was used with the assumption that one of each pair of pumps operates for the heating season. According to weather bin data for Newark, each pump considered should operate for approximately 5,000 hours per year.

**Rebates/financial incentives:**

*NJ Clean Energy - Premium three-phase motors (\$45-\$700 per motor)  
Maximum incentive amount is \$216.*

**Options for funding ECM:**

*This project may benefit from enrolling in NJ SmartStart program with Technical Assistance to offset a portion of the cost of implementation.*

<http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/nj-smartstart-buildings>

#### **ECM#4: *Install 170kW PV system***

##### **Description:**

Currently, the Riker Hill Elementary School building does not use any renewable energy systems. Renewable energy systems such as photovoltaic panels, can be mounted on the building roofs, and can offset a portion of the purchased electricity for the building. Power stations generally have two separate electrical charges: usage and demand. Usage is the amount of electricity in kilowatt-hours that a building uses from month to month. Demand is the amount of electrical power that a building uses at any given instance in a month period. During the summer periods, when electric demand at a power station is high due to the amount of air conditioners, lights, equipment, etc... being used within the region, demand charges go up to offset the utility's cost to provide enough electricity at that given time. Photovoltaic systems not only offset the amount of electricity use by a building, but also reduce the building's electrical demand, resulting in a higher cost savings as well. SWA presents below the economics, and recommends at this time that Livingston Board of Education further review installing a 170kW PV system to offset electrical demand and reduce the annual net electric consumption for the building, and review guaranteed incentives from NJ rebates to justify the investment. The Riker Hill Elementary School building is not eligible for a 30% federal tax credit. Instead, the Livingston Board of Education may consider applying for a grant and / or engage a PV generator / leaser who would install the PV system and then sell the power at a reduced rate. PSE&G provides the ability to buy SRECs at \$600 / MWh or best market offer.

There are many possible locations for a 170kW PV installation on the building roofs and away from shade. A commercial multi-crystalline 230 Watts panel (37.0 volts, 8.24 amps) has 17.5 square feet of surface area (13. 1 Watts per square foot). A 170kW system needs approximately 740 panels, which would take up 12,980 square feet. The installation of a renewable Solar Photovoltaic power generating system could also serve as a good educational tool and exhibit for the community.

##### **Installation cost:**

Estimated installed cost: \$1,319,000

Source of cost estimate: Similar projects

**Economics (without NJ 40% debt service aid - pending December referendum approval):**

school	ECM description	source	est. installed cost, \$	est. incentives, \$	net est. ECM cost with incentives, \$	kWh, 1st yr savings	kW, demand reduction/mo	therms, 1st yr savings	kBtu/sq ft, 1st yr savings	est. operating cost, 1st yr savings, \$	total 1st yr savings, \$	life of measure, yrs	est. lifetime energy cost savings, \$	simple payback, yrs	lifetime return on investment, %	annual return on investment, %	internal rate of return, %	net present value, \$	CO <sub>2</sub> reduced, lbs/yr
Burnet Hill Elementary	install 120 kW PV rooftop system with incentives	similar projects	932,250	0	932,250	136,459	120	N/A	9.0	0	106,572	25	574,302	8.7	98.3	3.9	8.5	476,728	186,949
Collins Elementary	install 128 kW PV rooftop system with incentives	similar projects	995,000	0	995,000	145,591	128	N/A	10.2	0	110,003	25	575,086	9.0	89.0	3.6	7.9	444,163	199,460
Harrison Elementary	install 45 kW PV rooftop system with incentives	similar projects	349,350	51,000	298,350	51,140	45	N/A	2.7	0	38,885	25	207,116	7.7	123.3	4.9	10.5	211,212	70,061
Hillside Elementary	install 98 kW PV rooftop system with incentives	similar projects	757,560	0	757,560	110,890	98	N/A	8.4	0	83,742	25	443,558	9.0	89.2	3.6	7.9	339,294	151,919
Mount Pleasant Schools	install 248 kW PV rooftop system with incentives	similar projects	1,925,000	0	1,925,000	281,570	248	N/A	7.1	0	211,714	25	1,077,846	9.1	87.4	3.5	7.8	838,484	386,052
Riker Hill Elementary	install 170 kW PV rooftop system with incentives	similar projects	1,319,000	0	1,319,000	193,078	170	N/A	13.6	0	147,465	25	571,571	8.9	91.7	3.7	8.1	614,577	264,517
Heritage Middle School	install 116 kW PV rooftop system with incentives	similar projects	900,000	0	900,000	131,763	116	N/A	3.0	0	100,868	25	556,698	8.9	92.9	3.7	8.2	426,076	180,515
Livingston High School	install 195 kW PV rooftop system with incentives	similar projects	1,509,745	0	1,509,745	220,996	195	N/A	2.4	0	165,370	25	834,261	9.1	86.4	3.5	7.8	647,147	302,765
Totals			8,687,905	51,000	8,636,905	1,271,708	1,121		56.5	0	964,570		5,110,489					3,997,901	1,742,239



**Economics (with NJ 40% debt service aid - pending December referendum approval):**

school	ECM description	source	est. installed cost, \$	est. incentives, \$	net est. ECM cost with incentives, \$	kWh, 1st yr savings	kW, demand reduction/mo	therms, 1st yr savings	kBtu/sq ft, 1st yr savings	est. operating cost, 1st yr savings, \$	total 1st yr savings, \$	life of measure, yrs	est. lifetime energy cost savings, \$	simple payback, yrs	lifetime return on investment, %	annual return on investment, %	internal rate of return, %	net present value, \$	CO <sub>2</sub> reduced, lbs/yr
Burnet Hill Elementary	install 120 kW PV rooftop system with incentives	similar projects	932,250	372,900	559,350	136,459	120	N/A	9.0	0	106,572	25	574,302	5.2	230.4	9.2	17.7	849,578	186,949
Collins Elementary	install 128 kW PV rooftop system with incentives	similar projects	995,000	398,000	597,000	145,591	128	N/A	10.2	0	110,003	25	575,086	5.4	214.9	8.6	17.0	842,163	199,460
Harrison Elementary	install 45 kW PV rooftop system with incentives	similar projects	349,350	190,740	158,610	51,140	45	N/A	2.7	0	38,885	25	207,116	4.1	320.0	12.8	23.7	350,952	70,061
Hillside Elementary	install 98 kW PV rooftop system with incentives	similar projects	757,560	303,024	454,576	110,890	98	N/A	8.4	0	83,742	25	443,558	5.4	215.4	8.6	17.0	642,318	151,919
Mount Pleasant Schools	install 248 kW PV rooftop system with incentives	similar projects	1,925,000	770,000	1,155,000	281,570	248	N/A	7.1	0	211,714	25	1,077,846	5.5	212.3	8.5	16.8	1,608,484	386,052
Riker Hill Elementary	install 170 kW PV rooftop system with incentives	similar projects	1,319,000	527,600	571,400	193,078	170	N/A	13.6	0	147,465	25	571,571	5.4	219.5	8.8	17.2	1,142,397	264,517
Heritage Middle School	install 116 kW PV rooftop system with incentives	similar projects	900,000	360,000	540,000	131,763	116	N/A	3.0	0	100,868	25	556,698	5.4	221.4	8.9	17.3	786,076	180,515
Livingston High School	install 195 kW PV rooftop system with incentives	similar projects	1,509,745	603,898	905,847	220,996	195	N/A	2.4	0	165,370	25	834,261	5.5	210.7	8.4	16.8	1,251,045	302,765
Totals			8,687,905	3,526,157	5,161,743	1,271,708	1,121		56.5	0	964,570		5,110,489					7,473,063	1,742,239

**Assumptions:** SWA estimated the cost and savings of the system based on past PV projects. SWA projected physical dimensions based on a typical Polycrystalline Solar Panel (230 Watts, model #ND-U230C1). PV systems are sized based on Watts and physical dimensions for an array will differ with the efficiency of a given solar panel (W/sq ft).

**Rebates/financial incentives:**

*NJ Clean Energy - Renewable Energy Incentive Program, Incentive based on \$1.00 / watt Solar PV application for systems 50kW or less. Incentive amount for this application is \$45,000 only for the Riker Hill Elementary Schools.*

<http://www.njcleanenergy.com/renewable-energy/programs/renewable-energy-incentive-program>

*NJ Clean Energy - Solar Renewable Energy Certificate Program. Each time a solar electric system generates 1000kWh (1MWh) of electricity, a SREC is issued which can then be sold or traded separately from the power. The buildings must also become net-metered in order to earn SRECs as well as sell power back to the electric grid. A total Livingston Public Schools \$760,200 has been incorporated in the above costs, however it requires proof of performance, application approval and negotiations with the utility.*

**Options for funding ECM:**

*This project may benefit from enrolling in NJ SmartStart program with Technical Assistance to offset a portion of the cost of implementation.*

<http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/nj-smartstart-buildings>

## ECM#5: Retro-Commissioning

### Description:

Retro-commissioning is a process that seeks to improve how building equipment and systems function together. Depending on the age of the building, retro-commissioning can often resolve problems that occurred during design or construction and / or address problems that have developed throughout the building's life. Owners often undertake retro-commissioning to optimize building systems, reduce operating costs, and address comfort complaints from building occupants.

Since the systems at the Riker Hill Elementary School building have undergone some renovations in recent years, and the building continues to have concerns with thermal comfort control, SWA recommends undertaking retro-commissioning to optimize system operation as a follow-up to completion of the upgrades. The retro-commissioning process should include a review of existing operational parameters for both newer and older installed equipment. During retro-commissioning, the individual loop temperatures should also be reviewed to identify opportunities for optimizing system performance.

### Installation cost:

Estimated installed cost: \$48,279

Source of cost estimate: Similar projects

### Economics (without incentives):

ECM #	ECM description	source	est. installed cost, \$	est. incentives, \$	net est. ECM cost with incentives, \$	kWh, 1st yr savings	kW, demand reduction/mo	therms, 1st yr savings	kBtu/sq ft, 1st yr savings	est. operating cost, 1st yr savings, \$	total 1st yr savings, \$	life of measure, yrs	est. lifetime energy cost savings, \$	simple payback, yrs	lifetime return on investment, %	annual return on investment, %	internal rate of return, %	net present value, \$	CO <sub>2</sub> reduced, lbs/yr
5	retro commissioning	similar projects	48,279	none at this time	48,279	8,560	2.7	2,682	6.2	1,820	7,386	12	66,798	6.5	84	7	11	25,246	11,727

**Assumptions:** Since the utility bills have some accounting fluctuations, it is difficult to determine the amount of energy used for heating and cooling the Riker Hill Elementary School building. Based on experience with similar buildings, SWA estimated the heating and cooling energy consumption. Typical savings for retro-commissioning range from 5-20%, as a percentage of the total space conditioning consumption. SWA assumed 10% savings. Estimated costs for retro-commissioning range from \$0.50-\$2.00 per square foot. SWA assumed \$1.00 per square foot of a

total square footage of 48,279. SWA also assumed on the average 1 hr/wk operational savings when systems are operating per design vs. the need to make more frequent adjustments.

**Rebates / financial incentives:**

*There are currently no incentives for this measure at this time.*

**Options for funding ECM:**

*This project may benefit from enrolling in NJ SmartStart program with Technical Assistance to offset a portion of the cost of implementation.*

<http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/nj-smartstart-buildings>

## ECM#6: Replace Exhaust Fans with High Efficiency Units

### Description:

Most of the building rooftop exhaust fans are in good condition and should be retained. SWA recommends replacement of approximately five (5) of the building exhaust fans that are operating beyond their useful lives. The motors are small, in the 1-2 horsepower range, and replacement units will have small energy savings over the existing.

### Installation cost:

Estimated installed cost: \$13,980

Source of cost estimate: Similar projects

### Economics (with incentives):

ECM #	ECM description	source	est. installed cost, \$	est. incentives, \$	net est. ECM cost with incentives, \$	kWh, 1st yr savings	kW, demand reduction/mo	therms, 1st yr savings	kBtu/sq ft, 1st yr savings	est. operating cost, 1st yr savings, \$	total 1st yr savings, \$	life of measure, yrs	est. lifetime energy cost savings, \$	simple payback, yrs	lifetime return on investment, %	annual return on investment, %	internal rate of return, %	net present value, \$	CO <sub>2</sub> reduced, lbs/yr
6a	replace 5 exhaust fans with premium efficiency units	similar projects, DOE Motor Master + International	14,250	270	13,980	1,275	0.4	0	0.1	175	384	10	2,091	36.4	-73	-7	<0	-10,704	1,747
6b	incremental cost to replace 5 exhaust fans with premium efficiency units	similar projects, DOE Motor Master + International	2,135	270	1,865	1,275	0.4	0	0.1	175	384	10	2,091	4.9	106	11	16	1,411	1,747

**Assumptions:** SWA calculated the savings for this measure using measurements taken the days of the field visits and using the billing analysis. SWA also assumed an aggregated 5 hrs/yr to troubleshoot exhaust fan malfunctions vs. newly installed.

**Rebates/financial incentives:**

*NJ Clean Energy - Premium three-phase motors (\$45-\$700 per motor)  
Maximum incentive amount is \$270.*

*State of NJ School Grant - The Livingston Public Schools are eligible for a 40% state grant, which will decrease investment and simple payback when the December bond referendum passes. Since approval is pending, this has not been included in the above calculations.*

**Options for funding the Lighting ECM:** *This project may benefit from enrolling in NJ SmartStart program with Technical Assistance to offset a portion of the cost of implementation.*

<http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/nj-smartstart-buildings>

### ECM#7: Replace Old Refrigerator with Energy Star Model

#### Description:

On the days of the site visits, SWA observed that there is one (1) existing solid door commercial refrigerator in the kitchen area which is not Energy Star rated (using approximately 2,600 kWh/yr). Appliances, such as refrigerators, that are over 10-12 years of age should be replaced with newer efficient models with the Energy Star label. SWA recommends the replacement of the existing refrigerator, freezer, and ice cream chest freezer, which are operating at the end of their useful lives with more modern, ENERGY STAR®, energy efficient systems. Besides saving energy, the replacement will also keep the kitchen and other areas cooler. In addition, the existing systems utilize R-12 refrigerant, which is not an ozone-friendly refrigerant. Newer systems should be specified with R-134A or R-404A refrigerant. When compared to the average electrical consumption of older equipment, Energy Star equipment results in large savings. Look for the Energy Star label when replacing appliances and equipment, including: window air conditioners, refrigerators, printers, computers, copy machines, etc. More information can be found in the “Products” section of the Energy Star website at: <http://www.energystar.gov>.

#### Installation cost:

Estimated installed cost: \$10,000

Source of cost estimate: *Energy Star purchasing and procurement site, similar projects, Manufacturer and Store established costs*

#### Economics:

ECM #	ECM description	source	est. installed cost, \$	est. incentives, \$	net est. ECM cost with incentives, \$	kWh, 1st yr savings	kW, demand reduction/mo	therms, 1st yr savings	kBtu/sq ft, 1st yr savings	est. operating cost, 1st yr savings, \$	total 1st yr savings, \$	life of measure, yrs	est. lifetime energy cost savings, \$	simple payback, yrs	lifetime return on investment, %	annual return on investment, %	internal rate of return, %	net present value, \$	CO <sub>2</sub> reduced, lbs/yr
7a	replace (1) reach-in stainless steel refrigerators with 42 cu ft Energy Star models	Energy Star purchasing and procurement site, similar projects	10,000	0	10,000	250	0.1	0	0.0	150	191	12	492	52.4	-77	-6	<0	-8,099	343
7b	incremental cost to replace (1) reach-in stainless steel refrigerators with 42 cu ft Energy Star models	Energy Star purchasing and procurement site, similar projects	275	0	275	250	0.1	0	0.0	150	191	12	492	1.4	733	61	69	1,626	343

**Assumptions:** SWA calculated the savings for this measure using measurements taken the day of the field visit and using the billing analysis. SWA assumed one annual call to a refrigeration contractor to perform minor repairs on old refrigerators / freezers.

**Rebates/financial incentives:**

*NJ Clean Energy - There aren't any incentives at this time offered by the state of NJ for this energy conservation measure.*

**Options for funding the Lighting ECM:**

*This project may benefit from enrolling in NJ SmartStart program with Technical Assistance to offset a portion of the cost of implementation.*

<http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/nj-smartstart-buildings>



## **5. RENEWABLE AND DISTRIBUTED ENERGY MEASURES**

### **5.1. Existing systems**

There aren't currently any existing renewable energy systems.

### **5.2. Wind**

#### **Description:**

*A Wind system is not applicable for this building because the area does not have winds of sufficient velocity to justify installing a wind turbine system.*

### **5.3. Solar Photovoltaic**

Plases see the above recommended ECM#4.

### **5.4. Solar Thermal Collectors**

#### **Description:**

*Solar thermal collectors are not cost effective for this building and would not be recommended due to the insufficient and not constant use of domestic hot water throughout the building to justify the expenditure.*

### **5.5. Combined Heat and Power**

#### **Description:**

*CHP is not applicable for this building because of several existing split system cooling, and insufficient domestic hot water use.*

### **5.6. Geothermal**


#### **Description:**

*Geothermal is not applicable for this building because it would not be cost effective, since it would require replacement of the existing HVAC system, of which major components still have as a whole a number of useful operating years.*


## **6. ENERGY PURCHASING AND PROCUREMENT STRATEGIES**

### **6.1. Load profiles**



The following are charts that show the annual electric and natural gas load profiles for the Livingston Riker Hill Elementary School building.



Some minor unusual electric fluctuations shown may be due to adjustments between estimated and actual meter readings. Also, note on the following chart how the electrical Demand peaks (except for a few unusual fluctuation anomalies) follow the electrical consumption peaks.




The following is a chart of the natural gas annual load profile for the building, peaking in the coldest months of the year and a chart showing natural gas consumption following the “heating degree days” curve.



## 6.2. Tariff analysis

Currently, natural gas is provided to the Riker Hill Elementary School building via one gas meter with the Hess Corporation acting as the supply and PSE&G acting as the transport company. Gas is provided by the Hess Corporation at a general service rate. The suppliers' general service rate for natural gas charges a market-rate price based on use and the Riker Hill Elementary School billing does not breakdown demand costs for all periods. Demand prices are reflected in the utility bills and can be verified by observing the price fluctuations throughout the year. Typically, the natural gas prices increase during the heating months when natural gas is used by the hot water boiler units. The high gas price per therm fluctuations in the summer may be due to high energy costs that occurred in 2008 and low use caps for the non-heating months. Thus the building pays for fixed costs such as meter reading charges during the summer months. So June, July, August and September cap payment are excluded from the following chart.





The Riker Hill Elementary School building is direct-metered (via one main meter) and currently purchases electricity from PSE&G at a general service rate. The general service rate for electric charges are market-rate based on use and the Riker Hill Elementary School building billing does show a breakdown of demand costs. Demand prices are reflected in the utility bills and can be verified by observing the price fluctuations throughout the year. Typically, the electricity prices increase during the cooling months when electricity is used by the HVAC condensing units and air handlers.

## 6.3. Energy Procurement strategies

The Riker Hill Elementary School building receives natural gas via one incoming meter. The Hess Corporation supplies the gas and PSE&G transports it. There is not an ESCO engaged in the process. An Energy Services Company (ESCO) is a consultancy group that engages in a performance based contract with a client firm to implement measures which reduce energy consumption and costs in a technically and

financially viable manner. Electricity is also purchased via one incoming meter directly for the Riker Hill Elementary School building from PSE&G without an ESCO. SWA analyzed the utility rate for natural gas and electricity supply over an extended period. Electric bill analysis shows fluctuations up to 25% over the most recent 12 month period. Natural gas bill analysis shows fluctuations up to 35% over the most recent 12 month period. Some of these fluctuations may have been caused by adjustments between estimated and actual meter readings, others may be due to unusual high and escalating energy costs in 2008. The average estimated NJ commercial utility rates for electric and gas are \$0.150/kWh and \$1.550/therm respectively. The Riker Hill Elementary School building annual utility costs are \$4,289 higher for electric and \$54 lower for natural gas for a total of \$4,343 higher, when compared to the average estimated NJ commercial utility rates. SWA recommends that the Livingston Board of Education further explore opportunities of purchasing both natural gas and electricity from ESCOs in order to reduce rate fluctuation and ultimately reduce the annual cost of energy for the Riker Hill Elementary School building. Appendix B contains a complete list of third party energy suppliers for the Livingston Township service area. The Livingston Board of Education may want to consider partnering with other school districts, municipalities, townships and communities to aggregate a substantial electric and natural gas use for better leveraging in negotiations with ESCOs and of improving the pricing structures. This sort of activity is happening in many parts of the country and in New Jersey. Also, the Riker Hill Elementary School building would not be eligible for enrollment in a Demand Response Program, because there isn't the capability at this time to shed a minimum of 150 kW electric demand when requested by the utility during peak demand periods, which is the typical threshold for considering this option. Demand Response could be an option in the future when the Livingston Board of Education may install a large enough back-up emergency generator. The following charts show the Riker Hill Elementary School building monthly spending per unit of energy in 2008.





## 7. METHOD OF ANALYSIS

### 7.1. Assumptions and tools

Energy modeling tool: established / standard industry assumptions, E-Quest  
Cost estimates: RS Means 2009 (Facilities Maintenance & Repair Cost Data)  
RS Means 2009 (Building Construction Cost Data)  
RS Means 2009 (Mechanical Cost Data)  
Published and established specialized equipment material and labor costs  
Cost estimates also based on utility bill analysis and prior experience with similar projects

### 7.2. Disclaimer

This engineering audit was prepared using the most current and accurate fuel consumption data available for the site. The estimates that it projects are intended to help guide the owner toward best energy choices. The costs and savings are subject to fluctuations in weather, variations in quality of maintenance, changes in prices of fuel, materials, and labor, and other factors. Although we cannot guarantee savings or costs, we suggest that you use this report for economic analysis of the building and as a means to estimate future cash flow.

***THE RECOMMENDATIONS PRESENTED IN THIS REPORT ARE BASED ON THE RESULTS OF ANALYSIS, INSPECTION, AND PERFORMANCE TESTING OF A SAMPLE OF COMPONENTS OF THE BUILDING SITE. ALTHOUGH CODE-RELATED ISSUES MAY BE NOTED, SWA STAFF HAVE NOT COMPLETED A COMPREHENSIVE EVALUATION FOR CODE-COMPLIANCE OR HEALTH AND SAFETY ISSUES. THE OWNER(S) AND MANAGER(S) OF THE BUILDING(S) CONTAINED IN THIS REPORT ARE REMINDED THAT ANY IMPROVEMENTS SUGGESTED IN THIS SCOPE OF WORK MUST BE PERFORMED IN ACCORDANCE WITH ALL LOCAL, STATE, AND FEDERAL LAWS AND REGULATIONS THAT APPLY TO SAID WORK. PARTICULAR ATTENTION MUST BE PAID TO ANY WORK WHICH INVOLVES HEATING AND AIR MOVEMENT SYSTEMS, AND ANY WORK WHICH WILL INVOLVE THE DISTURBANCE OF PRODUCTS CONTAINING MOLD, ASBESTOS, OR LEAD.***



# Appendix A: Lighting Study

Location			Existing Fixture Information													Retrofit Information													Annual Savings					
Marker	Floor	Room Identification	Fixture Type	Ballast	Lamp Type	# of Fixtures	# of Lamps per Fixture	Watts per Lamp	Controls	Operational Hours per Day	Operational Days per Year	Ballast	Wattage	Total Watts	Energy Use kWh/year	Category	Fixture Type	Lamp Type	Ballast	Controls	# of Fixtures	# of Lamps per Fixture	Watts per Lamp	Operational Hours per Day	Operational Days per Year	Ballast	Wattage	Total Watts	Energy Use kWh/year	Fixture	Savings (kWh)	Controls	Savings (kWh)	Total Savings (kWh)
1	GF	Classroom K1	Parabolic	E	4T8	21	2	32	S	9	190	3	1,347	2,406	N/A	Parabolic	4T8	E	S	21	2	32	9	190	3	1,347	2,406	0	0	0				
2	GF	Classroom K1	Screw-in	N/A	CFL	6	2	13	N	9	190	1	157	277	N/A	Screw-in	CFL	N/A	N	6	2	13	9	190	1	157	277	0	0	0				
3	GF	Classroom K2	Parabolic	E	4T8	24	2	32	S	9	190	3	1,539	2,750	N/A	Parabolic	4T8	E	S	24	2	32	9	190	3	1,539	2,750	0	0	0				
4	GF	Classroom K2 bath	Parabolic	E	2T8	1	2	16	S	9	190	2	34	58	N/A	Parabolic	2T8	E	S	1	2	16	9	190	2	34	58	0	0	0				
5	GF	Classroom K1 bath	Parabolic	E	2T8	1	2	16	S	9	190	2	34	58	N/A	Parabolic	2T8	E	S	1	2	16	9	190	2	34	58	0	0	0				
6	GF	Classroom K1 closet	Parabolic	E	2T8	1	2	16	S	9	190	2	34	58	N/A	Parabolic	2T8	E	S	1	2	16	9	190	2	34	58	0	0	0				
7	GF	Classroom K2 closet	Parabolic	E	2T8	1	2	16	S	9	190	2	34	58	N/A	Parabolic	2T8	E	S	1	2	16	9	190	2	34	58	0	0	0				
8	GF	Classroom K3 closet	Parabolic	E	2T8	1	2	16	S	9	190	2	34	58	N/A	Parabolic	2T8	E	S	1	2	16	9	190	2	34	58	0	0	0				
9	GF	Classroom K3 bath	Parabolic	E	2T8	1	2	16	S	9	190	2	34	58	N/A	Parabolic	2T8	E	S	1	2	16	9	190	2	34	58	0	0	0				
10	GF	Classroom K3	Parabolic	E	4T8	22	2	32	S	9	190	3	1,411	2,521	N/A	Parabolic	4T8	E	S	22	2	32	9	190	3	1,411	2,521	0	0	0				
11	GF	Boiler Rm closet	Parabolic	E	4T8	1	2	32	S	2	190	3	67	25	N/A	Parabolic	4T8	E	S	1	2	32	2	190	3	67	25	0	0	0				
12	GF	Boiler Rm	Parabolic	E	4T8	8	2	32	S	2	190	3	515	204	N/A	Parabolic	4T8	E	S	8	2	32	2	190	3	515	204	0	0	0				
13	GF	Music Classroom	Parabolic	E	4T8	10	2	32	S	9	190	3	643	1,146	N/A	Parabolic	4T8	E	S	10	2	32	9	190	3	643	1,146	0	0	0				
14	GF	Storage Rm	Parabolic	E	2T8	2	2	16	S	3	190	2	66	39	N/A	Parabolic	2T8	E	S	2	2	16	3	190	2	66	39	0	0	0				
15	GF	CST Classroom	Parabolic	E	4T8	11	2	32	S	9	190	3	707	1,260	C	Parabolic	4T8	E	OS	11	2	32	6.75	190	3	707	945	0	315	315				
16	GF	Faculty room	Parabolic	E	4T8	10	2	32	S	9	190	3	643	1,146	N/A	Parabolic	4T8	E	S	10	2	32	9	190	3	643	1,146	0	0	0				
17	GF	Bathroom Women	Parabolic	E	4T8	1	2	32	S	9	190	3	67	115	N/A	Parabolic	4T8	E	S	1	2	32	9	190	3	67	115	0	0	0				
18	GF	Bathroom Men	Parabolic	E	4T8	1	2	32	S	9	190	3	67	115	N/A	Parabolic	4T8	E	S	1	2	32	9	190	3	67	115	0	0	0				
19	GF	Storage Rm	Parabolic	E	2T8	1	2	16	S	2	190	2	34	13	N/A	Parabolic	2T8	E	S	1	2	16	2	190	2	34	13	0	0	0				
20	GF	Storage Rm	Parabolic	E	2T8	1	2	16	S	2	190	2	34	13	N/A	Parabolic	2T8	E	S	1	2	16	2	190	2	34	13	0	0	0				
21	GF	Nurse's bath	Recessed	E	2T8	1	2	16	S	2	190	2	34	13	N/A	Recessed	2T8	E	S	1	2	16	2	190	2	34	13	0	0	0				
22	GF	Nurse's office	Recessed	E	4T8	11	2	32	S	9	190	3	707	1,260	C	Recessed	4T8	E	OS	11	2	32	6.75	190	3	707	945	0	315	315				
23	GF	Main office	Recessed	E	4T8	8	4	32	S	9	190	4	1,028	1,806	N/A	Recessed	4T8	E	S	8	4	32	9	190	4	1,028	1,806	0	0	0				
24	GF	Principal's office	Recessed	E	4T8	6	2	32	S	9	190	3	387	687	C	Recessed	4T8	E	OS	6	2	32	6.75	190	3	387	516	0	172	172				
25	GF	Gym office	Parabolic	E	4T8	6	2	32	S	9	190	3	387	687	N/A	Parabolic	4T8	E	S	6	2	32	9	190	3	387	687	0	0	0				
26	GF	Kitchen	Recessed	E	4T8	13	2	32	S	9	190	3	835	1,489	N/A	Recessed	4T8	E	S	13	2	32	9	190	3	835	1,489	0	0	0				
27	GF	Hallway	Recessed	E	T8 U	5	2	32	S	9	190	4	324	581	N/A	Recessed	T8 U	E	S	5	2	32	9	190	4	324	581	0	0	0				
28	GF	Hallway	Recessed	E	4T8	9	2	32	S	9	190	3	579	1,031	N/A	Recessed	4T8	E	S	9	2	32	9	190	3	579	1,031	0	0	0				
29	GF	Hallway	Exit sign	N/A	LED Exit	5	2	5	N	24	365	1	51	482	N/A	Exit sign	LED Exit	N/A	N	5	2	5	24	365	1	51	482	0	0	0				
30	GF	Hallway displays	Screw-in	N/A	CFL	2	1	25	S	16	190	1	51	158	N/A	Screw-in	CFL	N/A	S	2	1	25	16	190	1	51	158	0	0	0				
31	GF	Hallway displays	Screw-in	N/A	CFL	2	1	25	S	16	190	1	51	158	N/A	Screw-in	CFL	N/A	S	2	1	25	16	190	1	51	158	0	0	0				
32	GF	Entrance	Recessed	E	2T8	14	4	16	S	16	190	3	899	2,852	N/A	Recessed	2T8	E	S	14	4	16	16	190	3	899	2,852	0	0	0				
33	GF	Entrance	2U-shape	E	T8 U	2	2	32	S	16	190	4	132	413	N/A	2U-shape	T8 U	E	S	2	2	32	16	190	4	132	413	0	0	0				
34	GF	Entrance	Recessed	E	4T8	2	2	32	S	16	190	3	131	407	N/A	Recessed	4T8	E	S	2	2	32	16	190	3	131	407	0	0	0				
35	GF	Storage Rm	Parabolic	E	4T8	1	2	32	S	2	190	3	67	25	N/A	Parabolic	4T8	E	S	1	2	32	2	190	3	67	25	0	0	0				
36	GF	Gymnasium	Parabolic	E	4T8	40	2	32	S	9	190	3	2,563	4,583	N/A	Parabolic	4T8	E	S	40	2	32	9	190	3	2,563	4,583	0	0	0				
37	GF	Gymnasium	Exit sign	N/A	LED Exit	2	2	5	N	24	365	1	21	193	N/A	Exit sign	LED Exit	N/A	N	2	2	5	24	365	1	21	193	0	0	0				
38	GF	Stage	Screw-in	N/A	Inc	2	1	100	S	3	190	0	200	114	CFL	Screw-in	CFL	N/A	S	2	1	33	3	190	0	66	38	76	0	76				
39	GF	Stage	Screw-in	N/A	Inc	72	1	100	S	3	190	0	7,200	4,104	CFL	Screw-in	CFL	N/A	S	72	1	33	3	190	0	2,376	1,364	2,760	0	2,760				
40	GF	Activity room	Exit sign	N/A	LED Exit	3	2	5	N	24	365	1	31	289	N/A	Exit sign	LED Exit	N/A	N	3	2	5	24	365	1	31	289	0	0	0				
41	GF	Activity room	Parabolic	E	4T8	35	1	32	S	9	190	1	1,121	1,975	C	Parabolic	4T8	E	OS	35	1	32	6.75	190	1	1,121	1,481	0	494	494				
42	GF	Storage Rm	Parabolic	E	2T8	2	2	16	S	2	190	1	65	25	N/A	Parabolic	2T8	E	S	2	2	16	2	190	1	65	25	0	0	0				
43	GF	Storage Rm	Parabolic	E	2T8	2	2	16	S	2	190	1	65	25	N/A	Parabolic	2T8	E	S	2	2	16	2	190	1	65	25	0	0	0				
44	GF	Classroom #1	Parabolic	E	4T8	18	2	32	S	9	190	3	1,155	2,062	N/A	Parabolic	4T8	E	S	18	2	32	9	190	3	1,155	2,062	0	0	0				
45	GF	Classroom #2	Parabolic	E	4T8	18	2	32	S	9	190	3	1,155	2,062	N/A	Parabolic	4T8	E	S	18	2	32	9	190	3	1,155	2,062	0	0	0				
46	GF	Classroom #3	Parabolic	E	4T8	18	2	32	S	9	190	3	1,155	2,062	N/A	Parabolic	4T8	E	S	18	2	32	9	190	3	1,155	2,062	0	0	0				
47	GF	Classroom #4	Parabolic	E	4T8	18	2</																											



Location			Existing Fixture Information												Retrofit Information												Annual Savings				
Marker	Floor	Room Identification	Fixture Type	Ballast	Lamp Type	# of Fixtures	# of Lamps per Fixture	Watts per Lamp	Controls	Operational Hours per Day	Operational Days per Year	Ballast Wattage	Total Watts	Energy Use kWh/year	Category	Fixture Type	Lamp Type	Ballast	Controls	# of Fixtures	# of Lamps per Fixture	Watts per Lamp	Operational Hours per Day	Operational Days per Year	Ballast Watts	Total Watts	Energy Use kWh/year	Fixture Savings (kWh)	Controls Savings (kWh)	Total Savings (kWh)	
69	GF	Bathroom Women	Parabolic	E	4'T8	3	3	32	S	9	190	4	292	513	C	Parabolic	4'T8	E	OS	3	3	32	6.75	190	4	292	385	0	128	128	
70	GF	Bathroom Men	Parabolic	E	4'T8	1	2	32	S	9	190	3	67	115	N/A	Parabolic	4'T8	E	S	1	2	32	9	190	3	67	115	0	0	0	
71	GF	Storage Rm	Parabolic	E	2'T8	1	2	16	S	2	190	2	34	13	N/A	Parabolic	2'T8	E	S	1	2	16	2	190	2	34	13	0	0	0	
72	GF	Hallway	Recessed	E	4'T8	30	2	32	S	16	190	3	1,923	6,110	N/A	Recessed	4'T8	E	S	30	2	32	16	190	3	1,923	6,110	0	0	0	
73	GF	Hallway	2'U-shape	E	T8 U	18	2	32	S	16	190	4	1,156	3,721	N/A	2'U-shape	T8 U	E	S	18	2	32	16	190	4	1,156	3,721	0	0	0	
74	GF	Hallway	Recessed	N/A	CFL	6	2	32	S	16	190	1	385	1,186	N/A	Recessed	CFL	N/A	S	6	2	32	16	190	1	385	1,186	0	0	0	
75	GF	Hallway	Exit sign	N/A	LED Exit	3	2	5	N	24	365	0	30	263	N/A	Exit sign	LED Exit	N/A	N	3	2	5	24	365	0	30	263	0	0	0	
76	GF	Classroom #24	Parabolic	E	4'T8	20	2	32	S	9	190	3	1,283	2,291	N/A	Parabolic	4'T8	E	S	20	2	32	9	190	3	1,283	2,291	0	0	0	
77	GF	Classroom #24	Screw-in	N/A	CFL	4	2	13	S	9	190	1	105	185	N/A	Screw-in	CFL	N/A	S	4	2	13	9	190	1	105	185	0	0	0	
78	GF	Classroom #25	Parabolic	E	4'T8	11	2	5	S	9	190	3	113	245	N/A	Parabolic	4'T8	E	S	11	2	5	9	190	3	113	245	0	0	0	
79	GF	Classroom #26	Parabolic	E	4'T8	11	2	32	S	9	190	3	707	1,260	N/A	Parabolic	4'T8	E	S	11	2	32	9	190	3	707	1,260	0	0	0	
80	GF	Classroom #27	Parabolic	E	4'T8	11	2	32	S	9	190	3	707	1,260	N/A	Parabolic	4'T8	E	S	11	2	32	9	190	3	707	1,260	0	0	0	
81	GF	Classroom #28	Parabolic	E	4'T8	11	2	32	S	9	190	3	707	1,260	N/A	Parabolic	4'T8	E	S	11	2	32	9	190	3	707	1,260	0	0	0	
82	GF	Classroom #29	Parabolic	E	4'T8	11	2	32	S	9	190	3	707	1,260	N/A	Parabolic	4'T8	E	S	11	2	32	9	190	3	707	1,260	0	0	0	
83	GF	Classroom #30	Parabolic	E	4'T8	14	2	32	S	9	190	3	899	1,604	N/A	Parabolic	4'T8	E	S	14	2	32	9	190	3	899	1,604	0	0	0	
84	GF	Classroom #30	Screw-in	N/A	CFL	4	2	13	S	9	190	1	105	185	N/A	Screw-in	CFL	N/A	S	4	2	13	9	190	1	105	185	0	0	0	
85	GF	Classroom #31	Screw-in	N/A	CFL	4	2	13	S	9	190	1	105	185	N/A	Screw-in	CFL	N/A	S	4	2	13	9	190	1	105	185	0	0	0	
86	GF	Classroom #31	Parabolic	E	4'T8	14	2	32	S	9	190	3	899	1,604	N/A	Parabolic	4'T8	E	S	14	2	32	9	190	3	899	1,604	0	0	0	
87	GF	Storage Rm	Parabolic	E	4'T8	2	2	32	S	2	190	3	131	51	N/A	Parabolic	4'T8	E	S	2	2	32	2	190	3	131	51	0	0	0	
88	Ext	Exterior	Screw-in	None	CFL	3	1	23	T	12	365	0	69	302	N/A	Screw-in	CFL	None	T	3	1	23	12	365	0	69	302	0	0	0	
89	Ext	Exterior	Screw-in	None	MH	24	1	400	T	12	365	0	9,600	42,048	T8	Screw-in	MH	None	T	24	1	400	12	365	0	9,600	42,048	0	0	0	
90	Ext	Exterior	Screw-in	None	HPS	3	1	250	T	12	365	0	750	3,285	T8	Screw-in	HPS	None	T	3	1	250	12	365	0	750	3,285	0	0	0	
91	Ext	Exterior	Screw-in	None	HPS	2	1	150	T	12	365	0	300	1,314	T8	Screw-in	HPS	None	T	2	1	150	12	365	0	300	1,314	0	0	0	
92	Ext	Exterior	Screw-in	None	MH	5	1	150	T	12	365	0	750	3,285	T8	Screw-in	MH	None	T	5	1	150	12	365	0	750	3,285	0	0	0	
Totals:						938	181	3,369				217	68,810	149,640						938	181	3,235			217	63,852	144,359	2,826	2,455	5,281	
Note: Bolded items in yellow represent fixtures with proposed improvements																															
Total Building Floor Area (SF)									48,279																						
Total Interior Existing Annual Consumption (kWh)									99,406																						
Total Interior Proposed Annual Consumption (kWh)									94,125																						
Total Existing Interior Lighting Power(Watts)									57,341																						
Total Existing Interior Lighting Power Density (Watts/SF)									1.19																						
Total Proposed Interior Lighting Power(Watts)									52,383																						
Total Proposed Interior Power Density (Watts/SF)									1.09																						
Total Exterior Existing Annual Consumption (kWh)									50,234																						
Total Exterior Proposed Annual Consumption (kWh)									50,234																						
Total Existing Exterior Lighting Power(Watts)									11,469																						
Total Proposed Exterior Lighting Power(Watts)									11,469																						
Estimated Cost of Fixture Replacements (\$)									\$1,480																						
Estimated Cost of Controls Improvements (\$)									\$1,200																						
Proposed Annual Savings (kWh)									5,281																						
Proposed Annual Cost Savings (\$)									\$880																						

<b>Legend:</b>									
<b><u>Fixture Type</u></b>	<b><u>Lamp Type</u></b>	<b><u>Control Type</u></b>	<b><u>Ballast Type</u></b>	<b><u>Retrofit Category</u></b>					
Exit Sign	LED	N (None)	N/A (None)	N/A (None)					
Screw-in	Inc (Incandescent)	S (Switch)	E (Electronic)	T8 (Install new T8)					
Pin	1T5	OS (Occupancy Sensor)	M (Magnetic)	T5 (Install new T5)					
Parabolic	2T5	T (Timer)		CFL (Install new CFL)					
Recessed	3T5	PC (Photocell)		LEDex (Install new LED Exit)					
2'U-shape	4T5	D (Dimming)		LED (Install new LED)					
Circiline	2T8	DL (Daylight Sensor)		D (Delamping)					
Exterior	3T8	M (Microphonic Sensor)		C (Controls Only)					
HID (High Intensity Discharge)	4T8								
	6T8								
	8T8								
	2T12								
	3T12								
	4T12								
	6T12								
	8T12								
	CFL (Compact Fluorescent Lightbulb)								
	MR16								
	Halogen								
	MV (Mercury Vapor)								
	MH (Metal Halide)								
	HPS (High Pressure Sodium)								
	LPS (Low Pressure Sodium)								

**Appendix B: Third Party Energy Suppliers (ESCOs)**

<http://www.state.nj.us/bpu/commercial/shopping.html>

<b>PSE&amp;G ELECTRICAL SERVICE TERRITORY</b> <b>Last Updated: 06/15/09</b>		
<b>Hess Corporation</b> 1 Hess Plaza Woodbridge, NJ 07095 (800) 437-7872 <a href="http://www.hess.com">www.hess.com</a>	<b>BOC Energy Services, Inc.</b> 575 Mountain Avenue Murray Hill, NJ 05774 (800) 247-2644 <a href="http://www.boc.com">www.boc.com</a>	<b>Commerce Energy, Inc.</b> 4400 Route 9 South, Suite 100 Freehold, NJ 07728 (800) 556-8457 <a href="http://www.commerceenergy.com">www.commerceenergy.com</a>
<b>Constellation NewEnergy, Inc.</b> 900A Lake Street, Suite 2 Ramsey, NJ 07446 (888) 635-0827 <a href="http://www.newenergy.com">www.newenergy.com</a>	<b>Direct Energy Services, LLC</b> 120 Wood Avenue Suite 611 Iselin, NJ 08830 (866) 547-2722 <a href="http://www.directenergy.com">www.directenergy.com</a>	<b>FirstEnergy Solutions Corp.</b> 300 Madison Avenue Morristown, NJ 05757 (800) 977-0500 <a href="http://www.fes.com">www.fes.com</a>
<b>Glacial Energy of New Jersey, Inc.</b> 207 LaRoche Avenue Harrington Park, NJ 07640 (877) 569-2841 <a href="http://www.glacialenergy.com">www.glacialenergy.com</a>	<b>Integritys Energy Services, Inc.</b> 99 Wood Ave, South, Suite 802 Iselin, NJ 08830 (877) 763-9977 <a href="http://www.integritysenergy.com">www.integritysenergy.com</a>	<b>Strategic Energy, LLC</b> 55 Madison Avenue, Suite 400 Morristown, NJ 05760 (888) 925-9115, <a href="http://www.sel.com">www.sel.com</a>
<b>Liberty Power Holdings, LLC</b> Park 80 West, Plaza II, Suite 200 Saddle Brook, NJ 07663 (866) 769-3579 <a href="http://www.libertypowercorp.com">www.libertypowercorp.com</a>	<b>Pepco Energy Services, Inc.</b> 112 Main St. Lebanon, NJ 08833 (800) ENERGY-9 (363-7499) <a href="http://www.pepco-services.com">www.pepco-services.com</a>	<b>PPL EnergyPlus, LLC</b> 811 Church Road Cherry Hill, NJ 08002 (800) 281-2000 <a href="http://www.pplenergyplus.com">www.pplenergyplus.com</a>
<b>Sempra Energy Solutions</b> The Mac-Cali Building 581 Main Street, 8 <sup>th</sup> Floor Woodbridge, NJ 07095 (877) 273-6772 <a href="http://www.semprasolutions.com">www.semprasolutions.com</a>	<b>South Jersey Energy Company</b> One South Jersey Plaza Route 54 Folsom, NJ 08037 (800) 800-756-3749 <a href="http://www.southjerseyenergy.com">www.southjerseyenergy.com</a>	<b>Suez Energy Resources NA, Inc.</b> 333 Thornall Street 6th Floor Edison, NJ 08837 (888) 644-1014 <a href="http://www.suezenergyresources.com">www.suezenergyresources.com</a>
<b>UGI Energy Services, Inc.</b> 704 East Main Street, Suite 1 Moorestown, NJ 08057 (856) 273-9995 <a href="http://www.ugienergyservices.com">www.ugienergyservices.com</a>	<b>American Powernet Management, LP</b> 437 North Grove St. Berlin, NJ 08009 (800) 437-7872 <a href="http://www.hess.com">www.hess.com</a>	<b>ConEdison Solutions</b> Cherry Tree, Corporate Center 575 State Highway 38 Cherry Hill, NJ 08002 (888) 665-0955 <a href="http://www.conedsolutions.com">www.conedsolutions.com</a>
<b>Credit Suisse, (USA) Inc.</b> 700 College Road East Princeton, NJ 08450 212-578-3124 <a href="http://www.creditsuisse.com">www.creditsuisse.com</a>	<b>Sprague Energy Corp.</b> 12 Ridge Road Chatham Township NJ 05728 (800) 225-1560 <a href="http://www.spragueenergy.com">www.spragueenergy.com</a>	

**PSE&G NATURAL GAS SERVICE TERRITORY**

**Last Updated: 06/15/09**

<b>Cooperative Industries</b> 412-420 Washington Avenue Belleville, NJ 07109 800-6BUYGAS (6-289427) <a href="http://www.cooperativenet.com">www.cooperativenet.com</a>	<b>Direct Energy Services, LLP</b> 120 Wood Avenue, Suite 611 Iselin, NJ 08830 866-547-2722 <a href="http://www.directenergyservices.com">www.directenergyservices.com</a>	<b>Dominion Retail, Inc.</b> 395 Highway 170 - Suite 125 Lakewood, NJ 08701 866-275-4240 <a href="http://retail.dom.com">http://retail.dom.com</a>
<b>Gateway Energy Services Corp.</b> 44 Whispering Pines Lane Lakewood, NJ 08701 800-805-8586 <a href="http://www.gesc.com">www.gesc.com</a>	<b>UGI Energy Services, Inc. d/b/a GASMAR</b> 704 East Main Street, Suite 1 Moorestown, NJ 08057 856-273-9995 <a href="http://www.ugienergyservices.com">www.ugienergyservices.com</a>	<b>Great Eastern Energy</b> 116 Village Riva, Suite 200 Princeton, NJ 08540 888-651-4121 <a href="http://www.greateastern.com">www.greateastern.com</a>
<b>Hess Energy, Inc.</b> One Hess Plaza Woodbridge, NJ 07095 800-437-7872 <a href="http://www.hess.com">www.hess.com</a>	<b>Hudson Energy Services, LLC</b> 403 Route 17 South Ridgewood, NJ 07450 877- Hudson 9 <a href="http://www.hudsonenergyservices.com">www.hudsonenergyservices.com</a>	<b>Intelligent Energy</b> 2050 Center Avenue, Suite 500 Fort Lee, NJ 07024 800-724-1880 <a href="http://www.intelligentenergy.org">www.intelligentenergy.org</a>
<b>Keil &amp; Sons</b> 1 Bergen Blvd. Fairview, NJ 07002 1-877-Systrum <a href="mailto:www.systrumenergy@aol.com">www.systrumenergy@aol.com</a>	<b>Metromedia Energy, Inc.</b> 6 Industrial Way Eatontown, NJ 07724 877-750-7046 <a href="http://www.metromediaenergy.com">www.metromediaenergy.com</a>	<b>Metro Energy Group, LLC</b> 14 Washington Place Hackensack, NJ 07601 888-57-Metro <a href="http://www.metroenergy.com">www.metroenergy.com</a>
<b>MxEnergy, Inc.</b> 510 Thornall Street, Suite 270 Edison, NJ 088327 800-375-1277 <a href="http://www.mxenergy.com">www.mxenergy.com</a>	<b>NATGASCO (Mitchell Supreme)</b> 572 Freeman Street Orange, NJ 07050 800-840-4GAS <a href="http://www.natgasco.com">www.natgasco.com</a>	<b>Pepco Energy Services, Inc.</b> 112 Main Street Lebanon, NJ 08833 800-363-7499 <a href="http://www.pepco-services.com">www.pepco-services.com</a>
<b>PPL EnergyPlus, LLC</b> 811 Church Road - Office 105 Cherry Hill, NJ 08002 800-281-2000 <a href="http://www.pplenergyplus.com">www.pplenergyplus.com</a>	<b>Sempra Energy Solutions</b> The Mac-Cali Building 581 Main Street, 8th fl. Woodbridge, NJ 07095 877-273-6772 800-2 SEMPRA <a href="http://www.semprasolutions.com">www.semprasolutions.com</a>	<b>South Jersey Energy Company</b> One South Jersey Plaza, Route 54 Folsom, NJ 08037 800-756-3749 <a href="http://www.sjindustries.com/sje.htm">www.sjindustries.com/sje.htm</a>
<b>Sprague Energy Corp.</b> 12 Ridge Road Chatham Township, NJ 05728 800-225-1560 <a href="http://www.spragueenergy.com">www.spragueenergy.com</a>	<b>Stuyvesant Energy LLC</b> 10 West Ivy Lane, Suite 4 Englewood, NJ 07631 800-646-6457 <a href="http://www.stuyfuel.com">www.stuyfuel.com</a>	<b>Woodruff Energy</b> 73 Water Street Bridgeton, NJ 08302 800-557-1121 <a href="http://www.woodruffenergy.com">www.woodruffenergy.com</a>