



ENERGY AUDIT – FINAL REPORT

MILLVILLE BOARD OF EDUCATION
CHILD FAMILY CENTER
1100 COOMBS ROAD
MILLVILLE, NJ 08332
ATTN: TONI BASICH
ASSISTANT SCHOOL BOARD
SECRETARY/PURCHASING

CEG PROJECT No. 9C09072

CONCORD ENGINEERING GROUP



520 SOUTH BURNT MILL ROAD
VOORHEES, NJ 08043
TELEPHONE: (856) 427-0200
FACSIMILE: (856) 427-6529
WWW.CEG-INC.NET

CONTACT: RAYMOND JOHNSON, PRINCIPAL
EMAIL: rjohnson@ceg-inc.net

Table of Contents

I.	EXECUTIVE SUMMARY	3
II.	INTRODUCTION	7
III.	METHOD OF ANALYSIS.....	8
IV.	HISTORIC ENERGY CONSUMPTION/COST.....	10
A.	ENERGY USAGE / TARIFFS	10
B.	ENERGY USE INDEX (EUI).....	15
C.	EPA ENERGY BENCHMARKING SYSTEM.....	17
V.	FACILITY DESCRIPTION	18
VI.	MAJOR EQUIPMENT LIST	20
VII.	ENERGY CONSERVATION MEASURES.....	21
VIII.	RENEWABLE/DISTRIBUTED ENERGY MEASURES	28
IX.	ENERGY PURCHASING AND PROCUREMENT STRATEGY	31
X.	INSTALLATION FUNDING OPTIONS.....	31
XI.	ADDITIONAL RECOMMENDATIONS	37
Appendix A – ECM Cost & Savings Breakdown		
Appendix B – New Jersey Smart Start® Program Incentives		
Appendix C – Portfolio Manager “Statement of Energy Performance”		
Appendix D – Major Equipment List		
Appendix E – Investment Grade Lighting Audit		
Appendix F – Renewable / Distributed Energy Measures Calculations		
Appendix G - Variable Speed Kitchen Hood		

REPORT DISCLAIMER

The information contained within this report, including any attachment(s), is intended solely for use by the named addressee(s). If you are not the intended recipient, or a person designated as responsible for delivering such messages to the intended recipient, you are not authorized to disclose, copy, distribute or retain this report, in whole or in part, without written authorization from Concord Engineering Group, Inc., 520 S. Burnt Mill Road, Voorhees, NJ 08043.

This report may contain proprietary, confidential or privileged information. If you have received this report in error, please notify the sender immediately. Thank you for your anticipated cooperation.

I. EXECUTIVE SUMMARY

This report presents the findings of the energy audit conducted for:

Millville Board of Education
Child Family Center
1100 Coombs Road
Millville, NJ 08332

Municipal Contact Person: Toni Basich
Facility Contact Person: Esteban Garcia

This audit is performed in connection with the New Jersey Clean Energy - Local Government Energy Audit Program. The energy audit is conducted to promote the mission of the office of Clean Energy, which is to use innovation and technology to solve energy and environmental problems in a way that improves the State's economy. This can be achieved through the wiser and more efficient use of energy.

The annual energy costs at this facility are as follows:

Electricity	\$185,770
Natural Gas	\$18,443
<hr/>	
Total	\$204,213

The potential annual energy cost savings for each energy conservation measure (ECM) and renewable energy measure (REM) are shown below in Table 1. Be aware that the ECM's and REM' are not additive because of the interrelation of some of the measures. This audit is consistent with an ASHRAE level 2 audit. The cost and savings for each measure is $\pm 20\%$. The evaluations are based on engineering estimations and industry standard calculation methods. More detailed analyses would require engineering simulation models, hard equipment specifications, and contractor bid pricing.

Table 1
Financial Summary Table

ENERGY CONSERVATION MEASURES (ECM's)					
ECM NO.	DESCRIPTION	NET INSTALLATION COST^A	ANNUAL SAVINGS^B	SIMPLE PAYBACK (Yrs)	SIMPLE LIFETIME ROI
ECM #1	Lighting Controls	\$11,760	\$3,582	3.3	356.9%
ECM #2	Demand Control Ventilation	\$177,000	\$4,813	36.8	-59.2%
ECM #3	Variable Speed Kitchen Hood Upgrade	\$34,501	\$1,156	29.8	-49.7%
RENEWABLE ENERGY MEASURES (REM's)					
ECM NO.	DESCRIPTION	NET INSTALLATION COST	ANNUAL SAVINGS	SIMPLE PAYBACK (Yrs)	SIMPLE LIFETIME ROI
REM #1	Photovoltaic Panel Installation	\$786,600	\$55,615	14.1	6.1%

Notes: A. Cost takes into consideration applicable NJ Smart StartTM incentives.
 B. Savings takes into consideration applicable maintenance savings.

The estimated demand and energy savings for each ECM and REM is shown below in Table 2. The descriptions in this table correspond to the ECM's and REM's listed in Table 1.

Table 2
Estimated Energy Savings Summary Table

ENERGY CONSERVATION MEASURES (ECM's)				
ECM NO.	DESCRIPTION	ANNUAL UTILITY REDUCTION		
		ELECTRIC DEMAND (KW)	ELECTRIC CONSUMPTION (KWH)	NATURAL GAS (THERMS)
ECM #1	Lighting Controls	0.0	26934.0	0.0
ECM #2	Demand Control Ventilation	0.0	23760.0	1080.0
ECM #3	Variable Speed Kitchen Hood Upgrade	0.0	1857.0	590.0
RENEWABLE ENERGY MEASURES (REM's)				
ECM NO.	DESCRIPTION	ANNUAL UTILITY REDUCTION		
		ELECTRIC DEMAND (KW)	ELECTRIC CONSUMPTION (KWH)	NATURAL GAS (THERMS)
REM #1	Photovoltaic Panel Installation	14.1	115147.0	0.0

Concord Engineering Group (CEG) recommends proceeding with the implementation of all ECM's that provide a calculated simple payback at or under ten (10) years. The following Energy Conservation Measures are recommended for the facility:

- **ECM #1: Lighting Controls**

In addition to the ECMs, there are maintenance and operational measures that can provide significant energy savings and provide immediate benefit. The ECMs listed above represent investments that can be made to the facility which are justified by the savings seen overtime. However, the maintenance items and small operational improvements below are typically achievable with on site staff or maintenance contractors and in turn have the potential to provide substantial operational savings compared to the costs associated. The following are recommendations which should be considered a priority in achieving an energy efficient building:

1. Chemically clean the condenser and evaporator coils periodically to optimize efficiency. Poorly maintained heat transfer surfaces can reduce efficiency 5-10%.
2. Maintain all weather stripping on entrance doors.
3. Clean all light fixtures to maximize light output.
4. Provide more frequent air filter changes to decrease overall system power usage and maintain better IAQ.

All in all, incentives provide financial motivation and much needed support for the implementation of energy conservation measures. Along with the NJ Smart Start program, the Pay for Performance Program incentives, sponsored by NJ Clean Energy Program, are applicable for this facility. The existing average operating demand above 200 KW and high energy consumption qualifies for the Pay for Performance Program. The incentive based on a 15% electrical energy reduction for this facility would qualify for an additional \$14,625 in the Pay for Performance Program. If natural gas consumption could be reduced by 15% the resultant incentive would be approximately \$1,268. This would equate to a total incentive equal to approximately \$15,893. This option is one to consider for a whole-building approach to energy reduction. The Pay for Performance Program represents a significant commitment to energy reduction of a facility. This option should be reviewed in more detail with a Pay for Performance Program partner.

II. INTRODUCTION

The comprehensive energy audit covers the 88,000 square foot Child Family Center, which includes the following spaces: classrooms, multipurpose areas, a cafeteria and administration offices.

Electrical and natural gas utility information is collected and analyzed for one full year's energy use of the building. The utility information allows for analysis of the building's operational characteristics; calculate energy benchmarks for comparison to industry averages, estimated savings potential, and baseline usage/cost to monitor the effectiveness of implemented measures. A computer spreadsheet is used to calculate benchmarks and to graph utility information (see the utility profiles below).

The Energy Use Index (EUI) is established for the building. Energy Use Index (EUI) is expressed in British Thermal Units/square foot/year (BTU/ft²/yr), which is used to compare energy consumption to similar building types or to track consumption from year to year in the same building. The EUI is calculated by converting the annual consumption of all energy sources to BTU's and dividing by the area (gross square footage) of the building. Blueprints (where available) are utilized to verify the gross area of the facility. The EUI is a good indicator of the relative potential for energy savings. A low EUI indicates less potential for energy savings, while a high EUI indicates poor building performance therefore a high potential for energy savings.

Existing building architectural and engineering drawings (where available) are utilized for additional background information. The building envelope, lighting systems, HVAC equipment, and controls information gathered from building drawings allow for a more accurate and detailed review of the building. The information is compared to the energy usage profiles developed from utility data. Through the review of the architectural and engineering drawings a building profile can be defined that documents building age, type, usage, major energy consuming equipment or systems, etc.

The preliminary audit information is gathered in preparation for the site survey. The site survey provides critical information in deciphering where energy is spent and opportunities exist within a facility. The entire site is surveyed to inventory the following to gain an understanding of how each facility operates:

- Building envelope (roof, windows, etc.)
- Heating, ventilation, and air conditioning equipment (HVAC)
- Lighting systems and controls
- Facility-specific equipment

The building site visit is performed to survey all major building components and systems. The site visit includes detailed inspection of energy consuming components. Summary of building occupancy schedules, operating and maintenance practices, and energy management programs provided by the building manager are collected along with the system and components to determine a more accurate impact on energy consumption.

III. METHOD OF ANALYSIS

Post site visit work includes evaluation of the information gathered, researching possible conservation opportunities, organizing the audit into a comprehensive report, and making recommendations on HVAC, lighting and building envelope improvements. Data collected is processed using energy engineering calculations to anticipate energy usage for each of the proposed energy conservation measures (ECMs). The actual building's energy usage is entered directly from the utility bills provided by the owner. The anticipated energy usage is compared to the historical data to determine energy savings for the proposed ECMs.

It is pertinent to note, that the savings noted in this report are not additive. The savings for each recommendation is calculated as standalone energy conservation measures. Implementation of more than one ECM may in some cases affect the savings of each ECM. The savings may in some cases be relatively higher if an individual ECM is implemented in lieu of multiple recommended ECMs. For example implementing reduced operating schedules for inefficient lighting will result in a greater relative savings. Implementing reduced operating schedules for newly installed efficient lighting will result in a lower relative savings, because there is less energy to be saved. If multiple ECM's are recommended to be implemented, the combined savings is calculated and identified appropriately.

ECMs are determined by identifying the building's unique properties and deciphering the most beneficial energy saving measures available that meet the specific needs of the facility. The building construction type, function, operational schedule, existing conditions, and foreseen future plans are critical in the evaluation and final recommendations. Energy savings are calculated base on industry standard methods and engineering estimations. Energy consumption is calculated based on manufacturer's cataloged information when new equipment is proposed.

Cost savings are calculated based on the actual historical energy costs for the facility. Installation costs include labor and equipment costs to estimate the full up-front investment required to implement a change. Costs are derived from Means Cost Data, industry publications, and local contractors and equipment suppliers. The NJ Smart Start Building® program incentives savings (where applicable) are included for the appropriate ECM's and subtracted from the installed cost. Maintenance savings are calculated where applicable and added to the energy savings for each ECM. The life-time for each ECM is estimated based on the typical life of the equipment being replaced or altered. The costs and savings are applied and a simple payback, simple lifetime savings, and simple return on investment are calculated. See below for calculation methods:

ECM Calculation Equations:

$$\text{Simple Payback} = \left(\frac{\text{Net Cost}}{\text{Yearly Savings}} \right)$$

$$\text{Simple Lifetime Savings} = (\text{Yearly Savings} \times \text{ECM Lifetime})$$

$$\text{Simple Lifetime ROI} = \frac{(\text{Simple Lifetime Savings} - \text{Net Cost})}{\text{Net Cost}}$$

$$\text{Lifetime Maintenance Savings} = (\text{Yearly Maintenance Savings} \times \text{ECM Lifetime})$$

$$\text{Internal Rate of Return} = \sum_{n=0}^N \left(\frac{\text{Cash Flow of Period}}{(1 + \text{IRR})^n} \right)$$

$$\text{Net Present Value} = \sum_{n=0}^N \left(\frac{\text{Cash Flow of Period}}{(1 + \text{DR})^n} \right)$$

Net Present Value calculations based on Interest Rate of 3%.

IV. HISTORIC ENERGY CONSUMPTION/COST

A. Energy Usage / Tariffs

The energy usage for the facility has been tabulated and plotted in graph form as depicted within this section. Each energy source has been identified and monthly consumption and cost noted per the information provided by the Owner.

The electric usage profile represents the actual electrical usage for the facility. Atlantic City Electric provides electricity to the facility under their Basic General Service (BGS) rate structure. The electric utility measures consumption in kilowatt-hours (KWH) and maximum demand in kilowatts (KW). One KWH usage is equivalent to 1000 watts running for one hour. One KW of electric demand is equivalent to 1000 watts running at any given time. The basic usage charges are shown as generation service and delivery charges along with several non-utility generation charges. Rates used in this report reflect the historical data received for the facility.

The gas usage profile shows the actual natural gas energy usage for the facility. South Jersey Natural Gas provides the natural gas to the facility under the Basic General Supply Service (BGSS) rate structures. The gas utility measures consumption in cubic feet x 100 (CCF), and converts the quantity into Therms of energy. One Therm is equivalent to 100,000 BTUs of energy.

The third party commodity provider PEPCO Energy Service, Co is responsible for providing the commodities of Natural Gas to the Board of Education. Commodity and delivery is billed separately for each respective utility service.

<u>Description</u>	<u>Average</u>
Electricity	13.3¢ / kWh
Natural Gas	\$1.53 / Therm

Table 3
Electricity Billing Data

ELECTRIC USAGE SUMMARY			
Utility Provider: Atlantic City Electric Rate: Annual General Service (AGS) Meter No: 80592320 Customer ID No: - Third Party Utility - TPS Meter / Acct No: -			
MONTH OF USE	CONSUMPTION KWH	DEMAND	TOTAL BILL
Jan-09	137,200	350.4	\$17,658
Feb-09	126,000	351.2	\$16,598
Mar-09	113,840	312.8	\$14,907
Apr-09	138,640	340.0	\$14,548
May-09	114,160	342.4	\$11,979
Jun-08	113,840	392.0	\$17,875
Jul-08	105,680	339.2	\$16,688
Aug-08	107,120	317.6	\$15,109
Sep-08	108,560	366.4	\$16,825
Oct-08	96,080	292.8	\$12,881
Nov-08	109,680	293.6	\$14,436
Dec-08	122,080	351.2	\$16,266
Totals	1,392,880	392.0 Max	\$185,770
AVERAGE DEMAND 337.5 KW average AVERAGE RATE \$0.133 \$/kWh			
Estimate Value, Utility Information Not Provided			

Figure 1
Electricity Usage Profile





Table 4
Natural Gas Billing Data

NATURAL GAS USAGE SUMMARY		
Utility Provider: South Jersey Gas Rate: BGSS Meter No: 450993 Point of Delivery ID: - Third Party Utility Provider: PEPCO Energy Services, Inc. TPS Meter No: -		
MONTH OF USE	CONSUMPTION (THERMS)	TOTAL BILL
Jan-09	3,379.00	\$5,045
Feb-09	2,697.00	\$4,121
Mar-09	1,008.00	\$1,551
Apr-09	670.00	\$1,047
May-09	224.00	\$363
Jun-08	107.00	\$221
Jul-08	74.00	\$169
Aug-08	74.00	\$139
Sep-08	171.00	\$280
Oct-08	361.00	\$521
Nov-08	1,140.00	\$1,755
Dec-08	2,179.00	\$3,231
TOTALS	12,084.00	\$18,443.03
AVERAGE RATE:	\$1.526	\$/THERM
Estimate Value, Utility Information Not Provided		

Figure 2
Natural Gas Usage Profile



B. Energy Use Index (EUI)

Energy Use Index (EUI) is a measure of a building's annual energy utilization per square foot of building. This calculation is completed by converting all utility usage consumed by a building for one year, to British Thermal Units (BTU) and dividing this number by the building square footage. EUI is a good measure of a building's energy use and is utilized regularly for comparison of energy performance for similar building types. The Oak Ridge National Laboratory (ORNL) Buildings Technology Center under a contract with the U.S. Department of Energy maintains a Benchmarking Building Energy Performance Program. The ORNL website determines how a building's energy use compares with similar facilities throughout the U.S. and in a specific region or state.

Source use differs from site usage when comparing a building's energy consumption with the national average. Site energy use is the energy consumed by the building at the building site only. Source energy use includes the site energy use as well as all of the losses to create and distribute the energy to the building. Source energy represents the total amount of raw fuel that is required to operate the building. It incorporates all transmission, delivery, and production losses, which allows for a complete assessment of energy efficiency in a building. The type of utility purchased has a substantial impact on the source energy use of a building. The EPA has determined that source energy is the most comparable unit for evaluation purposes and overall global impact. Both the site and source EUI ratings for the building are provided to understand and compare the differences in energy use.

The site and source EUI for this facility is calculated as follows:

$$\text{Building Site EUI} = \frac{(\text{Electric Usage in kBtu} + \text{Gas Usage in kBtu})}{\text{Building Square Footage}}$$


$$\text{Building Source EUI} = \frac{(\text{Electric Usage in kBtu} \times \text{SS Ratio} + \text{Gas Usage in kBtu} \times \text{SS Ratio})}{\text{Building Square Footage}}$$

Table 5
Facility Energy Use Index (EUI) Calculation

ENERGY USE INTENSITY CALCULATION						
ENERGY TYPE	BUILDING USE			SITE ENERGY kBtu	SITE-SOURCE RATIO	SOURCE ENERGY kBtu
	kWh	Therms	Gallons			
ELECTRIC	1392880.0			4,755,292	3.340	15,882,676
NATURAL GAS		12084.0		1,208,400	1.047	1,265,195
FUEL OIL			0.0	0	1.010	0
PROPANE			0.0	0	1.010	0
TOTAL				5,963,692		17,147,871
*Site - Source Ratio data is provided by the Energy Star Performance Rating Methodology for Incorporating Source Energy Use document issued Dec 2007.						
BUILDING AREA		88,000	SQUARE FEET			
BUILDING SITE EUI		67.77	kBtu/SF/YR			
BUILDING SOURCE EUI		194.86	kBtu/SF/YR			

Figure 3 below depicts a national EUI grading for the source use of an Elementary School.

Figure 3
Source Energy Use Intensity Distributions: Elementary School



C. EPA Energy Benchmarking System

The United States Environmental Protection Agency (EPA) in an effort to promote energy management has created a system for benchmarking energy use amongst various end users. The benchmarking tool utilized for this analysis is entitled Portfolio Manager. The Portfolio Manager tool allows tracking and assessment of energy consumption via the template forms located on the ENERGY STAR website (www.energystar.gov). The importance of benchmarking for local government municipalities is becoming more important as utility costs continue to increase and emphasis is being placed on carbon reduction, greenhouse gas emissions and other environmental impacts.

Based on information gathered from the ENERGY STAR website, Government agencies spend more than \$10 billion a year on energy to provide public services and meet constituent needs. Furthermore, energy use in commercial buildings and industrial facilities is responsible for more than 50 percent of U.S. carbon dioxide emissions. It is vital that local government municipalities assess facility energy usage, benchmark energy usage utilizing Portfolio Manager, set priorities and goals to lessen energy usage and move forward with priorities and goals.

In accordance with the Local Government Energy Audit Program, CEG has created an ENERGY STAR account for the municipality to access and monitoring the facility's yearly energy usage as it compares to facilities of similar type. The login page for the account can be accessed at the following web address; the username and password are also listed below:

<https://www.energystar.gov/istar/pmpam/index.cfm?fuseaction=login.login>

User Name: millvilleboe
Password: lgeaceg2009

Security Question: What city were you born in?
Security Answer: "millville"

The utility bills and other information gathered during the energy audit process are entered into the Portfolio Manager. The following is a summary of the results for the facility:

Table 6
ENERGY STAR Performance Rating

ENERGY STAR PERFORMANCE RATING		
FACILITY DESCRIPTION	ENERGY PERFORMANCE RATING	NATIONAL AVERAGE
Child Family Center	18	50

Refer to **Statement of Energy Performance Appendix** for the detailed energy summary.

V. FACILITY DESCRIPTION

The 88,000 SF Child Family Center is a two story facility comprised of a classrooms, cafeteria, kitchen, multi-purpose room and administration/faculty offices. The typical hours of operation for this facility are between 8:00 am and 12:00 am. Exterior walls are brick and metal frame construction with 2" of rigid polystyrene insulation. The windows throughout the facility are in good condition and appear to be maintained. Typical windows throughout the facility are double pane, 1/4" clear glass with aluminum frames. Blinds are utilized through the facility per occupant comfort. The blinds are valuable because they help to reduce heat loss in the winter and reduce solar heat gain in the summer. The A-frame roofs on the structure are typical metal roofing and are painted white to reduce solar heat gain. The flat sections of the roof are typical built up rubber construction with light gray stone covering. The amount of insulation below the roofing is unknown. The building was built in 2005 with no additions since the original construction.

HVAC Systems

Heating and cooling is provided to the facility via a conventional water-source heat pump system. Vertical Mammoth heat pumps are located throughout the facility in heat pump closets adjacent to the room they serve; heat pumps vary in size depending on the space being conditioned. Pre-conditioned ventilation air is provided to each heat pump by one of five (5) Des Champs Roof Top Units (RTU's). The condenser water loop is tempered by a hot water boiler plant and cooling tower. Two (2) 1,656 MBH Weil McLain, Series 88 gas fired hot water boilers provide heat to the loop in the heating season. A 202 Ton Baltimore Aircoil cooling tower is utilized to cool the condenser loop during the cooling season.

HVAC System Controls

The HVAC system within the facility is controlled via a Honeywell control system. The Honeywell Company monitors and controls the system from a central plant offsite. All building equipment utilizes electronic controls.

Domestic Hot Water

Domestic hot water for the facility is provided by two (2) separate hot water heaters. The first a 140 gallon AO Smith Custom natural gas fired hot water heater, capacity of 140 MBH. The second 75 gallon AO Smith Preferred natural gas fired hot water heater, capacity of 78 MBH. The domestic hot water is circulated throughout the building by an Allan Pump Circ hot water re-circ pump system. The circulation pump is controlled by an aqua stat. The domestic hot water piping insulation appeared to be in good condition.

Lighting

Typical lighting throughout the building is fluorescent tube lay-in fixtures with T-8 lamps and electronic ballasts. Storage rooms and closets are lit with a mixture of incandescent lamps and compact fluorescent lamps. A detailed list containing all building light fixtures can be found in the **Investment Grade Lighting Audit Appendix** of this report.

VI. MAJOR EQUIPMENT LIST

The equipment list is considered major energy consuming equipment and through energy conservation measures could yield substantial energy savings. The list shows the major equipment in the facility and all pertinent information utilized in energy savings calculations. An approximate age was assigned to the equipment in some cases if a manufactures date was not shown on the equipment's nameplate. The ASHRAE service life for the equipment along with the remaining useful life is also shown in the Appendix.

Refer to the **Major Equipment List Appendix** for this facility.

VII. ENERGY CONSERVATION MEASURES

ECM #1: Lighting Controls

Description:

In some areas the lighting is left on unnecessarily. In many cases the lights are left on because of the inconvenience to manually switch lights on when the room is first occupied. This is common in storage rooms that are occupied for only short periods and only a few times per day. In some instances lights are left on due to the misconception that it is better to keep the lights on rather than to continuously switch lights on and off. Although increased switching reduces lamp life, the energy savings outweigh the lamp replacement costs. The payback timeframe for when to turn the lights off is approximately two minutes. If the lights are off for at least a two minute interval, then it pays to shut them off.

Lighting controls come in many forms. Sometimes an additional switch is adequate to provide reduced lighting levels when full light output is not needed. Occupancy sensors detect motion and will switch the lights on when the room is occupied. Occupancy sensors can either be mounted in place of a current wall switch, or on the ceiling to cover large areas. Photocell control senses light levels and turn off or reduce lights when there is adequate daylight. Photocells are mostly used outside, but are becoming more popular in energy-efficient interior lighting designs as well.

ASHRAE Standard 90.1-2004, Appendix G is a reference standard for modeling building efficiency. The standard estimates that lighting controls provide a 10% reduction in lighting power usage for daytime occupancies in buildings over 5,000 SF, and 15% reduction in buildings under 5,000 SF. This ECM implements dual technology occupancy sensors in classrooms (that are not already controlled), offices, private study rooms and storage areas.

The ECM includes replacement of standard wall switches with sensors wall switches for individual rooms, ceiling mount sensors for large areas or restrooms. Sensors shall be manufactured by Sensorswitch, Watt Stopper or equivalent.

The “Investment Grade Lighting Audit” appendix of this indicates which areas of the facility would benefit from lighting control. The calculations adjust the lighting power usage by 10% for all areas that include occupancy sensor lighting controls.

Energy Savings Calculations:

$$\text{Energy Savings} = 10\% \times \text{Occupancy Sensored Light Energy (kWh / Yr)}$$

$$\text{Energy Savings} = 10\% \times 269,345 \text{ (kWh)} = 26,934 \text{ (kWh)}$$

$$\text{Savings.} = \text{Energy Savings (kWh)} \times \text{Ave Elec Cost} \left(\frac{\$}{\text{kWh}} \right)$$

$$\text{Savings} = 26,934 \text{ (kWh)} \times 0.133 \left(\frac{\$}{\text{kWh}} \right) = \$3,582$$

Installation cost per dual-technology sensor (Basis: Sensorswitch or equivalent) is \$160/unit including material and labor.

$$\text{Installation Cost} = (\# \text{ of sensors} \times \$ \text{ per sensor}) = (84 \times \$160) = \underline{\$13,440}$$

NJ Smart Start[®] Program Incentives are calculated as follows:

From Appendix C, the incentive for installing a lighting control is \$20 per controller.

$$\text{Smart Start}^{\circledR} \text{ Incentive} = (\# \text{ of controller} \times \$ 20) = (84 \times \$ 20) = \underline{\$1,680}$$

Energy Savings Summary:

ECM #1 - ENERGY SAVINGS SUMMARY	
Installation Cost (\$):	\$13,440
NJ Smart Start Equipment Incentive (\$):	\$1,680
Net Installation Cost (\$):	\$11,760
Maintenance Savings (\$/Yr):	\$0
Energy Savings (\$/Yr):	\$3,582
Total Yearly Savings (\$/Yr):	\$3,582
Estimated ECM Lifetime (Yr):	15
Simple Payback	3.3
Simple Lifetime ROI	356.9%
Simple Lifetime Maintenance Savings	\$0
Simple Lifetime Savings	\$53,730
Internal Rate of Return (IRR)	30%
Net Present Value (NPV)	\$31,001.68

ECM #2: Demand Control Ventilation

Description:

The existing roof top dedicated outdoor air units provide outside air to the space through. The outside air is set to a minimum damper position to provide outside air to the space whenever the supply fan is set to run (in occupied mode). Unoccupied mode the outside air dampers shut. This operation is typical for the majority of the systems throughout the building. The outside air volume is typically based on the maximum occupancy of the space conditioned. When a given space is not fully occupied the outside air quantity delivered to the space is greater than the amount needed for adequate ventilation.

This ECM includes the installation of CO₂ sensors integrated into a demand control ventilation system. This system allows the air handling unit to respond to changes in occupancy and therefore reduce the amount of outside air that has to be conditioned. Outside air accounts for a large portion of the energy consumption in the HVAC system, especially in high occupancy spaces. The U.S. Department of Energy sponsored a study to analyze energy savings achieved through various types of building system controls. The referenced savings is based on the “Advanced Sensors and Controls for Building Applications: Market Assessment and Potential R&D Pathways,” document posted for public use April 2005. The study has found that commercial buildings have the potential to achieve significant energy savings through the use of building controls. The average energy savings are as follows based on the report:

- Demand Control Ventilation - 10%-15%.

Energy savings achieved through “Demand Control Ventilation” average 10%-15%. Savings resulting from the implementation of this ECM for energy management controls are estimated to be 10% of the total HVAC energy cost for the facility.

The components included to install a demand control ventilation system include controllers, software programming, and CO₂ sensors. Each occupied zone would require a CO₂ sensor installed to monitor occupancy levels. This ECM is based on wireless sensors to minimize on installation cost. Savings from the implementation of this ECM will be achieved through reduced gas consumption from reduced heating energy as well as reduced electric consumption from reduced air conditioning energy.

Cost of Demand Control Ventilation System Controls = (\$1.50/SF x 88,000 SF) = \$132,000.

Cost of CO₂ Sensors for all spaces = (\$450/Sensor x 100 Sensors) = \$45,000

Total = \$177,000

Total Gas Usage = 12,084 Therms

Estimated non-Heat gas usage (Dom HW) = 106.5 Therms*

(*50% of Gas usage averaged from Jun, Jul, Aug & Sept. gas usage)

Average Cost of Gas = \$1.53/Therm

Total Cooling Capacity = 110 tons

(total from equipment list)	
Cooling Season Full Load Cooling Hrs.	= 1,800 hrs/yr.
Average Cooling Equipment EER	= 10 EER
(Est. based on all equipment)	
Average Cost of Electricity	= \$0.146/kWh

Energy Savings Calculations:

Heating Savings Calculations

$$\text{Gas Heat Usage} = \text{Total Cons. (Therms)} - \left(\text{Est. Dom. HW Use} \left(\frac{\text{Therms}}{\text{Month}} \right) \times \text{Use} \left(\frac{\text{Months}}{\text{Yr}} \right) \right)$$

$$\text{Gas Heat Usage} = 12,084 \text{ (Therms)} - \left(106.5 \left(\frac{\text{Therms}}{\text{Month}} \right) \times 12 \left(\frac{\text{Months}}{\text{Yr}} \right) \right) = 10,806 \text{ (Therms)}$$

$$\text{Savings.} = \text{Heating Input (Gallons)} \times 10\% \text{ Savings} \times \text{Ave Oil Cost (\$/Therm)}$$

$$\text{Savings.} = 10,806 \text{ (Therms)} \times 10\% \times 1.53 \text{ (\$/Therm)} = \underline{\$1,653}$$

Cooling Savings Calculations

$$\text{Est Cool Cons.} = \frac{\text{Cool Load (Tons)} \times 12,000 \left(\frac{\text{Btu}}{\text{Ton Hr}} \right) \times \text{Full Load Cooling Hrs.}}{\text{Ave Energy Efficiency Ratio} \left(\frac{\text{Btu}}{\text{Wh}} \right) \times 1000 \left(\frac{\text{Wh}}{\text{kWh}} \right)}$$

$$\text{Est Cool Cons.} = \frac{110 \text{ (Tons)} \times 12,000 \left(\frac{\text{Btu}}{\text{Ton Hr}} \right) \times 1800 \text{ Hrs.}}{10 \left(\frac{\text{Btu}}{\text{Wh}} \right) \times 1000 \left(\frac{\text{Wh}}{\text{kWh}} \right)} = 237,600 \text{ (kWh)}$$

$$\text{Savings.} = \text{Cool Cons. (kWh)} \times 10\% \text{ Savings} \times \text{Ave Elec Cost} \left(\frac{\$}{\text{kWh}} \right)$$

$$\text{Savings.} = 237,600 \text{ (kWh)} \times 10\% \times 0.133 \left(\frac{\$}{\text{kWh}} \right) = \underline{\$3,160}$$

$$\text{Total ECM Savings} = \$1,653 + \$3,160 = \underline{\$4,813}$$

Energy Savings Summary:

ECM #2 - ENERGY SAVINGS SUMMARY	
Installation Cost (\$):	\$177,000
NJ Smart Start Equipment Incentive (\$):	\$0
Net Installation Cost (\$):	\$177,000
Maintenance Savings (\$/Yr):	\$0
Energy Savings (\$/Yr):	\$4,813
Total Yearly Savings (\$/Yr):	\$4,813
Estimated ECM Lifetime (Yr):	15
Simple Payback	36.8
Simple Lifetime ROI	-59.2%
Simple Lifetime Maintenance Savings	\$0
Simple Lifetime Savings	\$72,195
Internal Rate of Return (IRR)	-10%
Net Present Value (NPV)	(\$119,542.72)

ECM #3: Variable Speed Kitchen Hood Upgrade

Description:

Standard kitchen hood controls consist of switches and relays that interlock the kitchen grease hood exhaust fan(s) with the 100% outside air unit that provides make-up air for this system. Normal occupation of kitchen hood system is limited to occupied hours. There is great potential energy savings through better control of the hood exhaust fan(s) and make-up air unit. The two (2) 1 1/2 HP kitchen exhaust fans consumes large amounts of electricity when operating and if controlled properly, the energy consumption can be greatly reduced.

This energy conservation measure would install a Melink Kitchen Hood Variable Air Volume Controller; variable frequency drive on the make-up air supply fan along with the kitchen hood exhaust fan; and turn off all the kitchen hood exhaust systems when the kitchen is closed. When the cooking appliances are turned on, the hood exhaust fan speed will increase based on the hood exhaust temperature. During actual cooking, the kitchen hood exhaust fan increases to 100% speed until the smoke/vapor is removed. Energy savings are also realized when the kitchen equipment is operating at less than full load due to reduced cooking temperature. During these times the fan speed decreases, removing only the necessary amount of air, saving energy.

Energy Savings Calculations:

Detailed calculation and cost break down for the proposed kitchen hood control system can be found in **Variable Speed Kitchen Exhaust Appendix**. It is pertinent to note that the calculation assumes the exhaust fans and make-up air unit are manually turned off for approximately 18 hours per day.

$$\begin{aligned}\text{Smart Start}^{\circledR} \text{ Incentive (VFD < 10HP)} &= (\text{HP} \times \text{VFD Incentive}) \\ &= 2 \times (1 \frac{1}{2} \text{ HP} \times \$155 / \text{HP}) + (1 \frac{1}{2} \text{ HP} \times \$155 / \text{HP}) = \underline{\$542}\end{aligned}$$

$$\begin{aligned}\text{Smart Start}^{\circledR} \text{ Incentive (Premium Eff Motors)} &= (\$ \text{ for HP}) \\ &= 2 \times (1 \frac{1}{2} \text{ HP for } \$54) + (1 \frac{1}{2} \text{ HP for } \$54) = \underline{\$162}\end{aligned}$$

$$\text{Total Smart Start Incentive} = \$542 + \$162 = \underline{\$704}$$

Energy Savings Summary:

ECM #3 - ENERGY SAVINGS SUMMARY	
Installation Cost (\$):	\$35,205
NJ Smart Start Equipment Incentive (\$):	\$704
Net Installation Cost (\$):	\$34,501
Maintenance Savings (\$/Yr):	\$0
Energy Savings (\$/Yr):	\$1,156
Total Yearly Savings (\$/Yr):	\$1,156
Estimated ECM Lifetime (Yr):	15
Simple Payback	29.8
Simple Lifetime ROI	-49.7%
Simple Lifetime Maintenance Savings	\$0
Simple Lifetime Savings	\$17,340
Internal Rate of Return (IRR)	-8%
Net Present Value (NPV)	(\$20,700.75)

VIII. RENEWABLE/DISTRIBUTED ENERGY MEASURES

Globally, renewable energy has become a priority affecting international and domestic energy policy. The State of New Jersey has taken a proactive approach, and has recently adopted in its Energy Master Plan a goal of 30% renewable energy by 2020. To help reach this goal New Jersey created the Office of Clean Energy under the direction of the Board of Public Utilities and instituted a Renewable Energy Incentive Program to provide additional funding to private and public entities for installing qualified renewable technologies. A renewable energy source can greatly reduce a building's operating expenses while producing clean environmentally friendly energy. CEG has assessed the feasibility of installing renewable energy technologies for the Millville Board of Education, to evaluate if there is any potential for solar or wind energy generation.

Solar energy produces clean energy and reduces a building's carbon footprint. This is accomplished via photovoltaic panels which can be mounted on all south and southwestern facades of the building. Flat roof, as well as sloped areas can be utilized; flat areas will have the panels turned to an optimum solar absorbing angle. (A structural survey of the roof would be necessary before the installation of PV panels is considered). Parking lots can also be utilized for the installation of a solar array. A truss system can be installed that is high enough to park a vehicle under the array, this way no parking lot area is lost. The state of NJ has instituted a program in which one Solar Renewable Energy Certificate (SREC) is given to the Owner for every 1000 kWh of generation. SREC's can be sold anytime on the market at their current market value. The value of the credit varies upon the current need of the power companies. The average value per credit is around \$350, this value was used in our financial calculations. This equates to \$0.35 per kWh generated.

CEG has reviewed the facility and believes a roof mounted system is best suited. A depiction of the proposed area layouts is shown in **Renewable / Distributed Energy Measures Calculation, Appendix**. Based on measurements of the roof it was determined that a system size of 87.4 kilowatts could be installed. The total system has an estimated kilowatt hour production of 115,147 KWh annually, reducing the overall electric consumption by approximately 8%. A detailed financial analysis can be found in **Renewable / Distributed Energy Measures Calculation, Appendix**. This analysis illustrates the payback of the system over a 25 year period. The eventual degradation of the solar panels and the price of accumulated SREC's are factored into the payback.

The proposed photovoltaic array layout is designed based on the specifications for the Sun Power SPR-230 panel. This panel has a "DC" rated full load output of 230 watts, and has a total panel conversion efficiency of 18%. Although panels rated at higher wattages are available through Sun Power and other various manufacturers, in general most manufacturers who produce commercially available solar panels produce a similar panel in the 200 to 250 watt range. This provides more manufacturer options to the public entity if they wish to pursue the proposed solar recommendation without losing significant system capacity.

The array system capacity was sized on available parking lot space on the campus. Estimated solar array generation was then calculated based on the National Renewable Energy Laboratory

PVWatts Version 1.0 Calculator. In order to calculate the array generation an appropriate location with solar data on file must be selected. In addition the system DC rated kilowatt (kW) capacity must be inputted, a DC to AC de-rate factor, panel tilt angle, and array azimuth angle. The DC to AC de-rate factor is based on the panel nameplate DC rating, inverter and transformer efficiencies (95%), mismatch factor (98%), diodes and connections (100%), dc and ac wiring (98%, 99%), soiling, (95%), system availability (95%), shading (if applicable), and age (new/100%). The overall DC to AC de-rate factor has been calculated at an overall rating of 81%. The PVWatts Calculator program then calculates estimated system generation based on average monthly solar irradiance and user provided inputs. The monthly energy generation and offset electric costs from the PVWatts calculator is shown in the Renewable/Distributed Energy Measures Calculation appendix.

The proposed solar array is qualified by the New Jersey Board of Public Utilities Net Metering Guidelines as a Class I Renewable Energy Source. These guidelines allow onsite customer generation using renewable energy sources such as solar and wind with a capacity of 2 megawatts (MW) or less. This limits a customer system design capacity to being a net user and not a net generator of electricity on an annual basis. Although these guidelines state that if a customer does not generate (produce more electricity than they use), the customer will be credited those kilowatt-hours generated to be carried over for future usage on a month to month basis. Then, on an annual basis if the customer is a net generator the customer will then be compensated by the utility the average annual PJM Grid LMP price per kilowatt-hour for the over generation. Due to the aforementioned legislation, the customer is at limited risk if they generate more than they use at times throughout the year. With the inefficiency of today's energy storage systems, such as batteries, the added cost of storage systems is not warranted and was not considered in the proposed design.

Direct purchase involves the BOE paying for 100% of the total project cost upfront via one of the methods noted in the Installation Funding Options section below. Calculations include a utility inflation rate as well as the degradation of the solar panels over time. Based on our calculations the following is the payback period:

FINANCIAL SUMMARY - PHOTOVOLTAIC SYSTEM				
PAYMENT TYPE	SIMPLE PAYBACK	SIMPLE ROI	NET PRESENT VALUE	INTERNAL RATE OF RETURN
Direct Purchase	14.14 Years	7.1%	\$697,892	5.4 %

*The solar energy measure is shown for reference in the executive summary REM table as REM#1.

Given the large amount of capital required by the BOE to invest in a solar system through a Direct Purchase CEG does not recommend the BOE pursue this route. It would be more advantageous for the BOE to solicit Power Purchase Agreement (PPA) Providers who will own, operate, and maintain the system for a period of 15 years. During this time the PPA Provider would sell all of the electric generated by Solar Arrays to the BOE at a reduced rate compared to their existing electric rate.

In addition to the Solar Analysis, CEG also conducted a review of the applicability of wind energy for the facility. Wind energy production is another option available through the Renewable Energy Incentive Program. Wind turbines of various types can be utilized to produce clean energy on a per building basis. Cash incentives are available per kWh of electric usage. CEG's review of the applicability of wind energy for the facility found; the low average wind speed and proximity to residential neighborhoods make facility a poor candidate for wind energy production.

IX. ENERGY PURCHASING AND PROCUREMENT STRATEGY

Load Profile:

Load Profile analysis was performed to determine the seasonal energy usage of the facility. Irregularities in the load profile will indicate potential problems within the facility. Consequently based on the profile a recommendation will be made to remedy the irregularity in energy usage. For this report, the facility's energy consumption data was gathered in table format and plotted in graph form to create the load profile. Refer to the Electric and Natural Gas Usage Profiles included within this report to reference the respective electricity and natural gas usage load profiles.

Electricity:

This facility is comprised of classrooms, cafeteria, kitchen, multi-purpose room, and administration/faculty offices. The typical hours of operation for this facility are 8:00 a.m. to 12:00 a.m. This building was constructed in 2005 with no new renovations.

The Electric Usage Profile demonstrates a very flat or consistent load consumption profile throughout the year. For a school this would not be a typical load profile, however since this is a family center with long operation hours, it is understandable. Cooling in this facility is provided through a conventional water source heat pump system. Vertical Mammoth heat pumps are located throughout the facility. (5) roof-top units provide conditioned air to each heat pump. The condenser water loop is tempered by a hot water boiler plant and cooling tower. A 202 ton cooling tower is utilized to cool the condenser loop during the cooling season. This facility receives its electric delivery service via Atlantic City Electric (ACE) on an AGS rate schedule. This facility receives its electric commodity service from South Jersey Energy Company through the ACES agreement. A flat (base-load) shaping is important because it will yield more competitive pricing when shopping for alternative energy supply.

Natural Gas:

The Natural Gas Usage Profile demonstrates a very typical heating load profile, with increasing consumption in the winter months (October – March) and a dramatic drop in consumption in the summer months (May – September). Heating is the obvious reason for the winter consumption and in this facility heating is supplied via a conventional water source heat pump system (as is the cooling). Vertical Mammoth heat pumps are located throughout the facility. The condenser loop is tempered by a hot water boiler plant and cooling tower. Two (2) Weil McLain natural gas-fired hot water boilers provide heat to the loop during heating season. Domestic hot water for this facility is provided by two (2) separate hot water heaters. An A.O. Smith natural gas-fired hot water heater with 140 gallon capacity and an A.O. Smith natural gas-fired hot water heater with 75 gallon capacity. Natural gas delivery service in this facility is provided by South Jersey Gas Company on a GSG rate schedule. The natural gas commodity service is provided by PEPCO Energy Services through the ACES agreement. A flat load profile will always allow for the most competitive price available when shopping for alternative energy supplies.

Tariff Analysis:**Electricity:**

This facility receives electrical delivery Service from Atlantic City Electric on an AGS Secondary (Annual General Service) utility rate. This rate is available at any point in the utility's system where facilities of adequate character and capacity exist for the entire electric service requirements of any customer contracting for annual service delivered at one point and metered at or compensated to the voltage of delivery. This delivery service includes the following charges: Delivery Service Charges, Distribution Demand Charges, Reactive Demand Charges, Distribution Rates, Non-Utility Generation Charges, Societal Benefits Charges, Regulatory Assets Recovery Charges, Transition Bond Charges, Market Transition Charge Tax, Transmission Demand Charge, Regional Greenhouse Gas Initiative Recovery Charge, and Infrastructure Investment Surcharge.

This facility receives electrical supply service through the ACES agreement (Alliance for Competitive Energy Services). ACES, is an alliance composed of the NJSBA and the NJASBO and is administered by Gable Associates. CEG believes that if the BOE wants to procure alternative energy, they must through the ACES agreement. CEG will make a recommendation that is counter to this agreement. The term of the ACES agreement is the first meter read date on or after April 30, 2009 until the last meter read date, May, 2011.

The ACES agreement provides for NJSBA to adopt a resolution for renewal for no more than a (5) consecutive year term. CEG will recommend against such renewal and believes that a 5 – year term may not be allowed under local government law.

Natural Gas:

This facility is serviced by South Jersey Gas Company (SJG) on its firm delivery rate, General Service Gas (GSG) from the utility and BGSS (Basic Generation Supply Service) when not being served by a Third Party Supplier (TPS). Currently The BOE is procuring natural gas from a Third Party Supplier (TPS), PEPCO Energy Services. This Delivery Rate has the following charges: Customer Charge, Delivery Charge, BSC Volume Charge and Commodity Charge under this rate structure. The BGSS Supply rates are designed to recover SJG's cost of gas applicable to customers who purchase gas from SJG. The company earns no profit from BGSS. BGSS consists of two (2) pricing mechanisms: Residential and Commercial customers that use less than 5,000 therms annually and Commercial and Industrial customers that consume at least 5,000 therms annually.

Imbalances occur when Third Party Suppliers (TPS) are used to supply natural gas and full-delivery is not made, and when a new supplier is contracted or the customer returns to the utility. Note: It is important when utilizing a Third Party Supplier, that an experienced regional supplier is used, otherwise, imbalances can occur, jeopardizing economics and scheduling. If the supplier does not deliver they can be placed on a very costly rate. A customer can automatically be put on an alternative supply rate by the utility.

A “firm account” refers to the type of interstate pipeline service that the utility has subscribed for and delivered on behalf of the customer. Much like the telecom industry, the pipeline space (capacity) has been deregulated. The pipeline capacity is broken down into reliability of service. “Firm service” is the highest level of reliability and is the last, in pecking order, for interruption.

Recommendations:

CEG recommends a global approach that will be consistent with all facilities within the scope of this project. Therefore, CEG recommends aggregating all energy loads. CEG’s observations are seen in both the electric and natural gas costs. The average “price to compare” per kWh (kilowatt hour) for all buildings is \$.1058/ kWh (kWh is the common unit of electric measure). The average “price to compare” per decatherm for natural gas is \$10.90 /dth (dth is the common unit of measure). These Weighted Average Prices are as supplied via Third Party Suppliers (TPS) for electricity (South Jersey Energy Company) and for natural gas (PEPCO Energy services), as administered through the ACES (Alliance for Competitive Energy Services) and the lead agency, The New Jersey School Boards Association, with administration from Gable Associates.

Energy commodities are among the most volatile of all commodities, however at this point and time, energy is extremely competitive. The BOE could see significant savings if it were to take advantage of these current market prices quickly, before energy increases. Based on last year’s historical consumption (January – December 2009) and current electric rates, the BOE could see an improvement of up to 15 % or up to \$150,000 in its electric costs annually. (Note: Savings were calculated using an Average Annual Consumption of 9,776,921 kWh and an Average fixed one-year commodity contract). CEG recommends aggregating the entire electric load to gain the most optimal energy costs. CEG recommends that the BOE seek an energy advisor to maximize energy savings and to apply a “managed approach” to procuring energy.

CEG’s secondary recommendation coincides with the BOE’s natural gas costs. Based on the current market, (which is very competitive), the BOE could see a savings of over 20% or up to \$90,000 annually in its natural gas expenditures. Again, CEG recommends the use of any energy advisor to review alternative energy sourcing strategies and to install a “managed approach” to energy procurement.

CEG also recommends that The BOE not renew its energy supply contract with the ACES aggregation and PEPCO Energy Services, and the ACES agreement with South Jersey Energy and its fixed price contract. The fixed priced contract does not accomplish the needs of the BOE. The BOE needs budget protection and CEG has shown that these energy prices are not competitive to the market. The ACES agreement has demonstrated that the price is much above market and the BOE has no way of adjusting the price should prices fall.

CEG further recommends that the BOE create an energy program through a “managed approach.” The “managed approach” will take into account creating an “energy budget” that is in line with the BOE’s budget year and risk tolerance. Risk tolerance is the appetite that a customer has for risk. Based on the reduced state and local government budgets and the general aversion for risk, the local government is required to manage this risk.

CEG recommends the BOE schedule a meeting with their current utility providers to review their utility charges and current tariff structures for electricity and natural gas. This meeting would provide insight regarding alternative procurement options that are currently available. Through its meeting with the Local Distribution Company (LDC), they will learn more about the competitive supply process. They can acquire a list of approved Third Party Suppliers from the New Jersey Board of Public Utilities website at www.nj.gov/bpu, and should also consider using a billing-auditing service to further analyze the utility invoices, manage the data and use the data to manage ongoing demand-side management projects. Furthermore, CEG recommends special attention given to credit mechanisms, imbalances, balancing charges and commodity charges when meeting with their utility representative. In addition, the BOE should also ask the utility representative about alternative billing options. Some utilities allow for consolidated billing options when utilizing the service of a Third Party Supplier.

Finally, if the BOE frequently changes its supplier for energy, CEG recommends it closely monitor balancing, particularly when the contract is close to termination.

X. INSTALLATION FUNDING OPTIONS

CEG has reviewed various funding options for the facility owner to utilize in subsidizing the costs for installing the energy conservation measures noted within this report. Below are a few alternative funding methods:

- i. *Energy Savings Improvement Program (ESIP)* – Public Law 2009, Chapter 4 authorizes government entities to make energy related improvements to their facilities and pay for the costs using the value of energy savings that result from the improvements. The “Energy Savings Improvement Program (ESIP)” law provides a flexible approach that can allow all government agencies in New Jersey to improve and reduce energy usage with minimal expenditure of new financial resources.
- ii. *Municipal Bonds* – Municipal bonds are a bond issued by a city or other local government, or their agencies. Potential issuers of municipal bonds include cities, counties, redevelopment agencies, school districts, publicly owned airports and seaports, and any other governmental entity (or group of governments) below the state level. Municipal bonds may be general obligations of the issuer or secured by specified revenues. Interest income received by holders of municipal bonds is often exempt from the federal income tax and from the income tax of the state in which they are issued, although municipal bonds issued for certain purposes may not be tax exempt.
- iii. *Power Purchase Agreement* – Public Law 2008, Chapter 3 authorizes contractor of up to fifteen (15) years for contracts commonly known as “power purchase agreements.” These are programs where the contracting unit (Owner) procures a contract for, in most cases, a third party to install, maintain, and own a renewable energy system. These renewable energy systems are typically solar panels, windmills or other systems that create renewable energy. In exchange for the third party’s work of installing, maintaining and owning the renewable energy system, the contracting unit (Owner) agrees to purchase the power generated by the renewable energy system from the third party at agreed upon energy rates.
- iv. *Pay For Performance* – The New Jersey Smart Start Pay for Performance program includes incentives based on savings resulted from implemented ECMs. The program is available for all buildings with average demand loads above 200 KW. The facility’s participation in the program is assisted by an approved program partner. An “Energy Reduction Plan” is created with the facility and approved partner to show at least 15% reduction in the building’s current energy use. Multiple energy conservation measures implemented together are applicable toward the total savings of at least 15%. No more than 50% of the total energy savings can result from lighting upgrades / changes.

Total incentive is capped at 50% of the project cost. The program savings is broken down into three benchmarks; Energy Reduction Plan, Project

Implementation, and Measurement and Verification. Each step provides additional incentives as the energy reduction project continues. The benchmark incentives are as follows:

- 1. Energy Reduction Plan – Upon completion of an energy reduction plan by an approved program partner, the incentive will grant \$0.10 per square foot between \$5,000 and \$50,000, and not to exceed 50% of the facility's annual energy expense. (Benchmark #1 is not provided in addition to the local government energy audit program incentive.)*
- 2. Project Implementation – Upon installation of the recommended measures along with the "Substantial Completion Construction Report," the incentive will grant savings per KWH or Therm based on the program's rates. Minimum saving must be 15%. (Example \$0.11 / kWh for 15% savings, \$0.12/ kWh for 17% savings, ... and \$1.10 / Therm for 15% savings, \$1.20 / Therm for 17% saving, ...) Increased incentives result from projected savings above 15%.*
- 3. Measurement and Verification – Upon verification 12 months after implementation of all recommended measures, that actual savings have been achieved, based on a completed verification report, the incentive will grant additional savings per kWh or Therm based on the program's rates. Minimum savings must be 15%. (Example \$0.07 / kWh for 15% savings, \$0.08/ kWh for 17% savings, ... and \$0.70 / Therm for 15% savings, \$0.80 / Therm for 17% saving, ...) Increased incentives result from verified savings above 15%.*

CEG recommends the Owner review the use of the above-listed funding options in addition to utilizing their standard method of financing for facilities upgrades in order to fund the proposed energy conservation measures.

XI. ADDITIONAL RECOMMENDATIONS

The following recommendations include no cost/low cost measures, Operation & Maintenance (O&M) items, and water conservation measures with attractive paybacks. These measures are not eligible for the Smart Start Buildings incentives from the office of Clean Energy but save energy none the less.

- A. Chemically clean the condenser and evaporator coils periodically to optimize efficiency. Poorly maintained heat transfer surfaces can reduce efficiency 5-10%.
- B. Maintain all weather stripping on windows and doors.
- C. Clean all light fixtures to maximize light output.
- D. Provide more frequent air filter changes to decrease overall system power usage and maintain better IAQ.
- E. Confirm that outside air economizers on the rooftop units are functioning properly to take advantage of free cooling and avoid excess outside air during occupied periods.

ECM COST & SAVINGS BREAKDOWN
CONCORD ENGINEERING GROUP

Middleville Board of Education Child Family Center

ECM ENERGY AND FINANCIAL COSTS AND SAVINGS SUMMARY															
ECM NO.	DESCRIPTION	INSTALLATION COST			YEARLY SAVINGS			ECM LIFETIME	LIFETIME ENERGY SAVINGS	LIFETIME MAINTENANCE SAVINGS	LIFETIME ROI	SIMPLE PAYBACK	INTERNAL RATE OF RETURN	NET PRESENT VALUE (NPV)	
		MATERIAL	LABOR	REBATES, INCENTIVES	NET INSTALLATION COST	ENERGY	TOTAL								
							MAINT. / SRECC								MAINT. / SRECC
		(\$)	(\$)	(\$)	(\$)	(\$/yr)	(\$/yr)	(\$/yr)	(\$)	(\$)	(%)	(Yr)	(%)	(\$)	
ECM #1	Lighting Controls	\$8,960	\$4,480	\$1,680	\$11,760	\$3,582	\$0	15	\$53,730	\$0	356.9%	3.3	29.85%	\$31,001.68	
ECM #2	Demand Control Ventilation	\$88,500	\$88,500	\$0	\$177,000	\$4,813	\$0	15	\$72,195	\$0	-59.2%	36.8	-9.56%	(\$119,542.72)	
ECM #3	Variable Speed Kitchen Hood Upgrade	\$23,470	\$11,735	\$704	\$34,901	\$1,156	\$0	15	\$17,340	\$0	-49.7%	29.8	-7.58%	(\$20,700.75)	
RDM RENEWABLE ENERGY AND FINANCIAL COSTS AND SAVINGS SUMMARY															
RDM #1	Photovoltaic Panel Installation	\$393,300	\$393,300	\$0	\$786,600	\$15,314	\$40,301	15	\$834,225	\$604,515	6.1%	14.1	0.78%	(\$322,671.34)	

Notes: 1) The variable Cn in the formulas for Internal Rate of Return and Net Present Value stands for the cash flow during each period.
2) The variable DR in the NPV equation stands for Discount Rate.
3) For NPV and IRR calculations: From n=0 to N periods where N is the lifetime of ECM and Cn is the cash flow during each period.



Concord Engineering Group, Inc.

520 BURNT MILL ROAD
VOORHEES, NEW JERSEY 08043
PHONE: (856) 427-0200
FAX: (856) 427-6508

SmartStart Building Incentives

The NJ SmartStart Buildings Program offers financial incentives on a wide variety of building system equipment. The incentives were developed to help offset the initial cost of energy-efficient equipment. The following tables show the current available incentives as of January, 2009:

Electric Chillers

Water-Cooled Chillers	\$12 - \$170 per ton
Air-Cooled Chillers	\$8 - \$52 per ton

Gas Cooling

Gas Absorption Chillers	\$185 - \$400 per ton
Gas Engine-Driven Chillers	Calculated through custom measure path)

Desiccant Systems

\$1.00 per cfm – gas or electric

Electric Unitary HVAC

Unitary AC and Split Systems	\$73 - \$93 per ton
Air-to-Air Heat Pumps	\$73 - \$92 per ton
Water-Source Heat Pumps	\$81 per ton
Packaged Terminal AC & HP	\$65 per ton
Central DX AC Systems	\$40- \$72 per ton
Dual Enthalpy Economizer Controls	\$250

Ground Source Heat Pumps

Closed Loop & Open Loop	\$370 per ton
-------------------------	---------------

Gas Heating

Gas Fired Boilers < 300 MBH	\$300 per unit
Gas Fired Boilers ≥ 300 - 1500 MBH	\$1.75 per MBH
Gas Fired Boilers ≥1500 - ≤ 4000 MBH	\$1.00 per MBH
Gas Fired Boilers > 4000 MBH	(Calculated through Custom Measure Path)
Gas Furnaces	\$300 - \$400 per unit

Variable Frequency Drives

Variable Air Volume	\$65 - \$155 per hp
Chilled-Water Pumps	\$60 per hp
Compressors	\$5,250 to \$12,500 per drive

Natural Gas Water Heating

Gas Water Heaters ≤ 50 gallons	\$50 per unit
Gas-Fired Water Heaters >50 gallons	\$1.00 - \$2.00 per MBH
Gas-Fired Booster Water Heaters	\$17 - \$35 per MBH

Premium Motors

Three-Phase Motors	\$45 - \$700 per motor
--------------------	------------------------

Prescriptive Lighting

T-5 and T-8 Lamps w/Electronic Ballast in Existing Facilities	\$10 - \$30 per fixture, (depending on quantity)
Hard-Wired Compact Fluorescent	\$25 - \$30 per fixture
Metal Halide w/Pulse Start	\$25 per fixture
LED Exit Signs	\$10 - \$20 per fixture
T-5 and T-8 High Bay Fixtures	\$16 - \$284 per fixture

Lighting Controls – Occupancy Sensors

Wall Mounted	\$20 per control
Remote Mounted	\$35 per control
Daylight Dimmers	\$25 per fixture
Occupancy Controlled hi- low Fluorescent Controls	\$25 per fixture controlled

Lighting Controls – HID or Fluorescent Hi-Bay Controls

Occupancy hi-low	\$75 per fixture controlled
Daylight Dimming	\$75 per fixture controlled

Other Equipment Incentives

Performance Lighting	\$1.00 per watt per SF below program incentive threshold, currently 5% more energy efficient than ASHRAE 90.1-2004 for New Construction and Complete Renovation
Custom Electric and Gas Equipment Incentives	not prescriptive



STATEMENT OF ENERGY PERFORMANCE

Child Family Center

Building ID: 1872523

For 12-month Period Ending: May 31, 2009¹

Date SEP becomes ineligible: N/A

Date SEP Generated: October 07, 2009

Facility

Child Family Center
1100 Combs Road
Millville, NJ 08332

Facility Owner

Millville Board of Education
110 N. Third Street
Millville, NJ 08332

Primary Contact for this Facility

Toni Basich
110 N. Third Street
Millville, NJ 08332

Year Built: 2005

Gross Floor Area (ft²): 88,000Energy Performance Rating² (1-100) 18**Site Energy Use Summary³**

Electricity - Grid Purchase(kBtu)	4,752,507
Natural Gas (kBtu) ⁴	1,208,400
Total Energy (kBtu)	5,960,907

Energy Intensity⁵

Site (kBtu/ft ² /yr)	68
Source (kBtu/ft ² /yr)	195

Emissions (based on site energy use)

Greenhouse Gas Emissions (MtCO ₂ e/year)	788
---	-----

Electric Distribution Utility

Atlantic City Electric Co

National Average Comparison

National Average Site EUI	50
National Average Source EUI	144
% Difference from National Average Source EUI	36%
Building Type	K-12 School

Stamp of Certifying Professional

Based on the conditions observed at the time of my visit to this building, I certify that the information contained within this statement is accurate.

Meets Industry Standards⁶ for Indoor Environmental Conditions:

Ventilation for Acceptable Indoor Air Quality	N/A
Acceptable Thermal Environmental Conditions	N/A
Adequate Illumination	N/A

Certifying Professional

Raymond Johnson
520 South Burnt Mill Rd.
Voorhees, NJ 08332

Notes:

1. Application for the ENERGY STAR must be submitted to EPA within 4 months of the Period Ending date. Award of the ENERGY STAR is not final until approval is received from EPA.
2. The EPA Energy Performance Rating is based on total source energy. A rating of 75 is the minimum to be eligible for the ENERGY STAR.
3. Values represent energy consumption, annualized to a 12-month period.
4. Natural Gas values in units of volume (e.g. cubic feet) are converted to kBtu with adjustments made for elevation based on Facility zip code.
5. Values represent energy intensity, annualized to a 12-month period.
6. Based on Meeting ASHRAE Standard 62 for ventilation for acceptable indoor air quality, ASHRAE Standard 55 for thermal comfort, and IESNA Lighting Handbook for lighting quality.

ENERGY STAR® Data Checklist for Commercial Buildings

In order for a building to qualify for the ENERGY STAR, a Professional Engineer (PE) must validate the accuracy of the data underlying the building's energy performance rating. This checklist is designed to provide an at-a-glance summary of a property's physical and operating characteristics, as well as its total energy consumption, to assist the PE in double-checking the information that the building owner or operator has entered into Portfolio Manager.

Please complete and sign this checklist and include it with the stamped, signed Statement of Energy Performance.

NOTE: You must check each box to indicate that each value is correct, OR include a note.

CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
Building Name	Child Family Center	Is this the official building name to be displayed in the ENERGY STAR Registry of Labeled Buildings?		<input type="checkbox"/>
Type	K-12 School	Is this an accurate description of the space in question?		<input type="checkbox"/>
Location	1100 Combs Road, Millville, NJ 08332	Is this address accurate and complete? Correct weather normalization requires an accurate zip code.		<input type="checkbox"/>
Single Structure	Single Facility	Does this SEP represent a single structure? SEPs cannot be submitted for multiple-building campuses (with the exception of acute care or children's hospitals) nor can they be submitted as representing only a portion of a building		<input type="checkbox"/>
Child Family Center (K-12 School)				
CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
Gross Floor Area	88,000 Sq. Ft.	Does this square footage include all supporting functions such as kitchens and break rooms used by staff, storage areas, administrative areas, elevators, stairwells, atria, vent shafts, etc. Also note that existing atriums should only include the base floor area that it occupies. Interstitial (plenum) space between floors should not be included in the total. Finally gross floor area is not the same as leasable space. Leasable space is a subset of gross floor area.		<input type="checkbox"/>
Open Weekends?	No	Is this building normally open at all on the weekends? This includes activities beyond the work conducted by maintenance, cleaning, and security personnel. Weekend activity could include any time when the space is used for classes, performances or other school or community activities. If the building is open on the weekend as part of the standard schedule during one or more seasons, the building should select ?yes? for open weekends. The ?yes? response should apply whether the building is open for one or both of the weekend days.		<input type="checkbox"/>
Number of PCs	100	Is this the number of personal computers in the K12 School?		<input type="checkbox"/>
Number of walk-in refrigeration/freezer units	1	Is this the total number of commercial walk-in type freezers and coolers? These units are typically found in storage and receiving areas.		<input type="checkbox"/>
Presence of cooking facilities	Yes	Does this school have a dedicated space in which food is prepared and served to students? If the school has space in which food for students is only kept warm and/or served to students, or has only a galley that is used by teachers and staff then the answer is "no".		<input type="checkbox"/>
Percent Cooled	100 %	Is this the percentage of the total floor space within the facility that is served by mechanical cooling equipment?		<input type="checkbox"/>
Percent Heated	100 %	Is this the percentage of the total floor space within the facility that is served by mechanical heating equipment?		<input type="checkbox"/>
Months	N/A(Optional)	Is this school in operation for at least 8 months of the year?		<input type="checkbox"/>

High School?	No	Is this building a high school (teaching grades 10, 11, and/or 12)? If the building teaches to high school students at all, the user should check 'yes' to 'high school'. For example, if the school teaches to grades K-12 (elementary/middle and high school), the user should check 'yes' to 'high school'.	<input type="checkbox"/>
--------------	----	--	--------------------------

ENERGY STAR® Data Checklist for Commercial Buildings

Energy Consumption

Power Generation Plant or Distribution Utility: Atlantic City Electric Co

Fuel Type: Electricity		
Meter: Electric Meter (kWh (thousand Watt-hours)) Space(s): Entire Facility Generation Method: Grid Purchase		
Start Date	End Date	Energy Use (kWh (thousand Watt-hours))
05/01/2009	05/31/2009	114,160.00
04/01/2009	04/30/2009	138,640.00
03/01/2009	03/31/2009	113,840.00
02/01/2009	02/28/2009	126,000.00
01/01/2009	01/31/2009	137,200.00
12/01/2008	12/31/2008	122,080.00
11/01/2008	11/30/2008	109,680.00
10/01/2008	10/31/2008	96,080.00
09/01/2008	09/30/2008	108,560.00
08/01/2008	08/31/2008	107,120.00
07/01/2008	07/31/2008	105,680.00
06/01/2008	06/30/2008	113,840.00
Electric Meter Consumption (kWh (thousand Watt-hours))		1,392,880.00
Electric Meter Consumption (kBtu (thousand Btu))		4,752,506.56
Total Electricity (Grid Purchase) Consumption (kBtu (thousand Btu))		4,752,506.56
Is this the total Electricity (Grid Purchase) consumption at this building including all Electricity meters?		<input type="checkbox"/>
Fuel Type: Natural Gas		
Meter: Natural Gas (therms) Space(s): Entire Facility		
Start Date	End Date	Energy Use (therms)
05/01/2009	05/31/2009	224.00
04/01/2009	04/30/2009	670.00
03/01/2009	03/31/2009	1,008.00
02/01/2009	02/28/2009	2,697.00
01/01/2009	01/31/2009	3,379.00
12/01/2008	12/31/2008	2,179.00
11/01/2008	11/30/2008	1,140.00
10/01/2008	10/31/2008	361.00
09/01/2008	09/30/2008	171.00
08/01/2008	08/31/2008	74.00

07/01/2008	07/31/2008	74.00
06/01/2008	06/30/2008	107.00
Natural Gas Consumption (therms)		12,084.00
Natural Gas Consumption (kBtu (thousand Btu))		1,208,400.00
Total Natural Gas Consumption (kBtu (thousand Btu))		1,208,400.00
Is this the total Natural Gas consumption at this building including all Natural Gas meters?		<input type="checkbox"/>

Additional Fuels	
Do the fuel consumption totals shown above represent the total energy use of this building? Please confirm there are no additional fuels (district energy, generator fuel oil) used in this facility.	<input type="checkbox"/>

On-Site Solar and Wind Energy	
Do the fuel consumption totals shown above include all on-site solar and/or wind power located at your facility? Please confirm that no on-site solar or wind installations have been omitted from this list. All on-site systems must be reported.	<input type="checkbox"/>

Certifying Professional

(When applying for the ENERGY STAR, the Certifying Professional must be the same as the PE that signed and stamped the SEP.)

Name: _____ Date: _____

Signature: _____

Signature is required when applying for the ENERGY STAR.

FOR YOUR RECORDS ONLY. DO NOT SUBMIT TO EPA.

Please keep this Facility Summary for your own records; do not submit it to EPA. Only the Statement of Energy Performance (SEP), Data Checklist and Letter of Agreement need to be submitted to EPA when applying for the ENERGY STAR.

Facility

Child Family Center
1100 Combs Road
Millville, NJ 08332

Facility Owner

Millville Board of Education
110 N. Third Street
Millville, NJ 08332

Primary Contact for this Facility

Toni Basich
110 N. Third Street
Millville, NJ 08332

General Information

Child Family Center	
Gross Floor Area Excluding Parking: (ft ²)	88,000
Year Built	2005
For 12-month Evaluation Period Ending Date:	May 31, 2009

Facility Space Use Summary

Child Family Center	
Space Type	K-12 School
Gross Floor Area(ft ²)	88,000
Open Weekends?	No
Number of PCs	100
Number of walk-in refrigeration/freezer units	1
Presence of cooking facilities	Yes
Percent Cooled	100
Percent Heated	100
Months ^o	N/A
High School?	No
School District ^o	N/A

Energy Performance Comparison

Performance Metrics	Evaluation Periods		Comparisons		
	Current (Ending Date 05/31/2009)	Baseline (Ending Date 05/31/2009)	Rating of 75	Target	National Average
Energy Performance Rating	18	18	75	N/A	50
Energy Intensity					
Site (kBtu/ft ²)	68	68	39	N/A	50
Source (kBtu/ft ²)	195	195	112	N/A	144
Energy Cost					
\$/year	N/A	N/A	N/A	N/A	N/A
\$/ft ² /year	N/A	N/A	N/A	N/A	N/A
Greenhouse Gas Emissions					
MtCO ₂ e/year	788	788	454	N/A	581
kgCO ₂ e/ft ² /year	9	9	5	N/A	7

More than 50% of your building is defined as K-12 School. Please note that your rating accounts for all of the spaces listed. The National Average column presents energy performance data your building would have if your building had an average rating of 50.

Notes:

o - This attribute is optional.

d - A default value has been supplied by Portfolio Manager.


Statement of Energy Performance

2009

Child Family Center
1100 Combs Road
Millville, NJ 08332

Portfolio Manager Building ID: 1872523

The energy use of this building has been measured and compared to other similar buildings using the Environmental Protection Agency's (EPA's) Energy Performance Scale of 1–100, with 1 being the least energy efficient and 100 the most energy efficient. For more information, visit energystar.gov/benchmark.



This building uses 195 kBtu per square foot per year.*

*Based on source energy intensity for the 12 month period ending May 2009

Buildings with a score of 75 or higher may qualify for EPA's ENERGY STAR.

I certify that the information contained within this statement is accurate and in accordance with U.S. Environmental Protection Agency's measurement standards, found at energystar.gov

Date of certification



MAJOR EQUIPMENT LIST
Concord Engineering Group
"Milhelle B.O.E. - Child Family Center"

Boiler

Location	Area Served	Manufacturer	Qty.	Model #	Serial #	Input (MBtu)	Output (MBtu)	Efficiency (%)	Fuel	Approx. Age	ASHRAE Service Remaining Life
Boiler Room	Entire Facility	Wool McLain Series 88	2	888	-	2,396	1,656	70%	Natural Gas	4	31

Boiler - Burner

Location	Area Served	Manufacturer	Qty.	Model #	Serial #	Max Input (MBtu)	Fuel	Approx. Age	ASHRAE Service Remaining Life
Boiler Room	Entire Facility	Webster	2	BJLGG-BK7895A, 120 Fm	-	2,396	Natural Gas	4	17

HVAC - Pumps

Location	Area Served	Manufacturer	Qty.	Model #	Serial #	HP	RPM	GPM	Fl. Hd	Frame Size	VFD	Volts	Phase	Hz	Approx. Age	ASHRAE Service Remaining Life	Notes
Boiler Room	Cooling Tower	Bell and Gossett	2	VSC BFP 9.375	-	20	1800	860	65	256T	Yes	460	3	60	4	20	Cooling Tower Loop Pumps
Boiler Room	Entire Facility	Bell and Gossett	2	VSC BFP 9.625	-	25	1800	820	75	284T	Yes	460	3	60	4	16	Heat Pump Loop Pumps

Domestic Hot Water Heater

Location	Area Served	Manufacturer	Qty	Model #	Serial #	Input (MBtu)	Recovery (gal/hr)	Capacity (gal)	Efficiency (%)	Fuel	Approx. Age	ASHRAE Service Remaining Life
Boiler Room	Entire Facility	A.O.Smith	1	BTPI40 - 140,000	SC0399237-3	140	170	140	80%	Natural Gas	4	12
Boiler Room	Entire Facility	A.O.Smith	1	BT100110	MC03-2329766-10	98	71.7	98	80%	Natural Gas	4	12

DHW - Pumps

Location	Area Served	Manufacturer	Qty.	Model #	Serial #	HP	GPM	FT HD	Volts	Phase	Hz	Approx. Age	ASHRAE Service Remaining Life
Boiler Room	Entire Facility	Norton Pump Circ Sys.	1	CPS-12060-2.5	36583	Qty 2 - 5HP	240	100	460	3	60	4	16

Roof Top Units

Location	Area Served	Manufacturer	Qty.	Model #	Serial #	Equipment Tag	Cooling Capacity (Tons)	Cooling Effic. (EER)	Refrigerant	Heating Type	Input (MBtu)	Output (MBtu)	Heating Effic. (%)	Fuel	Energy Recovery	Volts	Phase	Hz	Approx. Age	ASHRAE Service Remaining Life
Roof	Kitchen & Café	Dix Chumps	1	PV-MZT-8704	47743	RTU - A01	258	10	R-22	Heat Pump	245	-	-	Electric	Yes	460	3	60	4	15
Roof	Administrative	Dix Chumps	1	PV-MZT-8704	47744	RTU - A02	258	10	R-22	Heat Pump	245	-	-	Electric	Yes	460	3	60	4	15
Roof	Admin Suite	Dix Chumps	1	PV-MZT-8704	47745	RTU - A03	270.1	10	R-22	Heat Pump	242.9	-	-	Electric	Yes	460	3	60	4	15
Roof	Classrooms	Dix Chumps	1	PV-MZT-8704-5	47746	RTU - A04	278.9	10	R-22	Heat Pump	190.2	-	-	Electric	Yes	460	3	60	4	15
Roof	Classrooms	Dix Chumps	1	PV-MZT-8704	47747	RTU - B05	250.1	10	R-22	Heat Pump	203.2	-	-	Electric	Yes	460	3	60	4	15

Cooling Tower

Location	Area Served	Manufacturer	Qty.	Model #	Serial #	Tower Capacity	Fan HP	Volts	Phase	Hz	Approx. Age	ASHRAE Service Remaining Life
Building Exterior	Entire Facility	Baltimore Aerial Co.	1	PXV-0661	4040213401	211 Ton	40	460	3	60	4	16

INVESTMENT GRADE LIGHTING AUDIT

CEG Job #: 9C09072
Project: Millville R.O.E.
Address: 1100 Coombs Rd,
Millville, NJ 08332
Building SF: 88,000

"Millville - Child Family Center"

KWH COST: \$0.133

EXISTING LIGHTING				PROPOSED LIGHTING										SAVINGS								
Line #	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Lamps	Retro-Unit Description	Watts Used	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback
1	Boiler Room	3650	23	2	4" Industrial, 2-Lamp, T8 32W, Electronic Ballast, Pendant Mount	58	1.33	4,869.1	\$647.59	0	0	No Change Required (NCR)	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
2	100	3650	16	3	2' x 4', 3-Lamp, T8 32W, Electronic Ballast, Recessed Mount, Prismatic Lens	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
3	100 Bathroom	3650	1	1	4" Vanity, 1-Lamp, T8 32W, Electronic Ballast, Surface Mount, Prismatic Lens	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
4	101	3650	16	3	2' x 4', 3-Lamp, T8 32W, Electronic Ballast, Recessed Mount, Prismatic Lens	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
5	101 Bathroom	3650	1	1	4" Vanity, 1-Lamp, T8 32W, Electronic Ballast, Surface Mount, Prismatic Lens	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
6	102	3650	16	3	2' x 4', 3-Lamp, T8 32W, Electronic Ballast, Recessed Mount, Prismatic Lens	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
7	102 Bathroom	3650	1	1	4" Vanity, 1-Lamp, T8 32W, Electronic Ballast, Surface Mount, Prismatic Lens	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
8	103	3650	16	3	2' x 4', 3-Lamp, T8 32W, Electronic Ballast, Recessed Mount, Prismatic Lens	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
9	103 Bathroom	3650	1	1	4" Vanity, 1-Lamp, T8 32W, Electronic Ballast, Surface Mount, Prismatic Lens	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
10	Teachers Dining Room	3650	8	3	2' x 4', 3-Lamp, T8 32W, Electronic Ballast, Recessed Mount, Prismatic Lens	82	0.66	2,394.4	\$318.46	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
11	Parent Meeting Room	3650	40	3	2' x 4', 3-Lamp, T8 32W, Electronic Ballast, Recessed Mount, Prismatic Lens	82	3.28	11,972.0	\$1,592.28	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
12	Storage #3	3650	3	3	2' x 4', 3-Lamp, T8 32W, Electronic Ballast, Recessed Mount, Prismatic Lens	82	0.25	897.9	\$119.42	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
13	Kitchen	3650	23	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.89	6,883.9	\$915.56	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00

INVESTMENT GRADE LIGHTING AUDIT

14	Kitchen	3650	1	3	2' x 2', 3-Lamp, T8 17W, Electronic Ballast, Recessed Mount, Prismatic Lens	82	0.08	299.3	\$39.81	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
15	Office	3650	1	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	0.08	299.3	\$39.81	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
16	Kitchen Locker Room	3650	1	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	0.08	299.3	\$39.81	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
17	Kitchen Bathroom	3650	1	1	4' Vanity, 1-Lamp, T8 32W, Electronic Ballast, Surface Mount, Prismatic Lens	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
18	Kitchen Vestibule	3650	1	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	0.08	299.3	\$39.81	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
19	Kitchen Janitor Closet	3650	1	2	4' Vaportight, 2-Lamp, T8 32W, Electronic Ballast, Surface Mount, Prismatic Lens	58	0.06	211.7	\$28.16	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
20	Kitchen Storage	3650	2	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	0.16	598.6	\$79.61	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
21	Nurse	3650	5	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	0.41	1,496.5	\$199.03	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
22	Nurse Exam	3650	3	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	0.25	897.9	\$119.42	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
23	Nurse Bathroom	3650	1	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	0.08	299.3	\$39.81	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
24	Electrical Room #1	3650	3	2	4' Industrial, 2-Lamp, T8 32W, Electronic Ballast, Pendant Mount	58	0.17	635.1	\$84.47	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
25	Conference	3650	6	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	0.49	1,795.8	\$238.84	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
26		3650	6	1	High-hat with Floodlight, 1-Lamp, Incandescent 75W, Recessed Mount	75	0.45	1,642.5	\$218.45	6	1	18 W CFL Lamp	18	0.11	\$52.43	\$60.00	\$166.02	1248.3	\$0.00	0.36
27	Boys Bathroom	3650	3	1	High-hat with Floodlight, 1-Lamp, Incandescent 75W, Recessed Mount	75	0.23	821.3	\$109.23	3	1	18 W CFL Lamp	18	0.05	\$26.21	\$30.00	\$83.01	624.15	\$0.00	0.36
28	Men's Bathroom	3650	7	1	High-hat with Floodlight, 1-Lamp, Incandescent 75W, Recessed Mount	75	0.53	1,916.3	\$254.86	7	1	18 W CFL Lamp	18	0.13	\$61.17	\$70.00	\$193.69	1456.35	\$0.00	0.36
29		3650	8	1	4' x 6' along walls, 1- Lamp, T8 32W, Electronic Ballast, Recessed Mount, Parabolic Lens	28	0.22	817.6	\$108.74	0	0	NCR	0	0.00	\$0.00	\$0.00	\$0.00	0	\$0.00	0.00
30	Janitor Closet	3650	1	2	4' Industrial, 2-Lamp, T8 32W, Electronic Ballast, Pendant Mount	58	0.06	211.7	\$28.16	0	0	NCR	0	0.00	\$0.00	\$0.00	\$0.00	0	\$0.00	0.00

INVESTMENT GRADE LIGHTING AUDIT

31		3650	3	1	High-hat with Floodlight, 1-Lamp, Incandescent 75W, Recessed Mount	75	0.23	821.3	\$109.23	3	1	18 W CFL Lamp	18	0.05	197.1	\$26.21	\$10.00	\$30.00	0.17	624.15	\$83.01	0.36
32	Girls Bathroom	3650	5	1	4' x 6' along wells, 1-Lamp, T8 32W, Electronic Ballast, Recessed Mount, Parabolic Lens	28	0.14	511.0	\$67.96	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
33	Women's Bathroom	3650	8	1	4' x 6' along wells, 1-Lamp, T8 32W, Electronic Ballast, Recessed Mount, Parabolic Lens	28	0.22	817.6	\$108.74	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
34	Office	3650	8	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	0.66	2,394.4	\$318.46	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
35	Principal Office	3650	4	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	0.33	1,197.2	\$159.23	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
36	Family Liaison	3650	8	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	0.66	2,394.4	\$318.46	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
37	Vice Principal	3650	3	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	0.25	897.9	\$119.42	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
38	104	3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
39	104 Bathroom	3650	1	1	4' Vanity, 1-Lamp, T8 32W, Electronic Ballast, Surface Mount	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
40	Motor 1	3650	23	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.89	6,883.9	\$915.56	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
41	Motor Bathroom	3650	1	1	4' Vanity, 1-Lamp, T8 32W, Electronic Ballast, Surface Mount	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
42	Storage 1	3650	1	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	0.08	299.3	\$39.81	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
43	105	3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
44	105 Bathroom	3650	1	1	4' Vanity, 1-Lamp, T8 32W, Electronic Ballast, Surface Mount	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
45	106	3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
46	106 Bathroom	3650	1	1	4' Vanity, 1-Lamp, T8 32W, Electronic Ballast, Surface Mount	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
47	107	3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
48	107 Bathroom	3650	1	1	4' Vanity, 1-Lamp, T8 32W, Electronic Ballast, Surface Mount	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
49	108	3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00

INVESTMENT GRADE LIGHTING AUDIT

50	108 Bathroom	3650	1	1	4' Vanity, 1-Lamp, T8 32W, Electronic Ballast, Surface Mount	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0.00
51	109	3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0.00
52	109 Bathroom	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0.00
53	110	3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0.00
54	110 Bathroom	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0.00
55	111	3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0.00
56	111 Bathroom	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0.00
57	112	3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0.00
58	112 Bathroom	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0.00
59	113	3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0.00
60	113 Bathroom	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0.00
61	114	3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0.00
62	114 Bathroom	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0.00
63	Storage 4	3650	2	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	0.16	598.6	\$79.61	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0.00
64	Motor 3	3650	25	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	2.05	7,482.5	\$995.17	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0.00
65		3650	4	1	Highest with Flood lamp 1-Lamp, Incandescent 75W, Recessed Mount	75	0.30	1,095.0	\$145.64	4	1	18 W CFL Lamp	18	0.07	\$34.95	\$10.00	\$40.00	832.2
66	Storage 5	3650	2	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	0.16	598.6	\$79.61	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0.00
67	Storage Bathroom	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0.00

INVESTMENT GRADE LIGHTING AUDIT

68	Motor 3	3650	25	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	2.05	7,482.5	\$995.17	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
69		3650	4	1	Highest with Flood lamp, 1-Lamp, Incandescent 75W, Recessed Mount	75	0.30	1,095.0	\$145.64	4	1	18 W CFL Lamp	18	0.07	262.8	\$34.95	\$10.00	\$40.00	0.36
70	Motor 3 Bathroom	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
71	Custodian Office	3650	2	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	0.16	598.6	\$79.61	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
72	Electrical Room #2	3650	1	2	4' Industrial, 2-Lamp, T8 32W, Electronic Ballast, Pendant Mount	58	0.06	211.7	\$28.16	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
73	Corridor A	3650	31	3	2' x 2', 3-Lamp, T8 17W, Electronic Ballast, Recessed Mount, Prismatic Lens	41	1.27	4,639.2	\$617.01	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
74	Corridor A	3650	4	1	Highest, 1-Lamp, Incandescent 75W, Recessed Mount	75	0.30	1,095.0	\$145.64	4	1	18 W CFL Lamp	18	0.07	262.8	\$34.95	\$10.00	\$40.00	0.36
75	Stair #5	3650	4	1	Highest, 1-Lamp, Incandescent 75W, Recessed Mount	75	0.30	1,095.0	\$145.64	4	1	18 W CFL Lamp	18	0.07	262.8	\$34.95	\$10.00	\$40.00	0.36
76	Stair #5	3650	8	2	4', 2-Lamp, T8 32W, Electronic Ballast, Pendant Mount, Parabolic Lens	58	0.46	1,693.6	\$225.25	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
77	225	3650	13	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.07	3,890.9	\$517.49	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
78	224	3650	13	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.07	3,890.9	\$517.49	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
79	223	3650	13	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.07	3,890.9	\$517.49	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
80	222	3650	13	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.07	3,890.9	\$517.49	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
81	221	3650	13	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.07	3,890.9	\$517.49	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
82		3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
83	220	3650	13	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.07	3,890.9	\$517.49	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
84		3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
85		3650	13	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.07	3,890.9	\$517.49	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00

INVESTMENT GRADE LIGHTING AUDIT

86	219	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	\$0.00	\$0.00	0	\$0.00	0.00
87		3650	13	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.07	3,890.9	\$517.49	0	0	NCR	0	0.00	\$0.00	\$0.00	0	\$0.00	0.00
88	218	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	\$0.00	\$0.00	0	\$0.00	0.00
89	Storage 24	3650	4	2	4' Industrial, 2-Lamp, T8 32W, Electronic Ballast, Pendant Mount	58	0.23	846.8	\$112.62	0	0	NCR	0	0.00	\$0.00	\$0.00	0	\$0.00	0.00
90	Roof Access	3650	1	2	4' Industrial, 2-Lamp, T8 32W, Electronic Ballast, Pendant Mount	58	0.06	211.7	\$28.16	0	0	NCR	0	0.00	\$0.00	\$0.00	0	\$0.00	0.00
91		3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	\$0.00	\$0.00	0	\$0.00	0.00
92	200	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	\$0.00	\$0.00	0	\$0.00	0.00
93		3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	\$0.00	\$0.00	0	\$0.00	0.00
94	201	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	\$0.00	\$0.00	0	\$0.00	0.00
95		3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	\$0.00	\$0.00	0	\$0.00	0.00
96	202	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	\$0.00	\$0.00	0	\$0.00	0.00
97		3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	\$0.00	\$0.00	0	\$0.00	0.00
98	203	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	\$0.00	\$0.00	0	\$0.00	0.00
99	Intervention Team A	3650	5	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	0.41	1,496.5	\$199.03	0	0	NCR	0	0.00	\$0.00	\$0.00	0	\$0.00	0.00
100	Teach Planning	3650	7	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	0.57	2,095.1	\$278.65	0	0	NCR	0	0.00	\$0.00	\$0.00	0	\$0.00	0.00
101	Teach Planning Storage 23	3650	1	4	2' x 2', 3-Lamp, T8 17W, Electronic Ballast, Recessed Mount, Prismatic Lens	41	0.04	149.7	\$19.90	0	0	NCR	0	0.00	\$0.00	\$0.00	0	\$0.00	0.00
102	Intervention Team C	3650	4	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	0.33	1,197.2	\$159.23	0	0	NCR	0	0.00	\$0.00	\$0.00	0	\$0.00	0.00
103	Master Teacher	3650	6	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	0.49	1,795.8	\$238.84	0	0	NCR	0	0.00	\$0.00	\$0.00	0	\$0.00	0.00

INVESTMENT GRADE LIGHTING AUDIT

104	Storage	3650	2	4	2' x 4', 4-Lamp, T8 32W, Electronic Ballast, Surface Mount, Prismatic Lens	109	0.22	795.7	\$105.83	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
105		3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
106	214	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
107		3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
108	215	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
109		3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
110	216	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
111		3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
112	217	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
113	217 Storage 21	3650	3	2	4' Industrial, 2-Lamp, T8 32W, Electronic Ballast, Pendant Mount	58	0.17	635.1	\$84.47	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
114		3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
115	204	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
116	Intervention Team B	3650	5	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	0.41	1,496.5	\$199.03	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
117	Conference Room	3650	8	2	2-Lamp, T8 32W, Electronic Ballast, Pendant Mount, Parabolic Lens	58	0.46	1,693.6	\$225.25	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
118		3650	15	1	High-bay, 1-Lamp, Incandescent 75W	75	1.13	4,106.3	\$546.13	15	1	18 W CFL Lamp	18	0.27	\$131.07	\$150.00	0.86	3120.75	\$415.06	0.36
119	205	3650	12	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	0.98	3,591.6	\$477.68	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
120		3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
121	206	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00

INVESTMENT GRADE LIGHTING AUDIT

122		3650	13	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.07	3,890.9	\$517.49	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
123	207	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
124		3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
125	208	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
126		3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
127	209	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
128		3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
129	210	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
130		3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
131	211	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
132		3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
133	212	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
134		3650	16	3	2'x4' 3-Lamp T8 32W, Prism Lens, Electronic Ballast	82	1.31	4,788.8	\$636.91	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
135	213	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	0	\$0.00	\$0.00	0.00	0.00
136	Women's Bathroom	3650		1	High-hat with Floodlight, 1-Lamp, Incandescent 75W., Recessed Mount	75	0.00	0.0	\$0.00	0	1	18 W CFL Lamp	18	0.00	0	\$0.00	\$10.00	\$0.00	0.00
137	Girls Bathroom	3650	3	1	High-hat with Floodlight, 1-Lamp, Incandescent 75W., Recessed Mount	75	0.23	821.3	\$109.23	3	1	18 W CFL Lamp	18	0.05	197.1	\$26.21	\$30.00	\$83.01	0.36
138	Boys Bathroom	3650	3	1	High-hat with Floodlight, 1-Lamp, Incandescent 75W., Recessed Mount	75	0.23	821.3	\$109.23	3	1	18 W CFL Lamp	18	0.05	197.1	\$26.21	\$30.00	\$83.01	0.36


INVESTMENT GRADE LIGHTING AUDIT

139	Men's Bathroom	3650	7	1	High-hat with Floodlight, 1-Lamp, Incandescent 75W, Recessed Mount	75	0.53	1,916.3	\$254.86	7	1	18 W CFL Lamp	18	0.13	459.9	\$61.17	\$10.00	\$70.00	0.40	1456.35	\$193.69	0.36
140	Motor #2	3650	25	2	High-hat x 2, 75W	150	3.75	13,687.5	\$1,820.44	25	2	18 W CFL Lamp	36	0.90	3285	\$436.91	\$20.00	\$500.00	2.85	10402.5	\$1,383.53	0.36
141	Motor Bathroom	3650	1	1	4' 1-Lamp T8 32W, Prism Lens, Electronic Ballast, Vanity Fixture	28	0.03	102.2	\$13.59	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
142	Janitor Closet	3650	1	2	4' Industrial, 2-Lamp, T8 32W, Electronic Ballast, Pendant Mount	58	0.06	211.7	\$28.16	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
143	Stair #2	3650	6	2	4', 2-Lamp, T8 32W, Electronic Ballast, Pendant Mount, Parabolic Lens	58	0.35	1,270.2	\$168.94	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
144	Stair #2	3650	2	1	High-hat, 1-Lamp, Incandescent 75W, Recessed Mount	75	0.15	547.5	\$72.82	2	1	18 W CFL Lamp	18	0.04	131.4	\$17.48	\$10.00	\$20.00	0.11	416.1	\$55.34	0.36
145	Stair #1	3650	3	2	High-hat x 2, 75W	150	0.45	1,642.5	\$218.45	3	2	18 W CFL Lamp	36	0.11	394.2	\$52.43	\$20.00	\$60.00	0.34	1248.3	\$166.02	0.36
146	Stair #4	3650	6	2	4', 2-Lamp, T8 32W, Electronic Ballast, Pendant Mount, Parabolic Lens	58	0.35	1,270.2	\$168.94	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
147	Stair #4	3650	4	1	High-hat, 1-Lamp, Incandescent 75W, Recessed Mount	75	0.30	1,095.0	\$145.64	4	1	18 W CFL Lamp	18	0.07	262.8	\$34.95	\$10.00	\$40.00	0.23	832.2	\$110.68	0.36
148	Stair #3	3650	6	2	4', 2-Lamp, T8 32W, Electronic Ballast, Pendant Mount, Parabolic Lens	58	0.35	1,270.2	\$168.94	0	0	NCR	0	0.00	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
149	Stair #3	3650	4	1	High-hat, 1-Lamp, Incandescent 75W, Recessed Mount	75	0.30	1,095.0	\$145.64	4	1	18 W CFL Lamp	18	0.07	262.8	\$34.95	\$10.00	\$40.00	0.23	832.2	\$110.68	0.36
Totals			1119	313			86.82	316,882.1	\$42,145.31	101	20			2.322	8475.3	\$1,127.21		\$1,290.00	7.35	26838.5	\$3,569.51	0.36

Lighting Control Applicable

Project Name: Millville BOE - Child Family Center							
Location: Millville, NJ 08332							
Description: Photovoltaic System - Direct Purchase							
Simple Payback Analysis							
		Photovoltaic System - Direct Purchase					
Total Construction Cost		\$786,600					
Annual kWh Production		115,147					
Annual Energy Cost Reduction		\$15,315					
Annual SREC Revenue		\$40,301					
First Cost Premium		\$786,600					
Simple Payback:		14.14					Years
Life Cycle Cost Analysis							
Analysis Period (years):		25		Financing %:		0%	
Financing Term (mths):		0		Maintenance Escalation Rate:		3.0%	
Average Energy Cost (\$/kWh)		\$0.133		Energy Cost Escalation Rate:		3.0%	
Financing Rate:		0.00%		SREC Value (\$/kWh)		\$0.350	
Period	Additional Cash Outlay	Energy kWh Production	Energy Cost Savings	Additional Maint Costs	SREC Revenue	Net Cash Flow	Cumulative Cash Flow
0	\$786,600	0	0	0	\$0	(786,600)	0
1	\$0	115,147	\$15,315	\$0	\$40,301	\$55,616	(\$730,984)
2	\$0	114,571	\$15,774	\$0	\$40,100	\$55,874	(\$675,110)
3	\$0	113,998	\$16,247	\$0	\$39,899	\$56,147	(\$618,963)
4	\$0	113,428	\$16,735	\$0	\$39,700	\$56,435	(\$562,529)
5	\$0	112,861	\$17,237	\$1,162	\$39,501	\$55,576	(\$506,953)
6	\$0	112,297	\$17,754	\$1,157	\$39,304	\$55,901	(\$451,052)
7	\$0	111,735	\$18,286	\$1,151	\$39,107	\$56,243	(\$394,809)
8	\$0	111,177	\$18,835	\$1,145	\$38,912	\$56,602	(\$338,208)
9	\$0	110,621	\$19,400	\$1,139	\$38,717	\$56,978	(\$281,230)
10	\$0	110,068	\$19,982	\$1,134	\$38,524	\$57,372	(\$223,858)
11	\$0	109,517	\$20,581	\$1,128	\$38,331	\$57,785	(\$166,073)
12	\$0	108,970	\$21,199	\$1,122	\$38,139	\$58,216	(\$107,857)
13	\$0	108,425	\$21,835	\$1,117	\$37,949	\$58,667	(\$49,190)
14	\$0	107,883	\$22,490	\$1,111	\$37,759	\$59,138	\$9,948
15	\$0	107,344	\$23,165	\$1,106	\$37,570	\$59,629	\$69,577
16	\$0	106,807	\$23,860	\$1,100	\$37,382	\$60,142	\$129,719
17	\$0	106,273	\$24,575	\$1,095	\$37,195	\$60,676	\$190,395
18	\$0	105,741	\$25,313	\$1,089	\$37,009	\$61,233	\$251,628
19	\$0	105,213	\$26,072	\$1,084	\$36,824	\$61,813	\$313,441
20	\$0	104,687	\$26,854	\$1,078	\$36,640	\$62,416	\$375,857
21	\$1	104,163	\$27,660	\$1,073	\$36,457	\$63,044	\$438,901
22	\$2	103,642	\$28,490	\$1,068	\$36,275	\$63,697	\$502,598
23	\$3	103,124	\$29,344	\$1,062	\$36,093	\$64,376	\$566,973
24	\$4	102,609	\$30,225	\$1,057	\$35,913	\$65,081	\$632,054
25	\$5	102,095	\$31,131	\$1,052	\$35,733	\$65,813	\$697,867
Totals:		2,196,763	\$411,508	\$17,918	\$768,867	\$1,484,467	\$1,162,457
Net Present Value (NPV)						\$697,892	
Internal Rate of Return (IRR)						5.4%	

Building	Roof Area (sq ft)	Panel	Qty	Panel Sq Ft	Panel Total Sq Ft	Total KW _{DC}	Total Annual kWh	Panel Weight (33 lbs)	W/SQFT
Child Family Center	6200	Sunpower SPR230	380	14.7	5,588	87.40	115,147	12,540	15.64



Station Identification	
City:	Atlantic_City
State:	New_Jersey
Latitude:	39.45° N
Longitude:	74.57° W
Elevation:	20 m
PV System Specifications	
DC Rating:	87.4 kW
DC to AC Derate Factor:	0.810
AC Rating:	70.8 kW
Array Type:	Fixed Tilt
Array Tilt:	39.5°
Array Azimuth:	180.0°
Energy Specifications	
Cost of Electricity:	13.3 ¢/kWh

Results			
Month	Solar Radiation (kWh/m ² /day)	AC Energy (kWh)	Energy Value (\$)
1	3.61	8238	1095.65
2	4.20	8577	1140.74
3	4.78	10348	1376.28
4	5.23	10628	1413.52
5	5.44	11156	1483.75
6	5.48	10442	1388.79
7	5.55	10796	1435.87
8	5.41	10637	1414.72
9	5.23	10181	1354.07
10	4.60	9521	1266.29
11	3.59	7564	1006.01
12	3.17	7061	939.11
Year	4.69	115147	15314.55

 := Proposed PV Layout

Notes:

1. Estimated kWh based on the National Renewable Energy Laboratory PVWatts Version 1 Calculator Program.



INTELLI-HOOD VARIABLE EXHAUST CONTROLLER

ENERGY SAVINGS REPORT

COMPANY:	CEG	RETROFIT
ADDRESS:	1100 Combs Road	
	Millville, NJ	Nov-13-09
APPLICATION:	Main Kitchen - Child Family Center	
- MOTOR OPERATING SAVINGS:		\$164 /YEAR
- HEATING SAVINGS:		\$909 /YEAR
- COOLING SAVINGS:		\$83 /YEAR
- TOTAL SAVINGS:		\$1,155 /YEAR
- INSTALLED COST:		\$35,207
- PAYBACK PERIOD:		30.5 YEARS
- RATE OF RETURN -	5 YEARS:	-20.9 %
	10 YEARS:	-14.3 %

The projected savings shown above are based on the above store's operating hours, HVAC system, cooking load, and geographic location.

I. MOTOR OPERATING SAVINGS

INPUT DATA:

A Operating Hours Per Day	6	HRS/DAY
B Operating Days Per Week	5	DAYS/WK
C Operating Weeks Per Year	30	WKS/YR
D Horsepower of Fan Motor(s)	4	HP
E Load Factor of Fan Motor(s)	0.88	
F Cost Per Kilowatt Hour	0.133	\$/KWH

CONSTANT EXHAUST VOLUME ANALYSIS:

G Total Time (A x B x C)	900	HRS/YR
H Total KWHR/HP/YR (0.746/0.9 x G)	746.0	KWHR/HP/YR

VARIABLE EXHAUST VOLUME ANALYSIS:

% Rated RPM H	% Run Time I	Time HRS/YR J=FxI	Output KW/HP K	System Effic. L	Input KW/HP M=K/L	KWHR/ HP/YR N=JxM
100	40	360	0.746	0.9	0.829	298.4
90	0	0	0.544	0.9	0.604	0.0
80	13.3333333	120	0.382	0.9	0.424	50.9
70	0	0	0.256	0.9	0.284	0.0
60	20	180	0.161	0.9	0.179	32.2
50	13.3333333	120	0.093	0.9	0.103	12.4
40	0	0	0.048	0.9	0.053	0.0
30	13.3333333	120	0.020	0.9	0.022	2.7
20	0	0	0.015	0.9	0.017	0.0
10	0	0	0.010	0.90	0.011	0.0

O Total KWH/HP/YR (Total of Column N)	396.6
---------------------------------------	-------

CALCULATION:

$$\text{SAVINGS} = (H - O) \times D \times E \times F = \text{\$164 /YEAR}$$

=====

II. CONDITIONED MAKE-UP AIR - HEATING

INPUT DATA:

A Previous Net Exhaust Volume	7500	CFM
B New Net Exhaust Volume (1)	5500	CFM
C Winter Building Temperature	70	F
D Previous Net Heat Load (2)	315665	kBTU
E New Net Heat Load (2)	231488	kBTU
F Operating Hours Per Day	6	HRS/DAY
G Operating Days Per Week	5	DAYS/WK
- Heating Fuel Type	Hot Water	
H Cost Per Fuel Unit (3)	15.3	\$/UNIT
J BTU Per Fuel Unit (4)	1,000	kBTU/UNIT
K System Efficiency (4)	0.85	

CALCULATION:

$$\text{SAVINGS} = (D - E) \times 0.6 \times H / (J \times K)$$

$$= \quad \$909 \text{ /YEAR}$$

$$\text{=====}$$

NOTES:

(1) Determine the New Exhaust Volume by completing TABLE 1. The New Exhaust Volume equals the AVG % RPM x the Previous Exhaust Volume.

(2) Using design weather data via the Outdoor Airload Calculator and multiplied by days/year ratio.

(3) Using local energy costs.

(4) Using typical system efficiency.

TABLE 1

% Rated RPM (F)	% Run Time (I)	F x I
100	40	40
90	0	0
80	13	11
70	0	0
60	20	12
50	13	7
40	0	0
30	13	4
20	0	0
10	0	0

AVG % RPM = 73%

III. CONDITIONED MAKE-UP AIR SAVINGS - COOLING

INPUT DATA:

A Previous Net Exhaust Volume	7500 CFM
B New Net Exhaust Volume (1)	5500 CFM
C Previous Net Cooling Load (2)	31302.507 kBTU
D New Net Cooling Load (2)	22955 kBTU
E AC Correction Factor (3)	1
F Cost Per Fuel Unit (5)	0.141 \$/kWH
G COP (6)	2.5

CALCULATION:

$$\text{SAVINGS} = (C - D) \times 0.6 \times E \times F / (3.413 \times G)$$

$$= \frac{\$83}{\text{YEAR}}$$

NOTES:

(1) Using New Exhaust Volume from CONDITIONED MAKE-UP AIR SAVINGS - HEATING on page 2. See Note 1.

(2) Obtained from Outdoor Airload Calculator

(3) Using design weather data.

(4) The multiplier corrects for actual % outside air.

(5) Using local energy costs.

(6) Using typical system efficiency.

AFTER-TAX CASH FLOW ANALYSIS

INPUT DATA:

FIRST YEAR SAVINGS	\$1,155 /YEAR
INITIAL COST PLUS INSTALLATION	\$35,207
MARGINAL TAX RATE	0%
ESTIMATED ANNUAL INCREASE IN ENERGY COSTS	3%

<u>YEAR</u>	<u>SAVINGS</u>	<u>COST</u>	<u>DEPREC. %</u>	<u>DEPREC. \$</u>	<u>NET AFTER-TAX CASH FLOW</u>
0		-35,207			-35,207
1	1155	-	29	10210	1155
2	1190	-	20	7041	1190
3	1226	-	13	4577	1226
4	1263	-	10	3521	1263
5	1300	-	9	3169	1300
6	1339	-	9	3169	1339
7	1380	-	9	3169	1380
8	1421	-			1421
9	1464	-			1464
10	1508	-			1508

CALCULATIONS:

NET PRESENT VALUE = -\$27,068 ; 5 YEARS @ 15%	INTERNAL RATE OF RETURN (IRR) =	-20.9 %
NET PRESENT VALUE = -\$25,024 ; 10 YEARS @ 15%	INTERNAL RATE OF RETURN (IRR) =	-14.3 %

NOTE:

Net After-tax Cash Flow is calculated as follows:

$$\text{NATCF} = \text{SAVINGS} - \text{COSTS} - \text{TAX RATE}(\text{SAVINGS} - \text{COSTS} - \text{DEPRECIATION})$$

Net Present Value is calculated as follows:

$$\text{NPV} = \text{C}(0) + \text{C}(1)/(1 + r) + \text{C}(2)/(1 + r)^2 + \dots + \text{C}(n)/(1 + r)^n$$

(where C(n) is the net cash flow for the nth year

and r is the opportunity cost of capital)

IRR is calculated by trial and error using the formula:

$$\text{NPV} = \text{C}(0) + \text{C}(1)/(1 + \text{IRR}) + \text{C}(2)/(1 + \text{IRR})^2 + \dots + \text{C}(n)/(1 + \text{IRR})^n$$