

**NORTH BERGEN HOUSING AUTHORITY
LAWLER TOWERS APARTMENTS
ENERGY ASSESSMENT**

for

**NEW JERSEY
BUREAU OF PUBLIC UTILITIES**

**NORTH BERGEN HOUSING AUTHORITY
LAWLER TOWERS APARTMENTS**

ENERGY ASSESSMENT

for

**NEW JERSEY
BUREAU OF PUBLIC UTILITIES**

CHA PROJECT NO. 20241

January 2010

Prepared by:

Clough Harbour & Associates LLP

2001 Route 46
Suite 107
Parsippany, NJ 07054

(973) 299-1100

TABLE OF CONTENTS

| | <u>Page</u> |
|--|-------------|
| 1.0 INTRODUCTION & BACKGROUND..... | 1 |
| 2.0 EXECUTIVE SUMMARY..... | 2 |
| 3.0 EXISTING CONDITIONS..... | 6 |
| 3.1 Building General | |
| 3.2 Utility Usage | |
| 3.3 HVAC Systems | |
| 3.4 Lighting/Electrical System | |
| 3.5 Control Systems | |
| 4.0 ENERGY CONSERVATION MEASURES..... | 10 |
| 4.1 ECM-1 Lighting Upgrades | |
| 4.2 ECM-2 Light Bulb Exchange | |
| 4.3 ECM-3 Water Conservation | |
| 4.4 ECM-4 Thermostats and Control Valves for Steam Radiators | |
| 4.5 ECM-5 Door Seals | |
| 4.6 ECM-6 Insulate Steam and Condensate Piping | |
| 4.7 ECM-7 Air Conditioner Changeout | |
| 4.8 ECM-8 Night Setback for Offices and Community Room | |
| 4.9 ECM-9 Boiler Replacement | |
| 4.10 ECM-10 Window Replacements | |
| 4.11 ECM-11 Insulation Addition | |
| 4.12 ECM-12 Exhaust Fan Controls | |
| 4.13 ECM-13 Energy Star Appliances | |
| 4.14 North Bergen Housing Authority Building Incentives | |
| 5.0 ALTERNATIVE ENERGY EVALUATION..... | 24 |
| 5.1 Geothermal | |
| 5.2 Solar | |
| 5.3 Wind | |
| 5.4 Combined Heat and Power Generation (CHP) | |
| 5.5 Biomass Power Generation | |
| 5.6 Demand Response Curtailment | |
| 6.0 EPA PORTFOLIO MANAGER..... | 30 |
| 7.0 CONCLUSIONS & RECOMMENDATIONS..... | 31 |

APPENDICES

| | |
|---|---|
| A | Utility Usage Analysis |
| B | ECM-1a Lighting Replacements |
| C | ECM-1b Install Lighting Occupancy Sensors |
| D | ECM-1c Lighting Replacements with Occupancy Sensors |
| E | ECM-2 Light Bulb Exchange |
| F | ECM-3a Replace Urinals and Flush Valves with Low Flow Units |
| G | ECM-3b Replace Toilets and Flush Valves with Low Flow Types |
| H | Not Used |
| I | ECM-3c Install Low Flow Showerheads |
| J | ECM-4 Thermostats and Control Valves for Steam Radiators |
| K | ECM-5 Install Door Seals |
| L | ECM-6 Insulate Steam and Condensate Piping |
| M | ECM-7 Air Conditioner Changeout |
| N | ECM-8 Night Setback for Offices and Community Room |
| O | ECM-9 Boiler Replacement |
| P | ECM-10 Window Replacements |
| Q | ECM-11a Insulate NBHA Office Walls |
| R | ECM-11b Insulate Area Below the NBHA Offices and Community Room |
| S | ECM-12a Install On/Off Controls for Apartment Exhaust Fans |
| T | ECM-12b Install On/Off Controls for Common Area Exhaust Fans |
| U | ECM-13 Energy Star Appliances |
| V | ECM-14 Photovoltaic Power Generation |
| W | EPA Energy Star Portfolio Manager Report |
| X | New Jersey Pay for Performance Incentives |
| Y | Equipment Inventory |

1.0 INTRODUCTION & BACKGROUND

The North Bergen Housing Authority (NBHA) Edward A. Lawler Towers (Towers) is a 191,100 square foot facility located in North Bergen, New Jersey. The facility was built in 1967 and consists of two 15 floor towers, including the basement, with a connecting ground level Community Room situated between the two buildings. There are 253 senior citizen apartments in the complex, designated as Tower A and Tower B. Approximately 28 apartments, equaling slightly over 10%, were surveyed as part of the energy audit.

Tower A houses senior housing apartments, laundry room, boiler room in the basement, and the Community Room kitchen. Tower B consists of the NBHA Administrative Offices on the ground floor and senior housing apartments. The Community Room connects the south side of Tower A to the north of Tower B. NBHA Administrative Offices are comprised of a general work area with low partitions, conference room, server room, and five offices. An addition was recently constructed to the south side of the Tower B to expand the Administrative Offices.

New Jersey's Clean Energy Program, funded by the New Jersey Board of Public Utilities, supports energy efficiency and sustainability for Municipal and Local Government Energy Audits. Through the support of a utility trust fund, New Jersey is able to assist state and local authorities in reducing energy consumption while increasing comfort.

This report covers the energy audit for the North Bergen Housing Authority, Lawler Towers.

2.0 EXECUTIVE SUMMARY

This report details the results of the North Bergen Housing Authority's Lawler Towers, a 191,100 square foot senior housing complex in North Bergen, New Jersey. The facility consists of two 15 story buildings and a connecting Community Room. The following areas were evaluated for energy conservation measures:

- Lighting replacements
- Light bulb exchange
- Water conservation
- Thermostat and control valves for steam radiators
- Door seal replacement
- Insulation upgrade
- Air conditioner changeout
- Night setback
- Boiler replacement
- Window replacement
- Exhaust fan controls
- Energy Star appliances

Various potential Energy Conservation Measures (ECMs) were identified for the above categories. Measures which are recommended for implementation have a payback of 10 years or less. This threshold is considered a viable return on investment. Potential annual savings of \$181,100 for the recommended ECMs may be realized with a payback of 4.1 years.

The ECMs identified in this report will allow for the building to reduce its energy usage and if all the recommended ECMs are pursued has the opportunity to qualify for the New Jersey Pay For Performance Program. A summary of the costs, savings, and paybacks for the recommended ECMs follows:

ECM – 1c Lighting Replacements with Occupancy Sensors

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|---------|--------|--------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 147,400 | 25 | 195,100 | 0 | 27,800 | 0.9 | 13,600 | 5.3 | 4.5 |

* Incentive is based on the New Jersey Smart Start Prescriptive Lighting Measures.

ECM – 2 Light Bulb Exchange

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|--------|---------|--------|------|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | #2 Oil | Total | | | | |
| \$ | kW | kWh | gallons | \$ | | \$ | Years | Years |
| 6,000 | 48.1 | 24,054 | 0 | 11,600 | 8.68 | NA | 0.5 | NA |

* No incentive available.

ECM -3c Install Low Flow Showerheads

| Budgetary Cost | Annual Utility Savings | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Water / Sewer | Total | | | | |
| \$ | Kgal | \$ | | \$ | Years | Years |
| 17,300 | 850 | 7,600 | 5.6 | NA | 2.3 | NA |

* No incentive available.

ECM – 4 Thermostats and Control Valves for Steam Radiators

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-----|----------|--------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 114,700 | 0 | 0 | 10,400 | 11,500 | 0.5 | 18,700 | 10 | 8.4 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

ECM – 5 Install Door Seals

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-----|----------|-------|-------|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 1,700 | 0 | 0 | 210 | 200 | (0.4) | 400 | 7.2 | 5.6 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

ECM – 6 Insulate Steam and Condensate Piping

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-----|----------|--------|------|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 17,300 | 0 | 0 | 20,700 | 23,000 | 25.6 | 11,800 | 0.8 | 0.3 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program

ECM – 7 Air Conditioner Changeout

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|--------|----------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| NA | 0.0 | 16,900 | 0 | 2,500 | NA | NA | NA | NA |

* No incentive available.

ECM- 8 Night Setback for Offices and Community Room

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|--------|----------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 1,100 | 0.0 | 20,000 | 0 | 3,000 | 40 | 400 | 0.4 | 0.1 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

ECM- 9 Boiler Replacement

| Budgetary Cost | Annual Utility Savings | | | | ROI | New Jersey Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-----|----------|--------|-----|-----------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 335,900 | 0 | 0 | 35,100 | 39,000 | 1.3 | 63,300 | 8.6 | 7.0 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

ECM-11a Insulate the NBHA Office Walls

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|--------|----------|-------|------|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 8,300 | 0.0 | 41,100 | 0 | 6,200 | 21.4 | 4,200 | 1.3 | 0.7 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

ECM-11b Insulate Area Below the NBHA Offices and Community

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|--------|----------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 26,900 | 0.0 | 47,150 | 0 | 7,100 | 6.9 | 8,500 | 3.8 | 2.6 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

ECM-12a Install On/Off Controls for Apartment Exhaust Fans

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-------|----------|--------|------|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 11,800 | 0.0 | 6,537 | 14,200 | 16,700 | 20.2 | 5,900 | 0.7 | 0.4 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

ECM-12b Install On/Off Controls for Common Area Exhaust Fans

| Budgetary Cost | Annual Utility Savings | | | | ROI | New Jersey Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-------|----------|-------|-----|-----------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 7,600 | 0.0 | 2,179 | 1,575 | 2,100 | 3.1 | 3,200 | 3.6 | 2.1 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

ECM – 13 Energy Star Appliances

| Budgetary Cost | Annual Utility Savings | | | | ROI | New Jersey Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|---------|----------|--------|-----|-----------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 177,200 | 0.0 | 106,600 | | 16,000 | 0.4 | 19,200 | 11.1 | 9.9 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

3.0 EXISTING CONDITIONS

3.1 Building – General

Lawler Towers, 191,100 square feet, is comprised of two 15 story (including the basement) towers for senior housing. A large Community Room connects Tower A and B. The ground floor of Tower B houses the NBHA Administrative Offices. The building's exterior is composed of face brick and concrete with some metal fascia on a concrete foundation. The Community Room's exterior on the east and west is a 4 inch insulated panel and double pane windows, with a precast slab floor over a large open crawl space. The crawl space provides access to the steam, condensate, and domestic hot water piping fed from Tower A to Tower B. The roof of both Towers is a flat built up with drains original to the construction. The roof over the Community Room is a series of pitched built ups. The basement of Tower A houses the boiler/electrical room, storage, and compactor room. The basement of Tower B houses the electrical room, storage rooms, and compactor room.

Heat to Towers A and B is provided by fintube radiators in the apartments fed from the two 125 BHP Kewanee low pressure fire tube steam boilers located in the basement of Tower A. The domestic hot water heating is supplied through three PVI gas fired condensing water heaters. The diesel fired emergency generator for the entire complex is located on the west side of the Community Room, and is automatically tested once per week for one hour. It is used for emergency power only.

Apartment toilets and kitchens, and common elevators and hallways are ventilated by seven exhaust fans located on the roofs of each tower. There is no active means of makeup air to the building. The laundry room is located on the ground floor of Tower A and operates with ten washing machines and ten 146,000 BTUH gas-fired dryers.

The Towers are occupied continually, with the exception of the Administrative Offices, which are operational approximately eight to ten hours per day, five days a week. Other multi-use spaces such as the Community Room can be occupied into the evening hours.

An inventory of equipment for all energy consuming units is provided in Appendix Y.

3.2 Utility Usage

The building uses electricity, natural gas, and diesel fuel. Water for boiler make up and potable uses is delivered by a public municipal water system, and sewer water is discharged to a municipal wastewater treatment system.

Electricity and natural gas are supplied and delivered by PSE&G. Electricity is delivered via one meter (#778003748), and natural gas is delivered via two meters (#2415033, #2600157). From July 2008 through June 2009, the building had an annual electric consumption of 1,650,800 kWh, with a demand peak of approximately 398.3 kW (occurring in July 2008), and an annual electric cost of \$247,800. This resulted in a blended electric unit cost of \$0.1501 per kWh. Natural gas consumption during the same period was 171,300 therms, for an annual cost of \$189,800. This resulted in a natural gas unit cost of \$1.108 per therm.

The building's 230 kW Cummins Model No. DFAB-5632283 emergency generator is fired by diesel fuel, and has a dedicated storage tank. The generator is run periodically for testing.

A summary of the monthly electricity and natural gas usages and charges for the past year is provided in Appendix A.

Electricity and natural gas commodity supply and delivery are presently purchased from PSE&G. The delivery component for electricity and natural gas will always be the responsibility of the utility that connects the facility to the power grid or natural gas distribution network; however, electrical and natural gas commodity supply can be purchased from a third party organization. Traditionally, the electrical and natural gas commodity supply entity will require one to three years of past energy bills to submit a contract. Contract terms can vary by supplier; therefore, all aspects of contract terms should be carefully considered before making a selection. A list of approved electrical and natural gas energy commodity suppliers is provided in Appendix A.

After a review of PSE&G tariffs, based on existing usage has been concluded that the building is in the correct utility rate structure for both natural gas and electricity. Electricity is billed under the Large Power and Lighting Tariff and natural gas is billed under the Large Volume Service.

3.3 HVAC Systems

3.3.1 Low Pressure Steam Heating System

Low pressure steam for the fintube radiation system is provided by two 125 BHP Kewanee fire tube boilers. The steam is fed to central vertical steam risers on the north, east, west, and south walls of Towers A and B. The low pressure steam feeds into the fintube radiation through a thermostatic trap, and into condensate risers to the left and right of the baseboard fintube. The condensate risers are ¾" lines that run the entire 15 floors.

The condensate return system was designed as a vacuum return system. Due to the season, the system was not in use; therefore, it could not be determined if the vacuum system portion of the condensate return was operational. However, through visual observation, it appeared to be in disrepair. At a minimum, the system operates as a basic condensate return system. Each Tower has a dedicated condensate pump return system. All condensate is pumped into a 7' long x 3' diameter receiver tank. Makeup water and boiler chemicals are also fed into the receiver tank. Two feedwater pumps supply makeup water to the respective Kewanee boiler.

There are no temperature control valves on any of the low pressure steam fintubes. Low pressure steam fills the fintube and condenses through the thermostatic valve as heat is transferred to the fintube. The entire heating system operates in this manner. Almost 60% of the condensate return lines are not insulated. This includes the ¾" return lines from the Towers, return lines from area unit heaters, condensate pumps, receiver tank, and feed pumps. There is no ductwork into the boiler room to supply combustion makeup air to the Kewanee boilers and PVI water heaters. There is a propeller fan in the northwest corner of the boiler room that looks like it was to be used for room ventilation or makeup air. The fan was missing drive belts.

3.3.2 Domestic Hot Water Heating System

The domestic hot water heating for the building is supplied through three PVI power VT gas fired condensing water heaters. Each system is designed for 1 MMBH capacity. Two systems usually carry the load with the third unit as a backup. The system contains a mixing valve and small recirculation pump. The heaters are located in the basement of Tower A.

3.3.3 Direct Expansion Air Conditioning Units

The NBHA Administrative Offices' mechanical air conditioning systems are comprised of six split direct expansion systems with remote condensers and ceiling mounted fan coil units. The fan coil units consist of the DX evaporator coil and electric reheat coil. Five of the systems are York split systems with condensers on the west side of the building. A sixth system is a Trane split system with the condenser located on the roof of the NBHA Director's Office. A small Sanyo split system conditions the server room. All systems have wall mounted thermostats for heating and cooling control.

The Community Room is heated and cooled by four Daiken heat pumps. The evaporator/fan sections are mounted in the ceiling, the associated condenser units are outside on the west side of the area.

Two ceiling radiant panels are mounted above the two doors leading outside on the east side of the Community Room to address the infiltration load from the doors opening and closing. It was unclear if the panels are operational since they were not being utilized during the site visit.

The Community Room has a Honeywell carbon dioxide (CO₂) detection system, with the CO₂ sensor located on the wall near the thermostats. The Daiken heat pumps do not have the capacity to bring in outside air; therefore, the CO₂ system was installed to bring in fresh air based upon CO₂ concentrations in the room. The system has a small muffin fan; isolation damper, and 6" round ductwork that pulls fresh air from a wall louver on the west wall above the ceiling and sends it to one of the Daiken units.

The document storage room on the first floor of Tower B has two Mitsubishi split AC units, with condensers mounted on the west side of the building. The room is heated with steam fin tube radiation.

Tower A has 159 window air conditioning units, Tower B has 155. The units range from 5000 BTUH to 10,000 BTUH in capacity. Almost all observed units had an EER below 10.

3.3.4 Exhaust Fans

Tower A and B each has seven roof exhaust fans for exhausting the apartments' bathrooms and kitchen hoods, and common hallways. During the site visit, the majority of the 14 exhaust fans were observed to be operational; two were observed to be off; and two were running but without any exhaust air, it is likely they had broken or missing drive belts.

The Community Room kitchen has a wall mounted exhaust fan near the range. The restrooms in the Office Conference Room and Director's Office are exhausted to the outside through individual small ceiling exhaust fans.

3.4 Lighting/Electrical

Most of the lighting was specified for efficiency in the late 1960s. By today's standards the building's lighting fixtures and controls are inefficient and can be upgraded. A majority of the lighting is provided by inefficient T-12 fixtures with magnetic ballasts. Most of the lighting in the NBHA Administrative Offices consists of inefficient T-12 fixtures with magnetic ballast which hang from the ceiling; however, in some of the recently renovated office areas square U-Tube efficient T-8 lighting fixtures were observed. Occupancy sensors were observed in the restrooms of the Administrative Offices.

Most of the observed apartments located on the top 13 floors of both Towers had enclosed T-8 ceiling mounted fixtures; T-12 under-cabinet lighting; and incandescent bulbs, ranging in size from 40 watts to 150 watts, located in ceiling fixtures and lamps. Some apartments also had screw-in compact fluorescent

light bulbs (CFL) in ceiling fixtures and lamps. Most of the original incandescent lighting fixtures in the apartments owned by NBHA have been replaced with efficient CFLs. No occupancy sensors were observed in the apartments. Most of the existing exit signs presently do not utilize high efficiency LED technology.

Outdoor lighting consists of high pressure sodium (HPS) and mercury vapor (MV) fixtures utilizing timers which allow for the fixtures to de-energize at a specific time to shut off fixtures during daylight hours. Outdoor lighting fixtures that are connected to timers turn on and off at a certain time each day. All observed outdoor lighting fixtures were observed to be off during our site visit.

3.5 Control Systems

There is no centralized building management system. All cooling and reheat systems are controlled with wall mounted dual function thermostats or separate heating and cooling thermostats. The domestic hot water system is managed from controls on the PVI boilers, and there are no sequencing controls on the Kewanee fire tube boilers. Each boiler operates off the water column and pressure controller.

There is no individual control of the heating in the apartments. The perimeter radiation provides heat and condenses back through the thermostatic trap. In the summer time, individual apartment cooling is provided with window air conditioners placed in the living room and/or bedroom.

4.0 ENERGY CONSERVATION MEASURES

The TREAT (Targeted Retrofit Energy Analysis Tool) modeling software was selected to perform the majority of the building energy analyses for this project. TREAT, designed and funded by the New York State Energy Research and Development Authority with software protocols specific to public housing projects, integrates fuel bill analysis, weather data, and building modeling information into a database environment. TREAT allows energy efficiency programs to track actual savings relative to predicted savings, and is designed to support Total Quality Management techniques.

TREAT integrates room-by-room heat loss analysis for public housing structures with an hourly energy model developed by the United States Department of Energy National Renewable Energy Lab. Combined, these tools provide enhanced whole building energy saving packages. It is also approved by USDOE for use in Weatherization Assistance Programs.

Cost estimates were performed using vendor quotes, RS Means costing guides, and industry experience. Costs were developed as lump sums while taking in account the existing conditions and project requirements. It is understood that any project greater than \$10,000 needs to follow Davis/Macon wages rates to comply with Federal Public contract requirements.

4.1 ECM-1 Lighting Upgrades

4.1.1 ECM-1a Lighting Replacements

A comprehensive fixture survey was conducted of common areas and approximately 10% of the apartments. The existing base case lighting energy consumption was calculated and compared to the proposed lighting replacements.

The following lighting upgrades were also considered where appropriate:

- Retrofit existing hallway and lobby T-12 fixtures (2' x 2' U-Tube) to 17 watt 2' lamps with reflector kits
- Replace apartment level hallway T-12 fixtures with T-8 fixtures.
- Retrofit existing T-12 34-watt 2 & 4 fixtures with T-8 28-watt lamps and electronic ballasts
- Replace incandescent exit signs with LED technology
- Retrofit outdoor incandescent wall mounted fixtures with outdoor rated efficient compact fluorescent fixtures

The above measures will allow the facility to stock only T-8 fixtures in the future. Presently, the facility has a mixture of T-12 and T-8 lamps with multiple ballast combinations. In the future, the facility should only purchase low wattage super T-8s and ballasts, such as the low wattage 4 ft 28 watt units. These lamps may be directly installed into any existing 34 watt fixture when lamps fail. This will provide optimal energy efficiency and decrease confusion when performing lighting fixture maintenance.

Lighting has an expected lifetime of 20 years, according to IEEE, and the estimated annual energy savings is 163,200 kWh for a total energy savings of 3,264,000 kWh (\$480,000) over the life of the project.

The implementation cost and savings related to this ECM are presented in Appendix B and summarized as follows:

ECM – 1a Lighting Replacements

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|---------|--------|--------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 111,300 | 25 | 163,200 | 0 | 24,000 | 3.3 | 16,200 | 4.7 | 4.0 |

*Incentive is based on the New Jersey Smart Start Prescriptive Lighting Measures.

This measure is not recommended in lieu of ECM-1c.

NBHA is considering replacing all T-12 fixtures located in the hallways of the senior housing apartment floors with new T-8 fixtures. Each floor has nine fixtures, and the fixture have 2 x 48" T-12 lamps with Mag-STD ballast, and would be replaced with 2 x 48" T-8 lamps with electronic ballast. For this study, a cost of \$250 per fixture was assumed for the replacements. Therefore, the payback for this replacement will be 7.5 years, or 6.7 years if the New Jersey Smart Start Prescriptive Lighting Measure incentive of \$25 per fixture is included.

4.1.2 ECM-1b Install Lighting Occupancy Sensors

In many areas of the Towers, occupancy varies based on usage and time of day. A lighting survey was conducted of all fixtures to determine the average time lights are presently on in each space. It is proposed that occupancy sensors be installed in selected rooms to turn off lights when the area is unoccupied.

Ceiling mounted lighting sensors were considered for the Community Room, NBHA's conference rooms and offices, as well as apartment kitchens and bathrooms. Occupancy sensors were not considered in mechanical areas and stairways due to safety concerns. Other areas were not considered due to the proposed location of the occupancy sensor. If a sensor does not have a clear view of the occupant's room or hallway, it may darken even with people in the space, creating an unsafe condition.

Occupancy sensors have an expected lifetime of 10 years, according to IEEE, and the estimated annual energy savings is 35,900 kWh for a total energy savings of 359,000 kWh (\$43,000) over the life of the project.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM – 1b Install Occupancy Sensors

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|--------|--------|-------|-----|-------------------------|-----------------------------------|-----------------------------|
| | Electricity | | Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 36,100 | 0.0 | 35,900 | 0 | 4,300 | 0.2 | 6,100 | 8.4 | 7.0 |

* Incentive is based on the New Jersey Smart Start Prescriptive Lighting Measures.

This measure is recommended in lieu of ECM-1c.

4.1.3 ECM-1c Lighting Replacements with Occupancy Sensors

This measure is a combination of ECMs 1a and 1b to allow for maximum energy and demand reduction. Due to interactive effects, the energy and cost savings for occupancy sensors and lighting upgrades are not cumulative. Presently, the facility has numerous fixtures that contain T-8, T-12 lamps with magnetic and electric ballasts. To increase reliability and ease of maintenance, all fixtures with the older technology should be upgraded so that NBHA has common T-8 lamps with electronic ballasts throughout the facility. Stocking low wattage 28 watt T-8s 4-foot lamps to replace the existing 32 watt lamps when they fail should be considered. These lamps can be installed in the existing efficient T-8 electronic ballasted fixtures and increase the energy efficiency of the system.

This type of system has an expected lifetime of 10 years and the estimated annual energy savings is 195,100 kWh for a total energy savings of 1,951,000 kWh (\$278,000) over the life of the project.

The implementation cost and savings related to this ECM are presented in Appendix D and summarized below:

ECM – 1c Lighting Replacements with Occupancy Sensors

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|---------|--------|--------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 147,400 | 25 | 195,100 | 0 | 27,800 | 0.9 | 13,600 | 5.3 | 4.5 |

* Incentive is based on the New Jersey Smart Start Prescriptive Lighting Measures.

This measure is recommended.

4.2 ECM-2 Light Bulb Exchange

Approximately 28 apartments were surveyed as part of this energy audit. It is estimated that approximately 1,100 incandescent light bulbs are presently used in various tenant-owned lamps and plug-in lighting fixtures. For this ECM, the energy savings that could be realized if the NBHA initiated a bulb exchange program to replace tenant owned incandescent bulbs with higher efficient CFL bulbs was determined. This measure has less than a one year of payback, assuming an estimated cost of \$5 per bulb replaced.

Light bulbs have an expected lifetime of about five years and the estimated annual energy savings is 24,054 kWh for a total energy savings of 120,270 kWh (\$58,000) over the life of the project.

The implementation cost and savings related to this ECM are presented in Appendix E and summarized as follows:

ECM – 2 Light Bulb Exchange

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|--------|---------|--------|------|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | #2 Oil | Total | | | | |
| \$ | kW | kWh | gallons | \$ | | \$ | Years | Years |
| 6,000 | 48.1 | 24,054 | 0 | 11,600 | 8.68 | NA | 0.5 | NA |

* No incentive available.

This measure is recommended.

4.3 ECM-3 Water Conservation**4.3.1 ECM-3a Replace Urinals and Flush Valves with Low Flow Types**

There are two urinals in the Lawler complex, which would be replaced with low flow flush valves.

This measure is not recommended due to the long payback. However, when the urinals have to be replaced, it is recommended that the low flow fixtures be considered.

The implementation cost and savings related to this ECM are presented in Appendix F and summarized below:

ECM -3a Replace Urinals and Flush Valves with Low Flow Types

| Budgetary Cost | Annual Utility Savings | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-------|-----|-------------------------|--------------------------------|-----------------------------|
| | Water / Sewer | Total | | | | |
| \$ | Kgal | \$ | | \$ | Years | Years |
| 1,300 | 11 | 100 | NA | NA | 13.0 | NA |

* No incentive available.

This measure is not recommended.

4.3.2 ECM-3b Replace Toilets and Flush Valves with Low Flow Types

There are 260 toilets in the Lawler complex. Approximately half have been replaced over the years with low flow fixtures. This measure considers replacing the remaining toilets with new low flow fixtures.

The implementation cost and savings related to this ECM are presented in Appendix G and summarized as follows:

ECM -3b Replace Toilets and Flush Valves with Low Flow Types

| Budgetary Cost | Annual Utility Savings | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Water / Sewer | Total | | | | |
| \$ | Kgal | \$ | | \$ | Years | Years |
| 59,000 | 541 | 4,900 | NA | NA | 12.1 | NA |

* No incentive available.

This measure is not recommended.

4.3.3 ECM-3c Install Low Flow Showerheads

There are 252 showers in the apartments in the Lawler complex. The showers have the standard showerhead that is nominally rated at 2.5 gallons per minute. LEED information indicates that an average shower last for approximately five minutes. This measure would install new 1.6 GPM showerheads to replace the existing 2.5 GPM showerheads.

Showerheads have an expected lifetime of about 15 years and the estimated annual water and sewer savings are 850 Kgal for a total savings of 12,750 Kgal (\$114,000) over the life of the project.

The implementation cost and savings related to this ECM are presented in Appendix I and summarized below:

ECM -3c Install Low Flow Showerheads

| Budgetary Cost | Annual Utility Savings | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Water / Sewer | Total | | | | |
| \$ | Kgal | \$ | | \$ | Years | Years |
| 17,300 | 850 | 7,600 | 5.6 | NA | 2.3 | NA |

* No incentive available.

This measure is recommended.

4.4 ECM-4 Thermostats and Control Valves for Steam Radiators

The apartments are heated with low pressure steam. The steam is supplied from two Kewanee 125 BHP low pressure steam boilers. The steam heating system is comprised of the steam supply main, fintube radiation that transfers heat to the apartment, and the condensate return headers. Each Tower has a series of steam headers that run from the basement to the top floor.

The apartments have no temperature control thermostats to regulate the heat from the fintube. Heat is given off the fintube into the surrounding space. If the space becomes too hot, the windows are opened to cool the space.

This measure evaluates installing a self contained, temperature control valve on each leg of the fintube in each apartment. The control valve would have a capillary tube that would extend from the control valve to a wall mounted thermostat to allow the tenant to set and control to a particular space temperature with a temperature limit. This would not allow the occupant to raise the temperature above a set maximum

temperature limit, which for the purposes of this study is assumed to be 72°F, unless it is approved by NBHA. The maintenance staff would be able to change the temperature limit for occupants that need a higher temperature. A cutsheet of a proposed control valve and thermostat is presented in Appendix J.

Thermostats and control valves have an expected lifetime of 15 years, according to ASHRAE, and the estimated annual energy savings is 10,400 therms for a total energy savings of 156,000 (\$172,500) therms over the life of the project.

The implementation cost and savings related to this ECM are presented in Appendix J and summarized below:

ECM – 4 Thermostats and Control Valves for Steam Radiators

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-----|----------|--------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 114,700 | 0 | 0 | 10,400 | 11,500 | 0.5 | 18,700 | 10 | 8.4 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

This measure is recommended.

4.5 ECM-5 Install Door Seals

Some of the door seals on the outside doors at the Towers are worn, and some maintenance access doors have no door seals. This has caused issues in the past with fire protection pipes in the basement of Tower B freezing during winter. This measure recommends new door seals be installed to eliminate infiltration and potential pipe freezing.

Door seals have an expected lifetime of a door seal is about 5 years and the estimated annual energy savings is 210 therms for a total energy savings of 1,050 therms (\$1,150) over the life of the project.

The implementation cost and savings related to this ECM are presented in Appendix K and summarized below:

ECM – 5 Install Door Seals

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-----|----------|-------|-------|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 1,700 | 0 | 0 | 210 | 230 | (0.4) | 400 | 7.2 | 5.6 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

This measure is recommended.

4.6 ECM-6 Insulate Steam and Condensate Piping

Lawler Tower A houses the two Kewanee 125 BHP low pressure steam boilers along with the condensate return pump for Tower A, the condensate heatwell tank, and the boiler feed pumps. Each Tower has 14

condensate return lines that are ¾" and 1-1/4" in line size. They return the condensate from the fintube radiators in the apartments. All lines feed back to a condensate return pump, and the pumped condensate from each system goes to the heatwell tank where it is fed to the boilers.

The condensate return lines from the steam radiators and unit heaters and the two condensate receivers are uninsulated. The pumped condensate lines are partially insulated. The 3' diameter x 7' long heatwell tank is uninsulated.

The heat released by these uninsulated lines and vessels has to be made up in the boilers. The hotter the condensate coming back to the boiler, the less energy is required to boil the water to make steam.

The expected lifetime of piping insulation is about 20 years and the estimated annual energy savings is 20,700 therms for a total energy savings of 414,000 therms (\$460,000) over the life of the project.

The implementation cost and savings related to this ECM are presented in Appendix L and summarized below:

ECM – 6 Insulate Steam and Condensate Piping

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-----|----------|--------|------|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 17,300 | 0 | 0 | 20,700 | 23,000 | 25.6 | 11,800 | 0.8 | 0.3 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

This measure is recommended.

4.7 ECM- 7 Air Conditioner Changeout

Lawler Towers has 314 window air conditioners ranging in capacity from 5,000 BTUH to 10,000 BTUH. The operational EER is estimated at between 8 to 9. All of these units are owned by the tenants who pay a monthly fee for the operational cost of the units. The rated EER on typical newer units is 10 to 12. Some of the newer units were observed to be higher efficiency units.

The available cooling capacity of the existing units is around 2,000,000 BTUH. The TREAT Model indicates that only about 25% of this capacity is used during a typical cooling hour. This measure proposes that new tenants to North Bergen Housing Authority buildings be required to use only Energy Star rated air conditioners with an EER above 10. Most EPA Energy Star rated window air conditioners are in this category. Energy Star rated air conditioners use at least 10% less energy than conventional models as published by the U.S. Environmental Protection Agency and the U.S. Department of Energy. For this ECM, it was assumed that the air conditioners used with average an EER of 12.

There is no implementation cost to this ECM. The savings related to this ECM are presented in Appendix M. The savings for an eventual change out over time are as follows:

ECM – 7 Air Conditioner Changeout

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|--------|----------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| NA | 0.0 | 16,900 | 0 | 2,500 | NA | NA | NA | NA |

* No incentive available.

This ECM is recommended.

4.8 ECM- 8 Night Setback for Offices and Community Room

The 3,200 SF Community Room is heated and cooled using four Daiken ceiling mounted heat pumps. Currently, the units operate to maintain a specified setpoint.

NBHA offices, conference room, and server room are air conditioned by five York air conditioning systems. These units range in cooling capacity from 2 to 5 tons, and have remote condensers located on the west side of the building. The fan coil units are mounted in the ceiling with air distribution to multiple diffusers in the respective rooms. Heating is provided by electric reheats. The Director's Office is heated and cooled from a roof mounted Trane unit.

All the systems have programmable thermostats for controlling space temperature. This measure proposes that the existing programmable thermostats be programmed for night setback of the heating and cooling space temperatures to save energy. As part of this measure, all air cooled condensers should be cleaned to reduce the operating head pressure of the compressors, improving system efficiency.

Night setback has an expected lifetime of 15 years, according to ASHRAE, and the estimated annual energy savings is 20,000 kWh for a total energy savings of 300,000 kWh (\$45,000) over the life of the project.

The implementation cost and savings related to this ECM are presented in Appendix N and summarized below:

ECM- 8 Night Setback for Offices and Community Room

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|--------|----------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 1,100 | 0.0 | 20,000 | 0 | 3,000 | 40 | 400 | 0.4 | 0.1 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

This measure is recommended.

4.9 ECM- 9 Boiler Replacement

Lawler Towers A and B are heated by two 125 BHP Kewanee horizontal fire tube boilers. Each boiler consists of a three pass boiler with a Coen MicroNOx, low NOx burner assembly that utilizes flue gas recirculation (FGR). The FGR burner assembly takes exhaust from the boiler stack and mixes it with

fresh combustion air to arrive at a low NOx emission. These systems are very effective at delivering a low NOx output (< 30 part per million) but do not allow for high turn down boiler modulation. This lack of modulation at low fire causes the boiler to shut down and restart continuously. When a boiler shuts down, it has to go through a pre-purge and heat up cycle that wastes energy and lowers the overall system efficiency, particularly in the spring and fall months.

Replacing the two existing burners with newer technology burners would allow for some higher turn down and continued low NOx operation, but would not result in substantially higher boiler efficiency.

This measure recommends replacing the two Kewanee boilers with four new high efficiency (> 84%) boilers and control system. The newer high efficiency designs allow for maintained boiler efficiencies above 84% despite the turn down. A conservative efficiency rating of 65% was used to perform energy saving calculations. A comprehensive boiler plant study should be performed before entering into a full capital project. Capital cost of the four boilers could be reduced if it was determined that the implementation of ECM-4 (Thermostats and Control Valves for Fintube Radiation) and ECM-6 (Insulate Steam and Condensate Piping) saved sufficient energy to feasibly reduce boiler plant size. A cutsheet of a proposed high efficiency low pressure steam boiler is presented in Appendix O.

Boilers have an expected lifetime of about 20 years, according to ASHRAE, and the estimated annual energy savings is 31,100 therms for a total energy savings of 622,700 (\$780,000) therms over the life of the project.

The implementation cost and savings related to this ECM are presented in Appendix O and summarized below:

ECM- 9 Boiler Replacement

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-----|----------|--------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 335,900 | 0 | 0 | 35,100 | 39,000 | 1.3 | 63,300 | 8.6 | 7.0 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

This measure is recommended.

4.10 ECM-10 Window Replacements

The existing double pane aluminum framed slider windows in both of the Lawler Towers were replaced in 1990. As part of the study, NBHA requested an assessment of replacing the windows with triple panes. To replace the existing windows would result in a total utility savings of approximately \$5,000. The cost to replace one 3' x 5' window is approximately \$450.

The implementation cost and savings related to this ECM are presented in Appendix P and summarized as follows:

ECM- 10 Window Replacements

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-----|----------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 1,178,400 | 0 | 0 | 4,500 | 5,000 | NA | 8,120 | > 30 | > 30 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program

This measure is not recommended.

4.11 ECM-11 Insulation Addition**4.11.1 ECM-11a Insulate NBHA Office Walls**

The new NBHA Administrative Offices were constructed in an area formerly used as an open balcony. The area was enclosed with new outside walls and interior walls and finishes. According to NBHA staff, due to budgetary constraints at the time of construction, the outside walls were not adequately insulated. These walls face west and are impacted by the prevailing winds. Therefore, the offices with windows are colder than other NBHA office space during the winter months.

This measure would use blown-in insulation to insulate the estimated 3-1/2" interior walls. The existing outside window wall panels would be repaired and resealed to eliminate infiltration. The walls would potentially be insulated from the outside. All wall panels would be capped and painted to match existing finishes at completion of the insulation work.

The insulation has an expected lifetime of over 30 years, according to ASHRAE, and the estimated annual energy savings is 41,100 kWh for a total energy savings of 1,233,000 kWh (\$186,000) over the life of the project.

The implementation cost and savings related to this ECM are presented in Appendix Q and summarized below:

ECM-11a Insulate NBHA Office Walls

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|--------|----------|-------|------|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 8,300 | 0.0 | 41,100 | 0 | 6,200 | 21.4 | 4,200 | 1.3 | 0.7 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

This measure is recommended.

4.11.2 ECM-11b Insulate Area Below the NBHA Offices and Community Room

The area below the Community Room and NBHA Administrative Offices consists of a crawl space for utilities, steam condensate pump, and a former chiller room. The floor of the Community Room and offices is an uninsulated concrete slab. The total affected area is approximately 8,000 SF. There are also

several louvered grilles in the basement wall for ventilation. During the winter months, the offices and Community Room are cold from the heat lost through the floor slabs.

This measure would insulate the floor slabs of the Community Room and NBHA Offices with 3" board insulation (R-19).

Insulation has an expected lifetime of over 30 years, according to ASHRAE, and the estimated annual energy savings is 47,150 kWh for a total energy savings of 1,414,500 kWh (\$213,000) over the life of the project.

The implementation cost and savings related to this ECM are presented in Appendix R and summarized below:

ECM-11b Insulate Area Below the NBHA Offices and Community Room

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|--------|----------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 26,900 | 0.0 | 47,150 | 0 | 7,100 | 6.9 | 8,500 | 3.8 | 2.6 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

This measure is recommended.

4.12 ECM-12 Exhaust Fan Controls

Lawler Tower A and B have seven roof exhaust fans each. The exhaust airflow for the facility is 24,000 CFM. The exhaust fans ventilate the common areas (hallways); and apartment stove exhaust and bathroom exhaust. The fans run continuously.

4.12.1 ECM-12a Install On/Off Controls for Apartment Exhaust Fans

The apartment exhaust constitutes approximately 6,000 CFM for each tower, for a total of 12,000 CFM.

This measure would install a stand alone controller and relay panel to turn the common area and apartment fans off for eight hours a day. This measure would reduce the combined motor horsepower of the fans, and heating and cooling of the makeup air.

Per New Jersey building code, for intermittent operation 100 cfm of exhaust is required in kitchens and 50 cfm in bathrooms. For continuous operation, 25 cfm is required in kitchens and 20 cfm in bathrooms.

A modification of this ECM that may have equal savings is to re-balance the system to meet the current code requirements. A review of past documentation reveals exhaust rates higher than code currently requires.

The controls have an expected lifetime of 15 years, according to ASHRAE, and the estimated annual energy savings is 6,500 kWh and 14,200 therms for a total energy savings of 98,000 kWh and 213,000 therms (\$250,500) over the life of the project.

The implementation cost and savings related to this ECM are presented in Appendix S and summarized below:

ECM-12a Install On/Off Controls for Apartment Exhaust Fans

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-------|----------|--------|------|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 11,800 | 0.0 | 6,500 | 14,200 | 16,700 | 20.2 | 5,900 | 0.7 | 0.4 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

This measure is recommended.

4.12.2 ECM-12b Install On/Off Controls for Common Area Exhaust Fans

The common area exhausts for the general areas constitute 7,500 CFM for each tower.

This measure would install a stand alone controller and relay panel to turn off the common area fans for a period of eight hours per day to reduce the combined motor horsepower and heating and cooling of makeup air.

A modification of this ECM that may have equal savings is to re-balance the system to meet the current code requirements. A review of past documentation reveals exhaust rates higher than code currently requires.

Controls have an expected lifetime of 15 years, according to ASHRAE, and the estimated annual energy savings is 2,200 kWh and 1,575 therms for a total energy savings of 32,700 kWh and 23,600 therms (\$31,500) over the life of the project.

The implementation cost and savings related to this ECM are presented in Appendix T and summarized below:

ECM-12b Install On/Off Controls for Common Area Exhaust Fans

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-------|----------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 7,600 | 0.0 | 2,200 | 1,575 | 2,100 | 3.1 | 3,200 | 3.6 | 2.1 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

This measure is recommended.

4.13 ECM-13 Energy Star Appliances

There are 253 apartments in the Towers, each with a standard refrigerator; size ranges between 15.5 to 17 cubic feet.

This measure evaluates replacement of the existing refrigerators with new Energy Star units. Energy Star qualified refrigerators are required by the U.S. Department of Energy to use 20% less energy than models not labeled "ENERGY STAR".

Refrigerators have an expected lifetime of 15 years, according to ASHRAE, and the estimated annual energy savings is 106,600 kWh for a total energy savings of 1,599,000 kWh (\$247,500) over the life of the project.

The implementation cost and savings related to this ECM are presented in Appendix U and summarized below:

ECM – 13 Energy Star Appliances

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|---------|----------|--------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 177,200 | 0.0 | 106,600 | | 16,000 | 0.4 | 19,200 | 11.1 | 9.9 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

This measure is recommended.

4.14 North Bergen Housing Authority Building Incentives

The North Bergen Housing Authority's energy conservation project will be eligible for various incentives by the New Jersey Office of Clean Energy.

The largest incentives available will be for the New Jersey Pay for Performance P4P Program. The P4P program is designed for qualified energy conservation projects in facilities that consume a minimum average electric demand of 200 kW per month (total of 12 months peak demand/12). Facilities that meet this criterion must also achieve a minimum performance target of 15% by using the EPA portfolio manager benchmarking tool before and after construction. Incentives for this program are in three parts.

Incentive #1 energy reduction plan pays \$0.05 per square foot to a maximum of \$25,000 or 25% of facility annual energy cost paid after approval of application. Incentive #2 is paid after installation of recommended measures; base incentives deliver \$0.11/kWh and \$1.10/therm not to exceed 30% of total project cost. Incentive #3 post-construction benchmarking is paid after acceptance of a report proving energy savings over one year utilizing the EPA portfolio manager benchmarking tool. Incentive #3 base incentives deliver \$0.07/ kWh and \$0.70/therm not to exceed 20% of total project cost. Combining incentives #2 and #3 will deliver a total of \$0.18/ kWh and \$1.8/therm not to exceed 50% of total project cost. Additional incentives for #2 and #3 are increased by \$0.005/kWh and \$0.05/therm for each percentage increase above the minimum performance target calculated with the EPA portfolio manager benchmarking tool not to exceed 50% of total project cost.

A new incentive structure has been announced for projects exceeding 20% in energy savings utilizing the required EPA portfolio manager benchmarking tool. The new incentive structure will double incentives #2 and #3, therefore providing a total of \$0.36/kWh and a \$3.60/ therm for projects exceeding 20%.. Incentive #1 for application and energy reduction plan has not changed yet the maximum incentive has now been raised to 80% of project costs. The 200 kW/month average minimum has been dropped so any structure can apply. This new incentive structure will be in effect until December 31st, 2009.

For detailed description of the (P4P) program see Appendix T.

Lighting energy reduction incentives were calculated utilizing the New Jersey SmartStart Building prescriptive lighting measures and incentive program. This program includes incentives dependent upon the existing fixture type and proposed lighting retrofit measure. Prescriptive lighting incentives were utilized for this report to demonstrate potential savings if only lighting was selected for implementation.

If the North Bergen Housing Authority energy conservation project qualifies and enters into the New Jersey Pay for Performance Program, lighting savings will be included in total building energy usage and savings; applicants cannot apply for both programs in the same project.

Pay for Performance projects for the five customer classes listed below will be eligible for increased incentive levels:

- Hospitals
- Non-profits
- Public colleges/universities
- Governmental entities not receiving Energy Efficiency and Conservation Block Grants (EECBG)
- Affordable multifamily housing ("affordable" is defined as low income, subsidized, HUD, etc.)

Increased incentive levels are as follows:

- Incentive #2: If a reduction in energy consumption of 20% or more is projected, above listed customers will be eligible for an additional \$0.11/kWh and \$1.10/therm
- Incentive #3: If a reduction in energy consumption of 20% or more is achieved, above listed customers will be eligible for an additional \$0.07/kWh and \$0.70/therm
- Incentive #2 and #3 combined may not exceed 80% of the total project cost
- Incentive cap is \$2 million per gas account and \$2 million per electric account
- 200kW threshold is not required

In order to take advantage of this opportunity Partners must submit the following by December 31, 2009:

- A signed P4P Initial Application, including
 - W9
 - 12 months utility bills
- Copy of Partner-Participant Contract
- EPA Portfolio Benchmarking results (may be print out)
- Cover letter indicating
 - Modeling software to be used in developing ERP
 - Type of customer class

Partners that have already submitted Initial Applications for eligible customer classes will be allowed to take advantage of the increased incentive levels.

5.0 ALTERNATIVE ENERGY EVALUATION

5.1 Geothermal

Geothermal heat pumps (GHP) transfer heat between the constant temperature of the earth and the building to maintain the building's interior space conditions. Below the surface of the earth throughout New Jersey the temperature remains in the low 50°F range throughout the year. With GHP systems, water is circulated between the building and the piping buried in the ground. The ground heat exchanger in a GHP system is made up of a closed or open loop pipe system. Most common is the closed loop, in which high density polyethylene pipe is buried horizontally at 4-6 feet deep or vertically at 100 to 400 feet deep. These pipes are filled with an environmentally friendly antifreeze/water solution that acts as a heat exchanger. In the summer, the water picks up heat from the building and moves it to the ground. In the winter the system reverses and fluid picks up heat from the ground and moves it to the building. Heat pumps make the collection and transfer of this heat to and from the building possible.

At present, there is no central chiller system or heat pump system from which to reject heat. The heating system is low pressure steam with a high condensate return percentage (> 90%). NBHA's property is in a city environment and consists mainly of buildings and parking area. Due to the limited green space, installation of a buried ground loop may not be possible.

Geothermal is not recommended due to the lack of opportunity to take advantage of any generated geothermal heat transfer, and unavailability of green space to install a buried ground loop system.

5.2 Solar

5.2.1 Photovoltaic (PV) Rooftop Solar Power Generation

The roof of Lawler Apartment Towers A and B were evaluated for the potential to install rooftop photovoltaic (PV) solar panels for the purpose of power generation. Present technology incorporates the use of solar cell arrays that produce direct current (DC) electricity. This DC Current is converted to alternating current (AC) with the use of an electrical device called an inverter. The roof of both Lawler Towers have room to install a small solar cell array between the edge of the roof and the roof exhaust fans in the center of the structure. The roof would be the most feasible location for any installation since it has a south face with no obstructions and has minimum rooftop obstructions such as rooftop units and exhaust fans.

To calculate the PV power generation, the PVWatts™ solar power generation model was utilized. The New Jersey clean power estimator that is provided by the NJCEP is presently going through updates, therefore they recommend using the PVWatts™ Version 1 calculator. The closest city available in the model is Newark, NJ and a fixed tilt array type was utilized to calculate energy production. PVWatts™ solar power generation model and satellite image of roof area may be found in Appendix V.

The incentive in the State of New Jersey for nonresidential solar PV applications is \$1.00 /Watt up to 50 kW of installed PV array. Federal tax credits are also available for renewable energy projects up to 30% of installation costs. NBHA does not pay Federal taxes, and, therefore, would not be able to utilize the Federal tax credit incentive.

Installation of PV arrays in the State of New Jersey will allow the owner to participate in the New Jersey Solar Renewable Energy Certificate (SREC) program. This is a program that has been set up to allow entities with large amounts of environmental emissions to purchase credits from zero emission PV solar-

producers. An Alternative Compliance Penalty (ACP) is paid for by the high emission producers and is set each year on a declining scale of 3% per year. One SREC credit is equivalent to 1,000 kilowatt hours of PV electrical production; these credits can be traded for period of 15 years from the date of installation. The cost of the APC penalty for 2009 is \$689; this is the amount that must be paid per SREC by the high emission producers. The dollar amount that will be paid to the PV producer for 2009 is expected to be \$600/SREC credit. Payments that will be received from the PV producer will change from year to year dependent upon supply and demand. As stated above, there is no definitive way to calculate an exact price that will be received by the PV producer per SREC over the next 15 years. R & R Renewable Energy Consultants, a third party SREC broker that has been approved by the NJCEP, estimated an average of \$487/ SREC per year and this number was utilized in the cash flow for this report.

Lawler Apartments has a maximum kW demand of 398.3 kW and a minimum kW of 212.5 kW. The monthly average over the year observed was 280.8 kW. The existing load would justify the use of a large PV solar array. A 20 kW system was selected for the calculations based on available roof area. The system costs for PV installations were derived from the most recent NYSEDA (New York State Energy Research and Development Authority) estimates of total cost of system installation. It should be noted that the cost of installation is now \$10.00 per watt or \$10,000 per kW of installed system. This has increased in the past few years due to the great national demand for PV power generator systems. Other cost considerations will also need to be considered. PV panels have a multiple decade life span yet the inverter device that converts DC electricity to AC has a planned life span of 10 to 12 years and will need to be replaced multiple times during the useful life of the PV system.

This measure is not recommended at this time due to the long payback period; however, could be a potentially viable renewable measure for the NBHA to consider in the future if electricity rates continue to increase above \$0.15/kWh and if PV installation costs decline below \$10 per Watt.

Photovoltaic solar panels have an expected lifetime of 15 years, according to ASHRAE, and the estimated annual energy savings was 23,700 kWh for a total energy savings of 355,000 kWh (\$53,250) over the life of the project. The implementation cost and savings related to this ECM are presented in Appendix V and summarized below:

ECM-14 Photovoltaic (PV) 20 kW Rooftop Solar Power Generation

| Budgetary Cost | Annual Utility Savings | | | | ROI | New Jersey Renewable Energy Incentive* | New Jersey Renewable SREC** | Payback (without incentive) | Payback (with incentives) |
|-------------------|------------------------|--------|---------|-------|-------|--|--------------------------------------|-----------------------------------|---------------------------------|
| | Electricity | | #2 Oil | Total | | | | | |
| \$ | kW | kWh | gallons | \$ | | \$ | \$ | Years | Years |
| 200,000 | 0 | 23,700 | 0 | 3,550 | (0.7) | 20,000 | 11,515 | > 30 | 11.9 |

*Incentive based on New Jersey Renewable Energy Program for non-residential applications of \$1.00 per Watt of installed capacity

** Estimated Solar Renewable Energy Certificate Program (SREC) for 15 years at \$487/1000 kWh

This is a potentially viable renewable measure that the North Bergen Housing Authority may want to consider investigating further in the future.

5.2.2 Solar Thermal Domestic Hot Water Plant

Active solar thermal systems use solar collectors to collect the sun's energy to heat water, another fluid, or air. The heart of a solar collector is an absorber that converts the sun's energy into heat. The heat is then transferred by circulating water, antifreeze, or sometimes air to another location for immediate use or

storage for later use. Applications for active solar thermal energy include providing hot water, heating swimming pools, space heating, and preheating air in both residential and commercial buildings.

A standard solar hot water system is typically composed of solar collectors, heat storage vessel, piping, circulators, and controls. Solar radiation is absorbed by the collector, and the heat collected is commonly used to heat or preheat water or air. Systems are typically integrated to work alongside a conventional heating system that provides heat when solar resources are not sufficient. The solar collectors are usually placed on the roof of the building, oriented south, and tilted around the site's latitude, so as to maximize the amount of radiation collected on a yearly basis.

There are several options for using active solar thermal systems for space heating; most common method involves using glazed collectors to heat a liquid held in a storage tank (similar to an active solar hot water system). The most practical system for Lawler Towers would be to transfer the heat from the panels to thermal storage tanks in the basement and transfer solar-produced thermal energy for domestic hot water production.

Currently, there are no incentives available for installation of thermal solar systems. There is a Federal tax credit of 30% of installation cost for the thermal applications; however, NBHA does not pay Federal taxes and, therefore, would not benefit from this program.

This is not recommended due to the proximity of the proposed solar collectors to the location of the existing domestic hot water system, consisting of 15 stories of housing and two subbasements of mechanical, electrical, and storage areas, with no easy route for the piping. The existing PVI condensing hot water heaters are already over 90% efficient. The area on the roof that would be used for the solar collectors is the same area that would be used for photovoltaic panels, which have a more direct potential payback.

5.3 Wind

Wind energy is a form of solar energy created by the uneven heating of the earth's surface by the sun. Most small wind turbines use a horizontal axis propeller, or rotor, to capture the kinetic energy of the wind and convert it into rotary motion to drive a generator which usually is designed specifically for the wind turbine. The rotor consists of two or three blades, usually made from wood or fiberglass. These materials give the turbine the required strength and flexibility, and have the added advantage of not interfering with television signals. The structural backbone of the wind turbine is called the mainframe, and it includes the "slip-rings" that connect the wind turbine, which rotates as it points into changing wind directions, and the fixed tower wiring. The tail aligns the rotor into the wind.

To avoid turbulence and capture greater wind energy, most turbines are mounted on towers. As a rule of thumb, turbines should be mounted at least 30 feet above any structures or natural features within 300 feet of the installation. Smaller turbines can go on shorter towers. For example, a 250-watt turbine may be mounted on a 30-50 foot tower, while a 10 kW turbine will usually need a tower of 80-120 feet. Towers are available in a variety of designs, including tubular or latticed, guyed or self-supporting. Wind turbine manufacturers also offer towers, and can verify that the tower meets required building and safety specifications as well as being compatible with the turbine.

The New Jersey Clean Energy Program for small wind installations has assigned numerous pre-approved wind turbines for installation in the State of New Jersey. Incentives for wind turbine installations are based on kilowatt hours saved in the first year. Systems size under 16,000 kWh per year of production will receive a \$3.20 per kWh incentive. Systems producing over 16,000 kWh will receive \$51,200 for the

first 16,000 kWh of production with an additional \$0.50 per kWh up to a maximum cap of 750,000 kWh per year. These incentives can make a project like this very cost effective. Federal tax credits are also available for renewable energy projects up to 30% of installation cost for systems less than 100 kW.

The most important part of any small wind generation project is the mean annual wind speed at the height of which the turbine will be installed. Due to the height of the Lawler Towers (15 stories), a vertical wind turbine could be located on the roof of the building and potentially attached to the elevator penthouse. A structural review of the roof and elevator penthouse would have to be performed to evaluate the effect of wind loads on the existing structure. A previous evaluation was performed for NBHA for this type of turbine; however, the potential savings were not attractive and the study was not progressed. A wind resource map downloaded from the AWS Truewind Corporation indicates that that mean annual wind speed at 30 meters in the North Bergen area is greater than 10.1 miles per hour of annual wind speed. Most small wind turbines become financially viable over 10 miles per hour of mean annual wind speed; therefore, the ASW Truewind model indicates that installation of a wind turbine may be applicable at this location. The NBHA site may have the minimum average wind speed needed to install a land based wind turbine but due to the city environment there is no open area that would allow the use of a ground based system.

An aerial satellite depiction of the Lawler Apartments location and a wind resource map may be found in Appendix V.

This is not recommended due to the complexity of the installation and the liabilities of operation, a roof top vertical wind turbine may have ice buildup that may become a safety hazard to the buildings in the surrounding area. There is not available land to consider a land based system.

5.4 Combined Heat and Power Generation (CHP)

Combined heat and power also known as “cogeneration” is self-production of electricity on-site with beneficial recovery of the heat byproduct from the electrical generator. Common CHP equipment includes reciprocating engine-driven generators, micro-turbines, steam turbines, and fuel cells. Typical CHP customers include industrial, commercial, institutional, educational institutions and multifamily residential facilities. CHP systems that are commercially viable at the present time are sized approximately 50 kW and above, with numerous options in blocks grouped around 300 kW, 800 kW, 1,200 kW and larger. Typically CHP systems are used to produce a portion of the electricity needed by a facility some or all of the time, with the balance of electric needs satisfied by purchase from the grid.

Any proposed CHP project will need to consider many factors such as existing system load, use of thermal energy produced, system size, natural gas fuel availability, and proposed plant location. Lawler has the need for electrical generation but no easy way to use the thermal byproduct of the cogeneration. The heating system is low pressure steam so the heat cannot be easily used the way it could with a hot water heating system. Thermal usage during the summer months would require a different cooling system incorporating an absorption chiller and cooling tower to convert hot water to chilled water. Due to the fact that the building cooling is done by window air conditioners and split systems, it would not be practical to install this type of cooling system with the existing HVAC equipment; therefore, thermal energy produced by the CHP plant in the warmer months will be wasted.

This is not recommended due to not having a practical use for the thermal production in the summer and winter months.

5.5 Biomass Power Generation

Biomass power generation is a process in which waste organic materials are used to produce electricity or thermal energy that otherwise would be sent to the landfill or expelled to the atmosphere. To participate in NJCEP's Customer On-Site Renewable Energy (CORE) program, participants must install an on-site sustainable biomass or fuel cell energy generation system. Incentives for bio-power installations are available to support up to 1MW-DC of rated capacity.

*Class I organic residues are eligible for funding through the NJCEP CORE program. Class I wastes include- uses a renewable supply of organic material:

- Wood wastes not adulterated with chemicals, glues or adhesives,
- Agricultural residues (corn stover, rice hulls or nut shells, manures, poultry litter, horse manure, etc) and/or methane gases from landfills,
- Food wastes
- Municipal tree trimming and grass clipping wastes
- Paper and cardboard wastes
- Non adulterated construction wood wastes, pallets
- NJDEP evaluates biomass resources not identified in the RPS

*From NJOCE website

Examples of eligible facilities for a CORE incentive include:

- Digestion of sewage sludge
- Landfill gas facilities
- Combustion of wood wastes to steam turbine
- Gasification of wood wastes to reciprocating engine
- Gasification or pyrolysis of bio-solid wastes to generation equipment

This is not recommended due to the building not having a waste stream or an external source that can be utilized for the production of electricity or thermal energy. The proximity of such a system in the surrounding neighborhood of North Bergen would create issues with environmental airborne discharge limits.

5.6 Demand Response Curtailment

Presently, NBHA has electricity delivered and supplied by PSE&G. Utility curtailment is an agreement with the regional transmission organization and an approved Curtailment Service Providers (CSP) to shed electrical load by either turning major equipment off or energizing all or part of a facility utilizing an emergency generator, therefore reducing the electrical demand on the utility grid. This program is to benefit the utility company during high demand periods and PSE&G offers incentives to the CSP to participate in this program. Enrolling in the program will require program participants to drop electrical load or turn on their emergency generators during high electrical demand conditions or during emergencies. Part of the program also will require that program participants reduce their required load or run their emergency generators with notice to test the system. A minimum of 100 kW of curtailable load is required to enter the program. Discussions with the EnerNoc Corporation, an approved CSP, indicate that existing emergency generators will not pass the emissions requirements to enter the program.

Presently, Lawler Apartments has back up generation and an average kW demand during the observed period of 280.8 kW/month. Lawler has a 230 kW Cummins emergency generator that runs on diesel fuel. The bulk of the electricity usage is controlled by the tenants and will not be able to be curtailed by NBHA staff; therefore, there is no ability to drop electrical load.

This is not recommended because the emergency generator cannot meet air emissions standards in the State of New Jersey and the building load cannot be curtailed for Demand Response Curtailment.

6.0 EPA PORTFOLIO MANAGER

The United State Energy Protection Agency (EPA) is a federal agency in charge of regulating environment waste and policy in the United States. The EPA has released a building energy program called the EPA Portfolio Manager for public use. This program is designed to allow property owners and managers to share, compare and improve upon their facility's energy consumption. Inputting such parameters at electricity, heating fuel, building characteristics and location into the website-based program generates a naturalized energy rating score out of 100. Once an account is registered, monthly utility data can be entered to track the savings progress and retrieve an updated energy rating score on a monthly basis.

Due to the facility having more than 10% of the total floor space allocated to "other" per the EPA Portfolio Manger benchmarking tool, the NBHA Lawler Towers Apartments is unable to acquire an Energy Rating. The "other" allocation is indicative of the Portfolio Manager not having a floor characteristic for a senior housing facility. An alternative method that can be utilized to compare the facility to similar buildings is the Source Energy Intensity designation, which measures energy per square foot per year. Lawler's Current Source Energy Intensity is 193.1 kBTU/ft²/year.

A full EPA Energy Star Portfolio Manager Report is located in Appendix W.

7.0 CONCLUSIONS & RECOMMENDATIONS

The energy audit conducted by CHA at the Lawler Towers complex of the New Jersey Housing Authority in North Bergen, New Jersey identified potential ECMs for lighting replacements, light bulb exchange, faucet aerators, low flow showerheads, exhaust fan control, boiler replacement, door seal upgrades, insulation upgrades, air conditioner changeout, night setback, and Energy Star appliances. Potential annual savings of \$181,100 may be realized for the recommended ECMs, with a summary of the costs, savings, and paybacks as follows:

ECM – 1c Lighting Replacements with Occupancy Sensors

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|---------|--------|--------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 147,400 | 25 | 195,100 | 0 | 27,800 | 0.9 | 13,600 | 5.3 | 4.5 |

* Incentive is based on the New Jersey Smart Start Prescriptive Lighting Measures.

ECM – 2 Light Bulb Exchange

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|--------|---------|--------|------|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | #2 Oil | Total | | | | |
| \$ | kW | kWh | gallons | \$ | | \$ | Years | Years |
| 6,000 | 48.1 | 24,054 | 0 | 11,600 | 8.68 | NA | 0.5 | NA |

* No incentive available.

ECM -3c Install Low Flow Showerheads

| Budgetary Cost | Annual Utility Savings | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Water / Sewer | Total | | | | |
| \$ | Kgal | \$ | | \$ | Years | Years |
| 17,300 | 850 | 7,600 | 5.6 | NA | 2.3 | NA |

* No incentive available.

ECM – 4 Thermostats and Control Valves for Steam Radiators

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-----|----------|--------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 114,700 | 0 | 0 | 10,400 | 11,500 | 0.5 | 18,700 | 10 | 8.4 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

ECM – 5 Install Door Seals

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-----|----------|-------|-------|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 1,700 | 0 | 0 | 210 | 200 | (0.4) | 400 | 7.2 | 5.6 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

ECM – 6 Insulate Steam and Condensate Piping

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-----|----------|--------|------|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 17,300 | 0 | 0 | 20,700 | 23,000 | 25.6 | 11,800 | 0.8 | 0.3 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program

ECM – 7 Air Conditioner Changeout

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|--------|----------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| NA | 0.0 | 16,900 | 0 | 2,500 | NA | NA | NA | NA |

* No incentive available.

ECM- 8 Night Setback for Offices and Community Room

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|--------|----------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 1,100 | 0.0 | 20,000 | 0 | 3,000 | 40 | 400 | 0.4 | 0.1 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

ECM- 9 Boiler Replacement

| Budgetary Cost | Annual Utility Savings | | | | ROI | New Jersey Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-----|----------|--------|-----|-----------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 335,900 | 0 | 0 | 35,100 | 39,000 | 1.3 | 63,300 | 8.6 | 7.0 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

ECM-11a Insulate the NBHA Office Walls

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|--------|----------|-------|------|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 8,300 | 0.0 | 41,100 | 0 | 6,200 | 21.4 | 4,200 | 1.3 | 0.7 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

ECM-11b Insulate Area Below the NBHA Offices and Community

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|--------|----------|-------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 26,900 | 0.0 | 47,150 | 0 | 7,100 | 6.9 | 8,500 | 3.8 | 2.6 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

ECM-12a Install On/Off Controls for Apartment Exhaust Fans

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-------|----------|--------|------|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 11,800 | 0.0 | 6,537 | 14,200 | 16,700 | 20.2 | 5,900 | 0.7 | 0.4 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

ECM-12b Install On/Off Controls for Common Area Exhaust Fans

| Budgetary Cost | Annual Utility Savings | | | | ROI | New Jersey Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-------|----------|-------|-----|-----------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 7,600 | 0.0 | 2,179 | 1,575 | 2,100 | 3.1 | 3,200 | 3.6 | 2.1 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

ECM – 13 Energy Star Appliances

| Budgetary Cost | Annual Utility Savings | | | | ROI | New Jersey Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|---------|----------|--------|-----|-----------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Nat. Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 177,200 | 0.0 | 106,600 | | 16,000 | 0.4 | 19,200 | 11.1 | 9.9 |

* Incentive based on New Jersey Office of Clean Energy Pay for Performance Program.

APPENDIX A

Utility Usage Analysis

New Jersey BPU Energy Audit Program
CHA #20241
North Bergen Housing Authority
Lawler Towers

Account Number: 2100695134
PSE&G - Electric Service

Meter #: 778003748

| Date | Consumption (kWh) | Demand (kW) | Charges | | Unit Costs | | |
|----------------|----------------------|----------------|---------------|----------------|---------------------|--------------------------|-------------------|
| | | | Total (\$) | Demand (\$) | Consumption (\$) | Blended Rate (\$/kWh) | Demand (\$/kW) |
| 7/3/2008 | 161,676 | 398.3 | \$27,505.83 | \$6,794.13 | \$20,711.70 | 0.1701 | 17.06 |
| 8/4/2008 | 198,280 | 380.2 | \$32,288.12 | \$6,596.85 | \$25,691.27 | 0.1628 | 17.35 |
| 9/3/2008 | 158,087 | 320.5 | \$27,573.79 | \$5,946.19 | \$21,627.60 | 0.1744 | 18.55 |
| 10/2/2008 | 132,462 | 333.5 | \$20,541.90 | \$3,529.97 | \$17,011.93 | 0.1551 | 10.58 |
| 10/31/2008 | 119,970 | 253.2 | \$16,682.92 | \$3,287.33 | \$13,395.59 | 0.1391 | 12.98 |
| 12/3/2008 | 147,737 | 283.4 | \$19,255.47 | \$3,384.74 | \$15,870.73 | 0.1303 | 11.94 |
| 12/30/2008 | 115,143 | 243.7 | \$15,670.42 | \$3,256.69 | \$12,413.73 | 0.1361 | 13.36 |
| 1/27/2009 | 119,739 | 236.7 | \$16,646.34 | \$3,277.77 | \$13,368.57 | 0.1390 | 13.85 |
| 2/23/2009 | 109,558 | 235.0 | \$16,214.98 | \$3,273.91 | \$12,941.07 | 0.1480 | 13.93 |
| 3/30/2009 | 140,558 | 214.3 | \$19,264.34 | \$3,207.14 | \$16,057.20 | 0.1371 | 14.97 |
| 4/29/2009 | 123,854 | 258.3 | \$17,433.00 | \$3,349.06 | \$14,083.94 | 0.1408 | 12.97 |
| 6/1/2009 | 123,694 | 212.5 | \$18,752.60 | \$4,858.09 | \$13,894.51 | 0.1516 | 22.86 |
| Most Recent Yr | 1,650,758 | 398.3 | \$247,829.71 | \$50,761.87 | \$197,067.84 | 0.1501 | 15.03 |
| | | | | | | 0.1194 | |

New Jersey BPU Energy Audit Program
CHA #20241
North Bergen Housing Authority
Lawler Towers

Account Number: 2100695134
PSE&G - Natural Gas Service

Meter #: 2415033

Meter #: 2600157

| Date | Therms | Cost | (\$/Therm) | Therms | Cost | (\$/Therm) |
|----------------|--------|-------------|------------|---------|--------------|------------|
| 7/3/2008 | 1,813 | \$3,025.86 | 1.669 | 0 | \$91.89 | - |
| 8/4/2008 | 1,674 | \$2,912.63 | 1.740 | 0 | \$91.89 | - |
| 9/3/2008 | 1,646 | \$2,218.57 | 1.348 | 0 | \$91.89 | - |
| 10/2/2008 | 1,812 | \$2,283.42 | 1.260 | 0 | \$91.89 | - |
| 11/3/2008 | 2,414 | \$3,158.14 | 1.308 | 10,761 | \$15,834.83 | 1.471 |
| 12/3/2008 | 2,602 | \$3,181.99 | 1.223 | 22,647 | \$28,109.11 | 1.241 |
| 12/30/2008 | 2,705 | \$3,444.33 | 1.273 | 22,379 | \$28,867.97 | 1.290 |
| 1/27/2009 | 2,847 | \$3,392.90 | 1.192 | 25,071 | \$30,365.35 | 1.211 |
| 2/23/2009 | 2,965 | \$3,092.47 | 1.043 | 21,928 | \$23,593.63 | 1.076 |
| 3/30/2009 | 3,684 | \$2,932.24 | 0.796 | 26,570 | \$20,435.55 | 0.769 |
| 4/29/2009 | 2,869 | \$2,099.50 | 0.732 | 12,291 | \$8,617.46 | 0.701 |
| 6/1/2009 | 2,586 | \$1,812.46 | 0.701 | 0 | \$93.66 | - |
| Most Recent Yr | 29,617 | \$33,554.51 | 1.133 | 141,647 | \$156,285.12 | 1.103 |

Total (both meters)

| Date | Therms | Cost | (\$/Therm) |
|----------------|---------|--------------|------------|
| 7/3/2008 | 1,813 | \$3,117.75 | 1.720 |
| 8/4/2008 | 1,674 | \$3,004.52 | 1.795 |
| 9/3/2008 | 1,646 | \$2,310.46 | 1.404 |
| 10/2/2008 | 1,812 | \$2,375.31 | 1.311 |
| 11/3/2008 | 13,175 | \$18,992.97 | 1.442 |
| 12/3/2008 | 25,249 | \$31,291.10 | 1.239 |
| 12/30/2008 | 25,084 | \$32,312.30 | 1.288 |
| 1/27/2009 | 27,918 | \$33,758.25 | 1.209 |
| 2/23/2009 | 24,893 | \$26,686.10 | 1.072 |
| 3/30/2009 | 30,254 | \$23,367.79 | 0.772 |
| 4/29/2009 | 15,161 | \$10,716.96 | 0.707 |
| 6/1/2009 | 2,586 | \$1,906.12 | 0.737 |
| Most Recent Yr | 171,264 | \$189,839.63 | 1.108 |

New Jersey BPU Energy Audit Program
CHA #20241
North Bergen Housing Authority
Lawler Towers

Account #: 10000997823060
United Water - Domestic Water Service

| Date | Gallons | Cost | (\$/kgal) |
|------------|-----------|------------|-----------|
| 8/13/2008 | 933,504 | \$3,721.21 | 3.986 |
| 9/13/2008 | 1,132,472 | \$4,465.45 | 3.943 |
| 10/11/2008 | 902,836 | \$3,606.50 | 3.995 |
| 11/10/2008 | 917,048 | \$3,659.60 | 3.991 |
| 12/8/2008 | 921,536 | \$3,676.44 | 3.989 |
| 1/12/2009 | 1,151,172 | \$4,535.40 | 3.940 |
| 2/11/2009 | 1,047,200 | \$4,146.49 | 3.960 |
| 3/13/2009 | 1,024,760 | \$4,062.55 | 3.964 |
| 4/16/2009 | 1,173,612 | \$4,952.99 | 4.220 |
| 5/12/2009 | 884,884 | \$4,160.21 | 4.701 |
| 6/11/2009 | 981,376 | \$4,584.45 | 4.671 |
| 7/17/2009 | 1,225,224 | \$5,656.57 | 4.617 |

| | | | |
|----------------|------------|-------------|-------|
| Most Recent Yr | 12,295,624 | \$51,227.86 | 4.166 |
|----------------|------------|-------------|-------|

United Water - Sewage Service

| Date | Gallons | Cost | (\$/Gal) |
|------------|-----------|-------------|----------|
| 9/30/2008 | 3,130,380 | \$16,403.19 | 5.240 |
| 12/31/2008 | 3,218,644 | \$16,865.69 | 5.240 |
| 3/31/2009 | 2,741,420 | \$15,086.50 | 5.503 |
| 6/30/2009 | 3,223,132 | \$17,727.15 | 5.500 |

| | | | |
|----------------|------------|-------------|-------|
| Most Recent Yr | 12,313,576 | \$66,082.53 | 5.367 |
|----------------|------------|-------------|-------|

ELECTRIC MARKETERS LIST

The following is a listing of marketers/suppliers/brokers that have been licensed by the NJ Board of Public Utilities to sell electricity to residential, small commercial and industrial customers served by the Public Service Electric and Gas Company distribution system. **This listing is provided for informational purposes only and PSE&G makes no representations or warranties as to the competencies of the entities listed herein or to the completeness of this listing.**

American Powernet Management
867 Berkshire Blvd, Suite 101
Wyomissing, PA 19610
www.americanpowernet.com

Gerdau Ameristeel Energy Co.
North Crossman Road
Sayreville, NJ 08872

PPL EnergyPlus, LLC
Energy Marketing Center
Two North Ninth Street
Allentown, PA 18101
1-866-505-8825
<http://www.pplenrgyplus.com/>

BOC Energy Services
575 Mountain Avenue
Murray Hill, NJ 07974
www.boc-gases.com

Gexa Energy LLC New Jersey
20 Greenway Plaza, Suite 600
Houston, TX 77046
(866) 304-GEXA
Beth.miller@gexaenergy.com

Sempra Energy Solutions
The Mac-Cali Building
581 Main Street, 8th Floor
Woodbridge, NJ 07095
(877) 273-6772
www.SempraSolutions.com

Commerce Energy Inc.
535 Route 38, Suite 138
Cherry Hill, NJ 08002
(888) 817-8572 or
(858) 910-8099
www.commerceenergy.com

Glacial Energy of New Jersey
2602 McKinney Avenue, Suite 220
Dallas, TX 75204
www.glacialenergy.com

South Jersey Energy Company
1 South Jersey Plaza, Route 54
Folsom, NJ 08037
(800) 756-3749
www.sjindustries.com

ConEdison Solutions
701 Westchester Avenue
Suite 201 West
White Plains, NY 10604
(800) 316-8011
www.ConEdSolutions.com

Hess Corporation
1 Hess Plaza
Woodbridge, NJ 07095
www.hess.com

Strategic Energy, LLC
6 East Main Street, Suite 6E
Ramsey, NJ 07446
(888) 925-9115
www.sel.com

Constellation NewEnergy, Inc.
1199 Route 22 East
Mountainside, NJ 07092
908 228-5100
www.newenergy.com

Integrus Energy Services, Inc
99 Wood Avenue, Suite 802
Iselin, NJ 08830
www.integrusenergy.com

Suez Energy Resources NA
333 Thornall Street FL6
Edison, NJ 08818
866.999.8374(toll free)
www.suezenergyresources.com

Credit Suisse (USA), Inc.
700 College Road East
Princeton, NJ 08450
www.creditsuisse.com

Liberty Power Delaware, LLC
1901 W Cypress Road, Suite 600
Fort Lauderdale, FL 33309
(866) Power-99
(866) 769-3799
www.libertypowercorp.com

UGI Energy Services, Inc.
d/b/a POWERMARK
1 Meridian Blvd. Suite 2C01
Wyomissing, PA 19610
(800) 427-8545
www.ugienergyservices.com

Direct Energy Services, LLC
One Gateway Center, Suite 2600
Newark, NJ 07102
(973) 799-8568
www.directenergy.com

Liberty Power Holdings, LLC
1901 W Cypress Creek Road, Suite 600
Fort Lauderdale, FL 33309
(866) Power-99
(866) 769-3799
www.libertypowercorp.com

FirstEnergy Solutions
395 Ghent Road Suite 407
Akron, OH 44333
(800) 977-0500
www.fes.com

Pepco Energy Services, Inc.
d/b/a Power Choice
23 S. Kinderkamack Rd Ste D
Montvale, NJ 07645
(800) 363-7499
www.pepco-services.com

GAS MARKETERS LIST

The following is a listing of marketers/suppliers/brokers that have been licensed by the NJ Board of Public Utilities to sell natural gas to residential, small commercial and industrial customers served by the Public Service Electric and Gas Company distribution system. **This listing is provided for informational purposes only and PSE&G makes no representations or warranties as to the competencies of the entities listed herein or to the completeness of this listing.**

Gateway Energy Services
44 Whispering Pines Lane
Lakewood, NJ 08701
(800) 805-8586
www.gesc.com

Metro Energy Group, LLC
14 Washington Place
Hackensack, NJ 07601
www.metroenergy.com

RPL Holdings, Inc
601 Carlson Pkwy
Minnetonka, MN 55305

Great Eastern Energy
3044 Coney Island Ave. PH
Brooklyn, NY 11235
888-651-4121
www.greasterngas.com

Metromedia Energy, Inc.
6 Industrial Way
Eatontown, NJ 07724
(800) 828-9427
www.metromediaenergy.com

South Jersey Energy Company
One South Jersey Plaza, Rte 54
Folsom, NJ 08037
(800) 756-3749
www.sjindustries.com/sje.htm

Hess Corporation
1 Hess Plaza
Woodbridge, NJ 07095
(800) 437-7872
www.hess.com

Mitchell- Supreme Fuel
(NATGASCO)
532 Freeman Street
Orange, NJ 07050
(800) 840-4GAS
www.mitchellsupreme.com

Sprague Energy Corp.
Two International Drive, Ste 200
Portsmouth, NH 03801
800-225-1560
www.spragueenergy.com

Hudson Energy Services, LLC
545 Route 17 South
Ridgewood, NJ 07450
(201) 251-2400
www.hudsonenergyservices.com

MxEnergy Inc.
P.O. Box 177
Annapolis Junction, MD 20701
800-375-1277
www.mxenergy.com

Stuyvesant Energy LLC
642 Southern Boulevard
Bronx, NY 10455
(718) 665-5700
www.stuyfuel.com

Intelligent Energy
7001 SW 24th Avenue
Gainesville, FL 32607
Sales: 1 877 I've Got Gas
(1 877 483-4684)
Customer Service:
1 800 927-9794
www.intelligentenergy.org

Pepco Energy Services, Inc.
23 S Kinderkamack Rd, Suite D
Montvale, NJ 07645
(800) 363-7499
www.pepco-services.com

Tiger Natural Gas, Inc.
1422 E. 71st Street, Suite J.
Tulsa, OK 74136
1-888-875-6122
www.tignaturalgas.com

Systrum Energy
877-SYSTRUM
(877-797-8786)
www.systrumenergy.com

Plymouth Rock Energy, LLC
165 Remsen Street
Brooklyn, NJ 11201
866-539-6450
www.plymouthrockenergy.com

UGI Energy Services, Inc.
d/b/a GASMARK
704 E. Main Street, Suite I
Moorestown, NJ 08057
856-273-9995
www.ugienergyservices.com

Macquarie Cook Energy, LLC
10100 Santa Monica Blvd, 18th
Fl
Los Angeles, CA 90067

PPL EnergyPlus, LLC
Energy Marketing Center
Two North Ninth Street
Allentown, PA 18101
1-866-505-8825
www.pplenergyplus.com/natural+gas/

Woodruff Energy
73 Water Street
P.O. Box 777
Bridgeton, NJ 08302
(856) 455-1111
www.woodruffenergy.com

NORMALIZED MODEL TO BILLING COMPARISON

Project name: NBHA Lawlwer Apts

For : NBHA

By :

Date: 8/17/2009

Billing Period Name: BillingPeriod1

Model Package Name: Base Building

Natural gas

| | Model | | Billing Data | |
|-----------------|----------------------|------------|----------------------|------------|
| | Consumption Therm | Cost \$ | Consumption Therm | Cost \$ |
| January | 37184.50 | 41287 | 35687.99 | 39626 |
| February | 28842.35 | 32027 | 28619.43 | 31780 |
| March | 24228.44 | 26906 | 24732.90 | 27466 |
| April | 15479.22 | 17194 | 16708.97 | 18559 |
| May | 6731.72 | 7484 | 6987.92 | 7769 |
| June | 1978.83 | 2209 | 1931.00 | 2155 |
| July | 2044.80 | 2282 | 1995.37 | 2227 |
| August | 2044.80 | 2282 | 1995.37 | 2227 |
| September | 3783.89 | 4212 | 3471.56 | 3865 |
| October | 10952.99 | 12170 | 11295.79 | 12550 |
| November | 20430.60 | 22690 | 19875.67 | 22074 |
| December | 29923.53 | 33227 | 28698.41 | 31867 |
| Total | 183625.67 | 203968 | 182000.37 | 202164 |
| Daily Base Load | 65.96 | 73 | 64.37 | 71 |

Electricity

| | Model | | Billing Data | |
|---------|--------------------|------------|--------------------|------------|
| | Consumption kWh | Cost \$ | Consumption kWh | Cost \$ |
| January | 126095.88 | 18924 | 131624.19 | 19754 |

| | | | | |
|-----------------|------------|--------|------------|--------|
| February | 113893.05 | 17094 | 118886.37 | 17843 |
| March | 126095.88 | 18924 | 131624.19 | 19754 |
| April | 122028.27 | 18314 | 127378.25 | 19117 |
| May | 126095.88 | 18924 | 131624.19 | 19754 |
| June | 145569.05 | 21845 | 140932.60 | 21150 |
| July | 150421.35 | 22573 | 155966.69 | 23405 |
| August | 150421.35 | 22573 | 149051.21 | 22368 |
| September | 122028.27 | 18314 | 127378.25 | 19117 |
| October | 126095.88 | 18924 | 131624.19 | 19754 |
| November | 122028.27 | 18314 | 127378.25 | 19117 |
| December | 126095.88 | 18924 | 131624.19 | 19754 |
| Total | 1556869.00 | 233650 | 1605092.57 | 240884 |
| Daily Base Load | 4067.61 | 610 | 4245.94 | 637 |

Notes:

1. The report compares model energy consumption with the consumption calculated using the billing analysis slope and reference temperature. The usage is for normalized thirty year average weather conditions.

2. Monthly fuel cost includes heating, cooling and base load usage and monthly flat meter fee entered on Fuels/Rates screen.

HEATING ENERGY SCORECARD


Project name: NBHA Lawlwer Apts

For : NBHA

By :

Date: 8/17/2009

Billing Period Name: BillingPeriod1



Heating Slope: 15.31

Reference temperature: 67

Note: Annual energy usage of your building shown on the chart is calculated by multiplying the building slope by the ratio of heating degree days for the actual reference temperature to heating degree days base 65F. The building gets credit for low reference temperature.

ACTUAL BILLING TO MODEL COMPARISON REPORT

Project name: NBHA Lawlwer Apts


For : NBHA



By :


Date: 8/17/2009

Billing Period Name: BillingPeriod1

Model Package Name: Base Building







Notes:

1. Only bills that are completely within the analysis period are included in the report.
2. Bills for the "Whole building" metered space are included in the report.
3. If there are multiple metered spaces for the fuel, then only the usage for the dates for which utility bills are available for ALL metered spaces is included in the report. The start date and elapsed days of all such bills must be exactly the same. The restriction allows TREAT to calculate the total building energy consumption for the time period.
4. The billing bar is color-coded as Not Included if utility bill for at least one individually metered space for the time period was entered as not to be included in the Billing Analysis (Include the Bill in Analysis field was set to No on the Utility Bills screen for this bill).
5. The billing bar is color-coded as Estimated if there is at least one estimated utility bill for at least one individually metered space for the time period (Bill Type field is set to Estimated on the Utility Bills screen for this bill) and all the bills for the time period are included in the billing analysis.
6. The billing bar is color-coded as Actual if utility bill for all individually metered spaces for the time period are actual.
7. Model data is only shown if the billing period is compared to the model with valid calculation results.
8. Model heating and cooling usage is calculated using model heating/cooling slope and reference temperature and weather data available in Daily Weather Data library for the period covered by utility bill.

Base Load Report

Customer Information

Customer Name: NBHA

Address: 6121/3131 Grand Avenue
North Bergen, NJ 07047

Billing Period: 5/2008 - 4/2009

Auditor Information

Technician Name:

Company:

Phone Number:

Date: 8/17/2009

Model to Actual Comparison of Base Usage Per Year

Model Name: Base Building

Billing Period Name: BillingPeriod1

| | Electricity | | Natural gas | | | |
|--------------|-------------|---------|-------------|--------|--|--|
| | kWh | \$ | Therm | \$ | | |
| Model | 1,484,677 | 222,702 | 24,076 | 26,724 | | |
| Billing | 1,549,769 | 226,409 | 23,494 | 31,740 | | |
| % Difference | 4 | 2 | -2 | 16 | | |

Note: Actual billing data is adjusted to reflect a full year's usage.


Annual Use of Domestic Hot Water, Appliances, and Lighting

Model Name: Base Building

| | Electricity \$0.15 per kWh | | Natural gas \$1.11 per Therm | | | | Total |
|--|-------------------------------|----------------|---------------------------------|---------------|--|--|----------------|
| | kWh | \$ | therms | \$ | | | \$ |
| 1. Domestic Hot Water | 0 | 0 | 23,161 | 25,709 | | | 25,709 |
| 2. Heating Community Rm & Offices | 130,680 | 19,602 | 0 | 0 | | | 19,602 |
| 3. Range, electric | 120,400 | 18,060 | 0 | 0 | | | 18,060 |
| 4. Oven, electric | 120,400 | 18,060 | 0 | 0 | | | 18,060 |
| 5. typical Other Heated Area lighting | 118,610 | 17,792 | 0 | 0 | | | 17,792 |
| 6. typical Other Heated Area lighting | 117,822 | 17,673 | 0 | 0 | | | 17,673 |
| 7. Refrigerator-auto def top freezer, 1990 | 88,400 | 13,260 | 0 | 0 | | | 13,260 |
| 8. Refrigerator-auto def top freezer, 1990 | 88,400 | 13,260 | 0 | 0 | | | 13,260 |
| 9. Cooling Community Rm & B-Offices | 57,408 | 8,611 | 0 | 0 | | | 8,611 |
| 10. Other | 609,883 | 91,482 | 915 | 1,016 | | | 92,498 |
| TOTAL | 1,452,003 | 217,800 | 24,076 | 26,725 | | | 244,525 |

Base Load Energy Users, \$/year

Model Name: Base Building





MODEL ENERGY REPORT FOR BASE BUILDING

NBHA Lawlwer Apts

For: NBHA

By:

Date: 8/17/2009



Note: Due to rounding, the sum of percentages may not be equal to 100.

DESIGN HEATING AND COOLING LOADS FOR BASE BUILDING

8/17/2009

Project Name: NBHA Lawlwer Apts

For: NBHA

By:

Date:

Primary Heating System:

| Space Name | Load, Btu/Hr | Load, per SF Btu/(Hr-SqFt) | Distribution | |
|-------------------------|--------------|-------------------------------|--------------|--------------------|
| | | | GPM | Ft of baseboard |
| Gr Fl Common Tower A | 166444 | 27 | 18.9 | 319 |
| 2nd Fl Apts Tower B | 102364 | 19 | 11.6 | 196 |
| 3rd Fl Apts Tower B | 105945 | 20 | 12.0 | 203 |
| 2nd Fl Common Tower B | 0 | 0 | 0.0 | 0 |
| Community Room | 205047 | 65 | 23.3 | 393 |
| Mechanical Spaces T-A | 396754 | 64 | 45.1 | 760 |
| 1st Fl Common Tower A | 31227 | 13 | 3.5 | 60 |
| 1st- Apts Tower A | 93445 | 26 | 10.6 | 179 |
| Gr Fl Office B Tower | 403732 | 52 | 45.9 | 773 |
| Basement Tower B | 19203 | 25 | 2.2 | 37 |
| 1st Fl Common Tower B | 0 | 0 | 0.0 | 0 |
| 1st Fl Apts Tower B | 88223 | 24 | 10.0 | 169 |
| 3rd Fl Common | 0 | 0 | 0.0 | 0 |
| 4th-13th Apts Tower B | 1280775 | 27 | 145.6 | 2451 |
| 4th-13th Common Tower B | 0 | 0 | 0.0 | 0 |
| 2nd Fl Apts Tower A | 116662 | 22 | 13.3 | 224 |
| 2nd Fl Common Tower A | 0 | 0 | 0.0 | 0 |
| 3rd Fl Apts Tower A | 119730 | 23 | 13.6 | 230 |
| 3rd Fl Common Tower A | 0 | 0 | 0.0 | 0 |
| 4th-13th Apts Tower A | 1442561 | 30 | 164.0 | 2760 |
| 4th-13th Common Tower A | 0 | 0 | 0.0 | 0 |

Required Heating Equipment Output Capacity: 5424734 Btu/hr

Available Heating Equipment Output Capacity: 6327100 Btu/hr

Total flow: 542.6 GPM

Baseboard Capacity: 575 Btu/Hr-Ft

Heating Equipment Efficiency: 65 %

Calculated Distribution Efficiency: 93 %

Supply Water Temperature: 220 F

Temperature Drop: 20 F

Heating Safety Factor: 1.10

Distribution Safety Factor: 1.10

Cooling System:

| Space Name | Load, Btu/Hr | Distribution CFM |
|-------------------------|--------------|---------------------|
| Gr Fl Common Tower A | 110762 | 4030 |
| 2nd Fl Apts Tower B | 70500 | 2565 |
| 3rd Fl Apts Tower B | 66013 | 2402 |
| 2nd Fl Common Tower B | 0 | 0 |
| Community Room | 87420 | 3180 |
| Mechanical Spaces T-A | 0 | 0 |
| 1st Fl Common Tower A | 64367 | 2342 |
| 1st- Apts Tower A | 57465 | 2091 |
| Gr Fl Office B Tower | 219345 | 7979 |
| Basement Tower B | 6271 | 229 |
| 1st Fl Common Tower B | 130099 | 4733 |
| 1st Fl Apts Tower B | 57589 | 2095 |
| 3rd Fl Common | 0 | 0 |
| 4th-13th Apts Tower B | 822976 | 29937 |
| 4th-13th Common Tower B | 0 | 0 |
| 2nd Fl Apts Tower A | 51676 | 1880 |
| 2nd Fl Common Tower A | 0 | 0 |
| 3rd Fl Apts Tower A | 67962 | 2473 |
| 3rd Fl Common Tower A | 0 | 0 |
| 4th-13th Apts Tower A | 661186 | 24052 |
| 4th-13th Common Tower A | 0 | 0 |

Required Cooling Equipment Output Capacity: 2672598 Btu/hr

Available Cooling Equipment Output Capacity: 290000 Btu/hr

Total flow: 88380 CFM

Cooling Equipment Efficiency: 9 SEER

Calculated Distribution Efficiency: 95%

Temperature Drop: 28 F

Cooling Safety Factor: 1.10

Distribution Safety Factor: 1.10

COOLING SYSTEM IS UNDERSIZED AND DOES NOT MEET THE REQUIRED COOLING LOAD.

Notes:

1. The room heating/cooling loads do not include the equipment and distribution safety factor and distribution losses
2. The room distribution includes distribution safety factor.
3. The load on the room is the peak load for this room in a year.
4. Available equipment output capacity includes equipment efficiency.
5. Required equipment output capacity includes diversity, distribution losses and equipment safety factor.
6. Overall distribution CFM/GPM for heating/cooling includes equipment safety factor, distribution losses and diversity.

APPENDIX B

ECM-1a Lighting Replacements

Cost of Electricity: \$0.119 \$/kWh
\$15.03 \$/kW

| EXISTING CONDITIONS | | | | | | | | | | RETROFIT CONDITIONS | | | | | | | | | | COST & SAVINGS ANALYSIS | | | | |
|---------------------|--|---|---|---------------------------------|------------------------|------------------------------------|---|----------------------------|--|---|---|---------------------------------|------------------------|------------------------------------|---|----------------------------|--|---------------------------------|---|-------------------------|-----|--|--|--|
| Field Code | Area Description (Unique description of the location, Room number, room name, floor, room number (if applicable)) | No. of Fixtures (Number of fixtures in room) | Standard Fixture Code (NYSEDA Standard Fixture Code) | Watts per Fixture (Watt/ft²) | kW/Space (Watt/ft²) | Exst. Control (Type of control) | Annual Hours (Estimated annual hours of use) | Annual kWh (Annual kWh) | Number of Fixtures (Number of fixtures in room) | Standard Fixture Code (NYSEDA Standard Fixture Code) | Fixture Code (Code from table of fixtures) | Watts per Fixture (Watt/ft²) | kW/Space (Watt/ft²) | Exst. Control (Type of control) | Annual Hours (Estimated annual hours of use) | Annual kWh (Annual kWh) | Annual kWh Saved (Original Annual kWh - Retrofitted Annual kWh) | Annual kWh Saved (% Savings) | Simple Payback (Length of time for investment to be recovered) | | | | | |
| Tower A | 19 Lobby/Entry | 19 | 30 34 R F 2 (MAG) | F42EE | 72 | 1.4 | Breaker | 8,100 | 11,584 | 19 | 27 17 R F 2 (ELE) | F2ELL | 33 | 0.6 | Breaker | 8,100 | 5,462 | 6,401 | 3 | 2.1 | | | | |
| | 20 Lobby/Entry | 20 | 30 34 R F 2 (MAG) | F42EE | 72 | 1.4 | Breaker | 8,100 | 11,584 | 20 | 27 17 R F 2 (ELE) | F2ELL | 33 | 0.6 | Breaker | 8,100 | 5,462 | 6,401 | 3 | 2.1 | | | | |
| | 21 Vestibule | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 3,240 | 0 | 4.8 | | | | |
| | 22 Vestibule | 7 | 13 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 5,670 | 7 | 13 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 5,670 | 5,670 | 0 | 4.8 | | | | |
| | 23 Vestibule | 7 | 13 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 5,670 | 7 | 13 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 5,670 | 5,670 | 0 | 4.8 | | | | |
| | 24 Vestibule | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 3,240 | 0 | 4.8 | | | | |
| | 25 Vestibule | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 3,240 | 0 | 4.8 | | | | |
| | 26 Vestibule | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 3,240 | 0 | 4.8 | | | | |
| | 27 Vestibule | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 3,240 | 0 | 4.8 | | | | |
| | 28 Vestibule | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 3,240 | 0 | 4.8 | | | | |
| | 29 Vestibule | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 3,240 | 0 | 4.8 | | | | |
| | 30 Vestibule | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 3,240 | 0 | 4.8 | | | | |
| | 31 Vestibule | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 3,240 | 0 | 4.8 | | | | |
| | 32 Vestibule | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 3,240 | 0 | 4.8 | | | | |
| | 33 Vestibule | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 3,240 | 0 | 4.8 | | | | |
| | 34 Vestibule | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 3,240 | 0 | 4.8 | | | | |
| | Tower B | 19 Lobby/Entry | 19 | 30 34 R F 2 (MAG) | F42EE | 72 | 1.4 | Breaker | 8,100 | 11,584 | 19 | 27 17 R F 2 (ELE) | F2ELL | 33 | 0.6 | Breaker | 8,100 | 5,462 | 6,401 | 3 | 2.1 | | | |
| 20 Lobby/Entry | | 20 | 30 34 R F 2 (MAG) | F42EE | 72 | 1.4 | Breaker | 8,100 | 11,584 | 20 | 27 17 R F 2 (ELE) | F2ELL | 33 | 0.6 | Breaker | 8,100 | 5,462 | 6,401 | 3 | 2.1 | | | | |
| 21 Vestibule | | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 3,240 | 0 | 4.8 | | | | |
| 22 Vestibule | | 7 | 13 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 5,670 | 7 | 13 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 5,670 | 5,670 | 0 | 4.8 | | | | |
| 23 Vestibule | | 7 | 13 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 5,670 | 7 | 13 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 5,670 | 5,670 | 0 | 4.8 | | | | |
| 24 Vestibule | | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 3,240 | 0 | 4.8 | | | | |
| 25 Vestibule | | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 3,240 | 0 | 4.8 | | | | |
| 26 Vestibule | | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 3,240 | 0 | 4.8 | | | | |
| 27 Vestibule | | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 3,240 | 0 | 4.8 | | | | |
| 28 Vestibule | | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 3,240 | 0 | 4.8 | | | | |
| 29 Vestibule | | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 3,240 | 0 | 4.8 | | | | |
| 30 Vestibule | | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 3,240 | 0 | 4.8 | | | | |
| 31 Vestibule | | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 3,240 | 0 | 4.8 | | | | |
| 32 Vestibule | | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 3,240 | 0 | 4.8 | | | | |
| 33 Vestibule | | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 3,240 | 0 | 4.8 | | | | |
| 34 Vestibule | | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 4 | 17 W F 1 (ELE) | F2ELL | 54 | 0.1 | Breaker | 8,100 | 3,240 | 3,240 | 0 | 4.8 | | | | |

Energy Audit of North Bergen Housing Authority
CHA Project No. 20241 Lawler Towers
ECM 1 - Fixture and Control Replacement Cost Lighting Analysis

Hours of Operation

| Energy Audit of North Bergen Housing Auth | Hours/Day | Hours/Year | Proposed | Utilized |
|---|-----------|------------|----------|----------|
| Hallways | 24 | 8760 | 8760 | Y |
| Offices | 10 | 2600 | 1200 | Y |
| Community Room | 12 | 4368 | 2000 | Y |
| Outdoor Lighting | 12 | 4368 | 4368 | Y |
| Stairway | 24 | 8760 | 8760 | Y |
| Laundry | 12 | 4368 | 1500 | Y |
| Storage Areas | | 1000 | 250 | Y |
| Boiler Room | | 2000 | 2000 | Y |
| Bath Room | 8 | 2080 | 1000 | Y |
| Cafeteria/Kitchen/Service | 8 | 2912 | 1200 | Y |
| Apartments (HA lights) | 8 | 2912 | 2184 | Y |

Energy Audit of North Bergen Housing Authority
CHA Project No. 20241 Lawler Towers
ECM-1 - Fixture and Control Replacement Cost Lighting Analysis

COST TABLE

| Field Code | Standard Code | NYSEDA Code | Watts per fixture | Retrofit | Standard Code | NYSEDA Code | Watts per fixture | Lamps/Fix | Ball/Fix | Fixture Replacement | | | Ballast Replacement | | | Lamp Replacement | | | O.P. & D | NJ Incentive | Retrofit Cost (inc. O&P) |
|------------|--------------------------------------|-------------|-------------------|----------|------------------|-------------|-------------------|-----------|----------|---------------------|---------|----------|---------------------|---------|----------|------------------|---------|----------|----------|--------------|--------------------------|
| 2 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | RL/RB | W 28 W F 2 | F42SILL | 48 | 2 | 1 | Material | Labor | Disposal | Material | Labor | Disposal | Material | Labor | Disposal | \$21.25 | \$10.00 | \$106.25 |
| 3 | W 34 W F 1 (MAG) | F41EE | 43 | RL/RB | W 28 W F 1 | F41SILL | 26 | 1 | 1 | | | | \$20.00 | \$45.00 | INC | \$10.00 | \$10.00 | INC | \$29.75 | \$25.00 | \$114.75 |
| 4 | 2B 34 R F 2 (u) (MAG) | F42EE | 72 | Replace | T 17 R F 2 (ELE) | F22ILL | 33 | 2 | 1 | | | | \$20.00 | \$45.00 | INC | \$5.00 | \$5.00 | INC | \$26.25 | \$10.00 | \$101.25 |
| 5 | 2T 32 R F 2 (u) (ELE) | F42LL | 60 | NONE | | | | | | | | | | | | | | | | | |
| 6 | T 34 R F 4 (MAG) | F44EE | 144 | RL/RB | T 28 R F 4 | F44SILL | 96 | 4 | 1 | | | | \$20.00 | \$45.00 | INC | \$20.00 | \$20.00 | INC | \$26.25 | \$20.00 | \$131.25 |
| 11 | S 34 P F 2 (MAG) | F42EE | 72 | RL/RB | C 28 P F 2 | F42SILL | 48 | | | | | | \$20.00 | \$45.00 | INC | \$10.00 | \$10.00 | INC | \$21.25 | \$10.00 | \$106.25 |
| 15 | S 32 C F 2 (ELE) | F42LL | 60 | NONE | | | | | | | | | | | | | | | \$0.00 | | \$0.00 |
| 16 | T 32 R F 4 (ELE) | F41LL | 112 | NONE | | | | | | | | | | | | | | | \$0.00 | | \$0.00 |
| 20 | S 32 C F 1 (ELE) | F41LL | 32 | NONE | | | | | | | | | | | | | | | \$0.00 | | \$0.00 |
| 33 | 13 W CF 1 | CFQ131-L | 15 | NONE | | | | | | | | | | | | | | | \$0.00 | | \$0.00 |
| 39 | 2 T 17 W F 2 (ELE) | F22ILL | 33 | NONE | | | | | | | | | | | | | | | \$0.00 | | \$0.00 |
| 61 | T 34 R F 3 (MAG) | F43EE | 115 | RL/RB | T 28 R F 3 | F43SILL | 72 | 3 | 10 | | | | \$20.00 | \$45.00 | INC | \$15.00 | \$15.00 | INC | \$33.25 | \$20.00 | \$128.25 |
| 71 | I 60 | I60/1 | 60 | Replace | CF 26 | CFQ26/1-L | 27 | 1 | | | | | | | | | | | \$0.00 | | \$0.00 |
| 73 | I 120 | I120/1 | 120 | Replace | CF 26 | CFQ26/1-L | 27 | | | | | | | | | | | | \$0.00 | | \$0.00 |
| 93 | I 75 | I75/1 | 75 | Replace | CF 26 | CFQ26/1-L | 27 | 1 | | | | | | | | | | | \$0.00 | | \$0.00 |
| 106 | SP 65 I | I65/1 | 65 | Replace | CF 26 | CFQ26/1-L | 27 | | | | | | | | | | | | \$0.00 | | \$0.00 |
| 117 | CF 23 | CF523/1 | 23 | NONE | | | | | | | | | | | | | | | \$0.00 | | \$0.00 |
| 126 | DC 23 C CF 2 | CFQ22/2 | 48 | NONE | | | | | | | | | | | | | | | \$0.00 | | \$0.00 |
| 182 | W 25 C F 2 (ELE) 3' T8 | F32EE | 66 | NONE | | | | | | | | | | | | | | | \$0.00 | | \$0.00 |
| 189 | X 7.0 W 1 | ECF7/1 | 10 | Replace | X 1.5C LED | ELED1.5/1 | 1.5 | 1 | | \$50.00 | \$45.00 | INC | | | | | | | \$53.25 | \$10.00 | \$128.25 |
| 217 | W 32 C F 4 (ELE) | F44ILL/2 | 118 | NONE | | | | | | | | | | | | | | | \$0.00 | | \$0.00 |
| 222 | W 20 CF 1 (MAG) | F21SS | 28 | Replace | W 17 C F 1 (ELE) | F21LL | 16 | 1 | 1 | \$40.00 | \$10.00 | INC | | | | | | | \$17.50 | \$25.00 | \$67.50 |
| 225 | 70 High Pressure Sodium | HP570/1 | 95 | NONE | | | | | | | | | | | | | | | | | |
| 235 | R 75 C Q 1 | h75/1 | 75 | RL/RB | CF 26 | CFQ26/1-L | 27 | 1 | | | | | | | | | | | \$0.00 | | \$0.00 |
| 235 | mv 250 | mv250/1 | 290 | NONE | | | | | | | | | | | | | | | \$0.00 | | \$0.00 |
| 237 | WP 400 Po HPS | hps400/1 | 465 | NONE | | | | | | | | | | | | | | | \$0.00 | | \$0.00 |
| OCC | OCCUPANCY SENSOR SWITCH | | | | | | | | | | | | | | | | | | | | |
| C-OCC | OCC SENSOR W/ 20 FT. WIRE TO CEILING | | | | | | | | | | | | | | | | | | \$50 | \$45 | \$23.75 |
| | | | | | | | | | | | | | | | | | | | \$100 | \$50 | \$52.50 |

Rebuild Notes:

(1) 1" x 2" U-Tube to 17 w 2" lamps with Reflector Kit Vendor Code RK(2F 17)

| New Jersey Smart Start Prescriptive Lighting type | | | | Watt/Fix | Lamps | \$/Unit |
|--|--|--|--|----------|-------|-----------------|
| New Hard Wired Compact Fluorescents | | | | N/A | 1 | \$25 |
| New Hard Wired Compact Fluorescents | | | | N/A | 2 | \$30 |
| For retrofit of T-12 fixtures to T-5 or T-8 with electronic ballasts | | | | | | |
| Retrofit T-12 to T-5, T-8 with Electronic Ballasts | | | | N/A | 1 & 2 | \$10 |
| Retrofit T-12 to T-5, T-8 with Electronic Ballasts | | | | N/A | 3 & 4 | \$20 |
| For replacement of fixtures with new T-5 or T-8 fixtures | | | | | | |
| HID, T-12, Incandescent to T-8, T-5 with Electronic Ballasts | | | | >1000 | N/A | \$284 |
| HID, T-12, Incandescent to T-8, T-5 with Electronic Ballasts | | | | 400-999 | N/A | \$100 |
| HID, T-12, Incandescent to T-8, T-5 with Electronic Ballasts | | | | 250-399 | N/A | \$50 |
| HID Only to T-8, T-5 with Electronic Ballasts | | | | 175-249 | N/A | \$43 |
| HID Only to T-8, T-5 with Electronic Ballasts | | | | 100-174 | N/A | \$30 |
| HID Only to T-8, T-5 with Electronic Ballasts | | | | 75-99 | N/A | \$16 |
| HID Only to T-8, T-5 with Electronic Ballasts (1 & 2 lamp) | | | | <250 | 1 & 2 | \$25 |
| HID Only to T-8, T-5 with Electronic Ballasts (3 & 4 lamp) | | | | <250 | 3 & 4 | \$30 |
| For retrofit of T-8 fixtures by permanent delamping & new reflectors | | | | N/A | N/A | \$20 |
| New construction and complete renovation | | | | N/A | N/A | Perf based only |
| LED Exit Signs (new fixtures only): For existing facilities with load <= 75 kW | | | | N/A | N/A | \$20 |
| LED Exit Signs (new fixtures only): For existing facilities with load >= 75 kW | | | | N/A | N/A | \$10 |
| Pulse Start Metal Halide (for fixtures >= 150 watts) - includes parking lot lighting | | | | N/A | N/A | \$25 |
| Parking lot low bay - LED | | | | N/A | N/A | \$43 |
| T-12 to T-8 fixtures by permanent delamping & new reflectors | | | | N/A | N/A | \$30 |
| Controls | | | | | | |
| OSW - Occupancy Sensor Wall Mounted (existing facilities only) | | | | N/A | N/A | \$20 |

| | | | | |
|---|-----|-----|------|------------------------|
| OSR- Occupancy Sensor Remote Mounted (existing facilities only) | N/A | N/A | \$35 | Per Fixture Controlled |
| DLD-Fluorescent Daylight Dimming | N/A | N/A | \$25 | Per Fixture Controlled |
| OHLF-Occupancy controlled High-Low with Step Ballast | N/A | N/A | \$25 | Per Fixture Controlled |
| OSRH- Occupancy Sensor Remote Mounted | N/A | N/A | \$35 | Per Fixture Controlled |
| OHLH-Occupancy controlled High-Low with Step Ballast | N/A | N/A | \$75 | Per Fixture Controlled |
| DDH-Daylight Dimming | N/A | N/A | \$75 | Per Fixture Controlled |

APPENDIX C

ECM-1b Install Lighting Occupancy Sensors

APPENDIX D

ECM-1c Lighting Replacements with Occupancy Sensors

APPENDIX E

ECM-2 Light Bulb Exchange

COST TABLE

| Field Code | Standard Code | Watts per fixture | Watts per fixture | NYSERDA Code | Standard Code | NYSERDA Code | Watts per fixture | Lamps/Fix | Ball/Fix | Fixture Replacement | | | Ballast Replacement | | | Lamp Replacement | | | O.P. & D | NJ Incentive | Retrofit Cost (inc. O&P) |
|------------|---------------|-------------------|-------------------|--------------|---------------|--------------|-------------------|-----------|----------|---------------------|-------|----------|---------------------|-------|----------|------------------|-------|----------|----------|--------------|--------------------------|
| 71 | I 60 | 60 | 60 | I60/1 | CF 13 | CFQ13/1 | 17 | 1 | | Material | Labor | Disposal | Material | Labor | Disposal | Material | Labor | Disposal | \$1.40 | \$0.00 | \$5.40 |
| 77 | I 150 | 150 | 150 | I150/1 | CF 28 | CFQ28/1 | 33 | 1 | | | | | | | | \$4.00 | INC | INC | \$1.40 | \$0.00 | \$5.40 |
| 86 | CF 13 1 LAMP | 15 | 15 | CFQ13/1-L | NONE | | | | | | | | | | | \$4.00 | INC | INC | \$0.00 | \$0.00 | \$5.40 |
| 101 | I 40 | 40 | 40 | I40/1 | CF 10 | CFQ10/1 | 15 | 1 | | | | | | | | \$4.00 | INC | INC | \$1.40 | \$0.00 | \$5.40 |
| 126 | DC 23 C CF 2 | 48 | 48 | CFQ22/2 | NONE | | | | | | | | | | | | | | \$0.00 | | \$0.00 |

| New Jersey Smart Start Prescriptive Lighting type | | | | | | | | | | Watt/Fix | Lamps | \$/Unit | | | |
|--|--|--|--|--|--|--|--|--|--|----------|-------|-----------------|--|--|--|
| New Hard Wired Compact Fluorescents | | | | | | | | | | N/A | 1 | \$25 | | | |
| New Hard Wired Compact Fluorescents | | | | | | | | | | N/A | 2 | \$30 | | | |
| For retrofit of T-12 fixtures to T-5 or T-8 with electronic ballasts | | | | | | | | | | N/A | 1&2 | \$10 | | | |
| Retrofit T-12 to T-5, T-8 with Electronic Ballasts | | | | | | | | | | N/A | 3 & 4 | \$20 | | | |
| For replacement of fixtures with new T-5 or T-8 fixtures | | | | | | | | | | | | | | | |
| HID, T-12, Incandescent to T-8, T-5 with Electronic Ballasts | | | | | | | | | | >1000 | N/A | \$284 | | | |
| HID, T-12, Incandescent to T-8, T-5 with Electronic Ballasts | | | | | | | | | | 400-999 | N/A | \$100 | | | |
| HID, T-12, Incandescent to T-8, T-5 with Electronic Ballasts | | | | | | | | | | 250-399 | N/A | \$50 | | | |
| HID Only to T-8, T-5 with Electronic Ballasts | | | | | | | | | | 175-249 | N/A | \$43 | | | |
| HID Only to T-8, T-5 with Electronic Ballasts | | | | | | | | | | 100-174 | N/A | \$30 | | | |
| HID Only to T-8, T-5 with Electronic Ballasts | | | | | | | | | | 75-99 | N/A | \$16 | | | |
| T-12 Only to T-8, T-5 with Electronic Ballasts (1&2 lamp) | | | | | | | | | | <250 | 1&2 | \$25 | | | |
| T-12 Only to T-8, T-5 with Electronic Ballasts (3&4 lamp) | | | | | | | | | | <250 | 3 & 4 | \$30 | | | |
| For retrofit of T-8 fixtures by permanent delamping & new reflectors | | | | | | | | | | N/A | N/A | \$20 | | | |
| New construction and complete renovation | | | | | | | | | | N/A | N/A | Perf based only | | | |
| LED Exit Signs (new fixtures only): For existing facilities with load <= 75 kW | | | | | | | | | | N/A | N/A | \$20 | | | |
| LED Exit Signs (new fixtures only): For existing facilities with load >= 75 kW | | | | | | | | | | N/A | N/A | \$10 | | | |
| Pulse Start Metal Halide (for fixtures >= 150 watts) - includes parking lot lighting | | | | | | | | | | N/A | N/A | \$25 | | | |
| Parking lot low bay - LED | | | | | | | | | | N/A | N/A | \$43 | | | |
| T-12 to T-8 fixtures by permanent delamping & new reflectors | | | | | | | | | | N/A | N/A | \$30 | | | |
| Controls | | | | | | | | | | | | | | | |
| OSW - Occupancy Sensor Wall Mounted (existing facilities only) | | | | | | | | | | N/A | N/A | \$20 | | | |
| OSR - Occupancy Sensor Remote Mounted (existing facilities only) | | | | | | | | | | N/A | N/A | \$35 | | | |
| DLD-Fluorescent Daylight Dimming | | | | | | | | | | N/A | N/A | \$25 | | | |
| OHLF - Occupancy controlled High-Low with Step Ballast | | | | | | | | | | N/A | N/A | \$25 | | | |
| OSRH - Occupancy Sensor Remote Mounted | | | | | | | | | | N/A | N/A | \$35 | | | |
| OHLH - Occupancy controlled High-Low with Step Ballast | | | | | | | | | | N/A | N/A | \$75 | | | |
| DDH-Daylight Dimming | | | | | | | | | | N/A | N/A | \$75 | | | |

CHA Project No. 20241 Lawler Towers
Existing Lighting - Apartment Lamps
ECM-2 Bulb Replacements (Apartment Lamps)

Hours of Operation

| | Hours/Day | Hours/Year | Proposed | Utilized |
|----------------------------|-----------|------------|----------|----------|
| Apartment (tenants' lamps) | | 500 | 500 | Y |

APPENDIX F

ECM-3a Replace Urinals and Flush Valves with Low Flow Units

North Bergen Housing Authority
CHA #20241
Building: Lawler Towers Apartments

ECM-3a Replace urinals and flush valves with low flow

| EXISTING CONDITIONS | | |
|------------------------------------|--------|-----------|
| Cost of Water / 1000 Gallons | \$9.00 | \$ / kGal |
| Urinals in Building | 2 | |
| Average Flushes / Urinal (per Day) | 30 | |
| Average Gallons / Flush | 3.0 | Gal |

| PROPOSED CONDITIONS | | |
|------------------------------------|---------|-----|
| Proposed Urinals to be Replaced | 2 | |
| Proposed Gallons / Flush | 1.0 | Gal |
| Proposed Material Cost | \$360 | |
| Proposed Installation Cost | \$269 | |
| Total cost of new urinals & valves | \$1,258 | |

| SAVINGS | | |
|---------------------------|------|-------------|
| Current Urinal Water Use | 66 | kGal / year |
| Proposed Urinal Water Use | 55 | kGal / year |
| Water Savings | 11 | kGal / year |
| Cost Savings | \$99 | / year |
| Simple Payback | 12.8 | years |

APPENDIX G

ECM-3b Replace Toilets and Flush Valves with Low Flow Types

North Bergen Housing Authority
CHA #20241
Building: Lawler Towers Apartments

ECM-3b Replace toilets with low flow units

| EXISTING CONDITIONS | | |
|------------------------------------|--------|-----------|
| Cost of Water / 1000 Gallons | \$9.00 | \$ / kGal |
| Toilets in Building | 130 | |
| Average Flushes / Toilet (per Day) | 6 | |
| Average Gallons / Flush | 3.5 | Gal |

| PROPOSED CONDITIONS | | |
|--|----------|-----|
| Proposed Toilets to be Replaced | 130 | |
| Proposed Gallons / Flush | 1.6 | Gal |
| Proposed Material Cost of new Flush Valves | \$315 | |
| Proposed Installation cost of new Flush Valves | \$139 | |
| Total cost of new toilets & valves | \$58,988 | |

| SAVINGS | | |
|---------------------------|---------|-------------|
| Current Toilet Water Use | 996 | kGal / year |
| Proposed Toilet Water Use | 456 | kGal / year |
| Water Savings | 541 | kGal / year |
| Cost Savings | \$4,868 | / year |
| Simple Payback | 12.1 | years |

Note:

Lawler has 261 toilets. This assumes that half of the toilets have been replaced with low flow toilets.

APPENDIX H

Not used

APPENDIX I

ECM-3c Install Low Flow Showerheads

North Bergen Housing Authority
CHA #20241
Building: Lawler Towers Apartments

ECM-3c Replace Showerheads

| EXISTING CONDITIONS | | |
|---------------------------------|--------|-----------|
| Cost of Water / 1000 Gallons | \$9.00 | \$ / kGal |
| Faucets in Building | 513 | |
| Average Uses / shower (per day) | 1 | |
| Time in shower | 5 | Minutes |
| Old Flow / Showerhead | 2.50 | GPM |
| Average Gallons / Use | 13 | Gal/Day |

| PROPOSED CONDITIONS | | |
|---|----------|---------|
| Proposed showers to modify | 513 | |
| Proposed Flow / Showerhead | 1.6 | Gal |
| Proposed Average Gallons / Use | 8.0 | Gal/Day |
| Proposed Material Cost of new showerheads | \$15 | |
| Proposed Installation cost of new showerheads | \$19 | |
| Total cost of new showerheads | \$17,314 | |

| SAVINGS | | |
|---------------------------|---------|-------------|
| Current Shower Water Use | 2,341 | kGal / year |
| Proposed Shower Water Use | 1,498 | kGal / year |
| Water Savings | 843 | kGal / year |
| Cost Savings | \$7,583 | / year |
| Simple Payback | 2.3 | years |

APPENDIX J

ECM-4 Thermostats and Control Valves for Steam Radiators

YOUR SUMMARY

This report addresses the key recommendations for improving the comfort, safety and efficiency of your home. You should use it as a guide for deciding what work you want to have done. Remember, your Home Performance Contractor is ready to complete these projects promptly, and the work is guaranteed.



Selected Packages

| Measure Description | Non-energy benefits | Package1 | Package2 | Package3 |
|--|---|-----------|----------|----------|
| <ul style="list-style-type: none"> Temp Limiting T-Stats Not Office & Comm Rm: Install 6 non-programmable Heating only thermostats. Install 12 non-programmable heating/cooling thermostats. | <ul style="list-style-type: none"> Improve comfort, improve convenience. | \$ 0 | | |
| Total Installed Cost | | \$ 0 | | |
| Annual Energy Cost Savings | | \$ 11,498 | | |
| Annual KWh Savings, KWh | | 0 | | |
| Total Energy Savings, MMBtu | | 1,035.8 | | |
| Simple annual payback, years | | NA | | |
| Savings to Investment Ratio | | NA | | |

The following fuel prices were used to estimate annual energy cost savings, payback and savings to investment ratio:

- Natural gas: 1.1100 \$/Therm
- Electricity: 0.1500 \$/kWh

Base Load Report

Customer Information

Customer Name: NBHA

Address: 6121/3131 Grand Avenue
North Bergen, NJ 07047

Billing Period: None

Auditor Information

Technician Name:

Company:

Phone Number:

Date: 8/17/2009

Model to Actual Comparison of Base Usage Per Year

Model Name: Temp Limiting Thermostats

Billing Period Name: None

| | Electricity | | Natural gas | | | |
|--------------|-------------|---------|-------------|--------|--|--|
| | kWh | \$ | Therm | \$ | | |
| Model | 1,484,677 | 222,702 | 24,076 | 26,724 | | |
| Billing | | | | | | |
| % Difference | | | | | | |

Note: No billing data is available because the model was not compared to a billing period


Annual Use of Domestic Hot Water, Appliances, and Lighting

Model Name: Temp Limiting Thermostats

| | Electricity \$0.15 per kWh | | Natural gas \$1.11 per Therm | | | | Total |
|--|-------------------------------|----------------|---------------------------------|---------------|--|--|----------------|
| | kWh | \$ | therms | \$ | | | \$ |
| 1. Domestic Hot Water | 0 | 0 | 23,161 | 25,709 | | | 25,709 |
| 2. Heating Community Rm & Offices | 130,680 | 19,602 | 0 | 0 | | | 19,602 |
| 3. Range. electric | 120,400 | 18,060 | 0 | 0 | | | 18,060 |
| 4. Oven. electric | 120,400 | 18,060 | 0 | 0 | | | 18,060 |
| 5. typical Other Heated Area lighting | 118,610 | 17,792 | 0 | 0 | | | 17,792 |
| 6. typical Other Heated Area lighting | 117,822 | 17,673 | 0 | 0 | | | 17,673 |
| 7. Refrigerator-auto def top freezer, 1990 | 88,400 | 13,260 | 0 | 0 | | | 13,260 |
| 8. Refrigerator-auto def top freezer, 1990 | 88,400 | 13,260 | 0 | 0 | | | 13,260 |
| 9. Cooling Community Rm & B-Offices | 57,408 | 8,611 | 0 | 0 | | | 8,611 |
| 10. Other | 609,883 | 91,482 | 915 | 1,016 | | | 92,498 |
| TOTAL | 1,452,003 | 217,800 | 24,076 | 26,725 | | | 244,525 |

Base Load Energy Users, \$/year

Model Name: Temp Limiting Thermostats





MODEL ENERGY REPORT FOR TEMP LIMITING THERMOSTATS

NBHA Lawlwer Apts

For: NBHA

By:

Date: 8/17/2009



Note: Due to rounding, the sum of percentages may not be equal to 100.

DESIGN HEATING AND COOLING LOADS FOR TEMP LIMITING THERMOSTATS

8/17/2009
Project Name: NBHA Lawlwer Apts

For: NBHA

By:

Date:

Primary Heating System:

| Space Name | Load, Btu/Hr | Load, per SF Btu/(Hr-SqFt) | Distribution | |
|-------------------------|--------------|-------------------------------|--------------|--------------------|
| | | | GPM | Ft of baseboard |
| Gr Fl Common Tower A | 160584 | 26 | 18.3 | 308 |
| 2nd Fl Apts Tower B | 98753 | 19 | 11.2 | 189 |
| 3rd Fl Apts Tower B | 102342 | 19 | 11.6 | 196 |
| 2nd Fl Common Tower B | 0 | 0 | 0.0 | 0 |
| Community Room | 205047 | 65 | 23.3 | 393 |
| Mechanical Spaces T-A | 396754 | 64 | 45.1 | 760 |
| 1st Fl Common Tower A | 29864 | 12 | 3.4 | 58 |
| 1st- Apts Tower A | 90322 | 25 | 10.3 | 173 |
| Gr Fl Office B Tower | 403732 | 52 | 45.9 | 773 |
| Basement Tower B | 18413 | 24 | 2.1 | 36 |
| 1st Fl Common Tower B | 0 | 0 | 0.0 | 0 |
| 1st Fl Apts Tower B | 85233 | 24 | 9.7 | 164 |
| 3rd Fl Common | 0 | 0 | 0.0 | 0 |
| 4th-13th Apts Tower B | 1236371 | 26 | 140.6 | 2366 |
| 4th-13th Common Tower B | 0 | 0 | 0.0 | 0 |
| 2nd Fl Apts Tower A | 113059 | 21 | 12.9 | 217 |
| 2nd Fl Common Tower A | 0 | 0 | 0.0 | 0 |
| 3rd Fl Apts Tower A | 115703 | 22 | 13.2 | 222 |
| 3rd Fl Common Tower A | 0 | 0 | 0.0 | 0 |
| 4th-13th Apts Tower A | 1398161 | 29 | 158.9 | 2675 |
| 4th-13th Common Tower A | 0 | 0 | 0.0 | 0 |

Required Heating Equipment Output Capacity: 5287735 Btu/hr

Available Heating Equipment Output Capacity: 6327100 Btu/hr

Total flow: 528.9 GPM

Baseboard Capacity: 575 Btu/Hr-Ft

Heating Equipment Efficiency: 65 %

Calculated Distribution Efficiency: 93 %

Supply Water Temperature: 220 F

Temperature Drop: 20 F

Heating Safety Factor: 1.10

Distribution Safety Factor: 1.10

DETAILED PACKAGE DESCRIPTION AND WORKSCOPE FOR Temp Limiting Thermostats

NBHA Lawlwer Apts

For: NBHA

By:

Date:8/17/2009

Improvement Information:

1. Temp Limiting T-Stats Not Office & Comm Rm

Programmable Thermostat Installation

| |
|--|
| Install 6 non-programmable Heating only thermostats. |
|--|

| |
|--|
| Install 12 non-programmable heating/cooling thermostats. |
|--|

Non-Energy Benefits: Improve comfort, improve convenience.

Work Scope:

Comply with General Conditions. Submit product information and obtain Owner approval prior to ordering. Thermostat shall have a minimum of two setback periods per day and allow for 7-day programming. Remove existing thermostat and leave with Owner if requested, otherwise dispose off-site in compliance with state and local solid waste regulations, including compliance with hazardous waste regulations for thermostats which contain mercury. Patch and paint surface where existing thermostat was removed, to match existing. Terminate unused existing thermostat wires safely and hidden from view. For removed line-voltage thermostats, disconnect wiring at load and breaker panel, safely terminate wiring, and label disconnected wiring and breakers as "ABANDONED". Install new thermostat 60" above finished floor in location approved by Owner. Level the new thermostat, and ensure that it is securely fastened and installed according to the manufacturer's instructions. Adjust anticipator according to heating system instructions. Test thermostat by cycling it automatically through setup and setback periods. Program the thermostat (temperature and time periods) according to the Owner's instructions. Provide a written report of settings. Provide training to Owner in use of thermostat, including at a minimum: How to change thermostat temperature, how to change program periods, how to temporarily override programmed periods, how to change auto/fan setting (if applicable) and what this does, how to adjust anticipator, and other system-specific features.

RA 2000 1PS Thermostatic Radiator Valve For Use on One-Pipe Low-Pressure Steam Systems




Typical Installation

Sample

Dial / Operator / Sensor + Valve

FREE STANDING RADIATORS

The free-standing one-pipe low-pressure steam radiator is positioned where air continually passes freely over the operator



Use standard or tamper resistant model with combined dial/operator/sensor. Always install the operator horizontally




Use air vent

PLUS

1/8" one-pipe
steam valve

FREE STANDING RADIATORS

The free-standing one-pipe low-pressure steam radiator is accessible, but air cannot continually pass freely over the operator



Use dial / operator with remote sensor. The sensor and capillary tube may be extended up to 6' and can be easily wall mounted.




Use air vent

PLUS

1/8" one-pipe
steam valve

CONVECTORS

The one-pipe low-pressure steam convector is inaccessible; room air cannot continually pass freely over the valve



Use operator with combined remote dial / sensor. The dial/sensor and capillary tube may be extended up to 6' and are wall mounted.



Use air vent


PLUS

Two 45° elbows
PLUS

1/8" one-pipe
steam valve

ENCLOSED RADIATORS

The cabinet enclosed radiator configuration requires that the dial and sensor be mounted separately, away from the valve



Use operator with separate remote dial and remote sensor. Place the remote sensor beneath the element or on a draft-free wall. The remote dial mounts on the enclosure or wall.



Use air vent


PLUS

1/8" one-pipe
steam valve

RA 2000 1PS Thermostatic Radiator Valve For Use on One-Pipe Low-Pressure Steam Systems




Design & Function



| Part | Material |
|-----------------------|---------------------|
| 1. Valve | Nickel plated brass |
| 2. Valve Disc | EPDM |
| 3. Spindle guide | Phosphor bronze |
| 4. Spring | Stainless steel |
| 5. Back seat washer | EPDM |
| 6. Valve spindle | Brass |
| 7. Pressure pin | Stainless steel |
| 8. Clamping band | Al. alloy |
| 9. Allenscrew | Steel |
| 10. Socket | Zytel Nylon |
| 11. Bellows | Phosphor bronze |
| 12. Handle | ABS |
| 13. Adjustment spring | Steel |
| 14. Safety spring | Steel |
| 15. Pressure spindle | Polyamide No. 6 |
| 16. Air vent | - |
| 17. Retainer | Brass |
| 18. Packing gland | - |
| Capillary Tube | Steel |

- Danfoss' RA 2000 1PS one-pipe steam thermostatic radiator valve provides accurate temperature control and quiet operation.
- The movement of air across the thermostatic operator effects the modulation control in regulating the venting of air from the radiator or convector.
- Based on the set temperature on the operator, the 1PS regulates the amount of steam allowed into the emitter by controlling the amount of air allowed to vent out.
- The venting action occurs during each system (boiler) on-cycle only when heat is required. Air will re-enter the system during the boiler off-cycle via a patented "across the seat" vacuum breaker. This eliminates condensate buildup and allows natural system aspiration to take place.
- The RA 2000 1PS assembly is specifically designed for low pressure steam systems. The system pressure should not be constant preventing air to get back into the system.
- Thermostatic radiator valve assembly- valve, thermostatic operator and air vent- can be used for free standing radiators, convectors, and enclosed radiators. 1PS is not recommended for copper fin tube radiators.

Dimensions



RA 2000 1PS

Thermostatic Radiator Valve

For Use on One-Pipe Low-Pressure Steam Systems



Technical Data

| Type | Maximum Temperature | Maximum Pressure |
|-------------|---------------------|------------------|
| RA 2000 1PS | 250°F | 15psig |

RA 2000 Operators

Temp. Range:
45°F-86°F

Max. Sensor
Temp.: 140°F

| Symbol | Code No. | Description | Sensor | Capillary |
|--------|----------|---|----------|-----------|
| | 013G8250 | Valve mounted dial & sensor | Built-in | - |
| | 013G8252 | Valve mounted dial with remote sensor | Remote | 6' |
| | 013G8240 | Valve mounted dial and sensor, tamper-resistant | Built-in | - |
| | 013G2922 | Valve mounted dial with remote sensor, tamper-resistant | Remote | 6' |
| | 013G8562 | Combined remote mounted dial & sensor | - | 6' |
| | 013G8565 | Combined remote mounted dial & sensor | - | 16' |
| | 013G8568 | Combined remote mounted dial & sensor | - | 26' |
| | 013G8564 | Separate remote mounted dial and sensor | Remote | 6' + 6' |

Parts & Accessories
For RA 2000 Operators:

013G8250
013G8252
013G8240
013G2922



| Code No. | Description |
|----------|---|
| 013G1236 | Screwdriver tool set |
| 013G1215 | Limitation pins for RA 8250/52 (30 pcs) |
| 013G1237 | Limitation pins for tamper resistant operators RA 8240 / 2922 (30 pcs) |
| 013G5245 | Anti-theft protection clips for RA 8250/52 (20 pcs) |
| 013G1232 | Locking screw plugs for tamper resistant operators RA 8240 / 2922 (50 pcs). |
| 013G1672 | Cover plate for scale window of tamper resistant operators (20 pcs) |

013G8562
013G8565
013G8568
013G8564



| Position No. | Description | Code No. |
|--------------|-------------------------------|----------|
| 1 | Socket Body for RA 2000 | 013G5191 |
| 2 | Bellows Holder (set of 2 pcs) | 013G5503 |

RA2000 1PS
Valve

| Design | Code no. | Valve Size | Pattern | Connections Inlet x Outlet |
|--------|----------|------------|---------|-------------------------------|
| | 013G0140 | 1/8" | 1PS | MPT x FTP |


Parts & Accessories
For RA2000 1PS Valve

| Code No. | Description |
|----------|--------------------------------------|
| 013L8011 | 1-pipe steam air vent |
| 013L8300 | Brass 45° street elbow for convector |
| 013G0290 | Packing gland for valves |

[About](#)[Valves](#)[Non-Electric Operators](#)[Electric Operators](#)[One-Pipe Steam](#)[Accessories](#)[Conversion Inserts](#)[Umbrella Adapters](#)[Inlet Orifice](#)[Specifications](#)[Warranty](#)[Literature Downloads](#)[Dimensioning Tools](#)[Questions / Comments](#)[Reps & Distributors](#)[Tunstall Corporation](#)[Links](#)

REMOTE SENSOR THERMOSTAT MTWZ

Sample



Operation

The sensor on the MTWZ is wax-filled and the wax volume varies according to ambient temperature. The volume changes are transmitted to the valve stem via a liquid capillary system. The valve body has a return spring which closes the valve when the stem is under low pressure. When the force from the sensor and the return spring are balanced to the room temperature selected, the valve disc stops in that position to allow a certain amount of water or steam to flow through the valve. Ambient temperature changes cause the valve disc to change position and thereby continuously modulate the flow so that the room temperature is maintained at the desired temperature. The unit is secured against damage from over-pressure by a built-in pressure absorbing spring.

Features:

- Valve-mounted setting knob and remote temperature sensor
- Brass sensor, High sensitivity
- Fiberglass valve plug shaft
- Stainless steel capillary tube, 6'6" standard length
- Longer capillary available, consult factory
- Fits all Macon NT series valves
- Replaces the valve-mounted sensors on built-in convectors, etc., and where the valve-mounted sensor is exposed to draft from doors and windows
- Fully automatic - nonelectric, no wiring
- Manufactured to exacting standards using exceptionally high quality materials
- Each sensor is tested and re-checked to achieve exact settings before leaving the factory
- Note that changing the actuator can be accomplished without draining the system
- All Macon thermostats can be locked at or limited to a specific

About

Valves

Non-Electric Operators

Electric Operators

One-Pipe Steam

Accessories

Conversion Inserts

Umbrella Adapters

Inlet Orifice

Specifications

Warranty

Literature Downloads

Dimensioning Tools

Questions / Comments

Reps & Distributors

Tunstall Corporation

Links



CAPACITY TABLES for "NT" SERIES VALVES

STEAM BTU/hour

| P.D. * with 10 PSI Inlet | 3.5 C _v 1-1/4" Valves | 2.74 C _v 1" Valves | 2.5 C _v 3/4" Valves | 1.8 C _v 1/2" Valves |
|-----------------------------|-------------------------------------|----------------------------------|-----------------------------------|-----------------------------------|
| 1 psi | 48,000 | 39,000 | 36,000 | 28,000 |
| 3 psi | 87,000 | 70,000 | 65,000 | 46,000 |
| 5 psi | 113,000 | 91,000 | 84,000 | 63,000 |
| 7 psi | 130,000 | 104,000 | 96,000 | 72,000 |
| 10 psi | 162,000 | 130,000 | 120,000 | 90,000 |

***P.D. = Pressure Drop**

Capacity measured with 10 psi inlet pressure.

EDR = Equivalent Direct Radiation (in ft.²)

EDR = (BTU/hr) / 240

BTU/hr = 240 x EDR

BTU/hour - lbs. steam/hour x 1000


HOT WATER BTU/hour**

| **Pressure Drop Ft. | P.D. PSI | 3.5 C _v 1-1/4" Valves | 2.74 C _v 1" Valves | 2.5 C _v 3/4" Valves | 1.8 C _v 1/2" Valves |
|------------------------|-------------|-------------------------------------|----------------------------------|-----------------------------------|-----------------------------------|
| 1 | .43 | 21,000 | 17,000 | 16,500 | 12,000 |
| 2 | .87 | 28,000 | 23,000 | 22,000 | 15,500 |
| 4 | 1.7 | 44,000 | 35,000 | 32,500 | 23,500 |
| 6 | 2.6 | 53,000 | 43,000 | 40,000 | 29,000 |
| 8 | 3.5 | 64,000 | 51,000 | 47,000 | 33,500 |
| 10 | 4.3 | 70,000 | 56,000 | 52,000 | 37,500 |
| 12 | 5.2 | 77,000 | 62,000 | 57,000 | 41,000 |
| 14 | 6.1 | 83,000 | 67,000 | 62,000 | 44,500 |
| 16 | 7.0 | 88,000 | 71,000 | 66,000 | 47,500 |

[About](#)[Valves](#)[Non-Electric Operators](#)[Electric Operators](#)[One-Pipe Steam](#)[Accessories](#)[Conversion Inserts](#)[Umbrella Adapters](#)[Inlet Orifice](#)[Specifications](#)[Warranty](#)[Literature Downloads](#)[Dimensioning Tools](#)[Questions / Comments](#)[Reps & Distributors](#)[Tunstall Corporation](#)[Links](#)

SPECIFICATIONS

MTW

**DATA:**

Temp. Range: 46° - 82°F

Hysteresis: 0.9°F

Heat Transfer: 1.1°F (Valve Housing Sensor)

Dead Time: 0.8 Minutes

Max. Differential Pressure: 20 psi

Suggested Differential Pressure = 0.5 to 2.9 psi

Max. Water Temp.: 250°F


Max. Storage & Ambient Temp.: 122°F

Max. Steam Pressure: 15 psig

Max. Movement: 0.125 inches

Nominal Opening: 0.018 (3.6°F)

Long Term Test: 5000 cycles (1.3°F)

**DIAL SETTINGS:**

0 = Off

* = 46°F (Frost Protection)

1 = 54°F

3 = 61°F


5 = 68°F

6 = 72°F

7 = 76°F

[About](#)[Valves](#)[Non-Electric Operators](#)[Electric Operators](#)[One-Pipe Steam](#)[Accessories](#)[Conversion Inserts](#)[Umbrella Adapters](#)[Inlet Orifice](#)[Specifications](#)[Warranty](#)[Literature Downloads](#)[Dimensioning Tools](#)[Questions / Comments](#)[Reps & Distributors](#)[Tunstall Corporation](#)[Links](#)

REMOTE SENSOR THERMOSTAT ENTL B46000



Operation:


The sensor is wax-filled and the wax volume varies according to ambient temperature. The volume changes are transmitted to the valve stem via a liquid capillary system. The valve body has a return spring which closes the valve when the stem is under low pressure. When the force from the sensor and the return spring are balanced to the room temperature selected, the valve disc stops in that position to allow a certain amount of water or steam to flow through the valve. Temperature changes cause the valve disc to change position and thereby continuously modulate the flow so that the room temperature is maintained at the desired temperature. The unit is secured against damage from over pressure by a pressure absorbing spring.

SPECIFICATIONS - ENTL B46000

| Features: | |
|--|--|
| Combined remote dial/sensor | Small dimensions |
| Brass sensor, High sensitivity | Manufactured to exacting standards using exceptionally high quality materials |
| Fiberglass valve plug shaft | Each sensor is tested and re-checked to achieve exact settings before leaving the factory |
| Stainless steel capillary tube, 6'6" standard length | Note that changing of the actuator can be accomplished without draining the system |
| Longer capillary available, consult factory | All Macon thermostats can be locked at or limited to a specific temperature or temperature range |
| Fits all Macon NT series valves | Simple one-trade installation |
| Replaces the valve-mounted | All Macon valves and thermostats conform |

[About](#)[Valves](#)[Non-Electric Operators](#)[Electric Operators](#)[One-Pipe Steam](#)[Accessories](#)[Conversion Inserts](#)[Umbrella Adapters](#)[Inlet Orifice](#)[Specifications](#)[Warranty](#)[Literature Downloads](#)[Dimensioning Tools](#)[Questions / Comments](#)[Reps & Distributors](#)[Tunstall Corporation](#)[Links](#)

DIRECT MOUNT OPERATOR MTW



The Macon MTW thermostatic valve will help you balance your heating system. The MTW operator has one of the most accurate sensors available for radiator temperature control. The problems of overheating, underheating and wide temperature swings can now be minimized.

The MTW thermostatic valve by Macon Controls conserves energy by regulating temperature. Fuel costs can be reduced up to 30%!

The MTW is a self-acting adjustable non-electric thermostatic operator. It has an anti-freeze position, adjustable max./min. temperature settings, selected temperature locking feature and can be shutoff completely if desired. Each MTW thermostatic operator is individually calibrated and conforms to ASHRAE standardization rules for temperature regulation. The MTW's smooth shape with narrow air gaps is a very functional design and allows for easy cleaning. The MTW can be mounted on all Macon NT series valves. Millions are in use throughout the world.

SPECIFICATIONS - MTW

Max, Min Setting - MTW

Toll Free: 1-800-423-5578
Tunstall Corporation - 118 Exchange Street - Chicopee, MA 01013
Phone: (413) 594-8695 - Fax: (413) 598-8109

North Bergen Housing Authority
CHA #20241
Building: Lawler Towers Apartments

ECM-4 Install Control Valves

Install new 3/4" self contained control valves on the existing 3/4" steam fin tube radiation.
Control valve to have a capillary and wall mounted thermostat for controlling space temperature.

| Multipliers* | |
|--------------|------|
| Material: | 1.00 |
| **Labor: | 1.22 |
| Equipment: | 1.00 |

| Description | QTY | UNIT | UNIT COSTS | | | SUBTOTAL COSTS | | | TOTAL COST | REMARKS |
|--|-----|------|------------|-------|--------|----------------|-----------|--------|------------|---------|
| | | | MAT. | LABOR | EQUIP. | MAT. | LABOR | EQUIP. | | |
| Install 3/4" control valve and thermostat. | 432 | ea. | \$ 100 | \$ 90 | | \$ 43,200 | \$ 47,434 | \$ - | \$ 90,634 | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |

| | |
|-------------------|----------------------------|
| \$ 90,634 | Subtotal |
| \$ 9,063 | 10% Contingency Contractor |
| \$ 14,955 | 15% O&P |
| \$ - | 0% Engineering |
| \$ 114,652 | Total |

*Multipliers per RS Means Mechanical Cost Data for Newark, New Jersey
**Multiplier for Mechanical Labor specific to Newark, New Jersey area.

APPENDIX K

ECM-5 Install Door Seals



North Bergen Housing Authority
CHA #20241
Building: Lawler Towers Apartments

ECM-5 Install Door Seals

Existing: Doors or Door Seals result in excessive heat loss and infiltration
Proposed: Install new doors and/or weatherstripping to eliminate door infiltration
Bld Data for Newark, New Jersey

| Bin Dry Bulb Temp. F | Bin Wet Bulb Temp. F | Enthalpy Bulb lba Ha | Humidity Ratio lba.a | Grains / lba.a | Specific Volume Cu. Ft./lba. | Delta T - F | Specific Heat BTU/lb.-F | Conversion Factor | Break Point Enthalpy Hb | Delta Enthalpy Ha-Hb | Mass Flow | Cooling Load BTUH | Heating Load BTUH | Hours of Operation / Yr. | BTU / Year | Therm / Year | Yearly Operating Cost (Heating) | Yearly Operating Cost (Cooling) |
|----------------------|----------------------|----------------------|----------------------|----------------|------------------------------|-------------|-------------------------|-------------------|-------------------------|------------------------------------|-----------|-------------------|-------------------|--------------------------|------------|--------------|---------------------------------|---------------------------------|
| 90 | 72.2 | 37.1 | 0.0112 | 90.177 | 14.2 | 20 | 0.24 | 1.01 | 21.1 | 16 | 337.18 | 5,395 | | 37 | 199,192 | 2 | | \$0.30 |
| 85 | 67.7 | 32.1 | 0.0104 | 73.821 | 15 | 15 | 0.24 | 1.04 | 21.1 | 16 | 344.48 | 3,769 | | 31 | 149,567 | 5 | | \$0.24 |
| 80 | 65.1 | 30.1 | 0.0098 | 68.91 | 13.7 | 10 | 0.24 | 1.05 | 21.1 | 9 | 349.49 | 3,145 | | 11 | 152,701 | 16 | | \$2.74 |
| 75 | 62.6 | 28.1 | 0.0092 | 64.95 | 13.55 | 5 | 0.24 | 1.05 | 21.1 | 7 | 350.77 | 2,455 | | 600 | 1,522,338 | 15 | | \$2.26 |
| 70 | 60.1 | 26.6 | 0.0086 | 61.69 | 13.55 | 5 | 0.24 | 1.05 | 21.1 | 5.5 | 353.36 | 1,943 | | 654 | 1,590,463 | 13 | | \$1.94 |
| 65 | 57.6 | 24.5 | 0.0084 | 58.97 | 13.4 | 5 | 0.24 | 1.08 | 21.1 | 3.4 | | | 439 | 854 | 366,175 | 4 | \$4.03 | |
| 60 | 55 | 22.1 | 0.0081 | 56.37 | 13.3 | 10 | 0.24 | 1.08 | 21.1 | 0.4 | | | 854 | 827 | 360,826 | 4 | \$3.81 | |
| 55 | 52.5 | 21.5 | 0.0078 | 54.655 | 13.2 | 15 | 0.24 | 1.09 | 21.1 | 0.4 | | | 1,306 | 600 | 1,763,491 | 8 | \$3.81 | |
| 50 | 50 | 20.3 | 0.0076 | 53.1 | 12.8 | 20 | 0.24 | 1.13 | 26.6 | -5.3 | | | 1,306 | 610 | 1,778,105 | 11 | \$11.86 | |
| 45 | 45 | 17.5 | 0.0063 | 44,152 | 12.8 | 25 | 0.24 | 1.13 | 26.6 | -9.3 | | | 2,744 | 611 | 1,371,313 | 14 | \$15.08 | |
| 40 | 40 | 15.5 | 0.0052 | 36.36 | 12.7 | 30 | 0.24 | 1.13 | 26.6 | -11.1 | | | 2,744 | 636 | 1,780,664 | 18 | \$19.59 | |
| 35 | 35 | 13 | 0.0043 | 29.82 | 12.6 | 35 | 0.24 | 1.14 | 26.6 | -13.6 | | | 3,182 | 1023 | 3,265,416 | 33 | \$35.52 | |
| 30 | 30 | 11 | 0.0035 | 24.09 | 12.4 | 40 | 0.24 | 1.17 | 26.6 | -15.6 | | | 3,707 | 734 | 2,720,820 | 27 | \$29.93 | |
| 25 | 25 | 8.75 | 0.0028 | 19.06 | 12.3 | 45 | 0.24 | 1.18 | 26.6 | -17.6 | | | 4,204 | 354 | 1,404,169 | 14 | \$15.45 | |
| 20 | 20 | 6.75 | 0.0022 | 15.01 | 12.2 | 50 | 0.24 | 1.22 | 26.6 | -19.85 | | | 4,210 | 252 | 1,086,796 | 12 | \$13.05 | |
| 15 | 15 | 3.5 | 0.0017 | 11.77 | 12 | 55 | 0.24 | 1.22 | 26.6 | -21.1 | | | 5,287 | 125 | 653,350 | 7 | \$12.24 | |
| 10 | 10 | 2 | 0.0013 | 9.14 | 11.8 | 60 | 0.24 | 1.25 | 26.6 | -21.1 | | | 6,495 | 77 | 274,620 | 3 | \$1.02 | |
| 5 | 5 | 2 | 0.001 | 7.116 | 11.2 | 65 | 0.24 | 1.25 | 26.6 | -21.1 | | | 7,079 | 22 | 162,891 | 1 | \$1.57 | |
| 1 | 1 | 1 | 0.0008 | 5.49 | 11.2 | 69 | 0.24 | 1.29 | 26.6 | -25.6 | | | 7,079 | 13 | 92,032 | 1 | \$1.01 | |
| | | | | | | | | | | Total | | 16,728 | 47,223 | 8760 | 15,996,089 | Total | \$162.35 | \$7.62 |
| | | | | | | | | | | Total Seasonal Heating - BTU / Yr. | | | | | 3,597 | | | |
| | | | | | | | | | | Average BTUH | | | | | 139 | | | |
| | | | | | | | | | | Therms / Yr. | | | | | 159 | | | |
| | | | | | | | | | | Cost / Year | | | | | \$162.35 | | | |
| | | | | | | | | | | Cost / CFM | | | | | \$2.03 | | | |
| | | | | | | | | | | Total Seasonal Cooling - BTU / Yr. | | | | | 5,081,482 | | | |
| | | | | | | | | | | Average BTUH | | | | | 1,173 | | | |
| | | | | | | | | | | Therms / Yr. | | | | | 0.01 | | | |
| | | | | | | | | | | Cost / Year | | | | | \$7.62 | | | |
| | | | | | | | | | | Cost / CFM | | | | | \$0.10 | | | |
| | | | | | | | | | | Therm (Btu) Conversion | | | | | 100,000 | | | |
| | | | | | | | | | | Cost Per Therm | | | | | \$1.10 | | | |
| | | | | | | | | | | Cost Per KW/H | | | | | \$0.1500 | | | |
| | | | | | | | | | | Total Operating Cost Savings | | | | | \$231.08 | | | |
| | | | | | | | | | | Total Therms per Year | | | | | 210 | | | |

Assumptions:
Average Space Temperature

70

Old Door Leakage - CFM

133

53.2

New Door Leakage - CFM

79.8

Leakage Reduction - CFM

| Door Dimensions | Width | Height | No. of Doors | Perimeter Dimen | Leakage / L.F. for Bad Door | Leakage / L.F. for Good Door | Old Door Leakage | New Door Leakage |
|-----------------|-------|--------|--------------|-----------------|-----------------------------|------------------------------|------------------|------------------|
| Single | 3 | 7 | 10 | 20 | 0.5 | 0.2 | 100 | 40 |
| Double | 6 | 7 | 2 | 33 | 0.5 | 0.2 | 33 | 13.2 |

| | |
|---------------|------|
| Multipliers * | |
| Material: | 1.00 |
| ***Labor: | 1.22 |
| Equipment: | 1.00 |

[illegible]

*Multipliers per RS Means Mechanical Cost Data for Newark, New Jersey
 **Multiplier for Carpentry Labor specific to the Newark, New Jersey area.

APPENDIX L

ECM-6 Insulate Steam and Condensate Piping

North Bergen Housing Authority
CHA #20241
Building: Lawler Towers Apartments

ECM-6 Piping Insulation (Bare Pipe)

Description Insulate the low pressure condensate piping which are not currently insulated to reduce heat loss from piping and heat gain to the spaces.

| | | | | | |
|-------------------|----------------------------------|---|-----------------------|-------------------------|----------------------|
| Given | Fuel Energy Cost | = | \$ | 1.10 | \$/Therm (Nat'l Gas) |
| | Operation (Hours/Week) | = | 168.00 | Hours/Week | |
| | Operation (Heating Weeks/Year) | = | 28.00 | Weeks/Year | |
| | Operation (Hours/Year) | = | 4704 | Hours/Year | |
| | Heating Media | = | Water | | |
| | Piping Material | = | Mild Steel | | |
| | Ambient Temperature | = | 65 | °F | |
| | Pipe Diameter | = | Pipe #1 3/4 inches | Pipe #2 1 1/2 inches | Pipe #3 8 inches |
| | Pipe Length | = | 1000.00 feet | 900.00 feet | 36.00 feet |
| | | | Pipe #4 2 inches | | |
| | | | 0.00 feet | | |
| Assumption | Min. Pipe Insulation Recommended | = | 1.50 inches | 1.50 inches | 1.50 inches |
| | Circulating Temperature | = | 210 | °F | |
| | Heating Efficiency | = | 65% | | |
| | Pipe Insulation Conductivity | = | 0.29 | Btu*in./(h*ft²°F) | |

Formula Piping Correction Factor = (Current Transmission Coefficient / Reference Transmission Coefficient)
Temperature Correction Factor = (Circulating Temperature - Ambient Temperature) / (Circulating Temperature - Reference Temperature)
Hourly Heat Loss per pipe size and length = (Heat loss per foot [from chart]) x (Piping Correction Factor) x (Temperature Correction Factor) x (Pipe Length)
Seasonal Heat Loss = (Hourly Heat Loss Total) x (Operating hours) / (Heating Efficiency) / (1,000 btu/Mbtu)

Energy Loss = (Seasonal Heat Loss) / (Conversion Factor [MBtu/Unit])
Energy Loss Cost = (Energy Loss) x (cost/unit)

| | | | | |
|--------------------|-----------------------------------|----------------------------------|------------------------------------|----------------|
| Calculation | Existing | Current Transmission Coefficient | Reference Transmission Coefficient | |
| | Piping Correction Factor = (| 2.00 | 2.00 | 1.00 |
| | Temperature Correction Factor = (| Circulating Temp. 210 | Ambient Temp. 65 | 1.12 |
| | Heat Loss Pipe #1 (Hourly) | 104.78 | 1.00 | 116,870 Btuh |
| | Heat Loss Pipe #2 (Hourly) | 179.28 | 1.00 | 179,970 Btuh |
| | Heat Loss Pipe #3 (Hourly) | 716.02 | 1.00 | 28,751 Btuh |
| | Heat Loss Pipe #4 (Hourly) | 219.69 | 1.00 | - Btuh |
| | | | | 325,590 Btuh |
| | Seasonal Heat Loss | 325,590 | 4,704 | 2,356,273 Mbtu |
| | Existing Energy Loss | 2,356,273 | 100 | 23,563 Therm |
| | Existing Energy Loss Cost | 23,563 | \$ 1.10 | \$ 25,919 |
| | New | Heat Loss per foot | Piping CF | Temperature CF |
| | Heat Loss Pipe #1 (Hourly) | 16.10 | 1.00 | 17,958 Btuh |
| | Heat Loss Pipe #2 (Hourly) | 20.19 | 1.00 | 20,268 Btuh |
| | Heat Loss Pipe #3 (Hourly) | 32.60 | 1.00 | 1,309 Btuh |
| | Heat Loss Pipe #4 (Hourly) | 20.00 | 1.00 | - Btuh |
| | | | | 39,534 Btuh |
| | Seasonal Heat Loss | 39,534 | 4,704 | 286,107 Mbtu |
| | New Energy Loss | 286,107 | 100 | 2,861 Therm |
| | New Energy Loss Cost | 2,861 | \$ 1.10 | \$ 3,147 |

| | | | |
|---------------|---------------------------|-------------------|-----------------|
| Result | Existing Heat Loss | 23,563 Therm | \$ 25,919 |
| | New Heat Loss | 2,861 Therm | \$ 3,147 |
| | Savings | 100% 20,702 Therm | \$ 22,772 87.9% |

Comment

North Bergen Housing Authority
CHA #20241
Building: Lawler Towers Apartments

ECM-6 Piping Insulation (Bare Pipe)

| Multipliers* | |
|--------------|------|
| Material: | 1.00 |
| **Labor: | 1.22 |
| Equipment: | 1.00 |

| Description | QTY | UNIT | INIT COSTS | | | SUBTOTAL COSTS | | | TOTAL COST | REMARKS |
|----------------------------------|------|------|------------|---------|--------|----------------|----------|--------|------------|-----------------------------|
| | | | MAT. | LABOR | EQUIP. | MAT. | LABOR | EQUIP. | | |
| Insulate 3/4" BS Pipe w/ 1-1/2" | 1140 | L.F. | \$ 1.68 | \$ 2.89 | | \$ 1,915 | \$ 4,019 | \$ - | \$ 5,935 | Means Mech. Cost Data 2009. |
| Insulation. | | | | | | \$ - | \$ - | \$ - | \$ - | |
| Insulate 11/2" BS Pipe w/ 1-1/2" | 1020 | L.F. | \$ 1.80 | \$ 3.02 | | \$ 1,836 | \$ 3,758 | \$ - | \$ 5,594 | Means Mech. Cost Data 2009. |
| Insulation. | | | | | | \$ - | \$ - | \$ - | \$ - | |
| Insulate Heatwell Tank | 15 | L.F. | \$ 34 | \$ 27 | | \$ 510 | \$ 485 | \$ - | \$ 995 | Means Mech. Cost Data 2009. |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |

*Multipliers per RS Means Mechanical Cost Data for Newark, New Jersey

**Multiplier for Mechanical Labor specific to the Newark, New Jersey area.

| | |
|-----------|--------------------|
| \$ 12,524 | Subtotal |
| \$ 2,505 | 20% Contingency |
| \$ 2,254 | 15% Contractor O&P |
| \$ - | 0% Engineering |
| \$ 17,283 | Total |

APPENDIX M

ECM-7 Air Conditioner Changeout

YOUR SUMMARY

This report addresses the key recommendations for improving the comfort, safety and efficiency of your home. You should use it as a guide for deciding what work you want to have done. Remember, your Home Performance Contractor is ready to complete these projects promptly, and the work is guaranteed.



Selected Packages

| Measure Description | Non-energy benefits | Package1 | Package2 | Package3 |
|---|--|----------|----------|----------|
| <input checked="" type="radio"/> A/C Window Replacement with 12 EER : Install 12 SEER 290,000 Btu/hr cooling system. <input type="radio"/> Reuse existing distribution system. | <input checked="" type="radio"/> Increase value of building. | \$ 0 | | |
| Total Installed Cost | | \$ 0 | | |
| Annual Energy Cost Savings | | \$ 2,529 | | |
| Annual KWh Savings, KWh | | 16,861 | | |
| Total Energy Savings, MMBtu | | 57.5 | | |
| Simple annual payback, years | | NA | | |
| Savings to Investment Ratio | | NA | | |

The following fuel prices were used to estimate annual energy cost savings, payback and savings to investment ratio:

- Natural gas: 1.1100 \$/Therm
- Electricity: 0.1500 \$/KWh

Base Load Report

Customer Information

Customer Name: NBHA

Address: 6121/3131 Grand Avenue
North Bergen, NJ 07047

Billing Period: None

Auditor Information

Technician Name:

Company:

Phone Number:

Date: 8/17/2009

Model to Actual Comparison of Base Usage Per Year

Model Name: Ac Unit Window Replacement with 12 EER

Billing Period Name: None

| | Electricity | | Natural gas | | | |
|--------------|-------------|---------|-------------|--------|--|--|
| | kWh | \$ | Therm | \$ | | |
| Model | 1,484,677 | 222,702 | 24,076 | 26,724 | | |
| Billing | | | | | | |
| % Difference | | | | | | |

Note: No billing data is available because the model was not compared to a billing period


Annual Use of Domestic Hot Water, Appliances, and Lighting

Model Name: Ac Unit Window Replacement with 12 EER

| | Electricity \$0.15 per kWh | | Natural gas \$1.11 per Therm | | | | Total |
|--|-------------------------------|----------------|---------------------------------|---------------|--|--|----------------|
| | kWh | \$ | therms | \$ | | | \$ |
| 1. Domestic Hot Water | 0 | 0 | 23,161 | 25,709 | | | 25,709 |
| 2. Heating Community Rm & Offices | 130,680 | 19,602 | 0 | 0 | | | 19,602 |
| 3. Range, electric | 120,400 | 18,060 | 0 | 0 | | | 18,060 |
| 4. Oven, electric | 120,400 | 18,060 | 0 | 0 | | | 18,060 |
| 5. typical Other Heated Area lighting | 118,610 | 17,792 | 0 | 0 | | | 17,792 |
| 6. typical Other Heated Area lighting | 117,822 | 17,673 | 0 | 0 | | | 17,673 |
| 7. Refrigerator-auto def top freezer, 1990 | 88,400 | 13,260 | 0 | 0 | | | 13,260 |
| 8. Refrigerator-auto def top freezer, 1990 | 88,400 | 13,260 | 0 | 0 | | | 13,260 |
| 9. Cooling Community Rm & B-Offices | 57,408 | 8,611 | 0 | 0 | | | 8,611 |
| 10. Other | 609,883 | 91,482 | 915 | 1,016 | | | 92,498 |
| TOTAL | 1,452,003 | 217,800 | 24,076 | 26,725 | | | 244,525 |

Base Load Energy Users, \$/year

Model Name: Ac Unit Window Replacement with 12 EER





MODEL ENERGY REPORT FOR AC UNIT WINDOW REPLACEMENT WITH 12 EER

NBHA Lawlwer Apts

For: NBHA

By:

Date: 8/17/2009



Note: Due to rounding, the sum of percentages may not be equal to 100.

DESIGN HEATING AND COOLING LOADS FOR AC UNIT WINDOW REPLACEMENT WITH 12 EER

8/17/2009

Project Name: NBHA Lawlwer Apts

For: NBHA

By:

Date:

Primary Heating System:

| Space Name | Load, Btu/Hr | Load, per SF Btu/(Hr-SqFt) | Distribution | |
|-------------------------|--------------|-------------------------------|--------------|--------------------|
| | | | GPM | Ft of baseboard |
| Gr FI Common Tower A | 166444 | 27 | 18.9 | 319 |
| 2nd FI Apts Tower B | 102364 | 19 | 11.6 | 196 |
| 3rd FI Apts Tower B | 105945 | 20 | 12.0 | 203 |
| 2nd FI Commom Tower B | 0 | 0 | 0.0 | 0 |
| Community Room | 205047 | 65 | 23.3 | 393 |
| Mechanical Spaces T-A | 396754 | 64 | 45.1 | 760 |
| 1st FI Common Tower A | 31227 | 13 | 3.5 | 60 |
| 1st- Apts Tower A | 93445 | 26 | 10.6 | 179 |
| Gr FI Office B Tower | 403732 | 52 | 45.9 | 773 |
| Basement Tower B | 19203 | 25 | 2.2 | 37 |
| 1st FI Common Tower B | 0 | 0 | 0.0 | 0 |
| 1st FI Apts Tower B | 88223 | 24 | 10.0 | 169 |
| 3rd FI Commom | 0 | 0 | 0.0 | 0 |
| 4th-13th Apts Tower B | 1280775 | 27 | 145.6 | 2451 |
| 4th-13th Common Tower B | 0 | 0 | 0.0 | 0 |
| 2nd FI Apts Tower A | 116662 | 22 | 13.3 | 224 |
| 2nd FI Common Tower A | 0 | 0 | 0.0 | 0 |
| 3rd FI Apts Tower A | 119730 | 23 | 13.6 | 230 |
| 3rd FI Common Tower A | 0 | 0 | 0.0 | 0 |
| 4th-13th Apts Tower A | 1442561 | 30 | 164.0 | 2760 |
| 4th-13th Common Tower A | 0 | 0 | 0.0 | 0 |

Required Heating Equipment Output Capacity: 5424734 Btu/hr

Available Heating Equipment Output Capacity: 6327100 Btu/hr

Total flow: 542.6 GPM

Baseboard Capacity: 575 Btu/Hr-Ft

Heating Equipment Efficiency: 65 %

Calculated Distribution Efficiency: 93 %

Supply Water Temperature: 220 F

Temperature Drop: 20 F

Heating Safety Factor: 1.10

Distribution Safety Factor: 1.10

Cooling System:

| Space Name | Load, Btu/Hr | Distribution CFM |
|-------------------------|--------------|---------------------|
| Gr Fl Common Tower A | 110762 | 4030 |
| 2nd Fl Apts Tower B | 70500 | 2565 |
| 3rd Fl Apts Tower B | 66013 | 2402 |
| 2nd Fl Common Tower B | 0 | 0 |
| Community Room | 87420 | 3180 |
| Mechanical Spaces T-A | 0 | 0 |
| 1st Fl Common Tower A | 64367 | 2342 |
| 1st- Apts Tower A | 57465 | 2091 |
| Gr Fl Office B Tower | 219345 | 7979 |
| Basement Tower B | 6271 | 229 |
| 1st Fl Common Tower B | 130099 | 4733 |
| 1st Fl Apts Tower B | 57589 | 2095 |
| 3rd Fl Common | 0 | 0 |
| 4th-13th Apts Tower B | 822976 | 29937 |
| 4th-13th Common Tower B | 0 | 0 |
| 2nd Fl Apts Tower A | 51676 | 1880 |
| 2nd Fl Common Tower A | 0 | 0 |
| 3rd Fl Apts Tower A | 67962 | 2473 |
| 3rd Fl Common Tower A | 0 | 0 |
| 4th-13th Apts Tower A | 661186 | 24052 |
| 4th-13th Common Tower A | 0 | 0 |

Required Cooling Equipment Output Capacity: 2562708 Btu/hr

Available Cooling Equipment Output Capacity: 290000 Btu/hr

Total flow: 84746 CFM

Cooling Equipment Efficiency: 12 SEER

Calculated Distribution Efficiency: 99%

Temperature Drop: 28 F

Cooling Safety Factor: 1.10

Distribution Safety Factor: 1.10

COOLING SYSTEM IS UNDERSIZED AND DOES NOT MEET THE REQUIRED COOLING LOAD.

Notes:

1. The room heating/cooling loads do not include the equipment and distribution safety factor and distribution losses
2. The room distribution includes distribution safety factor.
3. The load on the room is the peak load for this room in a year.
4. Available equipment output capacity includes equipment efficiency.
5. Required equipment output capacity includes diversity, distribution losses and equipment safety factor.
6. Overall distribution CFM/GPM for heating/cooling includes equipment safety factor, distribution losses and diversity.

DETAILED PACKAGE DESCRIPTION AND WORKSCOPE FOR Ac Unit Window Replacement with 12 EER

NBHA Lawlwer Apts

For: NBHA

By:

Date:8/17/2009

Improvement Information:

1. A/C Window Replacement with 12 EER

Cooling System Improvement

| | |
|------------------------|--------|
| Input Capacity, Btu/Hr | 290000 |
| SEER | 12 |

Non-Energy Benefits: Increase value of building.

Work Scope:

Comply with general conditions. Submit product information to owner for approval in writing prior to ordering. Remove existing air conditioning system safely and completely. Patch and paint where existing equipment was removed to match existing surfaces. Perform complete load sizing of the building prior to selecting replacement equipment, using standard methods such as ACCA manual J, or ASHRAE. Size new equipment according to this load sizing, and not according to the size of removed equipment. Provide a written copy of load sizing and assumptions for approval by the owner prior to ordering equipment. Size distribution system according to standard methods. Install forced air system securely and level. Securely fasten system to duct work with mechanical fasteners and seal. Install locking balancing dampers. Install a clean air filter. Duct sealing and insulation shall comply with standards described in the separate duct sealing and duct insulation work scopes. After installation is complete, measure and record air temperature change. Ensure that these measurements are within the manufacturer's requirements. Balance distribution system by measuring air supply to all grilles and adjusting manual balancing dampers. Set anticipator at thermostat. Charge per manufacturer's instructions. Measure and adjust superheat, subcooling, saturated suction temperature, saturated condensing temperature, compressor amps, outside air temperature, return air temperature, and supply air temperature. Provide training to the owner in the use of the system and thermostat. Deliver to the owner users manual, including measurement reports, warranties, and approved submittals.




Room Air Conditioners for Consumers

(Are you a partner? [For Partners](#))

If every room air conditioner sold in the U.S. were ENERGY STAR qualified, it would prevent 1.3 billion pounds of greenhouse gas emissions - the equivalent emissions from 115,000 cars.

Earning the ENERGY STAR means a product meets strict energy efficiency guidelines set by the U.S. Environmental Protection Agency and the U.S. Department of Energy.

- ENERGY STAR qualified room air conditioners use at least 10% less energy than conventional models.
- ENERGY STAR qualified room air conditioners often include timers for better temperature control, allowing you to use the minimum amount of energy you need to cool your room.



Remember, saving energy prevents pollution. By choosing ENERGY STAR, you are helping prevent global warming and promoting cleaner air without sacrificing the product quality and performance you expect.

You may also be interested to know that many people buy an air conditioner that is too large. ENERGY STAR suggests making sure your unit is properly sized.

FIND A PRODUCT ➔


FIND A STORE ➔

SPECIAL OFFERS ➔

ROOM AIR
CONDITIONERS
FOR PARTNERS ➔

Resources

Qualified Room Air Conditioners


Excel  | Text (CSV) | HTML

Definitions of Product List Column Headers

Purchasing Tips

Manufacturer List

Room AC FAQs

Savings Calculator 

Key Product Criteria

APPENDIX N

ECM-8 Night Setback for Offices and Community Room

North Bergen Housing Authority
CHA #20241
Building: Lawler Towers Apartments

ECHA Community Room and Office Night Setback

| | |
|-------------------------|---------|
| Utility Costs kW/ton | \$ 0.15 |
| | 1.2 |

| | | |
|-------------------------|-----------|-----------|
| Community Room Capacity | 21.6 | 16.2 |
| Office Area Capacity | 24.4 | 11.9 |
| Total | 46 | 28 |
| | 1,156 | 3,650 |
| | 57,408 | 130,680 |

NYC Bin Hours above and below balance temp

100,000 Btu/Therm
55 Balance Temp

Inputs

| Operating Hours | Current | Proposed |
|-------------------------|---------|----------|
| Hr per Day | 24 | 9 |
| Days per Week | 7 | 5 |
| Annual Operating Hours | 168 | 45 |
| Occupied Hours | 9 | 9 |
| Unoccupied Hours | 15 | 36 |
| Annual Occupied Hours | 81 | 45 |
| Annual Unoccupied Hours | 87 | 36 |
| Occupancy Rate | 32% | 100% |

Calculations

| Mean Temperature T _{db} | Bin Hours | Adjusted Hours | Current | Proposed |
|-------------------------------------|--------------|----------------|--------------|--------------|
| 92.5 | 1 | 1.0 | 0.1 | 0.1 |
| 87.5 | 1 | 1.0 | 0.1 | 0.1 |
| 82.5 | 21 | 21.0 | 21.0 | 21.0 |
| 77.5 | 366 | 366.0 | 117.3 | 117.3 |
| 72.5 | 718 | 718.0 | 230.2 | 230.2 |
| 67.5 | 941 | 941.0 | 257.1 | 257.1 |
| 62.5 | 759 | 759.0 | 243.3 | 243.3 |
| 57.5 | 830 | 830.0 | 261.1 | 261.1 |
| 52.5 | 754 | 754.0 | 241.7 | 241.7 |
| 47.5 | 789 | 789.0 | 252.9 | 252.9 |
| 42.5 | 627 | 627.0 | 201.6 | 201.6 |
| 37.5 | 627 | 627.0 | 201.6 | 201.6 |
| 32.5 | 909 | 909.0 | 291.4 | 291.4 |
| 27.5 | 788 | 788.0 | 252.6 | 252.6 |
| 22.5 | 121 | 121.0 | 35.8 | 35.8 |
| 17.5 | 223 | 223.0 | 68.8 | 68.8 |
| 12.5 | 121 | 121.0 | 35.8 | 35.8 |
| 7.5 | 50 | 50.0 | 14.9 | 14.9 |
| 2.5 | 5 | 5.0 | 1.7 | 1.7 |
| -2.5 | 0 | 0.0 | 0.0 | 0.0 |
| Total | 8,760 | 8,736 | 2,808 | 2,808 |

Proposed Night Setback Optimization

| Current | Proposed |
|--------------------------|--------------------------|
| Heating Therm | Heating Therm |
| 130,680 | 57,408 |
| Cooling Therm | Cooling Therm |
| 130,680 | 57,408 |
| Design Point BTU/hr F | Design Point BTU/hr F |
| 2,814 | 1,435 |
| Total Load BTU/hr F | Total Load BTU/hr F |
| 5,728 | 2,870 |
| Setpoints F DB | Setpoints F DB |
| 72 | 60 |
| Balance Point F DB | Balance Point F DB |
| 55 | 55 |

Savings

| | |
|--------------------------|--------------------------|
| Current | Proposed |
| Heating Therm | Heating Therm |
| 130,680 | 57,408 |
| Cooling Therm | Cooling Therm |
| 130,680 | 57,408 |
| Design Point BTU/hr F | Design Point BTU/hr F |
| 2,814 | 1,435 |
| Total Load BTU/hr F | Total Load BTU/hr F |
| 5,728 | 2,870 |
| Setpoints F DB | Setpoints F DB |
| 72 | 60 |
| Balance Point F DB | Balance Point F DB |
| 55 | 55 |

Total

\$3,997

Current

| Occ. Hours | Status | Heating Load BTU/hr | Cooling Load BTU/hr | Energy Therm |
|------------|--------|------------------------|------------------------|-----------------|
| 0.3 | 0 | 0 | 0 | 0 |
| 10.9 | 0 | 0 | 0 | 0 |
| 10.9 | 0 | 0 | 0 | 0 |
| 117.3 | 0 | 0 | 0 | 0 |
| 230.2 | 0 | 0 | 0 | 0 |
| 257.1 | 0 | 0 | 0 | 0 |
| 243.3 | 0 | 0 | 0 | 0 |
| 261.1 | 0 | 0 | 0 | 0 |
| 241.7 | 0 | 0 | 0 | 0 |
| 252.9 | 0 | 0 | 0 | 0 |
| 201.6 | 0 | 0 | 0 | 0 |
| 201.6 | 0 | 0 | 0 | 0 |
| 291.4 | 0 | 0 | 0 | 0 |
| 252.6 | 0 | 0 | 0 | 0 |
| 103.2 | 0 | 0 | 0 | 0 |
| 71.5 | 0 | 0 | 0 | 0 |
| 39.1 | 0 | 0 | 0 | 0 |
| 16.0 | 0 | 0 | 0 | 0 |
| 1.7 | 0 | 0 | 0 | 0 |
| 0.0 | 0 | 0 | 0 | 0 |
| 2,808 | 12 | 8 | 8 | 8 |

Occupied

| Unocc. Hours | Status | Heating Load BTU/hr | Cooling Load BTU/hr | Energy Therm |
|--------------|--------|------------------------|------------------------|-----------------|
| 0.7 | 0 | 0 | 0 | 0 |
| 23.0 | 0 | 0 | 0 | 0 |
| 23.0 | 0 | 0 | 0 | 0 |
| 347.7 | 0 | 0 | 0 | 0 |
| 485.9 | 0 | 0 | 0 | 0 |
| 542.7 | 0 | 0 | 0 | 0 |
| 513.6 | 0 | 0 | 0 | 0 |
| 561.7 | 0 | 0 | 0 | 0 |
| 510.2 | 0 | 0 | 0 | 0 |
| 533.9 | 0 | 0 | 0 | 0 |
| 485.9 | 0 | 0 | 0 | 0 |
| 615.1 | 0 | 0 | 0 | 0 |
| 533.2 | 0 | 0 | 0 | 0 |
| 217.9 | 0 | 0 | 0 | 0 |
| 150.9 | 0 | 0 | 0 | 0 |
| 82.6 | 0 | 0 | 0 | 0 |
| 33.6 | 0 | 0 | 0 | 0 |
| 13.5 | 0 | 0 | 0 | 0 |
| 3.4 | 0 | 0 | 0 | 0 |
| 5,928 | 12 | 8 | 8 | 8 |

Unoccupied

| Unocc. Hours | Status | Heating Load BTU/hr | Cooling Load BTU/hr | Energy Therm |
|--------------|--------|------------------------|------------------------|-----------------|
| 0.7 | 0 | 0 | 0 | 0 |
| 23.0 | 0 | 0 | 0 | 0 |
| 23.0 | 0 | 0 | 0 | 0 |
| 347.7 | 0 | 0 | 0 | 0 |
| 485.9 | 0 | 0 | 0 | 0 |
| 542.7 | 0 | 0 | 0 | 0 |
| 513.6 | 0 | 0 | 0 | 0 |
| 561.7 | 0 | 0 | 0 | 0 |
| 510.2 | 0 | 0 | 0 | 0 |
| 533.9 | 0 | 0 | 0 | 0 |
| 485.9 | 0 | 0 | 0 | 0 |
| 615.1 | 0 | 0 | 0 | 0 |
| 533.2 | 0 | 0 | 0 | 0 |
| 217.9 | 0 | 0 | 0 | 0 |
| 150.9 | 0 | 0 | 0 | 0 |
| 82.6 | 0 | 0 | 0 | 0 |
| 33.6 | 0 | 0 | 0 | 0 |
| 13.5 | 0 | 0 | 0 | 0 |
| 3.4 | 0 | 0 | 0 | 0 |
| 5,928 | 12 | 8 | 8 | 8 |

Proposed

| Occ. Hours | Status | Heating Load BTU/hr | Cooling Load BTU/hr | Energy Therm |
|------------|--------|------------------------|------------------------|-----------------|
| 0.3 | 0 | 0 | 0 | 0 |
| 10.9 | 0 | 0 | 0 | 0 |
| 10.9 | 0 | 0 | 0 | 0 |
| 117.3 | 0 | 0 | 0 | 0 |
| 230.2 | 0 | 0 | 0 | 0 |
| 257.1 | 0 | 0 | 0 | 0 |
| 243.3 | 0 | 0 | 0 | 0 |
| 261.1 | 0 | 0 | 0 | 0 |
| 241.7 | 0 | 0 | 0 | 0 |
| 252.9 | 0 | 0 | 0 | 0 |
| 201.6 | 0 | 0 | 0 | 0 |
| 201.6 | 0 | 0 | 0 | 0 |
| 291.4 | 0 | 0 | 0 | 0 |
| 252.6 | 0 | 0 | 0 | 0 |
| 103.2 | 0 | 0 | 0 | 0 |
| 71.5 | 0 | 0 | 0 | 0 |
| 39.1 | 0 | 0 | 0 | 0 |
| 16.0 | 0 | 0 | 0 | 0 |
| 1.7 | 0 | 0 | 0 | 0 |
| 0.0 | 0 | 0 | 0 | 0 |
| 2,808 | 12 | 8 | 8 | 8 |

Proposed

| Unocc. Hours | Status | Heating Load BTU/hr | Cooling Load BTU/hr | Energy Therm |
|--------------|--------|------------------------|------------------------|-----------------|
| 0.7 | 0 | 0 | 0 | 0 |
| 23.0 | 0 | 0 | 0 | 0 |
| 23.0 | 0 | 0 | 0 | 0 |
| 347.7 | 0 | 0 | 0 | 0 |
| 485.9 | 0 | 0 | 0 | 0 |
| 542.7 | 0 | 0 | 0 | 0 |
| 513.6 | 0 | 0 | 0 | 0 |
| 561.7 | 0 | 0 | 0 | 0 |
| 510.2 | 0 | 0 | 0 | 0 |
| 533.9 | 0 | 0 | 0 | 0 |
| 485.9 | 0 | 0 | 0 | 0 |
| 615.1 | 0 | 0 | 0 | 0 |
| 533.2 | 0 | 0 | 0 | 0 |
| 217.9 | 0 | 0 | 0 | 0 |
| 150.9 | 0 | 0 | 0 | 0 |
| 82.6 | 0 | 0 | 0 | 0 |
| 33.6 | 0 | 0 | 0 | 0 |
| 13.5 | 0 | 0 | 0 | 0 |
| 3.4 | 0 | 0 | 0 | 0 |
| 5,928 | 12 | 8 | 8 | 8 |

North Bergen Housing Authority
CHA #20241
Building: Lawler Towers Apartments

ECM-8 Night Setback Controls

Suggestions

Program the existing programable thermostats in the Community Room and the NBHA Offices for night set back temperatures for heating and cooling.

Clean the air cooled condensers for the Office and Community Room air conditioning equipment.

| Multipliers * | |
|---------------|------|
| Material: | 1.00 |
| **Labor: | 1.44 |
| Equipment: | 1.00 |

| Description | QTY | UNIT | UNIT COSTS | | | SUBTOTAL COSTS | | | TOTAL COST | REMARKS |
|---|-----|------|------------|-------|---------|----------------|--------|--------|------------|---------|
| | | | MAT. | LABOR | EQUIP. | MAT. | LABOR | EQUIP. | | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| Program the existing AC unit programmable thermostats for night setback conditions. | 10 | ea. | | \$ 20 | | \$ - | \$ 288 | \$ - | \$ 288 | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| Clean the remote air cooled condensers for the Office and Community Rm. AC Units. | 10 | ea. | | \$ 40 | \$ 1.00 | \$ - | \$ 576 | \$ 10 | \$ 586 | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |

| | |
|-----------------|--------------------|
| \$ 874 | Subtotal |
| \$ 87 | 10% Contingency |
| \$ 144 | 15% Contractor O&P |
| \$ - | 0% Engineering |
| \$ 1,106 | Total |

*Multipliers per RS Means Mechanical Cost Data for Newark, New Jersey

**Multiplier for Electrical and Controls Labor specific to the Newark, New Jersey area.

APPENDIX O

ECM-9 Boiler Replacement

YOUR SUMMARY

This report addresses the key recommendations for improving the comfort, safety and efficiency of your home. You should use it as a guide for deciding what work you want to have done. Remember, your Home Performance Contractor is ready to complete these projects promptly, and the work is guaranteed.



Selected Packages



| Measure Description | Non-energy benefits | Package1 | Package2 | Package3 |
|--|---------------------|-----------|----------|----------|
| Boiler Upgrade: Install new natural gas 9,734,000 Btu/hr boiler with efficiency of 72.0 %. | Increased equity. | \$ 0 | | |
| Total Installed Cost | | \$ 0 | | |
| Annual Energy Cost Savings | | \$ 18,440 | | |
| Annual KWh Savings, KWh | | 0 | | |
| Total Energy Savings, MMBtu | | 1,661.3 | | |
| Simple annual payback, years | | NA | | |
| Savings to Investment Ratio | | NA | | |

The following fuel prices were used to estimate annual energy cost savings, payback and savings to investment ratio:

- Natural gas: 1.1100 \$/Therm
- Electricity: 0.1500 \$/kWh

Base Load Report

Customer Information

Customer Name: NBHA

Address: 6121/3131 Grand Avenue
North Bergen, NJ 07047

Billing Period: None

Auditor Information

Technician Name:

Company:

Phone Number:

Date: 8/17/2009

Model to Actual Comparison of Base Usage Per Year

Model Name: Boiler Burner Upgrade

Billing Period Name: None

| | Electricity | | Natural gas | | | |
|--------------|-------------|---------|-------------|--------|--|--|
| | kWh | \$ | Therm | \$ | | |
| Model | 1,484,677 | 222,702 | 24,076 | 26,724 | | |
| Billing | | | | | | |
| % Difference | | | | | | |

Note: No billing data is available because the model was not compared to a billing period


Annual Use of Domestic Hot Water, Appliances, and Lighting

Model Name: Boiler Burner Upgrade

| | Electricity \$0.15 per kWh | | Natural gas \$1.11 per Therm | | | | Total |
|--|-------------------------------|----------------|---------------------------------|---------------|--|--|----------------|
| | kWh | \$ | therms | \$ | | | \$ |
| 1. Domestic Hot Water | 0 | 0 | 23,161 | 25,709 | | | 25,709 |
| 2. Heating Community Rm & Offices | 130,680 | 19,602 | 0 | 0 | | | 19,602 |
| 3. Range, electric | 120,400 | 18,060 | 0 | 0 | | | 18,060 |
| 4. Oven, electric | 120,400 | 18,060 | 0 | 0 | | | 18,060 |
| 5. typical Other Heated Area lighting | 118,610 | 17,792 | 0 | 0 | | | 17,792 |
| 6. typical Other Heated Area lighting | 117,822 | 17,673 | 0 | 0 | | | 17,673 |
| 7. Refrigerator-auto def top freezer, 1990 | 88,400 | 13,260 | 0 | 0 | | | 13,260 |
| 8. Refrigerator-auto def top freezer, 1990 | 88,400 | 13,260 | 0 | 0 | | | 13,260 |
| 9. Cooling Community Rm & B-Offices | 57,408 | 8,611 | 0 | 0 | | | 8,611 |
| 10. Other | 609,883 | 91,482 | 915 | 1,016 | | | 92,498 |
| TOTAL | 1,452,003 | 217,800 | 24,076 | 26,725 | | | 244,525 |

Base Load Energy Users, \$/year

Model Name: Boiler Burner Upgrade





MODEL ENERGY REPORT FOR BOILER BURNER UPGRADE

NBHA Lawlwer Apts

For: NBHA

By:

Date: 8/17/2009



Note: Due to rounding, the sum of percentages may not be equal to 100.

DESIGN HEATING AND COOLING LOADS FOR BOILER BURNER UPGRADE

8/17/2009

Project Name: NBHA Lawlwer Apts

For: NBHA

By:

Date:

Primary Heating System:

| Space Name | Load, Btu/Hr | Load, per SF Btu/(Hr-SqFt) | Distribution | |
|-------------------------|--------------|-------------------------------|--------------|--------------------|
| | | | GPM | Ft of baseboard |
| Gr Fl Common Tower A | 166444 | 27 | 18.9 | 319 |
| 2nd Fl Apts Tower B | 102364 | 19 | 11.6 | 196 |
| 3rd Fl Apts Tower B | 105945 | 20 | 12.0 | 203 |
| 2nd Fl Common Tower B | 0 | 0 | 0.0 | 0 |
| Community Room | 205047 | 65 | 23.3 | 393 |
| Mechanical Spaces T-A | 396754 | 64 | 45.1 | 760 |
| 1st Fl Common Tower A | 31227 | 13 | 3.5 | 60 |
| 1st- Apts Tower A | 93445 | 26 | 10.6 | 179 |
| Gr Fl Office B Tower | 403732 | 52 | 45.9 | 773 |
| Basement Tower B | 19203 | 25 | 2.2 | 37 |
| 1st Fl Common Tower B | 0 | 0 | 0.0 | 0 |
| 1st Fl Apts Tower B | 88223 | 24 | 10.0 | 169 |
| 3rd Fl Common | 0 | 0 | 0.0 | 0 |
| 4th-13th Apts Tower B | 1280775 | 27 | 145.6 | 2451 |
| 4th-13th Common Tower B | 0 | 0 | 0.0 | 0 |
| 2nd Fl Apts Tower A | 116662 | 22 | 13.3 | 224 |
| 2nd Fl Common Tower A | 0 | 0 | 0.0 | 0 |
| 3rd Fl Apts Tower A | 119730 | 23 | 13.6 | 230 |
| 3rd Fl Common Tower A | 0 | 0 | 0.0 | 0 |
| 4th-13th Apts Tower A | 1442561 | 30 | 164.0 | 2760 |
| 4th-13th Common Tower A | 0 | 0 | 0.0 | 0 |

Required Heating Equipment Output Capacity: 5383271 Btu/hr

Available Heating Equipment Output Capacity: 7008480 Btu/hr

Total flow: 538.5 GPM

Baseboard Capacity: 575 Btu/Hr-Ft

Heating Equipment Efficiency: 72 %

Calculated Distribution Efficiency: 93 %

Supply Water Temperature: 220 F

Temperature Drop: 20 F

Heating Safety Factor: 1.10

Distribution Safety Factor: 1.10

Cooling System:

| Space Name | Load, Btu/Hr | Distribution CFM |
|-------------------------|--------------|---------------------|
| Gr FI Common Tower A | 110762 | 4030 |
| 2nd FI Apts Tower B | 70500 | 2565 |
| 3rd FI Apts Tower B | 66013 | 2402 |
| 2nd FI Commom Tower B | 0 | 0 |
| Community Room | 87420 | 3180 |
| Mechanical Spaces T-A | 0 | 0 |
| 1st FI Common Tower A | 64367 | 2342 |
| 1st- Apts Tower A | 57465 | 2091 |
| Gr FI Office B Tower | 219345 | 7979 |
| Basement Tower B | 6271 | 229 |
| 1st FI Common Tower B | 130099 | 4733 |
| 1st FI Apts Tower B | 57589 | 2095 |
| 3rd FI Commom | 0 | 0 |
| 4th-13th Apts Tower B | 822976 | 29937 |
| 4th-13th Common Tower B | 0 | 0 |
| 2nd FI Apts Tower A | 51676 | 1880 |
| 2nd FI Common Tower A | 0 | 0 |
| 3rd FI Apts Tower A | 67962 | 2473 |
| 3rd FI Common Tower A | 0 | 0 |
| 4th-13th Apts Tower A | 661186 | 24052 |
| 4th-13th Common Tower A | 0 | 0 |

Required Cooling Equipment Output Capacity: 2672598 Btu/hr

Available Cooling Equipment Output Capacity: 290000 Btu/hr

Total flow: 88380 CFM

Cooling Equipment Efficiency: 9 SEER

Calculated Distribution Efficiency: 95%

Temperature Drop: 28 F

Cooling Safety Factor: 1.10

Distribution Safety Factor: 1.10

COOLING SYSTEM IS UNDERSIZED AND DOES NOT MEET THE REQUIRED COOLING LOAD.

Notes:

1. The room heating/cooling loads do not include the equipment and distribution safety factor and distribution losses
2. The room distribution includes distribution safety factor.
3. The load on the room is the peak load for this room in a year.
4. Available equipment output capacity includes equipment efficiency.
5. Required equipment output capacity includes diversity, distribution losses and equipment safety factor.
6. Overall distribution CFM/GPM for heating/cooling includes equipment safety factor, distribution losses and diversity.

DETAILED PACKAGE DESCRIPTION AND WORKSCOPE FOR Boiler Burner Upgrade

NBHA Lawlwer Apts

For: NBHA

By:

Date:8/17/2009

Improvement Information:

1. Boiler Upgrade

New Heating Plant Installation

| | |
|------------------------|---------------|
| Heat Plant Type | Boiler, Steam |
| Fuel | Natural gas |
| Input Capacity, Btu/Hr | 9734000 |
| Efficiency% | 72 |

Non-Energy Benefits: Increased equity.

Work Scope:

Comply with general conditions. Submit product information to owner for approval in writing prior to ordering. Remove existing heating system safely and completely. Patch and paint where existing equipment was removed to match existing surfaces. If existing heat was baseboard electric and included receptacles mounted on the heaters, install new receptacles to replace the ones removed. Perform complete load sizing of the building prior to selecting replacement equipment, using standard methods such as ACCA manual J, or ASHRAE. Size new equipment according to this load sizing, and not according to the size of removed equipment. Provide a written copy of load sizing and assumptions for approval by the owner prior to ordering equipment. Size distribution system according to standard methods. Install forced air system securely and level. Install locking balancing dampers. For combustion systems, install combustion air in compliance with NFPA 54. All gas piping shall be tested with a sniffer. All buried gas piping shall be pressure tested for 24 hours. Securely fasten heating system to duct work with mechanical fasteners and seal. Install a clean air filter. Make sure that there are no duct openings, filter openings, or furnace openings in the return air in the furnace room, as this will pose a risk of carbon monoxide poisoning. Duct sealing and insulation shall comply with standards described in the separate duct sealing and duct insulation work scopes. After installation is complete, measure and record air temperature rise, gas input at the gas meter, and gas pressure at the gas valve. Ensure that all of these measurements are within the manufacturer's requirements. Balance distribution system by measuring air supply to all grilles and adjusting manual balancing dampers. Measure and record combustion efficiency. Set anticipator at thermostat. Provide training to the owner in the use of the forced air system and thermostat. Deliver to the owner users manual, including measurement reports, warranties, and approved submittals.

PREMIER COMMERCIAL BOILERS

Sample



MODEL CFH
 **CLEARFIRE**

HORIZONTAL STEAM BOILER 10-60 HP
Full Modulation • High efficiency • Low Emissions • Touch Screen Control

ClearFire-H The New Standard in Commercial High-Efficiency Firetube Boilers

ClearFire-H

Features and Benefits

The Cleaver-Brooks compact gas-fired ClearFire-H horizontal boiler is designed specifically for the requirements of the commercial market and is available in sizes ranging 10-60 horsepower for 15# or 150# psig steam pressure.


- Fully-modulating with high turndown via variable speed blower maximizing fuel savings
- High efficiencies up to 85%, reduces greenhouse gas emissions
- Easily-tuned, zero-governor, premix Burner
- More reliable operation with no dampers or linkages
- Advanced combustion design eliminates need for flue gas recirculation while providing low emissions (< 20 ppm NO_x and < 10 ppm CO)
- Direct spark Ignition
- Low gas supply pressure < 14" W.C.
- Quiet operation < 70 DBA
- Single Phase Power - 115V for minimal electrical energy consumption
- UL Listed (Natural Gas)
- Controls are CSD-1 Compliant
- 15# & 150# designs deliver superior steam quality
- ModBus (RS 485) Communications

ClearFire-H Options

- Sealed combustion for reduced make-up air requirement thus reducing energy costs
- Surface Blow-Off Controls
- Chemical Feed Tank
- Integral Feedwater System
- High Pressure Regulator
- Blowdown & Feedwater Valve Assemblies
- Reuseable Air Filter
- Feedwater Economizer

Advanced Burner Technology


The ClearFire-H's high efficiency is achieved by employing an advanced Fecralloy burner designed to premix air and fuel for optimal combustion and low emissions. A variable speed blower motor provides extended burner turndown capability.



Durable Fecralloy Burner

Patented Heat Transfer Technology®

The internationally patented AluFer® firetube is the latest Cleaver-Brooks innovation in advanced heat transfer technology.



Patented AluFer Tubes®

The ClearFire-H utilizes AluFer® firetubes to achieve unmatched heat transfer rates and superior fuel-to-steam efficiency of up to 85% depending upon operating pressure, all in a compact design.

The tube is constructed from an inner aluminum alloy finned surface, die fitted within an outer carbon steel tube providing exceptional heat exchange characteristics that are attributed to the following factors:

- Thermal conductivity of the AluFer® insert is significantly greater than that of carbon steel.
- Internal finned surface of the AluFer® tube enlarges the heat exchange surface area threefold.
- Inner surface of the tube is divided into ten flow channels to create maximum turbulence and heat transfer.

C-B Falcon Control


The C-B Falcon is a total boiler control that provides our customers with the integrated functionality needed to efficiently and economically operate their boiler system, while providing necessary safety and reliability.

- A single source solution for total Boiler control
- Touch screen graphics with trending
- Integrated Burner sequencing, alarming and lockout
- Date/time stamping of lockouts and alerts
- First out expanded annunciation, firing rate limiting, time of day (setback) and PID loops.
- ModBus (RS485) Communications
- UL Recognized



User-friendly Touch Screen Graphics


The ClearFire- H Advantage




Single Source Skid Package Solutions

Looking for a turn-key steam solution? Cleaver-Brooks offers standard and complete steam boiler system skid mounted packages in gas and propane fuels. The package includes the steam boiler, feed system and blowdown separator with optional chemical feed system and water softener. This complete package saves you time installing the system as all is required is power, gas, steam and water connections.

- *Single Source Responsibility*
- *Plug and Play, minimizes installation*
- *Standard Skid Solutions to meet your needs*





ClearFire-H Boiler Dimensions and Ratings

| Boiler Horsepower | 10 | 15 | 20 | 25 | 30 | 40 | 50 | 60 |
|---|-------|-------|-------|-------|-------|-------|-------|-------|
| Dimensions – inches | | | | | | | | |
| Overall Length (A) | 86 | 86 | 87 | 87 | 92 | 104 | 110 | 110 |
| Overall Width (B) | 44 | 44 | 47 | 47 | 55.5 | 55.5 | 60.5 | 60.5 |
| Width (BB) minus water column and blowdown | 38 | 38 | 41.5 | 41.5 | 49 | 49 | 55 | 55 |
| Overall Height (C) | 54 | 54 | 57 | 57 | 66 | 66 | 68 | 68 |
| Connections - inches | | | | | | | | |
| Stack Nominal OD (D) | 6 | 6 | 6 | 6 | 8 | 8 | 10 | 10 |
| Gas Connection (E) | 1 | 1 | 1 | 1 | 1 1/4 | 1 1/4 | 1 1/2 | 1 1/2 |
| Feed Water (F) | 1 | 1 | 1 | 1 | 1 | 1 | 1 1/4 | 1 1/4 |
| Bottom Blowdown (G) | 1 | 1 | 1 | 1 | 1 | 1 | 1 1/4 | 1 1/4 |
| Steam Outlet (H) 15# ST. | 4 | 4 | 4 | 4 | 4 | 6 | 6 | 6 |
| Steam Outlet (H) 150# ST. | 1 1/2 | 1 1/2 | 1 1/2 | 1 1/2 | 2 | 2 | 3 | 3 |
| Surface Blowoff (I) | 1 1/4 | 1 1/4 | 1 1/4 | 1 1/4 | 1 1/4 | 1 1/4 | 1 1/4 | 1 1/4 |
| Chemical Feed (J) | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| Overflow (K) | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| Steam Boiler Weights in lbs | | | | | | | | |
| Normal Water Weight - 15# | 920 | 920 | 1,150 | 1,150 | 1,710 | 1,980 | 2,510 | 2,510 |
| Normal Water Weight - 150# | 1,010 | 1,010 | 1,250 | 1,250 | 1,850 | 2,150 | 2,700 | 2,700 |
| Approx. Shipping Weight | 2,450 | 2,450 | 2,750 | 2,750 | 3,400 | 3,700 | 5,200 | 5,200 |
| Power Requirements (115VAC, 60 Hz, single phase) | | | | | | | | |
| Blower Motor Size (Watts)* | 335 | 335 | 335 | 335 | 335 | 750 | 1,200 | 1,200 |
| Ratings | | | | | | | | |
| Rated Capacity–Steam (lbs-steam/hr from 212°F) | 345 | 518 | 690 | 863 | 1,035 | 1,380 | 1,725 | 2,070 |
| Efficiency % | 86.2 | 85.2 | 85.6 | 85.1 | 85.9 | 85.8 | 86.2 | 85.8 |
| Output (1,000 Btu/hr) | 339 | 503 | 674 | 838 | 1,015 | 1,351 | 1,697 | 2,027 |
| Input (1,000 Btu/hr) | 394 | 591 | 788 | 984 | 1,181 | 1,575 | 1,969 | 2,363 |
| Fireside Heating Surface (sq.ft.) | 122 | 122 | 191 | 191 | 310 | 381 | 573 | 573 |
| Turndown/Modulating Firing Range | 4:1 | 4:1 | 4:1 | 4:1 | 5:1 | 5:1 | 5:1 | 5:1 |

Notes:

* For altitudes above 1500 ft., contact local Cleaver-Brooks authorized representative for verification of boiler and blower motor size.

** All Ratings from 0 psig and at 212°



11950 W Lake Park Drive, Milwaukee, WI 53224 USA
+1-414-359-0600 • +1-800-250-5883
info@cleaver-brooks.com • www.cleaver-brooks.com

North Bergen Housing Authority
CHA #20241
Building: Lawler Towers Apartments

ECM - 9 Replacement of Kewanee Boilers with High Efficiency Steam Boilers

Suggestions

Install four (4) new high efficiency steam boilers to replace the existing two Kewanee low pressure steam boilers.

| Multipliers * | |
|---------------|------|
| Material: | 1.00 |
| **Labor: | 1.22 |
| Equipment: | 1.00 |

| Description | QTY | UNIT | UNIT COSTS | | | SUBTOTAL COSTS | | | TOTAL COST | REMARKS |
|--|-----|------|------------|-----------|--------|----------------|-----------|--------|------------|-----------------------------------|
| | | | MAT. | LABOR | EQUIP. | MAT. | LABOR | EQUIP. | | |
| New High Efficiency Steam Boilers | 4 | ea | \$ 32,000 | | | \$ 128,000 | \$ - | \$ - | \$ 128,000 | Vendor quote. |
| Boiler Control System | 1 | ea. | \$ 6,000 | | | \$ 6,000 | \$ - | \$ - | \$ 6,000 | Vendor quote. |
| System Startup | 1 | Lot | | \$ 4,000 | | \$ - | \$ 4,880 | \$ - | \$ 4,880 | Vendor quote. |
| Boiler removal includes disconnecting all piping, electrical and boiler flues and removal from the building. | 2 | | | \$ 5,000 | | \$ - | \$ 12,200 | \$ - | \$ 12,200 | Means Mechanical Cost Data - 2009 |
| Boiler installation includes all piping labor; flue stack material and installation; gas regulators; insulation labor and materials; setting of the boilers. | 2 | Lot | | \$ 25,500 | | \$ - | \$ 62,220 | \$ - | \$ 62,220 | Means Mechanical Cost Data - 2009 |
| Piping materials includes all pipe, valves, hangers, flanges and hardware. | 1 | Lot | \$ 17,000 | | | \$ 17,000 | \$ - | \$ - | \$ 17,000 | Means Mechanical Cost Data - 2009 |
| Electrical labor and materials. | 1 | Lot | \$ 5,000 | \$ 5,000 | | \$ 5,000 | \$ 6,100 | \$ - | \$ 11,100 | Means Mechanical Cost Data - 2009 |

*Multipliers per RS Means Mechanical Cost Data for Newark, New Jersey

**Multiplier for Mechanical Labor specific to the Newark, New Jersey area.


| | |
|-------------------|--------------------|
| \$ 241,400 | Subtotal |
| \$ 24,140 | 10% Contingency |
| \$ 39,831 | 15% Contractor O&P |
| \$ 30,537 | 10% Engineering |
| \$ 335,908 | Total |

APPENDIX P

ECM-10 Window Replacements

YOUR SUMMARY

This report addresses the key recommendations for improving the comfort, safety and efficiency of your home. You should use it as a guide for deciding what work you want to have done. Remember, your Home Performance Contractor is ready to complete these projects promptly, and the work is guaranteed.



Selected Packages

| Measure Description | Non-energy benefits | Package1 | Package2 | Package3 |
|--|--|----------|----------|----------|
| Window Replacement : Install 1823 triple pane clear windows with aluminum with 3/8" thermal break frame. | <ul style="list-style-type: none"> Improve comfort (reduce drafts), increase value of building. | \$ 0 | | |
| Total Installed Cost | | \$ 0 | | |
| Annual Energy Cost Savings | | \$ 5,008 | | |
| Annual KWh Savings, KWh | | 0 | | |
| Total Energy Savings, MMBtu | | 451.1 | | |
| Simple annual payback, years | | NA | | |
| Savings to Investment Ratio | | NA | | |

The following fuel prices were used to estimate annual energy cost savings, payback and savings to investment ratio:

- Natural gas: 1.1100 \$/therm
- Electricity: 0.1500 \$/kWh

DESIGN HEATING AND COOLING LOADS FOR WINDOW REPLACEMENT

9/2/2009

Project Name: NBHA Lawlwer Apts

For: NBHA

By:

Date:

Primary Heating System:

| Space Name | Load, Btu/Hr | Load, per SF Btu/(Hr-SqFt) | Distribution | |
|-------------------------|--------------|-------------------------------|--------------|--------------------|
| | | | GPM | Ft of baseboard |
| Gr FI Common Tower A | 163806 | 27 | 18.6 | 314 |
| 2nd FI Apts Tower B | 99020 | 19 | 11.3 | 190 |
| 3rd FI Apts Tower B | 102601 | 20 | 11.7 | 197 |
| 2nd FI Common Tower B | 0 | 0 | 0.0 | 0 |
| Community Room | 202888 | 64 | 23.1 | 389 |
| Mechanical Spaces T-A | 396603 | 64 | 45.1 | 759 |
| 1st FI Common Tower A | 31227 | 13 | 3.5 | 60 |
| 1st- Apts Tower A | 90101 | 25 | 10.2 | 173 |
| Gr FI Office B Tower | 401269 | 52 | 45.6 | 768 |
| Basement Tower B | 19203 | 25 | 2.2 | 37 |
| 1st FI Common Tower B | 0 | 0 | 0.0 | 0 |
| 1st FI Apts Tower B | 84878 | 23 | 9.6 | 163 |
| 3rd FI Common | 0 | 0 | 0.0 | 0 |
| 4th-13th Apts Tower B | 1240711 | 26 | 141.0 | 2374 |
| 4th-13th Common Tower B | 0 | 0 | 0.0 | 0 |
| 2nd FI Apts Tower A | 113319 | 21 | 12.9 | 217 |
| 2nd FI Common Tower A | 0 | 0 | 0.0 | 0 |
| 3rd FI Apts Tower A | 116386 | 22 | 13.2 | 223 |
| 3rd FI Common Tower A | 0 | 0 | 0.0 | 0 |
| 4th-13th Apts Tower A | 1402501 | 29 | 159.4 | 2684 |
| 4th-13th Common Tower A | 0 | 0 | 0.0 | 0 |

Required Heating Equipment Output Capacity: 5296346 Btu/hr
Available Heating Equipment Output Capacity: 6327100 Btu/hr
Total flow: 529.8 GPM
Baseboard Capacity: 575 Btu/Hr-Ft
Heating Equipment Efficiency: 65 %
Calculated Distribution Efficiency: 93 %
Supply Water Temperature: 220 F
Temperature Drop: 20 F
Heating Safety Factor: 1.10
Distribution Safety Factor: 1.10

Cooling System:

| Space Name | Load, Btu/Hr | Distribution CFM |
|-------------------------|--------------|---------------------|
| Gr Fl Common Tower A | 109696 | 3991 |
| 2nd Fl Apts Tower B | 69525 | 2529 |
| 3rd Fl Apts Tower B | 65492 | 2383 |
| 2nd Fl Common Tower B | 0 | 0 |
| Community Room | 87363 | 3178 |
| Mechanical Spaces T-A | 0 | 0 |
| 1st Fl Common Tower A | 64367 | 2342 |
| 1st- Apts Tower A | 56674 | 2062 |
| Gr Fl Office B Tower | 218961 | 7965 |
| Basement Tower B | 6271 | 229 |
| 1st Fl Common Tower B | 130099 | 4733 |
| 1st Fl Apts Tower B | 56796 | 2068 |
| 3rd Fl Common | 0 | 0 |
| 4th-13th Apts Tower B | 813704 | 29600 |
| 4th-13th Common Tower B | 0 | 0 |
| 2nd Fl Apts Tower A | 50983 | 1855 |
| 2nd Fl Common Tower A | 0 | 0 |
| 3rd Fl Apts Tower A | 67169 | 2444 |
| 3rd Fl Common Tower A | 0 | 0 |
| 4th-13th Apts Tower A | 651914 | 23714 |
| 4th-13th Common Tower A | 0 | 0 |

Required Cooling Equipment Output Capacity: 2643704 Btu/hr

Available Cooling Equipment Output Capacity: 290000 Btu/hr

Total flow: 87424 CFM

Cooling Equipment Efficiency: 9 SEER

Calculated Distribution Efficiency: 95%

Temperature Drop: 28 F

Cooling Safety Factor: 1.10

Distribution Safety Factor: 1.10

COOLING SYSTEM IS UNDERSIZED AND DOES NOT MEET THE REQUIRED COOLING LOAD.

Notes:

1. The room heating/cooling loads do not include the equipment and distribution safety factor and distribution losses
2. The room distribution includes distribution safety factor.
3. The load on the room is the peak load for this room in a year.
4. Available equipment output capacity includes equipment efficiency.
5. Required equipment output capacity includes diversity, distribution losses and equipment safety factor.
6. Overall distribution CFM/GPM for heating/cooling includes equipment safety factor, distribution losses and diversity.

MODEL ENERGY REPORT FOR WINDOW REPLACEMENT


NBHA Lawlwer Apts

For: NBHA


By:

Date: 9/2/2009

Total Annual Energy Bill by Category



Annual Heating/Cooling Bill by Category



Note: Due to rounding, the sum of percentages may not be equal to 100.

Base Load Report

Customer Information

Customer Name: NBHA

Address: 6121/3131 Grand Avenue
North Bergen, NJ 07047

Billing Period: None

Auditor Information

Technician Name:

Company:

Phone Number:

Date: 9/2/2009

Model to Actual Comparison of Base Usage Per Year

Model Name: Window Replacement

Billing Period Name: None

| | Electricity | | Natural gas | | | |
|--------------|-------------|---------|-------------|--------|--|--|
| | kWh | \$ | Therm | \$ | | |
| Model | 1,484,677 | 222,702 | 24,076 | 26,724 | | |
| Billing | | | | | | |
| % Difference | | | | | | |

Note: No billing data is available because the model was not compared to a billing period


Annual Use of Domestic Hot Water, Appliances, and Lighting

Model Name: Window Replacement

| | Electricity \$0.15 per kWh | | Natural gas \$1.11 per Therm | | Total | |
|--|-------------------------------|----------------|---------------------------------|---------------|-------|----------------|
| | kWh | \$ | therms | \$ | | \$ |
| 1. Domestic Hot Water | 0 | 0 | 23,161 | 25,709 | | 25,709 |
| 2. Heating Community Rm & Offices | 130,680 | 19,602 | 0 | 0 | | 19,602 |
| 3. Range, electric | 120,400 | 18,060 | 0 | 0 | | 18,060 |
| 4. Oven, electric | 120,400 | 18,060 | 0 | 0 | | 18,060 |
| 5. typical Other Heated Area lighting | 118,610 | 17,792 | 0 | 0 | | 17,792 |
| 6. typical Other Heated Area lighting | 117,322 | 17,673 | 0 | 0 | | 17,673 |
| 7. Refrigerator auto def top freezer, 1990 | 88,400 | 13,260 | 0 | 0 | | 13,260 |
| 8. Refrigerator auto def top freezer, 1990 | 88,400 | 13,260 | 0 | 0 | | 13,260 |
| 9. Cooling Community Rm & B-Offices | 57,408 | 8,611 | 0 | 0 | | 8,611 |
| 10. Other | 609,883 | 91,482 | 915 | 1,016 | | 92,498 |
| TOTAL | 1,452,003 | 217,800 | 24,076 | 26,725 | | 244,525 |

Base Load Energy Users, \$/year

Model Name: Window Replacement



IMPROVEMENT PACKAGES

NBHA Lawlwer Apts

For: NBHA

By:

Date: 9/2/2009

Evaluated Packages:

| Package Name | Cost \$ | Annual Savings, MMBtu | Annual Savings, \$ | Payback years | Cashflow \$/year | SIR |
|--------------------|------------|-----------------------------|-----------------------|------------------|---------------------|-----|
| Window Replacement | 0 | 451.14 | 5,008 | 0 | 5,008 | N/C |

Package Description:

1. Window Replacement

| Improvement Name | Cost (\$) | Annual Savings MMBtu | Annual Savings (\$) | Payback (years) | Cashflow (\$/year) | Improve- ment Life (Years) | SIR in Package |
|--------------------------|--------------|----------------------------|---------------------------|--------------------|-----------------------|----------------------------------|----------------------|
| Window Replacement | 0 | 451.14 | 5,008 | N/A | 5,008 | 20 | N/C |
| Total for Package | 0 | 451.14 | 5,008 | 0 | 5,008 | N/A | N/C |

Non-Energy Benefits:

1. Window Replacement : Improve comfort (reduce drafts), increase value of building.

DETAILED PACKAGE DESCRIPTION AND WORKSCOPE FOR Window Replacement

NBHA Lawlwer Apts

For: NBHA

By:

Date: 9/2/2009

Improvement Information:

1. Window Replacement

Window Replacement

| |
|---|
| Upgrade 1823 existing windows to the following: |
| Frame: Aluminum with 3/8" thermal break, Operable |
| Glazing: 7/8" triple glass, 0.25" argon spaces, $\epsilon = 0.2$ on surface 2, 3, 4 or 5, clear |

Non-Energy Benefits: Improve comfort (reduce drafts), increase value of building.

Work Scope:

Perform infrared scan if indoor/outdoor temperature difference is a minimum 15 F, prior to replacement. Perform blower door test prior to replacement. Record results and date of test. Notify owner if asbestos-containing materials are found. Comply with general conditions. Submit product information to owner for approval in writing prior to ordering. Inspect for the presence of lead paint. If lead paint is suspected, notify owner and proceed with owner's approval in compliance with state and local solid waste regulations, to remove windows and doors. Dispose of removed windows off site, or as instructed by owner. Provide temporary covering over window openings to protect the building from the outdoor weather before new windows are installed. Install windows in a workmanlike manner. Windows shall be installed per manufacturer's instructions and to meet the requirements of generally accepted standards. Install windows plumb and level. Test windows for smooth operation after installation, in the presence of owner. Install full weather-stripping. Weather-stripping shall not prevent smooth operation of windows. Caulk both interior and exterior frames of windows. After work is complete, if indoor/outdoor temperature difference is minimum 15 F, perform infrared scan. Provide written reports to the owner, including: approved submittals, written record of which windows were replaced, pre and post blower door tests results, pre and post infrared scan results, warranty.

RECOMMENDED IMPROVEMENTS



Customer: NBHA

This report addresses the key recommendations for improving the comfort, safety and efficiency of your home.

**Annual Cost Savings by Improvement
in Recommended Packages**

| Improvement Description | Non-energy benefits | Improvement Cost | Window Replacement | NA | NA |
|--|--|------------------|--------------------|----|----|
| Window Replacement : Install 1825 triple pane clear windows with aluminum with 3/8" thermal break frame. | ☉ Improve comfort (reduce drafts), increase value of building. | ➔ \$ 0 | \$ 5,008/yr | | |
| Total Annual Energy Cost Savings | | | \$ 5,008/yr | | |
| Total Installed Cost | | | \$ 0 | | |
| Monthly Loan Payment at 8.00%, 30-year Term | | | \$ 0 | | |
| Estimated Monthly Cash Flow After Energy Savings | | | \$ 417.30 | | |
| Simple Annual Payback, Years | | | NA | | |
| Savings to Investment Ratio | | | NA | | |

The following fuel prices were used to estimate annual energy cost savings, payback and savings to investment ratio:

- ☉ Natural gas: 1.1100 \$/Therm
- ☉ Electricity: 0.1500 \$/kWh

North Bergen Housing Authority
CHA #20241
Building: Lawler Towers Apartments

ECM - 10 Replace Windows

Suggestions

Replace exiting 4.5' x 4.5' aluminum slider windows with new High "E" triple pane windows.

| Multipliers * | |
|---------------|------|
| Material: | 1.00 |
| **Labor: | 1.22 |
| Equipment: | 1.00 |

| Description | QTY | UNIT | UNIT COSTS | | | SUBTOTAL COSTS | | | TOTAL COST | REMARKS |
|--|-------|------|------------|-------|--------|----------------|------------|------------|------------|---------------------------------|
| | | | MAT. | LABOR | EQUIP. | MAT. | LABOR | EQUIP. | | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| 4.5' x 4.5' aluminum slider window, installed. | 1,823 | ea. | | | \$ 450 | \$ - | \$ - | \$ 820,350 | \$ 820,350 | Means Building Cost Data - 2009 |
| Remove old windows. | 1,823 | ea. | | \$ 50 | | \$ - | \$ 111,203 | \$ - | \$ 111,203 | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |

| | |
|---------------------|--------------------|
| \$ 931,553 | Subtotal |
| \$ 93,155 | 10% Contingency |
| \$ 153,706 | 15% Contractor O&P |
| \$ - | 0% Engineering |
| \$ 1,178,415 | Total |

*Multipliers per RS Means Mechanical Cost Data for Newark, New Jersey

**Multiplier for Carpentry Labor specific to the Newark, New Jersey area.

APPENDIX Q

ECM-11a Insulate NBHA Office Walls

YOUR SUMMARY

This report addresses the key recommendations for improving the comfort, safety and efficiency of your home. You should use it as a guide for deciding what work you want to have done. Remember, your Home Performance Contractor is ready to complete these projects promptly, and the work is guaranteed.



Selected Packages

| Measure Description | Non-energy benefits | Package1 | Package2 | Package3 |
|---|--|----------|----------|----------|
| ● Wall Insulation Office Addition Tower B : Upgrade 1,940 square feet of existing wall to Gyp Bd, 2x4 16" OC, 2" Fiberglass, 1.5" Air, 1" Wood, R-9 | ● Improve comfort, increase value of building. | \$ 0 | | |
| Total Installed Cost | | \$ 0 | | |
| Annual Energy Cost Savings | | \$ 2,396 | | |
| Annual KWh Savings, KWh | | 0 | | |
| Total Energy Savings, MMBtu | | 215.8 | | |
| Simple annual payback, years | | NA | | |
| Savings to Investment Ratio | | NA | | |

The following fuel prices were used to estimate annual energy cost savings, payback and savings to investment ratio:

- Natural gas: 1.1100 \$/Therm
- Electricity: 0.1500 \$/kWh

Base Load Report

Customer Information

Customer Name: NBHA

Address: 6121/3131 Grand Avenue
North Bergen, NJ 07047

Billing Period: None

Auditor Information

Technician Name:

Company:

Phone Number:

Date: 8/17/2009

Model to Actual Comparison of Base Usage Per Year

Model Name: Insulation Office Addition Walls

Billing Period Name: None

| | Electricity | | Natural gas | | | |
|--------------|-------------|---------|-------------|--------|--|--|
| | kWh | \$ | Therm | \$ | | |
| Model | 1,484,677 | 222,702 | 24,076 | 26,724 | | |
| Billing | | | | | | |
| % Difference | | | | | | |

Note: No billing data is available because the model was not compared to a billing period


Annual Use of Domestic Hot Water, Appliances, and Lighting

Model Name: Insulation Office Addition Walls

| | Electricity \$0.15 per kWh | | Natural gas \$1.11 per Therm | | Total | |
|--|-------------------------------|----------------|---------------------------------|---------------|-------|----------------|
| | kWh | \$ | therms | \$ | | \$ |
| 1. Domestic Hot Water | 0 | 0 | 23,161 | 25,709 | | 25,709 |
| 2. Heating Community Rm & Offices | 130,680 | 19,602 | 0 | 0 | | 19,602 |
| 3. Range, electric | 120,400 | 18,060 | 0 | 0 | | 18,060 |
| 4. Oven, electric | 120,400 | 18,060 | 0 | 0 | | 18,060 |
| 5. typical Other Heated Area lighting | 118,610 | 17,792 | 0 | 0 | | 17,792 |
| 6. typical Other Heated Area lighting | 117,822 | 17,673 | 0 | 0 | | 17,673 |
| 7. Refrigerator-auto def top freezer, 1990 | 88,400 | 13,260 | 0 | 0 | | 13,260 |
| 8. Refrigerator-auto def top freezer, 1990 | 88,400 | 13,260 | 0 | 0 | | 13,260 |
| 9. Cooling Community Rm & B-Offices | 57,408 | 8,611 | 0 | 0 | | 8,611 |
| 10. Other | 609,883 | 91,482 | 915 | 1,016 | | 92,498 |
| TOTAL | 1,452,003 | 217,800 | 24,076 | 26,725 | | 244,525 |

Base Load Energy Users, \$/year

Model Name: Insulation Office Addition Walls





MODEL ENERGY REPORT FOR INSULATION OFFICE ADDITION WALLS

NBHA Lawlwer Apts

For: NBHA

By:

Date: 8/17/2009



Note: Due to rounding, the sum of percentages may not be equal to 100.

DESIGN HEATING AND COOLING LOADS FOR INSULATION OFFICE ADDITION WALLS

8/17/2009

Project Name: NBHA Lawlwer Apts

For: NBHA

By:

Date:

Primary Heating System:

| Space Name | Load, Btu/Hr | Load, per SF Btu/(Hr-SqFt) | Distribution | |
|-------------------------|--------------|-------------------------------|--------------|--------------------|
| | | | GPM | Ft of baseboard |
| Gr FI Common Tower A | 166444 | 27 | 18.9 | 319 |
| 2nd FI Apts Tower B | 102364 | 19 | 11.6 | 196 |
| 3rd FI Apts Tower B | 105945 | 20 | 12.0 | 203 |
| 2nd FI Commom Tower B | 0 | 0 | 0.0 | 0 |
| Community Room | 205047 | 65 | 23.3 | 393 |
| Mechanical Spaces T-A | 396754 | 64 | 45.1 | 760 |
| 1st FI Common Tower A | 31227 | 13 | 3.5 | 60 |
| 1st- Apts Tower A | 93445 | 26 | 10.6 | 179 |
| Gr FI Office B Tower | 348484 | 45 | 39.6 | 667 |
| Basement Tower B | 19203 | 25 | 2.2 | 37 |
| 1st FI Common Tower B | 0 | 0 | 0.0 | 0 |
| 1st FI Apts Tower B | 88223 | 24 | 10.0 | 169 |
| 3rd FI Commom | 0 | 0 | 0.0 | 0 |
| 4th-13th Apts Tower B | 1280775 | 27 | 145.6 | 2451 |
| 4th-13th Common Tower B | 0 | 0 | 0.0 | 0 |
| 2nd FI Apts Tower A | 116662 | 22 | 13.3 | 224 |
| 2nd FI Common Tower A | 0 | 0 | 0.0 | 0 |
| 3rd FI Apts Tower A | 119730 | 23 | 13.6 | 230 |
| 3rd FI Common Tower A | 0 | 0 | 0.0 | 0 |
| 4th-13th Apts Tower A | 1442561 | 30 | 164.0 | 2760 |
| 4th-13th Common Tower A | 0 | 0 | 0.0 | 0 |

Required Heating Equipment Output Capacity: 5359113 Btu/hr

Available Heating Equipment Output Capacity: 6327100 Btu/hr

Total flow: 536.1 GPM

Baseboard Capacity: 575 Btu/Hr-Ft

Heating Equipment Efficiency: 65 %

Calculated Distribution Efficiency: 93 %

Supply Water Temperature: 220 F

Temperature Drop: 20 F

Heating Safety Factor: 1.10

Distribution Safety Factor: 1.10

Cooling System:

| Space Name | Load, Btu/Hr | Distribution CFM |
|-------------------------|--------------|------------------|
| Gr FI Common Tower A | 110762 | 4030 |
| 2nd FI Apts Tower B | 70500 | 2565 |
| 3rd FI Apts Tower B | 66013 | 2402 |
| 2nd FI Commom Tower B | 0 | 0 |
| Community Room | 87417 | 3180 |
| Mechanical Spaces T-A | 0 | 0 |
| 1st FI Common Tower A | 64367 | 2342 |
| 1st- Apts Tower A | 57465 | 2091 |
| Gr FI Office B Tower | 200598 | 7297 |
| Basement Tower B | 6271 | 229 |
| 1st FI Common Tower B | 130099 | 4733 |
| 1st FI Apts Tower B | 57589 | 2095 |
| 3rd FI Commom | 0 | 0 |
| 4th-13th Apts Tower B | 822976 | 29937 |
| 4th-13th Common Tower B | 0 | 0 |
| 2nd FI Apts Tower A | 51676 | 1880 |
| 2nd FI Common Tower A | 0 | 0 |
| 3rd FI Apts Tower A | 67962 | 2473 |
| 3rd FI Common Tower A | 0 | 0 |
| 4th-13th Apts Tower A | 661186 | 24052 |
| 4th-13th Common Tower A | 0 | 0 |

Required Cooling Equipment Output Capacity: 2652641 Btu/hr

Available Cooling Equipment Output Capacity: 290000 Btu/hr

Total flow: 87720 CFM

Cooling Equipment Efficiency: 9 SEER

Calculated Distribution Efficiency: 95%

Temperature Drop: 28 F

Cooling Safety Factor: 1.10

Distribution Safety Factor: 1.10

COOLING SYSTEM IS UNDERSIZED AND DOES NOT MEET THE REQUIRED COOLING LOAD.

Notes:

1. The room heating/cooling loads do not include the equipment and distribution safety factor and distribution losses
2. The room distribution includes distribution safety factor.
3. The load on the room is the peak load for this room in a year.
4. Available equipment output capacity includes equipment efficiency.
5. Required equipment output capacity includes diversity, distribution losses and equipment safety factor.
6. Overall distribution CFM/GPM for heating/cooling includes equipment safety factor, distribution losses and diversity.

DETAILED PACKAGE DESCRIPTION AND WORKSCOPE FOR Insulation Office Addition Walls

NBHA Lawlwer Apts

For: NBHA

By:

Date:8/17/2009

Improvement Information:

1. Wall Insulation Office Addition Tower B

Surface Insulation

| |
|--|
| Upgrade 1940 Sq.Ft of existing surfaces to Gyp Bd, 2x4 16" OC, 2" Fiberglass, 1.5" Air, 1" Wood, R-9 |
|--|

Non-Energy Benefits: Improve comfort, increase value of building.

Work Scope:

Comply with general conditions. Perform blower door test prior to insulating. Record results and date. Perform infrared scan if indoor/outdoor temperature difference is a minimum 15 F, prior to insulating. Inspect walls for damage, including moisture, prior to insulating. If damage or moisture is found, notify owner before proceeding. Inspect walls for live wiring. If found, notify owner before proceeding. Notify owner if asbestos-containing materials are found. Submit product information to owner for approval in writing prior to ordering. Insulation shall be installed according to manufacturer's instructions. Remove siding to drill holes in sheathing, to blow insulation into wall cavities. If siding cannot be removed, notify owner before drilling holes in finished interior or exterior surfaces. If holes have to be drilled in finished interior or exterior surfaces, holes should be patched and painted to match the surface. Drill a minimum two-inch diameter hole. Probe the wall cavity thoroughly to identify obstructions before insulating. Drill additional holes to insulate on all sides of obstruction as necessary. Dense-pack blow cellulose insulation at sufficient density to avoid settling, and to fill all voids. Insulate to a minimum 3.5 lb. per cubic foot density. Allow owner to inspect the insulation prior to plugging holes. All holes shall be plugged with wood plugs, and air-sealed prior to finishing. After insulating is complete, perform blower door tests. If indoor/outdoor temperature difference is minimum 15 F, perform infrared scan. Clean-up shall be thorough, and shall include inspection and cleaning of any forced air systems. Provide written reports to the owner, including: approved submittals, written record of which walls were insulated and where insulation was not installed, pre and post blower door tests results, pre and post infrared scan results, and warranty.

North Bergen Housing Authority
CHA #20241
Building: Lawler Towers Apartments

ECM-11a Office Wall Insulation Cost

Suggestions

Insulate the walls of the Housing Authority Offices using blown in insulation (R-19).

| Multipliers * | |
|---------------|------|
| Material: | 1.00 |
| ** | 1.22 |
| Equipment: | 1.00 |

| Description | QTY | UNIT | UNIT COSTS | | | SUBTOTAL COSTS | | | TOTAL COST | REMARKS |
|-----------------------------------|-------|------|------------|---------|---------|----------------|----------|--------|------------|---------------------------------|
| | | | MAT. | LABOR | EQUIP. | MAT. | LABOR | EQUIP. | | |
| Insulate walls of office - 3-1/2" | 1,000 | S.F. | \$ 1.90 | \$ 1.50 | \$ 0.07 | \$ 1,900 | \$ 1,830 | \$ 70 | \$ 3,800 | Means Building Cost Data - 2009 |
| Wall Patching and insulating | 1,000 | S.F. | \$ 0.06 | \$ 1.16 | \$ 0.50 | \$ 60 | \$ 1,415 | \$ 500 | \$ 1,975 | Means Building Cost Data - 2009 |
| Seal external panels | 800 | L.F. | \$ 0.06 | \$ 0.15 | \$ 0.07 | \$ 48 | \$ 146 | \$ 56 | \$ 250 | Means Building Cost Data - 2009 |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |

*Multipliers per RS Means Mechanical Cost Data for Newark, New Jersey

**Multiplier for Carpentry Labor specific to the Newark, New Jersey area.

| | |
|-----------------|--------------------|
| \$ 6,026 | Subtotal |
| \$ 1,205 | 20% Contingency |
| \$ 1,085 | 15% Contractor O&P |
| \$ - | 0% Engineering |
| \$ 8,315 | Total |

APPENDIX R

ECM-11b Insulate Area Below the NBHA Offices and Community Room

YOUR SUMMARY

This report addresses the key recommendations for improving the comfort, safety and efficiency of your home. You should use it as a guide for deciding what work you want to have done. Remember, your Home Performance Contractor is ready to complete these projects promptly, and the work is guaranteed.



Selected Packages



| Measure Description | Non-energy benefits | Package1 | Package2 | Package3 |
|--|--|----------|----------|----------|
| ● Insulation Crawl Space Office & Comm Rm: Upgrade 10,880 square feet of existing floor above grade to 6" Concrete, 2" XPS, R-10 | ● Improve comfort, increase value of building. | \$ 0 | | |
| Total Installed Cost | | \$ 0 | | |
| Annual Energy Cost Savings | | \$ 2,747 | | |
| Annual KWh Savings, KWh | | 0 | | |
| Total Energy Savings, MMBtu | | 247.5 | | |
| Simple annual payback, years | | NA | | |
| Savings to Investment Ratio | | NA | | |

The following fuel prices were used to estimate annual energy cost savings, payback and savings to investment ratio:

- Natural gas: 1.1100 \$/Therm
- Electricity: 0.1500 \$/kWh

Base Load Report

Customer Information

Customer Name: NBHA

Address: 6121/3131 Grand Avenue
North Bergen, NJ 07047

Billing Period: None

Auditor Information

Technician Name:

Company:

Phone Number:

Date: 8/17/2009

Model to Actual Comparison of Base Usage Per Year

Model Name: Insulation Crawl Space Cieling B-Office & Comm Rm

Billing Period Name: None

| | Electricity | | Natural gas | | | |
|--------------|-------------|---------|-------------|--------|--|--|
| | kWh | \$ | Therm | \$ | | |
| Model | 1,484,677 | 222,702 | 24,076 | 26,724 | | |
| Billing | | | | | | |
| % Difference | | | | | | |

Note: No billing data is available because the model was not compared to a billing period


Annual Use of Domestic Hot Water, Appliances, and Lighting

Model Name: Insulation Crawl Space Cieling B-Office & Comm Rm

| | Electricity \$0.15 per kWh | | Natural gas \$1.11 per Therm | | | | Total |
|--|-------------------------------|----------------|---------------------------------|---------------|--|--|----------------|
| | kWh | \$ | therms | \$ | | | \$ |
| 1. Domestic Hot Water | 0 | 0 | 23,161 | 25,709 | | | 25,709 |
| 2. Heating Community Rm & Offices | 130,680 | 19,602 | 0 | 0 | | | 19,602 |
| 3. Range, electric | 120,400 | 18,060 | 0 | 0 | | | 18,060 |
| 4. Oven, electric | 120,400 | 18,060 | 0 | 0 | | | 18,060 |
| 5. typical Other Heated Area lighting | 118,610 | 17,792 | 0 | 0 | | | 17,792 |
| 6. typical Other Heated Area lighting | 117,822 | 17,673 | 0 | 0 | | | 17,673 |
| 7. Refrigerator-auto def top freezer, 1990 | 88,400 | 13,260 | 0 | 0 | | | 13,260 |
| 8. Refrigerator-auto def top freezer, 1990 | 88,400 | 13,260 | 0 | 0 | | | 13,260 |
| 9. Cooling Community Rm & B-Offices | 57,408 | 8,611 | 0 | 0 | | | 8,611 |
| 10. Other | 609,883 | 91,482 | 915 | 1,016 | | | 92,498 |
| TOTAL | 1,452,003 | 217,800 | 24,076 | 26,725 | | | 244,525 |

Base Load Energy Users, \$/year

Model Name: Insulation Crawl Space Cieling B-Office & Comm Rm





MODEL ENERGY REPORT FOR INSULATION CRAWL SPACE CIELING B-OFFICE & COMM RM

NBHA Lawlwer Apts

For: NBHA

By:

Date: 8/17/2009



Note: Due to rounding, the sum of percentages may not be equal to 100.

DESIGN HEATING AND COOLING LOADS FOR INSULATION CRAWL SPACE CIELING B-OFFICE & COMM RM

8/17/2009
 Project Name: NBHA Lawlwer Apts
 For: NBHA
 By:
 Date:

Primary Heating System:

| Space Name | Load, Btu/Hr | Load, per SF Btu/(Hr-SqFt) | Distribution | |
|-------------------------|--------------|-------------------------------|--------------|--------------------|
| | | | GPM | Ft of baseboard |
| Gr FI Common Tower A | 166444 | 27 | 18.9 | 319 |
| 2nd FI Apts Tower B | 102364 | 19 | 11.6 | 196 |
| 3rd FI Apts Tower B | 105945 | 20 | 12.0 | 203 |
| 2nd FI Commom Tower B | 0 | 0 | 0.0 | 0 |
| Community Room | 188216 | 59 | 21.4 | 361 |
| Mechanical Spaces T-A | 396754 | 64 | 45.1 | 760 |
| 1st FI Common Tower A | 31227 | 13 | 3.5 | 60 |
| 1st- Apts Tower A | 93445 | 26 | 10.6 | 179 |
| Gr FI Office B Tower | 362066 | 47 | 41.2 | 693 |
| Basement Tower B | 19203 | 25 | 2.2 | 37 |
| 1st FI Common Tower B | 0 | 0 | 0.0 | 0 |
| 1st FI Apts Tower B | 88223 | 24 | 10.0 | 169 |
| 3rd FI Commom | 0 | 0 | 0.0 | 0 |
| 4th-13th Apts Tower B | 1280775 | 27 | 145.6 | 2451 |
| 4th-13th Common Tower B | 0 | 0 | 0.0 | 0 |
| 2nd FI Apts Tower A | 116662 | 22 | 13.3 | 224 |
| 2nd FI Common Tower A | 0 | 0 | 0.0 | 0 |
| 3rd FI Apts Tower A | 119730 | 23 | 13.6 | 230 |
| 3rd FI Common Tower A | 0 | 0 | 0.0 | 0 |
| 4th-13th Apts Tower A | 1442561 | 30 | 164.0 | 2760 |
| 4th-13th Common Tower A | 0 | 0 | 0.0 | 0 |

Required Heating Equipment Output Capacity: 5369312 Btu/hr

Available Heating Equipment Output Capacity: 6327100 Btu/hr

Total flow: 537.1 GPM

Baseboard Capacity: 575 Btu/Hr-Ft

Heating Equipment Efficiency: 65 %

Calculated Distribution Efficiency: 92 %

Supply Water Temperature: 220 F

Temperature Drop: 20 F

Heating Safety Factor: 1.10

Distribution Safety Factor: 1.10

Cooling System:

| Space Name | Load, Btu/Hr | Distribution CFM |
|-------------------------|--------------|------------------|
| Gr FI Common Tower A | 110762 | 4030 |
| 2nd FI Apts Tower B | 70500 | 2565 |
| 3rd FI Apts Tower B | 66013 | 2402 |
| 2nd FI Common Tower B | 0 | 0 |
| Community Room | 86414 | 3144 |
| Mechanical Spaces T-A | 0 | 0 |
| 1st FI Common Tower A | 64367 | 2342 |
| 1st- Apts Tower A | 57465 | 2091 |
| Gr FI Office B Tower | 216225 | 7866 |
| Basement Tower B | 6271 | 229 |
| 1st FI Common Tower B | 130099 | 4733 |
| 1st FI Apts Tower B | 57589 | 2095 |
| 3rd FI Common | 0 | 0 |
| 4th-13th Apts Tower B | 822976 | 29937 |
| 4th-13th Common Tower B | 0 | 0 |
| 2nd FI Apts Tower A | 51676 | 1880 |
| 2nd FI Common Tower A | 0 | 0 |
| 3rd FI Apts Tower A | 67962 | 2473 |
| 3rd FI Common Tower A | 0 | 0 |
| 4th-13th Apts Tower A | 661186 | 24052 |
| 4th-13th Common Tower A | 0 | 0 |

Required Cooling Equipment Output Capacity: 2665498 Btu/hr

Available Cooling Equipment Output Capacity: 290000 Btu/hr

Total flow: 88145 CFM

Cooling Equipment Efficiency: 9 SEER

Calculated Distribution Efficiency: 95%

Temperature Drop: 28 F

Cooling Safety Factor: 1.10

Distribution Safety Factor: 1.10

COOLING SYSTEM IS UNDERSIZED AND DOES NOT MEET THE REQUIRED COOLING LOAD.

Notes:

1. The room heating/cooling loads do not include the equipment and distribution safety factor and distribution losses
2. The room distribution includes distribution safety factor.
3. The load on the room is the peak load for this room in a year.
4. Available equipment output capacity includes equipment efficiency.
5. Required equipment output capacity includes diversity, distribution losses and equipment safety factor.
6. Overall distribution CFM/GPM for heating/cooling includes equipment safety factor, distribution losses and diversity.

DETAILED PACKAGE DESCRIPTION AND WORKSCOPE FOR Insulation Crawl Space Cieling B-Office & Comm Rm

NBHA Lawlwer Apts

For: NBHA

By:

Date:8/17/2009

Improvement Information:

1. Insulation Crawl Space Office & Comm Rm

Surface Insulation

| |
|---|
| Upgrade 10880 Sq.Ft of existing surfaces to 6" Concrete, 2" XPS, R-10 |
|---|

Non-Energy Benefits: Improve comfort, increase value of building.

Work Scope:

Comply with general conditions. Perform blower door test prior to insulating. Record results and date. Perform infrared scan if indoor/outdoor temperature difference is a minimum 15 F, prior to insulating. Inspect walls for damage, including moisture, prior to insulating. If damage or moisture is found, notify owner before proceeding. Inspect walls for live wiring. If found, notify owner before proceeding. Notify owner if asbestos-containing materials are found. Submit product information to owner for approval in writing prior to ordering. Insulation shall be installed according to manufacturer's instructions. Remove siding to drill holes in sheathing, to blow insulation into wall cavities. If siding cannot be removed, notify owner before drilling holes in finished interior or exterior surfaces. If holes have to be drilled in finished interior or exterior surfaces, holes should be patched and painted to match the surface. Drill a minimum two-inch diameter hole. Probe the wall cavity thoroughly to identify obstructions before insulating. Drill additional holes to insulate on all sides of obstruction as necessary. Dense-pack blow cellulose insulation at sufficient density to avoid settling, and to fill all voids. Insulate to a minimum 3.5 lb. per cubic foot density. Allow owner to inspect the insulation prior to plugging holes. All holes shall be plugged with wood plugs, and air-sealed prior to finishing. After insulating is complete, perform blower door tests. If indoor/outdoor temperature difference is minimum 15 F, perform infrared scan. Clean-up shall be thorough, and shall include inspection and cleaning of any forced air systems. Provide written reports to the owner, including: approved submittals, written record of which walls were insulated and where insulation was not installed, pre and post blower door tests results, pre and post infrared scan results, and warranty.

North Bergen Housing Authority
CHA #20241
Building: Lawler Towers Apartments

ECM-11b Office and Community Room Floor Insulation Cost

Suggestions

Insulate the floor of the Community Room and the floor of the Housing Authority Offices.
Use a 3" Isocyanurate board insulation (R-21.6). 4' x 8' sheets.

| | |
|---------------|------|
| Multipliers * | |
| Material: | 1.00 |
| **Labor: | 1.22 |
| Equipment: | 1.00 |

| Description | QTY | UNIT | UNIT COSTS | | | SUBTOTAL COSTS | | | TOTAL COST | REMARKS |
|-----------------------------|-------|------|------------|---------|--------|----------------|----------|--------|------------|---------|
| | | | MAT. | LABOR | EQUIP. | MAT. | LABOR | EQUIP. | | |
| 3" Isocyanurate Ins. board. | 8,000 | S.F. | \$ 1.90 | \$ 0.44 | \$ - | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ 15,200 | \$ 4,294 | \$ - | \$ 19,494 | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |

*Multipliers per RS Means Mechanical Cost Data for Newark, New Jersey

**Multiplier for Carpentry Labor specific to the Newark, New Jersey area.

| | |
|-----------|--------------------|
| \$ 19,494 | Subtotal |
| \$ 3,899 | 20% Contingency |
| \$ 3,509 | 15% Contractor O&P |
| \$ - | 0% Engineering |
| \$ 26,902 | Total |

APPENDIX S

ECM-12a Install On/Off Controls for Apartment Exhaust Fans

YOUR SUMMARY

This report addresses the key recommendations for improving the comfort, safety and efficiency of your home. You should use it as a guide for deciding what work you want to have done. Remember, your Home Performance Contractor is ready to complete these projects promptly, and the work is guaranteed.

| Selected Packages | |
|-------------------|----------|
| Package1 | Package2 |
| Package3 | Package3 |

| Measure Description | Non-energy benefits | Package1 | Package2 | Package3 |
|--|--|-----------|----------|----------|
| <input type="radio"/> Fan Apartments Off 8hr/day Thermal: Replace existing fan with new 12,000 CFM fan. | <input type="radio"/> Improve indoor air quality, increase value of building. | \$ 0 | | |
| <input type="radio"/> Fan Off 8hr/day Apartments kWh Savings: Removed Appliances: 3 Rooftop fan, 1 hp Apartments; Added Appliances: 3 Fan Apartments Off 8hr Kwh Savings | <input type="radio"/> Increase value of building, reduce environmental risk due to old ozone-depleting refrigerants. | \$ 0 | | |
| Total Installed Cost | | \$ 0 | | |
| Annual Energy Cost Savings | | \$ 16,491 | | |
| Annual kWh Savings, kWh | | 6,537 | | |
| Total Energy Savings, MMBtu | | 1,419.6 | | |
| Simple annual payback, years | | NA | | |
| Savings to Investment Ratio | | NA | | |

The following fuel prices were used to estimate annual energy cost savings, payback and savings to investment ratio:

- ☐ Natural gas: 1.1100 \$/Therm
- ☐ Electricity: 0.1500 \$/kWh

Base Load Report

Customer Information

Customer Name: NBHA

Address: 6121/3131 Grand Avenue
North Bergen, NJ 07047

Billing Period: None

Auditor Information

Technician Name:

Company:

Phone Number:

Date: 8/17/2009

Model to Actual Comparison of Base Usage Per Year

Model Name: Fan Off 8hrday Apartments Thermal & kWh

Billing Period Name: None

| | Electricity | | Natural gas | | | |
|--------------|-------------|---------|-------------|--------|--|--|
| | kWh | \$ | Therm | \$ | | |
| Model | 1,478,140 | 221,721 | 24,076 | 26,724 | | |
| Billing | | | | | | |
| % Difference | | | | | | |

Note: No billing data is available because the model was not compared to a billing period


Annual Use of Domestic Hot Water, Appliances, and Lighting

Model Name: Fan Off 8hrday Apartments Thermal & kWh

| | Electricity \$0.15 per kWh | | Natural gas \$1.11 per Therm | | | | Total |
|--|-------------------------------|----------------|---------------------------------|---------------|--|--|----------------|
| | kWh | \$ | therms | \$ | | | \$ |
| 1. Domestic Hot Water | 0 | 0 | 23,161 | 25,709 | | | 25,709 |
| 2. Heating Community Rm & Offices | 130,680 | 19,602 | 0 | 0 | | | 19,602 |
| 3. Oven, electric | 120,400 | 18,060 | 0 | 0 | | | 18,060 |
| 4. Range, electric | 120,400 | 18,060 | 0 | 0 | | | 18,060 |
| 5. typical Other Heated Area lighting | 118,610 | 17,792 | 0 | 0 | | | 17,792 |
| 6. typical Other Heated Area lighting | 117,822 | 17,673 | 0 | 0 | | | 17,673 |
| 7. Refrigerator-auto def top freezer, 1990 | 88,400 | 13,260 | 0 | 0 | | | 13,260 |
| 8. Refrigerator-auto def top freezer, 1990 | 88,400 | 13,260 | 0 | 0 | | | 13,260 |
| 9. Cooling Community Rm & B-Offices | 57,408 | 8,611 | 0 | 0 | | | 8,611 |
| 10. Other | 603,346 | 90,501 | 915 | 1,016 | | | 91,517 |
| TOTAL | 1,445,466 | 216,819 | 24,076 | 26,725 | | | 243,544 |

Base Load Energy Users, \$/year

Model Name: Fan Off 8hrday Apartments Thermal & kWh





MODEL ENERGY REPORT FOR FAN OFF 8HRDAY APARTMENTS THERMAL & KWH

NBHA Lawlwer Apts

For: NBHA

By:

Date: 8/17/2009



Note: Due to rounding, the sum of percentages may not be equal to 100.

DESIGN HEATING AND COOLING LOADS FOR FAN OFF 8HRDAY APARTMENTS THERMAL & KWH

8/17/2009

Project Name: NBHA Lawlwer Apts

For: NBHA

By:

Date:

Primary Heating System:

| Space Name | Load, Btu/Hr | Load, per SF Btu/(Hr-SqFt) | Distribution | |
|-------------------------|--------------|-------------------------------|--------------|--------------------|
| | | | GPM | Ft of baseboard |
| Gr Fl Common Tower A | 166444 | 27 | 18.9 | 319 |
| 2nd Fl Apts Tower B | 95776 | 18 | 10.9 | 184 |
| 3rd Fl Apts Tower B | 99357 | 19 | 11.3 | 191 |
| 2nd Fl Commom Tower B | 0 | 0 | 0.0 | 0 |
| Community Room | 205047 | 65 | 23.3 | 393 |
| Mechanical Spaces T-A | 396754 | 64 | 45.1 | 760 |
| 1st Fl Common Tower A | 31227 | 13 | 3.5 | 60 |
| 1st- Apts Tower A | 86857 | 24 | 9.9 | 167 |
| Gr Fl Office B Tower | 403732 | 52 | 45.9 | 773 |
| Basement Tower B | 19203 | 25 | 2.2 | 37 |
| 1st Fl Common Tower B | 0 | 0 | 0.0 | 0 |
| 1st Fl Apts Tower B | 81635 | 23 | 9.3 | 157 |
| 3rd Fl Commom | 0 | 0 | 0.0 | 0 |
| 4th-13th Apts Tower B | 1165885 | 24 | 132.5 | 2231 |
| 4th-13th Common Tower B | 0 | 0 | 0.0 | 0 |
| 2nd Fl Apts Tower A | 110074 | 21 | 12.5 | 211 |
| 2nd Fl Common Tower A | 0 | 0 | 0.0 | 0 |
| 3rd Fl Apts Tower A | 108750 | 21 | 12.4 | 209 |
| 3rd Fl Common Tower A | 0 | 0 | 0.0 | 0 |
| 4th-13th Apts Tower A | 1332761 | 28 | 151.5 | 2550 |
| 4th-13th Common Tower A | 0 | 0 | 0.0 | 0 |

Required Heating Equipment Output Capacity: 5104244 Btu/hr

Available Heating Equipment Output Capacity: 6327100 Btu/hr

Total flow: 510.6 GPM

Baseboard Capacity: 575 Btu/Hr-Ft

Heating Equipment Efficiency: 65 %

Calculated Distribution Efficiency: 93 %

Supply Water Temperature: 220 F

Temperature Drop: 20 F

Heating Safety Factor: 1.10

Distribution Safety Factor: 1.10

Cooling System:

| Space Name | Load, Btu/Hr | Distribution CFM |
|-------------------------|--------------|---------------------|
| Gr FI Common Tower A | 110762 | 4030 |
| 2nd FI Apts Tower B | 67898 | 2470 |
| 3rd FI Apts Tower B | 63411 | 2307 |
| 2nd FI Common Tower B | 0 | 0 |
| Community Room | 87420 | 3180 |
| Mechanical Spaces T-A | 0 | 0 |
| 1st FI Common Tower A | 64367 | 2342 |
| 1st- Apts Tower A | 54863 | 1996 |
| Gr FI Office B Tower | 219345 | 7979 |
| Basement Tower B | 6271 | 229 |
| 1st FI Common Tower B | 130099 | 4733 |
| 1st FI Apts Tower B | 54987 | 2001 |
| 3rd FI Common | 0 | 0 |
| 4th-13th Apts Tower B | 784706 | 28545 |
| 4th-13th Common Tower B | 0 | 0 |
| 2nd FI Apts Tower A | 49075 | 1786 |
| 2nd FI Common Tower A | 0 | 0 |
| 3rd FI Apts Tower A | 63626 | 2315 |
| 3rd FI Common Tower A | 0 | 0 |
| 4th-13th Apts Tower A | 617826 | 22474 |
| 4th-13th Common Tower A | 0 | 0 |

Required Cooling Equipment Output Capacity: 2558162 Btu/hr

Available Cooling Equipment Output Capacity: 290000 Btu/hr

Total flow: 84595 CFM

Cooling Equipment Efficiency: 9 SEER

Calculated Distribution Efficiency: 95%

Temperature Drop: 28 F

Cooling Safety Factor: 1.10

Distribution Safety Factor: 1.10

COOLING SYSTEM IS UNDERSIZED AND DOES NOT MEET THE REQUIRED COOLING LOAD.

Notes:

1. The room heating/cooling loads do not include the equipment and distribution safety factor and distribution losses
2. The room distribution includes distribution safety factor.
3. The load on the room is the peak load for this room in a year.
4. Available equipment output capacity includes equipment efficiency.
5. Required equipment output capacity includes diversity, distribution losses and equipment safety factor.
6. Overall distribution CFM/GPM for heating/cooling includes equipment safety factor, distribution losses and diversity.

DETAILED PACKAGE DESCRIPTION AND WORKSCOPE FOR Fan Off 8hr/day Apartments Thermal & kWh

NBHA Lawlwer Apts

For: NBHA

By:

Date: 8/17/2009

Improvement Information:

1. Fan Apartments Off 8hr/day Thermal

Mechanical Ventilation Improvement

| Ventilation Rate, CFM | Heat Recovery Efficiency | Ventilated Spaces | Type of Installation |
|-----------------------|--------------------------|-----------------------|----------------------|
| 300 | 0 | 2nd Fl Apts Tower A | Replace existing fan |
| 300 | 0 | 1st Fl Apts Tower B | Replace existing fan |
| 300 | 0 | 2nd Fl Apts Tower B | Replace existing fan |
| 300 | 0 | 1st- Apts Tower A | Replace existing fan |
| 300 | 0 | 3rd Fl Apts Tower B | Replace existing fan |
| 500 | 0 | 3rd Fl Apts Tower A | Replace existing fan |
| 5000 | 0 | 4th-13th Apts Tower A | Replace existing fan |
| 5000 | 0 | 4th-13th Apts Tower B | Replace existing fan |

Non-Energy Benefits: Improve indoor air quality, increase value of building.

Work Scope:

Comply with general conditions. Submit product information to owner for approval in writing prior to ordering. Patch and paint where existing equipment was removed to match existing surfaces. Perform complete ventilation sizing of the building prior to selecting equipment, using standard methods such as ASHRAE Standard 62. Size new equipment according to this sizing, and not according to the size of removed equipment. Provide a written copy of sizing and assumptions for approval by the owner prior to ordering equipment. Size distribution system according to standard methods. Install system securely and level. Securely fasten system to duct work with mechanical fasteners and seal. Install clean air filters. Duct sealing and insulation shall comply with standards described in the separate duct sealing and duct

insulation work scopes. Balance distribution system by measuring air supply to all grilles and adjusting manual balancing dampers. Balancing dampers shall be of the locking type. Install defrost drainage per manufacturer's instructions. Provide air gap for drain pipe per building or local codes. Insulate all ductwork per energy code requirements. Insulation shall be mechanically fastened. Tape is unacceptable as a fastener. Install supply grilles in locations where cold entering air will not present a comfort problem. After installation is complete, measure and record entering and leaving air temperatures. Ensure that these measurements are within the manufacturer's requirements. Provide training to the owner in the use of the system and controls. Deliver to the owner users manual, including measurement reports, warranties, and approved submittals.

2. Fan Off 8hr/day Apartments kWh Savings

Removed Appliances:

| Appliance Name | Location | Quantity |
|------------------------------|-----------------------|----------|
| Rooftop fan, 1 hp Apartments | 4th-13th Apts Tower B | 3 |

Added Appliances:

| Appliance Name | Location | Quantity |
|------------------------------------|-----------------------|----------|
| Fan Apartments Off 8hr Kwh Savings | 4th-13th Apts Tower B | 3 |

Non-Energy Benefits: Increase value of building, reduce environmental risk due to old ozone-depleting refrigerants.

Work Scope:

Comply with general conditions. Submit product information and obtain Owner approval prior to ordering. Dispose of original refrigerator in compliance with state and local regulations. Remove refrigerant in compliance with EPA regulations. Set thermostat in refrigerator to its warmest position. After equilibrium, measure and record temperature in refrigerator. Deliver all owner's manuals, test results, and warranties to the Owner.

North Bergen Housing Authority
CHA #20241
Building: Lawler Towers Apartments

ECM - 12a Apartment Exhaust Fans On/Off 8 Hrs. / Day

Suggestions

Install a small programmable controller and relays to turn roof mounted exhaust fans on and off based on a time schedule.

| | |
|---------------|------|
| Multipliers * | |
| Material: | 1.00 |
| **Labor: | 1.44 |
| Equipment: | 1.00 |

| Description | QTY | UNIT | UNIT COSTS | | | SUBTOTAL COSTS | | | TOTAL COST | REMARKS |
|---|-----|------|------------|----------|----------|----------------|----------|----------|------------|-----------------------------------|
| | | | MAT. | LABOR | EQUIP. | MAT. | LABOR | EQUIP. | | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| 16 Point Programable Controller. Cost includes, installation, programming and startup | 1 | ea. | | \$ 1,000 | \$ 2,000 | \$ - | \$ 1,440 | \$ 2,000 | \$ 3,440 | Means Mechanical Cost Data - 2009 |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| Install On/Off Relays in NEMA cabinet. Install conduit and wire from controller to MCC. | 10 | ea. | | | \$ 510 | \$ - | \$ - | \$ 5,100 | \$ 5,100 | Means Mechanical Cost Data - 2009 |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |

*Multipliers per RS Means Mechanical Cost Data for Newark, New Jersey

**Multiplier for Electrical and Controls Labor specific to the Newark, New Jersey area.

| | |
|------------------|--------------------|
| \$ 8,540 | Subtotal |
| \$ 1,708 | 20% Contingency |
| \$ 1,537 | 15% Contractor O&P |
| \$ - | 0% Engineering |
| \$ 11,785 | Total |

APPENDIX T

ECM-12b Install On/Off Controls for Common Area Exhaust Fans

YOUR SUMMARY

This report addresses the key recommendations for improving the comfort, safety and efficiency of your home. You should use it as a guide for deciding what work you want to have done. Remember, your Home Performance Contractor is ready to complete these projects promptly, and the work is guaranteed.



Selected Packages

| Measure Description | Non-energy benefits | Package1 | Package2 | Package3 |
|---|--|----------|----------|----------|
| ● Fan Off Common Area 8hr/day Thermal: Replace existing fan with new 11,070 CFM fan. | ● Improve indoor air quality, increase value of building. | \$ 0 | | |
| ● Fan Common Off 8hr/day kWh: Removed Appliances: 1 Rooftop fan, Common Area 1 hp; Added Appliances: 1 Fan Common Off 8hr kWh Savings | ● Increase value of building, reduce environmental risk due to old ozone-depleting refrigerants. | \$ 0 | | |
| Total Installed Cost | | \$ 0 | | |
| Annual Energy Cost Savings | | \$ 1,993 | | |
| Annual kWh Savings, kWh | | 2,179 | | |
| Total Energy Savings, MMBtu | | 157.5 | | |
| Simple annual payback, years | | NA | | |
| Savings to Investment Ratio | | NA | | |

The following fuel prices were used to estimate annual energy cost savings, payback and savings to investment ratio:

- Natural gas: 1.1100 \$/Therm
- Electricity: 0.1500 \$/kWh

Base Load Report

Customer Information

Customer Name: NBHA

Address: 6121/3131 Grand Avenue
North Bergen, NJ 07047

Billing Period: None

Auditor Information

Technician Name:

Company:

Phone Number:

Date: 8/17/2009

Model to Actual Comparison of Base Usage Per Year

Model Name: Fan Off 8hrday Common Areas Thermal & kWh

Billing Period Name: None

| | Electricity | | Natural gas | | | |
|--------------|-------------|---------|-------------|--------|--|--|
| | kWh | \$ | Therm | \$ | | |
| Model | 1,482,498 | 222,375 | 24,076 | 26,724 | | |
| Billing | | | | | | |
| % Difference | | | | | | |

Note: No billing data is available because the model was not compared to a billing period


Annual Use of Domestic Hot Water, Appliances, and Lighting

Model Name: Fan Off 8hrday Common Areas Thermal & kWh

| | Electricity \$0.15 per kWh | | Natural gas \$1.11 per Therm | | | | Total |
|--|-------------------------------|----------------|---------------------------------|---------------|--|--|----------------|
| | kWh | \$ | therms | \$ | | | \$ |
| 1. Domestic Hot Water | 0 | 0 | 23,161 | 25,709 | | | 25,709 |
| 2. Heating Community Rm & Offices | 130,680 | 19,602 | 0 | 0 | | | 19,602 |
| 3. Oven, electric | 120,400 | 18,060 | 0 | 0 | | | 18,060 |
| 4. Range, electric | 120,400 | 18,060 | 0 | 0 | | | 18,060 |
| 5. typical Other Heated Area lighting | 118,610 | 17,792 | 0 | 0 | | | 17,792 |
| 6. typical Other Heated Area lighting | 117,822 | 17,673 | 0 | 0 | | | 17,673 |
| 7. Refrigerator-auto def top freezer, 1990 | 88,400 | 13,260 | 0 | 0 | | | 13,260 |
| 8. Refrigerator-auto def top freezer, 1990 | 88,400 | 13,260 | 0 | 0 | | | 13,260 |
| 9. Cooling Community Rm & B-Offices | 57,408 | 8,611 | 0 | 0 | | | 8,611 |
| 10. Other | 607,704 | 91,155 | 915 | 1,016 | | | 92,171 |
| TOTAL | 1,449,824 | 217,473 | 24,076 | 26,725 | | | 244,198 |

Base Load Energy Users, \$/year

Model Name: Fan Off 8hrday Common Areas Thermal & kWh





MODEL ENERGY REPORT FOR FAN OFF 8HRDAY COMMON AREAS THERMAL & KWH

NBHA Lawlwer Apts

For: NBHA

By:

Date: 8/17/2009



Note: Due to rounding, the sum of percentages may not be equal to 100.

DETAILED PACKAGE DESCRIPTION AND WORKSCOPE FOR Fan Off 8hr/day Common Areas Thermal & kWh

NBHA Lawlwer Apts

For: NBHA

By:

Date:8/17/2009

Improvement Information:

1. Fan Off Common Area 8hr/day Thermal

Mechanical Ventilation Improvement

| Ventilation Rate, CFM | Heat Recovery Efficiency | Ventilated Spaces | Type of Installation |
|-----------------------|--------------------------|-------------------------|----------------------|
| 350 | 0 | 2nd Fl Common Tower A | Replace existing fan |
| 350 | 0 | 3rd Fl Common | Replace existing fan |
| 350 | 0 | 2nd Fl Common Tower B | Replace existing fan |
| 350 | 0 | 1st Fl Common Tower B | Replace existing fan |
| 350 | 0 | 1st Fl Common Tower A | Replace existing fan |
| 1000 | 0 | Gr Fl Common Tower A | Replace existing fan |
| 4160 | 0 | 4th-13th Common Tower B | Replace existing fan |
| 4160 | 0 | 4th-13th Common Tower A | Replace existing fan |

Non-Energy Benefits: Improve indoor air quality, increase value of building.

Work Scope:

Comply with general conditions. Submit product information to owner for approval in writing prior to ordering. Patch and paint where existing equipment was removed to match existing surfaces. Perform complete ventilation sizing of the building prior to selecting equipment, using standard methods such as ASHRAE Standard 62. Size new equipment according to this sizing, and not according to the size of removed equipment. Provide a written copy of sizing and assumptions for approval by the owner prior to ordering equipment. Size distribution system according to standard methods. Install system securely and level. Securely fasten system to duct work with mechanical fasteners and seal. Install clean air filters. Duct sealing and insulation shall comply with standards described in the separate duct sealing and duct

2. Fan Common Off 8hr/day kWh

Removed Appliances:

| Appliance Name | Location | Quantity |
|-------------------------------|-------------------------|----------|
| Rooftop fan, Common Area 1 hp | 4th-13th Common Tower B | 1 |

Added Appliances:

| Appliance Name | Location | Quantity |
|--------------------------------|-----------------------|----------|
| Fan Common Off 8hr kWh Savings | 4th-13th Apts Tower B | 1 |

Non-Energy Benefits: Increase value of building, reduce environmental risk due to old ozone-depleting refrigerants.

Work Scope:

Comply with general conditions. Submit product information and obtain Owner approval prior to ordering. Dispose of original refrigerator in compliance with state and local regulations. Remove refrigerant in compliance with EPA regulations. Set thermostat in refrigerator to its warmest position. After equilibrium, measure and record temperature in refrigerator. Deliver all owner's manuals, test results, and warranties to the Owner.

insulation work scopes. Balance distribution system by measuring air supply to all grilles and adjusting manual balancing dampers. Balancing dampers shall be of the locking type. Install defrost drainage per manufacturer's instructions. Provide air gap for drain pipe per building or local codes. Insulate all ductwork per energy code requirements. Insulation shall be mechanically fastened. Tape is unacceptable as a fastener. Install supply grilles in locations where cold entering air will not present a comfort problem. After installation is complete, measure and record entering and leaving air temperatures. Ensure that these measurements are within the manufacturer's requirements. Provide training to the owner in the use of the system and controls. Deliver to the owner users manual, including measurement reports, warranties, and approved submittals.

North Bergen Housing Authority
CHA #20241
Building: Lawler Towers Apartments

ECM - 12b Common Area Exhaust Fans On/Off 8 Hrs. / Day

Suggestions

Install a small programmable controller and relays to turn roof mounted exhaust fans on and off based on a time schedule.

| Multipliers * | |
|---------------|------|
| Material: | 1.00 |
| **Labor: | 1.44 |
| Equipment: | 1.00 |

| Description | QTY | UNIT | UNIT COSTS | | | SUBTOTAL COSTS | | | TOTAL COST | REMARKS |
|---|-----|------|------------|----------|----------|----------------|----------|----------|------------|-----------------------------------|
| | | | MAT. | LABOR | EQUIP. | MAT. | LABOR | EQUIP. | | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| 16 Point Programable Controller. Cost includes, installation, programming and startup | 1 | ea. | | \$ 1,000 | \$ 2,000 | \$ - | \$ 1,440 | \$ 2,000 | \$ 3,440 | Means Mechanical Cost Data - 2009 |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| Install On/Off Relays in NEMA cabinet. Install conduit and wire from controller to MCC. | 4 | ea. | | | \$ 510 | \$ - | \$ - | \$ 2,040 | \$ 2,040 | Means Mechanical Cost Data - 2009 |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |

*Multipliers per RS Means Mechanical Cost Data for Newark, New Jersey

**Multiplier for Electrical and Controls Labor specific to the Newark, New Jersey area.

| | |
|-----------------|--------------------|
| \$ 5,480 | Subtotal |
| \$ 1,096 | 20% Contingency |
| \$ 986 | 15% Contractor O&P |
| \$ - | 0% Engineering |
| \$ 7,562 | Total |

APPENDIX U

ECM-13 Energy Star Appliances

YOUR SUMMARY

This report addresses the key recommendations for improving the comfort, safety and efficiency of your home. You should use it as a guide for deciding what work you want to have done. Remember, your Home Performance Contractor is ready to complete these projects promptly, and the work is guaranteed.



Selected Packages

| Measure Description | Non-energy benefits | Package1 | Package2 | Package3 |
|--|--|-----------|----------|----------|
| <ul style="list-style-type: none"> Energy Star Refrigerators: Removed Appliances: 1 Refrigerator - auto def side freezer, 20 CF, high eff 2000, 7 Kitchen Refrigerators, 7 Refrigerator 1st, 10 Refrigerators, 10 Refrigerator - auto def top freezer, 1990 model, 10 Refrigerator 2, 10 Refrigerator, 100 Refrigerator-auto def top freezer, 1990 model, 100 Refrigerator-auto def top freezer, 1990 model2; Added Appliances: 1 Refrigerator - auto def, 20 CF, high efficiency, 7 Refrigerator - auto def, 15 CF, high efficiency, 7 Refrigerator - auto def, 15 CF, high efficiency 7, 10 Refrigerator - auto def, 15 CF, high efficiency 11, 10 Refrigerator - auto def, 15 CF, high efficiency 2, 10 Refrigerator - auto def, 15 CF, high efficiency 3, 10 Refrigerator - auto def, 15 CF, high efficiency 4, 10 Refrigerator - auto def, 15 CF, high efficiency 6, 100 Refrigerator - auto def, 15 CF, high efficiency 10, 100 Refrigerator - auto def, 15 CF, high efficiency 8 | <ul style="list-style-type: none"> Increase value of building, reduce environmental risk due to old ozone-depleting refrigerants. | \$ 0 | | |
| Total Installed Cost | | \$ 0 | | |
| Annual Energy Cost Savings | | \$ 13,063 | | |
| Annual KWh Savings, KWh | | 106,584 | | |
| Total Energy Savings, MMBtu | | 100.2 | | |
| Simple annual payback, years | | NA | | |
| Savings to Investment Ratio | | NA | | |

The following fuel prices were used to estimate annual energy cost savings, payback and savings to investment ratio:

- Natural gas: 1.1100 \$/Therm
- Electricity: 0.1500 \$/kWh

Base Load Report

Customer Information

Customer Name: NBHA

Address: 6121/3131 Grand Avenue
North Bergen, NJ 07047

Billing Period: None

Auditor Information

Technician Name:

Company:

Phone Number:

Date: 8/17/2009

Model to Actual Comparison of Base Usage Per Year

Model Name: Energy Star Refrigerators

Billing Period Name: None

| | Electricity | | Natural gas | | | |
|--------------|-------------|---------|-------------|--------|--|--|
| | kWh | \$ | Therm | \$ | | |
| Model | 1,378,093 | 206,714 | 24,076 | 26,724 | | |
| Billing | | | | | | |
| % Difference | | | | | | |

Note: No billing data is available because the model was not compared to a billing period


Annual Use of Domestic Hot Water, Appliances, and Lighting

Model Name: Energy Star Refrigerators

| | Electricity \$0.15 per kWh | | Natural gas \$1.11 per Therm | | | | Total |
|---------------------------------------|-------------------------------|----------------|---------------------------------|---------------|--|--|----------------|
| | kWh | \$ | therms | \$ | | | \$ |
| 1. Domestic Hot Water | 0 | 0 | 23,161 | 25,709 | | | 25,709 |
| 2. Heating Community Rm & Offices | 130,680 | 19,602 | 0 | 0 | | | 19,602 |
| 3. Oven, electric | 120,400 | 18,060 | 0 | 0 | | | 18,060 |
| 4. Range, electric | 120,400 | 18,060 | 0 | 0 | | | 18,060 |
| 5. typical Other Heated Area lighting | 118,610 | 17,792 | 0 | 0 | | | 17,792 |
| 6. typical Other Heated Area lighting | 117,822 | 17,673 | 0 | 0 | | | 17,673 |
| 7. Cooling Community Rm & B-Offices | 57,408 | 8,611 | 0 | 0 | | | 8,611 |
| 8. typical Sleeping Quarters lighting | 54,417 | 8,163 | 0 | 0 | | | 8,163 |
| 9. typical Whole Building lighting | 54,417 | 8,163 | 0 | 0 | | | 8,163 |
| 10. Other | 571,265 | 85,688 | 915 | 1,016 | | | 86,704 |
| TOTAL | 1,345,419 | 201,812 | 24,076 | 26,725 | | | 228,537 |

Base Load Energy Users, \$/year

Model Name: Energy Star Refrigerators





MODEL ENERGY REPORT FOR ENERGY STAR REFRIGERATORS

NBHA Lawlwer Apts

For: NBHA

By:

Date: 8/17/2009



Note: Due to rounding, the sum of percentages may not be equal to 100.

DESIGN HEATING AND COOLING LOADS FOR ENERGY STAR REFRIGERATORS

8/17/2009
 Project Name: NBHA Lawlwer Apts
 For: NBHA
 By:
 Date:

Primary Heating System:

| Space Name | Load, Btu/Hr | Load, per SF Btu/(Hr-SqFt) | Distribution | |
|-------------------------|--------------|-------------------------------|--------------|--------------------|
| | | | GPM | Ft of baseboard |
| Gr Fl Common Tower A | 166444 | 27 | 18.9 | 319 |
| 2nd Fl Apts Tower B | 104064 | 20 | 11.8 | 200 |
| 3rd Fl Apts Tower B | 107645 | 20 | 12.2 | 206 |
| 2nd Fl Common Tower B | 0 | 0 | 0.0 | 0 |
| Community Room | 205047 | 65 | 23.3 | 393 |
| Mechanical Spaces T-A | 396754 | 64 | 45.1 | 760 |
| 1st Fl Common Tower A | 31227 | 13 | 3.5 | 60 |
| 1st- Apts Tower A | 94635 | 26 | 10.8 | 182 |
| Gr Fl Office B Tower | 403732 | 52 | 45.9 | 773 |
| Basement Tower B | 19203 | 25 | 2.2 | 37 |
| 1st Fl Common Tower B | 0 | 0 | 0.0 | 0 |
| 1st Fl Apts Tower B | 89413 | 25 | 10.2 | 172 |
| 3rd Fl Common | 0 | 0 | 0.0 | 0 |
| 4th-13th Apts Tower B | 1297755 | 27 | 147.5 | 2483 |
| 4th-13th Common Tower B | 0 | 0 | 0.0 | 0 |
| 2nd Fl Apts Tower A | 116662 | 22 | 13.3 | 224 |
| 2nd Fl Common Tower A | 0 | 0 | 0.0 | 0 |
| 3rd Fl Apts Tower A | 121430 | 23 | 13.8 | 233 |
| 3rd Fl Common Tower A | 0 | 0 | 0.0 | 0 |
| 4th-13th Apts Tower A | 1442561 | 30 | 164.0 | 2760 |
| 4th-13th Common Tower A | 0 | 0 | 0.0 | 0 |

Required Heating Equipment Output Capacity: 5454019 Btu/hr

Available Heating Equipment Output Capacity: 6327100 Btu/hr

Total flow: 545.6 GPM

Baseboard Capacity: 575 Btu/Hr-Ft

Heating Equipment Efficiency: 65 %

Calculated Distribution Efficiency: 93 %

Supply Water Temperature: 220 F

Temperature Drop: 20 F

Heating Safety Factor: 1.10

Distribution Safety Factor: 1.10

Cooling System:

| Space Name | Load, Btu/Hr | Distribution CFM |
|-------------------------|--------------|------------------|
| Gr FI Common Tower A | 110762 | 4030 |
| 2nd FI Apts Tower B | 68800 | 2503 |
| 3rd FI Apts Tower B | 63842 | 2323 |
| 2nd FI Commom Tower B | 0 | 0 |
| Community Room | 87290 | 3176 |
| Mechanical Spaces T-A | 0 | 0 |
| 1st FI Common Tower A | 64367 | 2342 |
| 1st- Apts Tower A | 56275 | 2048 |
| Gr FI Office B Tower | 219345 | 7979 |
| Basement Tower B | 6271 | 229 |
| 1st FI Common Tower B | 130099 | 4733 |
| 1st FI Apts Tower B | 56399 | 2052 |
| 3rd FI Commom | 0 | 0 |
| 4th-13th Apts Tower B | 805996 | 29319 |
| 4th-13th Common Tower B | 0 | 0 |
| 2nd FI Apts Tower A | 51676 | 1880 |
| 2nd FI Common Tower A | 0 | 0 |
| 3rd FI Apts Tower A | 66262 | 2411 |
| 3rd FI Common Tower A | 0 | 0 |
| 4th-13th Apts Tower A | 661186 | 24052 |
| 4th-13th Common Tower A | 0 | 0 |

Required Cooling Equipment Output Capacity: 2644317 Btu/hr

Available Cooling Equipment Output Capacity: 290000 Btu/hr

Total flow: 87444 CFM

Cooling Equipment Efficiency: 9 SEER

Calculated Distribution Efficiency: 95%

Temperature Drop: 28 F

Cooling Safety Factor: 1.10

Distribution Safety Factor: 1.10

COOLING SYSTEM IS UNDERSIZED AND DOES NOT MEET THE REQUIRED COOLING LOAD.

Notes:

1. The room heating/cooling loads do not include the equipment and distribution safety factor and distribution losses
2. The room distribution includes distribution safety factor.
3. The load on the room is the peak load for this room in a year.
4. Available equipment output capacity includes equipment efficiency.
5. Required equipment output capacity includes diversity, distribution losses and equipment safety factor.
6. Overall distribution CFM/GPM for heating/cooling includes equipment safety factor, distribution losses and diversity.

DETAILED PACKAGE DESCRIPTION AND WORKSCOPE FOR Energy Star Refrigerators

NBHA Lawlwer Apts

For: NBHA

By:

Date:8/17/2009

Improvement Information:

1. Energy Star Refrigerators

Removed Appliances:

| Appliance Name | Location | Quantity |
|--|-----------------------|----------|
| Kitchen Refrigerators | 1st- Apts Tower A | 7 |
| Refrigerators | 2nd Fl Apts Tower A | 10 |
| Refrigerator - auto def side freezer, 20 CF, high eff 2000 | Community Room | 1 |
| Refrigerator - auto def top freezer, 1990 model | 3rd Fl Apts Tower B | 10 |
| Refrigerator 2 | 3rd Fl Apts Tower A | 10 |
| Refrigerator-auto def top freezer, 1990 model | 4th-13th Apts Tower A | 100 |
| Refrigerator-auto def top freezer, 1990 model2 | 4th-13th Apts Tower B | 100 |
| Refrigerator 1st | 1st Fl Apts Tower B | 7 |
| Refrigerator | 2nd Fl Apts Tower B | 10 |

Added Appliances:

| Appliance Name | Location | Quantity |
|--|-----------------------|----------|
| Refrigerator - auto def, 15 CF, high efficiency | 1st- Apts Tower A | 7 |
| Refrigerator - auto def, 15 CF, high efficiency 10 | 4th-13th Apts Tower A | 100 |
| Refrigerator - auto def, 15 CF, high efficiency 11 | 2nd Fl Common Tower A | 10 |
| Refrigerator - auto def, 15 CF, high efficiency 2 | 2nd Fl Apts Tower B | 10 |
| Refrigerator - auto def, 15 CF, high efficiency 3 | 3rd Fl Apts Tower B | 10 |

| | | |
|---|-----------------------|-----|
| Refrigerator - auto def, 15 CF, high efficiency 4 | 3rd Fl Apts Tower A | 10 |
| Refrigerator - auto def, 15 CF, high efficiency 6 | 2nd Fl Apts Tower A | 10 |
| Refrigerator - auto def, 15 CF, high efficiency 7 | 1st Fl Apts Tower B | 7 |
| Refrigerator - auto def, 15 CF, high efficiency 8 | 4th-13th Apts Tower B | 100 |
| Refrigerator - auto def, 20 CF, high efficiency | Community Room | 1 |

Non-Energy Benefits: Increase value of building, reduce environmental risk due to old ozone-depleting refrigerants.

Work Scope:

Comply with general conditions. Submit product information and obtain Owner approval prior to ordering. Dispose of original refrigerator in compliance with state and local regulations. Remove refrigerant in compliance with EPA regulations. Set thermostat in refrigerator to its warmest position. After equilibrium, measure and record temperature in refrigerator. Deliver all owner's manuals, test results, and warranties to the Owner.

North Bergen Housing Authority
CHA #20241
Building: Lawler Towers Apartments

ECM - 13 Replace Refrigerators with Energy Star Rated Units

Suggestions

Replace existing 15 C.F. refrigerators with new 15 C.F. Energy Star rated refrigerators.

| Multipliers * | |
|---------------|------|
| Material: | 1.00 |
| **Labor: | 1.22 |
| Equipment: | 1.00 |

| Description | QTY | UNIT | UNIT COSTS | | | SUBTOTAL COSTS | | | TOTAL COST | REMARKS |
|--|-----|------|------------|-------|--------|----------------|-----------|--------|------------|-----------------------------------|
| | | | MAT. | LABOR | EQUIP. | MAT. | LABOR | EQUIP. | | |
| Replace all 15 C.F. refrigerators in Lawler Towers with Energy Star rated units. | 253 | ea. | \$ 600 | \$ 20 | | \$ 151,800 | \$ 6,173 | \$ - | \$ 157,973 | Quotes from Home Depot and Lowes. |
| Disposal cost for each unit. | 253 | ea. | | \$ 35 | | \$ - | \$ 10,803 | \$ - | \$ 10,803 | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |

*Multipliers per RS Means Mechanical Cost Data for Newark, New Jersey

**Multiplier for Millwright Labor specific to the Newark, New Jersey area.

| | |
|-------------------|-------------------|
| \$ 168,776 | Subtotal |
| \$ 8,439 | 5% Contingency |
| \$ - | 0% Contractor O&P |
| \$ - | 0% Engineering |
| \$ 177,215 | Total |



Energy Savings Are Just the Beginning

Thanks to recent improvements in insulation and compressors, today's refrigerators use much less energy than older models. With an ENERGY STAR qualified refrigerator, you can maximize your energy and dollar savings without sacrificing the features you want.

- **Slash your energy bills.**

ENERGY STAR qualified refrigerators are required by the U.S. Department of Energy to use 20% less energy than models not labeled with the ENERGY STAR logo. Choose a new qualified model rather than a non-qualified model and cut your energy bills by \$165 over the lifetime of your fridge.

- **Replace your old fridge for bigger savings.**


If you still have a fridge from the 1980s, replace it with an ENERGY STAR qualified model and save over \$100 each year on your utility bills. Replace a fridge from the 1970s and save nearly \$200 each year! Use the [ENERGY STAR Savings Calculator](#) to find out exactly how much money you'll save by replacing your existing refrigerator.

- **Get the latest features.**

You can find the ENERGY STAR label on the most advanced refrigerators in a variety of designs, including French-door, side-by-side, bottom-mount freezer, and top-mount freezer. Many ENERGY STAR qualified refrigerators use innovative drawer designs and improved temperature controls to keep your food fresher, longer.

- **Protect the environment.**

Nearly 70% of U.S. electricity is generated with coal and natural gas, which release greenhouse gasses into the atmosphere and contribute to global warming. ENERGY STAR qualified refrigerators use less energy and help us reduce our impact on the environment.



A fridge from the 1970s uses 4 times more energy than a new ENERGY STAR qualified model.

How old is YOUR fridge?

 [Email This Page](#)

[Products](#) | [Home Improvement](#) | [New Homes](#) | [Buildings & Plants](#) | [Partner Resources](#) | [Kids Publications](#) | [News Room](#) | [FAQs](#) | [Contact Us](#) | [Privacy](#) | [Site Index](#) | [Recursos en Español](#)
[PDF Viewer](#) | [Excel Viewer](#)



[EPA Home](#)
[EPA Search](#)



[DOE Home](#)
[DOE Search](#)

APPENDIX V

ECM-14 Photovoltaic Power Generation

North Bergen Housing Authority
CHA #20241
Building: Lawler Towers Apartments

ECM - 14 Photovoltaic Panels

Cost of Electricity \$0.15 \$/kWh

ECM-14 Photovoltaic (PV) Rooftop Solar Power Generation-20kW System

| Budgetary | Annual Utility Savings | | | | Estimated | Total | New Jersey Renewable | New Jersey Renewable | Payback | Payback |
|-----------|------------------------|--------|--------|---------|---------------------|---------|----------------------|----------------------|---------------------|------------------|
| Cost | | | | | Maintenance Savings | | * Energy Incentive | ** SREC | (without incentive) | (with incentive) |
| \$ | kW | kWh | therms | \$ | \$ | \$ | \$ | \$ | Years | Years |
| \$200,000 | 0.0 | 23,660 | 0 | \$3,549 | 0 | \$3,549 | \$20,000 | \$11,515 | >30 | 11.9 |

*Incentive based on New Jersey renewable energy program for non-residential applications(PV)= \$1.00/W of installed PV system

** Estimated Solar Renewable Energy Certificate Program (SREC) SREC for 15 Years= \$487/1000kwh

Estimated Solar Renewable Energy Certificate Program (SREC) payments for 15 Years from RR Renewable Energy Consultants

| Year | SREC |
|------------|------------|
| 1 | 600 |
| 2 | 600 |
| 3 | 600 |
| 4 | 500 |
| 5 | 500 |
| 6 | 500 |
| 7 | 500 |
| 8 | 500 |
| 9 | 500 |
| 10 | 500 |
| 11 | 400 |
| 12 | 400 |
| 13 | 400 |
| 14 | 400 |
| 15 | 400 |
| AVG | 487 |



W Granton Ave

Granton Ave

Grand Ave

Meadowview Ave

6131 Grand Ave, NJ 07047


© 2009 Tele Atlas
Image © 2009 Sanborn

Google

Imagery Date: 2004

40°47'40.61" N 74°01'22.56" W elev 187 ft

Eye alt 1145 ft



N

Granton Ave

Grand Ave

6131 Grand Ave, NJ 07047

© 2009 Tele Atlas
Image © 2009 Sanborn

2009 Google

Imagery Date: 2004

40°47'39.10" N 74°01'23.62" W elev 189 ft

Eye alt 604 ft

APPENDIX W

EPA Energy Star Portfolio Manager Report



STATEMENT OF ENERGY PERFORMANCE

Lawler

Building ID: 1789113
For 12-month Period Ending: May 31, 2009¹
Date SEP becomes ineligible: N/A

Date SEP Generated: August 25, 2009

Facility
 Lawler
 6121 Grand Ave
 North Bergen, NJ 07047

Facility Owner
 North Bergen Housing Authority
 6121 Grand Ave.
 North Bergen, NJ 07047

Primary Contact for this Facility
 Ryan Leggio
 6121 Grand Ave.
 North Bergen, NJ 07047

Year Built: 1968
Gross Floor Area (ft²): 191,100

Energy Performance Rating² (1-100) N/A

Site Energy Use Summary³

| | |
|---------------------------------|------------|
| Natural Gas (kBtu) ⁴ | 17,149,310 |
| Electricity (kBtu) | 5,671,878 |
| Total Energy (kBtu) | 22,821,188 |

Energy Intensity⁵

| | |
|-----------------------------------|-----|
| Site (kBtu/ft ² /yr) | 119 |
| Source (kBtu/ft ² /yr) | 193 |

Emissions (based on site energy use)

| | |
|---|-------|
| Greenhouse Gas Emissions (MtCO ₂ e/year) | 1,845 |
|---|-------|

Electric Distribution Utility

PSE&G - Public Service Elec & Gas Co

National Average Comparison

National Average Site EUI
 National Average Source EUI
 % Difference from National Average Source EUI
 Building Type

Multifamily
 Housing

Meets Industry Standards⁶ for Indoor Environmental Conditions:

| | |
|---|-----|
| Ventilation for Acceptable Indoor Air Quality | N/A |
| Acceptable Thermal Environmental Conditions | N/A |
| Adequate Illumination | N/A |

| |
|--|
| |
| Stamp of Certifying Professional |
| Based on the conditions observed at the time of my visit to this building, I certify that the information contained within this statement is accurate. |

Certifying Professional

Ryan Leggio
 6121 Grand Ave.
 North Bergen, NJ 07047

Notes:

1. Application for the ENERGY STAR must be submitted to EPA within 4 months of the Period Ending date. Award of the ENERGY STAR is not final until approval is received from EPA.
2. The EPA Energy Performance Rating is based on total source energy. A rating of 75 is the minimum to be eligible for the ENERGY STAR.
3. Values represent energy consumption, annualized to a 12-month period.
4. Natural Gas values in units of volume (e.g. cubic feet) are converted to kBtu with adjustments made for elevation based on Facility zip code.
5. Values represent energy intensity, annualized to a 12-month period.
6. Based on Meeting ASHRAE Standard 62 for ventilation for acceptable indoor air quality, ASHRAE Standard 55 for thermal comfort, and IESNA Lighting Handbook for lighting quality.

ENERGY STAR® Data Checklist for Commercial Buildings

In order for a building to qualify for the ENERGY STAR, a Professional Engineer (PE) must validate the accuracy of the data underlying the building's energy performance rating. This checklist is designed to provide an at-a-glance summary of a property's physical and operating characteristics, as well as its total energy consumption, to assist the PE in double-checking the information that the building owner or operator has entered into Portfolio Manager.

Please complete and sign this checklist and include it with the stamped, signed Statement of Energy Performance.

NOTE: You must check each box to indicate that each value is correct, OR include a note.

| CRITERION | VALUE AS ENTERED IN PORTFOLIO MANAGER | VERIFICATION QUESTIONS | NOTES | <input checked="" type="checkbox"/> |
|--|--|---|-------|-------------------------------------|
| Building Name | Lawler | Is this the official building name to be displayed in the ENERGY STAR Registry of Labeled Buildings? | | <input type="checkbox"/> |
| Type | Multifamily Housing | Is this an accurate description of the space in question? | | <input type="checkbox"/> |
| Location | 6121 Grand Ave, North Bergen, NJ 07047 | Is this address accurate and complete? Correct weather normalization requires an accurate zip code. | | <input type="checkbox"/> |
| Single Structure | Single Facility | Does this SEP represent a single structure? SEPs cannot be submitted for multiple-building campuses (with the exception of acute care or children's hospitals) nor can they be submitted as representing only a portion of a building | | <input type="checkbox"/> |
| Edward A. Lawler Towers (Multifamily Housing) | | | | |
| CRITERION | VALUE AS ENTERED IN PORTFOLIO MANAGER | VERIFICATION QUESTIONS | NOTES | <input checked="" type="checkbox"/> |
| Gross Floor Area | 191,100 Sq. Ft. | Does the square footage include all supporting functions such as residential units, common areas, elevators, storage areas, vent shafts, lobbies, boiler room and basement, etc? Interstitial (plenum) space between floors should be excluded from the total. | | <input type="checkbox"/> |
| Number of units | N/A(Optional) | Is this the total number of occupied or unoccupied apartment units in the Multifamily Housing building? This should include apartments on every line of the building and of every floor plan type and the basement apartments. This should exclude storage or maintenance closets, boiler rooms, garbage compactor or receptacle rooms, management offices or laundry facilities. | | <input type="checkbox"/> |
| Total Number of Bedrooms | N/A(Optional) | Is this the total number of bedrooms located in each individual apartment unit? This should include any additions to the original floor plan performed by the owner. This should exclude in-unit common areas being used as bedrooms by tenants. | | <input type="checkbox"/> |
| Number of Floors | N/A(Optional) | Is this the total number of floors located within a Multifamily Housing Building? This number should include the total number of floors above the existing grade plane. This number should exclude interstitial space between floors or the roof. | | <input type="checkbox"/> |
| Percent of square footage devoted to individual units | N/A(Optional) | Is this the percentage of square footage that is devoted to occupied and unoccupied apartment units? | | <input type="checkbox"/> |
| Laundry in each unit | N/A(Optional) | Is this the total number of laundry hookups located in each individual apartment unit? The laundry facility should be accounted for if the machine is inoperable, operable or if there is a laundry hookup available. | | <input type="checkbox"/> |
| Laundry in common area | N/A(Optional) | Is this the number of laundry hookups located in a common area that are either coin-operated or subsidized by the building owner? The laundry facility should be accounted for if the machine is inoperable, operable or if there is a laundry hookup available. | | <input type="checkbox"/> |

| | | | |
|--|---------------|---|--------------------------|
| Dishwashers in each unit | N/A(Optional) | Is this the total number of dishwashers located in individual apartment units? The dishwasher should be accounted for if the machine is inoperable, operable or if there is a dishwasher hookup available. | <input type="checkbox"/> |
| Percent Heated | N/A(Optional) | Is this the percentage of the total floor space within the facility that is served by mechanical heating equipment? This includes the individual apartment units that are individually mechanically heated. The percent heated cannot be greater than 100%. The percent heated attribute is similar to the percent heated attribute for dormitories. The user should select from a drop-down-menu with options presented in bins of 10 (i.e. 0, 10, 20, 30?). | <input type="checkbox"/> |
| Percent Cooled | N/A(Optional) | Is this the percentage of the total floor space within the facility that is served by mechanical cooling equipment? This includes the individual apartment units that are individually mechanically cooled. The percent cooled cannot be greater than 100%. The percent cooled attribute is similar to the percent cooled attribute for dormitories. The user should select from a drop-down-menu with options presented in bins of 10 (i.e. 0, 10, 20, 30?). | <input type="checkbox"/> |
| Market Rate or Affordable Housing | N/A(Optional) | Select Affordable Housing when a Multifamily Housing building is regulated by a national, state or local housing agency and offers subsidized housing to lower and moderate income range households. Select Market Rate when a Multifamily Housing building has either no subsidized units or minimal units with allocated subsidies. | <input type="checkbox"/> |

ENERGY STAR® Data Checklist for Commercial Buildings

Energy Consumption

Power Generation Plant or Distribution Utility: PSE&G - Public Service Elec & Gas Co

| Fuel Type: Electricity | | |
|--|------------|--|
| Meter: Electricity (kWh (thousand Watt-hours)) Space(s): Entire Facility | | |
| Start Date | End Date | Energy Use (kWh (thousand Watt-hours)) |
| 03/31/2009 | 04/29/2009 | 123,854.00 |
| 02/24/2009 | 03/30/2009 | 140,558.00 |
| 01/28/2009 | 02/23/2009 | 109,558.00 |
| 12/31/2008 | 01/27/2009 | 119,739.00 |
| 12/04/2008 | 12/30/2008 | 115,143.00 |
| 11/01/2008 | 12/03/2008 | 147,737.00 |
| 10/03/2008 | 10/31/2008 | 119,970.00 |
| 09/04/2008 | 10/02/2008 | 132,462.00 |
| 08/05/2008 | 09/03/2008 | 158,087.00 |
| 07/04/2008 | 08/04/2008 | 198,280.00 |
| 06/05/2008 | 07/03/2008 | 161,676.00 |
| Electricity Consumption (kWh (thousand Watt-hours)) | | 1,527,064.00 |
| Electricity Consumption (kBtu) | | 5,210,342.37 |
| Total Electricity Consumption (kBtu) | | 5,210,342.37 |
| Is this the total Electricity consumption at this building including all Electricity meters? | | <input type="checkbox"/> |

| Fuel Type: Natural Gas | | |
|--|------------|---------------------|
| Meter: Natural Gas 2415033 (therms) Space(s): Entire Facility | | |
| Start Date | End Date | Energy Use (therms) |
| 03/31/2009 | 04/29/2009 | 2,869.00 |
| 02/24/2009 | 03/30/2009 | 3,684.00 |
| 01/28/2009 | 02/23/2009 | 2,965.00 |
| 12/31/2008 | 01/27/2009 | 2,847.00 |
| 12/04/2008 | 12/30/2008 | 2,705.00 |
| 11/04/2008 | 12/03/2008 | 2,602.00 |
| 10/03/2008 | 11/03/2008 | 2,414.00 |
| 09/04/2008 | 10/02/2008 | 1,812.00 |
| 08/05/2008 | 09/03/2008 | 1,646.00 |
| 07/04/2008 | 08/04/2008 | 1,674.00 |

| | | |
|--|-----------------|----------------------------|
| 06/05/2008 | 07/03/2008 | 1,813.00 |
| Natural Gas 2415033 Consumption (therms) | | 27,031.00 |
| Natural Gas 2415033 Consumption (kBtu) | | 2,703,100.00 |
| Meter: Natural Gas - 2600157 (therms) Space(s): Entire Facility | | |
| Start Date | End Date | Energy Use (therms) |
| 03/31/2009 | 04/29/2009 | 12,291.00 |
| 02/24/2009 | 03/30/2009 | 26,570.00 |
| 01/28/2009 | 02/23/2009 | 21,928.00 |
| 12/31/2008 | 01/27/2009 | 25,071.00 |
| 12/04/2008 | 12/30/2008 | 22,379.00 |
| 11/04/2008 | 12/03/2008 | 22,647.00 |
| 10/03/2008 | 11/03/2008 | 10,761.00 |
| 09/04/2008 | 10/02/2008 | 0.00 |
| 08/05/2008 | 09/03/2008 | 0.00 |
| 07/04/2008 | 08/04/2008 | 0.00 |
| 06/05/2008 | 07/03/2008 | 0.00 |
| Natural Gas - 2600157 Consumption (therms) | | 141,647.00 |
| Natural Gas - 2600157 Consumption (kBtu) | | 14,164,700.00 |
| Total Natural Gas Consumption (kBtu) | | 16,867,800.00 |
| Is this the total Natural Gas consumption at this building including all Natural Gas meters? | | <input type="checkbox"/> |

| | |
|--|--------------------------|
| Additional Fuels | |
| Do the fuel consumption totals shown above represent the total energy use of this building? Please confirm there are no additional fuels (district energy, generator fuel oil) used in this facility. | <input type="checkbox"/> |

Certifying Professional

(When applying for the ENERGY STAR, this must be the same PE that signed and stamped the SEP.)

Name: _____ Date: _____

Signature: _____

Signature is required when applying for the ENERGY STAR.

FOR YOUR RECORDS ONLY. DO NOT SUBMIT TO EPA.

Please keep this Facility Summary for your own records; do not submit it to EPA. Only the Statement of Energy Performance (SEP), Data Checklist and Letter of Agreement need to be submitted to EPA when applying for the ENERGY STAR.

Facility

Lawler
6121 Grand Ave
North Bergen, NJ 07047

Facility Owner

North Bergen Housing Authority
6121 Grand Ave.
North Bergen, NJ 07047

Primary Contact for this Facility

Ryan Leggio
6121 Grand Ave.
North Bergen, NJ 07047

General Information

| Lawler | |
|--|--------------|
| Gross Floor Area Excluding Parking: (ft ²) | 191,100 |
| Year Built | 1968 |
| For 12-month Evaluation Period Ending Date: | May 31, 2009 |

Facility Space Use Summary

| Edward A. Lawler Towers | |
|--|---------------------|
| Space Type | Multifamily Housing |
| Gross Floor Area(ft ²) | 191,100 |
| Number of units ^a | N/A |
| Total Number of Bedrooms ^a | N/A |
| Number of Floors ^a | N/A |
| Percent of square footage devoted to individual units ^a | N/A |
| Laundry in each unit ^a | N/A |
| Laundry in common area ^a | N/A |
| Dishwashers in each unit ^a | N/A |
| Percent Heated ^a | N/A |
| Percent Cooled ^a | N/A |
| Market Rate or Affordable Housing ^a | N/A |

Energy Performance Comparison

| Performance Metrics | Evaluation Periods | | Comparisons | | |
|---|-------------------------------------|--------------------------------------|--------------|--------|------------------|
| | Current (Ending Date 05/31/2009) | Baseline (Ending Date 04/30/2009) | Rating of 75 | Target | National Average |
| Energy Performance Rating | N/A | N/A | 75 | N/A | N/A |
| Energy Intensity | | | | | |
| Site (kBtu/ft ²) | 119 | 120 | 0 | N/A | N/A |
| Source (kBtu/ft ²) | 193 | 194 | 0 | N/A | N/A |
| Energy Cost | | | | | |
| \$/year | \$ 439,731.78 | \$ 442,228.80 | N/A | N/A | N/A |
| \$/ft ² /year | \$ 2.30 | \$ 2.31 | N/A | N/A | N/A |
| Greenhouse Gas Emissions | | | | | |
| MtCO ₂ e/year | 1,845 | 1,853 | 0 | N/A | N/A |
| kgCO ₂ e/ft ² /year | 10 | 10 | 0 | N/A | N/A |

Because more than 50% of your building is Multifamily Housing, your building is designated as Multifamily Housing within Portfolio Manager. This type of building is not eligible for an energy performance rating and does not have a reference national average.

Notes:

o - This attribute is optional.

d - A default value has been supplied by Portfolio Manager.

APPENDIX X

New Jersey Pay for Performance Incentives

| Incentive Structure for NJ Pay For Performance Program | | | |
|--|---------------------------------------|--|---------------------------------------|
| Incentive #1: Energy Reduction Plan | | | |
| Incentive Amount: | | \$0.10 | per sq ft |
| Minimum Incentive: | | \$5,000 | |
| Maximum Incentive: | | \$50,000 | or 50% of facility annual energy cost |
| This incentive will be developed to offset the cost of services associated with the development of the Energy Reduction Plan. Projects must identify efficiency improvements that meet the minimum performance level in order to become eligible for Incentive #1. Incentive amount will be based on the square footage of the building. | | | |
| Incentive #2: Installation of Recommended Measures | | | |
| Minimum Performance Target: | | 15% | |
| Electric Incentives | Base Incentive based on 15% savings: | \$0.11 | per projected kWh saved |
| | For each % over 15% add: | \$0.005 | |
| | Maximum Incentive: | \$0.13 | |
| Gas Incentives | Base Incentive based on 15 % savings: | \$1.10 | per projected Therm saved |
| | For each % over 15% add: | \$0.05 | |
| | Maximum Incentive: | \$1.45 | |
| Incentive Cap: | | 30% | of total project cost |
| This incentive will be based on projected energy savings and designed to pay approximately 60% of the total performance-based incentive. Savings projections will be calculated using calibrated energy simulation and rounded to the nearest percent. Incentive #2 may not exceed 30% of the total project cost. | | | |
| Incentive #3: Post-Construction Benchmarking Report | | | |
| Minimum Performance Target: | | 15% | |
| Electric Incentives | Base Incentive based on 15% savings: | \$0.07 | per projected kWh saved |
| | For each % over 15% add: | \$0.005 | |
| | Maximum Incentive: | \$0.09 | |
| Gas Incentives | Base Incentive based on 15% savings: | \$0.70 | per projected Therm saved |
| | For each % over 15% add: | \$0.05 | |
| | Maximum Incentive: | \$1.05 | |
| Incentive Cap: | | 20% | of total project cost |
| This incentive will be released upon submittal of a Post-Construction Benchmarking Report that verifies that the level of savings actually achieved by the installed measures meets or exceeds the minimum performance threshold. To validate the savings and achievement of the Energy Target, the EPA Portfolio Manager shall be used. Savings should be rounded to the nearest percent. Total value of Incentive #2 and Incentive #3 may not exceed 50% of the total project cost. This incentive will "true up" proposed savings and the related payment for Incentive #2 so that the total incentive is based on actual savings. For buildings not covered by EPA, the process used by LEED EB shall be followed. | | | |
| Advanced Measure Incentive: Combined Heat and Power | | | |
| Eligible Technology | | Incentive (per Watt) Max: \$1 Million | Maximum % of Project Cost |
| Level 1: | | | |
| Fuel cells not fueled by Class I renewable fuel | | \$4.00 | 60% |
| Level 2: | | | |
| Microturbines | | \$1.00 | 30% ⁽¹⁾ |
| Internal Combustion Engines | | | |
| Combustion Turbines | | | |
| Level 3: | | | |
| Heat Recovery or Other Mechanical Recovery from Existing | | \$0.50 | 30% |
| ⁽¹⁾ The maximum % of project cost will go to 40% where a cooling application is used or included with the CHP system. | | | |
| Note: Incentives for renewable fueled projects (Class1) are currently being developed. This document will be updated when the incentive levels are finalized. | | | |

Effective through December 31st 2009

Pay for Performance projects for the FIVE(5) customer classes listed below will be eligible for increased incentive levels:

- Hospitals
- Non-profits
- Public colleges/universities
- Governmental entities not receiving Energy Efficiency and Conservation Block Grants (EECBG)
- Affordable multifamily housing ("affordable" is defined as low income, subsidized, HUD, etc.)

Increased incentive levels are as follows:

- Incentive #2: If a reduction in energy consumption of 20% or more is projected, above listed customers will be eligible for an additional \$0.11/kWh and \$1.10/therm.
- Incentive #3: If a reduction in energy consumption of 20% or more is achieved, above listed customers will be eligible for an additional \$0.07/kWh and \$0.70/therm.
- Incentive #2 and #3 combined may not exceed 80% of the total project cost.
- Incentive cap is \$2million per gas account and \$2million per electric account.
- 200kW threshold is not required

In order to take advantage of this opportunity Partners must submit the following by December 31st 2009:

- A signed P4P Initial Application, including
 - W9
 - 12 months utility bills
- Copy of Partner-Participant Contract
- EPA Portfolio Benchmarking results (may be print out)
- Cover letter indicating
 - The modeling software to be used in developing ERP
 - Type of customer class

Partners that have already submitted Initial Applications for eligible customer classes will be allowed to take advantage of the increased incentive levels.

Thank You,

Pay for Performance Program Update (TMC)

Original Program:

Structure Needs to be over 200 kW average monthly load

Structure saves more than 15% MMBTU (EPA Portfolio Manager)

| | 15% | Over 20% | 15% | Over 20% |
|-------------------------|--------|----------|----------------|------------------------------|
| Incentive #1 | \$0.10 | | | |
| | kWh | | Therm | |
| Min \$5000 Max \$50,000 | | | | |
| Incentive #2 | \$0.11 | 0.005 | Per % over 15% | \$1.10 0.05 Per % over 15% |
| 30% of Project Cost Cap | | | | |
| Incentive #3 | \$0.07 | 0.005 | Per % over 15% | \$0.70 0.05 Per % over 15% |
| 20% of Project Cost Cap | | | | |
| Incentive #2 & #3 | \$0.18 | 0.01 | Per % over 15% | \$1.80 \$0.10 Per % over 15% |
| 50% of Project Cost Cap | | | | |

Updated program till Dec 31st 2009

200 avg kW Requirement dropped

Structure saves more than 20% MMBTU (EPA Portfolio Manager)

Incentive Cap \$2 million per gas account and \$2 million per electric account

| | 15% | Over 20% | 15% | Over 20% |
|---|--------|----------|----------------|-------------------------|
| Incentive #1 | \$0.10 | | | |
| | kWh | | Therm | |
| Min \$5000 Max \$50,000 | | | | |
| Incentive #2 | \$0.22 | 0 | Per % over 15% | \$2.20 0 Per % over 15% |
| | | | | |
| Incentive #3 | \$0.14 | 0 | Per % over 15% | \$1.40 0 Per % over 15% |
| | | | | |
| Incentive #2 & #3 | \$0.36 | 0 | Per % over 15% | \$3.60 0 Per % over 15% |
| Incentive #2 & #3 not to exceed 80% of Project Cost | | | | |

APPENDIX Y

Equipment Inventory

North Bergen Housing Authority
CHA Project No. 20241
Lawler Tower Apartments
Equipment Inventory

| Description | Manufacturer Name | Model No. | Equipment Type | Capacity/Size | Location | Date Installed | Useable Life Expectancy | Other Info. |
|---|-------------------|----------------------------------|--|--|----------------------------------|----------------|-------------------------|--|
| HW Boiler #1 | PVI | Nickelshield Model 1400N-250A-PV | Condensing Hot Water Boiler | 1 MMBtu/hr (input) Natural Gas | Lawler Tower A - Boiler Room | 1990 | | |
| HW Boiler #2 | PVI | Nickelshield Model 1400N-250A-PV | Condensing Hot Water Boiler | 1 MMBtu/hr (input) Natural Gas | Lawler Tower A - Boiler Room | 1990 | | |
| HW Boiler #3 | PVI | Nickelshield Model 1400N-250A-PV | Condensing Hot Water Boiler | 1 MMBtu/hr (input) Natural Gas | Lawler Tower A - Boiler Room | 1990 | | |
| LPS Boiler #1 | Kewanee | LS3-125-G04 | Low Pressure Steam Boiler | Output - 4184 MBH Natural Gas | Lawler Tower A - Boiler Room | 1990 | | |
| LPS Boiler #2 | Kewanee | LS3-125-G04 | Low Pressure Steam Boiler | Output - 4184 MBH Natural Gas | Lawler Tower A - Boiler Room | 1990 | | |
| Heat Pump #1 | Daikin | RZQ42MVJU | Heat Pump - Heating / Cooling Unit | Cooling Input - 4.8 KW, Cooling Output - 40,500 BTUH, Heating Input - 4.15 KW, Heating Output - 41,500 BTUH | Community Room | Aug-08 | | |
| Heat Pump #2 | Daikin | RZQ42MVJU | Heat Pump - Heating / Cooling Unit | Cooling Input - 4.8 KW, Cooling Output - 40,500 BTUH, Heating Input - 4.15 KW, Heating Output - 41,500 BTUH | Community Room | Aug-08 | | |
| Heat Pump #3 | Daikin | RZQ42MVJU | Heat Pump - Heating / Cooling Unit | Cooling Input - 4.8 KW, Cooling Output - 40,500 BTUH, Heating Input - 4.15 KW, Heating Output - 41,500 BTUH | Community Room | Aug-08 | | |
| Heat Pump #4 | Daikin | RZQ42MVJU | Heat Pump - Heating / Cooling Unit | Cooling Input - 4.8 KW, Cooling Output - 40,500 BTUH, Heating Input - 4.15 KW, Heating Output - 41,500 BTUH | Community Room | Aug-08 | | |
| Air Conditioning Unit #1 | Mitsubishi | PL24AK / EK | Split Air Conditioning Unit | 24,000 BTUH Cooling Capacity | Basement - Document Storage Room | | | |
| Air Conditioning Unit #2 | Mitsubishi | PL24AK / EK | Split Air Conditioning Unit | 24,000 BTUH Cooling Capacity | Basement - Document Storage Room | | | |
| Emergency Generator | Cummins | DGAB-5632283 (S/N J 030552367) | Emergency Generator | 230 kW - Diesel Fuel | West Side - Community Room | | | automatically exercised once per week for 1-hr |
| R.T.U. #1 | Trane | YCC024F1L0BJ | Package Rooftop Unit | 24,000 BTUH Cooling Capacity | Directors Office Roof | Oct-05 | | |
| Air Conditioning Unit w/ Remote Air Cooled Condenser #1 | York | H5DB048S06A | Split Air Conditioning Unit with remote air cooled condenser. Electric Reheat. | 48,000 BTUH Cooling Capacity R22 - 6 lb, 0 oz | NBHA Offices | | | Condenser on the west side of Tower A. |
| Air Conditioning Unit w/ Remote Air Cooled Condenser #2 | York | H4DB060S06A | Split Air Conditioning Unit with remote air cooled condenser. Electric Reheat. | 60,000 BTUH Cooling Capacity R22 - 8 lb, 0 oz | NBHA Offices | | | Condenser on the west side of Tower A. |
| Air Conditioning Unit w/ Remote Air Cooled Condenser #3 | York | H5DB048S06A | Split Air Conditioning Unit with remote air cooled condenser. Electric Reheat. | 48,000 BTUH Cooling Capacity R22 - 6 lb, 0 oz | NBHA Offices | | | Condenser on the west side of Tower A. |

North Bergen Housing Authority
CHA Project No. 20241
Lawler Tower Apartments
Equipment Inventory

| Description | Manufacturer Name | Model No. | Equipment Type | Capacity/Size | Location | Date Installed | Useable Life Expectancy | Other Info. |
|---|-----------------------|-------------------|--|--|---|----------------|-------------------------|---|
| Air Conditioning Unit w/ Remote Air Cooled Condenser #4 | York | H5DB048S06A | Split Air Conditioning Unit with remote air cooled condenser. Electric Reheat. | 48,000 BTUH Cooling Capacity R22 - 5 lb, 11 oz | NBHA Offices | | | Condenser on the west side of Tower A. |
| Air Conditioning Unit w/ Remote Air Cooled Condenser #5 | York | H4DB036S06A | Split Air Conditioning Unit with remote air cooled condenser. Electric Reheat. | 36,000 BTUH Cooling Capacity | NBHA Offices (Air Handler #5) | | | Condenser on the west side of Tower A. |
| Air Conditioning Unit w/ Remote Air Cooled Condenser #5 | Sanyo | KSO9051 | Split Air Conditioning Unit with remote air cooled condenser. Wall mounted evaporator. | 9,000 BTUH Cooling Capacity | NBHA Offices - Server Room | Apr-05 | | |
| Bathroom Exhaust Fan | Loren Cook | 100 ACEH 100C10DH | Ceiling Mounted | 0.04 Hp | NBHA Offices - Conference Room Bathroom | | | |
| Bathroom Exhaust Fan | Fan Tech Turbo Flo | TBD 11 | Ceiling Mounted | 0.25 Hp | NBHA Offices - Directors Bathroom | Sep-05 | | |
| Clothes Washers (10) | Speed Queen | SWFF61WN | Front Loading Clothes Washer | | Tower A - First Floor | | | Typical of ten (10) units. |
| Clothes Dryers (10) | Speed Queen | STT30NNRB2G1W01 | Front Loading Clothes Dryer | N.G. input - 146,00 Btu/hr | Tower A - First Floor | | | Typical of ten (10) units. |
| Unit Heater | Reznor | V3TCOR52 | Gas Fired Unit Heater | Used to heat intake air to Speed Queen Dryers. Natural Gas. | Plenum behind dryers. | | | 1/20 fan H.P. |
| Roof Exhaust Fan | Greenheck | GB-100-4 | Roof Mounted; Belt Driven Centrifugal Exhaust Fan. | 1/4 H.P.; .25" W.C.; 1,100 CFM | Roof of Tower A | 1968 | | OFF |
| Roof Exhaust Fan | Greenheck | GB-240-7 | Roof Mounted; Belt Driven Centrifugal Exhaust Fan. | 3/4 H.P.; .25" W.C.; 5,500 CFM | Roof of Tower A | 1968 | | ON |
| Roof Exhaust Fan | Greenheck | GB-121-4x-QD | Roof Mounted; Belt Driven Centrifugal Exhaust Fan. | 1/4 H.P.; .25" W.C.; 1,200 CFM | Roof of Tower A | 1968 | | ON |
| Roof Exhaust Fans (2) | Greenheck | GB-120-4x-QD | Roof Mounted; Belt Driven Centrifugal Exhaust Fan. | 1/4 H.P.; .25" W.C.; 1,200 CFM | Roof of Tower A | 1968 | | ON |
| Roof Exhaust Fan | Greenheck | GB-101-4x-QD-R3 | Roof Mounted; Belt Driven Centrifugal Exhaust Fan. | 1/4 H.P.; .25" W.C.; 1,100 CFM | Roof of Tower A | 1968 | | ON |
| Roof Exhaust Fan | Greenheck | GB-180-4 | Roof Mounted; Belt Driven Centrifugal Exhaust Fan. | 1/4 H.P.; .25" W.C.; 4,000 CFM | Roof of Tower A | 1968 | | ON |
| Roof Exhaust Fan | Greenheck | GB-100-4 | Roof Mounted; Belt Driven Centrifugal Exhaust Fan. | 1/4 H.P.; .25" W.C.; 1,100 CFM | Roof of Tower B | 1968 | | ON, but not blowing (belt issue?) |
| Roof Exhaust Fan | Greenheck | GB-240-7 | Roof Mounted; Belt Driven Centrifugal Exhaust Fan. | 3/4 H.P.; .25" W.C.; 5,500 CFM | Roof of Tower B | 1968 | | OFF |
| Roof Exhaust Fan | Greenheck | GB-121-4x-QD | Roof Mounted; Belt Driven Centrifugal Exhaust Fan. | 1/4 H.P.; .25" W.C.; 1,200 CFM | Roof of Tower B | 1968 | | ON, but not blowing (belt issue?) |
| Roof Exhaust Fans (2) | Greenheck | GB-120-4x-QD | Roof Mounted; Belt Driven Centrifugal Exhaust Fan. | 1/4 H.P.; .25" W.C.; 1,200 CFM | Roof of Tower B | 1968 | | ON |
| Roof Exhaust Fan | Greenheck | GB-90-4x-QD | Roof Mounted; Belt Driven Centrifugal Exhaust Fan. | 1/4 H.P.; .25" W.C.; 1,100 CFM | Roof of Tower B | 1968 | | OFF |
| Roof Exhaust Fan | Greenheck | GB-130-4x-QD | Roof Mounted; Belt Driven Centrifugal Exhaust Fan. | 1/4 H.P.; .25" W.C.; 4,000 CFM | Roof of Tower B | 1968 | | ON |

North Bergen Housing Authority
CHA Project No. 20241
Lawler Tower Apartments
Equipment Inventory

| Description | Manufacturer Name | Model No. | Equipment Type | Capacity/Size | Location | Date Installed | Useable Life Expectancy | Other Info. |
|-----------------------------------|-------------------|-----------|--|--|------------------------|----------------|-------------------------|-------------|
| Tower A East Elevator Drive Motor | MAG - Magol Corp. | | Open Drip Proof Motor; VFD Driven. | 20 H.P.; 1180 RPM; 230/460V; 3 PH.; 60 Hz.; 91% Efficiency | Roof Mechanical Room | 2008 | | New motor |
| Tower A West Elevator Drive Motor | MAG - Magol Corp. | | Open Drip Proof Motor; VFD Driven. | 20 H.P.; 1180 RPM; 230/460V; 3 PH.; 60 Hz.; 91% Efficiency | Roof Mechanical Room | 2008 | | New motor |
| Tower B East Elevator Drive Motor | MAG - Magol Corp. | | Open Drip Proof Motor; VFD Driven. | 20 H.P.; 1180 RPM; 230/460V; 3 PH.; 60 Hz.; 91% Efficiency | Roof Mechanical Room | 2008 | | New motor |
| Tower B West Elevator Drive Motor | MAG - Magol Corp. | | Open Drip Proof Motor; VFD Driven. | 20 H.P.; 1180 RPM; 230/460V; 3 PH.; 60 Hz.; 91% Efficiency | Roof Mechanical Room | 2008 | | New motor |
| Vending | | | Snacks | | Community Room | | | |
| Vending | | | Pepsi | | Community Room | | | |
| Vending | | | Pepsi | | Community Room | | | |
| Vending | | | Snapple | | Community Room | | | |
| Refrigerator | Holpoint | ZF732500 | Vertical Type | 15 C.F. | Office Kitchen | | | |
| Refrigerator | Holpoint | ZF732500 | Vertical Type | 15 C.F. | Community Room Kitchen | | | |
| Refrigerator | Holpoint | CTF14CG | Vertical Type | 14.2 C.F. | Community Room Kitchen | | | |
| Window Air Conditioning Units | Various | Various | Window Mounted Air Conditioning Units. | Various - 5,000 BTUH to 10,000 BTUH | Tower Apartments | Various | Various | |

Lawler Towers - Building 6131

| Apartment # | # Bedrooms | Heating Type | Appliances | Washer/Dryer | Kitchen Equipment | Windows/Doors | Air Conditioning | Thermostats | Exhaust Fans | Lighting |
|---|------------|----------------|---|----------------|--|---|---|-------------|------------------------|--|
| 1A | 1 | Steam Fin Tube | Desktop Computer, (2)Cable Boxes, (2)Med.TVs, Alarm Clock, Box Fan | Common Laundry | GE Spacemaker Stove Mod.# JAS030H1WH 10.4 kW, GE Fridge Mod.# GTS16BBSARWW 6.5A, Sm. Microwave, Toaster, Coffee Pot | 3/4" Commercial Grade Double Glazed in Good Condition | (2) 7500BTU 10.0EER | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (3)2CF23 1SW EA, W17WFI-E (T8) Plug-In, 2I60 Plug-In |
| 1B | 3 | Steam Fin Tube | Fish Tank, (2)Desktop Computers, Printer, Lg. TV, Sm. TV, Med. TV, (3)Cable Boxes, (2)DVD, XBOX 360, Window Fan | Common Laundry | New GE 4-Burner Digital Control Stove, New GE Mod.# GTH22SBNARBS 11.6A Fridge, G.Foreman Grill, Coffee Pot, Toaster, Sm. Microwave | 3/4" Commercial Grade Double Glazed in Good Condition | (1) Amana: 7500BTU (1)Sunbeam: 5000BTU, 9.7EER (1)LG: 10000BTU 9.8EER | None | Central Exhaust System | 2CF23WallM-Dual SW, W34CF2-Mag(T12)SW, 5CF23: 4 on Med. Cabinet, 1 Clg. Mt. on one SW, (3) I40 Plug-In, 1CF13 & (2)2CF23 Plug-In |
| 1F | 1 | Steam Fin Tube | Recip. Fan, Ans. Mach., Med. TV, (2) DTV Cable Converter, DVD, Lg Stereo, Sm. TV | Common Laundry | Premier Stove Mod.#EAK220WP01 8,800W, Sears Fridge Mod.#2538692310 3.75A, Med. Microwave, Toaster, Coffee Maker, Coffee Grinder | 3/4" Commercial Grade Double Glazed in Good Condition | (2) Fedders: 6000BTU 9.7EER | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (3)2CF23 1SW EA, W17WFI-E (T8) Plug-In, 2I60 Plug-In |
| 1G *Moisture Problems due to Poor Ventilation | 1 | Steam Fin Tube | Med. TV, Cable Box, Sm. Radio, Alarm Clk. | Common Laundry | GE Spacemaker Stove Mod.# J243705WH 9.5kW, 220V, Old GE Energy Star Fridge, Sm. Microwave, Toaster | 3/4" Commercial Grade Double Glazed in Good Condition | Old Emerson Quiet Cool Window Low EER | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (3)2CF23 1SW EA, I60 on Bedrm SW, (4) I60 Plug-Ins |
| 2A | 0 | Steam Fin Tube | (2)Med. TV, SM. TV, Sm. Radio, Cable Box, DVD/VCR, VCR | Common Laundry | GE Fridge Mod.# GTS16BBSARWW 6.5A, Kenmore 4-Burner Stove, Sm. Microwave, Coffee Pot, Toaster | 3/4" Commercial Grade Double Glazed in Good Condition | Old GE Window 8000BTU 10.0EER | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (3)2CF23 1SW EA, I60 on Bedrm SW, (2) I60 Plug-Ins |
| 2B | 0 | Steam Fin Tube | Recip. Fan (2)Med. TV, SM. TV, Sm. Radio, (2)Cable Box, DVD/VCR, VCR | Common Laundry | GE Fridge Mod.# GTS16BBSARWW 6.5A, Kenmore 4-Burner Stove, Med. Microwave, Coffee Pot, Toaster, Croc Pot | 3/4" Commercial Grade Double Glazed in Good Condition | 6000BTU 9.7EER | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (3)2CF23 1SW EA, (3) I60 Plug-Ins |

Lawler Towers - Building 6131

| Apartment # | # Bedrooms | Heating Type | Appliances | Washer/Dryer | Kitchen Equipment | Windows/Doors | Air Conditioning | Thermostats | Exhaust Fans | Lighting |
|-------------|------------|----------------|---|----------------|---|---|---|-------------|---|---|
| 2D | 0 | Steam Fin Tube | Sm. RCA TV, Breathing Machine Cable Box | Common Laundry | Kanmore Fridge Mod.# 2539333010 3.75A, Smaller Kenmore Stove, Toaster, Sm. Microwave | 3/4" Commercial Grade Double Glazed in Good Condition | Frigidaire 6000BTU Low EER | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (3)2CF23 1SW EA, (3)2CF23 1SW EA, |
| 2F | 0 | Steam Fin Tube | (2)Med. TV, SM. TV, Sm. Radio, Cable Box, DVD/VCR, VCR | Common Laundry | GE Fridge Mod.# GTS16BBSARWW 6.5A, Kenmore 4-Burner Stove, Sm. Microwave, Coffee Pot, Toaster | 3/4" Commercial Grade Double Glazed in Good Condition | Old GE Window 8000BTU 10.0EER | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (3)2CF23 1SW EA, I60 on Bedrm SW, (2) I60 Plug-Ins |
| 2J | 0 | Steam Fin Tube | (2) SM. TV, Cable Box, Recip Fan | Common Laundry | Kenmore Fridge Mod.# 2539333010 3.75A, Smaller Kenmore Stove, Toaster, Sm. Microwave, Coffee Pot, Toaster Oven | 3/4" Commercial Grade Double Glazed in Good Condition | 7500BTU Low EER | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (3)2CF23 1SW EA, (2)75 Plug-Ins |
| 2K | 2 | Steam Fin Tube | Water Cooler, Air Cleaner, Med. TV, Sm. TV, (2) Cable Boxes, (2)Sm. Radios, Recip. Pedestal Fan | Common Laundry | LG Magic Chef 4-Burner Stove, Hotpoint Fridge Mod.# HTR16ABSERWW 6.5A, Blender, (2)Coffee Pots, Toaster, Med. Microwave | 3/4" Commercial Grade Double Glazed in Good Condition | (1)GE Window: 10500BTU 9.8EER (1)Frigidaire: 7500BTU 10EER | None | Central Exhaust System, Range Hood: GE Mod.# JN3220V1WH | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (3)2CF23 1SW EA, I150 Plug-In, (2)I40 Plug-In |
| 3A | 1 | Steam Fin Tube | Med. TV, Cable Box, VCR, Answering Machine, Recip. Fan, Alarm Clk. | Common Laundry | Magic Chef 4-Burner Stove, Old GE Fridge, Sm. Microwave | 3/4" Commercial Grade Double Glazed in Good Condition | Whirlpool Window 7500BTU Low EER | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (3)2CF23 1SW EA, (5)I60 Plug-Ins |
| 3B | 1 | Steam Fin Tube | Sm. TV, Cable Box, (2) Answering Machines | Common Laundry | GE Spacemaker Stove Mod.# JAS030H1WH 10.4 kW, GE Fridge Mod.# GTS16BBSARWW 6.5A, Sm. Microwave, Toaster Oven, Toaster, Coffee Pot | 3/4" Commercial Grade Double Glazed in Good Condition | Whirlpool Window 10000BTU Low EER | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (3)2CF23 1SW EA, (3)I60 Plug-Ins, 3I60 Plug-In |

Lawler Towers - Building 6131

| Apartment # | # Bedrooms | Heating Type | Appliances | Washer/Dryer | Kitchen Equipment | Windows/Doors | Air Conditioning | Thermostats | Exhaust Fans | Lighting |
|-------------|------------|----------------|--|----------------|--|---|-------------------------------------|-------------|------------------------|---|
| 3C | 1 | Steam Fin Tube | Med. TV, (2)Cable Boxes, DVD, Sm. TV, Alarm Clock | Common Laundry | Hotpoint Fridge Mod.# HTR16ABSERWW 6.5A, Premier Stove Mod.#EAK220WP01 8,800W, Toaster Oven | 3/4" Commercial Grade Double Glazed in Good Condition | Whirlpool Window 7500BTU Low EER | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (3)2CF23 1SW EA, (3)75 Plug-Ins |
| 3D | 0 | Steam Fin Tube | Lg. TV, Cable Box, DVD/VCR, Alarm Clock | Common Laundry | Hotpoint Fridge Mod.# HTR16ABSERWW 6.5A, Premier Stove Mod.#EAK220WP01 8,800W, Toaster Oven | 3/4" Commercial Grade Double Glazed in Good Condition | 7500BTU Low EER | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (3)2CF23 1SW EA, (2)75 Plug-Ins |
| 3E | 1 | Steam Fin Tube | (2) Sm. TV, Cable Box | Common Laundry | GE Spacemaker Stove Mod.# JAS030H1WH 10.4 kW, GE Fridge Mod.# GTS16BBSARWW 6.5A, Sm. Microwave, Toaster, Coffee Pot | 3/4" Commercial Grade Double Glazed in Good Condition | Daewoo Mod#DWC121C 12100BTU 10.1EER | None | Central Exhaust System | W32CF4-E(T8) Dual SW (2 Lamps Out), W20CF1-Mag(T12)SW, (3)2CF23 1SW EA, (3)60 Plug-Ins |
| 3F | 1 | Steam Fin Tube | Med. TV, DVD/VCR, (2)Cable Boxes, Sm. Radio, Pencil Sharpener, Sm. TV | Common Laundry | Hotpoint Fridge Mod.# HTR16ABSERWW 6.5A, New Hotpoint 4-Burner Stove | 3/4" Commercial Grade Double Glazed in Good Condition | Old Airtemp Window 10000BTU Low EER | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (3)2CF23 1SW EA, (4)150 Plug-Ins |
| 3G | 1 | Steam Fin Tube | (2)Desktop Computers, Net Modem, (2)Sm. Radios, Lg. TV, Cable Box, DVD, Ans. Machine, (2)Recip Fans, Lg. Stereo, Sm TV | Common Laundry | Hotpoint Fridge Mod.# HTH15ABSERWW 4A, GE Stove Mod.# JAS030H1WH 10.4 kW, Med. Microwave, Toaster Oven, Croc Pot, Espresso Maker, Coffee Pot | 3/4" Commercial Grade Double Glazed in Good Condition | Samsung Window 5200BTU 9.8EER | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (2)2CF23 1SW EA, W17WF1-E(T8) SW, (2)60 Plug-Ins, (2)CF23 Plug-Ins |
| 3H | 1 | Steam Fin Tube | Lg. TV, Cable Box, SM. TV, DVD, Record Player, Alarm Clock | Common Laundry | Premier Stove Mod.#EAK220WP01 8,800W, Old GE Energy Saver Fridge, Sm. Microwave, Coffee Pot, Toaster Oven, Croc Pot | 3/4" Commercial Grade Double Glazed in Good Condition | LG Window 8000BTU | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (3)2CF23 1SW EA, (2)60 Plug-Ins |

Lawler Towers - Building 6131

| Apartment # | # Bedrooms | Heating Type | Appliances | Washer/Dryer | Kitchen Equipment | Windows/Doors | Air Conditioning | Thermostats | Exhaust Fans | Lighting |
|-------------|------------|----------------|--|----------------|---|---|-----------------------------------|-------------|------------------------|---|
| 3J | 0 | Steam Fin Tube | Med. TV, Cable Box, Recip. Fan, Alarm Clock, DVD | Common Laundry | GE Spacemaker Stove Mod.# JAS030H1WH 10.4 kW, GE Fridge Mod.# GTS16BBSARWW 6.5A, Sm. Microwave, Toaster, Coffee Pot | 3/4" Commercial Grade Double Glazed in Good Condition | None | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (3)2CF23 1SW EA, (2)160 Plug-Ins, Cig Fan-3160 SW |
| 3K | 1 | Steam Fin Tube | Med. TV, Desktop Computer, Printer, Cable Box | Common Laundry | Premier Stove Mod.#EAK220WP01 8,800W, GE Fridge Mod.# GTS16BBSARWW 6.5A, Sm. Microwave | 3/4" Commercial Grade Double Glazed in Good Condition | Frigidaire 8000BTU 9.8EER | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (2)2CF23 SW, (4)100 Plug-Ins, Cig Fan-5160 SW |
| 4A | 1 | Steam Fin Tube | Desktop Computer, (2)Sm. TVs, (2)Cable Boxes, (2)VCRs, Pedestal Fan, Sm. Radio, Med. TV, DVD, (2) Alarm Clocks | Common Laundry | Tappan 4-Burner Stove, Frigidaire Fridge Mod.#FRT13CRHWO 3.75A, Med. Microwave, Coffee Pot, Toaster Oven | 3/4" Commercial Grade Double Glazed in Good Condition | Panasonic Window 10000BTU 10.5EER | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (2)2CF23 SW, (3)75 Plug-Ins, Chandelier-6175 SW |
| 4B | 1 | Steam Fin Tube | Fish Tank, (2)Recip. Fans, (3)Med. TVs, (2)Cable Boxes, DVD/VCR, Paper Shredder, Window Fan | Common Laundry | New Hotpoint 4-Burner Stove, Old GE Energy Saver Fridge, Med. Microwave, Toaster | 3/4" Commercial Grade Double Glazed in Good Condition | Kenmore Window 5600BTU 11.0EER | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (3)2CF23 SW (2) 160 Plug-Ins (1 on SW), W17CF1-E(T8) Plug-In |
| 4C | 1 | Steam Fin Tube | Pedestal Fan, Air Cleaner, (2) Cable Boxes, (2)Med. TVs, DVD, Laptop Computer | Common Laundry | Premier Stove Mod.#EAK220WP01 8,800W, Old GE Energy Saver Fridge, Sm. Microwave, Coffee Pot, Toaster, Blender | 3/4" Commercial Grade Double Glazed in Good Condition | Old Window 7500BTU Low EER | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (3)2CF23 1SW EA, (2)160 Plug-Ins |
| 4D | 0 | Steam Fin Tube | (2)Desktop Computers, Record Player, Lg. Stereo, Net Modem, Fax, Lg. TV, Cable Box, Answering Machine | Common Laundry | New Hotpoint 4-Burner Stove, Old GE Energy Saver Fridge, Med. Microwave, Toaster Oven, G. Foreman Grill, Coffee Pot | 3/4" Commercial Grade Double Glazed in Good Condition | Whirlpool 10000BTU | None | Central Exhaust System | W32CF4-E(T8)SW, (2)2CF23WallMt. SW |

Lawler Towers - Building 6131

| Apartment # | # Bedrooms | Heating Type | Appliances | Washer/Dryer | Kitchen Equipment | Windows/Doors | Air Conditioning | Thermostats | Exhaust Fans | Lighting |
|-------------|------------|----------------|---|----------------|---|---|--|-------------|---|---|
| 4E | 1 | Steam Fin Tube | Answering Machine, Sm. TV, Lg. Stereo, (2) Cable Boxes, DVD, (2) Sm. Radios, Med. TV, (2) Alarm Clocks | Common Laundry | New Larger GE Stove, Hotpoint Fridge Mod.#CTX14CYXKRWH 6.5A, Sm. Microwave, Toaster | 3/4" Commercial Grade Double Glazed in Good Condition | Sharp Window 8000BTU | None | Central Exhaust System, Range Hood: GE Mod.# JN3220V1WH | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (3)2CF23 1SW EA, (2)75 Plug-Ins |
| 4F | 1 | Steam Fin Tube | Laptop Computer, Printer, Net Modem, (2)Med. TVs, Elec. Piano, Lg. Stereo, Cable Box, DVD, (2)CD Players, Guitar Amp, Alarm Clock | Common Laundry | GE Stove Mod.# JAS030HIWH 10.4kW, Frigidaire Fridge Mod.# FRT113CRHW1 3.75A, Croc Pot, 700W Microwave | 3/4" Commercial Grade Double Glazed in Good Condition | (1)Daewoo: 9000BTU 9.6EER (1)Kenmore: 5300BTU 10.0EER | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (4)2CF23 1SW EA, 2CF15 Plug-In, (2)Small Plug-Ins |
| 4G | 1 | Steam Fin Tube | Lg. Stereo, (2)Med. TVs, (2)Cable Boxes, Answering Machine, (2)Recip. Fans, Sm. Stereo, (2)Alarm Clocks | Common Laundry | GE Stove Mod.# JAS030HIWH 10.4kW, GE Fridge Mod.# GTS16BBSPRWW 6.5A, Croc Pot, G. Foreman Grill, Blender, Toaster Oven, Sm. Microwave | 3/4" Commercial Grade Double Glazed in Good Condition | (1)Whirlpool: 7500BTU (1)Feddars: 7500BTU | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (3)2CF23 1SW EA, 160 Plug-In, 125 Plug-In, "Fish Tank" Plug-In |
| 4K | 1 | Steam Fin Tube | Med. TV, Cable Box | Common Laundry | Premier Stove Mod.#EAK220WP01 8,800W, GE Fridge Mod.# GTS16BBSARWW 6.5A, Croc Pot | 3/4" Commercial Grade Double Glazed in Good Condition | GE Window 8200BTU 10.8EER | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (3)2CF23 1SW EA, (2)CF23 Plug-Ins |

Building Averages

| Apartment # | # Bedrooms | Heating Type | Appliances | Washer/Dryer | Kitchen Equipment | Windows/Doors | Air Conditioning | Thermostats | Exhaust Fans | Lighting |
|-------------|------------|----------------|---|-------------------|--|---|--|-------------|------------------------|---|
| Average | 0 | Steam Fin Tube | (2)Med TVs, Cable Box, DVD/VCR, Sm. Radio, Alarm Clock | Community Laundry | GE Fridge Mod.# GTS16BBSARWW 6.5A, Kenmore 4-Burner Stove, Sm. Microwave, Coffee Pot, Toaster | 3/4" Commercial Grade Double Glazed in Good Condition | 7500BTU Low EER | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (3)2CF23 1SW EA, I60 on Bedrm SW, (2) I60 Plug-Ins |
| Average | 1 | Steam Fin Tube | Desktop Computer, (2)Cable Boxes, Lg. TV, Med. TV, Alarm Clock, Fan, Med. Stereo | Community Laundry | GE Spacemaker Stove Mod.# JAS030H1WH 10.4 kW, GE Fridge Mod.# GTS16BBSARWW 6.5A, Sm. Microwave, Toaster Oven, Toaster, Coffee Pot | 3/4" Commercial Grade Double Glazed in Good Condition | Frigidaire 8000BTU 9.8EER | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (3)2CF23 1SW EA, I60 on Bedrm SW, (4) I60 Plug-Ins |
| Average | 2 | Steam Fin Tube | Water Cooler, Air Cleaner, Med. TV, Sm. TV, (2) Cable Boxes, (2)Sm. Radios, Recip. Pedestal Fan | Community Laundry | LG Magic Chef 4-Burner Stove, Hotpoint Fridge Mod.# HTR16ABSERWW 6.5A, Blender, (2)Coffee Pots, Toaster, Med. Microwave | 3/4" Commercial Grade Double Glazed in Good Condition | (1)GE Window: 10500BTU 9.8EER (1)Frigidaire: 7500BTU 10EER | None | Central Exhaust System | W32CF4-E(T8) Dual SW, W20CF1-Mag(T12)SW, (3)2CF23 1SW EA, I150 Plug-In, (2)I40 Plug-In |
| Average | 3 | Steam Fin Tube | Fish Tank, (2)Desktop Computers, Printer, Lg. TV, Sm. TV, Med. TV, (3)Cable Boxes, (2)DVD, XBOX 360, Window Fan | Community Laundry | New GE 4-Burner Digital Control Stove, New GE Mod.# GTH22SBNARBS 11.6A Fridge, G Foreman Grill, Coffee Pot, Toaster, Sm. Microwave | 3/4" Commercial Grade Double Glazed in Good Condition | (1) Amana: 7500BTU (1)Sunbeam: 5000BTU, 9.7EER (1)LG: 10000BTU 9.8EER | None | Central Exhaust System | 2CF23WallMt-Dual SW, W34CF2-Mag(T12)SW, 5CF23: 4 on Med. Cabinet, 1 Clg. Mt. on one SW, (3) I40 Plug-In, 1CF13 & (2)2CF23 Plug-In |

Apartment Averages

| | Apartment Averages | | | | | | | |
|-------------------------------|-----------------------|--------------------|----------------------|-------------------------------|----------|--|--|--|
| | Appliances | Kitchen Equipment | Air Conditioning | HA Lighting | Lamps | | | |
| 0-Bed | 1 Cable Box | 1 GE Fridge | 1 7500 BTU, Low EER | 1 W32CF4-E Dual SW (T8, Occ) | 3 I60 | | | |
| | 2 Med. TVs | 1 Kenmore Stove | | 1 W20CF1-Mag SW (T12, Occ) | | | | |
| | 1 Alarm Clock | 1 Toaster | | 3 2CF23 1 SW EA (Occ) | | | | |
| | 1 Sm. Stereo | 1 Sm. Microwave | | | | | | |
| | 1 DVD/VCR | 1 Coffee Pot | | | | | | |
| 1-Bed | Appliances | Kitchen Equipment | Air Conditioning | HA Lighting | Lamps | | | |
| | 1 Desktop Computer | 1 GE Stove | 1 8000 BTU, 9.8 EER | 1 W32CF4-E SW (T8, Occ) | 5 I60 | | | |
| | 1 Lg. TV | 1 GE Fridge | | 1 W20CF1-Mag SW (T12, Occ) | | | | |
| | 2 Cable Boxes | 1 Coffee Pot | | 3 2CF23 1 SW EA (Occ) | | | | |
| | 1 Med. TV | 1 Toaster | | | | | | |
| | 1 Alarm Clock | 1 Sm. Microwave | | | | | | |
| | 1 Med. Stereo | 1 Toaster Oven | | | | | | |
| | 1 Fan | | | | | | | |
| 2-Bed | Appliances | Kitchen Equipment | Air Conditioning | HA Lighting | Lamps | | | |
| | 1 Med. TV | 1 Hotpoint Fridge | 1 7500 BTU, 10.0 EER | 1 W32CF4-E SW (T8, Occ) | 2 I40 | | | |
| | 1 Sm. TV | 1 LG Stove | 1 10500 BTU, 9.8 EER | 1 W20CF1-Mag SW (T12, Occ) | 1 I150 | | | |
| | 2 Cable Boxes | 2 Coffee Pots | | 3 2CF23 1 SW EA (Occ) | | | | |
| | 2 Sm. Radios | 1 Med. Microwave | | | | | | |
| | 1 Water Cooler | 1 Toaster | | | | | | |
| | 1 Air Cleaner | 1 Blender | | | | | | |
| | 1 Recip. Pedestal Fan | | | | | | | |
| 3-Bed | Appliances | Kitchen Equipment | Air Conditioning | HA Lighting | Lamps | | | |
| | 1 Fish Tank | 1 GE Digital Stove | 1 7500 BTU, 9.8 EER | 1 2CF23 Wall Mt Dual SW (Occ) | 3 I40 | | | |
| | 2 Desktop Computers | 1 New GE Fridge | 1 10000 BTU, 9.8 EER | 1 W34CF2-Mag SW (T12 Occ) | 2 C2CF23 | | | |
| | 1 Printer | 1 G. Foreman Grill | 1 5000 BTU, 9.7 EER | 1 4CF23 SW (No Occ) | 1 CF13 | | | |
| | 1 Lg. TV | 1 Coffee Pot | | 1 CF23 SW (Occ) | | | | |
| | 1 Sm. TV | 1 Toaster | | | | | | |
| | 1 Med. TV | 1 Sm. Microwave | | | | | | |
| | 3 Cable Boxes | | | | | | | |
| | 2 DVD | | | | | | | |
| | 1 XBOX 360 | | | | | | | |
| | 1 Window Fan | | | | | | | |
| Entire Complex Totals: | | | | | | | | |
| | Appliances | Kitchen Equipment | Air Conditioning | HA Lighting | Lamps | | | |
| 0-Bed | 62 Cable Box | 62 GE Fridge | 62 7500 BTU, Low EER | 62 W32CF4-E Dual SW (T8, Occ) | 186 I60 | | | |
| | 124 Med. TVs | 62 Kenmore Stove | | 62 W20CF1-Mag SW (T12, Occ) | | | | |
| | 62 Alarm Clock | 62 Toaster | | 186 2CF23 1 SW EA (Occ) | | | | |
| | 62 Sm. Stereo | 62 Sm. Microwave | | | | | | |

| Appliances | Kitchen Equipment | Air Conditioning | HA Lighting | Lamps |
|------------------------|--------------------|-----------------------|-------------------------------|----------|
| 174 Lg. TV | 1 GE Digital Stove | 17 10500 BTU, 9.8 EER | 252 W32CF4-E SW (T8, Occ) | 37 I40 |
| 315 Med. TV | 17 LG Stove | 1 10000 BTU, 9.8 EER | 1 W34CF2-Mag SW (T12 Occ) | 1051 I60 |
| 18 Sm. TV | 173 GE Stove | 173 8000 BTU, 9.8 EER | 252 W20CF1-Mag SW (T12, Occ) | 17 I150 |
| 445 Cable Boxes | 62 Kenmore Stove | 1 7500 BTU, 9.8 EER | 756 2CF23 1 SW EA (Occ) | 2 C2CF23 |
| 175 Desktop Computers | 1 New GE Fridge | 17 7500 BTU, 10.0 EER | 1 2CF23 Wall Mt Dual SW (Occ) | 1 CF13 |
| 1 Printers | 17 Hotpoint Fridge | 1 5000 BTU, 9.7 EER | 1 4CF23 SW (No Occ) | |
| 1 Fish Tanks | 235 GE Fridge | | 1 CF23 SW (Occ) | |
| 2 DVD | 173 Toaster Oven | | | |
| 34 Sm. Radios | 1 G. Foreman Grill | | | |
| 17 Water Cooler | 270 Coffee Pot | | | |
| 17 Air Cleaner | 253 Toaster | | | |
| 17 Recip. Pedestal Fan | 17 Med. Microwave | | | |
| 62 Sm. Stereo | 236 Sm. Microwave | | | |
| 173 Med. Stereo | 17 Blender | | | |
| 62 DVD/VCR | | | | |
| 1 Window Fan | | | | |

Totals

| | |
|----------------------|----------------|
| Cost of Electricity: | \$0.119 \$/kWh |
| | \$15.03 \$/kW |

[illegible]

Energy Audit of North Bergen Housing Authority
CHA Project No. 20241 Lawler Towers
Existing Lighting

Cost of Electricity: \$0.119 \$/kWh
\$15.03 \$/kW

| EXISTING CONDITIONS | | | | | | | | | | | |
|--|---------------------------------|-----------------|------------------------|----------------------|-------------------|-------------------|----------------|--------------|------------------|------------|-------------------|
| Field Code | Area Description | No. of Fixtures | Standard Fixture Code | NYSERDA Fixture Code | Watts per Fixture | kW/Space (Ft No.) | Exisit Control | Annual Hours | Retrofit Control | Annual kWh | Notes |
| Unique description of the location - Room number/Room name, Floor number (if applicable) | | | | | | | | | | | |
| No. of fixtures before the retrofit | | | | | | | | | | | |
| "Lighting Fixture Code" Example 2T 40 R F(U) = 2'x2' Troff 40" w Recess, Floor 2 lamps U shape | | | | | | | | | | | |
| Code from Table of Standard Fixture Wattages | | | | | | | | | | | |
| Value from Table of Standard Fixture Wattages | | | | | | | | | | | |
| 5 | Center Office | 2 | 2T 32 R F 2 (u) (ELE) | FU2LL | 60 | 0.1 | SW | 2600 | OCC | 312 | |
| 106 | Center Office | 3 | SP 651 | 6511 | 65 | 0.2 | SW | 2600 | OCC | 507 | |
| 5 | Center Office | 2 | 2T 32 R F 2 (u) (ELE) | FU2LL | 60 | 0.1 | SW | 2600 | OCC | 312 | |
| 5 | Cubical Area (north side) | 8 | 2T 32 R F 2 (u) (ELE) | FU2LL | 60 | 0.5 | SW | 2600 | None | 1,248 | |
| 182 | Cubical Area (north side) | 34 | W 25 C F 2 (ELE) 3' T8 | F32EE | 66 | 2.2 | SW | 2600 | None | 5,534 | |
| 106 | Cubical Area (north side) | 8 | SP 651 | 6511 | 65 | 0.5 | SW | 2600 | None | 1,352 | |
| 5 | Cubical Area (south side) | 12 | 2T 32 R F 2 (u) (ELE) | FU2LL | 60 | 0.7 | SW | 2600 | None | 1,872 | |
| 182 | Cubical Area (south side) | 16 | W 25 C F 2 (ELE) 3' T8 | F32EE | 66 | 1.1 | SW | 2600 | None | 2,746 | |
| 106 | Cubical Area (south side) | 18 | SP 651 | 6511 | 65 | 1.2 | SW | 2600 | None | 3,042 | |
| 182 | Cubical nook | 12 | W 25 C F 2 (ELE) 3' T8 | F32EE | 66 | 0.8 | SW | 2600 | None | 2,059 | |
| 106 | Cubical nook | 3 | SP 651 | 6511 | 65 | 0.2 | SW | 2600 | None | 507 | |
| 5 | Office Kitchen | 5 | 2T 32 R F 2 (u) (ELE) | FU2LL | 60 | 0.3 | SW | 2600 | OCC | 760 | |
| 117 | Office Men's Room | 3 | CF 23 | CF231 | 23 | 0.1 | SW | 2600 | None | 179 | |
| 117 | Office Women's Room | 3 | CF 23 | CF231 | 23 | 0.1 | SW | 2600 | None | 179 | |
| 15 | Elevator Motor Room | 4 | S 32 C F 2 (ELE) | F42LL | 60 | 0.2 | SW | 2600 | None | 624 | |
| 4 | File Storage Room (Tier B) | 3 | 2B 34 R F 2 (u) (MAG) | F42EE | 72 | 0.2 | SW | 2600 | None | 562 | |
| 18 | File Storage Room (Tier B) | 5 | T 32 R F 4 (ELE) | F44LL | 112 | 0.6 | SW | 2600 | None | 1,456 | |
| 18 | File Storage Room (Tier B) | 8 | T 32 R F 4 (ELE) | F44LL | 112 | 0.9 | SW | 2600 | None | 2,330 | |
| 18 | File Storage Room (Tier B) bath | 1 | T 32 R F 4 (ELE) | F44LL | 112 | 0.1 | SW | 2080 | OCC | 233 | |
| 11 | Trash Compactor Room | 3 | S 34 P F 2 (MAG) | F42EE | 72 | 0.2 | SW | 2000 | None | 432 | No OCC for safety |
| 117 | Chiller Room | 3 | CF 23 | CF231 | 23 | 0.1 | SW | 2000 | None | 138 | No OCC for safety |
| Both Towers A and B | | | | | | | | | | | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | No OCC for safety |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | No OCC for safety |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | No OCC for safety |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | 0.1 | Breaker | 8760 | None | 753 | |
| 73 | Hallway Doors | 4 | I 120 | I1201 | 120 | 0.5 | Breaker | 8760 | None | 4,205 | |
| 2 | Hallways (tenant floors) | 18 | T 34 W F 2 (MAG) RL/RB | F42ES | 80 | 1.4 | Breaker | 8760 | None | 12,614 | |
| 3 | Stairways | 2 | W 34 W F 1 (MAG) | F41EE | 43 | | | | | | |

Cost of Electricity:

EXISTING CONDITIONS

