## BOROUGH OF SOMERDALE MUNICIPAL BUILDING ENERGY ASSESSMENT

for

# NEW JERSEY BOARD OF PUBLIC UTILITIES

# CHA PROJECT NO. 22424

March 2011

Prepared by:

# **CLOUGH HARBOUR & ASSOCIATES LLP**

6 Campus Drive Parsippany, NJ 07054

(973) 538-2120

# TABLE OF CONTENTS

2.0	EXE	CUTIVE SUMMARY2
2.0		
3.0		STING CONDITIONS
	3.1	Building General
	3.2	Utility Usage
	3.3	HVAC Systems
	3.4	Lighting/Electrical Systems
	3.5	Control Systems
	3.6	Plumbing Systems
4.0	ENE	RGY CONSERVATION MEASURES6
	4.1	ECM-1 Lighting Replacements
	4.2	ECM-2 Install Lighting Controls
	4.3	ECM-3 Combined Lighting Replacements with Lighting Controls
	4.4	ECM-4 Replace Electric DHW with On Demand Gas
	4.5	ECM-5 Temperature Setback
	4.6	ECM-6 Dual Flush Toilets
	4.7	ECM-7 Install Storm Windows in Courtroom
	4.8	ECM-8 Increase Wall Insulation in Courtroom
	4.9	ECM-9 Replace Court Office RTU with More Efficient Unit
5.0	INC	ENTIVES OVERVIEW14
	5.1	Incentives Overview
	5.2	Building Incentives
6.0	ALT	ERNATIVE ENERGY EVALUATION18
	6.1	Geothermal
	6.2	Solar
	6.3	Wind
	6.4	Combined Heat and Power Generation (CHP)
	6.5	Biomass Power Generation
	6.6	Demand Response Curtailment
7.0	EPA	PORTFOLIO MANAGER23
8.0	CON	ICLUSIONS & RECOMMENDATIONS 24

### 1.0 INTRODUCTION & BACKGROUND

The Borough of Somerdale Municipal Building is an 8,500 square foot building located at 105 Kennedy Boulevard. The facility contains offices for tax collection, mayor, clerk, chief financial officer, construction, and court administration. The building also houses the Somerdale Police Department and a courtroom.

New Jersey's Clean Energy Program, funded by the New Jersey Board of Public Utilities, supports energy efficiency and sustainability for Municipal and Local Government Energy Audits. Through the support of a utility trust fund, New Jersey is able to assist state and local authorities in reducing energy consumption while increasing comfort.

### 2.0 EXECUTIVE SUMMARY

This report details the results of the Borough of Somerdale Municipal Building. The 8,500 square foot building contains offices for tax collection, mayor, clerk, chief financial officer, construction, and court administration. The building also houses the Somerdale Police Department and a courtroom. Various potential Energy Conservation Measures (ECMs) were identified for the above categories. Potential annual savings of \$5,850 for the recommended ECMs may be realized with a payback of 4.3 years.

The ECMs identified in this report will allow for the building to reduce its energy usage and if pursued has the opportunity to qualify for the New Jersey SmartStart Buildings Program and/or Direct Install Program. A summary of the costs, savings, and paybacks for the recommended ECMs follows:

	Summa	ry of Ene	rgy Conser	vation Me	asures		
E	nergy Conservation Measure	Approx. Cost (\$)	Approx. Annual Savings (\$)	Payback w/o Incentive	Potential Incentive* (\$)	Payback w/ Incentive	Recommended for Implementation (X)
ECM-1	Lighting Replacements	2,600	1,200	2.2	1,600	0.8	
ECM-2	Install Lighting Controls	5,000	1,500	3.3	3,000	1.3	
ECM-3	Combined Lighting Replacement with Lighting Controls	7,800	2,700	2.9	4,700	1.1	Х
ECM-4	Replace Electric DHW Heater with On Demand Gas	4,200	1,100	3.8	300	3.5	Х
ECM-5	Temperature Setback	500	1,400	0.4	300	0.1	Х
ECM-6	Dual Flush Toilets	3,900	300	13.0	•	-	-
ECM-7	Install Storm Windows in Courtroom	1,500	150	10.0	-	-	Х
ECM-8	Increase Wall Insulation in Courtroom	3,900	200	19.5	-	-	
ECM-9	Replace Court Office RTU with More Efficient Unit	11,300	500	22.5	6,800	9.0	Х
* Incentive	shown is the maximum amount potentia	ally available	per the NJ Smart	Start or Pay F	or Performance	Programs.	

### 3.0 EXISTING CONDITIONS

### 3.1 Building General

The Somerdale Municipal Building was constructed in 1978. The original building was about 3,500 square feet; with a 5,000 square foot addition in 2004. The expansion added office space and increased the size of the police department.

The northeast part of the building contains offices for the mayor, tax collector, deputy clerk, tax assessor, and chief financial officer. This area also contains a small meeting room and storage closets. The northwest side of the building contains the offices for the fire marshal, construction, and court violations. This area also has a conference room which is used 2-3 times per week, and employee breakroom.

The majority of the southern part of the building contains the police department. This area includes offices for the sergeants and chief, and also a locker room area for the officers. There are two prisoner cells and prisoner processing area. The southwest corner contains the courtroom which has a capacity of 150 people.

Normal operating hours for the building are Monday through Friday from 8:30 AM to 4:30 PM, except the police department which is a 24 hour operation. Meetings and gatherings occur in the evenings about two times per week for about 3-4 hours each. According to building personnel, about 15 employees occupy the building during normal operations.

The building walls are constructed with filled concrete block and concrete masonry exterior. In the section of the building constructed in 2004, the walls contain polyisocyanurate insulation. In the original section, there is no added insulation. The roof was replaced with a new rubber membrane in 2006 according to building personnel. Windows are double pane and in good condition, except the windows in the courtroom which are single pane and original to the building's construction. All the doors seal appropriately and are in good condition.

### 3.2 Utility Usage

Utilities include electricity, natural gas, and potable water. Electricity is supplied and delivered by Public Service Electric & Gas Company (PSE&G) and natural gas is supplied and delivered by South Jersey Gas. Potable water is provided by New Jersey American Water.

From November 2009 through October 2010, electric usage was approximately 117,820 kWh at a cost of about \$20,500. Analyzing electricity bills during this period showed that the building was charged a supply unit cost of \$0.125 per kWh, demand unit cost of \$12.99 per kW, and blended unit cost of \$0.174 per kWh. Electricity usage was generally higher in the summer months due to air conditioning.

From January 2010 through December 2010, natural gas usage was about 2,900 therms. Based on the annual cost of about \$3,900, the blended price for natural gas was \$1.36 per therm. Natural gas consumption is highest in winter months when the building is in heating mode.

Review of potable water utility bills from December 2009 through November 2010 determined the facility used a total of 58,000 gallons of water. There was a large spike in water usage in September 2009 for unknown reasons. At a total cost of about \$600, the unit cost for water was found to be \$10.44 per kGal. Utility data can be found in Appendix A.

Electricity supply and delivery are presently purchased from PSE&G, and natural gas supply and delivery from South Jersey Gas. The delivery component will always be the responsibility of the utility that connects the facility to the power grid or gas line; however, the supply can be purchased from a third party. The electricity or natural gas commodity supply entity will require submission of one to three years of past energy bills. Contract terms can vary among suppliers. A list of approved electrical and natural gas energy commodity suppliers can be found in Appendix A.

According to the Department of Energy, the state average cost per kWh for commercial buildings in 2010 was \$.141/kWh. The average cost for natural gas was \$.99/therm in 2009 (the most recent data available). If the borough paid average costs for kWh and therms of natural gas for the municipal building, about \$5,000 could be saved per year.

### 3.3 HVAC Systems

HVAC is divided into four sections; mayor's office wing, police department, tax and construction office, and courtroom. These areas are heated and cooled by five constant volume roof top units (RTUs); one per section, except the police department which has two. Each unit has a thermostat located in the space for temperature control.

The area that contains the offices of the mayor and chief financial officer is heated by an 80% efficient Trane natural gas heater. The RTU has an input rating of 200 MBtu and output rating of 160 MBtu. The RTU has a cooling capacity of 7.5 tons. This unit is located on the northern section of the roof and is about six years' old.

The police department is heated and cooled by two RTUs. One unit, manufactured by Trane, which is about six years old, has a natural gas input of 120 MBtu and output of 96 MBtu. This unit, with a standard 80% efficiency and cooling capacity of four tons, is located on the eastern side of the roof. The second RTU, manufactured by Carrier, for the police department is located on the south side of the roof and has an input capacity of 115 MBtu and output of 92 MBtu. The unit has a standard heating efficiency of 80% and cooling capacity of four tons.

The courtroom Carrier RTU is located on the southwest side of the roof, and according to building maintenance personnel, is slightly over a year old. The heating portion is 82% efficient with an input rating of 224 MBtu and output rating of 184 MBtu. The RTU has a cooling capacity of 9.5 tons and an Energy Efficiency Ratio of 11.1.

The fifth RTU, estimated to be about 12 years' old, heats and cools the offices of court administration, construction, and fire marshal, as well as breakroom and conference room. The unit, manufactured by Carrier, has a standard heating efficiency of 80%, and input heating rating of 180 MBtu and output rating of 144 MBtu. The cooling portion is rated to ten tons.

Six small exhaust fans ventilate the five restrooms; janitorial closet; and server closet in the mayor's wing. All fans are controlled by switches.

### 3.4 Lighting/Electrical Systems

Most main areas of the building, including the hallways, offices, and common areas are lit primarily with 2-lamp, 3-lamp, or 4-lamp T8 troffer fixtures containing electronic ballasts. The courtroom is lit with 4 lamp T12 fixtures containing magnetic ballasts. Some areas, including the conference room, main hallway, and courtroom, have incandescent bulbs. The restrooms are also primarily lit with T12 lamps.

All lighting is controlled by switches. During the site visit, a thorough lighting survey was conducted analyzing the lighting types and lighting controls. A full list of existing lighting can be viewed in Appendix R.

Outside lighting consists of 100 W metal halide fixtures and emergency wall packs.

There is a 100 kW emergency generator located on the southern part of the building. This unit runs on natural gas and is tested once a month.

#### 3.5 Control Systems

The five HVAC units noted above have dedicated thermostats; all are programmable except one manual thermostat in the police area. This area is on a 24/7 schedule; therefore, setback is not possible. During the site visit, the temperature of the space was about 72°F; a police officer noted that the air conditioning remained around 70°F in the summer.

The programmable thermostat in the mayor's section is set to about 74°F year round. There is setback capability with this unit; however during the site visit, this option had been manually overridden. Because of the overridden setpoint and building load calculations, it was assumed that the space is kept cooler than 74°F in the summer. A conservative estimate of 72°F was used for calculations based on building load. The court office area on the west side of the building has an outdated programmable thermostat. The thermostat was manually overridden to hold the space temperature at 74°F with no setback. An employee in that area noted that it was cool in the summer; therefore, a conservative estimate of 72°F was used as the cooling setpoint. The courtroom is also controlled with an outdated programmable thermostat set to 65°F when unoccupied, and 74°F when occupied in heating mode. In the summer, the courtroom was set to 73°F in occupied mode. This thermostat was manually overridden; therefore, an estimate of 70°F occupied, and 75°F unoccupied was used to determine building load requirements in the summer. The thermostats are not being properly utilized for setback.

### 3.6 Plumbing System

The building has five restrooms, two main restrooms located in the main hallway, two in the police area, and one employee restroom in the office area on the west side of the building. There is also a single janitorial closet next to the employee restroom that has a mop sink.

The main men's restroom has a 1.6 gallon per flush (gpf) toilet and a 1 gpf urinal. The flush valve on the toilet is not working correctly and the toilet flushes for about 10 seconds. During this time, water flows through unnecessarily. The men's restroom also has two low flow faucets. The main women's restroom has two high flow toilets (about 2.5 gpf) and two low flow faucets. The employee restroom has a low flow toilet (1.6 gpf) and low flow faucet.

One restroom in the police area is located in the officer locker room and has a 1.6 gpf toilet and low flow sink at about 1.0 gallons per minute (gpm). There is also a small restroom in the prisoner processing area with a 1.6 gpf toilet and a high flow sink at about 2.5 gpm.

Domestic hot water (DHW) is produced by a single 40 gallon Bradford White electric hot water heater that uses 4.5 kW. A small 1/12 HP circulation pump manufactured by Sid Harvey provides restroom hot water, and all supply piping is insulated. During the site visit, building staff noted that the hot water in the restrooms takes considerable time to become warm. This was confirmed when the hot water was tested at the restroom sinks.

### 4.0 ENERGY CONSERVATION MEASURES

### 4.1 ECM-1 Lighting Replacements

A lighting survey was performed during the site visit, which consisted of an overall lighting count, analysis of current lighting types, and potential replacement options for increased energy efficiency. Most of the building lighting is primarily T8 troffer fixtures with electronic ballasts. These fixtures are energy efficient by today's standards and were not considered for replacement. Some lighting fixtures that are not efficient by today's standards were evaluated for replacement.

In the police area where prisoners enter, there are five 2-lamp T12 fluorescent fixtures with magnetic ballasts which could be replaced with T8 fixtures containing electronic ballasts. There is also an incandescent lit exit sign in this area that could be replaced with an LED exit sign. The maintenance closet which contains the electric panels for the building has a single 2 lamp T12 fixture that could also be replaced with T8. Additionally, the area near the police attendant contains three 60 W incandescent bulbs that could be replaced with compact fluorescents lightbulbs (CFLs).

The men's and women's restrooms have a single 2-lamp T12 fixture, and the courtroom has nine 4-lamp T12 fixtures. There are also incandescent of various sizes located in the courtroom, main hallway, and conference room in the west office area. All incandescents were evaluated for replacement with CFLs.

To calculate the potential savings by switching out these lights, the existing wattages were compared with the proposed wattages, and multiplied by the hourly usage to determine kWh savings. This calculation can be seen in Appendix B. By replacing all old lighting technologies in the building, the borough could save about 2.1 kW and 7,300 kWh annually.

Lighting and electrical equipment have an expected life of 15 years, according to the manufacturers, and total energy savings over the life of the project are estimated at 109,500 kWh and \$18,000.

The implementation cost and savings related to this ECM are presented in Appendix B and summarized below:

**ECM-1 Lighting Replacements** 

Budgetary		Annua	l Utility Savings			Potential	Payback	Payback
Cost						Incentive*	(without incentive)	(with incentive)
	Electricity Therms Total				ROI			
\$	kW	kWh	Natural Gas	\$		\$	Years	Years
2,600	2.0	7,300	0	1,200	6.5	1,600	2.2	0.8

<sup>\*</sup> Incentive shown is per the 2010 Direct Install Program. See Section 5.0 for other incentive opportunities.

This measure is not recommended in lieu of ECM 3.

#### 4.2 ECM-2 Install Lighting Controls

As part of the lighting survey conducted for ECM-1, opportunities for lighting controls were evaluated. Areas where there is frequent intermittent use such as restrooms and offices are good candidates for occupancy sensors, and one outdoor light was considered for photocell control. The following were identified as viable areas for occupancy sensors, where not specifically called out as ceiling mounted, the sensor would be wall mounted:

Area Description	No. of Fixtures	Fixture Type	No. of Sensors Required
Maint. Closet with DHW Heater	. 1	2 lamp T12	1
Police General Restroom	1	20 W T12 2' fixture	1
Police Locker Room	1	2 lamp T8	1 Ceiling Mounted
Police Perimeter Office	1	4 lamp T8	1
Police Gun Cabinet	1	2 lamp T12	1
Interrogation Room	1	2 lamp T8	1
Sergeant Office 1	2	4 lamp T8	1
Sergeant Office 2	2	4 lamp T8	1
Sergeant Office 3	2	4 lamp T8	1
Chief's Office	2	4 lamp T8	1
Storage/Server Room	2	4 lamp T8	1
Mayor's Office	2	4 lamp T8	1
Deputy Treasurer's Office	2	2 lamp T8	1
Server Room Near Copy Machine	1	4 lamp T8	1 .
Conference Room	2	4 lamp T8	1
Supply Room 1	2	4 lamp T8	1
Supply Room 2	2	4 lamp T8	1
CFO Office	2	4 lamp T8	1
Municipal Clerk Office	2	4 lamp T8	1
Tax Office	4	4 lamp T8	1
Tax Office Closet	1	4 lamp T8	1
Clerk Office	2	4 lamp T8	1
Main Men's Restroom	1	2 lamp T12	2
Main Women's Restroom	1	2 lamp T12	2
Office in Hall Near Police Window	1	2 lamp T8	1
Breakroom	4	3 lamp T8	1 Ceiling Mounted
Restroom off Breakroom	1	4 lamp T8	1
Court Office	6	4 lamp T8	2 Ceiling Mounted
Court Office Storage	1	2 lamp T8	1
Janitor Closet	1	4 lamp T8	1
Conference Room	6	3 lamp T8	1 Ceiling Mounted
Construction Office	3	4 lamp T8	1 Ceiling Mounted
Fire Marshall Office	2	4 lamp T8	1
Tax Assessor Office	2	4 Lamp T8, 2 lamp T8	1
Outdoor Light	1	100 W Metal Halide	1

To calculate the energy saving potential with occupancy sensors, the existing lighting usage was compared to the approximate usage with occupancy sensors and photocells. With occupancy sensors, lights generally remain on for about 10 to 15 minutes after occupancy. Photocells sense daylight; therefore, the outdoor light will only turn on at night. By installing lighting controls in the municipal building, the borough could save about 12,290 kWh per year.

Lighting controls have an expected life of 15 years, according to ASHRAE, and total energy savings over the life of the project are estimated at 184,350 kWh and \$22,500.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

**ECM-2 Install Lighting Controls** 

Budgetary Cost		Annua	l Utility Savings			Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Elec	tricity	Therms	Therms Total				
\$	kW	kWh	Natural Gas	\$		\$	Years	Years
5,000	0	12,290	0	1,500	3.5	3,000	3.3	1.3

<sup>\*</sup> Incentive shown is per the 2010 Direct Install Program

This measure is not recommended in lieu of ECM 3.

### 4.3 ECM-3 Combined Lighting Replacements with Lighting Controls

Due to interactive effects, the energy and cost savings for occupancy sensors and lighting upgrades are not cumulative. This measure is a combination of ECMs-1 and 2 to allow for maximum energy and demand reduction.

Lighting and lighting controls have an expected life of 15 years, according to the manufacturers, and total energy savings over the life of the project are estimated at 288,300 kWh and \$40,500.

The implementation cost and savings related to this ECM are presented in Appendix D and summarized below:

ECM-3 Combined Lighting Replacements with Lighting Controls

Budgetary		Annua	l Utility Savings			Potential	Payback	Payback
Cost						Incentive*	(without incentive)	(with incentive)
	Electricity Therms Total				ROI			
\$	kW kWh		Natural Gas	\$		\$	Years	Years
7,800	2.0					4,700	2.9	1.1

<sup>\*</sup> Incentive shown is per the 2010 Direct Install Program. See Section 5.0 for other incentive opportunities.

This measure is recommended.

### 4.4 ECM-4 Replace Electric DHW Heater with On Demand Gas

Domestic hot water for the building is produced by a 40 gallon, 4.5 kW A.O. Smith electric hot water heater located in the storage room near the police section.

This ECM analyzed replacing the existing heater with an on-demand natural gas fired unit. The existing unit has to constantly maintain the 40 gallon tank heated to 120°F regardless if hot water is being used. The gas fired unit turns on when there is a hot water demand in the building. On-demand heaters do not have a reservoir tank, and, therefore, eliminate tank standby losses. Standby losses of about 2.5% occur with DHW tanks, and additional heating energy is required to maintain setpoint temperature.

The existing unit uses electricity to heat the water and overcome standby losses from the tank, and also to replenish the tank when hot water is needed. To calculate the savings of replacing the DHW heater, the existing energy usage was determined from hot water usage information obtained from discussions with

building personnel. Based on building usage of the restrooms and janitorial sink, an accurate representation of hot water use was calculated.

Electricity usage, including the 4.5 kW demand, would be eliminated with the new on-demand unit. The new heater would use natural gas which must be accounted for in the savings calculations. Installing an on-demand gas hot water heater could save 4,200 kWh per year. Based on existing usage, the new unit would use about 100 therms of natural gas annually.

Hot water heaters have a life expectancy of about 13 years according to manufacturers. The total energy savings over the life of the project would be 54,600 kWh. The new gas fired water heater would use an additional 1,300 therms of natural gas, which would correspond to a savings of about \$14,300 over the lifetime of the equipment.

The implementation cost and savings related to this ECM are presented in Appendix E and summarized below:

ECM-4 Replace Electric DHW Heater with On Demand Gas

Budgetary Cost		Annua	l Utility Savings			Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity Therms Total			ROI				
\$	kW	kWh	Natural Gas	\$		\$	Years	Years
4,200	4.5 ·	4,200	(100)	1,100	2.4	300	3.8	3.5

<sup>\*</sup> Incentive shown is per the 2010 New Jersey Smart Start Program's Gas Hot Water Heating Application, See Section 5.0 for other incentive opportunities.

This measure is recommended.

### 4.5 ECM-5 Temperature Setback

As previously noted, the building is divided into four primary HVAC sections. Each RTU manages a single section, with the exception of the police department which has two RTUs. Each RTU in the building has a thermostat in the space that regulates temperature. The thermostats are programmable, with the exception of the manual thermostat in the prisoner processing room of the police department. The programmable thermostats have setback capabilities and schedules; however, as noted during the site visit, all were manually overridden to maintain a single space temperature setpoint. Building personnel explained that the building was maintained at about 74°F during all occupied hours. However, by reviewing the programming of the thermostats and energy usage trends throughout the year, it was determined that this was not always adhered to, particularly in the summer. The following chart shows actual heating and cooling temperature setpoints:

		Setpoints							
	Неа	ating °F	Cooling °F						
	Occupied	Unoccupied	Occupied	Unoccupied					
Police Area	72	72	70	70					
Mayor's Office Wing	74	74	72	72					
Courtroom	74	65	70	75					
Court Office Area	74	74	72	72					

This ECM analyzed setting back the temperature during unoccupied times, with the exception of the police area which operates 24/7. In the summer, the temperature would be set back to 80°F during unoccupied times. In the winter, the temperature would be set to 70°F during occupied times and 60°F during unoccupied times. The current 74°F is considered a high setpoint for occupied heating; 70°F was used as a setpoint to maintain occupancy comfort, and save energy.

To calculate the savings for temperature setback, a block load model of all four main spaces of the building was created to establish the existing energy load. The block load considered window, wall, door areas, building infiltration loads, thermal resistances of building materials, occupancy, and usage. This load was then reconciled to the yearly utility data using outdoor air temperature bins from Newark, NJ. The block load was then modified to represent the energy usage of the building with all set back in place. The difference between energy usages represents the potential savings from setting back the temperature. If implemented, this ECM could save about 850 therms of natural gas and 1,120 kWh per year. The block load can be seen in appendix Q.

Two new thermostats would be required since the mayor's wing already has a newer programmable thermostat, and none is considered for the police section.

Programmable thermostats have an estimated life expectancy of about 15 years according to ASHRAE. The total savings over the life of this project would be about 12,750 therms, 16,800 kWh, and \$21,000.

The implementation cost and savings related to this ECM are presented in Appendix F and summarized below:

**ECM-5 Temperature Setback** 

Budgetary		Annua	l Utility Savings			Potential	Payback	Payback
Cost						Incentive*	(without incentive)	(with incentive)
	Electricity Therms Total				ROI			
\$	kW kWh		Natural Gas	\$		\$	Years	Years
500	0	0 1,120 850 1,400				300	0.4	0.1

<sup>\*</sup> Incentive shown is per the 2011 New Jersey Direct Install Program. See Section 5.0 for other incentive opportunities.

This measure is recommended.

#### 4.6 ECM-6 Dual Flush Toilets

The building has five restrooms with a total of six toilets. The toilets vary in the amount of water used per flush. The toilet in the police locker room and employee restroom use about 1.6 gpf. The general police toilet, and the two toilets in the women's restrooms use about 2.5 gpf, and the one toilet in the men's room has a broken flush valve; therefore, uses about 4 gpf. This ECM calculated water savings from replacing, or retrofitting, the toilets with dual flush valves. Dual flush valves save water by using 1.6 gpf for solids, and 0.8 gpf for liquids; standard toilets use 1.6 gpf regardless. All toilets would need to be completely replaced, except the toilet in the police locker room and employee restroom, which can be retrofitted.

To calculate the savings of installing a dual flush retrofit kit, and dual flush, low flow toilets, the existing water usage, which was estimated based on discussions with building personnel, was compared to the proposed water usage using replacement toilets and retrofit kits. An approximate number of occupants and types of usage were able to be determined. The savings was calculated based on the amount of liquid

flushes since the retrofits only save water when flushing liquids. By installing new toilets and dual flush retrofit kits, about 32,000 gallons of water, and \$300 could be saved.

Dual flush valves have an approximate lifespan of about 15 years according to manufacturers. The total energy savings over the life of the project would be 480,000 gallons of water and \$4,500.

The implementation cost and savings related to this ECM are presented in Appendix G and summarized below:

**ECM-6 Dual Flush Toilets** 

Budgetary Cost		Annua	l Utility Savings			Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Elec	tricity	kgals	Total	ROI			
\$	kW	kWh	Water	\$		\$	Years	Years
3,900	0	0	32	300	0.2	NA	13.0	NA

<sup>\*</sup>There are no incentives available through the New Jersey Pay For Performance or Direct Install Programs for this ECM. See Section 5.0 for other incentive opportunities.

This measure is not recommended.

#### 4.7 ECM-7 Install Storm Windows in Courtroom

Most of the windows in the building are newer, and double paned. They are in good condition with good seals, and minimal infiltration. The windows in the courtroom are original to the building's construction, are single pane, and have ineffective seals. Replacing the deteriorated windows is an option, but it is very expensive and typically yields a payback between 20 and 30 years. This ECM assesses installing storms on the courtroom windows.

To calculate the savings of adding storm windows in the courtroom, the existing window conditions were evaluated. There are eight, 2'x5' windows that could benefit from storms. Based on the condition of the courtroom windows, it was estimated they have a thermal resistance of about R-0.95 and an air infiltration rate of about 0.4 cfm per linear foot. The storm windows would add a half inch of air to serve as an insulator, and also decrease infiltration. This is expected to result in a thermal resistance of about R-2 and infiltration rate of 0.2 cfm per linear foot. The difference is a saving of about 110 therms, 10 kWh, and \$150.

Storm windows have an expected life of 25 years, according to the manufacturer, and total energy savings over the life of the project are estimated at 2,750 therms, 250 kWh and \$3,750.

The implementation cost and savings related to this ECM are presented in Appendix H and summarized as follows:

**ECM-7 Install Storm Windows in Courtroom** 

Budgetary Cost		Annua	l Utility Savings			Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity Therms Total				ROI			
\$	kW	kWh	Natural Gas	\$		\$	Years	Years
1,500	0	10	110	150	1.5	NA	10.0	NA

<sup>\*</sup>There are no incentives available through the New Jersey Pay For Performance or Direct Install Programs for this ECM. See Section 5.0 for other incentive opportunities.

This measure is recommended.

#### 4.8 ECM-8 Increase Wall Insulation in Courtroom

The courtroom walls are constructed of brick fascia, an air space, and filled concrete block. The thermal resistance of the wall can be calculated by summing all thermal resistances of each wall component. The R-value of the courtroom wall was calculated at about R-6.2. This ECM evaluated the addition of 3.5" thick craft faced insulation in the walls, and construction of a new wall along the inside of the old wall, which would increase the thermal resistance to about R-19.8.

To calculate the savings, the existing and proposed conditions were compared with outdoor air temperature bin data from Newark, NJ. The efficiency of the heating and cooling equipment was used to determine the amount of energy required to heat and cool the space, and the area of the exterior walls was calculated to determine the amount of heat transfer that occurs through the building envelope. The difference between the existing and proposed conditions resulted in a savings of about 150 therms of natural gas, and 60 kWh per year.

This ECM would require metal stude installed, then drywall, and paint over the drywall. This work was accounted for in the budgetary cost.

Insulation has an expected life of 24 years, according to ASHRAE, and total energy savings over the life of the project are estimated at 3,600 therms, 1,440 kWh, and \$4,800.

The implementation cost and savings related to this ECM are presented in Appendix I and summarized below:

**ECM-8 Increase Wall Insulation in Courtroom** 

Budgetary		Annua	l Utility Savings			Potential	Payback	Payback
Cost						Incentive*	(without incentive)	(with incentive)
	Electricity Therms Total			ROI				
\$	kW	kWh	Natural Gas	\$		\$	Years	Years
3,900	0	60	150	200	0.2	0	19.5	NA

<sup>\*</sup>There are no incentives available through the New Jersey Pay For Performance or Direct Install Programs for this ECM. See Section 5.0 for other incentive opportunities.

This measure is not recommended.

### 4.9 ECM-9 Replace Court Office RTU with More Efficient Unit

The Carrier RTU that serves the court office has a standard heating efficiency of about 80%; cooling capacity of 10 tons and cooling efficiency of about 1.48 kW/ton. This efficiency was calculated based on known amperage, voltage, and estimated power factor. The unit is approximately 12 years' old and is nearing the end of its useful life. This ECM assessed replacing the unit with a higher efficiency model.

To calculate the savings of a new unit, the existing and new unit efficiencies were compared. A comparable new system would achieve an efficiency of 82% in heating and 1.04 kW/ton in cooling. A block load was created for the space and evaluated with temperature bin data from Newark, NJ to determine heating and cooling loads. Installing a new unit could save about 30 therms of natural gas and 1,850 kWh in cooling energy. Additionally, there would be a fan efficiency savings of about 720 kWh, based on the existing standard efficiency motor, and replacement premium efficiency motor. In total, this amounts to about \$500 in annual savings.

Packaged rooftop units have an expected life of 15 years, according to ASHRAE, and total energy savings over the life of the project are estimated at 600 therms, 38,850 kWh and \$7,500.

The implementation cost and savings related to this ECM are presented in Appendix I and summarized below:

ECM-9 Replace Court Office RTU with More Efficient Unit

Budgetary Cost		Annua	l Utility Savings			Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Elec	tricity	Therms	Total	ROI			
\$	kW	kWh	Natural Gas	\$		\$	Years	Years
11,300	0	2,570	30	500	(0.3)	6,800	22.5	9.0

<sup>\*</sup> Incentive shown is per the 2011 New Jersey Direct Install Program. See Section 5.0 for other incentive opportunities.

This measure is recommended.

### 5.0 PROJECT INCENTIVES

### 5.1 Incentives Overview

### 5.1.1 New Jersey Pay For Performance Program

The building will be eligible for incentives from the New Jersey Office of Clean Energy. Particularly, significant incentives will be available from the New Jersey Pay for Performance (P4P) Program. The P4P program is designed for qualified energy conservation projects in facilities whose demand in any of the preceding 12 months exceeds 200 kW. However, the 200 kW/month average minimum has been waived for buildings owned by local governments or municipalities and non-profit organizations. Facilities that meet this criterion must also achieve a minimum performance target of 15% energy reduction by using the EPA Portfolio Manager benchmarking tool before and after implementation of the measure(s). If the participant is a municipal electric company customer, and a customer of a regulated gas New Jersey Utility, only gas measures will be eligible under the Program. American Recovery and Reinvestment Act (ARRA) funding, when available, may allow oil, propane and municipal electric customers to be eligible for the P4P Program. Available incentives are as follows:

Incentive #1: Energy Reduction Plan – This incentive is designed to offset the cost of services associated with the development of the Energy Reduction Plan (ERP). The standard incentive pays \$0.10 per square foot, up to a maximum of \$50,000, not to exceed 50% of facility annual energy cost, paid after approval of application. For building audits funded by the New Jersey Board of Public Utilities, which receive an initial 75% incentive toward performance of the energy audit, facilities are only eligible for an additional \$0.05 per square foot, up to a maximum of \$25,000, rather than the standard incentive noted above.

Incentive #2: Installation of Recommended Measures – This incentive is based on projected energy saving and designed to pay approximately 60% of the total performance-based incentive. Base incentives deliver \$0.11/kWh and \$1.10/therm not to exceed 30% of total project cost.

Incentive #3: Post-Construction Benchmarking Report – This incentive is paid after acceptance of a report proving energy savings over one year utilizing the Environmental Protection Agency (EPA) Portfolio Manager benchmarking tool. Incentive #3 base incentives deliver \$0.07/kWh and \$0.70/therm not to exceed 20% of total project cost.

Combining incentives #2 and #3 will provide a total of \$0.18/kWh and \$1.80/therm not to exceed 50% of total project cost. Additional incentives for #2 and #3 are increased by \$0.005/kWh and \$0.05/therm for each percentage increase above the 15% minimum target to 20%, calculated with the EPA Portfolio Manager benchmarking tool, not to exceed 50% of total project cost.

### 5.1.2 New Jersey Smart Start Program

For this program, specific incentives for energy conservation measures are calculated on an individual basis utilizing the 2010 New Jersey Smart Start incentive program. This program provides incentives dependent upon mechanical and electrical equipment. If applicable, incentives from this program are reflected in the ECM summaries and attached appendices.

If the building qualifies and enters into the New Jersey Pay for Performance Program, all energy savings will be included in the total building energy reduction, and savings will be applied towards the Pay for Performance incentive. A project is not applicable for both New Jersey incentive programs.

### 5.1.3 Energy Efficient and Conservation Block Grant

The following is a brief summary of the Energy Efficient and Conservation Block Grant (EECBG) program. The Energy Efficiency and Conservation Block Grant Complete Program Application Package should be consulted for rules and regulations.

Additional funding is available to local government entities through the EECBG, a part of New Jersey's Clean Energy program (NJCEP). The grant is for local government entities only, and can offset the cost of energy reduction implementation to a maximum of \$50,000 per entity.

This program is provided in conjunction with NJCEP funding and any utility incentive programs; the total amount of the three incentives combined cannot exceed 100% of project cost. Funds shall first be provided by NJCEP, followed by the EECBG and any utility incentives available to the customer. The total amount of the incentive shall be determined by TRC Solutions, a third party technical consulting firm for the NJCEP.

In order to receive EECBG incentives, local governments must not have received a Direct Block Grant from the US Department of Energy. A list of the 512 qualifying municipalities and counties is provided on the NJCEP website. Qualifying municipalities must participate in at least one eligible Commercial & Industrial component of the NJCEP, utility incentive programs, or install building shell measures recommended by the Local Government Energy Audit Program. Eligible conservation programs through NJCEP include:

- Direct Install
- Pay for Performance
- NJ SmartStart Buildings for measures recommended by a Local Government Energy Audit (LGEA) or an equivalent audit completed within the last 12 months
- Applicants may propose to independently install building shell measures recommended by a LGEA or an equivalent audit. The audit must have been completed within the past 12 months.
- Any eligible utility energy efficiency incentive program

Most facilities owned or leased by an eligible local government within the State of New Jersey are eligible for this grant. Ineligible facilities include casinos or other gambling establishments, aquariums, zoos, golf courses, swimming pools, and any building owned or leased by the United States Federal Government. New construction is also ineligible.

### 5.1.4 ARRA Initiative "Energy Efficiency Programs through the Clean Energy Program"

The American Recovery and Reinvestment Act (ARRA) Initiative is available to New Jersey oil, propane, cooperative and municipal electric customers who do not pay the Societal Benefits Charge. This charge can be seen on any electric bill as the line item "SBC Charge." Applicants can participate in this program in conjunction with other New Jersey Clean Energy Program initiatives including Pay for Performance, Local Government Energy Audits, and Direct Install programs.

Funding for this program is dispersed on a first come, first serve basis until all funds are exhausted. The program does not limit the municipality to a minimum or maximum incentive, and the availability of funding cannot be determined prior to application. If the municipality meets all qualifications, the application must be submitted to TRC Energy Solutions for review. TRC will then determine the amount

of the incentive based on projected energy savings of the project. It is important to note that all applications for this incentive must be submitted before implementation of energy conservation measures.

Additional information is available on New Jersey's Clean Energy Program website.

### 5.1.5 Direct Install Program

The Direct Install Program targets small and medium sized facilities where the peak electrical demand does not exceed 200 kW in any of the previous 12 months. Buildings must be located in New Jersey and served by one of the state's public, regulated electric or natural gas utility companies. On a case-by-case basis, the program manager may accept a project for a customer that is within 10% of the 200 kW peak demand threshold.

The 200 kW peak demand threshold has been waived for local government entities that receive and utilize their Energy Efficiency and Conservation Block Grant as discussed in section 5.1.3 in conjunction with Direct Install.

Direct Install is funded through New Jersey's Clean Energy Program and is designed to provide capital for building energy upgrade projects to fast track implementation. The program will pay up to 60% of the costs for lighting, HVAC, motors, natural gas, refrigeration, and other equipment upgrades with higher efficiency alternatives. If a building is eligible for this funding, the Direct Install Program can significantly reduce the implementation cost of energy conservation projects.

The program pays a maximum amount of \$50,000 per building, and up to \$250,000 per customer per year. Installations must be completed by a Direct Install participating contractor, a list of which can be found on the New Jersey Clean Energy Website at http://www.njcleanenergy.com. Contractors will coordinate with the applicant to arrange installation of recommended measures identified in a previous energy assessment, such as this document.

### 5.2 Somerdale Building Incentives

### 5.2.1 New Jersey Pay For Performance Program

The building is eligible for all three incentives available from the New Jersey P4P program. Incentive #1 is for the development of an energy reduction plan and will pay \$.05/ square foot of the building footprint, which equates to about \$400. Implementation of the energy conservation measures discussed in this report is expected to reduce the building's energy usage by over 15% which qualifies it for both incentives #2 and #3. Based on a 27% savings, combining incentives #2 and #3 will provide maximum savings of \$0.24/ kWh and \$2.40/ therm not to exceed 50% of the total project cost. The building is projected to save about 24,180 kWh which amounts to about \$5,300 in incentives. The building is also projected to save about 1,140 therms of natural gas. With New Jersey's current incentive structure, this would qualify for about \$2,600 in incentive money. Combining all incentives in the P4P program would amount to approximately \$8,400, reducing the overall payback of the project from 5.2 years to 3.9 years. See Appendix K for calculations.

#### 5.2.2 New Jersey Smart Start Program

The Somerdale Municipal Building is eligible for incentives from the New Jersey Smart Start Program. However, incentives cannot be obtained for the same ECMs under both the Smart Start and Direct Install Programs. It will be up to the borough to decide which incentive should be applied for with respect to each measure. In most cases, the direct install program provides more funding than Smart Start Program.

Only ECM 4, Replacing the Electric Domestic Hot Water heater is recommended to be applied for under the Smart Start Program. This ECM is not covered in the Direct Install Program. The Smart Start incentive would provide \$300 towards a new on-demand natural gas unit.

#### 5.2.3 Energy Efficient and Conservation Block Grant

The Somerdale Municipal Building is owned by local government which makes it eligible for this incentive. The incentive amount is determined by TRC Solutions and is not calculable at this time. Further information about this incentive, including the application, can be found at: <a href="http://www.njcleanenergy.com/commercial-industrial/programs/energy-efficiency-and-conservation-block-grants">http://www.njcleanenergy.com/commercial-industrial/programs/energy-efficiency-and-conservation-block-grants</a>

### 5.2.4 ARRA Initiative "Energy Efficiency Programs through the Clean Energy Program"

The Borough does pay the Societal Benefits Charge and is therefore not able to receive this incentive.

### 5.2.5 Direct Install Program

Municipal Building will be eligible to receive funding from the Direct Install Program. This money will be in conjunction with the Energy Efficiency and Conservation Block Grant. Certain ECMs will be eligible for this incentive. The program would pay 60% of the implementation cost for approved incentives. The approved incentives for the Municipal Building would be Lighting Replacements with Controls, Temperature Setback, and the Replacement of the Court Office RTU. These ECMs have a combined implementation cost of about \$19,600. The Direct Install Program would pay about \$11,800 of this cost bringing the combined payback of these measures from about 4.3 years to 2.6 years.

In order to apply for this program the borough must contact the Direct Install contractor for Camden County, Hutchinson Mechanical Services. Contact information is available on the New Jersey Clean Energy Website.

### 6.0 ALTERNATIVE ENERGY SCREENING EVALUATION

#### 6.1 Geothermal

Geothermal heat pumps (GHP) transfer heat between the constant temperature of the earth and the building to maintain the building's interior space conditions. Below the surface of the earth throughout New Jersey the temperature remains in the low 50s°F range throughout the year. This stable temperature provides a source for heat in the winter and a means to reject excess heat in the summer. With GHP systems, water is circulated between the building and the piping buried in the ground. The ground heat exchanger in a GHP system is made up of a closed or open loop pipe system. Most common is the closed loop in which high density polyethylene pipe is buried horizontally at 4-6 feet deep or vertically at 100 to 400 feet deep. These pipes are filled with an environmentally friendly antifreeze/water solution that acts as a heat exchanger. In the summer, the water picks up heat from the building and moves it to the ground. In the winter the system reverses and fluid picks up heat from the ground and moves it to the building. Heat pumps make collection and transfer of this heat to and from the building possible.

The building uses gas-fired packaged rooftop units to meet its HVAC needs. These are not compatible with a geothermal energy source. Therefore, to take advantage of a GHP system, the existing mechanical equipment would have to be removed; and either a low temperature closed loop water source heat pump system or a water to water heat pump system would have to be installed to realize the benefit of the consistent temperature of the ground.

This measure is not recommended due to the extent of HVAC system renovation needed for implementation.

#### 6.2 Solar

### 6.2.1 Photovoltaic Rooftop Solar Power Generation

The Municipal Building was evaluated for the potential to install rooftop photovoltaic (PV) solar panels for power generation. Present technology incorporates the use of solar cell arrays that produce direct current (DC) electricity. This DC current is converted to alternating current (AC) with the use of an electrical device known as an inverter. The building's roof has sufficient room to install a solar cell array above the library and courtroom but it would need to be angled south for maximum efficiency. A structural analysis would be required to determine if the roof framing could support a cell array.

The PVWATTS solar power generation model was utilized to calculate PV power generation. The New Jersey Clean Power Estimator provided by the New Jersey Clean Energy Program is presently being updated; therefore, the site recommended use of the PVWATT solar grid analyzer version 1. The closest city available in the model is Newark, New Jersey and a fixed tilt array type was utilized to calculate energy production. The PVWATT solar power generation model is provided in appendix L.

The State of New Jersey incentives for non-residential PV applications is \$0.75/watt up to 30 kW of installed PV array. Projects up to 50 kW are eligible to apply. Federal tax credits are also available for renewable energy projects up to 30% of installation cost. Municipalities do not pay federal taxes and would not be able to utilize the federal tax credit incentive.

Installation of (PV) arrays in the state of New Jersey will allow the owner to participate in the New Jersey solar renewable energy certificates program (SREC). This is a program that has been set up to allow entities with large amounts of environmentally unfriendly emissions to purchase credits from zero

emission (PV) solar-producers. An alternative compliance penalty (ACP) is paid for by the high emission producers and is set each year on a declining scale of 3% per year. One SREC credit is equivalent to 1000 kilowatt hours of PV electrical production; these credits can be traded for periods of 15 years from the date of installation. The cost of the ACP penalty for 2010 was \$700; this is the amount that must be paid per SERC by the high emission producers. The expected dollar amount that will be paid to the PV producer for 2011 is expected to be \$600/SREC credit. Payments that will be received from the PV producer will change from year to year dependent upon supply and demand. Renewable Energy Consultants is a third party SREC broker that has been approved by the New Jersey Clean Energy Program. As stated above there is no definitive way to calculate an exact price that will be received by the PV producer per SREC over the next 15 years. Renewable Energy Consultants estimated an average of \$487/ SERC per year and this number was utilized in the cash flow for this report.

The building had a maximum electricity demand of 41.7 kW and a minimum of 16.8kW, over the previous 24 months. The monthly average over the observed 12 month period was 29.2 kW. The existing load does not justify the use of the maximum incentive cap of 50 kW of installed PV solar array. Instead, a 30 kW was used for the calculations. Based on Contractor pricing obtained from The Solar Center in Rockaway, NJ, a 30 kW system would cost about \$5.50/Watt, or \$5,500/kW.

Space considerations must be taken into account before installation and other cost considerations will also need to be considered. PV panels have an approximate 20 year life span; however, the inverter device that converts DC electricity to AC has a life span of 10 to 12 years and will need to be replaced multiple times during the useful life of the PV system.

The implementation cost and savings related to this ECM are presented in Appendix L and summarized below:

Photovoltaic (PV) Rooftop Solar Power Generation - 30 kW System

Budgetary Cost	Annu	al Utility Sa	avings		Total Savings	New Jersey Renewable Energy Incentive*	New Jersey Renewable SREC**	Payback (without incentive)	Payback (with incentives)
	Electr	ricity	Natural Gas	Total					
\$	kW	kWh	Therms	\$	\$	\$	\$	Years	Years
165,000	0	37,510	0	6,500	6,500	22,500	18,300	>25	5.7

<sup>\*</sup>Incentive based on New Jersey Renewable Energy Program for non-residential applications of \$0.75 per Watt of installed capacity

The Somerdale Municipal Building does have space on the roof for a PV system; however there are lots of tall trees that could potentially cast shadows over the solar cells.

While the payback period is within the parameters for recommended measures, further investigation of possible installation locations, required system maintenance, and local installation costs are suggested prior to consideration for implementation.

#### 6.2.2 Solar Thermal Hot Water Plant

Active solar thermal systems use solar collectors to gather the sun's energy to heat water, other fluids, or air. An absorber in the collector converts the sun's energy into heat. The heat is then transferred by circulating water, antifreeze, or sometimes air to another location for immediate use or storage for later

<sup>\*\*</sup> Estimated Solar Renewable Energy Certificate Program (SREC) for 15 years at \$487/1000 kWh

utilization. Applications for active solar thermal energy include providing hot water, heating swimming pools, space heating, and preheating air in residential and commercial buildings.

A standard solar hot water system is typically composed of solar collectors, a heat storage vessel, piping, circulators, and controls. Systems are typically integrated to work alongside a conventional heating system that provides heat when solar resources are not sufficient. The solar collectors are usually placed on the roof of the building, oriented south, and tilted around the site's latitude, to maximize the amount of radiation collected on a yearly basis.

Several options exist for using active solar thermal systems for space heating. The most common method involves using glazed collectors to heat a liquid held in a storage tank (similar to an active solar hot water system). The most practical system would transfer the heat from the panels to thermal storage tanks and transfer solar produced thermal energy to use for domestic hot water production. DHW is presently produced by an electric water heater and a solar DHW system would save site electricity.

Currently, an incentive is not available for installation of thermal solar systems. A federal tax credit of 30% of installation cost for the thermal applications is available; however, Somerdale does not pay federal taxes and, therefore, would not benefit from this program.

The implementation cost and savings related to this ECM are presented in appendix M and summarized as follows:

Solar Thermal Domestic Hot Water Plant

Budgetary Cost		Annua	l Utility Savings		Total Savings	New Jersey Renewable Energy Incentive	Payback (without incentive)	Payback (with incentive)
	Elec	tricity	Natural Gas	Total				
\$	kW	kWh	Therms	\$	\$	\$	Years	Years
12,200	0	1110	0	200	200	NA	>25	NA

<sup>\*</sup> No incentive is available in New Jersey at this time.

This measure is not recommended.

### 6.3 Wind

Small wind turbines use a horizontal axis propeller, or rotor, to capture the kinetic energy of the wind and convert it into rotary motion to drive a generator which usually is designed specifically for the wind turbine. The rotor consists of two or three blades, usually made from wood or fiberglass. These materials give the turbine the needed strength and flexibility, and have the added advantage of not interfering with television signals. The structural backbone of the wind turbine is the mainframe, and includes the sliprings that connect the wind turbine, which rotates as it points into changing wind directions, and the fixed tower wiring. The tail aligns the rotor into the wind.

To avoid turbulence and capture greater wind energy, turbines are mounted on towers. Turbines should be mounted at least 30 feet above any structure or natural feature within 300 feet of the installation. Smaller turbines can utilize shorter towers. For example, a 250-watt turbine may be mounted on a 30-50 foot tower, while a 10 kW turbine will usually need a tower of 80-120 feet. Tower designs include tubular or latticed, guyed or self-supporting. Wind turbine manufacturers also provide towers.

The New Jersey Clean Energy Program for small wind installations has designated numerous preapproved wind turbines for installation in the State of New Jersey. Incentives for wind turbine installations are based on kilowatt hours saved in the first year. Systems sized under 16,000 kWh per year of production will receive a \$3.20 per kWh incentive. Systems producing over 16,000 kWh will receive \$51,200 for the first 16,000 kWh of production with an additional \$0.50 per kWh up to a maximum cap of 750,000 kWh per year. Federal tax credits are also available for renewable energy projects up to 30% of installation cost for systems less than 100 kW. However, as noted previously, municipalities do not pay federal taxes and are not eligible for the tax credit incentive.

The most important part of any small wind generation project is the mean annual wind speed at the height of which the turbine will be installed. In the Somerdale Borough area, the map shown in the appendices indicates a mean annual wind speed of about 10.5 miles per hour. For the building, there are site restrictions, such as parking lots, trees and surrounding structures that would greatly affect a tower location.

A wind speed map and aerial site photo are included in Appendix N.

Due to the low annual wind speed, and surrounding trees and structures, a wind turbine is not recommended.

### 6.4 Combined Heat and Power Generation (CHP)

Combined heat and power, cogeneration, is self-production of electricity on-site with beneficial recovery of the heat byproduct from the electrical generator. Common CHP equipment includes reciprocating engine-driven, micro turbines, steam turbines, and fuel cells. Typical CHP customers include industrial, commercial, institutional, educational institutions, and multifamily residential facilities. CHP systems that are commercially viable at the present time are sized approximately 50 kW and above, with numerous options in blocks grouped around 300 kW, 800 kW, 1,200 kW and larger. Typically, CHP systems are used to produce a portion of the electricity needed by a facility, with the balance of electric needs satisfied by purchase from the grid.

Any proposed CHP project will need to consider many factors, such as existing system load, use of thermal energy produced, system size, natural gas fuel availability, and proposed plant location. The building does not have an excessively large electricity demand, and it does not have a heating load to use the thermal byproduct in the summer. An absorption chiller could be installed to utilize the heat to produce chilled water; however, there is no chilled water distribution system in the building. The most viable selection for a CHP plant at this location would be a reciprocating engine natural gas-fired unit. Purchasing this system and performing modifications to the existing HVAC and electrical systems would greatly outweigh the savings over the life of the equipment.

This measure is not recommended.

#### 6.5 Biomass Power Generation

Biomass power generation is a process in which waste organic materials are used to produce electricity or thermal energy. These materials would otherwise be sent to the landfill or expelled to the atmosphere. To participate in NJCEP's Customer On-Site Renewable Energy program, participants must install an on-site sustainable biomass or fuel cell energy generation system. Incentives for bio-power installations are available to support up to 1MW-dc of rated capacity.

\*Class I organic residues are eligible for funding through the NJCEP CORE program. Class I wastes include the following renewable supply of organic material:

- · Wood wastes not adulterated with chemicals, glues or adhesives
- Agricultural residues (corn stover, rice hulls or nut shells, manures, poultry litter, horse manure, etc) and/or methane gases from landfills
- Food wastes
- · Municipal tree trimming and grass clipping wastes
- · Paper and cardboard wastes
- Non adulterated construction wood wastes, pallets

The NJDEP evaluates biomass resources not identified in the RPS.

Examples of eligible facilities for a CORE incentive include:

- · Digestion of sewage sludge
- · Landfill gas facilities
- · Combustion of wood wastes to steam turbine
- · Gasification of wood wastes to reciprocating engine
- · Gasification or pyrolysis of bio-solid wastes to generation equipment

This measure is not recommended due to the extent of HVAC system renovation needed for implementation.

### 6.6 Demand Response Curtailment

Presently, electricity is delivered by PSE&G, which receives the electricity from regional power grid RFC. PSE&G is the regional transmission organization (RTO) that coordinates the movement of wholesale electricity in all or parts of 13 states and the District of Columbia including the State of New Jersey.

Utility Curtailment is an agreement with the PSE&G regional transmission organization and an approved Curtailment Service Provider (CSP) to shed electrical load by either turning major equipment off or energizing all or part of a facility utilizing an emergency generator; therefore, reducing the electrical demand on the utility grid. This program is to benefit the utility company during high demand periods and PSE&G offers incentives to the CSP to participate in this program. Enrolling in the program will require program participants to drop electrical load or turn on emergency generators during high electrical demand conditions or during emergencies. Part of the program also will require that program participants reduce their required load or run emergency generators with notice to test the system.

A PSE&G pre-approved CSP will require a minimum of 100 kW of load reduction to participate in any curtailment program. The Somerdale Municipal building had a monthly average electricity demand of 29.2 kW and a maximum demand of 41.6 kW from October 2008 through October 2010.

This measure is not recommended because the facility does not have adequate load to meet the required minimum load reduction.

<sup>\*</sup> From NJOCE Website

### 7.0 EPA PORTFOLIO MANAGER

The United State Environmental Protection Agency (EPA) is a federal agency in charge of regulating environment waste and policy in the United States. The EPA has released the EPA Portfolio Manager for public use. The program is designed to allow property owners and managers to share, compare and improve upon their facility's energy consumption. Inputting such parameters as electricity, heating fuel, building characteristics and location into the website based program generates a naturalized energy rating score out of 100. Once an account is registered, monthly utility data can be entered to track the savings progress and retrieve an updated energy rating score on a monthly basis.

The Municipal Building is considered a high energy consumer by the Portfolio Manager with a Site Energy Usage Index (EUI) of 82 kBTU/ft²/year. Several factors contribute to the unfavorable EUI, including, but not limited to, wasted energy from poor insulation, lack of heating controls, and inefficient lighting. By implementing the measures discussed in this report, it is expected that the EUI can be reduced to approximately 59 kBTU/ft²/year; the national average for this building type is 68 kBTU/ft²/year. The EPA Portfolio Manager generated an energy rating score for the building at 32. This number represents how energy efficient a building is on a scale from 1 to 100 with 100 being the best. In order for a building to receive and energy star label, this energy benchmark rating must be at least 75. As energy use decreases from the implementation of the proposed ECMs, this rating will increase.

A full EPA Energy Star Portfolio Manager Report is located in Appendix O.

The user name and password for the EPA Portfolio Manager Account has been provided to Victor Cantillo, the Somerdale Borough CFO.

### 8.0 CONCLUSIONS & RECOMMENDATIONS

The energy audit conducted by CHA at the Borough of Somerdale Municipal Building in Somerdale, New Jersey identified potential ECMs for lighting replacements and controls, electric DHW heater replacement, temperature setback, and RTU replacement. Potential annual savings of \$5,700 may be realized for the recommended ECMs, with a summary of the costs, savings, and paybacks as follows:

ECM-3 Combined Lighting Replacements with Lighting Controls

Budgetary Cost		Annua	l Utility Savings			Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Elec	tricity	Therms	Total	ROI			(**************************************
. \$	kW	kWh	Natural Gas	\$		\$	Years	Years
7,800	2.0	19,220	0	2,700	4.2	4,700	2.9	1.1

<sup>\*</sup> Incentive shown is per the 2010 Direct Install Program. See Section 5.0 for other incentive opportunities.

ECM-4 Replace Electric DHW Heater with On Demand Gas

Budgetary Cost		Annua	l Utility Savings			Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Elec	tricity	Therms	Total	ROI			
\$	kW	kWh	Natural Gas	\$		\$	Years	Years
4,200	4.5	4,200	(100)	1,100	2.4	300	3.8	3.5

<sup>\*</sup> Incentive shown is per the 2010 New Jersey Smart Start Program's Gas Hot Water Heating Application, See Section 5.0 for other incentive opportunities.

**ECM-5 Temperature Setback** 

Budgetary Cost		Annua	l Utility Savings			Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Elec	tricity	Therms	Total	ROI			
\$	kW	kWh	Natural Gas	\$		\$	Years	Years
500	0	1,120	850	1,400	41.0	300	0.4	0.1

<sup>\*</sup> Incentive shown is per the 2011 New Jersey Direct Install Program. See Section 5.0 for other incentive opportunities.

#### **ECM-7 Install Storm Windows in Courtroom**

Budgetary Cost		Annua	l Utility Savings			Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Elec	tricity	Therms	Total	ROI			
\$	kW	kWh	Natural Gas	\$		\$	Years	Years
1,500	0	10	110	150	1.5	NA	10.0	NA

<sup>\*</sup>There are no incentives available through the New Jersey Pay For Performance or Direct Install Programs for this ECM. See Section 5.0 for other incentive opportunities.

ECM-9 Replace Court Office RTU with More Efficient Unit

Budgetary Cost		Annua	al Utility Savings			Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Elec	tricity	Therms	Total	ROI			
\$	kW	kWh	Natural Gas	\$		\$	Years	Years
11,300	0	720	30	500	(0.3)	6,800	22.5	9.0

<sup>\*</sup> Incentive shown is per the 2011 New Jersey Direct Install Program. See Section 5.0 for other incentive opportunities.

# **APPENDICES**

A	Utility Usage Analysis
В	ECM-1 Lighting Replacements
C	ECM-2 Install Lighting Controls
D	ECM-3 Lighting Replacements with Controls
E	ECM-4 Replace Electric DHW with On Demand Gas
F	ECM-5 Temperature Setback
G	ECM-6 Dual Flush Toilets
H	ECM-7 Install Storm Windows in Courtroom
I	ECM-8 Increase Wall Insulation in Courtroom
J	ECM-9 Replace Court Office RTU with More Efficient Uni
K	New Jersey Pay For Performance Incentive Program
L	Photovoltaic (PV) Rooftop Solar Power Generation
M	Solar Thermal Domestic Hot Water Plant
N	Wind
O	EPA Portfolio Manager
P	Building Summaries and ROI Calculation
Q	Building Block Loads
R	Equipment Inventory and Lighting

# APPENDIX A

**Utility Usage Analysis** 

New Jersey BPU Energy Audit Program CHA Project Number: 22424 Somerdale Municipal Building


**South Jersey Gas** 

Borough of Somerdale - Natural Gas Account Number: 20341003307

Month	Therms	C	harges (\$)	(\$	/therm)
January-10	797	\$	1,044.65	\$	1.31
February-10	724	\$	956.52	\$	1.32
March-10	705	\$	933.91	\$	1.32
April-10	198	\$	274.87	\$	1.39
May-10	41	\$	71.35	\$	1.74
June-10	15	\$	39.98	\$	2.59
July-10	5	\$	25.42	\$	4.93
August-10	0	\$	18.10	\$	-
September-10	1	\$	21.91	\$	21.48
October-10	0	\$	20.70	\$	_
November-10	. 49	\$	81.92	\$	1.67
December-10	361	\$	459.00	\$	1.27

Total	2,896	\$ 3,948	\$ 1.36
Most Recent Yr	2,896	\$ 3,948	\$ 1.36


Natural Gas Usage - Somerdale Municipal Building



New Jersey BPU Energy Audit Program CHA Project Number: 22424 Somerdale Municipal Building PSE&G Borough of Somerdale- Electricity Account Number: 6510183102

				ਨੂੰ ਹ	Charges			Unit Costs	
	Consumption	Demand	Total	Demand	Summer Demand	Consumption	Blended Rate	Consumption	Demand
Month	(kWh)	(kW)	(\$)	(\$)	(\$)	(\$)	(\$/kWh)	(\$/kWh)	(\$/kW)
October-08	10,320	41.6	\$1,671.63	\$398.06	\$0.00	\$1,273.57	0.1620	0.1234	9.57
November-08	14,880	32.0	\$2,494.88	\$721.97	\$0.00	\$1,772.91	0.1677	0.1191	22.56
December-08	2,760	19.2	\$1,181.00	\$311.50	\$0.00	\$869.50	0.1522	0.1120	16.22
January-09	6,720	19.2	\$1,079.74	\$311.81	\$0.00	\$767.93	0.1607	0.1143	16.24
February-09	6,560	21.6	\$1,100.10	\$321.44	\$0.00	\$778.66	0.1677	0.1187	14.88
March-09	6,720	20.8	\$1,135.24	\$318.33	\$0.00	\$816.91	0.1689	0.1216	15.30
April-09	7,680	16.8	\$1,209.15	\$302.75	\$0.00	\$906.40	0.1574	0.1180	18.02
May-09	2,360	36.0	\$1,238.62	\$377.96	\$0.00	\$860.66	0.1683	0.1169	10.50
June-09	10,240	31.2	\$1,951.31	\$374.96	\$227.00	\$1,349.35	0.1906	0.1318	19.29
July-09	11,120	32.8	\$2,237.00	\$397.52	\$238.64	\$1,600.84	0.2012	0.1440	19.40
August-09	13,680	40.0	\$2,701.76	\$425.75	\$291.02	\$1,984.99	0.1975	0.1451	17.92
September-09	11,520	40.8	\$2,376.08	\$429.77	\$296.84	\$1,649.47	0.2063	0.1432	17.81
October-09	1,600	31.2	\$597.55	\$394.65	\$0.00	\$202.90	0.3735	0.1268	12.65
November-09	13,440	18.4	\$1,908.38	\$345.92	\$0.00	\$1,562.46	0.1420	0.1163	18.80
December-09	9,740	18.4	\$1,658.72	\$345.92	\$0.00	\$1,312.80	0.1703	0.1348	18.80
January-10	8,000	18.4	\$1,256.55	\$345.17	\$0.00	\$911.38	0.1571	0.1139	18.76
February-10	7,120	18.4	\$1,183.24	\$344.62	\$0.00	\$838.62	0.1662	0.1178	18.73
March-10	008'9	19.2	\$1,148.48	\$347.85	\$0.00	\$800.63	0.1689	0.1177	18.12
April-10	7,360	32.0	\$1,265.30	\$399.48	\$0.00	\$865.82	0.1719	0.1176	12.48
May-10	7,360	29.6	\$1,242.50	\$389.79	\$0.00	\$852.71	0.1688	0.1159	13.17
June-10	10,960	37.6	\$2,081,33	\$400.89	\$285.01	\$1,395.43	0.1899	0.1273	18.24
July-10	13,920	40.8	\$2,574.24	\$401.68	\$315.04	\$1,857.52	0.1849	0.1334	17.57
August-10	12,720	40.0	\$2,410.51	\$398.36	\$308.86	\$1,703.29	0.1895	0.1339	17.68
September-10	11,840	41.6	\$2,343,43	\$406.05	\$321.21	\$1,616.17	0.1979	0.1365	17.48
October-10	8,560	31.2	\$1,420.76	\$363.22	\$0.00	\$1,057.54	0.1660	0.1235	11.64
		;							
Total	233,980	41.6	\$41,467.50	\$9,575.42	\$2,283.62	\$29,608.46		0.1265	13.14
Most Recent Yr	117,820	41.6	\$20,493.44	\$4,488.95	\$1,230.12	\$14,774.37	0.1739	0.1254	12.99






New Jersey BPU Energy Audit Program CHA Project Number: 22424 Somerdale Municipal Building

105 Kennedy BLVD					
Account	20341003307				
Date	Usage (kgals)	Cost (\$)		Cost(\$)/kgal	
January-09	11	\$	85.75	\$	7.80
February-09	6	\$	57.01	\$	9.50
March-09	6	\$	57.01	\$	9.50
April-09	5	\$	51.25	\$	10.25
May-09	6	\$	57.01	\$	9.50
June-09	5	\$	51.25	\$	10.25
July-09	7	\$	62.75	\$	8.96
August-09	9	\$	74.25	\$	8.25
September-09	35	\$	225.05	\$	6.43
October-09	5	\$	51.45	\$	10.29
November-09	5	\$	51.45	\$	10.29
December-09	5	\$	51.45	\$	10.29
January-10	5	\$	51.45	\$	10.29
February-10	5	\$	51.45	\$	10.29
March-10	6	\$	57.25	\$	9.54
April-10	5	\$	51.45	\$	10.29
May-10	5	\$	51.45	\$	10.29
June-10	4	\$	45.66	\$	11.42
July-10	4	\$	45.66	\$	11.42
August-10	5	\$	51.44	\$	10.29
September-10	4	\$	45.65	\$	11.41
October-10	5	\$	51.43	\$	10.29
November-10	5	\$	51.43	\$	10.29
Total	158	\$	1,430.00	\$	9.05
Most Recent Year	58	65	605.77	\$	10.44

<sup>\*</sup> Estimated based on Previous Usage



### **ELECTRIC MARKETERS LIST**

The following is a listing of marketers/suppliers/brokers that have been licensed by the NJ Board of Public Utilities to sell electricity to residential, small commercial and industrial customers served by the Public Service Electric and Gas Company distribution system. This listing is provided for informational purposes only and PSE&G makes no representations or warranties as to the competencies of the entities listed herein or to the completeness of this listing.

American Powernet Management 867 Berkshire Blvd, Suite 101 Wyomissing, PA 19610 www.americanpowernet.com Gerdau Ameristeel Energy Co. North Crossman Road Sayreville, NJ 08872 PPL EnergyPlus, LLC
Energy Marketing Center
Two North Ninth Street
Allentown, PA 18101
1-866-505-8825
http://www.pplenergyplus.com/

BOC Energy Services 575 Mountain Avenue Murray Hill, NJ 07974 www.boc-gases.com Gexa Energy LLC New Jersey 20 Greenway Plaza, Suite 600 Houston, TX 77046 (866) 304-GEXA Beth.miller@gexaenergy.com Sempra Energy Solutions The Mac-Cali Building 581 Main Street, 8<sup>th</sup> Floor Woodbridge, NJ 07095 (877) 273-6772 www.SempraSolutions.com

Commerce Energy Inc. 535 Route 38, Suite 138 Cherry Hill, NJ 08002 (888) 817-8572 or (858) 910-8099 www.commerceenergy.com Glacial Energy of New Jersey 2602 McKinney Avenue, Suite 220 Dallas, TX 75204 www.glacialenergy.com South Jersey Energy Company 1 South Jersey Plaza, Route 54 Folsom, NJ 08037 (800) 756-3749 www.sjindustries.com

ConEdison Solutions
701 Westchester Avenue
Suite 201 West
White Plains, NY 10604
(800) 316-8011
www.ConEdSolutions.com

Hess Corporation 1 Hess Plaza Woodbridge, NJ 07095 www.hess.com Strategic Energy, LLC 6 East Main Street, Suite 6E Ramsey, NJ 07446 (888) 925-9115 www.sel.com

Constellation NewEnergy, Inc. 1199 Route 22 East Mountainside, NJ 07092 908 228-5100 www.newenergy.com Integrys Energy Services, Inc 99 Wood Avenue, Suite 802 Iselin, NJ 08830 www.integrysenergy.com Suez Energy Resources NA 333 Thornall Street FL6 Edison, NJ 08818 866.999.8374(toll free) www.suezenergyresources.com

Credit Suisse (USA), Inc. 700 College Road East Princeton, NJ 08450 www.creditsuisse.com Liberty Power Delaware, LLC 1901 W Cypress Road, Suite 600 Fort Lauderdale, FL 33309 (866) Power-99 (866) 769-3799 www.libertypowercorp.com UGI Energy Services, Inc. d/b/a POWERMARK 1 Meridian Blvd. Suite 2C01 Wyomissing, PA 19610 (800) 427-8545 www.ugienergyservices.com

Direct Energy Services, LLC One Gateway Center, Suite 2600 Newark, NJ 07102 (973) 799-8568 www.directenergy.com

Liberty Power Holdings, LLC 1901 W Cypress Creek Road, Suite 600 Fort Lauderdale, FL 33309 (866) Power-99 (866) 769-3799 www.libertypowercorp.com

FirstEnergy Solutions 395 Ghent Road Suite 407 Akron, OH 44333 (800) 977-0500 www.fes.com Pepco Energy Services, Inc. d/b/a Power Choice 23 S. Kinderkamack Rd Ste D Montvale, NJ 07645 (800) 363-7499 www.pepco-services.com

### **GAS MARKETERS LIST**

The following is a listing of marketers/suppliers/brokers that have been licensed by the NJ Board of Public Utilities to sell natural gas to residential, small commercial and industrial customers served by the Public Service Electric and Gas Company distribution system. This listing is provided for informational purposes only and PSE&G makes no representations or warranties as to the competencies of the entities listed herein or to the completeness of this listing.

Gateway Energy Services
44 Whispering Pines Lane
Lakewood, NJ 08701
(800) 805-8586
www.gesc.com

Metro Energy Group, LLC 14 Washington Place Hackensack, NJ 07601 www.metroenergy.com RPL Holdings, Inc 601 Carlson Pkwy Minnetonka, MN 55305

Great Eastern Energy 3044 Coney Island Ave. PH Brooklyn, NY 11235 888-651-4121 www.greateasterngas.com Metromedia Energy, Inc. 6 Industrial Way Eatontown, NJ 07724 (800) 828-9427 www.metromediaenergy.com South Jersey Energy Company One South Jersey Plaza, Rte 54 Folsom, NJ 08037 (800) 756-3749 www.sjindustries.com/sje.htm

Hess Corporation 1 Hess Plaza Woodbridge, NJ 07095 (800) 437-7872 www.hess.com Mitchell- Supreme Fuel (NATGASCO) 532 Freeman Street Orange, NJ 07050 (800) 840-4GAS www.mitchellsupreme.com Sprague Energy Corp.
Two International Drive, Ste 200
Portsmouth, NH 03801
800-225-1560
www.spragueenergy.com

Hudson Energy Services, LLC 545 Route 17 South Ridgewood, NJ 07450 (201) 251-2400 www.hudsonenergyservices.com MxEnergy Inc. P.O. Box 177 Annapolis Junction, MD 20701 800-375-1277 www.mxenergy.com Stuyvesant Energy LLC 642 Southern Boulevard Bronx, NY 10455 (718) 665-5700 www.stuyfuel.com

Intelligent Energy 7001 SW 24<sup>th</sup> Avenue Gainesville, FL 32607 Sales: 1 877 I've Got Gas (1 877 483-4684) Customer Service: 1 800 927-9794 www.intelligentenergy.org Pepco Energy Services, Inc.
23 S Kinderkamack Rd, Suite D
Montvale, NJ 07645
(800) 363-7499
www.pepco-services.com

Tiger Natural Gas, Inc. 1422 E. 71st Street, Suite J. Tulsa, OK. 74136 1-888-875-6122 www.tigernaturalgas.com

Systrum Energy 877-SYSTRUM (877-797-8786) www.systrumenergy.com Plymouth Rock Energy, LLC 165 Remsen Street Brooklyn, NJ 11201 866-539-6450 www.plymouthrockenergy.com UGI Energy Services, Inc. d/b/a GASMARK 704 E. Main Street, Suite I Moorestown, NJ 08057 856-273-9995 www.ugienergyservices.com

Macquarie Cook Energy, LLC 10100 Santa Monica Blvd, 18<sup>th</sup> Fl Los Angeles, CA 90067 PPL EnergyPlus, LLC
Energy Marketing Center
Two North Ninth Street
Allentown, PA 18101
1-866-505-8825
www.pplenergyplus.com/natural+gas/

Woodruff Energy
73 Water Street
P.O. Box 777
Bridgeton, NJ 08302
(856) 455-1111
www.woodruffenergy.com

### APPENDIX B

ECM-1 Lighting Replacements

Cost of Electricity:

\$0.125 \$/kWh

\$12.99 \$/kW

_	· · · · · · · · · · · · · · · · · · ·			EXISTING CON	DITIONS								RETROFIT C	ONDITION	S				(	OST & SAVIN	GS ANALY	SIS		
	Area Description	No. of Fixtures	Standard Fixture Code	NYSERDA Fixture God		kW/Space	Exist Control	Annual Hours	Annual kWh	Number of Fixtures		Foothere Code	Fixture Code	Watts per Fixture	kW/Space		Annual Hours	kWh	Annual kWh Annual I Saved Saved	Saved	Retrofit Cost	NJ Lighting Incentive	Simple Payback With Out Incentive	0.407005004500000000
Field Code	Unique description of the location - Room number/Room name: Floor number (if applicable)	No. of fixtures before the retrofit	"Lighting Fixture Code" Example 2T 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape	Code from Table of Standar Fixture Wattages	d Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Fixt No.)	Pre-inst. control device	Estimated daily hours for the usage group		No. of fixtures after the retrofit	2T 40 R F(U)	Code" Example = 2'x2' Troff 40 2 lamps U shape	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Number of Fixtures)	Retrofit control device	Estimated annual hours for the usage group	(kW/space) * (Annual Hours)	(Original Annual kWh) - Annual kW, (Retrofit Annual (Retrofit An kWh) kW)		Cost for renovations to lighting system	Prescriptive Lighting Measures	Length of time for renovations cost to be recovered	Length of time renovations of to be recovered
	Maintenance Closet	11	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	2920	210		C 28 P F 2		F42SSILL	48	0.0	SW	2,920	140			\$ 106.25		8.5	7.3
	Police Bathroom Police Locker Room	1 1	1 Lamp T12 S 32 P F 2 (ELE)	F21SE F42LL	26 60	0.0	SW	2920 4380	76 263		1 Lamp T12 S 32 P F 2 (ELE)		F21SE F42LL	60	0.0	SW	2,920 4,380	76 263		\$ -	\$ - \$ -	7.7		<del></del>
	Prisoner Processing Room	5	1B 40 R F 2 (MAG)	F42SS	94	0.5	SW	8760	4,117		1B 28 R F 2		F42SSILL	48	0.2	SW	8,760	2,102		\$ 288.50			2.0	1.5
	Prisoner Processing Room	1	140	140/1	40	0.0	SW	8760	350	1	CF 13	100000000000000000000000000000000000000	CFQ13/1-L	15	0.0	SW	8,760	131		\$ 31.36			0.2	0.2
	Prisoner Processing Room Perimeter Office	1	X 7.0 W I 2 T 32 R F 4 (ELE)	EI10/2 F44ILL	20 112	0.0	Breaker SW	8760 2190	175	11	X 1.5C LED T 32 R F 4 (ELE)	1000	ELED1.5/1 F44ILL	1.5	0.0	Breaker SW	8,760 2,190	13 245		\$ 23.21	\$ 128.25 \$ -		5.5	5.1
	Sun Cabinet	1	W 32 W F 2 (MAG)	F42LE	71	0.1	SW	2190	245 155	<del>  </del>	W 32 W F 2 (MA)	G)	F42LE	71	0.1	SW	2,190	155		\$ -	\$		<del> </del>	+
13	nterrogation Room	1	S 32 P F 2 (ELE)	F42LL	60	0.1	SW	2600	156	1	S 32 P F 2 (ELE)		F42LL	60	0.1	sw	2,600	156	- 0.0	\$ -	\$ -			1
	Main Police Hallway	6	T 32 R F 4 (ELE)	F44ILL	112	0.7	SW	2600 2600	1,747 468		T 32 R F 4 (ELE) CF 26	2072032030303040320355	F44ILL CFQ26/1-L	112	0.7	SW	2,600	1,747		\$ - \$ 47.71	\$ -	\$0		1
	Main Police Halfway Sergeant Office 1	3 2	T 32 R F 4 (ELE)	160/1 F44ILL	60 112	0,2	SW	4380	981		T 32 R F 4 (ELE)	00095310053799399999	F44ILL	112	0.1	SW	2,600 4,380	211 981		\$ 47.71 \$ -			0.4	0.4
18	Sergeant Office 2	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	SW	4380	981	2	T 32 R F 4 (ELE)		F44ILL	112	0.2	sw	4,380	981	- 0.0	\$ -	\$ -	**		
	Sergeant Office 3	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	SW	4380	981		T 32 R F 4 (ELE)		F44ILL	112	0.2	SW	4,380	981		\$ -	\$ -	***		
	Chief's Office Storage/ Server Room	2	T 32 R F 4 (ELE)	F44ILL F44ILL	112	0.2	SW	4380 4380	981 981		T 32 R F 4 (ELE) T 32 R F 4 (ELE)		F44ILL F44ILL	112	0,2	SW	4,380 4,380	981 981		\$ - \$ -	\$ -			+
	Mayor's Office	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	sw	1460	327		T 32 R F 4 (ELE)			112	0.2	SW	1,460	327		\$ -	+-	**		+
	Deputy Treasurer Office	2	S 32 P F 2 (ELE)	F42LL	60	0.1	SW	2190	263		S 32 P F 2 (ELE)		F42LL	60	0.1	SW	2,190	263		\$ -	\$ -	\$0		
	ast Offices Hallway	5	S 32 P F 2 (ELE)	F42LL F44ILL	60	0.3	SW	4380	1,314		S 32 P F 2 (ELE)		F42LL	60 112	0.3	SW	4,380	1,314		\$ -			ļ	
	East Offices Hallway East Offices Hallway	3	T 32 R F 4 (ELE)	F44ILL ELED1.5/1	112 1.5	0.2	SW	4380 8760	981		T 32 R F 4 (ELE) X 1.5 W LED		F44ILL ELED1.5/1	11.5	0.2	SW Breaker	4,380 8,760	981 39		\$ - \$ -	\$ - \$ -	· · · · · · · · · · · · · · · · · · ·	ļ	<del></del>
	Server/Storage Room	1 1	T 32 R F 4 (ELE)	F44ILL	112	0.1	SW	2190	245		T 32 R F 4 (ELE)		F44ILL	112	0.1	SW	2,190	245		\$ -	\$ -		<del> </del>	1
	Conference Room	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	SW	2190	491		T 32 R F 4 (ELE)		F44!LL	112	0.2	SW	2,190	491		\$ -	\$ -	***		
	Supply Room 1 CFO's Office	2	T 32 R F 4 (ELE)	F44ILL F44ILL	112 112	0.2	SW	2190 2190	491 491		T 32 R F 4 (ELE)		F44ILL F44ILL	112	0.2	SW	2,190 2,190	491 491		\$ - \$ -	\$ - \$ -			<del></del>
	Municipal Clerk Office	2 2	T 32 R F 4 (ELE)	F44ILL F44ILL	112	0.2	SW	2190	491		T 32 R F 4 (ELE)			112	0.2	SW	2,190	491		\$ -	· ·	40	-	<del> </del>
	Supply Room 2	2	S 32 P F 2 (ELE)	F42LL	60	0.1	SW	2190	263	2	S 32 P F 2 (ELE)		F42LL	60	0.1	sw	2,190	263		\$ -	\$ -			
	Tax Office	4	T 32 R F 4 (ELE)	F44ILL	112	0.4	SW	2190	981		T 32 R F 4 (ELE)		F44ILL	112	0.4	SW	2,190	981		\$ -	\$ -	140		
	Γax Office Closet Clerk Office	1 2	T 32 R F 4 (ELE) T 32 R F 4 (ELE)	F44ILL F44ILL	112 112	0.1	SW	2190 2190	245 491		T 32 R F 4 (ELE)		F44ILL F44ILL	112 112	0.1 0.2	SW	2,190 2,190	245 491		\$ - \$ -	\$ - \$ -	17.		
	Men's Restroom	1	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	8000	576		C28 P F 2	No. of the control of	F42SSILL	48	0.0	SW	8,000	384		\$ 27.82		144	3.8	3.3
	Women's Restroom	1	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	8000	576		C 28 P F 2	X	F42SSILL	48	0.0	SW	8,000	384		\$ 27.82			3.8	3.3
	Main Hallway	8	S 32 P F 2 (ELE)	F42LL	60	0.5	SW	8760	4,205		S 32 P F 2 (ELE)		F42LL	60	0.5	SW	8,760	4,205		\$ -	\$ -			
	Main Hallway Bathrooms	+ - <sup>2</sup>	EP I 100 S 32 P F 2 (ELE)	1100/1 F42LL	100	0.2	SW	2080 4380	416 263		CF 26 S 32 P F 2 (ELE)		CFQ26/1-L F42LL	127 160	0.1	SW	2,080 4,380	112 263	304 0.1	\$ 60.84	\$ 40.50		0.7	0.7
	Courtroom	9	DC 40 W F 4	F44SE	172	1.5	SW	4380	6,780		DC 28 W F 4		F44SSILL	96	0.9	SW	4,380	3,784	2,996 0.7	\$ 482,29		<del>-</del>	2.6	2.1
	Courtroom	3	1 60	160/1	60	0.2	SW	4380	788		CF 26		CFQ26/1-L	27	0.1	SW	4,380	355		\$ 69.81			0.3	0.3
	West Offices Hallway Breakroom	4	T 32 R F 3 (ELE) T 32 R F 3 (ELE)	F43ILL/2 F43ILL/2	90	0.4	SW	8760 5000	3,154 1,800		T 32 R F 3 (ELE) T 32 R F 3 (ELE)	1	F43ILL/2 F43ILL/2	90	0.4	SW	8,760 5,000	3,154 1,800		\$ - \$ -	\$ - \$ -	T-	<u> </u>	<del></del>
	Bathroom off Breakroom	1	T 32 R F 4 (ELE)	F43ILL/2 F44ILL	112	0.4	SW	8760	981		T 32 R F 4 (ELE)		F431LL/2	112	0.4	SW	8,760	981		\$ -	\$ -	T -		
18	Court Office	6	T 32 R F 4 (ELE)	F44ILL	112	0.7	SW	2190	1,472		T 32 R F 4 (ELE)		F44ILL	112	0.7	SW	2,190	1,472		\$ -	\$ -			
	Court Office Storage	1	T 32 R F 4 (ELE)	F44ILL	112	0.1	SW	8760	981	11	T 32 R F 4 (ELE)	)		112	0.1	SW	8,760	981		\$ -		*-		
	Janitor Closet Conference Room	6	T 32 R F 4 (ELE) T 32 R F 3 (ELE)	F44ILL F43ILL/2	90	0.1	SW	4380 2190	491 1,183	6	T 32 R F 4 (ELE) T 32 R F 3 (ELE)		F44ILL F43ILL/2	90	0.1	SW	4,380 2,190	491 1,183		\$ ~ \$ ~	\$ -	12.	<del> </del>	
	Conference Room	10	EP I 100	1100/1	100	1.0	SW	624	624	10	CF 26			27	0.5	SW	624	1,183		\$ 170.90		140	1.2	1.2
18 (	Construction Office	3	T 32 R F 4 (ELE)	F44ILL	112	0.3	sw	2190	736	3	T 32 R F 4 (ELE)		F44ILL	112	0.3	SW	2,190	736	- 0.0	\$ -	\$ -	\$0		
	Fire Marshall Office	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	SW	2190	491		T 32 R F 4 (ELE)		F44ILL	112	0.2	SW	2,190	491		\$ -	\$ -	+:		
	Fax Assessor Office Fax Assessor Office	1 1	T 32 R F 4 (ELE) S 32 P F 2 (ELE)	F44ILL F42LL	112 60	0.1	SW	2190 2190	245 131		T 32 R F 4 (ELE) S 32 P F 2 (ELE)		F44ILL F42LL	112	0.1	SW	2,190 2,190	245 131		\$ - \$ -	\$ - \$ -	40	<del> </del>	+
142	Outdoor Lights	3	MH 100	MH100/1	128	0.4	Photo	4380	1,682		MH 100		MH100/1	128	0.1	Photo	4,380	1,682		\$ -	\$ -	**	<del>                                     </del>	<del> </del>
142 (	Outdoor Light	1	MH 100	MH100/1	128	0.1	None	8760	1,121		MH 100		MH100/1	128	0.1	None	8,760	1,121	- 0.0	\$ -	\$ -	<b>V</b>		
	l'otal	133				12.8			48,676	133				4,205	10.7			41,380		\$1,243	\$2,587	\$475		
																			nd Savings Savings	7,296	\$328 \$915	<del> </del>	ļ	<del> </del>

### APPENDIX C

**ECM-2 Install Lighting Controls** 

Cost of Electricity:

\$0.125 \$/kWh \$12.99 \$/kW

Company   Comp					EXISTING CON	IDITIONS					2.4	1000	RETROFIT	ONDITION	IS .				05.106/201363	COS	ST & SAVIN	GS ANALYS	SIS		2000000
Second	Area Desci	iption		Standard Fixture Code	NYSERDA Fixture Coo		kW/Space		•	Annual kWh		Standard Fixture Code	Fixture Code						\$450 MARKED BOOK (4500)		** *** **** **** **** **** **** **** ****		Lighting	Payback With Out	Simple
Fig.   Fig.   St.   Co.   St	ode Room number/Room	name: Floor b	efore the	2T 40 R F(U) = 2'x2' Troff 40 w		Table of Standard Fixture		control	annual hours for the usage			2T 40 R F(U) = 2'x2' Troff 40	Standard Fixture	Table of Standard Fixture	(Number of	control	annual hours for the usage	(Annual	Annual kWh) - (Retrofit Annua	Annual kW) - I (Retrofit Annual	(\$/kWh)	renovations to		for renovations cost to be	e Length of time renovations of to be recove
Part	11 Maintenance Closet		1															02:0							5.0
Figure   F																									16.6 7.6
Description   1		юm																						9.2	7.6
Propert Clin																				+				†	+
Company   1		om															8760			0.0	T				
International Name	18 Perimeter Office																			1717					9.6
Company   Comp																				. 0.0					15.2 11.5
March Carlow   2   17   18   18   19   19   18   18   18   18	18 Main Potice Hallway																			0.0				13,8	11.5
Company   Comp	71 Main Police Hallway																							<del> </del>	+
Separation   Property   Propert	18 Sergeant Office 1		2	T 32 R F 4 (ELE)	F44ILL	112			4380	981.1	2		F44ILL	112	0.2		1460							1.4	1.2
Carlo Office   2   15   17   16   17   17   17   17   17   17	18 Sergeant Office 2																								1.2
State   Prince   Pr	18 Sergeant Office 3																								1.2
Magnet Primes   2   12   17   14   12   12   12   12   14   15   15   15   15   15   15   15																				0.0					1.2
Depth   Transport   Color			- 2																						4.8
Fact Offices Nathway   S   S   S   P   P   R   R   R   R   R   R   R   R	3 Deputy Treasurer Office	8	2																						9.0
Eart Office Helmory   3   1.5 \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \	3 East Offices Hallway		5	S 32 P F 2 (ELE)			0.3	sw		1,314.0	5		F42LL	60	0.3										
Several Seve	8 East Offices Hallway		2																	0,0					
Conference Name   2   T 2 R F 4 (LLE)   F44LL   112   0.2   9W   2110   4000   2   T 2 R F 4 (LLE)   F44LL   112   0.2   9W   2110   4000   2   T 2 R F 4 (LLE)   F44LL   112   0.2   9W   2110   4000   2   T 2 R F 4 (LLE)   112   0.2   9W   2110   4000   2   T 2 R F 4 (LLE)   112   0.2   9W   2110   4000   2   T 2 R F 4 (LLE)   112   0.2   9W   2110   4000   2   T 2 R F 4 (LLE)   112   0.2   9W   2110   4000   2   T 2 R F 4 (LLE)   112   0.2   9W   2110   4000   2   T 2 R F 4 (LLE)   112   0.2   9W   2110   4000   2   T 2 R F 4 (LLE)   112   0.2   4000   2   T 2																		00.7		0.0					
Supply Report   2   T 32 R F 4 (ELE)																									4.8 5.4
GPÓ-Offide  2			2																						2.4
Manigrap   Control	8 CFO's Office		2																						6.5
Tax Office 4 T \$28 FF 4(ELE) F44LL 112 0.4 SW 2190 991.1 4 T \$28 FF 4(ELE) F44LL 112 0.4 0.000 \$30.0	8 Municipal Clerk Office		2				0.2	SW	2190	490.6	2		F44ILL												6.5
Tax Office Closet 1 T 32 R F 4 (ILL) F44IL 112 0.1 SW 2100 24.5.3 1 T 32 R F 4 (ILL) P44IL 112 0.1 SOC 388 40.9 29.4.4 0.0 \$26.5.3 \$116.75 \$20.00 4.6 SOC 500 \$10.00 \$1.	3 Supply Room 2		2																						4.5
Clark Offline   2   T32 F F 4 (ELE)   F44LL   112   0.2   SW   2190   400.0   2   T32 F F 4 (ELE)   F44LL   112   0.2   SGC   568   368.5   T2.1   0.0   315.31   \$118.72   520.00   7.8   T3.01   T	8 Tax Office																								5.5
Metric Netherlor   1   Stef P 2 (MAG)																				0,0					3.9 6.5
Women's Redection   1   S.M.P. F. (MAG)   F42EE   72   0.1   S.W.   8000   576.0   1   S.M.P. F. (MAG)   F42EE   72   0.1   C.SCC   1480   105.1   470.9   0.0   580.06   500.00   53																				0.0					2.8
Main Hallway   8   S. 32 P F 2 (EE)   F-42LL   60   0.5   S.W   3760   4,204.8   8   S. 32 P F 2 (EE)   F-42LL   60   0.5   None   8760   4,204.8   0.0	1 Women's Restroom		i																	0.0					2.8
Small Office to the left of Bathrooms   1   S 32 PF 2 (ELE)   F42LL   60   0.1   SW   4380   262.8   1   S 32 PF 2 (ELE)   F42LL   50   0.1   300.0   313.4   313.4   0.0   516.48   5113.75   520.00   7.2   60   60   60   60   60   60   60   6	3 Main Hallway		8				0.5	SW	8760				F42LL							0.0				1	+
Courtnorm   9   DC 40 WF 4   F445E   172   1,5   SW   4380   6,780.2   9   DC 40 WF 4   F445E   172   1,5   None   4380   6,780.2   0.0   0.0   50.00   50.00   50.00	B Main Hallway																								
Courtnome   3   160		of Bathrooms																		+				7.2	6.0
West Offices Halway																									-
Streamorn   4   T32 RF 3 (ELE)   F43ILI/2   90   0.4   SW   5000   1,800.0   4   T32 RF 3 (ELE)   F43ILI/2   90   0.4   GCSC   2190   784.4   1011.6   0.0   5126.85   5202.9   535.00   1.6   1.8				. 00																					+
Bathnom off Breakroom   1   T 32 R F 4 (ELE)   F44LL   112   0.1   SW   8760   981.1   1   T 32 R F 4 (ELE)   F44LL   112   0.1   0.0C   2160   246.3   735.8   0.0   892.27   8118.75   \$20.00   1.3   T 2.0 Court Office   6   T 32 R F 4 (ELE)   F44LL   112   0.7   SW   2190   1.471.7   6   T 32 R F 4 (ELE)   F44LL   112   0.1   0.0C   730   81.8   892.4   0.0   \$112.78   \$118.75   \$20.00   1.1   1.	5 Breakroom																							1.6	1.3
Court Office   6   T32 R F 4 (ELE)   F44ILL   112   0.7   SW   2190   1,471.7   6   T32 R F 4 (ELE)   F44ILL   112   0.1   SW   8760   981.1   1   T32 R F 4 (ELE)   F44ILL   112   0.1   OCC   730   81.8   899.4   0.0   \$112.78   \$118.75   \$20.00   1.1   Court Office Storage   1   T32 R F 4 (ELE)   F44ILL   112   0.1   SW   4380   449.6   1   T32 R F 4 (ELE)   F44ILL   112   0.1   OCC   730   81.8   899.4   0.0   \$112.78   \$118.75   \$20.00   2.3   1.8   Court Office Storage   1   T32 R F 4 (ELE)   F44ILL   112   0.1   OCC   730   81.8   899.4   0.0   \$112.78   \$118.75   \$20.00   2.3   1.8   Court Office Storage   1   T32 R F 4 (ELE)   F44ILL   112   0.1   OCC   730   81.8   408.8   0.0   \$112.78   \$118.75   \$20.00   2.3   1.8   408.8   0.0   \$112.78   \$118.75   \$20.00   2.3   1.8   408.8   0.0   \$112.78   \$118.75   \$20.00   2.3   1.8   408.8   0.0   \$112.78   \$118.75   \$20.00   2.3   1.8   408.8   0.0   \$112.78   \$118.75   \$20.00   2.3   1.8   408.8   0.0   \$112.78   \$118.75   \$20.00   2.3   1.8   408.8   0.0   \$112.78   \$118.75   \$20.00   2.3   1.8   408.8   0.0   \$112.78   \$118.75   \$20.00   2.3   1.8   408.8   0.0   \$112.78   \$118.75   \$20.00   2.3   1.8   408.8   0.0   \$112.78   \$118.75   \$20.00   \$112.78   \$118.75   \$20.00   \$112.78   \$118.75   \$20.00   \$112.78   \$118.75   \$20.00   \$112.78   \$118.75   \$20.00   \$112.78   \$118.75   \$20.00   \$112.78   \$118.75   \$20.00   \$112.78   \$118.75   \$20.00   \$12.7	Bathroom off Breakroo	m	1		F44ILL	112	0.1		8760	981.1	1		F44ILL	112	0.1										1.1
Janitor Closet   1   T32 R F 4 (ELE)   F44ILL   112   0.1   SW   4380   490.6   1   T32 R F 4 (ELE)   F44ILL   112   0.1   OCC   730   81.8   408.8   0.0   \$51.26   \$118.75   \$20.00   2.3   72   \$1.00   \$	B Court Office											T 32 R F 4 (ELE)													7.3
Conference Room 6 T32 R F 3 (ELE) F43ILL/2 90 0.5 SW 2190 1,182.6 6 T32 R F 3 (ELE) F43ILL/2 90 0.5 C-OCC 624 337.0 845.6 0.0 \$106.04 \$202.50 \$35.00 1.9 1001 100 1.0 SW 624 624.0 10 EP 100 11001 100 1.0 None 624 624.0 0.0 0.0 \$0.00 \$0	Court Office Storage																								0.9
Conference Room   10   EP   100     100/1   100   1.0   SW   624   624.0   10   EP   100     100/1   100   1.0   None   624   624.0   0.0   0.0   \$0.00   \$0																									1.9
Construction Office 3 T32 RF 4 (ELE) F44ILL 112 0.3 SW 2190 735.8 3 T32 RF 4 (ELE) F44ILL 112 0.3 QGC 1645 552.7 183.1 0.0 \$22.96 \$116.75 \$20.00 5.2 4.6 Fine Marshall Office 2 T32 RF 4 (ELE) F44ILL 112 0.2 SW 2190 480.6 2 T32 RF 4 (ELE) F44ILL 112 0.2 QGC 1645 380.5 122.1 0.0 \$15.31 \$116.75 \$20.00 7.8 € 1.0 Tax Assessor Office 1 T32 RF 4 (ELE) F44ILL 112 0.1 SW 2190 245.3 1 T32 RF 4 (ELE) F44ILL 112 0.1 QGC 1645 380.5 122.1 0.0 \$15.31 \$116.75 \$20.00 7.8 € 1.0 Tax Assessor Office 1 S32 FF 2 (ELE) F44ILL 112 0.1 SW 2190 131.4 1 S32 FF 2 (ELE) F44ILL 112 0.1 QGC 1645 38.7 32.7 0.0 \$16.51 \$116.75 \$20.00 15.5 11.0 GCC 1645 38.7 32.7 0.0 \$16.51 \$116.75 \$20.00 15.5 11.0 GCC 1645 38.7 \$16.75 \$1	8 Conference Room																							1.9	1,6
Fire Marshall Office 2 T 32 R F 4 (ELE) F44ILL 112 0.2 SW 2190 490.6 2 T 32 R F 4 (ELE) F44ILL 112 0.2 OCC 1645 368.5 122.1 0.0 \$15.31 \$118.75 \$20.00 7.8 € Tax Assessor Office 1 T 32 R F 4 (ELE) F44ILL 112 0.1 SW 2190 245.3 1 T 32 R F 4 (ELE) F44ILL 112 0.1 OCC 1645 184.2 61.0 0.0 \$7.85 \$118.75 \$20.00 15.5 1  Tax Assessor Office 1 T 32 R F 2 (ELE) F42ILL 60 0.1 OCC 1645 184.2 61.0 0.0 \$7.85 \$118.75 \$20.00 15.5 1  Tax Assessor Office 1 T 32 R F 2 (ELE) F42ILL 60 0.1 OCC 1645 184.2 61.0 0.0 \$7.85 \$118.75 \$20.00 15.5 1  Outdoor Lights 3 MH 100 MH100/1 128 0.4 Photo 4380 1,681.9 3 MH 100 MH100/1 128 0.4 None 4380 1,681.9 0.0 0.0 \$0.00 \$0.	8 Construction Office		,,,																	1111				5.2	4.3
Tax Assessor Office 1 S 32 PF 2 (ELE) F42LL 60 0.1 SW 2190 131.4 1 S 32 PF 2 (ELE) F42LL 60 0.1 QCC 1645 98.7 32.7 0.0 \$4.10 \$118.75 \$20.00 29.0 2.0 QUID OUT OF TAX ASSESSOR	8 Fire Marshall Office		2	T 32 R F 4 (ELE)	F44ILL	112						T 32 R F 4 (ELE)	F44ILL	112	0.2	000	1645	368.5		0.0	\$15.31	\$118.75	\$20.00		6,5
Outdoor Lights         3         MH 100         MH100/1         128         0.4         Photo         4380         1,681.9         3         MH 100/1         128         0.0         50.00         \$0.00 <th< td=""><td>18 Tax Assessor Office</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>0.0</td><td></td><td></td><td></td><td></td><td>12.9</td></th<>	18 Tax Assessor Office																			0.0					12.9
Outdoor Light         1         MH 100         MH 100/1         128         0.1         None         8760         1,121.3         1         MH 100/1         128         0.1         Photo         4380°         560.6         560.6         560.6         50.0         \$70.30         \$0.00         \$0.00         0.0         C           Total         133         133         133         134         133         134	13 Tax Assossor Office																			1-1-				29.0	24.1
Total 133 12,8 48,676 133 13 36,363 12,293 0 1,542 \$5,029 855 Demand Savings 0.0 \$0	142 Outdoor Lights																							<del> </del>	+
Demand Savings 0.0 \$0				IVIT 100		128		None	8/60	.,		NIU 100	MH100/1	128		Photo	4380			0.0	, , , , , , ,	*****		0.0	0,0
	Liotai		133			1	12.0			1 40,010	133		<u> </u>	1	1 13		1			Iv.		\$0,UZ9	000	+	+
																				+		\$4 E42	<del></del>	+	+

### APPENDIX D

**ECM-3** Lighting Replacements with Controls

Cost of Electricity:

\$0.125 \$/kWh \$12.99 \$/kW

				EXISTING COND	DITIONS							RETROFIL	ONDITION	IS .					C	OST & SAVIN	IGS ANALYS	IS		
	Area Description	No. of Fixtures	Standard Fixture Code	NYSERDA Fixture Code	Watts per Fixture	kW/Space	Exist Control	Annual Hours	Annual kWh	Number of Fixtures	Standard Fixture Code	Fixture Code	Watts pe	r kW/Space	Retrofit Control		Annual kWh	Annual kWh Saved	Annual kW Saved	Annual \$ Saved	Retrofit Cost	NJ Lighting Incentive	Simple Payback With Out Incentive	Simple Payback
Field Code	Unique description of the location - Room number/Room name: Floor number (if applicable)		"Lighting Fixture Code" Example 2T 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Fixt No.)	Pre-inst. control device	Estimated daily hours for the usage group		No. of fixtures after the retrofit	"Lighting Fixture Code" Examp 2T 40 R F(U) = 2'x2' Trof w Recess. Floor 2 lamps U shap	40 Standard Fixture	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Number of Fixtures)	Retrofit control device	annual hours	(kW/space) * (Annual Hours)	(Original Annual kWh) - (Retrofit Annual kWh)	(Original Annual kW) - (Retrofit Annua kW)	(\$/kWh)	Cost for- renovations to lighting system	Prescriptive Lighting Measures	Length of time for renovations cost to be recovered	Length of time for renovations cost to be recovered
	Maintenance Closet	1	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	2920	210	1	C 28 P F 2	F42SSILL	48	0.0	OCC	730	35	175	0.0	\$ 25.71	\$ 225.00	\$ 35	8.8	7.4
	Police Bathroom	1	1 Lamp T12	F21SE	26	0.0	SW	2920	76	1	1 Lamp T12	F21SE	26	0.0	occ	1,095	28		0.0	\$ 5.95				16.6
	Police Locker Room Prisoner Processing Room	1 5	S 32 P F 2 (ELE) 1B 40 R F 2 (MAG)	F42LL F42SS	94		SW	4380 8760	263 4.117		S 32 P F 2 (ELE) 1B 28 R F 2	F42LL F42SSILL	60 48	0.1	C-OCC None	1,460 8,760	88	175	0.0	\$ 21.97				7.6
	Prisoner Processing Room	1 1	140	14203	40		SW	8760	350	1	CF 13	CFQ13/1-L	15	0.2	None	8,760	2,102 131		0.2	\$ 288.50 \$ 31.36			2.0 0.2	1.5 0.2
	Prisoner Processing Room	1	X 7.0 W 12	El10/2	20		Breaker	8760	175	1	X 1.5C LED	ELED1.5/1	1.5	0.0	None	8,760	13		0.0	\$ 23.21				5.1
	Perimeter Office	1	T 32 R F 4 (ELE)	F44ILL	112		SW	2190	245	1	T 32 R F 4 (ELE)	F44ILL	112	0.1	000	1,460	164		0.0	\$ 10.25				9.6
	Gun Cabinet Interrogation Room	1 1	W 32 W F 2 (MAG) S 32 P F 2 (ELE)	F42LE F42LL	71	0.1	SW	2190	155		W 32 W F 2 (MAG)	F42LE	71	0.1	000	1,460	104		0.0	\$ 6.50				15.2
	Main Police Hallway	6	T 32 R F 4 (ELE)	F42LL F44ILL	112		SW	2600 2600	156 1,747	1 6	S 32 P F 2 (ELE) T 32 R F 4 (ELE)	F42LL F44ILL	112	0.1	OCC None	1,460 2,600	1,747		0.0	\$ 8.58 \$ -	\$ 118.75 \$ 118.75			11.5
	Main Police Hallway	3	1 60	160/1	60		SW	2600	468	3	CF 26	CFQ26/1-L	27	0.7	None	2,600	211		0.0	\$ 47.71			0.4	0,4
	Sergeant Office 1	2	T 32 R F 4 (ELE)	F44ILL	112		SW	4380	981	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	OCC	1,460			0.0	\$ 82.02				1.2
	Sergeant Office 2	2	T 32 R F 4 (ELE)	F44ILL	112		SW	4380	981	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	000	1,460	327		0.0	\$ 82.02		\$ 20	1.4	1.2
18	Sergeant Office 3 Chief's Office	2	T 32 R F 4 (ELE)	F44ILL F44ILL	112		SW	4380 4380	981 981	2	T 32 R F 4 (ELE)	F44ILL F44ILL	112	0.2	occ	1,460	327		0.0	\$ 82.02			1.4	1.2
	Storage/ Server Room	2	T 32 R F 4 (ELE)	F44ILL	112		SW	4380	981	2	T 32 R F 4 (ELE)	F44ILL F44ILL	112 112	0.2	000	1.460 730	327 164		0.0	\$ 82.02 \$ 102.53			1.4 1.2	1.2
	Mayor's Office	2	T 32 R F 4 (ELE)	F44ILL	112		SW	1460	327	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	000	730	164		0.0	\$ 102.53				1.0
	Deputy Treasurer Office	2	S 32 P F 2 (ELE)	F42LL	60	0.1	SW	2190	263	2	S 32 P F 2 (ELE)	F42LL	60	0.1	occ	1,460	175		0.0	\$ 10.98				9.0
	East Offices Hallway	5	S 32 P F 2 (ELE)	F42LL	60		SW	4380	1,314	5	S 32 P F 2 (ELE)	F42LL	60	0.3	None	4,380	1,314	-	0.0	\$ -				1
	East Offices Hallway	2	T 32 R F 4 (ELE)	F44ILL	112		SW	4380	981	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	None	4,380	981		0.0	\$ -	\$ 118.75	\$ 20		
	East Offices Hallway Server/Storage Room	3 .	X 1.5 W LED T 32 R F 4 (ELE)	ELED1.5/1 F44ILL	1.5		Breaker SW	8760 2190	39 245	3	X 1.5 W LED T 32 R F 4 (ELE)	ELED1.5/1 F44ILL	1.5	0.0	None	8,760	39		0.0	\$ -	\$ -			
	Conference Room	2	T 32 R F 4 (ELE)	F44ILL	112		SW	2190	491	2	T 32 R F 4 (ELE)	F44ILL	112 112	0.1	000	730 1 095	82 245		0.0	\$ 20.51 \$ 30.76				4.8 5.4
18	Supply Room 1	2	T 32 R F 4 (ELE)	F44ILL	112		sw	2190	491	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	OCC	730	164		0.0	\$ 41.01				2.4
	CFO's Office	2	T 32 R F 4 (ELE)	F44ILL	112		sw	2190	491	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	occ	1,645	368	122	0.0	\$ 15.31			7.8	6.5
	Municipal Clerk Office	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	SW	2190	491	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	occ	1,645	368		0.0	\$ 15.31			7.8	6.5
13	Supply Room 2 Tax Office	4	S 32 P F 2 (ELE) T 32 R F 4 (ELE)	F42LL F44ILL	112	0.1	SW	2190 2190	263 981	2 4	S 32 P F 2 (ELE) T 32 R F 4 (ELE)	F42LL F44ILL	60	0.1	000	730	88		0.0	\$ 21.97			5.4	4.5
	Tax Office Closet	1 1	T 32 R F 4 (ELE)	F44ILL	112		SW	2190	245	1	T 32 R F 4 (ELE)	F44ILL	112 112	0.4	000	1,645	737 41		0.0	\$ 30.62 \$ 25.63				5.5 3.9
	Clerk Office	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	SW	2190	491	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	OCC	1,645	368		0.0	\$ 15.31				6.5
	Men's Restroom	1	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	8000	576	1	C28 P F 2	F42SSILL	48	0.0	C-00C		70	506	0.0	\$ 67.18				1.5
	Women's Restroom	1	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	8000	576	1	C 28 P F 2	F42SSILL	48	0.0	0.000	1,480	70	506		\$ 67.18	\$ 118.75	\$ 20	1.8	1.5
	Main Hallway Main Hallway	8	S 32 P F 2 (ELE) EP I 100	F42LL  100/1	100	0.5	SW SW	8760 2080	4,205 416	8	S 32 P F 2 (ELE) CF 26	F42LL CFQ26/1-L	60	0.5	None	8,760	4,205		0.0	\$ -	\$ -			
	Small Office to the left of Bathrooms	1	S 32 P F 2 (ELE)	F42LL	60	0.2	SW	4380	263		S 32 P F 2 (ELE)	F42LL	27 60	0.1	None OCC	2,080 2,190	112 131	304 131		\$ 60.84 \$ 16.48			0.7 7.2	0.7 6.0
	Courtroom	9	DC 40 W F 4	F44SE	172		sw	4380	6,780	9	DC 28 W F 4	F44SSILL	96	0.9	None	4,380				\$ 482.29				2.1
	Courtroom	3	1 60	160/1	. 60	0.2	sw	4380	788		CF 26	CFQ26/1-L	27	0.1	None	4,380	355	434		\$ 69.81			0.3	0.3
	West Offices Hallway	4	T 32 R F 3 (ELE)	F43ILL/2	90	0.4	SW	8760	3,154		T 32 R F 3 (ELE)	F43!LL/2	90	0.4	None	8,760	3,154		0.0	\$ -	\$ -			
	Breakroom Bathroom off Breakroom	4	T 32 R F 3 (ELE) T 32 R F 4 (ELE)	F43ILL/2 F44ILL	112	0.4	SW	5000 8760	1,800 981	1	T 32 R F 3 (ELE) T 32 R F 4 (ELE)	F43ILL/2 F44ILL	90	0.4	220-2	2.190	788 245	1,012 736		\$ 126.85 \$ 92.27			1.6	1.3
	Court Office	6	T 32 R F 4 (ELE)	F44ILL	112		SW	2190	1.472		T 32 R F 4 (ELE)	F44ILL F44ILL	112	0.7	0.000	2,190 1,645	1,105			\$ 92.27 \$ 45.93			1.3 8.8	7.3
18	Court Office Storage	1	T 32 R F 4 (ELE)	F44ILL	112	0.1	SW	8760	981	1	T 32 R F 4 (ELE)	F44ILL	112	0.1	OCC	730	82		0.0	\$ 112.78				0.9
18	Janitor Closet	1	T 32 R F 4 (ELE)	F44ILL	112		SW	4380	491	1	T 32 R F 4 (ELE)	F44ILL	112	0,1	occ	730	82	409	0.0	\$ 51.26				6.5
	Conference Room	- 6 10	T 32 R F 3 (ELE)	F43ILL/2	90	0.5	SW	2190	1,183		T 32 R F 3 (ELE)	F43ILL/2	90	0.5	C-OCC	624	337		0.0	\$ 106.04				1.6
	Conference Room Construction Office	10	EP i 100 T 32 R F 4 (ELE)	I100/1 F44ILL	100		SW	624 2190	624		CF 26	CFQ26/1-L	27	0.3	None		168	456	J0.7	\$ 170.90			1.2	1.2
	Fire Marshall Office	2	T 32 R F 4 (ELE)	F44ILL	112		SW	2190	736 491	2	T 32 R F 4 (ELE) T 32 R F 4 (ELE)	F44ILL F44ILL	112 112	0.3	000 000	1,645 1,645	553 368		0.0	\$ 22.96 \$ 15.31		\$ 20	5.2 7.8	4.3 6.5
	Tax Assessor Office	1 1	T 32 R F 4 (ELE)	F44ILL	112		SW	2190	245	1	T 32 R F 4 (ELE)	F44ILL	112	0.2	OCC	1,645	184		0.0	\$ 7.65		\$ 20	15.5	12.9
	Tax Assossor Office	1	S 32 P F 2 (ELE)	F42LL	60	0.1	sw	2190	131	1	S 32 P F 2 (ELE)	F42LL	60	0.1	occ	1,645	99		0.0	\$ 4.10				24.1
	Outdoor Lights	3	MH 100	MH100/1	128		Photo	4380	1,682	3	MH 100	MH100/1	128	0.4	None	4,380	1,682	-	0.0	\$ -	\$ -			
142	Outdoor Light	1 422	MH 100	MH100/1	128	1	None	8760	1,121		MH 100	MH100/1	128	0.1	Photo	4,380	561	561	0.0	\$ 70.30		<u> </u>	0.0	0.0
	Total	133	<u> </u>	1		12.8			48,676	133			<u> </u>	10.7	1	1	29,453	l <u>.                                    </u>	2.1	2,738	7,759	1,360		<u> </u>
																<u> </u>		nd Savings	-	2.1	\$328			<del> </del>
											- *							Savings Savings		19,223	\$2,411		2.0	1 22
																L	ı otal	Odamila	1	l	\$2,738		2.8	2.3

### APPENDIX E

ECM-4 Replace Electric DHW with On Demand Gas

# ECM 4: Replace Electric DHW Heater with On Demand Gas

Summary
\* Replace Electric DHW Heater w/ Instantaneous, Condensing, Gas-Fired DHW Heater

<u>item</u>	<u>value</u>	Ornis	
Occupied days per week		days/wk	
Water supply Temperature	09	ļ.	Termperature of water coming into building
Hot Water Temperature	120	<u>u</u> .	
Hot Water Usage per day	10	gal/day	Calculated from usage below
Annual Hot Water Energy Demand	944.9	MBTU/yr	Energy required to heat annual quantity of hot water to setpoint
Existing Tank Size	40	Gallons	Per manufacturer nameplate
Hot Water Temperature	120	ı.	Per building personnel
Average Room Temperature	09	ļ.	
Standby Losses (% by Volume)	7.67		(2.5% of stored capacity per hour, per U.S. Department of Energy)
Standby Losses (Heat Loss)	9.0	MBH	
Annual Standby Hot Water Load	9887	MBTU/yr	
Total Annual Hot Water Demand (w/ standby losses)	12.35	Mbtu/yr	Building demand plus standby losses
Existing Water Heater Efficiency	92%		Per Manufacturer
Total Annual Energy Required	14.277	Wbtu/yr	
Total Annual Electric Required	\$81.7	kWh/yr	Electrical Savings
Average Annual Electric Demand	0.48	kW	***************************************
Peak Electric Demand	4.50	kW	Per Manufacturer's Nameplate (Demand Savings)
New Tank Size	. 0	Gallons	tankless
Hot Water Temperature	120	Ļ	THE PERSON NAMED IN COLUMN TO THE PE
Average Room Temperature	80	į.	
Standby Losses (% by Volume)	82.2		(2.5% of stored capacity per hour, per U.S. Department of Energy)
Standby Losses (Heat Loss)	0.0	MBH	
Annual Standby Hot Water Load	0	MBTU/yr	
Prop Annual Hot Water Demand (w/ standby losses)	997.9	MBTU/yr	
Proposed Avg. Hot water heater efficiency	92%		Based on Bosch GWH C 920 ESC
Proposed Total Annual Energy Required	9.517	MBTU/yr	
Proposed Fuel Use	35	Therms/yr	Standby Losses and inefficient DHW heater eliminated
Elec Utility Demand Unit Cost	212.99	\$/kW	
Elec Utility Supply Unit Cost	90.13	\$/kWh	
NG Utility Unit Cost	\$1.36	\$/Therm	
Existing Operating Cost of DHW	91.276	\$/yr	
Proposed Operating Cost of DHW	\$130	\$/yr	
Apprilate Hillita Coot Cardinan	950 13	S/vr	

℧
_
m
ë
=
•
Ω
_
ā
<b>∓</b>
ď
~
-
•
0
Ť
_
>
='
ē
~
_

	ral HW L/DAY	38	4		
	T TOT R GA				
	% HO. WATE	20%	<b>%</b> 52		
	TOTAL % HOT TOTAL HW GAL/DAY WATER GAL/DAY	22	5	Ca	8
CCUPANTS**	FEMALE	02	0	TOTAL	2
FULL TIME OCCUPANTS**	MALE	20	. 1		
USES PER DAY	FEMALE	က	- 1		
#USES P	MALE	3	1		
	DURATION OF USE (MIN)	0.25	2		
	*BASE WATER USE GPM	2.5	2.5		
	FIXTURE	(Low-Flow Lavs use 0.5 G			
		LAVATORY	MOP SINK		

Multipliers	
Material:	0.99
Labor:	1.23
Equipment:	1.00

Somerdale, NJ Energy Audit												
CHA #22424				Σ	<b>1ultipliers</b>							
<b>Building: Somerdale Municipal Building</b>	ing			<u> </u>		Material:	0.99	ī			,	
						Labor:	1.23	1				,
ECM 4: Replace Electric DHW Heater with On Demand Gas	r with On D	emand G	as		Ш	Equipment:	1.00	<u> </u>				
								1				
Description	\	TIMI		N N	JNIT COSTS		าร	SUBTOTAL COSTS	COSTS	TOTAL	SZGVMJG -	3/10
	<u>-</u> 3	5	MAT.	Ľ	LABOR	EQUIP.	MAT.	LABOR	RAUIP.	COST		2
Condensing Gas Hot Water Heater	1	EA	\$ 2,062	\$	300		\$ 2,041	↔	\$ 698	- \$ 2,4	110 Bosch (	2,410 Bosch GWH C 920 ESC
Hot Water Heater Removal	1	EA		\$	150		€9	- \$	185 \$	8	185	
Venting	10	ΗT	\$ 5.50	\$ 0	6.70		\$ 54	\$	82 \$	÷	137	
Miscellaneous Piping and Valves	1	ST	\$ 500	\$ 0	200		\$ 495	\$	246 \$	. \$ -	741 Natural Gas Line	Gas Line

Total	4,202	8
Engineering	•	ક્ક
10% Contractor O&P	382.00	↔
10% Contingency	347.27	ક
3,473 Subtotal	3,473	ક

### APPENDIX F

**ECM-5** Temperature Setback

### ECM 5 Temperature Setback - Mayor

Building Footprint Heating Efficiency Cooling Efficiency Building Balance Ten Internal Gains Unoc Internal Gain fa Ave Occ Internal Gain fa

	_				
	kW/lon	¥.90	btu/h	<del>)</del>	
8			8	٥	

### Ex Occupied Cing Temp. Ex Unoccupied Cing Temp. Prop Occupied Cing Temp. Prop Unoccupied Cing Temp.

## Ex Occupled Htg Temp. Ex Unoccupied Htg Temp. Prop Occupied Htg Temp. Prop Inoccupied Htg Temp.

### 

Heating Energy Savings Cooling Energy Savings



е тетр.	- CO	Prop Unoccupied Cing Temp.	40 A	Prop Unoccupied Htg Temp.	
	21.88C btu/h	Occupied Cooling UA	Poct btu/hr/F	Occupied Heating UA	
ain factor	), O	Unoccupied Cooling UA		Unoccupied Heating UA	
I Gain Factor	92	Cooling Occ Enthalpy Setpoint	Stuffb Stuffb		
		Cooling Unocc Enthalpy Setpoint	nt Stuffb		

Heating and cooling energy are unrelated in this model. If the building being analyzed is not cooled, clistogard cooling energy calculations

		pesodo.	leating	Energy	herms	z	0	0	0	0	0	0	٥	0	0	0	0	88	62	135	124	69	62	88	15	80	Đ.	0	0	550
		_	_				0	0	0	0	0	0	0	0	0	0	63	98	117	221	186	26	83	46	19	5	9	0	0	935
		Existir	Heatin	Energy	therm	æ																								
		roposed	Sooling	Energy	KWh	٦	0	14	134	406	1,160	587	481	433	378	106	10	0	0	0	0	0	0	•	0	0	0	0	7	3,708
		Existing P			KWh	¥	0	15	145	450	1,328	1,183	774	200	125	23	0	0	0	0	0	0	0	0	0	0	0	0	0	4,240
		ន័	Š				-		-	•													_							
				Internal Gain	BTUH	а	-2,198	-2.198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	
	Unoccupled			Ventilation	Load BTUH	0	-34,515	-24,653	-20,171	-15,838	-11,953	0	0	0	0	968	2,689	4,482	6,275	8,068	9,861	11,654	13,447	15,240	17,033	18,826	20,619	22,412	24,205	
8	5		_		oad BTUH Lo		10,646	-8,280	-5,914	-3,549	-1,183	0	0	0	0	604	1,813	3,022	4,230	5,439	6,648	7,856	9,065	10,274	11,482	12,691	13,900	15,108	16,317	
PROPOSED LOADS			_		Load	z	ľ																							
PROPO				Internal Gain	втин	¥	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	
	Occupled				oad BTUH		-34,515	-24,653	-20,171	-15,838	-11,953	-8,367	-4,781	988	2,689	4,482	6,275	8,068	9,861	11,654	13,447	15,240	17,033	18,826	20,619	22,412	24,205	25,998	27,791	
	ő				_		906	307	707	308	609	601	-310	304	313	122	330	621	348	356	965	274	182	391	900	80	317	526	734	
			Envelop	Load	BTUH	×	-18,	-15.8	-12,707	6	9	ķ		_	=	9,0	.4	'n	9,0	7,856	9,6	10,	17.	12,6	13,6	, <del>,</del>	16,3	17,8	18,7	
				Internal Gain	втин	٦	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	
	Unoccupied						4,515	4,653	-20,171	5,838	1,953	8,367	4,781	2,331	4,124	5,917	7,710	9,503	1,296	3,089	4,882	3,675	8,468	0,260	2,053	23,846	5,639	7,432	9,225	
	Unoco		_		H Load BTUH	_	ľ	•	·	ĺ	Ī																			
NG LOADS			Unoccupia	Envelope	Load BTUH	x	-14,4	-12,0	-9,699	-7,3	9,4	-2,6	ņ	15,	2,7	9,9	5,1	6,4	7,6	8,8	10,01	11,2	12,4	13,6	14,8	16,0	17,2	18,4	19,7	
EXISTING				ral Gain	втин	o	10,990	10,990	10,990	0,990	0,990	066'0	066'0	066'0	0,990	066,0	0,990	066'0	066'0	068'0	0,990	068'0	0,990	0,990	0,890	066'0	066'0	10,990	10,990	
	ped			Ē			ľ	•		·	•	•			4,124 -1		•			13,089 -1							•		•	
	Occupied			Ventifation	Load BTUH	ı.	-34,	-24	-20,171	-15,	-													•••		23,846			29,	
			Envelope	Load	BTUH	ш	-18,906	-15,807	12,707	809'e-	-6,509	-3,409	-310	1,571	2,780	3,989	5,197	6,406	7,615	8,823	10,032	11,241	12,449	13,658	14,867	16,075	17,284	18,493	19,701	
<u> </u>		-		ent Bin	lrs.	_		_					0	0	9	9	8	4	9	ņ				_			_	_	-	94
			Unoccupied	튭	Hours	٥		~	25	ð	38	€	84	62	67	5	4	4	47	7	53	24		ò	ñ	=	<b>D</b>	•	0	6,361
			Occupled	uipment Bi	Hours	o	٥	-	6	38	137	170	182	234	254	164	167	167	180	280	201	91	69	8	13	60	4	0	0	2,399
			ting	ent Bin Eq	Irs	_		_	•	=	0	0	4	4	7	0	0	-	9	23	4	4	Ŋ	δī	_	~	3	_		99
			Existing	量	Ĭ	<u></u>		10	8	5	36	9	99	-88	35	9		61	- 65	1,0,	22	88	25	12	4	2	<del>-</del>	_	0	8,760
				Avg Outdoo	Air Enthalpy		49.1	42.5	39.5	36.6	34	31.6	29.2	27	24.5	21.4	18.7	16.2	14.4	12.6	10.7	8.6	6,8	5.5	4.1	2.6	-	0	-1.5	
			_	ċ	Bins °F /	∢	102.5	97.5	92.5	87.5	82.5	77.5	72.5	67.5	62.5	67.5	52.5	47.5	42.5	37.5	32.5	27.5	22.5	17.5	12.5	7.5	2.5	-2.5	-7.5	TOTALS
			Ave	¥	ő		Ĺ	_	_	_	_	_	_	_	_	_	_	_	_				_					_		۲

332 dfm 1.00 0 dfm 332 dfm

Existing Building Ventilation & Inflitation (oce) Overheat Ventilation Textor Additional ventilation to offset overheat Existing Building Ventilation & Inflitation (unoce)

Somerdale, NJ Energy Audit CHA #22424

Building: Somerdale Municipal Building

ECM 5 Temperature Setback - Court Office

Buliding Footprint Heating Efficiency Cooling Efficiency Building Balance Te Internal Gains Unoc Internal Gain 1

Ex Occupied Cing Temp.

Ex Occupied Htg Temp.

Heating Energy Savings

					+-	 _		_	_			_	_	_	-	_		_	_	_	_	_	_	_	_	_	_	ᆉ	╛
			Proposed Cooling	Energy	7	ں	14	133	412	1,211	725	578	703	674	305	130	7	4	J	J	J	J	J	ى	J	ى	ا د	3	4,966
			Existing Cooling	Energy	¥	0	5	146	462	1,401	1,310	945	361	303	139	83	24	0	0	0	0	0	0	0	0	0	0	0	5,190
				nternal Gain BTUH		-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	
£		Unoccupled		Ventilation Internal Gain	٥	-30,629	-21,878	-17,900	-14,055	-10,607	0	0	0	0	286	2,387	3,978	5,569	7,160	8,751	10,342	11,933	13,524	15,116	16,707	18,298	19,889	21,480	
2.2. KWh	LOADS		١ _	Envelope Ventilation	z	-10,143	-7,889	-5,635	-3,381	-1,127	0		0	0	623	1,869	3,114	4,360	5,608	6,852	8,097	9,343	10,589	11,835	13,080	14,326	15,572	16,817	
avings	PROPOSED LOADS	-		Internal Gain RTUH	T	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	
Cooling Energy Savings		Occupied		Ventilation I	۲	-30,629	-21,878	-17,900	-14,055	-10,607	-7,425	0	96/	2,387	3,978	5,569	7,160	8,751	10,342	11,933	13,524	15,116	16,707	18,298	19,889	21,480	23,071	24,662	
<i>ስ</i> ክንን ቸ				Load		-15,463	-12,652	-9,840	-7,029	-4,217	-1,406	0	623	1,869	3,114	4,360	5,606	6,852	8,097	9,343	10,589	11,835	13,080	14,326	15,572	16,817	18,063	19,309	
70 70 70 70 70 70 70 70 70 70 70 70 70 7				Internal Gain RTUH	-	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	
g Temp. a Temp. Hg Temp. UA ng UA		Unoccupled			-	-30,629	-21,878	-17,900	-14,055	-10,607	-7,425	-4,243	2,068	3,660	5,251	6,842	8,433	10,024	11,615	13,206	14,797	16,388	17,980	19,571	21,162	22,753	24,344	25,935	
emp. 75 F EX Unoccupied Hig Temp. emp. 76 F Prop Courpied Hig Temp. 17 F Prop Unoccupied Hig Temp. 18 G F Prop Concupied Hig Temp. 18 Suhm/F Occupied Healing UA 18 Suhm/F Unoccupied Healing UA 28 Suhm/F Unoccupied Healing UA 28 Suhm/F Unoccupied Healing UA 29 Sexpoint 25 Suhm/F Suhm/F Unoccupied Healing UA 20 Suhm/F Unoccupied High Temp.	LOADS		Unoccupied	Envelope Ventilation	Ŧ	-13,749	-11,495	-9,241	-6,987	-4,733	-2,479	-225	1,619	2,865	4,111	5,357	6,602	7,848	9,094	10,340	11,585	12,831	14,077	15,323	16,568	17,814	19,060	20,306	
75 +F 76 +F 80 +F 80 +F 8u/n/F Buylb 19u/lb	EXISTING LOADS			Internal Gain RTUH	9	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	
7. 7. 7. 7. 7. 7. 7. 7. 7. 7. 7. 7. 7. 7		Occupled		Ventiletion	F	-30,629	-21,878	-17,900		•			2,068		5,251					13,206			17,980	18,571	21,162	22,753	24,344	25,935	
			Envelope	Load	Е	-17,150	-14,339	-11,527	-8,716	-5,904	-3,093	-281	1,619	2,865	4,111	5,357	6,602	7,848	9,094	10,340	11,585	12,831	14,077	15,323	16,568	17,814	19,060	20,306	
Ex Unoccupied Cing Temp. Prop Occupied Cing Temp. Prop Unoccupied Cing Temp. Occupied Cooling Us. Unoccupied Cooling Us. Cooling Unocc Enthalpy Selpoir Cooling Unocc Enthalpy Selpoir Cooling Unocc Enthalpy Selpoir			Unoccupied	Equipment Bin Hours	٥	0	2	52	92	363	450	482	620	673	436	443	444	476	743	533	243	183	8	8	16	6	0	0	6,361
78 kW/ton 65 + F 65 + F 60 - 2 0.9 0.9 d in this model. If the			Occupied	Equipment Bin Hours	o	0	-	o	8	137	170	182	234	254	164	167	167	180	280	201	26	69	¥	5	9	4	0	0	2,399
relating Efficiency  2.2. (Widon Prop Goupled Cing 1  Building Balance Fem. 65 F  Prop Concepted Cing 1  Prop Uncoupled Cing 1  Prop Lincoupled Cing 1  Processing A Cooling Once Enthalpy  Cooling Once Enthalpy  Real Cing 1  Processing A Cooling Cincoupled Cooling Cincoupled Cooling Cincoupled Cooling Cincoupled Cing 1  Processing A Cooling Cincoupled Cincoupled Cing 1  Processing A Cooling Cincoupled Cing 1  Processing A Cooling Cincoupled Cincoupled Cing 1  Processing A Cooling Cincoupled Cincoupled Cing 1  Processing A Cooling Cincoupled Cing 1  Processing A Cooling Cincoupled Cincoupled Cing 1  Processing A Cooling Cincoupled Cing 1  Processing A Cooling Cincoupled Cing 1  Processing A Cooling Cinc			Existing	Avg Outdoor   Equipment Bin Equipment Bin Equipment Bin Air Enthalor Hours	8	0	က	Ŗ	131	200	620	664	854	927	900	610	611	656	1,023	734	334	252	125	47	22	13	0	٥	8,760
cy cy e Temp. ain factor I Gain Factor olling energy ar				Avg Outdoor		49.1	42.5	39.5	36.6	8	31.6	28.2	27	24.5	21.4	18.7	16.2	14.4	12.6	10.7	9.6	6.8	5.5	4.1	5.6	<b>,</b> -	o :	-1.5	
Healting Efficiency Cooling Efficiency Building Balance 1 emp. Internal Gallans Unco Internal Gain Factor Ave Occ Internal Gain Factor Heatting and cooling energy			Avg Outdoor	Air Temp.	4	102.5	97.5	85.5	87.5	82.5	77.5	72.5	67.5	62.5	57.5	52.5	47.5	42.5	37.5	32.5	27.5	22.5	17.5	12.5	7.5	2.5	-2.5	-7.5	TOTALS

Proposed Heating Energy therms N

Existing Heating Energy therms

Existing Building Ventitation & Inflitration (occ) Overheat Ventitation Factor Additional ventitation to offset overheat Existing Building Ventilation & Inflitration (unocc)

295 cfm 1,00 0 cfm 295 cfm

ECM 5 Temperature Setback - Courtroom

Building Footprint Heating Efficiency Cooling Efficiency Building Batance Ten Internal Gains Unoc Internal Gain fa

Ex Occupied Cing Temp.
Ex Unoccupied Cing Temp.
Prop Occupied Cing Temp.

Ex Occupied Hig Temp. Ex Unoccupied Hig Temp. Prop Occupied Hig Temp.

Heating Energy Savings Cooling Energy Savings

				_	_	_			_	_	_	_	_	_	_		_	_	_	_	_	_	_	_	_	_	_	_		
				Proposed Heating	Energy	therms	z	0	ō	ō	ō	ō	ō	ō	ō	0	0		37			•		83	96	15	<b>6</b> 0 1	ισ ·	ō	6
				Existing Heating	Energy	therms	Z	0	0	0	0	0	0	0	٥	0	0	37	9	æ (	177	155	83	72	6	17	o	9	0	0
				Proposed Cooling	Energy	KWh	.,	0	6	83	248	889	217	209	235	240	92	0	0 (	<del>-</del>	0	0	0	0	0	0	0	0	-	0
		_	_	Existing	Energy	kWh	×	0	9	8	274	784	999	508	224	104	-	-	0	-	-	-	-	-	•	_	_	-	•	-
					Internal Gain	втин	<b>L</b>	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	2,628	-2,628
			Unoccupled			Load BTUH	o	-30,012	-21,437	-17,539	-13,772	-10,394	0	0	0	•	780	2,339	3,898	5,457	7,016	8,575	10,134	11,693	13,252	14,811	16,370	17,929	19,488	21,047
		LOADS		Unoccupled		Load BTUH L	2	-10,074	-7,835	-5,597	-3,358	-1,119	0	0	0	0	763	2,289	3,815	5,340	998'9	8,392	9,918	11,444	12,969	14,485	16,021	17,547	19,073	20,598
	•	PROPOSED LOADS			튑		Σ	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512
			Occupled			Load BTUH	ب	-30,012	-21,437	-17,539	-13,772	-10,394	-7,276	-4,157	780	2,339	3,898	5,457	7,016	8,575	10,134	11,693	13,252	14,811	16,370	17,929	19,488	21,047	22,606	24,165
60°F blu/hr″F btu/hr″F				Envelope		BTUH L	¥	-20,343	-17,214	-14,084	-10,954	-7,824	-4,695	-1,565	763	2,289	3,815	5,340	998'9	8,392	9,918	11,444	12,969	14,485	16,021	17,547	19,073	20,598	22,124	23,650
7.09 bld 308 bud 308					Internal Gain	втин	7	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2,628	-2.628
Hig Temp.	### 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1		Unoccupied			oad BTUH	_	-30,012	-21,437	-17,539	-13,772	-10,394	-7,276	0	0	780	2,339	3,898	5,457	7,016	8,575	10,134	11,693	13,252	14,811	16,370	17,929	19,488	21,047	22,606
Prop Unoccupied Hig Temp. Occupied Heating UA Unoccupied Heating UA	ling energy calculations	LOADS		Unoccupled	Envelope	Load BTUH Load BTUH	Ŧ	-12,313	-10,074	-7,835	-5,597	-3,358	-1,119	0	0	763	2,289	3,815	5,340	998'9	8,392	9,918	11,444	12,969	14,495	16,021	17,547	19,073	20,598	22,124
ከ/ ቸ ከ/ ቸ (ነዕ (ነዕ	rd cooling energ	EXISTING LOADS			ıl Galn	BTUH	Ø	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512	-10,512
80 °F SAM blufni 448 blufni 28 Blufh	ooled, disrega		Occupied			Load BTUH	Ŀ	-30,012	-21,437	-17,539	-13,772	-10,394	-7,276	4,157	2,027	3,586	5,145	6,704	8,263	9,822	11,381	12,940	14,499	16,058	17,617	19,176	20,735	22,294	23,853	25.412
Cing Temp. UA ig UA Ipy Setpoint	nalyzed is not c			Envelope		BTUH L	ш	-20,343	-17,214	-14,084	-10,954	-7,824	-4,695	-1,565	1,984	3,509	5,035	6,561	8,087	9,613	11,138	12,664	14,190	15,716	17,242	18,767	20,293	21,819	23,345	24.871
Prop Unoccupied Cing Temp. Occupied Cooling UA Unoccupied Cooling UA Cooling Occ Enthalpy Setpoint Cooling Unocc Enthalpy Setpoint	Heating and cooling energy are unrelated in this model. If the building being analyzed is not cooled, disregard coo		-	Unoccupied	Squipment Bin	Hours	۵	0	e	32	123	470	583	624	803	872	564	574	575	617	862	069	314	237	118	4	21	12		0
£	is model, if the			Occupied	quipment Bin t	Hours	ပ	0	0	7	œ	30	37	4	51	92	98	36	36	88	61	4	20	15	7	6	-	-	0	0
55 °F (3.140 bu/h 0.2 0.8	s unrelated in th			Existing	Avg Outdoor Equipment Bin Equipment Bin	Hours	æ	0	၉	34	131	200	620	664	854	927	009	610	611	929	1,023	734	334	252	125	47	22	13	0	0
a Temp.	oling energy an				Avg Outdoor E	Air Enthalpy		49.1	42.5	39.5	36.6	8	31.6	28.2	27	24.5	21.4	18.7	16.2	14.4	12.6	10.7	8.6	6.8	5.5	1.7	2.6	-	0	-1,5
Building Balance Temp. Internal Gains Unoc Internal Gain factor Ave Occ Internal Gain Factor	Heating and co.			Ava Outdoor		-	4	102.5	97.5	92.5	87.5	82.5	77.5	72.5	67.5	62.5	57.5	52.5	47.5	42.5	37.5	32.5	27.5	22.5	17.5	12.5	5.7	2.5	-2.5	-7.5
	_							-	_	_	_	_	_	_		_			_					_		_		_		

Existing Building Ventilation & Infiltration (000)
Overheat Ventilation Factor
Additional ventilation to offset overheat
Existing Building Ventilation & Infiltration (unoco)

289 cfm 1.09 0 cfm 289 cfm

		iat: 0.99	or: 1.23	int: 1.00
Multipliers  Mate  Lai  Equipm	Multipliers	Material:	Labor	Equipment:

CHA #22424			Multipliers						
<b>Building: Somerdale Municipal Building</b>	Building			Material:	0.99				
				Labor:	1.23				
ECM 5 - Temperature Setback				Equipment:	1.00				
		4							
Coordation	VIO	TIMI		UNIT COSTS	8	SUB	SUBTOTAL COSTS	STS	TOTAL
Description	3		MAT.	MAT.   LABOR   EQUIP.   MAT.   LABOR   EQUIP.	EQUIP.	MAT.	LABOR	EQUIP.	COST

REMARKS

507 Total	507	\$
Engineering	•	₩.
15% Contractor O&P	99	ક્ક
15% Contingency	58	8
384  Subtotal	384	ક્ક
	92	ક્ક
Office Areas	291	s
Replace Old Units in Courtroom and Western	·	

Programmable T-Stats Program Thermostats

### APPENDIX G

**ECM-6 Dual Flush Toilets** 

### ECM 6 Dual Flush Toilets

EXISTING	CONDITIONS
Cost of Water / 1000 Gallons	\$10 44 \$ / kGal
Number of Toilets in Building	9

נו מי	0 14 C 1 F 1 G 14 C C
מחטרטאר	CONDITIONS
Proposed Toilets to be Replaced	9
Proposed Gallons / Flush Solids	1.6 Gal
Proposed Gallons / Flush Liquids	0.8 Gal
Total Installation Cost	\$3,961

SAV	SAVINGS
Current Toilet Water Use	68 kGal / year
Proposed Toilet Water Use	36 kGal / year
Water Savings	32 kGal / year
Cost Savings	\$ 335 / year
Simple Pavback	11.8 years

						Total Usage	Proposed	
	Toilets	Uses/day/toilet	Liquid/Day Solid/Day Gal/Flush	Solid/Day	Gal/Flush	(gals)	Usage (gals)	Repl
Mons		15	0	15	4	09	54	
Womens	2	15	9	10	2.5	37.5	20	
			· Contraction					
General/PoliceToilet	_	7	S.	2	2.5	17.5	7.2	
Police Toilet		25	15	10	1.6	40	28	
Employee Toilet		20	15	5	1.6	32	20	
						187	2.66	
						-		

### ECM 6 Dual Flush Toilets

			_
	0.99	1.23	1.00
Multipliers	Material:	Labor:	Equipment:
<u></u>	<u> </u>		Ш

REMARKS		I Kohler Units		-	3
TOTAL		1,951	1,110	\$ 62	178
TS	EQUIP.	- 8	\$	\$	\$
SUBTOTAL COSTS	LABOR	\$ 684	\$ 615	\$ 62	\$ 123
SUBT	MAT.	\$ 1,267	\$ 495	•	\$ 55
	EQUIP.				
UNIT COSTS	LABOR	\$ 139	\$ 100	\$ 10	\$ 20
ר	MAT.	\$ 320 \$	\$ 100		\$ 28 \$
LINO		ea	ea	ea	ea
αту		4	5	5	2
Description		Dual Flush Toilets	Misc Plumbing fixtures, etc	Old Valve Removal	Dual Flush Retrofit

49	3,301	Subtotal
ક્ક	330	10% Contingency
↔	330	10% Contractor O&P
s		0% Engineering
49	3,961	Total

### APPENDIX H

**ECM-7 Install Storm Windows in Courtroom** 

# ECM 7 Install Storm Windows in Courtroom

Windows can lead to increased energy consumption due to infiltration/exfiltration and heat gain/loss. Adding storm windows to single pained glass can more than double the window's thermal resistance and decrease infiltration. Description

\*Change U-value and air infiltration rates based on new windows or storm windows See block load spreadsheet for U-values

Occupied Cooling Hours per Week
Cocupied Healing Hours per Week
Healing Energy Coat
Cooling Coat
Cocupied Cooling Selpoint Temperature
Occupied Cooling Selpoint Temperature
Unoccupied Healing Selpoint Temperature
Window Area
Window Area
Proposed of Infiltation
Cooling Conversion
Healing Blu Conversion Assumptions Given

Existing U factor
Existing Air Infiltration
Heating System Efficiency
Cooling System Efficiency

10 Hours
10 Hours
8 Khwin
12 Khwin
11 Khwin
11 Khwin
11 Khwin
11 Khwin
12 Khwin
12 Khwin
12 Khwin
12 Khwin
12 Khwin
13 Khwin
14 Khwin
15 E.O. Btu/(h\*sqft\*degf) O.A. cfm/ft R.A. (10 KW/lan

(From ASHRAE Fundamentals) (From ASHRAE Fundamentals)

(Assumption)
(Assumption)
(Assumption)
(Assumption)
(From window survey)
(From window survey)
(From window vendor)
(From window vendor)

Occupied Unoccupied

Cooling Energy Conduction = (Existing U x Area x (OA Temp - RA Temp) x Op Hours) Formula

Heating Energy Conduction = (Existing U x Area x (RA Temp - QA Temp) x Op Hours)
Cooling Energy Infiltration = (4,5 x Leakage x Perimeter x (OA Enthsipy - RA Enthsipy) x Op Hours)
Heating Energy Infiltration = 1.08 x Leakage x Perimeter x (IA4 temp - OA temp) x Op Hours)
Load = (Conduction) + (Infiltration)
Cooling Energy = (Cooling Load) / (12,000 Bur/Molls) (Rw/Ton)
Heating Energy = (Heating Load) / (1,000,000 Bur/MMBu) / (Boller Efficiency)

						Heating	Cooling		Heating	Cooling		Heating
			Total	Cooling	Heating Occupied	Unoccupied	Occupied	Heating Occupied	Unoccupied	Occupied	Heating Occupied	Unoccupied
Existing Operation	OA Enthalphy	OA Temp	Hours	Occupied Hours	Hours	Hours	Conduction	Conduction	Conduction	Infiltration	Infiltration	Infiltration
Cooling	38.3	92.5	37	2.2	0.0	0.0	4,163	0	0	5,461	0	0
Cooling	36.6	87.5	131	7.8	0.0	0.0	11,463	0	0	16,663	0	0
Cooling	33.5	82.5	200	29.8	0.0	0.0	31,250	0	0	45,000	0	0
Cooling	31.6	77.5	620	36.9	0.0	0.0	23,250	0	0	41,664	0	0
Cooling	30.3	72.5	664	39.5	38.5	0.0	8,300	4,980	0	34,262	2,868	0
Heating	27.9	67.5	854	0.0	50.8	0.0	•	27,755	0	0	15,987	0
Heating	24.6	62.5	927	0.0	55.2	871.8	0	53,303	183,083	0	30,702	105,456
Heating	21.6	57.5	900	0.0	35.7	564,3	0	49,500	355,500	0	28,512	204,768
Heating	18.7	52.5	610	0.0	36.3	573.7	0	65,575	602,375	0	37,771	346,968
Heating	16.2	47.5	611	0.0	36.4	574.6	0	80,958	844,708	0	46,632	486,552
Heating	14,3	42.5	656	0.0	39.0	617.0	0	103,320	1,166,040	0	59,512	671,639
Heating	12.4	37.5	1,023	0.0	6'09	962.1	0	186,698	2,222,468	0	107,538	1,280,141
Heating	10.4	32.5	734	0.0	43.7	690.3	0	152,305	1,884,545	0	87,728	1,085,498
Heating	8.7	27.5	334	0,0	19.9	314.1	0	77,655	989,475	0	44,729	569,938
Heating	7	22.5	252	0.0	15.0	237.0	0	64,890	846,090	0	37,377	487,348
Heating	5.4	17.5	125	0.0	7.4	117.6	0	35,313	469,063	0	20,340	270,180
Heating	3.9	12.5	47	0.0	2.8	44.2	0	14,453	194,933	0	8,325	112,281
Heating	2.5	7.5	23	0.0	1.3	20.7	0	7,315	99,935	0	4,213	57,563
Heating	1.2	2.5	13	0.0	9.0	12.2	0	4,648	64,188	0	2,677	36,972
Heating	-0.2	-2.5	0	0.0	0.0	0.0	0	0	0	0	0	0
Heating	-1.4	-7.5	0	0.0	0.0	0.0	0	0	0	0	0	0
Subtofal			8 760	446	AAR	2 600	78 A9E	298 865	0 922 ANN bbs	143 051	£24 044	5 715 302 hts

221,476 btu		20 KWh		3,53		17,101,278 btu		209 therms		\$ 284	
78425 ) + ( 143051 ) =	Cooling Load	221476 )/( 12000 )*( 1.10 )=	Cooling Energy Cooling Cost	20.30 ) x ( \$0.174 ) =	Conduction Inflitration	10851065 ) + ( 6250213 ) =	Heating Load Heat Content	17101278 )/( 82% )/( 100000 )=	Heating Energy Heating Cost	208.55 ) x ( \$1.363 ) =	
Cooling Load =		Cooling Energy =		Cooling Energy Cost =		Heating Load ≂		Heating Energy =		Heating Energy Cost = (	

			Total	Cooling	Heating Occupied Linguistic	hairmoon	Occupied	Heating Organia	Incorning	Occuminad	Heating Occupied	I Increminad	
Operation	OA Enthalphy	OA Temp	Hours	Occupied Hours	Hours	Hours		Conduction	Conduction	Infiltration	Infiltration	Infiltration	
Cooling	38.3	92.5	37	2.2	0.0		1.982	0	0	2.731	0		
Cooling	36.6	87.5	131	7.8	0.0		5.458	0	0	8.332	0	0	
Cooling	33.5	82.5	200	29.8		0.0	14.881	0	0	22,500		0	
Cooling	31,6	77.5	620	36.9			11.071	0	0	20,832	0	0	
Cooling	30.3	72.5	664	39.5			3,952	2.371	0	17,131		-	
Heating	27.9	67.5	854	0.0	50.8			13,217	0	0	7,993	0	
Heating	24.6	62.5	927	0.0		8	0	25,382	87,182	•	15,351	52,728	
Heating	21.6	57.5	900	0.0			0	23,571	169,286	0	14,256	102,384	
Heating	18.7	52.5	610	0.0			0	31,226	286,845	0	18,886	173,484	
Heating	16.2	47.5	611	0.0			0	38,551	402,242	0	23,316	243,276	
Heating	14.3	42.5	999	0.0	39.0		0	49,200	555,257	0	29,756	335,820	
Heating	12.4	37.5	1,023	0.0	6:09		0	88,904	1,058,318	0	53,769	640,071	
Heating	10.4	32.5	734	0.0	43.7		0	72,528	897,402	0	43,864	542,749	
Heating	8.7	27.5	334	0.0	19,9		0	36,979	471,179	0	22,365	284,969	
Heating	۷ _	22.5	252	0.0	15.0		0	30,900	402,900	0	18,688	243,674	
Heating	5.4	17.5	125	0.0	7.4	_	0	16,815	223,363	0	10,170	135,090	
Heating	3.9	12.5	47	0.0	2.8		0	6,882	92,825	0	4,162	56,141	
Heating	2.5	7.5	22	0.0	1.3	20.7	0	3,483	47,588	0	2,107	28,781	
Heating	1.2	2.5	13	0.0	_		0	2,213	30,565	0	1,338	18,486	
Heating	-0.2	-2.5	0	0.0			0	•	•	0	•	0	
Heating	4.1-	-7.5	0	0.0			0	0	0	0	0	6	
Subtotal =			8,760	116	445	5.	37,345	442,221	4,724,952 btu	71,525	267,456	2,857,651 btu	Þ
	Conduction	Inflitratio											
Cooling Load =	37345)+	+( 71525)=			108,871 btu	Þtu							
	Cooling Load												
Cooling Energy =	)( 108871 )/(		( 1.10 )=	=	10	10 KWh							
	Cooling Energy	Solin											
Cooling Energy Cost =	x(86.6)	ч			\$ 1.74								
	Conduction	Infiltration											
Heating Load ≈	( 5167174 )	+( 3125107)=			8,292,281 btu	btu							
	Heating Load	Heat Content											
Heating Energy =	( 8292281 )/(	95%)/(	= ( 000001 )		101	101 therms							
	Heating Energy	Heating											
Heating Energy Cost =	( 101.13)×	x( \$1.363)=			\$ 138								
EXISTING COOLING ENERGY		20.30 KWh	٩		\$ 3,53								
EXISTING HEATING ENERGY		208.55 the	therms		\$ 284.31								
EXISTING ENERGY COST					\$ 287.84								
		П											
PROPOSED COOLING ENERGY		9.98 KWh	£		\$ 1.74								
PROPOSED HEATING ENERGY			therms		\$ 137.86								
PROPOSED ENERGY COST					\$ 139.60								
		1						:					
HEATING ENERGY SAVINGS		10.32 KWN	Kwn		1.80		50.8%	50.8% of existing					
ENERGY COST SAVINGS			2		\$ 148.25		51.5%	51.5% of existing					

**ECM 7 Install Storm Windows in Courtroom** 

# Material: Labor: Equipment:

Description	QTY	TINO		<u> </u>	UNIT COSTS	S		SUB	SUBTOTAL COSTS	COSTS		TOTAL	DEMADIKS
			2	MAT.	LABOR	EQUIP.	Σ	MAT.	LABOR	$\vdash$	EQUIP.	COST	REINIARNS
2'x5' storm windows	8	EA	\$	86	\$ 21		\$	922	\$ 2	207   \$	-	\$ 983	983 Cost Estimated from Means
							÷	1	æ	\$	-	- \$	

\$ 295 30% Contingency \$ 192 15% Contractor O&P \$ - 0% Engineering \$ 1,469 Total	ક્ર	983	Subtotal
15% 0% <b>Total</b>	↔	295	30% Contingency
0%   <b>Total</b>	ક્ર	192	15% Contractor O&P
•	છ	-	
	\$	1,469	Total

### APPENDIX I

**ECM-8** Increase Wall Insulation in Courtroom

# ECM 8 Increase Wall Insulation in Courtroom

l Area 818 sf	0.06 Btu/hr/(sf*F)	8277	
0,16 Btu/hr/(sf*F)	19.78	1 10 kW/ton	
Total Existing Exterior Wall Area Existing U-value	Proposed U-value Proposed R-value	Heating Efficiency Cooling Efficiency	Existing Cooling

1.10 kW/to	U. Btu/hr 144 Btu/hr 185 Btu/hr 11.188 Btu/hr
Cooling Efficiency	Existing Cooling Max. North Wall Cooling Load Max. East Wall Cooling Load Max. South Wall Cooling Load Max. Wall Cooling Load

1	Btu/		Btu	Btu/	
-	X	×		(2)	
		×			
-	×				
1					
- 1					

A F A Btu/hr 60 F

Existing Heating
Existing Heating Load Temp Diff:
Existing Max. Wall Heating Load
Heating On Point

759 Btu/hr

Proposed Heating Proposed Max. Heating Load

ž	
100	1.158
큟	867
器	pp.
B Tr	





Occupied Cooling Setpoint Unoccupied Cooling Setpoint



Existing Cooling Total Proposed Cooling Total

ı	S kWh/yr 5 kWh/yr 55 kWh/yr	
#2 ***	80 25 55	
	8	

University

Existing Heating Total
Proposed Heating Total
Savings Occupied Heating Setpoint Unoccupied Heating Setpoint

Btu/yr Btu/yr Btu/yr therms

			Proposed Heating	(Btu/vr)	-		1	•	,		•	•	246,336	376,112	502,604	674,768	1,263,022	1,057,431	549,984	466,874	257,336	106,441	54,356	34,798		•	5,590,062
				(kWh/vr)	0	7	S	7	9	•			•	•		•			٠	٠	•		•		٠	٠	25
			Existing Heating	(Btu/vr)				,	•	•	•	•	782,108	1,194,140	1,595,749	2,142,360	4,010,044	3,357,301	1,746,176	1,482,306	817,032	337,947	172,578	110,481	•	•	17,748,223
			Existing Cooling Existing Heating	(KWh/vr)	-	ß	15	36	19	က				٠	•	,			•	•	•	•			•	•	80
				(Btu/hr)		•		,				•	309	515	721	927	1,133	1,339	1,545	1,751	1,957	2,163	2,369	2,575	2,781	2,987	
	Unoccupled		Existing	(Btu/hr)		٠			•				981	1,635	2,289	2,943	3,598	4,252	4,906	5,560	6,214	6,868	7,522	8,176	8,830	9,484	
	Onoc		Proposed	(Btu/hr)	683	531	380	228	76		•			•	•	•	•	•		•	•	•		•		•	
				(Btu/hr)	2,169	1,687	1,205	723	241	•	•	•	,	٠	•	•	•	•	•	•	•	•	•	•	•	•	
			Proposed Heat	(Btu/hr)		•	•	•		•	•	•	089	886	1,092	1,298	1,504	1,710	1,916	2,122	2,328	2,534	2,740	2,946	3,152	3,358	
	þe		Existing Heat	(Btu/hr)									2,159	2,813	3,467	4,121	4,775	5,429	6,083	6,737	7,391	8,045	8,699	9,354	10,008	10,662	
	Occupied		Proposed Heat Existing Heat Proposed Heat	(Btu/hr)		559	435	311	186	62				•		•		•		•	•	•				•	
			leat	(Btu/hr)	2,169	1,775	1,380	986	592	197			•	•	•	•	•	•	•	•	•	•		•	•	•	
•		Unoccupled	Equipment Bin	uodis	2	52	92	363	420	482	620	673	436	443	444	476	743	533	243	183	9	8	16	6	0	0	6,361
		Occupled	Equipment	s inou sile	-	6	98	137	170	182	234	254	164	167	167	180	280	201	91	69	34	5	9	4	0	0	2,399
		Existing	Equipment Bin	Sinou	3	8	131	200	620	664	854	927	009	610	611	929	1,023	734	334	252	125	47	22	13	0	0	8,760
			Avg Outdoor Air	i ellip. Dillo r	97.5	92.5	87.5	82.5	77.5	72.5	67.5	62.5	57.5	52.5	47.5	42.5	37.5	32.5	27.5	22.5	17.5	12.5	7.5	2.5	-2.5	-7.5	TOTALS

room
Court
lation in
Wall Inst
Increase
ECM 8

	0.99	1.23	1.00
Multipliers	Material:	Labor:	Equipment:

Document	75	HIN		Ď	JNIT COSTS	TS	S	UBTC	SUBTOTAL COSTS	STS	Н	TOTAL	SAGVE
Describing	3		Ŋ,	MAT.	LABOR	EQUIP.	MAT.		LABOR	EQUIP		COST	
Kraft Faced Fiberglass Insulation	815	SF	ક્ક	0.28	\$ 0.21	1	\$ 22	226   \$	211	\$	1	3 436	R-13, 3.5" thick, 23" wide
Metal Framing	38	EA	€>	15.00	\$ 5.00	0	\$ 564	.4 \$	234	\$	-	3 798	Metal Studs
1/2" Gypsum Board, without finish	815	SF	ક્ક	0.24	\$ 0.33	3	\$ 15	94 \$	331	\$	1	524	From Means
Drywall Finishing	815	SF	ક્ક	0.12	\$ 0.30	0	3 \$	\$   26	301	\$	•	398	From Means
Painting	815	SF	ક્ર	0.19	\$ 0.29	6	\$ 15	123 \$	291	s	۱	3 444	From Means
Miscellaneous electrical and plumbing costs	815	SF	↔	0.10	\$ 0.10	0	3	81 \$	100	\$	•	3 181	Estimated
Miscellaneous Trim Work	815	SF	\$	0.25	\$ 0.25	5	\$ 20	202   \$	251	\$	1	3 452	Estimated

Total	3,913 Total	s
Engineering	•	\$
10% Contractor O&P	356	မှာ
10% Contingency	323	↔
Subtotal	3,234	ક

### APPENDIX J

ECM-9 Replace Court Office RTU with More Efficient Unit

# ECM-9 Replace Court Office RTU with more Efficient Unit

Building Footprint	RS (00)	Ex Occupied
Building Balance Temp.	¥ 58	Ex Unoccup
Internal Gains	18,021 btu/h	Occupled C
Unoc Internal Gain factor	0.2	Unoccupied
Ave Occ Internal Gain Factor	6.0	Cooling Occ
Economizer available (Y/N)	Yes	Cooling Und
Proposed Economizer (Y/N)	Yes	
Existing Heating Efficiency	%82	
Existing Cooling Efficiency	1,48 kW/ton	
Proposed Heating Efficiency	82%	
Proposed Cooling Efficiency	1.04 kW/lon	

72 + 72 + 552 bu/hr/*F 553 bu/hr/*F 26 Bu/h t	
Ex Occupied Cing Temp. Ex Unoccupied Cing Temp. Occupied Cooling UA Unoccupied Cooling UA Cooling Occ Enthalpy Setpoint Cooling Unocc Enthalpy Setpoint	
44.0 SF 55.0 btu/h 0.2 0.9 Yes Yes	

Heating Energy	Cooling Energy	Fan Savings		
7.4.7	74.15	249 btu/hr/°F	249 btu/hr/°F	
Ex Occupied Htg Temp.	Ex Unoccupied Htg Temp.	Occupied Heating UA	Unoccupled Heating UA	

Heating Ene	Cooling Ene	Fan Savings	
74 17	74 17	249 btu/hr/°F	ביין היים ביים

32 therm	₹	κW	
32	1854 kW	717	
gy Savings	gy Savings		

Discussion   Dis	Proposed Cooling Efficiency 1.04 kW/ton	1.04 kW/ton	04 kW/ton					EXISTING LOADS	LOADS								
Internal Gain   Cooling				Occu	Occu	Occu	pied			Unoccupied							
Internal Gain	Existing Occupied Unoccupied Envelope	Occupied Unoccupied	Unoccupied		Envelope				Unoccupied			Existing Cooling	Proposed Cooling	Available	Proposed	Existing Heating	Proposed Heating
G         H         I         J         K         L         L         L         M           9         -16,219         -13,749         -30,629         -3,604         15         I         0 <th>Bin Equipment Bin Equipment Bin Load Venti</th> <th>Equipment Bin Load Venti</th> <th>Equipment Bin Load Venti</th> <th>Equipment Bin Load Venti</th> <th>Venti</th> <th></th> <th>5 =</th> <th>Internal Gain RTIIH</th> <th></th> <th>Ventilation</th> <th>Internal Gain BTUH</th> <th>Energy</th> <th>Energy</th> <th>Ë</th> <th>Energy</th> <th>Energy</th> <th>Energy</th>	Bin Equipment Bin Equipment Bin Load Venti	Venti		5 =	Internal Gain RTIIH		Ventilation	Internal Gain BTUH	Energy	Energy	Ë	Energy	Energy	Energy			
-16.219 -13.749 -30,629 -3,604 15 11 0 0 0 0 10 11 11 11 14,65 -21,878 -3,604 15 11 11 0 11 11 0 11 11 11 11 11 11 11 11	B C D E	B C D E	D			-		9		_	,	¥				Σ	z
-16.219 -11,495 -21,878 -3,604 15 11 11 0 0 113 113 115.219 -11,495 -21,878 -3,604 146 103 103 103 103 105.21 114.95 -9,241 -17,900 -3,604 1401 985 0 985 103 103 103 105.21 10,607 -3,604 1401 985 0 985 105.21 10,619 2.2479 -10,667 -3,604 1401 985 0 985 10,619 2.2479 -10,667 -3,604 1401 985 0 985 10,6219 2.865 3,604 361 2.64 0 264 114 5,219 2.865 3,604 141 5,225 -3,604 141 5,225 3,604 141 5,225 3,604 141 1,615 -3,604 141 1,615 -3,604 14,077 11,985 14,077 17,980 3,604 16,219 16,586 2.1,627 3,604 16,219 17,814 22,753 3,604 16,219 17,814 22,753 3,604 16,219 17,814 22,753 3,604 16,219 17,814 22,753 3,604 16,219 17,814 22,753 3,604 16,219 17,814 22,753 3,604 16,219 17,814 22,753 3,604 16,219 17,814 22,753 3,604 16,219 17,814 22,753 3,604 16,219 17,814 22,753 3,604 16,219 17,814 22,753 3,804 16,219 17,814 22,753 3,336 17,814 22,753	0 0 0 -17.150	0 0 0 -17.150				ľ	30,629	-16 219	-13 749	-30 629	-3 604	C	C	C	C	0	0
-16,219	3 1 2 -14.339	3 1 2 -14.339					21.878	-16,219	-11.495	-21.878	-3.604	15	-	0	-	0	0
-16,219	9 25 -11,527	34 9 25 -11,527	-11,527	-11,527		•	17,900	-16,219	-9,241	-17,900	-3,604	146	103	0	103	0	0
-16.219	131 36 95 -8,716	131 36 95 -8,716	95 -8,716	-8,716		•	14,055	-16,219	-6,987	-14,055	-3,604	462	324	0	324	0	0
-16.219		137 363 -5,904	363 -5,904	-5,904		·	-10,607	-16,219	4,733	-10,607	-3,604	1401	985	0	982	0	0
-16.219	620 170 450 -3,093	620 170 450 -3,093	450 -3,093	-3,093			-7,425	-16,219	-2,479	-7,425	-3,604	1310	920	0	920	0	0
-16,219	664 182 482 -281	664 182 482 -281	482 -281	-281			4,243	-16,219	-225	4,243	-3,604	945	664	0	664	0	0
-16.219 2.865 3.660 -3.604 303 213 423 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	854 234 620	854 234 620	620		1,619		2,068	-16,219	1,619	2,068	-3,604	361	254	0	254	0	0
-16.219	927 254 673	927 254 673	673		2,865		3,660	-16,219	2,865	3,660	-3,604	303	213		0	0	0
-16,219	600 164 436	600 164 436	436		4,111		5,251	-16,219	4,111	5,251	-3,604	139	86		0	0	0
-16.219 6.602 8.433 -3.604 24 17 0 17 0 17 0 17 0 17 0 17 0 17 0 17	167	610 167 443	443		5,357		6,842	-16,219	5,357	6,842	-3,604	83	28	0	28	0	0
-16,219 7,848 10,024 -3,604 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	611 167 444	611 167 444	444		6,602		8,433	-16,219	6,602	8,433	-3,604	24	17	0	17	0	0
-16,219 9,094 11,615 -3,604 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	656 180 476	656 180 476	476		7,848		10,024	-16,219	7,848	10,024	-3,604	0	0	0	0	91	87
-16,219	1,023 280 743	1,023 280 743	743		9,094		11,615	-16,219	9,094	11,615	-3,604	0	0	0	0	179	170
-16,219	533	734 201 533	533		10,340		13,206	-16,219	10,340	13,206	-3,604	0	0	0	0	155	148
-16,219 12,831 16,388 -3,604 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	334 91 243	334 91 243	243		11,585		14,797	-16,219	11,585	14,797	-3,604	0	0	0	0	83	92
-16,219 15,323 19,571 -3,604 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	252 69 183	252 69 183	183		12,831		16,388	-16,219	12,831	16,388	-3,604	0	0	0	0	72	89
-16,219 15,323 19,571 -3,604 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	125	125 34 91	91		14,077		17,980	-16,219	14,077	17,980	-3,604	0	0	0	0	40	88
-16,219 16,568 21,162 -3,604 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	47 13 34	47 13 34	<b>₹</b>		15,323		19,571	-16,219	15,323	19,571	-3,604	0	0	0	0	17	16
-16.219 17.814 22.753 -3.604 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	6 16	22 6 16			16,568		21,162	-16,219	16,568	21,162	-3,604	0	0	0	0	6	8
-16,219 19,060 24,344 -3,604 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	1 13 4 9 17,814	6			17,814		22,753	-16,219	17,814	22,753	-3,604	0	0	0	0	9	5
-16,219 20306 25,935 -3,604 0 0 0 0 0 0 0 0 0 126.336 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0	0 0	0 0 0 0	0 19,060	19,060		24,344	-16,219	19,060	24,344	-3,604	0	0	0	0	0	0
3,647 1,263 3,336	0 0	0 0 0	0 0 20,306	0 20,306	20,306		25,935	-16,219	20306	25,935	-3,604	0	0	0	o	0	0
	8,760 2,399 6,361	2,399		6,361								5190	3,647	1,263	3,336	651	619

Existing Building Ventilation & Inflitration (occ)	Overheat Ventilation Factor	Additional ventilation to offset overheat	Existing Building Ventilation & Infiltration (unocc)	Economists Ventilation
Existing Building Ventilation & Infiltration (	Overheat Ventilation Factor	Additional ventilation to offset overheat	Existing Building Ventilation & Infiltration (	Toomomissa Montilation

_	_	_	_	
1 1	0 cfm	동	듄	
8	٥	88	2,850 cfm	
			N	
		_		
		O		

	- 7
	Ö te
	;
	u
_	
5	
ž	
<u> </u>	
=	
Ξ.	
mizer Ventilatio	
τ.	
₫.	
N	
Ε	

	Usage k	9,038		Usage kWh	
	Run Hours/year	3,066		Run Hours/year	3,066
	Efficiency	82.4%	y)	Efficiency	89.5%
	샑	3.3	Proposed Fan (premium efficiency)	롸	3,3
	KW	2.4	Proposed Fan (p	κw	2.4
	Current	7.5		Current	5.7
	Phase	3		Phase	3
existing ran	Volts	208		Volts	208

Somerdale, NJ Energy Audit CHA #22424

**Building: Somerdale Municipal Building** 

ECM-9 Replace Court Office RTU with more Efficient Unit

Multipliers	
Material:	0.99
Labor:	1.23
Equipment:	1.00

Docociotion	) YE			UNIT COSTS	(0)	SUB	SUBTOTAL COSTS	STS	SYGNEG TSOCIATOR	DEMADIC
Describaci	ב	O I	MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.	I O I AL COSI	CANAMA
						- \$	\$	- \$	*	
RTU Removal	1	EA		009 \$		- \$	\$ 738	- \$	\$ 738	
						- \$	٠ <del>د</del>	- \$	\$	
10 Ton cooling /200MBH heating RTU (11.5 EER)*	-	ΕĀ	\$ 5,900	\$ 1,750		\$ 5,841	\$ 2,153	-	\$ 7,994	7,994  From Contractor
Roof Curb Adapter	-	Ę	\$ 225	\$ 125		\$ 223	\$ 154	-	\$ 377	
Miscellaneous Electrical	1	S.I	\$ 250			\$ 248	۰ چ	- چ	\$ 248	
*RTU pricing is estimated based on Carrier model 48HC12 w/ econo	w/ economize	omizer and gas heat.	at.							

i	economizer and gas hear
l	ĕ
i	<u></u>
ı	ŭ
ì	50
	헏
ı	늄
l	+
ı	8
ı	- 🛱
ı	=
ı	8
ı	2
ı	ပ္က
ı	2 w/e
ı	- ₹
ı	<u>~</u>
ı	$\stackrel{\sim}{\sim}$
ı	$\circ$
ľ	Ĭ
ı	48HC
l	4.
ı	ē
ı	Ğ
ľ	8
ı	r mod
ı	63
ı	Ē
ı	Ħ
ı	Ü
ı	d on C
ı	10
ı	ਚ
ı	asec
ı	æ
۱	
ı	귯
ĺ	5
ı	뗨
ı	.⊟
ı	st
ı	O
ı	₽.
۱	60
ı	.Ē
ı	.2
ı	pricing is estimat
۱	. =-
۱	$\supset$
۱	
ſ	~

\$         936         10% Contingency           \$         1,029         10% O&P           \$         -         0% Engineering           \$         11,320         Total	G	9,356	9,356  Subtotal
1 Total	₩	936	10% Contingency
Total			Contractor
Total	G	1,029	10% O&P
÷	₩	•	0% Engineering
	<del>s</del>	11,320	Total

### APPENDIX K

New Jersey Pay For Performance Incentive Program

### Somerdale, NJ Energy Audit

CHA #22424

**Building: Somerdale Municipal Building** 

### New Jersey Pay For Performance Incentive Program

Note: The following calculation is based on the New Jersey Pay For Performance Incentive Program per April, 2010. Building must have a minimum average electric demand of 200 kW. This minimum is waived for buildings owned by local governements or non-profit organizations.

The incentive values represented below are applicable through December 31, 2010.

Total Building Area (Square Feet)	8,500
Is this audit funded by the NJ BPU (Y/N)	Yes
Bureau of Public Utilites (BPU)	

Incentiv	e #1	
Audit not funded by NJ BPU	\$0.10	\$/sqft
Audit is funded by NJ BPU	\$0.05	\$/sqft

	Annual	Utilities		
	kWh	Therms		
Existing Cost (from utility)	\$20,493	\$3,948		
Existing Usage (from utility)	117,820	2,896		
Proposed Savings	24,178	1,043		
Existing Total MMBtus	692			
Proposed Savings MMBtus	187			
% Energy Reduction	27.0%			
Proposed Annual Savings	\$6,328			

Does not Include Water Savings

	Min (Savir	igs = 15%)	Increase (Sa	vings > 15%)	Max Incentive		Achieved	Incentive
	\$/kWh	\$/therm	\$/kWh	\$/therm	\$/kWh	\$/therm	\$/kWh	\$/therm
Incentive #2	\$0.11	\$1.10	\$0.005	\$0.05	\$0.13	\$1.45	\$0.13	\$1.45
Incentive #3	\$0.07	\$0.70	\$0.005	\$0.05	\$0.09	\$1.05	\$0.09	\$1.05

		Incentives	\$
	Elec	Gas	Total
Incentive #1	\$0	\$0	\$425
Incentive #2	\$3,143	\$1,512	\$4,655
Incentive #3	\$2,176	\$1,095	\$3,271
Total All Incentives	\$5,319	\$2,606	\$8,350

|--|

		Allowable	
	:	Incentive	
% Incentives #1 of Utility Cost*	1.7%	\$425	
% Incentives #2 of Project Cost**	Cost** 14.1%		
% Incentives #3 of Project Cost**	9.9% \$3,271		
Total Eligible Incentives***	\$8,350		
Project Cost w/ Incentives	\$24,674		

ack (years)
w/ Incentives
3.9

<sup>\*</sup> Maximum allowable incentive is 50% of annual utility cost if not funded by NJ BPU, and %25 if it is.

Maximum allowable amount of Incentive #3 is 20% of total project cost.

Maximum allowable amount of Incentive #2 & #3 is \$1 million per gas account and \$1 million per electric account

<sup>\*\*</sup> Maximum allowable amount of Incentive #2 is 30% of total project cost.

<sup>\*\*\*</sup> Maximum allowable amount of Incentive #1 is \$50,000 if not funded by NJ BPU, and \$25,000 if it is.

### APPENDIX L

Photovoltaic (PV) Rooftop Solar Power Generation

Somerdale Borough Hall

Cost of Electricity

\$0.174 \$/kWh

Photovoltaic (PV) Rooftop Solar Power Generation-30 kW System

Budgetary		Annual Util	Utility Savings		Estimated	Total	New Jersey Renewable	New Jersey Renewable	Payback	Payback
							* Energy		(without	(with
Cost					Maintenance   Savings	Savings	Incentive	** SREC	$\overline{}$	incentive)
					Savings					
\$	ΚW	kWh	therms	s	ક	s	s	↔	Years	Years
\$165,000	0.0	37,510	0	\$6,500	0	\$6,500	\$22,500	\$18,300	25.4	5.7

Note: Budgetary cost is based on \$5,500/kW.

\*Incentive based on New Jersey renewable energy program for non-residential applications(PV)= \$0.75/W of installed PV system
\*\* Estimated Solar Renewable Energy Certificate Program (SREC) SREC for 15 Years= \$487/1000kwh

Estimated Solar Renewable Energy Certificate Program (SREC) payments for 15 Years from RR Renewable Energy Consultants

SREC	009	009	009	200	200	200	200	500	500	200	400	400	400	400	400	487
Year	l l	2	3	7	2	9	2	8	6	10	11	12	13	14	15	AVG



### AC Energy & Cost Savings



(Type comments here to appear on printout; maximum 1 row of 80 characters.)



Station Identif	ication
City:	Atlantic_City
State:	New_Jersey
Latitude:	39.45° N
Longitude:	74.57° W
Elevation:	20 m
PV System Specification	S
DC Rating:	30.0 kW
DC to AC Derate Factor:	0.770
AC Rating:	23.1 kW
Array Type:	Fixed Tilt
Array Tilt:	39.5°
Array Azimuth:	180.0°
Energy Specifications	
Cost of Electricity:	17.4 ¢/kWh

	Res	sults	
Month	Solar Radiation (kWh/m²/day)	AC Energy (kWh)	Energy Value (\$)
1	3.61	2684	466.75
2	4.20	2795	486.05
3	4.78	3373	586.56
4	5.23	3464	602.39
5	5.44	3634	631.95
6	5.48	3399	591.09
7	5.55	3514	611.08
8	5.41	3465	602.56
9	5.23	3318	577.00
10	4.60	3102	539.44
11	3.59	2463	428.32
12	3.17	2299	399.80
Year	4.69	37510	6522.99

Output Hourly Performance Data

Output Results as Text

About the Hourly Performance Data

Saving Text from a Browser

Run PVWATTS v.1 for another US location or an International location Run PVWATTS v.2 (US only)

Please send questions and comments regarding PVWATTS to Webmaster

Disclaimer and copyright notice



Return to RReDC home page (http://rredc.nrel.gov)



### **Cautions for Interpreting the Results**

The monthly and yearly energy production are modeled using the PV system parameters you selected and weather data that are typical or representative of long-term averages. For reference, or comparison with local information, the solar radiation values modeled for the PV array are included in the performance results.

Because weather patterns vary from year-to-year, the values in the tables are better indicators of long-term performance than performance for a particular month or year. PV performance is largely proportional to the amount of solar radiation received, which may vary from the long-term average by  $\pm$  30% for monthly values and  $\pm$  10% for yearly values. How the solar radiation might vary for your location may be evaluated by examining the tables in the Solar Radiation Data Manual for Flat-Plate and Concentrating Collectors (http://rredc.nrel.gov/solar/old\_data/nsrdb/redbook/).

For these variations and the uncertainties associated with the weather data and the model used to model the PV performance, future months and years may be encountered where the actual PV performance is less than or greater than the values shown in the table. The variations may be as much as 40% for individual months and up to 20% for individual years. Compared to long-term performance over many years, the values in the table are accurate to within 10% to 12%.

If the default overall DC to AC derate factor is used, the energy values in the table will overestimate the actual energy production if nearby buildings, objects, or other PV modules and array structure shade the PV modules; if tracking mechanisms for one- and two-axis tracking systems do not keep the PV arrays at the optimum orientation with respect to the sun's position; if soiling or snow cover related losses exceed 5%; or if the system performance has degraded from new. (PV performance typically degrades 1% per year.) If any of these situations exist, an overall DC to AC derate factor should be used with PVWATTS that was calculated using system specific component derate factors for *shading*, *sun-tracking*, *soiling*, and *age*.

The PV system size is the nameplate DC power rating. The energy production values in the table are valid only for crystalline silicon PV systems.

The cost savings are determined as the product of the number of kilowatt hours (kWh) and the cost of electricity per kWh. These cost savings occur if the owner uses all the electricity produced by the PV system, or if the owner has a net-metering agreement with the utility. With net-metering, the utility bills the owner for the net electricity consumed. When electricity flows from the utility to the owner, the meter spins forward. When electricity flows from the PV system to the utility, the meter spins backwards.

If net-metering isn't available and the PV system sends surplus electricity to the utility grid, the utility generally buys the electricity from the owner at a lower price than the owner pays the utility for electricity. In this case, the cost savings shown in the table should be reduced.

Besides the cost savings shown in the table, other benefits of PV systems include greater energy independence and a reduction in fossil fuel usage and air pollution. For commercial customers, additional cost savings may come from reducing demand charges. Homeowners can often include the cost of the PV system in their home mortgage as a way of accommodating the PV system's initial cost.

To accelerate the use of PV systems, many state and local governments offer financial incentives and programs. Go to http://www.nrel.gov/stateandlocal for more information.

Please send questions and comments to Webmaster

Disclaimer and copyright notice.



Return to RREDC Home Page (http://rredc.nrel.gov/)

### APPENDIX M

**Solar Thermal Domestic Hot Water Plant** 

NJBPU Energy Audits CHA #22424 Somerdale Borough Hall

ultipliers	
Material:	0.99
Labor:	1.23
Equipment:	-

Material:	0.99
Labor:	1.23
Equipment:	1

			,							
Description	λL	HIN		UNIT COSTS	3	റ	SUBTOTAL COSTS	STS	TOTAL	STOWNE
	<u>-</u>	I INO	MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.	COST	COST REMARKS
Synergy Solar Thermal System	1	EA	\$ 2,400 \$	0 \$ 1,200		\$ 2,376 \$	\$ 1,476	\$	\$ 3,852	
Piping modifications	1	S7	\$ 1,50	1,500 \$ 2,000		\$ 1,485 \$	\$ 2,460 \$	- ج	\$ 3,945	
Electrical modifications	1	ST	\$ 40	400 \$ 500		\$ 396 \$	\$ 615 \$	\$	\$ 1,011	
65 GallonStorage Tank	-	EA	\$	300 \$ 200		\$ 300	\$ 200 \$	- \$	\$ 500	
10 Gallon Drip Tank	1	EA	\$ 10	100 \$ 80		\$ 100 \$	\$ 08 \$	ا چ	\$ 180	
						•		•	•	

es l	9,488	\$ 9,488 Subtotal
 ↔	949	10% Contingency
↔	949	10% Contractor O&P
 ↔	949	10% Engineering
 ès	\$12,334	Total



<u>Home</u>

# Interactive Energy Calculators

RENEWABLE ENERGY THE INFINITE POWER OF TEXAS

What Can I Do? Electric Choice

Our calculators help you understand energy production and consumption in a whole new way. Use them to develop a personal profile of your own energy use.

Home Energy

**FAQs** 

Carbon Pollution Calculator
Electric Power Pollution Calculator
PV System Economics

LEARN Fact Sheets Lesson Plans PV System Economics
Solar Water Heating
What's a Watt?

PLAY Calculators **Solar Water Heating Calculator** 

NETWORK Organizations Businesses Events Calendar Water heating is a major energy consumer. Although the energy consumed daily is often less than for air conditioning or heating, it is required year round, making it a good application of solar energy. Use this calculator to explore the energy usage of your water heater, and to estimate whether a solar water heater could save you money.

BROWSE Resources Solar

Solar Wind Biomass Geothermal Water

Projects

TX Energy -Past and Present

Financial Help

About Us

About SECO

RARE

Wa	ter Heate	er Characteristics	
Physical		Thermal	
? Diameter (feet)	1.5	? Water Inlet Temperature (Degrees F)	58
? Capacity (gallons)	40	? Ambient Temperature (Degrees F)	70
? Surface Area (calculated - sq ft)	17.79	Phot Water Temperature (Degrees F)	120
? Effective R-value	NaN	? Hot Water Usage (Gallons per Day)	20
	Ene	ergy Use	
424.2		Pleat Delivered in Hot Water (BT	U/hr)
0		PHeat loss through insulation (BT	U/hr)

	Gas vs. Electric Water Heating	
Gas		Electric
0	? Overall Efficiency	0.98
0	? Conversion Efficiency	0.98
NaN BTU/hr	? Power Into Water Heater	432.9 BTU/hr
	Cost	
\$ 0.40 /Therm	? Utility Rates	\$0.17 /kWh
\$ NaN	? Yearly Water Heating Cost	<b>\$</b> 188.809(
	How Does Solar Compare?	
? Sol	ar Water Heater Cost: \$ 12300	Percentage Solar:
NaN years for gas	? Payback Time for Solar System	93.0645/years for electric

More information on solar water heating:

Fact sheet - Solar Water Heaters

Fact sheet - Solar Water Heaters for Swimming Pools


Kids fact sheet - Heat from the Sun

Return to Top of Page

# APPENDIX N

Wind





Wind Resource of New Jersey Mean Annual Wind Speed at 30 Meters

	Generalized Transmi:	ssion Line				
eatures	Category	./•√* 500 kV	Mean Speed at 30 i	m _	13.4 - 14.5	6.0 - 6.5
O City	✓ √ Under 100 kV	•	mph	m/s	14.5 - 15.7	6.5 - 7.0
/ Interstate Highway	Ç Gilder 100 ki	åå 735 kV +	< 10.1	< 4.5	15.7 - 16.8	7.0 - 7.5
	/ 🗸 ` 100 kV-161 kV	.∕•√• Step-Up	10.1 - 11.2	4.5 - 5.0	16.8 - 17.9	7.5 - 8.0
County Boundary	✓ ✓ 230 kV-287 kV	•	11.2 - 12.3	5.0 - 5.5	17.9 - 19.0	8.0 - 8.5
Water Body	•	✓ ✓ DC Line	12.3 - 13.4	5.5 - 6.0	> 19.0	> 8.5
	.∕ •√ • 345 kV			******		



Projection: Tranverse Mercator, UTM Zone 17 WGS84

Spatial Resolution of Wind Resolution of Wind Resolution This map was created by AWS Truewind using the MesoNdap system and historical weather data. Although it is believed to represent an accurate overall picture of the wind energy resource, estimates at any location should be confirmed by measurement.

The transmission line information was obtained by AWS Truewind from the Global Energy Decisions Velocity Suite. AWS does not warrant the accuracy of the transmission line information.

# APPENDIX O

**EPA Portfolio Manager** 



# STATEMENT OF ENERGY PERFORMANCE **Somerdale Municipal Building**

**Building ID: 2562855** 

For 12-month Period Ending: December 31, 20101

Date SEP becomes ineligible: N/A

Date SEP Generated: January 26, 2011

**Facility** 

Somerdale Municipal Building 105 Kennedy Blvd. Somerdale, NJ 08083

**Facility Owner** Borough of Somerdale 105 Kennedy Blvd. Somerdale, NJ 08083

**Primary Contact for this Facility** Victor Cantillo 105 Kennedy Blvd. Somerdale, NJ 08083

Year Built: 1978

Gross Floor Area (ft2): 8,500

Energy Performance Rating<sup>2</sup> (1-100) 32

Site Energy Use Summary<sup>3</sup>

Electricity - Grid Purchase(kBtu) 404,800 Natural Gas (kBtu)4 289.600 Total Energy (kBtu) 694,400

Energy Intensity<sup>5</sup>

Site (kBtu/ft²/yr) 82 Source (kBtu/ft²/yr) 195

Emissions (based on site energy use) Greenhouse Gas Emissions (MtCO<sub>2</sub>e/year) 77

**Electric Distribution Utility** 

Public Service Elec & Gas Co

**National Average Comparison** 

National Average Site EUI 68 National Average Source EUI 162 % Difference from National Average Source EUI 20% **Building Type** Office Stamp of Certifying Professional

Based on the conditions observed at the time of my visit to this building, I certify that the information contained within this statement is accurate.

## Meets Industry Standards<sup>6</sup> for Indoor Environmental Conditions:

Ventilation for Acceptable Indoor Air Quality N/A Acceptable Thermal Environmental Conditions N/A Adequate Illumination N/A **Certifying Professional** 

1. Application for the ENERGY STAR must be submitted to EPA within 4 months of the Period Ending date. Award of the ENERGY STAR is not final until approval is received from EPA.

1. Application for the ENERGY STAK must be submitted to EPA within 4 months of the Penote Lending date. Award of the ENERGY STAK is not that until approval is received from EPA 2. The EPA Energy Performance Rating is based on total source energy. A rating of 75 is the minimum to be eligible for the ENERGY STAR.
3. Values represent energy consumption, annualized to a 12-month period.
4. Natural Gas values in units of volume (e.g. cubic feet) are converted to kBtu with adjustments made for elevation based on Facility zip code.
5. Values represent energy intensity, annualized to a 12-month period.
6. Based on Meeting ASHRAE Standard 62 for ventilation for acceptable indoor air quality, ASHRAE Standard 55 for thermal comfort, and IESNA Lighting Handbook for lighting quality.

The government estimates the average time needed to fill out this form is 6 hours (includes the time for entering energy data, Licensed Professional facility inspection, and notarizing the SEP) and welcomes suggestions for reducing this level of effort. Send comments (referencing OMB control number) to the Director, Collection Strategies Division, U.S., EPA (2822T), 1200 Pennsylvania Ave NW, Washington, D.C. 20460.

# ENERGY STAR® Data Checklist for Commercial Buildings

In order for a building to qualify for the ENERGY STAR, a Professional Engineer (PE) or a Registered Architect (RA) must validate the accuracy of the data underlying the building's energy performance rating. This checklist is designed to provide an at-a-glance summary of a property's physical and operating characteristics, as well as its total energy consumption, to assist the PE or RA in double-checking the information that the building owner or operator has entered into Portfolio Manager.

Please complete and sign this checklist and include it with the stamped, signed Statement of Energy Performance. NOTE: You must check each box to indicate that each value is correct, OR include a note.

CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	V
Building Name	Somerdale Municipal Building	Is this the official building name to be displayed in the ENERGY STAR Registry of Labeled Buildings?		
Туре	Office	ls this an accurate description of the space in question?		
Location	105 Kennedy Blvd., Somerdale, NJ 08083	ls this address accurate and complete? Correct weather normalization requires an accurate zip code.		
Single Structure	Single Facility	Does this SEP represent a single structure? SEPs cannot be submitted for multiple-building campuses (with the exception of acute care or children's hospitals) nor can they be submitted as representing only a portion of a building		
Municipal Building (Of				
CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	V
Gross Floor Area	8,500 Sq. Ft.	Does this square footage include all supporting functions such as kitchens and break rooms used by staff, storage areas, administrative areas, elevators, stairwells, atria, vent shafts, etc. Also note that existing atriums should only include the base floor area that it occupies. Interstitial (plenum) space between floors should not be included in the total. Finally gross floor area is not the same as leasable space. Leasable space is a subset of gross floor area.		<b>1</b> 23.2
Weekly operating hours	46 Hours	Is this the total number of hours per week that the Office space is 75% occupied? This number should exclude hours when the facility is occupied only by maintenance, security, or other support or facilities with a schedule that varies during the year, "operating hours/week" refers to the total weekly hours for the schedule most often followed.		
Workers on Main Shift	15	Is this the number of employees present during the main shift? Note this is not the total number of employees or visitors who are in a building during an entire 24 hour period. For example, if there are two daily 8 hour shifts of 100 workers each, the Workers on Main Shift value is 100. The normal worker density ranges between 0.3 and 5.3 workers per 1000 square feet (92.8 square meters)		
Number of PCs	20	is this the number of personal computers in the Office?		
Percent Cooled	50% or more	Is this the percentage of the total floor space within the facility that is served by mechanical cooling equipment?		
Percent Heated	50% or more	Is this the percentage of the total floor space within the facility that is served by mechanical heating equipment?		

# ENERGY STAR® Data Checklist for Commercial Buildings

# Energy Consumption

Power Generation Plant or Distribution Utility: Public Service Elec & Gas Co

Me	eter: Electricity (kWh (thousand Watt-ho Space(s): Entire Facility Generation Method: Grid Purchase	urs))
Start Date	End Date	Energy Use (kWh (thousand Watt-hours)
12/01/2010	12/31/2010	12,000.00
11/01/2010	11/30/2010	12,000.00
10/01/2010	10/31/2010	8,560.00
09/01/2010	09/30/2010	11,840.00
08/01/2010	08/31/2010	12,720.00
07/01/2010	07/31/2010	13,920.00
06/01/2010	06/30/2010	10,960.00
05/01/2010	05/31/2010	7,360.00
04/01/2010	04/30/2010	7,360.00
03/01/2010	03/31/2010	6,800.00
02/01/2010	02/28/2010	7,120.00
01/01/2010	01/31/2010	8,000.00
Electricity Consumption (kWh (thousand Wa	tt-hours))	118,640.00
Electricity Consumption (kBtu (thousand Btu	1))	404,799.68
		404,799.68
Total Electricity (Grid Purchase) Consumptions this the total Electricity (Grid Purchase) co	on (kBtu (thousand Btu))	
Electricity Consumption (kBtu (thousand Btu Total Electricity (Grid Purchase) Consumptions Is this the total Electricity (Grid Purchase) co Electricity meters?	on (kBtu (thousand Btu))	404,799.68
Total Electricity (Grid Purchase) Consumptions this the total Electricity (Grid Purchase) coelectricity meters?	on (kBtu (thousand Btu))	404,799.68
Total Electricity (Grid Purchase) Consumptions the total Electricity (Grid Purchase) coelectricity meters?	on (kBtu (thousand Btu)) onsumption at this building including all Meter: Natural Gas (therms)	404,799.68
Total Electricity (Grid Purchase) Consumptions this the total Electricity (Grid Purchase) considered the Electricity meters?  Fuel Type: Natural Gas	Meter: Natural Gas (therms) Space(s): Entire Facility	404,799.68
Total Electricity (Grid Purchase) Consumptions this the total Electricity (Grid Purchase) considered the Electricity meters?  Fuel Type: Natural Gas  Start Date	Meter: Natural Gas (therms) Space(s): End Date	Energy Use (therms)
Fotal Electricity (Grid Purchase) Consumptions this the total Electricity (Grid Purchase) considered the Electricity meters?  Fuel Type: Natural Gas  Start Date  12/01/2010	Meter: Natural Gas (therms) Space(s): Entire Facility End Date 12/31/2010	Energy Use (therms) 361.00
Fuel Type: Natural Gas  Start Date 12/01/2010 11/01/2010	Meter: Natural Gas (therms) Space(s): Entire Facility End Date 12/31/2010 11/30/2010	### ### ##############################
Fotal Electricity (Grid Purchase) Consumptions this the total Electricity (Grid Purchase) considered and the Electricity meters?  Fuel Type: Natural Gas  Start Date  12/01/2010  11/01/2010	Meter: Natural Gas (therms) Space(s): Entire Facility End Date 12/31/2010 11/30/2010	### ### ##############################
Fotal Electricity (Grid Purchase) Consumptions this the total Electricity (Grid Purchase) consumptions the total Electricity (Grid Purchase) considered the Electricity meters?  Start Date  12/01/2010  11/01/2010  09/01/2010	Meter: Natural Gas (therms) Space(s): Entire Facility End Date 12/31/2010 11/30/2010 09/30/2010	### ##################################
Start Date 12/01/2010 09/01/2010 08/01/2010	Meter: Natural Gas (therms) Space(s): Entire Facility  End Date  12/31/2010  11/30/2010  09/30/2010  08/31/2010	### ##################################
Total Electricity (Grid Purchase) Consumptions this the total Electricity (Grid Purchase) considerable states and the states of	Meter: Natural Gas (therms) Space(s): Entire Facility End Date 12/31/2010 11/30/2010 09/30/2010 08/31/2010 07/31/2010	### ##################################
Total Electricity (Grid Purchase) Consumptions this the total Electricity (Grid Purchase) consumptions this the total Electricity (Grid Purchase) consumptions that the total Electricity (Grid Purcha	Meter: Natural Gas (therms) Space(s): Entire Facility  End Date  12/31/2010  11/30/2010  09/30/2010  08/31/2010  07/31/2010  06/30/2010	### ##################################

02/01/2010	02/28/2010	724.00
01/01/2010	01/31/2010	797.00
Natural Gas Consumption (therms)		2,896.00
Natural Gas Consumption (kBtu (thousand Btu	a))	289,600.00
Total Natural Gas Consumption (kBtu (thousa	nd Btu))	289,600.00
Is this the total Natural Gas consumption at th	is building including all Natural Gas meters?	
Additional Fuels		
Do the fuel consumption totals shown above repre Please confirm there are no additional fuels (distric		889
On-Site Solar and Wind Energy		
Do the fuel consumption totals shown above include your facility? Please confirm that no on-site solar of list. All on-site systems must be reported.		Recei.
Certifying Professional (When applying for the ENERGY STAR, the Certif	ying Professional must be the same PE or RA tha	at signed and stamped the SEP.)
Name:	Date:	
Signature:		
Signature is required when applying for the ENERGY STAR.		

# FOR YOUR RECORDS ONLY. DO NOT SUBMIT TO EPA.

Please keep this Facility Summary for your own records; do not submit it to EPA. Only the Statement of Energy Performance (SEP), Data Checklist and Letter of Agreement need to be submitted to EPA when applying for the ENERGY STAR.

Facility
Somerdale Municipal Building
105 Kennedy Blvd.
Somerdale, NJ 08083

Facility Owner
Borough of Somerdale
105 Kennedy Blvd.
Somerdale, NJ 08083

Primary Contact for this Facility Victor Cantillo 105 Kennedy Blvd. Somerdale, NJ 08083

# **General Information**

Somerdale Municipal Building	
Gross Floor Area Excluding Parking: (ft²)	8,500
Year Built	1978
For 12-month Evaluation Period Ending Date:	December 31, 2010

**Facility Space Use Summary** 

Municipal Bu	ilding
Space Type	Office
Gross Floor Area(ft²)	8,500
Weekly operating hours	46
Workers on Main Shift	15
Number of PCs	20
Percent Cooled	50% or more
Percent Heated	50% or more

**Energy Performance Comparison** 

	Evaluatio .	n Periods		Comparis	sons
Performance Metrics	Current (Ending Date 12/31/2010)	Baseline (Ending Date 11/30/2010)	Rating of 75	Target	National Average
Energy Performance Rating	32	34	75	N/A	50
Energy Intensity					
Site (kBtu/ft²)	82	79	50	N/A	68
Source (kBtu/ft²)	195	190	120 N/A		162
Energy Cost					
\$/year	\$ 20,874.67	\$ 22,074.39	\$ 12,832.98	N/A	\$ 17,350.84
\$/ft²/year	\$ 2.46	\$ 2.46 \$ 2.60		N/A	\$ 2.04
Greenhouse Gas Emissions					
MtCO <sub>2</sub> e/year	77	75	47	N/A	64
kgCO <sub>2</sub> e/ft²/year	9	9	6	N/A	7

More than 50% of your building is defined as Office. Please note that your rating accounts for all of the spaces listed. The National Average column presents energy performance data your building would have if your building had an average rating of 50.

- o This attribute is optional.
- d A default value has been supplied by Portfolio Manager.

# Statement of Energy Performance

2010

Somerdale Municipal Building 105 Kennedy Blvd. Somerdale, NJ 08083

Portfolio Manager Building ID: 2562855

The energy use of this building has been measured and compared to other similar buildings using the Environmental Protection Agency's (EPA's) Energy Performance Scale of 1–100, with 1 being the least energy efficient and 100 the most energy efficient. For more information, visit energystar.gov/benchmark.

This building's score

32

1 50 100
Least Efficient Average Most Efficient

This building uses 195 kBtu per square foot per year.\*

\*Based on source energy intensity for the 12 month period ending December 2010

Buildings with a score of 75 or higher may qualify for EPA's ENERGY STAR.

I certify that the information contained within this statement is accurate and in accordance with U.S. Environmental Protection Agency's measurement standards, found at energystar.gov

Date of certification



Date Generated: 01/28/2011

# APPENDIX P

**Building Summaries and ROI Calculation** 

# Somerdale, NJ Energy Audit CHA #22424

Engineer: Matt Pittinger

Utility	/ Costs	Yearly Usage	MTCDE
\$ 0.174	\$/kWh blended		0.00042021
\$ 0.125	\$/kWh supply	117,820	0.00042021
\$ 12.99	\$/kW	41.6	0
\$ 1.36	\$/Therm	2,896	0.00533471
\$ 10.44	\$/kgals	58	0

Somerdale Municipal Building

21%

36%

3%

% of Existing 21%

	Item			Sa	vings			Cost	Simple	1	Life		Sin	nple Projecte	d Lifetime Savi	ngs		ROI
		kW	kWh	therms	cooling kWh	kgal/yr	\$ \$	1	Payback	MTCDE	Expectancy	kW	kWh	therms	cooling kWh	kgal/yr	\$	
	<u>Mechanical</u>	1																
ECM-1	Lighting Replacements	2.1	7296	0.0	0.0	0.0	\$ 1,243	\$ 2,587	2.1	3.1	15	31.6	109441	0	0	0	\$ 18,642	6.2
ECM-2	Install Lighting Controls	0.0	12293	0.0	0.0	0.0	\$ 1,542	\$ 5,029	3.3	5.2	15	0.0	184401	0	0	0	\$ 32,074	5.4
ECM-3	Lighting Replacements with Controls	2.1	19223	0.0	0.0	0.0	\$ 2,738	\$ 7,759	2.8	8.1	15	31.6	288345	0	0	0	\$ 41,076	4.3
ECM-4	Replace Electric DHW Heater with On Demand Gas	4.5	4183	-95.2	0.0	0.0	\$ 1,096	\$ 4,202	3.8	1.3	13	58.5	54382	-1237	0	0	\$ 14,251	2.4
ECM-5	Temperature Setback	0.0	0	850.3	1122	0.0	\$ 1,354	\$ 507	0.4	5.0	15	0.0	16833	12754	16833	0	\$ 23,243	44.8
ECM-6	Dual Flush Toilets	0.0	0	0.0	0.0	32.0	\$ 335	\$ 3,961	11.8	0.0	15	0.0	0	0	0	481	\$ 5,021	0.3
ECM-7	Install Storm Windows in Courtroom	0.0	0	107.4	10.3	0.0	\$ 148	\$ 1,469	9.9	0.6	25	0.0	0	2686	258	0	\$ 3,706	1.5
ECM-8	Increase Wall Insulation in Courtroom	0.0	55	148	0.0	0.0	\$ 212	\$ 3,913	18.5	0.8	24	0.0	1313	3558	. 0	0	\$ 5,079	0.3
ECM-9	Replace Court Office RTU with More Efficient Unit	0	717	32	1,854	0	\$ 490	\$ 11,320	23.1	1.2	15	0.0	10754	476	27809	0	\$ 7,357	-0.4
	Tota	1 9	24,178	1,043	2,986	32												

55%

# APPENDIX Q

**Block Load Models** 

# Somerdale, NJ Energy Audit CHA #22424 Building: Somerdale Municipal Building

# Reconcile Thermal Model - Mayor's Office Wing

Building Footprint Heating Efficiency Cooling Efficiency Internal Gains Unco Internal Gain fa Ave Occ Internal Gai Economizer available

1.45 kW/ton 000 SF 80%

Ex Occupied Cing Temp.
Ex Unoccupied Cing Temp.
Occupied Cooling UA
Unoccupied Cooling UA

72 °F 72 °F (620) btu/hr/°F (473) btu/hr/°F

Ex Occupied Htg Temp.
Ex Unoccupied Htg Temp.
Occupied Heating UA

74 \*F 74 \*F 242 btu/hr/°F 242 btu/hr/°F

Heating and cooling energy are unrelated in this model. If the building being analyzed is not cooled, disregard cooling energy calculations

2	II/DIO FIOR 12	Chlocoupled Colling OA	L (111/010 (C/4)	Onoccupied nearing OA	
al Gain factor	0.4	Cooling Occ Enthalpy Setpoint	26 Btu/lb		
ternal Gain Factor	tor 0.5	Cooling Unocc Enthalpy Setpoint	26 Btu/lb		
r available (Y/N)	Yes				

					_																	_						
		Existing Heating Energy	therms	Σ	0	0	0	0	0	0	0	0	0	0	63	86	117	221	186	97	83	46	19	9	9	0	0	935
		Existing Cooling	Energy kWh	×	0	15	145	450	1,326	1,183	774	200	0	0	0	0	0	0	0	0	0	0		0	0	0	0	4,093
		Necessary Cooling Energy	κw	_	0	15	145	420	1,326	1,183	774	200	125	22	0	0	0	0	0	0	0	0	0	0	0	0	0	4,240
		Available Economizer	Cooling kWh	¥	0	0	0	0	0	0	0	0	621	1,233	0	0	0	0	0	0	0	0	0	0	0	0	0	
		Internal Gain	BTUH	7	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	-2,198	
	Unoccupied	Ventilation	Load BTUH	_	-34,515	-24,653	-20,171	-15,838	-11,953	-8,367	-4,781	2,331	4,124	5,917	7,710	9,503	11,296	13,089	14,882	16,675	18,468	20,260	22,053	23,846	25,639	27,432	29,225	
LOADS		Unoccupled Envelope	_	Ŧ	-14,431	-12,065	669'6-	-7,334	4,968	-2,602	-237	1,571	2,780	3,989	5,197	6,406	7,615	8,823	10,032	11,241	12,449	13,658	14,867	16,075	17,284	18,493	19,701	
EXISTING LOADS		Internal Gain	BTUH	9	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	-10,990	
	Occupied	Ventilation	Load BTUH	L	-34,515	-24,653	-20,171	-15,838	-11,953	-8,367	4,781	2,331	4,124	5,917	7,710	9,503	11,296	13,089	14,882	16,675	18,468	20,260	22,053	23,846	25,639	27,432	29,225	
		Envelope Load	BTCH .	w	-18,906	-15,807	-12,707	809'6-	-6,509	-3,409	-310	1,571	2,780	3,989	5,197	6,406	7,615	8,823	10,032	11,241	12,449	13,658	14,867	16,075	17,284	18,493	19,701	
		Unoccupled Equipment Bin	Hours	٥	0	7	25	92	363	420	482	620	673	436	443	444	476	743	533	243	183	6	34	16	6	0	0	6,361
		Occupied Equipment Bin	Hours	ပ	0	-	6	36	137	170	182	234	254	164	167	167	180	280	201	94	69	8	13	9	4	0	0	2,399
		Total Bin	Hours	œ	0	ო	34	131	200	620	664	854	927	009	610	611	929	1,023	734	334	252	125	47	22	13	0	0	8,760
		Avg Outdoor	Air Enthalpy		49.1	42.5	39.5	36.6	9 <u>.</u>	34.6	29.2	27.0	24.5	21.4	18.7	16.2	14.4	12.6	10.7	8.8	6.9	o o	£.4	2.6	0.1	0.0	-1.5	
		Avg Outdoor Air Temp.	Bins %	4	102.5	97.5	92.5	87.5	82.5	77.5	72.5	67.5	62.5	57.5	52.5	47.5	42.5	37.5	32.5	27.5	22.5	17.5	12.5	7.5	2.5	-2.5	-7.5	TOTALS

332 cfm 1,00 0 cfm 332 cfm 3,000 cfm

Overheat Ventilation Factor
Additional ventilation to offset overheat
Existing Building Ventilation & Inflitration (unocc)
Economizer Ventilation (from AHU's)

Existing Building Ventilation & Infiltration (occ)

Energy Use Indices (calculated)

Base Case 935 Heating

The second secon	Base Case	4,093	
		Cooling	

	HEAT G/	AIN/LOSS WORKSHEET	
lame: Name	Somerdale, NJ Energy Audit Somerdale, NJ Somerdale Municipal Büllding	Project No.: CHA #22424 Site Elevation: 80 Feet Specific Volum Date: 12/06/10	ne 14.00]CF/#
r: /Facility Desi	Mayor's Office Wing		
Summer De	gn DB Temperature 10 *F sign DB Temperature 93 *F sign WB Temperature 73 *F mildity Ratio 0.0121 ##	Indoor Winter Design DB Temperature Indoor Summer Design DB Temperature Indoor Summer Design WB Temperature Indoor Air (70°F) Humidity Ratio	74 *F 72 *F 60 *F 0.0079 ##
	PTIONS (Descriptions are from Interior to Exterior)		
elect One - T	ype X)  Steel Siding, 4" Insulation, Steel Siding Plaster or Gypsum, frame construction, 5" Insulation, 1" stucco  4" WH CMU, 1" Insulation, Finished Exterior	R Value Wall Type 15.2 1 18.22 1 5.2 2	
	Plaster or Gypsum, frame construction, 3" Insulation, 8" EW CM 4" Face Brick, 2" Concrete, 1" Insulation, Exterior Finish 4" Face Brick, 4" Concrete, 1" Insulation, Exterior Finish Interior Finish, 2" Insulation, 3" CMU, 4" Face Brick	U 7.8 5 5.1 12 4.0 11 10.9 16	
	Finished Surface, 8" LW CMU (filled), Air Space, 4" Face Brick Stucco or Gypsum, 2.5" Insul, Face Brick 4" Block, 1" insulation, 8" Block U value calculator	11.1 16 14.3 10 19.9 16	
elect One)		R Value Roof Type	E. Symples Characteristics
	Tectum Deck, 3.3" Insul., BU Roof Steel Deck, 5" Insul., BU Roof Attic Roof with 6" Insul.	13.0 1 18.2 1 25.0 4	
	4" HW Concrete Deck, BU Roof Geiling, 3" Insulation, 4" Concrete Deck, BU Roof	25.0 4 2.7 2 14.9 4	
	Celling, 4" Concrete Deck, 3" Insulation, BU Roof Celling, 4" Concrete Deck, 6" Insulation, BU Roof	18.5 13 21.7 14	
	Geiling, Wood Deck, 6" Insulation, Felt & Membrane Wood Deck, 6" insulation, Felt & Membrane	22.7 10 18.0	
х	U value calculator	21.8	
(Select One	Aluminum Frame, 1/8" SP Glazing	U Value 1.05	Flat Glass Flat Glass (e=.6)
	Aluminum Frame, 1/4" DP Glazing Aluminum Frame, 3/16" DP Glazing	0.60 0.62	Flat Glass (e=0.4) Flat Glass (e=0.2)
X	Aluminum Frame, 1/2° DP Glazing Skylights Other	0.50 0.90	Double Glaze (3/16 in air) Double Glaze (1/4 in air) Double Glaze (1/2 in air)
G CHARACT	ERISTICS  2,000 SF		Double Glaze (e=6) Double Glaze (e=0.4) Double Glaze (e=0.2) Triple Glaze (1/4 in air)
d Area	2,000 SF	Return Plenum? n	Triple Glaze (1/2 in air)
	Gross Average Wall Wall Height Length	The state of the s	Door Net Wall Area Area
posure osure	69 Ft. 11.0 Ft 29 Ft 11.0 Ft	8.0 Ft 48 SF 8.0 Ft 36 SF	42 SF 669 SF 21 SF 262 SF
oposure posure	0 FL 0.0 Ft 0.0 Ft 0.0 Ft	8.0 Ft 0 SF 8.0 Ft 0 SF	0 SF 0 SF 0 SF 0 SF
d Forced Ver	ntilation 158 cfm 9.5 AC/hr		

	TEA	T GAIN/LOSS WORKSHEET		
n Somer 3 Name Somer	dale, NJ Energy Audit dale, NJ dale Municipal Building	Project No.: CHA #22424 Site Elevation: 80 Date: 12/06/10	Specific Volume	14.00 CF/#
r: <u> Matt P</u> //Facility Designation	PANALE MEDICAL PROPERTY OF THE PARALEST OF THE			
	TO THE ROOM - SENSIBLE			
GAINS	TO THE ROOM - SERGIBLE			
WS	AREA SHGF Shi	Cooling ade Coef Load Factor	Solar Heat Gain	
xposure posure	36 216 btu/h/sf	0.8 0.75 Glass Type C 0.8 0.31 Glass Type C 0.8 0.58 Glass Type C	1,094 Btu/hr 1,928 Btu/hr	
xposure posure	0 109 btu/h/sf 0 216 btu/h/sf	0.8 0.58 Glass Type C 0.8 0.29 Glass Type C	0 Btu/hr 0 Btu/hr	3,023 Btu/h
CTION	NET. Cooling			
	AREA U-VALUE Load Temp. (SF) Dif.	Return Air Factor	Room Heat Gain	
kposure posure xposure	462 0.08 20 °F 175 0.08 39 °F 0 0.08 27 °F	1.0 1.0 1.0	742 Btu/hr 548 Btu/hr 0 Btu/hr	
posure	0 0.08 <u>22 °F</u> 2,000 0.05 <u>73 °F</u>	1.0 1.0	0 Btu/hr 6,750 Btu/hr	
ation	84 0.50 21 °F 63 0.14 27 °F 2,000 0.14 0 °F		865 Btu/hr 238 Btu/hr 0 Btu/hr	
	2,000 0.04 0 °F		0 Btu/hr 0 Btu/hr	
AL HEAT GAINS (all I	loads below are based on Occupied Periods)		Room Heat Gain	9,142 Btu/h
	1.53     w/sf x     2,000 Occ Area =       0.20     w/sf x     2,000 Occ Area =	3.1 kW x 3.4x 1.0 RAF = 0.4 kW x 3.4x 1.0 RAF =	10,444 Btu/h 1,365 Btu/h	
er Work Stations ent	5 people x 255 btu/person x 10 Units x 1.5 kW x 3.413 =	75% time in space = 120 W/Unit x 3414 =	956 Btu/h 4,096 Btu/h 5,120 Btu/h	
	Marie Carlos		0 Btu/h	21,980 Btu/h
ATION AND INFILTRA	Infiltration Factor Perimeter Ratio  0.13 CFM/SF	Coef Temp. Diff. 1.04 21 *F	Room Heat Gain	
63 SF s 84 SF	0.25 CFM/LF 0.73 LF/S 0.30 CFM/LF 41.67 LF/S	SF 1.04 21 *F	267 Btu/h 975 Btu/h	
on 158 cfm on 136 cfm	8.2 AC/hr	1.04 21 *F	3,658 Btu/h	6,823 Btu/h
		Company of the compan		
NG HEAT GAINS CTION	TO THE RA PLENUM - SENSIBLE	4,5	950	
	NET Cooling AREA U-VALUE Load Temp.	Return Air Factor	Room Heat Gain	
(posure	(SF) Dif. 207 0.08 20	1.0	332 Btu/hr	
oosure xposure	87 0.08 39 0 0.08 27	1.0 1.0	272 Btu/hr 0 Btu/hr	
posure	0 0.08 22 2,000 0.05 73	1.0 0.0	0 Btu/hr 0 Btu/hr	605 Btu/h
AL HEAT GAINS			•	
	1.53 w/sf x 2,000 Occ Area =	3.1 kW x3413x 0.00 RAF =	0 Btu/h 0 Btu/h	
				0 Btu/h
LE HEAT GAINS - TE		ISIBLE HEAT GAINS - TEMP. INDEPENDENT		

## **HEAT GAIN/LOSS WORKSHEET** Samerdale, NJ Energy Audit Project Name: Project No.: CHA #22424 Somerdale, NJ Somerdale Municipal Building 14.00 CF/# Site Elevation: Feet Specific Volume Location Building Name Date: 12/06/10 Engineer Matt Pittinger **Building/Facility Designation** Mayor's Office Wing LATENT COOLING LOADS Infiltration Humidity Ratio Dif. 0.0042 #/# 0.0042 #/# Infiltration Factor Air Density Room Heat Gain 0.13 CFM/SF 4,629 4,629 Btu/h Walls 2.294 SF 5,857 0.25 CFM/LF Btu/h Doors 63 SF 226 Windows Ventilation 84 SF 0.30 CFM/LF 0.0042 #/# Btu/h 4,629 825 0.0042 #/# 158 cfm 4,629 3,093 Btu/h 0.75 time in space 250 Btu/hr/person 938 Btu/h People 5 people 10,938 Btu/h **Cooling Load Summary** Sensible Latent Total 19,592 10,938 30,530 Temperature Dependent Gains Temperature Indep. Gains 21,980 21,980 SHR= 0.79 Total 41,573 10,938 52,511 **Building Cooling Load** 4.4 Tons at 457 SF/Ton Building Air Flow to Condition Space based on a 12\*F Temp Rise is 3,271 CFM 1.64 CFM/sf HEATING CALCULATION CONDUCTION NET Heating U-VALUE Room Heat Gain AREA Load Temp. (SF) 669 Dif. 80.0 64 3,436 Btu/h North Exposure East Exposure 262 80.0 64 1,346 Btu/h South Exposure 80.0 64 Btu/h West Exposure 0.08 64 0 Btu/h Fenestration 84 0.50 64 2,688 Btu/h Roof 2,000 0.05 64 5,918 Btu/h

Ventilation and Infiltration	1				
		Infiltration Factor	Coef	Temp. Differenc	e Air Flow
Walls	931 SF	0.13 CFM/SF	1.04	64	121 cfm
Doors	63 SF	0:25 CFM/LF	1.04	64	12 cfm
Windows	84 SF	0.30 CFM/LF	1.04	64	42 cfm
Ventilation Load	158 cfm		1.04	64	158 cfm
<b>Total Ventilation &amp; Infiltra</b>	ition Load				332 cfm

64

0

63

2,000

2,000

0.14

0.14

0.05

0.04

Doors

Floor

Ceiling

Partition

	23,023 Btu/h
×400	1.7.0

563

1,520

8,085

768

2,806

a

0

Room Heat Gain

Btu/h Btu/h

Btu/h

Btu/h

Btu/h

Btu/h

Btu/h

<b>Building Heating Load</b>		
	38.	493 btu/h
		19.2 btu/sf

# Somerdale, NJ Energy Audit

CHA #22424

**Building: Somerdale Municipal Building** 

Mayor's Wing

<u>Doors</u>						
	Width (ft)		Quantity		Lineal Feet	
North	6.0	7.0	1	42.0	26.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
			Sub-total	42.0	26.0	
East	3.0	7.0	1	21.0 0.0	20.0	
					0.0	
			Sub-total	0.0	20.0	
			Sup-total	21.0	20.0	
South				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
			Sub-total	0.0	0.0	
West				0.0 0.0	0.0	
			Sub-total	0.0	0.0	
			Total	63.0	46.0	LF/SF 0.73

	Walls					
		Width (ft) Height (ft) Quantity		Lineal Feet		
	North	69.0 11.0 1	759.0	160.0		All wall quantities must remain
			0.0 0.0	0.0 0.0	ş	equal to 1
			0.0	0.0		
			0.0	0.0	Ave. height	
		69.0	759.0	160.0	11.0	Average height wall
						automatically linked
	East	29.0 11.0 1	√319.0	80.0		
	Laot	2000	0.0	0.0		
			0.0	0.0		
			0.0	0.0		
			0.0 0.0	0.0 0.0	Ave. height	
		29.0	319.0	80.0	11.0	Average height wall
						automatically linked
						•
	South	0.0 0.0 0	0.0	0.0		
			0.0 0.0	0.0 0.0		
			0.0	0.0		
			0.0	0.0	Ave. height	
		0.0	0.0	0.0	0.0	Average height wall
						automatically linked
	West	0.0 0.0 0	0.0	0.0		
			0.0	0.0		
			0.0	0.0		
			0.0 0.0	0.0	Ave. height	
		0.0	0.0	0.0	Ave. neight 0.0	Average height auto linked to block load sheet
	Windows					
5	North	Width (ft) Height (ft) Quantity 2.0 3.0 8	Area (SF) 48.0	Lineal Feet 80.0		
•	140101	2.0 0.0 0	0.0	0.0		
			0.0	0.0		
			0.0	0.0		
			0.0	0.0		
		Sub-total	0.0 0.0	0.0		
		Sub-total	0.0			
	East		0.0 0.0 48.0	0.0 80.0		
	East	Sub-total 2.0 3.0 6	0.0 0.0 48.0 36.0	0.0 80.0 60.0		
	East		0.0 0.0 48.0 36.0 0.0 0.0	60.0 0.0 0.0		
	East		36.0 0.0 0.0 48.0	60.0 0.0 0.0 0.0		
	East		36.0 0.0 0.0 36.0 0.0 0.0 0.0	60.0 0.0 0.0 0.0 0.0		
	East		36.0 0.0 0.0 36.0 0.0 0.0 0.0 0.0	60.0 0.0 0.0 0.0		
		2.0 3.0 6	0.0 0.0 48.0 36.0 0.0 0.0 0.0 0.0 0.0 36.0	0.0 80.0 60.0 0.0 0.0 0.0 0.0 0.0 60.0		
	East	2.0 3.0 6	0.0 0.0 48.0 36.0 0.0 0.0 0.0 0.0 36.0	0.0 80.0 60.0 0.0 0.0 0.0 0.0 60.0		
		2.0 3.0 6	0.0 0.0 48.0 36.0 0.0 0.0 0.0 0.0 36.0	0.0 80.0 60.0 0.0 0.0 0.0 0.0 60.0		
		2.0 3.0 6	0.0 0.0 48.0 36.0 0.0 0.0 0.0 0.0 36.0	0.0 80.0 60.0 0.0 0.0 0.0 0.0 60.0		
		2.0 3.0 6	0.0 0.0 48.0 36.0 0.0 0.0 0.0 0.0 36.0 0.0 0.0 0.0 0.0	0.0 80.0 60.0 0.0 0.0 0.0 0.0 60.0		
		2.0 3.0 6 Sub-total	0.0 0.0 48.0 36.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 80.0 60.0 0.0 0.0 0.0 60.0 0.0 0.0 0.0		
		2.0 3.0 6	0.0 0.0 48.0 36.0 0.0 0.0 0.0 0.0 36.0 0.0 0.0 0.0 0.0	0.0 80.0 60.0 0.0 0.0 0.0 0.0 60.0		
	South	2.0 3.0 6 Sub-total	0.0 0.0 48.0 36.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 80.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0		
		2.0 3.0 6 Sub-total	0.0 0.0 48.0 36.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 80.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0		
	South	2.0 3.0 6 Sub-total	0.0 0.0 48.0 36.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 80.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0		
	South	2.0 3.0 6 Sub-total	0.0 0.0 48.0 36.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 80.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0		
	South	2.0 3.0 6 Sub-total	0.0 0.0 48.0 36.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 80.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0		
	South	2.0 3.0 6 Sub-total	0.0 0.0 48.0 36.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 80.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	15/05	
	South	2.0 3.0 6 Sub-total	0.0 0.0 48.0 36.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 80.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	LF/SF 1.67	

Building	Volume	Calcu	lator

	Length (ft)			Volume (cf)
10	10	10	1	1,000

# Building: Somerdale Municipal Building Somerdale, NJ Energy Audit CHA #22424

# Reconcile Thermal Model - Court Office

Building Footprint
Heating Efficiency
Cooling Efficiency
Internal Gains
Ave Occ Internal Gain Factor
Ave Occ Internal Gain Factor
Economizer available (YIN)

8.02 btu/h 0.2 0.9

Ex Ocoupled Cing Temp.
Ex Unoccupied Cing Temp.
Occupied Cooling UA
Unoccupied Cooling UA
Cooling Oce Enthalpy Setpoint
Cooling Unocc Enthalpy Setpoint

72 'F 72 'F (562) buuhn'F (451) buuhn'F 26 Btullb 26 Btullb

Ex Occupied Hig Temp.
Ex Unoccupied Htg Temp.
Occupied Heating UA
Unoccupied Heating UA

74 °F 74 °F 249 btu/hr/°F 249 btu/hr/°F

Heating and cooling energy are unrelated in this model. If the building being analyzed is not cooled, disregard cooling energy calculations

					<del></del>																							
		Existing	Heating Energy	Σ	0	0	0	0	0	0	0	0	0	0	0	0	9	179	155	8	72	40	17	6	ဖ	0	0	651
		Existing	Cooling Energy kWh	_	0	15	146	462	1,401	1,310	945	361	303	139	83	24	0	0	0	0	0	0	0	0	0	0	0	5,190
		Necessary	Cooling Energy	_	0	15	146	462	1,401	1,310	945	361	303	139	83	54	0	0	0	0	0	0	0	0	0	0	0	5,190
		Available	. §	L	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
			Internal Gain BTUH	-	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	-3,604	
	Unoccupied		Ventilation	-	-30,629	-21,878	-17,900	-14,055	-10,607	-7,425	-4,243	2,068	3,660	5,251	6,842	8,433	10,024	11,615	13,206	14,797	16,388	17,980	19,571	21,162	22,753	24,344	25,935	
OADS		Unoccupied	Envelope	1	-13,749	-11,495	-9,241	-6,987	-4,733	-2,479	-225	1,619	2,865	4,111	5,357	6,602	7,848	9,094	10,340	11,585	12,831	14,077	15,323	16,568	17,814	19,060	20,306	
EXISTING LOADS			Internal Gain BTUH	O	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	-16,219	
	Occupied		Ventilation	-	-30,629	-21,878	-17,900	-14,055	-10,607	-7,425	4,243	2,068	3,660	5,251	6,842	8,433	10,024	11,615	13,206	14,797	16,388	17,980	19,571	21,162	22,753	24,344	25,935	
			Envelope Load		-17,150	-14,339	-11,527	-8,716	-5,904	-3,093	-281	1,619	2,865	4,111	5,357	6,602	7,848	9,094	10,340	11,585	12,831	14,077	15,323	16,568	17,814	19,060	20,306	
		Unoccupied	Equipment Bin Hours	٥	0	2	25	92	363	420	482	620	673	436	443	444	476	743	533	243	183	91	8	16	6	0	0	6,361
		Occupied	Equipment Bin	U	0	-	6	36	137	170	182	234	254	164	167	167	180	280	201	91	69	뚕	13	9	4	0	0	2,399
			Total Bin Hours	en.	0	ო	8	131	200	620	664	854	927	009	610	611	929	1,023	734	334	252	125	47	22	13	0	0	8,760
			Avg Outdoor		49.1	42.5	39.5	36.6	8,0	31.6	29.2	27.0	24.5	21.4	18.7	16.2	14:4	12.6	70,7	8.6	6.8	6.5	4.1	2.6	10	0:0	-1.5	
		Avg Outdoor	Air Temp. Bins °F	A	102.5	97.5	92.5	87.5	82.5	77.5	72.5	67.5	62.5	57.5	52.5	47.5	42.5	37.5	32.5	27.5	22.5	17.5	12.5	7.5	2.5	-2.5	-7.5	TOTALS

Existing Building Ventilation & Infiltration (occ)
Overheat Ventilation Factor
Odditional ventilation to offset overheat
Existing Building Ventilation & Infiltration (unocc)
Economizer Ventilation (from AHU's)

295 cfm 1.00 0 cfm 295 cfm cfm

Energy Use Indices (calculated)

Cooling

Base Case	651
	Heating

Project No.			HEAT GA	IN/LOSS WO	RKSHEET		
Outdoor Winter Design DB. Temperature	Location Building Name	Somerdale, NJ Somerdale Municipal Building		Site Elevation:	80 Feet	Specific Volume	14.00 CF##
Diction Summer Design DB Temperature	Building/Facility De	signation Court Of	fice				
Walls (Select One - Type X)   R Value   Well Type	Outdoor Summer De Outdoor Summer De	esign DB Temperature esign WB Temperature	93 <b>*F</b> 73 <b>*</b> F	Indoor Summer D Indoor Summer D	esign DB Temperatur esign WB Temperatur		72 *F 60 *F
Steel Sdring, 4" Insulation, Steel Sdring   15.2   1   1   1   1   1   1   1   1   1	ENVELOPE DESCRI	IPTIONS (Descriptions are from I	nterior to Exterior)				
Tectum Deck, 33" Insul, BU Roof		Steel Siding, 4" Insulation, Steel Plaster or Gypsum, frame const 4" WH CMU, 1" Insulation, Finish Plaster or Gypsum, frame const 4" Face Brick, 2" Concrete, 1" In 4" Face Brick, 4" Concrete, 1" In Interior Finish, 2" Insulation, 8" Finished Surface, 8" LW CMU (ff Stucco or Gypsum, 2.5" Insul, F. 4" Block, 1" insulation, 8" Block	ruction, 5" Insulation, 1" stucco hed Exterior ruction, 3" Insulation, 8" LW CMU sulation, Exterior Finish sulation, Exterior Finish CMU, 4" Face Brick illed), Air Space, 4" Face Brick	nata Astronomica Series	15.2 1 18.2 1 5.2 2 7.8 5 5.1 12 4.0 11 10.9 16 11.1 16 14.3 10 19.9 16		
Sieel Deck, 5' Insul, BU Roof	Roofs (Select One)		a.f.	R			
Ceiling, 4" Concrete Deck, 3" Insulation, BU Roof		Steel Deck, 5" Insul., BU Roof	VI		18.2 1		Action of the Control
Celling, Wood Deck, 6" Insulation, Felt & Membrane   22.7   10		Ceiling, 3" Insulation, 4" Concret	e Deck, BU Roof		14.9 4	•	
Wood Deck, 6" insulation, Feit & Membrane   18.0		Ceiling, 4" Concrete Deck, 6" In	sulation, BU Roof		21.7 14		
Windows (Select One)	<u> </u>	Wood Deck, 6" insulation, Felt &			18.0		
Aluminum Frame, 1/4" DP Glazing   0.50   Flat Glass (e=0.4)   0.90	Windows (Select On		an.				Flat Glass 1.05
Skylights   0.90   Double Glaze (1/4 in air)   0.60		Aluminum Frame, 1/4" DP Glazi	ng.		0.60		Flat Glass (e=0.4) 0.90
Double Glaze (e= 6)   0.50	X	Skylights	ng :				Double Glaze (1/4 in air) 0.60
Double Glaze (e=0.2)   0.35					100000000000000000000000000000000000000		Double Glaze (e=.6) 0.50
Gross   Wall   Average Wall   Ceiling   Window   Door   Net Wall Area	Roof Area	1,900 SF					Triple Glaze (1/4 in air) 0.42
Wall Length         Average Wall Length         Ceiling Length         Window Door Area         Net Wall Area           North Exposure         48 Ft         10.0 Ft         8.0 Ft         48 SF         0 SF         43.2 SF           East Exposure         0 Ft         0.0 Ft         8.0 Ft         0 SF         21 SF         -21 SF           South Exposure         0 Ft         0.0 Ft         8.0 Ft         0 SF         0 SF         0 SF	Occupied Area				Keturn Plenum /	nj.	Imple Glaze (1/2 in air) 0.35
North Exposure         48 Ft         10.0 Ft         8.0 Ft         48 SF         0 SF         432 SF           East Exposure         0 Ft         0.0 Ft         8.0 Ft         0 SF         21 SF         -21 SF           South Exposure         0 Ft         0.0 Ft         8.0 Ft         0 SF         0 SF         0 SF		Wall		COMPANY OF THE CONTRACT OF THE	tale data both in the contract and the contract of the contrac		Net Wall Area
South Exposure 0 Ft 0.0 Ft 8.0 Ft 0 SF 0 SF 0 SF		48 Ft					
		0 Ft 39 Ft	0,0 Ft 10,0 Ft		0	SF C	SF 0 SF
Occupied Forced Ventilation 150 cfm 9.0 AC/hr Unoccupied Forced Ventilation 150 cfm 9.0 AC/hr		entilation 150 cfm	9.0 AC/hr				

	H	EAT GAIN/LOSS WORI	KSHEET	
ion Somerda ng Name Somerda	ie Municipal Building	Project No.: CHA #22 Site Elevation: Date: 12	2424 80 Feet Specific Volume 2/06/10	14.00 CF/#
eer: Matt Pitti ing/Facility Designation	nger Court Office			
	OTHE ROOM - SENSIBLE			
R GAINS OWS	AREA SHGF (SF)	Gooling Shade Coef Load	Solar Heat Gain	
Exposure Exposure Exposure	48 38 btu/h/sf 0 216 btu/h/sf 0 109 btu/h/sf	Factor	ype C 0 Btu/hr	
Exposure Exposure DUCTION	24 216 btu/h/sf	0.8 0.29 Glass Ty		2,297 Btu/h
GCTION	NET Cooling AREA U-YALUE Load Temp.	Return Air Fact	or Room Heat Gain	To London 1990 Springer 1990
Exposure	(SF) Dif.  336 0.13 20 *F  -21 0.13 39 *F	1,0	867 Btu/hr -106 Btu/hr	
Exposure Exposure	0 0.13 27 °F 263 0.13 22 °F 1,900 0.05 73 °F	j.0 1.0	0 Btu/hr 746 Btu/hr 6,412 Btu/hr	
tration 9	72 0.50 21*F 42 0.14 27*F 1,900 0.14 0*F 0.05 0*F	\$50 <b>4.0</b> 00.00	742 Btu/hr 158 Btu/hr 0 Btu/hr	
ON HEAT CAINS (All lo	1,900 0.04 0 °F ads below are based on Occupied Period		0 Btu/hr 0 Btu/hr Room Heat Gain	8,820 Btu/h
i 1.	56 w/sf x 1,900 Occ Area = 20 w/sf x 1,900 Occ A	3.0 kW x 3.4x 0.4 kW x 3.4x	1.0 RAF = 10,116 Btu/h 1.0 RAF = 1,297 Btu/h	
e outer Work Stations ment	5 people x 255 btu/person x 5 Units x 1.0 kW x 3.413 =	90% time in space = 120 W/Unit x 3414 =	1,148 Btwh 2,048 Btwh 3,413 Btwh	
ILATION AND INFILTRAT	ION		0 Btu/h	18,021 Btu/h
578 SF 42 SF		1.04 LF/SF 1.04	21 °F 2,013 Btu/h 21 °F 186 Btu/h	
ows 72 SF atlon 150 cfm		LF/SF 1.04 1.04	21 °F 557 Btu/h 21 °F 3,483 Btu/h	6,240 Btu/h
ation 119 cfm	7.1 AC/hr			
LING HEAT GAINS TO DUCTION	O THE RA PLENUM - SENSIBLE		4,950	
	NET Cooling AREA U-VALUE Load Temp. (SF) Dif.	Return Air Fact	or Room Heat Gain	
Exposure Exposure	96 0.13 20 0 0.13 39	10 10	248 Btu/hr 0 Btu/hr	
Exposure Exposure	0 0.13 27 77 0.13 22 1,900 0.05 73	1.0 1.0 0.0	0 Btu/hr 219 Btu/hr 0 Btu/hr	Acc Park
RNAL HEAT GAINS				466 Btú/h
s	56 w/sf x 1,900 Occ Area =	3.0 kW x3413x	0.00 RAF = 0 Btu/h 0 Btu/h	0 Btu/h
IBLE HEAT GAINS - TEM	P. DEPENDENT 2.297	SENSIBLE HEAT GAINS - TEMP. II	NDEPENDENT:	L ODIMS
uction to Room uction to Plenum	8,820 466 6,240	Internal Gains to Plenum	0	

## **HEAT GAIN/LOSS WORKSHEET** Project Name: Project No.: CHA #22424 Site Elevation: 8 Somerdale, NJ Energy Audit Somerdale, NJ Somerdale Münicipal Building Location 80 Building Name Engineer:

Feet Date: 12/06/10

Specific Volume

14.00 CF/#

**Building/Facility Designation** 

Court Office

## LATENT COOLING LOADS

tion

Walls		2.073	
		42	
Doors			
Windo			SF
Ventila			cfm
People			people

Infiltration Factor 0.15 CFM/SF 0.20 CFM/LF 0.20 CFM/LF 0.90 time in space

Humidity Ratio Dif. Air Density 4,629 4,629 0.0042 #/# 0.0042 #/# 0.0042 #/# 0.0042 #/# 250 Btu/hr/person 4,629 4,629

Room Heat Gain 6,107 Btu/h 157 Btu/h 471 Btu/h 2,946 Btu/h 4,125 Btu/h

10,806 Btu/h

**Cooling Load Summary** 

	rature C			ns
200000000000000000000000000000000000000	rature li	ndep. G	ains	
Total				

Sensible 17,823 18,021 35,845 Latent 10,806 10,806

28,629 18,021 46,650

Total

SHR=

0.77

**Building Cooling Load** 

3.9 Tons at

489 SF/Ton

Building Air Flow to Condition Space based on a 12\*F Temp Rise is

2,824 CFM 1.49 CFM/sf

## HEATING CALCULATION

<b>8</b> (6)	NI	818	(88	36 [	83	N
		- W	806	333	200	٥

	¥	NET		Heating
		AREA	U-VALUE	Load Temp.
		(SF)		Dif.
North Exposure		432	0.13	64
East Exposure		-21	0.13	64
South Exposure		0	0.13	64
West Exposure		340	0.13	64
Fenestration		72	0.50	64
Roof		1,900	0.05	64
Doors		42	0.14	64
Ceiling		1,900	0.14	0
Partition		0	0.05	0
Floor		1,900	0.04	19

3,567	Btu/h
-173	Btu/h
0	Btu/h
2,807	Btu/h
2,304	Btu/h
5,622	Btu/h
375	Btu/h
0	Btu/h
0	Btu/h
1,444	Btu/h

Ventilation and Infiltration

		Infiltration Factor	Coef		Temp. Difference	9	Air Flow
Walls	751 SF	0.15 CFN		1.04	64		113 cfm
Doors	42 SF	0.20 CFN		1.04	64		8 cfm
Windows Ventilation Load	72 SF 150 cfm	0.20 CFN	A/LF	1.04 1.04	64 64		24 cfm 150 cfm
Total Ventilation & Infiltrati				1.04	04		295 cfm

ä	534 Btu/h
	1,603 Btu/h
	10,822 Btu/h
×	20,485 Btu/h

Room Heat Gain

**Building Heating Load** btu/h 19.2 btu/sf

# Somerdale, NJ Energy Audit CHA #22424

# Building: Somerdale Municipal Building Court Office Area

n	n	a	rs

	Width (ft)	Height (ft)	Quantity	Area (SF)	Lineal Feet	
North	0.0	0.0		0.0	0.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
			0.1.1.1.1	0.0	0.0	
			Sub-total	0.0	0.0	
East	3.0	7.0	1	21.0	20.0	
•				0.0	0.0	
				0.0	0.0	
	•		Sub-total	21.0	20.0	
South				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
			Sub-total	0.0	0.0	
West	3.0	7.0	1		20.0	
			<u> </u>	0.0	0.0	
			Sub-total	21.0	20.0	
			Total	42.0	40.0	LF/SF 0.95
						-

<u>Walls</u>				
		Area (SF)	Lineal Feet	
North	48.0 10.0 1	480.0 0.0	116.0 0.0	
		0.0	0.0	
		0.0	0.0	
	48.0	0.0 480.0	0.0 116.0	
	,			automatically linked
East	0.0 0.0 0	0.0	0.0	
Last		0.0	0.0	
		0.0	0.0	
		0.0 0.0	0.0 0.0	
		0.0	0.0	
	0.0	0.0	0.0	0.0 Average height wall
				automatically linked
South	0.0 0.0 0	0.0	0.0	
		0.0	0.0	
		0.0 0.0	0.0 0.0	
		0.0	0.0	Ave. height
	0.0	0.0	0.0	
				automatically linked
West	38.5 10.0 1	385.0	97.0	
		0.0 0.0	0.0 0.0	
		0.0	0.0	
		0.0	0.0	Ave. height
	38.5	385.0	97.0	10.0 Average height auto linked to block load sheet
Windows				
N I markle	Width (ft) Height (ft) Quantity 2.0 3.0 8	Area (SF) 48.0	Lineal Feet 80.0	
North	Z:U 3.U 0	0.0	0.0	
		0.0	0.0	
		0.0 0.0	0.0	
		0.0	0.0	
	Sub-total	48.0	80.0	<del>-</del>
East		0.0	0.0	
		0.0 0.0	0.0 0.0	
		0.0	0.0	
		0.0	0.0	
	Sub-total	0.0	0.0	
South		0.0 0.0	0.0 0.0	
		0.0	0.0	
		0.0	0.0	
		0.0 0.0	0.0 0.0	
	Sub-total	0.0	0.0	
		¥		
West	2.0 3.0 4	24.0	40.0	
		0.0	0.0	
		0.0	0.0	
		0.0 0.0	0.0 0.0	
	Sub-total	24.0	40.0	<u> </u>
	Total	72.0	120.0	LF/SF 1.67

Building Volume Calc	<u>ulator</u>		,	
Width(ft)	Length (ft)	Height(ft)	Count	Volume (cf)
10	10	10	1	1,000

Building: Somerdale Municipal Building Somerdale, NJ Energy Audit CHA #22424 Courtroom

# Reconcile Thermal Model

Building Footprint
Heating Efficiency
Cooling Efficiency
Internal Gains
Unco Internal Gain factor
Ave Occ Internal Gain Factor
Economizer available (Y/N)

| KW/fon | KW/fon | 0.2 | 0.8 ş

Ex Occupied Cing Temp.
Ex Unoccupied Cing Temp.
Occupied Cooling UA
Unoccupied Cooling UA
Cooling OA Cooling VA
Cooling One Enthalpy Setpoint
Cooling Unocc Enthalpy Setpoint

70 + 75 + (628) buhn/\* (448) buhn/\* 26 Buh 26 Buh

Ex Occupled Htg Temp.
Ex Unoccupled Htg Temp.
Occupled Heating UA
Unoccupled Heating UA

74 \*F 65 \*F 305 btu/hr/°F 305 btu/hr/°F

Heating and cooling energy are unrelated in this model. If the building being analyzed is not cooled, disregard cooling energy calculations

							EXISTING LOADS	LOADS						
						Occupled			Unoccupied					
Avg Outdoor			Occupled	Unoccupied				Unoccupled			Available	Necessary	Existing	Existing
Air Temp. Bins °F	Avg Outdoor Air Enthalpy	Total Bin Hours	Equipment Bin Hours		Envelope Load BTUH	Ventilation Load BTUH	Internal Gain BTUH	_	Ventilation Load BTUH	Internal Gain BTUH	Economizer Cooling kWh	Cooling Energy kWh	Cooling Energy kWh	Heating Energy therms
∢		m	ပ	۵	ш	LL.	o	Ŧ		,	J		W	Σ
102.5	49.1	0	0	0	-20,343	-30,012	-10,512	-12,313	-30,012	-2,628	0	0	0	0
97.5	42.5	က	0	က	-17,214	-21,437	-10,512	-10,074	-21,437	-2,628	0	9	10	0
92.5	39.5	8	2	32	-14,084	-17,539	-10,512	-7,835	-17,539	-2,628	0	8	06	0
87.5	36,6	131	œ	123	-10,954	-13,772	-10,512	-5,597	-13,772	-2,628	0	274	274	0
82.5	8.0	200	8	470	-7,824	-10,394	-10,512	-3,358	-10,394	-2,628	0	784	784	0
77.5	31.6	620	37	583	4,695	-7,276	-10,512	-1,119	-7,276	-2,628	0	665	999	0
72.5	. 28.2	664	40	624	-1,565	4,157	-10,512	0	0	-2,628	0	209	209	0
67.5	27.0	854	51	803	1,984	2,027	-10,512	0	0	-2,628	0	224	224	0
62.5	24.5	927	55	872	3,509	3,586	-10,512	763	780	-2,628	0	104	104	0
57.5	21.4	009	98	564	5,035	5,145	-10,512	2,289	2,339	-2,628	0	-	-	0
52.5	18.7	610	98	574	6,561	6,704	-10,512	3,815	3,898	-2,628	0	0	0	37
47.5	16.2	611	98	575	8,087	8,263	-10,512	5,340	5,457	-2,628	0	0	0	09
42.5	14.4	929	36	617	9,613	9,822	-10,512	998'9	7,016	-2,628	0	0	0	89
37.5	12.6	1,023	61	962	11,138	11,381	-10,512	8,392	8,575	-2,628	0	0	0	177
32.5	10.7	734	4	069	12,664	12,940	-10,512	9,918	10,134	-2,628	0	0	0	155
27.5	9.8	334	50	314	14,190	14,499	-10,512	11,444	11,693	-2,628	0	0	0	83
22.5	6.8	252	15	237	15,716	16,058	-10,512	12,969	13,252	-2,628	0	0	0	72
17.5	5.5	125	7	118	17,242	17,617	-10,512	14,495	14,811	-2,628	0	0	0	4
12.5	1.4	47	ო	4	18,767	19,176	-10,512	16,021	16,370	-2,628	0	0	0	17
7.5	2.6	22	-	21	20,293	20,735	-10,512	17,547	17,929	-2,628	0	0	0	თ
2.5	0:0	13	-	12	21,819	22,294	-10,512	19,073	19,488	-2,628	0	0	0	9
-2.5	0:0	0	0	0	23,345	23,853	-10,512	20,598	21,047	-2,628	0	0	0	0
-7.5	-1.5	0	0	0	24,871	25,412	-10,512	22,124	22,606	-2,628	0	0	0	0
TOTALS		8,760	521	8,239								2,361	2,361	744

Existing Building Ventilation & Infiltration (occ)
Overheat Ventilation Factor
Additional ventilation to offset overheat
Existing Building Ventilation & Infiltration (unocc)
Economizer Ventilation (from AHU's)

289 cfm 1.00 0 cfm 289 cfm cfm

Energy Use Indices (calculated)

Base Case	744	
	Heating	

Base Case	2,361
<b>60</b>	Cooling

		HEAT G	AIN/LOSS WOI	RKSHEET			
Project Name: Location Building Name Engineer:	Somerdale, NJ:Energy Audit Somerdale, NJ: Somerdale Municipal Building Matt Pittinger		Project No.: CHA 3	22424 80 Feet 12/06/10	Specific Volume	14.00 CF/#	
Building/Facility De	signation Courtroom						
Outdoor Summer D	ign DB Temperature esign DB Temperature esign WB Temperature umidity Ratio	10 *F 93 *F 73 *F 0.0121 ##	Indoor Summer De	ign DB Temperatur esign DB Temperati esign WB Temperat lumidity Ratio	ure	74 *F 70 *F 60 *F 0.0079 #/#	
ENVELOPE DESCR	IPTIONS (Descriptions are from Interio	or to Exterior)		Į.			
Walls (Select One -	Type X)  Steel Siding, 4" Insulation, Steel Sidin Plaster or Gypsum, frame construction, WH CMU, 1" Insulation, Finished Englaster or Gypsum, frame construction 4" Face Brick, 2" Concrete, 1" Insulation Face Brick, 4" Concrete, 1" Insulation frame CMU Finished Surface, 8" LW CMU (filled), Stucco or Gypsum, 2.5" Insul, Face Englaster, 1" Insulation, 8" Block, 1" Insulation, 8" Block	n, 5" Insulation, 1" stucco xterior n, 3" Insulation, 8" LW CM on, Exterior Finish on, Exterior Finish 4" Face Brick Air Space, 4" Face Brick		5.1 1 4.0 1 10.9 1 11.1 14.3 1	1 1 2 5 5 5 12 11 16 6 6 6 10		
Roofs (Select One)	Tectum Deck, 3.3" Insul., BU Roof Steel Deck, 5" Insul., BU Roof Attic Roof with 6" Insul. 4" HW Concrete Deck, BU Roof Ceiling, 3" Insulation, 4" Concrete De Ceiling, 4" Concrete Deck, 3" Insulat Ceiling, 4" Concrete Deck, 6" Insulat Ceiling, Wood Deck, 6" Insulation, Fe Wood Deck, 6" Insulation, Felt & Men U value calculator	on, BU Roof on, BU Roof elt & Membrane	R	21.7	1 1 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4		Ne Storm
Windows (Select Or	Aluminum Frame, 1/8* SP Glazing Aluminum Frame, 1/8* SP Glazing Aluminum Frame, 1/4* DP Glazing Aluminum Frame, 3/16* DP Glazing Aluminum Frame, 1/2* DP Glazing Skylights Other			U Value 1.05 0.60 0.62 0.50 0.90		Flat Glass Flat Glass (e= 6) Flat Glass (e=0.4) Flat Glass (e=0.2) Double Glaze (3/16 in air) Double Glaze (1/4 in air) Double Glaze (1/2 in air) Double Glaze (e= 6)	1.05 1.00 0.90 0.77 0.63 0.60 0.53
BUILDING CHARAC Roof Area Occupied Area	TERISTICS  1,400 SF 1,400 SF			Return Plenum	n7	Double Glaze (e=0.4) Double Glaze (e=0.2) Triple Glaze (1/4 in air) Triple Glaze (1/2 in air)	0.42 0.35 0.42 0.35
North Exposure East Exposure South Exposure West Exposure Occupied Forced Vo		Average Wall Height  0.0 Ft 14.5 Ft 11.5 Ft 11.5 Ft  6.6 AC/hr 6.6 AC/hr	Ceiling Height  8.0 Ft 8.0 Ft 8.0 Ft 8.0 Ft		Area  O SF O SF O SF	M SF 5 0 SF 30	a 0 SF 9 SF 5 SF 9 SF

	H H	EAT GAIN/LOSS WORKSHEET		
ocation Somerda	le Municipal Building	Project No.: GHA #22424 Site Elevation: 80 Feet Date: 12/06/10	Specific Volume	14.00 CF/#
iliding/Facility Designation	Courtroom			
OOLING HEAT GAINS TO	OTHE ROOM - SENSIBLE			
DLAR GAINS	AREA	Cooling		4
NDOWS orth Exposure	(SF) SHGF	Shade Coef Load  Factor	Solar Heat Gain	
orm Exposure st Exposure outh Exposure	0 38 btu/h/sf 0 216 btu/h/sf 40 109 btu/h/sf	0.8 0.75 Glass Type C  0.8 0.31 Glass Type C  0.8 0.58 Glass Type C	0 Btu/hr 0 Btu/hr 2,023 Btu/hr	
st Exposure	40 216 btu/h/sf	0.8 0.29 Glass Type C	2,004 Btu/hr	4,028 Btw/h
NDUCTION	NET Cooling AREA U-VALUE Load Temp. (SF) Dif.	Return Air Factor	Room Heat Gain	S West State of the State of th
th Exposure It Exposure	0 0.16 20.°F 23 0.16 39.°F	1.0	0 Btu/hr 144 Btu/hr	
ith Exposure st Exposure of	200 0.16 27.*F 328 0.16 22.*F 1,400 0.05 73.*F	1.0	867 Btu/hr 1,158 Btu/hr 4,725 Btu/hr	
nestration Ors	80 1.05 23 °F 21 0.14 27 °F		1,898 Btu/hr 79 Btu/hr	
iling rtition or	1,400 0.14 0 *F 0.05 0 *F 1,400 0.04 0 *F		0 Btu/hr 0 Btu/hr	
	ids below are based on Occupied Period		0 Btu/hr Room Heat Gain	8,872 Btu/h
hts 1.	23 w/sf x 1,400 Occ Area =	1.7 kW x 3.4x 1.0 RAF =	5,877 Btu/h	
•	10 w/sf x 1,400 Occ Area = 50 people x 255 btu/person x 1 Units x	0.1 kW x 3.4x 1.0 RAF = 50% time in space = 120 W/Unit x 3414 =	478 Btu/h 6,375 Btu/h 410 Btu/h	
uipment sc.	0.0 kW x 3.413 =		0 Btu/h 0 Btu/h	100 mg/s
NTILATION AND INFILTRATI	ON	atio Coef Temp. Diff.	Room Heat Gain	13,140 Btu/h
ils 551 SF ors 21 SF	0.15 CFM/SF	1.04 23 *F 1.04 23 *F	2,106 Btu/h 153 Btu/h	
ndows 80 SF ntilation 110 cfm	0.40 CFM/LF 1.40	LF/SF 1.04 23 *F 1.04 23 *F	1,141 Btu/h 2,802 Btu/h	
ltration 133 cfm	8.0 AC/hr		Landing Control of the Control of th	6,202 Btu/h
	OTHE RAPLENUM - SENSIBLE	4.9	50.	
INDUCTION	NET Cooling AREA U-VALUE Load Temp.	Return Air Factor	Room Heat Gain	
rth Exposure	(SF) Dif. 0 0.16 20	1.0	0 Btu/hr	
st Exposure uth Exposure ist Exposure	36 0.16 39 105 0.16 27 161 0.16 22	1.0 1.0 1.0	224 Btu/hr 455 Btu/hr 569 Btu/hr	7.740
es(Exposure of	1,400 0.05 73	0.0	0 Btu/hr	1,247 Btu/h
ERNAL HEAT GAINS				
	23 w/sf x 1,400 Occ Area =	1.7 kW x3413x 0.00 RAF =	0 Btu/h 0 Btu/h	
			J Dian	0 Btu/h

	4,028
	8,872
33, 38 s	1,247
	6,202
	20,349

SENSIBLE HEAT GAINS - TEMP. INDEPENDENT Internal Gains to Room Internal Gains to Plenum

	13,	140	00000
100	×(	)	
	87.W)	1000	400
	Mou	ä (in	
	13.	140	

Sub Total

ition Somerdale, N	unicipal Building	102.24		oject No.: CHA #22424 Elevation: 80 Feet Date: 12/06/10	Specific Volume	14.00 CF/#
ling/Facility Designation	Courtroom	2-11				
ENT COOLING LOADS			i de la			
ration  s 1,702 S  s 21 S  lows 80 S  llation 110 d  50 p	F 0.3 F 0.4 Im	Factor 15 CFM/SF 30 CFM/LF 40 CFM/LF 50 time in space	Air Density 4,629 4,629 4,629 4,629	Humidity Ratio Dif. 0.0042 ## 0.0042 ## 0.0042 ## 0.0042 ## 250 Btu/hr/person	Room Heat Gain 5,013 Btu/h 118 Btu/h 880 Btu/h 2,160 Btu/h 6,250 Btu/h	
ling Load Summary	171771		23			14,421 Btu/h
perature Dependent Gains perature Indep. Gains	Sensible 20,34 13,14 33,48	49 40 [	Latent 14,421 14,421	Total 34,770 13,140 47,909	SHR= 0.70	
			OF#			
ing Cooling Load	4.0 Tons at	351	SF/Ton			
			5F/10n	2,574 CFM 1.84 CFM/sf		
			Sir/Ion	2,574 CFM 1.84 CFM/sf		
ing Air Flow to Condition Spac			Sr/Ion			
ling Air Flow to Condition Spac			STION			
ing Air Flow to Condition Space		emp Rise is Heating	ST/10h			Room Heat Gai
ing Air Flow to Condition Space TING CALCULATION DUCTION	e based on a 12°F To NET AREA U-VALUE (SF) 0 0.1	emp Rise is  Heating Load Temp. DH. 16 64	STION			0 Bt
ing Air Flow to Condition Space TING CALCULATION DUCTION Exposure Exposure Exposure Exposure	NET AREA U-VALUE (SF) 0.1 305 0.1	Heating Load Temp. Dif. 16 64 16 64 16 64	STION			0 Bt 604 Bt 3,133 Bt
ing Air Flow to Condition Space TING CALCULATION DUCTION  Exposure Exposure Exposure Exposure Exposure Exposure Exposure Exposure Estation	NET U-VALUE (SF) 0 0.1 305 0.1 489 1.0 1,400 0.0	Heating Load Temp. Dif. 16 64 16 64 16 64 16 64 05 64	ST/ION			0 Bt 604 Bt 3,133 Bt 5,023 Bt 5,376 Bt 4,142 Bt
ing Air Flow to Condition Space TING CALCULATION DUCTION  EXPOSURE	NET U-VALUE (SF) 0 0.1 489 0.1 80 1.400 0.6 21 0.1 1,400 0.1	Heating Load Temp. Dif. 16 64 16 64 16 64 105 64 14 64				0 Bt 604 Bt 3,133 Bt 5,023 Bt 5,376 Bt 4,142 Bt 188 Bt 0 Bt
ing Air Flow to Condition Space TING CALCULATION DUCTION  Exposure Exposure Exposure Exposure exposure stration s ing	NET AREA U-VALUE (SF) 0.1, 305 0.1, 489 0.1, 80 1.400 0.0, 21 0.1	Heating Load Temp. Dif. 16 64 16 64 16 64 05 64 05 64 05 64 14 64 14 64 14 00 05 0				0 Bt 604 Bt 3,133 Bt 5,023 Bt 5,376 Bt 4,142 Bt 188 Bt 0 Bt
TING CALCULATION  Exposure Exposure Exposure Exposure Exposure Exposure Exposure Stration  s	NET U-VALUE (SF) 0 0.1 59 0.1 305 0.1 489 0.1 80 1.0 1.400 0.0 21 0.1 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.	Heating Load Temp. Dif. 16 64 16 64 16 64 105 64 14 00 05 00 04 19	Sr/10n		AirFlow	0 Bth 604 Bth 3,133 Bth 5,023 Bth 5,376 Bth 4,142 Bth 188 Bth 0 Bth 1,064 Bth
TING CALCULATION  DUCTION  Exposure Exposure Exposure Exposure Exposure Stration  s  illation and infiltration  853 S  21 S	NET AREA U-VALUE (SF) 0 0.1 305 0.1 489 0.1 0.1 1,400 0.1 1,400 0.0 1,400 0.	Heating Load Temp. Dif. 16 64 16 64 16 64 16 64 16 64 16 64 17 64 18 64 19 Factor 15 CFM/SF 30 CFM/LF	Coef 1.04 1.04	Temp. Difference 64 64 64	Air Flow 128 cfm 8 cfm	604 Bth 3,133 Bth 5,023 Bth 5,376 Bth 4,142 Bth 188 Bth 0 Bth 1,064 Bth Room Heat Gai 8,545 Btu/h 401 Btu/h
TING CALCULATION  DUCTION  Exposure Exposure Exposure Exposure Stration  s  10  10  10  10  10  10  10  10  10	NET AREA U-VALUE (SF) 0 0.1 59 0.1 305 0.1 489 0.1 1400 0.0 11,400 0.0 11,400 0.0 11,400 0.0 11,400 0.0 15,400	Heating Load Temp. Dif. 16 64 16 64 16 64 105 64 105 64 105 04 114 00 105 00 104 119  Factor 15 CFM/SF	Goef 104	Temp. Difference	Air Flow 128 cfm 6 cfm 45 cfm 110 cfm	0 Btt 604 Btt 3,133 Btt 5,023 Btt 5,376 Btt 4,142 Btt 188 Btt 0 Btt 1,064 Btt  Room Heat Gai 8,545 Btu/h 401 Btu/h 2,993 Btu/h 7,936 Btu/h
s 21 S lows 80 S	NET AREA U-VALUE (SF) 0 0.1 59 0.1 305 0.1 489 0.1 1400 0.0 11,400 0.0 11,400 0.0 11,400 0.0 11,400 0.0 15,400	Heating Load Temp. Dif. 16 64 16 64 16 64 16 64 16 64 16 64 17 64 18 64 19 Factor 15 CFM/SF 30 CFM/LF	Coef 1.04 1.04 1.04	Temp. Difference 64 64 64 64	Air Flow 128 cfm 6 cfm 45 cfm	0   1

# Somerdale, NJ Energy Audit

CHA #22424

**Building: Somerdale Municipal Building** 

Courtroom

<b>Doors</b>						
	Width (ft)	Height (ft)	Quantity	Area (SF)		
North				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
			Sub-total	0.0	0.0	
East	3.0	7.0	1	21.0	20.0	
				0.0	0.0	
				0.0	0.0	
			Sub-total	21.0	20.0	
South				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
			Sub-total	0.0	0.0	
West				0.0	0.0	
				0.0	0.0	
			Sub-total	0.0	0.0	
					Г	LF/SF
			Total	21.0	20.0	0.95
					_	

<u>Walls</u>				
	Width (ft) Height (ft) Quantity	Area (SF)	Lineal Feet	0,000
North		0.0 0.0	0.0 0.0	All wall quantities must remain equal to 1
		0.0	0.0	
		0.0	0.0	
	0.0	0.0	0.0 0.0	Ave. height 0.0 Average height wall
	0.0	0.0	0.0	automatically linked
East	5.5 14.5 1	79.8	40.0	
East	0.0 14.0 1	0.0	0.0	
		0.0	0.0	
		0.0 0.0	0.0 0.0	
		0.0	0.0	Ave. height
	5.5	79.8	40.0	14.5 Average height wall
				automatically linked
South	30.0 11.5 1	345.0	83.0	
		0.0	0.0 0.0	
		0.0 0.0	0.0	
		0.0	0.0	Ave. height
	30.0	345.0	83.0	11.5 Average height wall automatically linked
West	46.0 11.5 1	529.0	115.0	
Wost	40.0 11.0 1	0.0	0.0	
		0.0	0.0	
		0.0 0.0	0.0 0.0	Ava haisht
	46.0	529.0	115.0	Ave. height 11.5 Average height auto linked to block load sheet
1441			•	
Windows	: Width (ft) Height (ft) Quantity	Area (SF)	Lineal Feet	
North	, , , , , , , , , , , , , , , , , , ,	0.0	0.0	
		0.0	0.0	
		0.0 0.0	0.0 0.0	
		0.0	0.0	
	2011	0.0	0.0	
	Sub-total	0.0	0.0	
East		0.0	0.0	
		0.0	0.0	
		0.0 0.0	0.0 0.0	
		0.0	0.0	
		0.0	0.0	
	Sub-total	0.0	0.0	
South	2.0 5.0 4	40.0	56.0	
		0.0 0.0	0.0 0.0	
		0.0	0.0	
		0.0	0.0	
	Sub-total	0.0 40.0	0.0 56.0	
	<u> </u>	40.0	30.0	
West	2.0 5.0 4	40.0	56.0	
		0.0	0.0	
		0.0 0.0	0.0 0.0	
		0.0	0.0	
	Sub-total	40.0	56.0	1505
	Total	80.0	112.0	LF/SF 1.40

Building Volume Calculator
Width(ft) Length (ft) Height(ft) Count Volume (cf)
10 10 10 1 1,000

CHA #22424 Building: Somerdale Municipal Building Somerdale, NJ Energy Audit

Reconcile Thermal Model

Police Area

Unoc Internal Gain factor
Ave Occ Internal Gain Factor
Economizer available (YIN) Building Footprint Heating Efficiency Cooling Efficiency Internal Gains

145 kW/ton 18.810 btu/h ptn/h Ŗ . 0.8 0.8

Ex Occupied Cing Temp.
Ex Unoccupied Cing Temp.
Occupied Cooling UA
Unoccupied Cooling UA
Cooling Occ Enthalpy Setpoint
Cooling Unocc Enthalpy Setpoint

70 °F 70 °F (795) btu/hr/°F (600) btu/hr/°F 26 Btu/lb

Ex Occupled Htg Temp.
Ex Unoccupled Htg Temp.
Occupled Heating UA
Unoccupled Heating UA

72 \*F 72 \*F 327 btu/hr/°F 327 btu/hr/°F

Heating and cooling energy are unrelated in this model. If the building being analyzed is not cooled, disregard cooling energy calculations

			ZG.	<u> </u>	Τ																						_	Γ
		Existing	neating Energy therms	ž	0	0	0	0	0	0	0	0	0	0	0	22	55	135	132	92	69	40	17	6	9	0	0	562
		Existing	Cooling Energy kWh	Æ	0	52	240	111	2,440	2,399	1,899	1,280	961	345	69	0	0	0	0	0	0	0	0	0	0	0	0	10.435
		Necessary	cooling Energy kWh	-1	0	25	240	777	2,440	2,399	1,899	1,280	961	345	69	0	0	0	0	0	0	0	0	0	0	0	0	10.435
			Cooling KWh	¥	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
		1	BTUH	7	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	
	Unoccupled	2010	Load BTUH	_	-42,126	-30,090	-24,619	-19,330	-14,589	-10,212	-5,836	1,970	4,158	6,346	8,535	10,723	12,911	15,100	17,288	19,476	21,665	23,853	26,041	28,230	30,418	32,606	34,795	
OADS		Unoccupied	Load BTUH Lo	I	-19,485	-16,487	-13,490	-10,492	-7,494	-4,497	-1,499	1,472	3,108	4,743	6,379	8,014	9,650	11,285	12,921	14,557	16,192	17,828	19,463	21,099	22,734	24,370	26,006	
EXISTING LOADS		100	BTUH	o	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	-15,848	
	Occupled	Vonelletion	Load BTUH	ш	-42,126	-30,090	-24,619	-19,330	-14,589	-10,212	-5,836	1,970	4,158	6,346	8,535	10,723	12,911	15,100	17,288	19,476	21,665	23,853	26,041	28,230	30,418	32,606	34,795	
			Eliverope Load	ш	-25,853	-21,875	-17,898	-13,921	-9,943	-5,966	-1,989	1,472	3,108	4,743	6,379	8,014	9,650	11,285	12,921	14,557	16,192	17,828	19,463	21,099	22,734	24,370	26,006	
		Unoccupled		۵	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
		Occupied		ပ	0	ო	34	131	200	620	664	854	927	009	610	611	929	1,023	<b>73</b>	334	252	125	47	22	13	0	0	8,760
		T C C C C C C C C C C C C C C C C C C C	Hours	ω	0	ო	35	131	200	620	664	854	927	009	610	611	929	1,023	734	334	252	125	47	55	13	0	0	8,760
		Ava Outdoor	Air Enthalpy		49.1	42.5	39.5	36.6	8. 0.	31.6	29.5	27.0	24.5	21,4	18.7	16.2	14,4	12.6	10.7	8.6	8.9	5.5	4.	2.6	0.	0:0	-1.5	
		Avg Outdoor	Bins F	∢	102.5	97.5	92.5	87.5	82.5	77.5	72.5	67.5	62.5	57.5	52.5	47.5	42.5	37.5	32.5	27.5	22.5	17.5	12.5	7.5	2.5	-2.5	-7.5	TOTALS

Existing Building Ventilation & Infiltration (occ)
Overheat Ventilation Factor
Additional ventilation to offset overheat
Existing Building Ventilation & Infiltration (unocc)
Economizer Ventilation (from AHU's)

Energy Use Indices (calculated)

405 cfm 100 0 cfm 405 cfm

Base Case	10,435
	Cooling

Base Case Heating 562

Base Case	10,435
	Cooling

Base Case	10,435
	Cooling

	HEAT GA	IN/LOSS WORKSHEET	
Project Name: Location Building Name Engineer:	Somerdale, NJ Energy Audit. Somerdale Municipal Building Matt Pittinger	Project No.: CHA #22424 Site Elevation: 80 Date: 12/06/10 Feet Specific Volume	14.00 CF/#
Building/Facility De	Police Police	A CONTROL OF THE CONT	
Outdoor Summer D	sign DB Temperature         10 *F           Design DB Temperature         93 *F           Design WB Temperature         73 *F           Jumidity Ratio         0.0121 ###	Indoor Winter Design DB Temperature Indoor Summer Design DB Temperature Indoor Summer Design WB Temperature Indoor Air (70°F) Humidity Ratio	72 *F 70 *F 60 *F 0.0079 ##
NVELOPE DESCR	RIPTIONS (Descriptions are from Interior to Exterior)		
Valls (Select One - x	Steel Siding, 4* Insulation, Steel Siding Plaster or Gypsum, frame construction, 5" Insulation, 1" stucco 4" WH CMU, 1* Insulation, Finished Extenor Plaster or Gypsum, frame construction, 3" Insulation, 8" LW CMU 4* Face Brick, 2" Concrete, 1" Insulation, Exterior Finish 4* Face Brick, 4" Concrete, 1" Insulation, Exterior Finish Interior Finish, 2" Insulation, 8" CMU, 4* Face Brick Finished Surface, 8" LW CMU (fillied), Air Space, 4" Face Brick Stucco or Gypsum, 2.5" Insul, Face Brick 4" Block, 1" insulation, 8" Block U value calculator	R Value   Wall Type   15.2   1   18.2   1   1   1   1   1   1   1   1   1	
2000	Ceiling, Wood Deck, 6* Insulation, Felt & Membrane Wood Deck, 6* insulation, Felt & Membrane	22.7 18.0	
(indows (Select O	U value calculator  ine)  Aluminum Frame, 1/8* SP Glazing Aluminum Frame, 1/4* DP Glazing Aluminum Frame, 3/16* DP Glazing Aluminum Frame, 1/2* DP Glazing Skylights Other	UValue 1.05 0.80 0.62 0.50 0.90	No Storm   Flat Glass   1.05   Flat Glass (e=.6)   1.00   Flat Glass (e=0.4)   0.90   Flat Glass (e=0.2)   0.77   Double Glaze (3/16 in air)   0.63   Double Glaze (1/4 in air)   0.60   Double Glaze (1/2 in air)   0.53
UILDING CHARAC oof Area ccupied Area	CTERISTICS  2,400 SF 2,400 SF	Return Plenum?n	Double Glaze (e=.6)   0.50
	Gross Average Wall Wall Average Wall Length Height	Ceiling Window Do Height Area Are	Not Wall Area
lorth Exposure ast Exposure outh Exposure Vest Exposure	0 Ft 0.0 Ft 9.9 Ft 76 Ft 11.0 Ft 0.0 Ft 0.0 Ft 12.0 Ft 13.0 Ft	8.0 Ft 0 SF 8.0 Ft 60 SF 8.0 Ft 24 SF 8.0 Ft 0 SF	0 SF 0 SF 0 SF 425 SF 425 SF 770 SF 0 SF 0 SF
Occupied Forced V Unoccupied Forced			

cation Some ilding Name Some	dale, NJ Energy Audit dale, NJ dale Municipal Building ittinger	Project No.: GHA #22424 Site Elevation: 80 Feet Date: 12/06/10	Specific Volume	14.00 CF/#
ilding/Facility Designation		Application of the second of t		
OLING HEAT GAINS	TO THE ROOM - SENSIBLE			
AR GAINS	AREA OUG-	Cooling		
IDOWS	(SF) SHGF Sha	ide Coef Load Factor	Solar Heat Gain	
th Exposure	0 38 btu/h/sf	0.8 0.75 Glass Type C	0 Btu/hr	
st Exposure ith Exposure	60 216 btu/h/sf 24 109 btu/h/sf	0.8 0.31 Glass Type C 0.8 0.58 Glass Type C	3,214 Btu/hr	1000
st Exposure	0 216 btu/h/sf	0.8 0.29 Glass Type C	1,214 Btu/hr 0 Btu/hr	
	18 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1			4,428 Btu/h
NDUCTION			24.0	78 S. S. S.
	NET Cooling AREA U-VALUE Load Temp,	Return Air Factor	Room Heat Gain	
	(SF) Dif.			18
th Exposure	0 0.12 <u>20 *F</u>	1.0	0 Btu/hr	
st Exposure uth Exposure	332 0.12 39 *F	1.0	1,505 Btu/hr	
st Exposure	542 0.12 27 *F 0 0.12 22 *F	1.0 1.0	1,701 Btu/hr 0 Btu/hr	
of .	2,400 0.05 73 *F	1.0	8,100 Btu/hr	
estration	84 0.50 <u>23 *F</u>		949 Btu/hr	
ors ling	42 0.14 27 *F 2.400 0.14 0 *F		158 Btu/hr 0 Btu/hr	
tition	0.05 0 *F	Control of the Contro	0 Btu/hr	
or	2,400 0.04 0 F		0 Btu/hr	
ERNAL HEAT GAINS (all	loads below are based on Occupied Periods)		Room Heat Gain	12,413 Btwh
hts	1.11 w/sf x 2,400 Occ Area =	2.7 kW x 3.4x 1.0 RAF =	9,092 Btu/h	
g Load	0.10 w/sf x 2,400 Occ Area =	0.2 kW x 3.4x 1.0 RAF =	819 Btu/h	
ople mputer Work Stations	5 people x 255 btu/person x 1 Units x	75% time in space = 120 W/Unit x 3414 =	956 Btu/h 410 Btu/h	
ipment	2.5 kW x 3:413 =		8,533 Btu/h	
C.			0 Btu/h	40.040 Dr. D
ITILATION AND INFILTRA	ATION		L	19,810 Btu/h
	Infiltration Factor Perimeter Ratio	Coef Temp. Diff.	Room Heat Gain	
lls 874 SF ors 42 SF	0.15 CFM/SF 0.20 CFM/LF 0.95 LF/S	1.04 23 *F F 1.04 23 *F	3,340 Btu/h 204 Btu/h	
ndows 84 SF	0.20 CFM/LF 0.95 LF/S		713 Btu/h	
tilation 190 cfm		1.04 23 *F	4,841 Btu/h	
	10.0 AC/hr	SUSPENDENCE CONTRACTOR		9,098 Btu/h

	NET AREA (SF)	U-VALUE	Cooling Load Temp. Dif.	Return Air Factor	Room Heat Gain	
North Exposure	0	0.12	20	1.0	0 Btu/hr	
East Exposure	93	0.12	39	1.0	421 Btu/hr	
South Exposure	228	0.12	27	1.0.	715 Btu/hr	100000
Nest Exposure	0	0.12	22	1.0	0 Btu/hr	
Roof	2,400	0.05	73	0.0	0 Btu/hr	
						1,137 Btu/h
NTERNAL HEAT GAINS						
ights	1.11 w/sf x	2,400	Occ Area =	2.7 kW x3413x	0 Btu/h	
Misc.				nt Chaganes - ac	0 Btu/h	
	100					0 Btu/h

SENSIBLE HEAT GAINS - TEMP.	DEPENDENT
Solar	4,428
Conduction to Room	12,413
Conduction to Plenum	1,137
Ventilaton and Infiltration	9,098
Sub Total	27,076

					2.00	١
SENS	IBLE	HEAI	UAI	N5 -		
		4000		22.70		
merr	ıal Gai	ns to	KOO	m 🕦	488 E	
					32000	ļ
Interr	ıal Gai	пѕ то	Hier	ıum		
			AN # 24 H 2	0.000		
			CONTRACTOR OF THE PARTY OF THE	CONTROL	30000	
	82 B. S. S.	300000	AY	32 HW	30530	

Sub Total

IP. INDEP	ENDENT
	19,810
	0
	19,810
in the second	

# HEAT GAIN/LOSS WORKSHEET Project Name: Somerdale, NJ Energy Audif Project No.: CHA #22424 Location Somerdale, NJ Site Elevation: 80 Feet Building Name Somerdale Municipal Building Engineer: Matt Pittinger

#22424 80 Feet Specific Volume 14.00 CF/#

Building/Facility Designation

Police

# LATENT COOLING LOADS

Infil		

				Infiltration I	actor	Air Den	eitu	Humidity I	Fill nites
	75.0°				55,525,735,971,000	Au Dei	747	, iumony ,	vano on
Walls	2.00	2.72	l SF	0.1	5 CFM/SF		4.629	0.0042#/	Ħ
						200			
Doors		4.	2 SF	U.2	O CFM/LF		4,629	0.0042 #/	F
Windo	400	9.	I SF	n c	O CFM/LF		4 629	0 0042 #/	#
			, OI	U.2	.O (O1 1911 E1		4,023	U.UU42 #1	T .
Ventila	tion	190	) cfm	1981 36 4 36 3			4.629	0.0042 #/	#
m					re u i	- XX XX - XX		250 04	

Room Heat Gain 8,015 Btu/h 157 Btu/h 550 Btu/h 3,731 Btu/h 938 Btu/h

13,391 Btu/h

**Cooling Load Summary** 

Temperature Dependent Gai Temperature Indep. Gains			Total 3,391	40,467 19,810	SHR= 0.78
Total	46	,885 1	3,391	60,276	

**Building Cooling Load** 

5.0 Tons at

478 SF/Ton

Building Air Flow to Condition Space based on a 12\*F Temp Rise is

3,652 CFM 1.52 CFM/sf

## HEATING CALCULATION

COL		

	NET		Heating
	AREA (	J-VALUE	Load Temp.
	(SF)		Dif.
North Exposure	0	0.12	62
East Exposure	425	0.12	62
South Exposure	770	0.12	62
West Exposure	0	0.12	62
Fenestration	84	0.50	62
Roof	2,400	0.05	62
Doors	42	0.14	62
Ceiling	2,400	0.14	0
Partition	0	0.05	0
Floor	2,400	0.04	19

		Ga	

200	
0.	Btú/h
3,062	Btu/h
5,548	Btu/h
0	:Btu/h
2,604	Btu/h
 6,879	Btu/h
364	Btu/h
. 0	Btu/h
0	Btu/h
1,824	Btu/h

Ventilation and Infiltration

	Infiltration Factor Coef	Temp. Dil	ference Air Flow
Walls 1,195 SF	0.15 GFM/SF	1.04	62 179 cfm
Doors 42 SF Windows 84 SF	0.20 CFM/LF	1.04	62 8 cfm
Windows 84 SF Ventilation Load 190 cfm	0.20 CFM/LF	1.04 1.04	62 28 cfm 62 190 cfm
Total Ventilation & Infiltration Load		1.01	405 cfm

1,8	312	Btu/h
3233	13,280	Btu/h
120000	27,210	Btu/h

Room Heat Gain 11,600 Btu/h

	Building Heating Load 47,491 btu/h
889	pulled Ti, Ti
	19.8 btu/sf
	19.0 0008

# Somerdale, NJ Energy Audit CHA #22424

# **Building: Somerdale Municipal Building**

Police Area

<u>Doors</u>						
	Width (ft)	Height (ft)	Quantity	Area (SF)	Lineal Feet	
North				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
			Sub-total	0.0	0.0	
East				0.0	0.0	
Last				0.0	0.0	
				0.0	0.0	
	200000000000000000000000000000000000000		Sub-total	0.0	0.0	
	*************	0.0000000000000000000000000000000000000				
South	3.0	7.0	2		40.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
			Sub-total	42.0	40.0	
West				0.0	0.0	
				0.0	0.0	
	<u> </u>	******************************	Sub-total	0.0	0.0	
				0.0	ı	LF/SF
			Total	42.0	40.0	0.95
			Total	72.0	70.0	0.00

<u>Walls</u>				
	Width (ft) Height (ft) Quantity	Area (SF)	Lineal Feet	
North		0.0 0.0	0.0	***************************************
		0.0	0.0 0.0	
		0.0	0.0	
		0.0	0.0	Ave. height
	0.0	0.0	0.0	
				automatically linked
East	27.0 9.0 1	243.0	72.0	
Last	22.0 11.0 1	242.0	66.0	
		0.0	0.0	
		0.0	0.0	
		0.0 0.0	0.0 0.0	
	49.0	485.0	138.0	
		,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,		automatically linked
South	76.0 11.0 1	836.0	174.0	
		0.0 0.0	0.0 0.0	
		0.0	0.0	
		0.0	0.0	
	76.0	836.0	174.0	11.0 Average height wall
			_	automatically linked
West		0.0	0.0	
W OOL		0.0	0.0	
		0.0	0.0	
		0.0	0.0	
		0.0		Ave. height
	0.0	0.0	0.0	0.0 Average height auto linked to block load sheet
Windows	<b>S</b>			
	Width (ft) Height (ft) Quantity	Area (SE)	Lineal Foot	
	width (it) Height (it) Quantity		Lineal Feet	
North	with the ringht the admins	0.0	0.0	
North	vidar (it) Teight (it) Quantity	0.0 0.0	0.0 0.0	
North	vider (it) Teight (it) Quantity	0.0	0.0	
North	vidar (il) Teight (il) Quantity	0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0	
North		0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0 0.0	
North	Sub-total	0.0 0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0	
North		0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0 0.0	
North East		0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0 0.0 0.0	
	Sub-total	0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0 0.0 0.0	
	Sub-total	0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0 0.0 0.0	
	Sub-total	0.0 0.0 0.0 0.0 0.0 0.0 0.0 60.0 0.0	0.0 0.0 0.0 0.0 0.0 0.0 0.0	·
	Sub-total	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	
	Sub-total	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	
East	Sub-total  2.0 3.0 10  Sub-total	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	
	Sub-total .2.0 3.0 10	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	
East	Sub-total  2.0 3.0 10  Sub-total	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	
East	Sub-total  2.0 3.0 10  Sub-total	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	
East	Sub-total  2.0 3.0 10  Sub-total	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	
East	Sub-total  2.0 3.0 10  Sub-total  2.0 3.0 4	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	
East	Sub-total  2.0 3.0 10  Sub-total	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	
East	Sub-total  2.0 3.0 10  Sub-total  2.0 3.0 4	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	
East	Sub-total  2.0 3.0 10  Sub-total  2.0 3.0 4	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	
East	Sub-total  2.0 3.0 10  Sub-total  2.0 3.0 4	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	
East	Sub-total  2.0 3.0 10  Sub-total  2.0 3.0 4	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	
East	Sub-total  2.0 3.0 10  Sub-total  2.0 3.0 4  Sub-total	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	
East	Sub-total  2.0 3.0 10  Sub-total  2.0 3.0 4	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	
East	Sub-total  2.0 3.0 10  Sub-total  2.0 3.0 4  Sub-total	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	

Building Volume Calculator									
Width(ft)	Length (ft)	Height(ft)	Count	Volume (cf)					
10	10	10	1	1,000					

# APPENDIX R

**Equipment Inventory and Lighting** 

Useable Life Expectancy (years) 5 20 15 5 15 55 12 Approximate Age 1.5 12 Tax Offices, 80% gas, 1.48
Fire Marshal kW/ton
8760
Mayor's Wing 80% gas, 1.45
Mayor's Wing 80% gas, 1.45
Police Area kW/ton
8760
Police Area kW/ton
Police Area kW/ton
R760
Police Area kW/ton 82% gas, 1.1 kW/ton cooling Estimated Efficiency Closet Emergency Usage Entire Building 8760 Court Offices, Tax Offices, Fire Marshal 8760 Police Area Operation Hours Areas Served 8760 Police Area Restrooms and Janitor 8760 Courtroom As Needed Cooling
200 Mbtu Heating, 7.5
tons Cooling
120 Mbtu Heating, 4 tons
Cooling
115 Mbtu Heating, 4 tons
Cooling 180 Mbtu Heating, 10 tons 224 Mbtu Heating, 9.5 tons Cooling Capacity/Size 40 Gallon, 4.5 kW 100 kW Equipment Type Packaged RTU Packaged RTU Packaged RTU Packaged RTU Packaged RTU Natural Gas Electric Serial Number FF12007812 4509G40400 0807G21765 444100867L 444100553L 902040358 2024075 48TCED12A2GSA0A0A0 M240S6DS-1NCWW 48TME012-A-501 YSC090A3RHA1PF1 YSC048A3RHA1FF Model No. 48TFE005-A-511 100 RZG Manufacturer Name Bradford White Carrier Kohler Carrier Carrier Trane 1 Trane Q Ą Emergency Generator Description OHW Heater RTU RT Ę M RTU.

# Somerdale Municipal Building CHA Project No. 22424 Existing Lighting

Cost of Electricity:

\$0.125 \$/kWh \$12.99 \$/kW

		EXISTING CONDITIONS								
	Area Description	No. of Fixtures	Standard Fixture Code	NYSERDA Fixture Code	Watts per Fixture	kW/Space	Exist Control	Annual Hours	Retrofit Control	Annual kWh
Field Code	Unique description of the location - Room number/Room name: Floor number (if applicable)		"Lighting Fixture Code" Example 2T 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Fixt No.)	Pre-inst. control device	Estimated annual hours for the usage group	Retrofit control device	(kW/space) * (Annual Hours)
11	Maintenance Closet	1	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	2920	OCC	210
246	Police Bathroom	1	1 Lamp T12	F21SE	26	0.0	SW	2920	OCC	76
13	Police Locker Room	1	S 32 P F 2 (ELE)	F42LL	60	0.1	sw	4380	C-OCC	263
163	Prisoner Processing Room	5	1B 40 R F 2 (MAG)	F42SS	94	0.5	SW	8760	None	4,117
101	Prisoner Processing Room	1	I 40	I40/1	40	0.0	SW	8760	None	350
164	Prisoner Processing Room	1	X 7.0 W I 2	El10/2	20	0.0	Breaker	8760	None	175
18	Perimeter Office	1	T 32 R F 4 (ELE)	F44ILL	112	0.1	SW	2190	OCC	245
87	Gun Cabinet	1	W 32 W F 2 (MAG)	F42LE	71	0.1	SW	2190	OCC	155
13	Interrogation Room	1	S 32 P F 2 (ELE)	F42LL	60	0.1	SW	2600	OCC	156
18	Main Police Hallway	6	T 32 R F 4 (ELE)	F44ILL	112	0.7	SW	2600	None	1,747
71	Main Police Hallway	3	I 60	160/1	60	0.2	SW	2600	None	468
18	Sergeant Office 1	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	SW	4380	OCC	981
18	Sergeant Office 2	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	SW	4380	OCC	981
18	Sergeant Office 3	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	SW	4380	OCC	981
18	Chief's Office	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	SW	4380	OCC	981
18	Storage/ Server Room	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	SW	4380	OCC	981
18	Mayor's Office	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	SW	1460	OCC	327
13	Deputy Treasurer Office	2	S 32 P F 2 (ELE)	F42LL	60	0.1	SW	2190	OCC	263
13	East Offices Hallway	5	S 32 P F 2 (ELE)	F42LL	60	0.3	SW	4380	None	1,314
18	East Offices Hallway	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	SW	4380	None	981
X1	East Offices Hallway	3	X 1.5 W LED	ELED1.5/1	1.5	0.0	Breaker	8760	None	39
18	Server/Storage Room	1	T 32 R F 4 (ELE)	F44ILL	112	0.1	SW	2190	OCC	245
18	Conference Room	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	SW	2190	C-OCC	491
18	Supply Room 1	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	SW	2190	OCC	491
18	CFO's Office	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	SW	2190	OCC	491
18	Municipal Clerk Office	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	SW	2190	OCC	491
13	Supply Room 2	2	S 32 P F 2 (ELE)	F42LL	60	0.1	SW	2190	OCC	263
18	Tax Office	4	T 32 R F 4 (ELE)	F44ILL	112	0.4	SW	2190	C-OCC	981
18	Tax Office Closet	1	T 32 R F 4 (ELE)	F44ILL	112	0.1	SW	2190	OCC	245
	Clerk Office	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	SW	2190	occ	491
11	Men's Restroom		S 34 P F 2 (MAG)	F42EE	72	0.1	SW	8000	C-OCC	576
	Women's Restroom		S 34 P F 2 (MAG)	F42EE	72	0.1	SW	8000	C-OCC	576
	Main Hallway		S 32 P F 2 (ELE)	F42LL	60	0.5	SW	8760	None	4,205

# Somerdale Municipal Building CHA Project No. 22424 Existing Lighting

Cost of Electricity:

\$0.125 \$/kWh \$12.99 \$/kW

		EXISTING CONDITIONS								
	Area Description	No. of Fixtures	Standard Fixture Code	NYSERDA Fixture Code	Watts per Fixture	kW/Space	Exist Control	Annual Hours	Retrofit Control	Annual kWh
Field Code	Unique description of the location - Room number/Room name: Floor number (if applicable)	before the retrofit	"Lighting Fixture Code" Example 2T 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape		Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Fixt No.)	Pre-inst. control device	Estimated annual hours for the usage group	Retrofit control device	(kW/space) * (Annual Hours)
78	Main Hallway	2	EP I 100	1100/1	100	0.2	SW	2080	None	416
13	Small Office to the left of Bathrooms	11	S 32 P F 2 (ELE)	F42LL	60	0.1	SW	4380	OCC	263
185	Courtroom	9	DC 40 W F 4	F44SE	172	1.5	SW	4380	None	6,780
71	Courtroom	3	I 60	160/1	60	0.2	SW	4380	None	788
35	West Offices Hallway	4	T 32 R F 3 (ELE)	F43ILL/2	90	0.4	SW	8760	None	3,154
35	Breakroom	4	T 32 R F 3 (ELE)	F43ILL/2	90	0.4	SW	5000	C-OCC	1,800
18	Bathroom off Breakroom	1	T 32 R F 4 (ELE)	F44ILL	112	0.1	SW	8760	OCC	981
18	Court Office	6	T 32 R F 4 (ELE)	F44ILL	112	0.7	SW	2190	C-OCC	1,472
18	Court Office Storage	1	T 32 R F 4 (ELE)	F44ILL	112	0.1	SW	8760	OCC	981
18	Janitor Closet	1	T 32 R F 4 (ELE)	F44ILL	112	0.1	SW	4380	OCC	491
35	Conference Room	6	T 32 R F 3 (ELE)	F43ILL/2	90	0.5	SW	2190	C-OCC	1,183
78	Conference Room	10	EP I 100	1100/1	100	1.0	SW	624	None	624
18	Construction Office	3	T 32 R F 4 (ELE)	F44ILL	112	0.3	SW	2190	OCC	736
18	Fire Marshall Office	2	T 32 R F 4 (ELE)	F44ILL	112	0.2	SW	2190	OCC	491
18	Tax Assessor Office	1	T 32 R F 4 (ELE)	F44ILL	112	0.1	SW	2190	OCC	245
13	Tax Assossor Office	1	S 32 P F 2 (ELE)	F42LL	60	0.1	SW	2190	occ	131
142	Outdoor Lights	3	MH 100	MH100/1	128	0.4	Photo	4380	None	1,682
142	Outdoor Light	1	MH 100	MH100/1	128	0.1	None	8760	Photo	1,121
	Total	133				12.8				48,676