

**CITY OF BALTIMORE  
DEPARTMENT OF PUBLIC WORKS  
OFFICE OF ENGINEERING AND CONSTRUCTION**

**ADDENDUM NO. 2**

**April 27, 2026**

**FOR DRAWING, SPECIFICATIONS, PROPOSAL, CONTRACT AND BOND**

**FOR  
WATER CONTRACT NO. 1454 - URGENT NEED WATER INFRASTRUCTURE  
REHABILITATION AND IMPROVEMENTS PHASE I-FY27**


**FOR THE MAYOR AND CITY COUNCIL OF BALTIMORE**

---

TO BIDDERS: PLEASE ATTACHED TO YOUR CONTRACT DOCUMENTS. THIS ADDENDUM IS HEREBY MADE A PART OF THE CONTRACT DOCUMENTS ON WHICH THE CONTRACT WILL BE BASED AND IS ISSUED TO MODIFY, EXPLAIN AND/OR CORRECT THE ORIGINAL DRAWINGS AND SPECIFICATIONS. PLEASE ACKNOWLEDGE THIS ADDENDUM ON THE BID OR PROPOSAL PAGE WHERE INDICATED. IF THIS DOCUMENT HAS BEEN RECEIVED VIA EMAIL, A CONFIRMATION EMAIL MUST BE SENT BY THE BIDDER WITHIN 24 HOURS CONFIRMING RECEIPT OF THE ADDENDUM TO [DPWCONTRACTADMIN@BALTIMORECITY.GOV](mailto:DPWCONTRACTADMIN@BALTIMORECITY.GOV). IF EMAIL ACKNOWLEDGMENT IS NOT RECEIVED BY DPW, YOUR BID MAY BE REJECTED.

---

APPROVED:



---

Timothy Wolfe, P.E., BCEE.  
Chief  
Office of Engineering and Construction



---

Matthew Garbark  
Director  
Department of Public Works

**A. QUESTIONS**

- 1. What restorations are included in the bid items 852 – 856, as it says “restorations”. Can you clarify what will be included in restoration?**

**Answer:** Per *SC-29 Street Cut and Restoration of Pavement Policy and Payment*, Part B – Measurement & Payment, "All temporary pavement restorations for any water main work in this contract shall not be measured but shall be considered incidental to all utility bid items". At all times, SC-29 supersedes all the restoration related payment policy for WC 1454. Accordingly, Bid Items 852–856 pertain solely to all temporary restorations.

**ITEM 852: 4 INCH DUCTILE IRON PIPE (CL. 54) AND FITTINGS, UP TO 8 FT LENGTH (Section 33 11 13)**

**ITEM 853: 6-8 INCH DUCTILE IRON PIPE (CL. 54) AND FITTINGS, UP TO 8 FT LENGTH (Section 33 11 13)**

**ITEM 854: 10-12 INCH DUCTILE IRON PIPE (CL. 54) AND FITTINGS, UP TO 8 FT LENGTH (Section 33 11 13)**

**ITEM 855: 16-20 INCH DUCTILE IRON PIPE (CL. 54) AND FITTINGS, UP TO 8 FT LENGTH (Section 33 11 13)**

**ITEM 856: 24-30 INCH DUCTILE IRON PIPE (CL. 54) AND FITTINGS, UP TO 8 FT LENGTH (Section 33 11 13)**

**ITEM 857: 36 INCH DUCTILE IRON PIPE (CL. 54) AND FITTINGS, UP TO 8 FT LENGTH (Section 33 11 13)**

Delete PART 4 MEASUREMENT AND PAYMENT in its entirety and replace it with the following:

Part 4 Measurement and Payment:

These items shall be measured for payment on a per each basis. Each location will be paid for under the appropriate item of work.

Payment for the furnishing and installing ductile iron pipe and fittings, up to 8 ft length shall be made at the Contract price bid per each for “4 Inch Ductile Iron Pipe (CL. 54) and Fittings, up to 8 ft length”, “6-8 Inch Ductile Iron Pipe (CL. 54) and Fittings, up to 8 ft length”, “10-12 Inch Ductile Iron Pipe (CL. 54) and Fittings, up to 8 ft length”, “16-20 Inch Ductile Iron Pipe (CL. 54) and Fittings, up to 8 ft length”, “24-30 Inch Ductile Iron Pipe (CL. 54) and Fittings, up to 8 ft length”, and “36 Inch Ductile Iron Pipe (CL. 54) and Fittings, up to 8 ft length” which price shall include all excavation, backfilling, compactions, temporary pavement restorations, furnishing of topsoil, seeding and mulching, sodding, furnishing and installing of ductile iron pipe and fittings, buttress (where required), furnishing and installing restraint devices and non-detectable tape, furnishing and installing sheeting and shoring, pumping, dewatering, couplings, sleeves, spool pieces, tees, crosses, insulation joints, cathodic protective coatings and wrappings, removing and disposing of existing pipe and fittings, removing and disposing of existing valves and vaults, and all tools, labor, materials, equipment, notifying consumers,

permits as required and coordination with the City, as-built submittal, and all incidentals necessary to complete the work.

Refer to Special Condition “STREET CUT AND RESTORATION OF PAVEMENT POLICY AND PAYMENT”.

- 2. What standard number the precast vaults are? 813 is for 16”-24” resilient wedge gate valve and 814 is for 36”-48” double Disc Gate Valve.**

**Answer:** BC Standard Detail No. 880.02 applies to 16-inch to 24-inch precast valve vaults. This standard detail is included in the WC 1454 Specifications under “Attachment A: Standard Details.” For 36-inch to 48-inch valve vaults, there are no published standard details within the contract documents. Accordingly, for 36-inch to 48-inch vaults, the Contractor is required to submit complete shop drawings for review and approval prior to fabrication, in accordance with the ‘SC-23 Shop Drawings Submittal’ requirements.

**ITEM 813 : ADDITIONAL COMPENSATION FOR FURNISHING & INSTALLATION OF PRE-CAST VAULT FOR 16 THRU 24 INCH RESILIENT WEDGE GATE VALVE**

**ITEM 814 : ADDITIONAL COMPENSATION FOR FURNISHING & INSTALLATION OF PRE-CAST VAULT FOR 36 THRU 48 INCH DOUBLE DISC GATE VALVE**

Supplement Item 813 & 814, Part 2 of the WC 1454 specifications with the following:

Refer to “Attachment A – Standard Details” BC Standard Detail No. 880.02 within the WC 1454 Specifications, for the standard details applicable to 16-inch to 24-inch precast vaults.