ELECTRIC PANEL SCHEDULE

DESIGNATION: HV1CR | LOCATION: MESH ROOM #145 | MOUNTING: SURFACE | PANEL TYPE: NEHB | MIN. A.I.C.: 14,000 | MAIN: M.L.O. | RATING: 225A.
VOLTAGE: 277/480 | PHASE: 3 | WIRE: 4 | CONNECTED LOAD: 23.0KW | FEEDER SIZE: 4#2THWN+1#6GND,1-1/2"C | SOURCE: HV DIST. BOARD | FEEDER PROTECTION: 100AMP-3P

CIR. NO.	CIRCUIT DESCRIPTION	VOLTS	PH	LOAD HP	LOAD KW	CIR BRKR AMPS	CIR BRKR POLE	BRANCH CIRCUIT WIRE/CABLE	BRANCH CIRCUIT CONDUIT	PH CON	PH CON	CIR. NO.	CIRCUIT DESCRIPTION	VOLTS	PH	LOAD HP	LOAD KW	CIR BRKR AMPS	CIR BRKR POLE	BRANCH CIRCUIT WIRE/CABLE	BRANCH CIRCUIT CONDUIT
1	LIGHTING-CORRIDOR	277	1		2.00	20A.	1	2#12+GND	3/4"	A	A	2	LIGHTING- LAVS. STOR. & CLASSROOM #155	277	1		3.30	20A.	1	2#12+GND	3/4"
3	LIGHTING-BOYS L.R.&CLASSRM#148	277	1		3.70	20A.	1	2#12+GND	3/4"	B	B	4	LIGHTING-CLASSRMS #153,154	277	1		3.0	20A.	1	2#12+GND	3/4"
5	LIGHTING-CLASSRMS #149,150	277	1		3.0	20A.	1	2#12+GND	3/4"	C	C	6	AIR HANDLING UNIT #6	480	3	3.0	4.0	20A.	3	3#12+GND	3/4"
7	AIR HANDLING UNIT #7	480	3	3/4	1.2	20A.	3	3#12+GND	3/4"	A		8									
9											B	10									
11											C	12	AIR HANDLING UNIT #8	480	3	1.0	1.5	20A.	3	3#12+GND	3/4"
13	AIR HANDLING UNIT #5	480	3	3/4	1.2	20A.	3	3#12+GND	3/4"	A		14									
15											B	16									
17											C	18	SPARE	277	1			20A.	1		
19	SPARE	277	1			20A.	1			A	A	20	SPARE	277	1			20A.	1		
21	SPARE	277	1			20A.	1			B	B	22	SPARE	277	1			20A.	1		
23	SPACE & BUSSING	277	1				1			C	C	24	SPACE & BUSSING	277	1				1		
25	SPACE & BUSSING	277	1				1			A	A	26	SPACE & BUSSING	277	1				1		
27	SPACE & BUSSING	277	1				1			B	B	28	SPACE & BUSSING	277	1				1		
29	SPACE & BUSSING	277	1				1			C	C	30	SPACE & BUSSING	277	1				1		
31	SPACE & BUSSING	277	1				1			A	A	32	SPACE & BUSSING	277	1				1		
33	SPACE & BUSSING	277	1				1			B	B	34	SPACE & BUSSING	277	1				1		
35	SPACE & BUSSING	277	1				1			C	C	36	SPACE & BUSSING	277	1				1		
37	SPACE & BUSSING	277	1				1			A	A	38	SPACE & BUSSING	277	1				1		
39	SPACE & BUSSING	277	1				1			B	B	40	SPACE & BUSSING	277	1				1		
41	SPACE & BUSSING	277	1				1			C	C	42	SPACE & BUSSING	277	1				1		

ELECTRIC PANEL SCHEDULE

DESIGNATION: HV2CR | LOCATION: STORAGE | MOUNTING: SURFACE | PANEL TYPE: NEHB | MIN. A.I.C.: 14,000 | MAIN: M.L.O. | RATING: 225A.
VOLTAGE: 277/480 | PHASE: 3 | WIRE: 4 | CONNECTED LOAD: 48.0KW | FEEDER SIZE: 4#1THWN+1#4GND,2"C | SOURCE: HV DIST. BOARD | FEEDER PROTECTION: 125AMP-3P

CIR. NO.	CIRCUIT DESCRIPTION	VOLTS	PH	LOAD HP	LOAD KW	CIR BRKR AMPS	CIR BRKR POLE	BRANCH CIRCUIT WIRE/CABLE	BRANCH CIRCUIT CONDUIT	PH CON	PH CON	CIR. NO.	CIRCUIT DESCRIPTION	VOLTS	PH	LOAD HP	LOAD KW	CIR BRKR AMPS	CIR BRKR POLE	BRANCH CIRCUIT WIRE/CABLE	BRANCH CIRCUIT CONDUIT
1	LIGHTING-CLASSRMS #212,213	277	1		3.0	20A.	1	2#12+GND	3/4"	A	A	2	LIGHTING-CLASSRMS #225,226	277	1		3.0	20A.	1	2#12+GND	3/4"
3	LIGHTING-CLASSRMS #214,215	277	1		3.0	20A.	1	2#12+GND	3/4"	B	B	4	LIGHTING-CLASSRMS #223,224	277	1		3.0	20A.	1	2#12+GND	3/4"
5	LIGHTING-LAV'S	277	1		2.0	20A.	1	2#12+GND	3/4"	C	C	6	LIGHTING-CLASSRMS #221,222	277	1		3.0	20A.	1	2#12+GND	3/4"
7	LIGHTING-CORRIDOR	277	1		2.4	20A.	1	2#12+GND	3/4"	A	A	8	LIGHTING-CLASSRMS #218,220	277	1		3.0	20A.	1	2#12+GND	3/4"
9	LIGHTING-STOR.#203&WORKRM.#202	277	1		1.5	20A.	1	2#12+GND	3/4"	B	B	10	LIGHTING-CLASSRMS #217,218	277	1		3.0	20A.	1	2#12+GND	3/4"
11	AIR HANDLING UNIT #9	480	3	2.0	3.0	20A.	3	3#12+GND	3/4"	C	C	12	AIR HANDLING UNIT #10	480	3	3/4	1.2	20A.	3	3#12+GND	3/4"
13										A	A	14									
15										B	B	16									
17	LIGHTING-SKYLIGHTS	277	1		1.5	20A.	1	2#12+GND	3/4"	C	C	18	SPARE	277	1			20A.	1		
19	CONDENSING UNIT	480	3		5.4	30A.	3	2#12+GND	3/4"	A	A	20	CONDENSING UNIT	480	3		5.4	30A.	3	3#12+GND	3/4"
21										B	B	22									
23										C	C	24									
25	SPARE	277	1			20A.	1			A	A	26	SPARE	277	1			20A.	1		
27	SPARE	277	1			20A.	1			B	B	28	SPARE	277	1			20A.	1		
29	SPARE	277	1			20A.	1			C	C	30	SPARE	277	1			20A.	1		
31	SPACE & BUSSING	277	1				1			A	A	32	SPACE & BUSSING	277	1				1		
33	SPACE & BUSSING	277	1				1			B	B	34	SPACE & BUSSING	277	1				1		
35	SPACE & BUSSING	277	1				1			C	C	36	SPACE & BUSSING	277	1				1		
37	SPACE & BUSSING	277	1				1			A	A	38	SPACE & BUSSING	277	1				1		
39	SPACE & BUSSING	277	1				1			B	B	40	SPACE & BUSSING	277	1				1		
41	SPACE & BUSSING	277	1				1			C	C	42	SPACE & BUSSING	277	1				1		

ELECTRIC PANEL SCHEDULE

DESIGNATION: HVAD | LOCATION: STORAGE # | MOUNTING: SURFACE | PANEL TYPE: NEHB | MIN. A.I.C.: 14,000 | MAIN: M.L.O. | RATING: 225A.
VOLTAGE: 277/480 | PHASE: 3 | WIRE: 4 | CONNECTED LOAD: 12.0KW | FEEDER SIZE: 4#2THWN+1#6GND,1-1/2"C. | SOURCE: HV DIST. BOARD | FEEDER PROTECTION: 100A-3P

CIR. NO.	CIRCUIT DESCRIPTION	VOLTS	PH	LOAD HP	LOAD KW	CIR BRKR AMPS	CIR BRKR POLE	BRANCH CIRCUIT WIRE/CABLE	BRANCH CIRCUIT CONDUIT	PH CON	PH CON	CIR. NO.	CIRCUIT DESCRIPTION	VOLTS	PH	LOAD HP	LOAD KW	CIR BRKR AMPS	CIR BRKR POLE	BRANCH CIRCUIT WIRE/CABLE	BRANCH CIRCUIT CONDUIT
1	LIGHTING- SCHOOL OFFICE & PRIN. OFFICE	277	1		3.8	20A.	1	2#12+GND	3/4"	A	A	2	LIGHTING-MAIN LOBBY	277	1		1.00	20A.	1	2#12+GND	3/4"
3	LIGHTING-CORRIDOR	277	1		3.0	20A.	1	2#12+GND	3/4"	B	B	4	LIGHTING-WORK RM. #162	277	1		2.00	20A.	1	2#12+GND	3/4"
5	SPARE	277	1			20A.	1			C	C	6	LIGHTING-GIRL'S LOCKER RM.	277	1		2.00	20A.	1	2#12+GND	3/4"
7	SPARE	277	1			20A.	1			A	A	8	SPARE	277	1			20A.	1		
9	SPARE	277	1			20A.	1			B	B	10	SPARE	277	1			20A.	1		
11	SPARE	277	1			20A.	1			C	C	12	SPARE	277	1			20A.	1		
13	SPACE & BUSSING	277	1				1			A	A	14	SPACE & BUSSING	277	1				1		
15	SPACE & BUSSING	277	1				1			B	B	16	SPACE & BUSSING	277	1				1		
17	SPACE & BUSSING	277	1				1			C	C	18	SPACE & BUSSING	277	1				1		
19	SPACE & BUSSING	277	1				1			A	A	20	SPACE & BUSSING	277	1				1		
21	SPACE & BUSSING	277	1				1			B	B	22	SPACE & BUSSING	277	1				1		
23	SPACE & BUSSING	277	1				1			C	C	24	SPACE & BUSSING	277	1				1		
25	SPACE & BUSSING	277	1				1			A	A	26	SPACE & BUSSING	277	1				1		
27	SPACE & BUSSING	277	1				1			B	B	28	SPACE & BUSSING	277	1				1		
29	SPACE & BUSSING	277	1				1			C	C	30	SPACE & BUSSING	277	1				1		

ELECTRIC PANEL SCHEDULE

DESIGNATION: HVMC | LOCATION: STORAGE #101 | MOUNTING: SURFACE | PANEL TYPE: NEHB | MIN. A.I.C.: 14,000 | MAIN: M.L.O. | RATING: 225A.
VOLTAGE: 277/480 | PHASE: 3 | WIRE: 4 | CONNECTED LOAD: 25.0KW | FEEDER SIZE: 4#2THWN+1#6GND,1-1/2"C. | SOURCE: HV DIST. SECTION | FEEDER PROTECTION: 100A-3P

CIR. NO.	CIRCUIT DESCRIPTION	VOLTS	PH	LOAD HP	LOAD KW	CIR BRKR AMPS	CIR BRKR POLE	BRANCH CIRCUIT WIRE/CABLE	BRANCH CIRCUIT CONDUIT	PH CON	PH CON	CIR. NO.	CIRCUIT DESCRIPTION	VOLTS	PH	LOAD HP	LOAD KW	CIR BRKR AMPS	CIR BRKR POLE	BRANCH CIRCUIT WIRE/CABLE	BRANCH CIRCUIT CONDUIT
1	LIGHTING-SKYLIGHT	277	1		2.0	20A.	1	2#12+GND	3/4"	A	A	2	LIGHTING-#101,102,103,104	277	1		2.0	20A.	1	2#12+GND	3/4"
3	LIGHTING-SKYLIGHT	277	1		1.2	20A.	1	2#12+GND	3/4"	B	B	4	LIGHTING-STORY#106,INSTRUC.#107	277	1		2.0	20A.	1	2#12+GND	3/4"
5	LIGHTING-MEDIA CENTER	277	1		1.0	20A.	1	2#12+GND	3/4"	C	C	6	LIGHTING-TYPE X FIXT.THRU R.C.	277	1		3.2	20A.	1	2#12+GND	3/4"
7	LIGHTING- EXIT SIGNS EMERGENCY LTG.	277	1		1.2	20A.	1	2#12+GND	3/4"	A	A	8	LIGHTING-TYPE X FIXT.THRU R.C.	277	1		2.0	20A.	1	2#12+GND	3/4"
9	LIGHTING-SPECIAL ED.#96&98	277	1		3.0	20A.	1	2#12+GND	3/4"	B	B	10	SPARE	277	1			20A.	1		
11	AIR HANDLING UNIT #14	480	3	1	1.8	20A.	3	3#12+GND	3/4"	C	C	12	AIR HANDLING UNIT #15	480	3	2.0	3.0	20A.	3	3#12+GND	3/4"
13										A		14									
15										B	B	16									
17	CONDENSING UNIT	480	3		12.0	50A.	3	3#10+GND	3/4"	C	C	18	SPARE	277	1			20A.	1		
19										A	A	20	SPARE	277	1			20A.	1		
21										B	B	22	SPARE	277	1			20A.	1		
23	SPARE	277	1			20A.	1			C	C	24	SPARE	277	1			20A.	1		
25	SPARE	277	1			20A.	1			A	A	26	SPACE & BUSSING	277	1				1		
27	SPARE	277	1			20A.	1			B	B	28	SPACE & BUSSING	277	1				1		
29	SPARE	277	1			20A.	1			C	C	30	SPACE & BUSSING	277	1				1		
31	SPACE & BUSSING	277	1				1			A	A	32	SPACE & BUSSING	277	1				1		
33	SPACE & BUSSING	277	1				1			B	B	34	SPACE & BUSSING	277	1				1		
35	SPACE & BUSSING	277	1				1			C	C	36	SPACE & BUSSING	277	1				1		
37	SPACE & BUSSING	277	1				1			A	A	38	SPACE & BUSSING	277	1				1		
39	SPACE & BUSSING	277	1				1			B	B	40	SPACE & BUSSING	277	1				1		
41	SPACE & BUSSING	277	1				1			C	C	42	SPACE & BUSSING	277	1				1		

ELECTRIC PANEL SCHEDULE

DESIGNATION: HVMR | LOCATION: MECHANICAL ROOM #125 | MOUNTING: SURFACE | PANEL TYPE: NEHB | MIN. A.I.C.: 14,000 | MAIN: M.L.O. | RATING: 225A.
VOLTAGE: 277/480 | PHASE: 3 | WIRE: 4 | CONNECTED LOAD: 78.0KW | FEEDER SIZE: 4#250MCM THWN +GND,3"C. | SOURCE: HV DIST. BOARD | FEEDER PROTECTION: 250A-3P

CIR. NO.	CIRCUIT DESCRIPTION	VOLTS	PH	LOAD HP	LOAD KW	CIR BRKR AMPS	CIR BRKR POLE	BRANCH CIRCUIT WIRE/CABLE	BRANCH CIRCUIT CONDUIT	PH CON	PH CON	CIR. NO.	CIRCUIT DESCRIPTION	VOLTS	PH	LOAD HP	LOAD KW	CIR BRKR AMPS	CIR BRKR POLE	BRANCH CIRCUIT WIRE/CABLE	BRANCH CIRCUIT CONDUIT
1	LIGHTING- SCIENCE #34 & READING #35	277	1		2.3	20A.	1	2#12+GND	3/4"	A	A	2	LIGHTING- CLASSROOM #99 & COMPUTER LAB #100	277	1		3.3	20A.	1	2#12+GND	3/4"
3	LIGHTING-#32,29,28	277	1		3.2	20A.	1	2#12+GND	3/4"	B	B	4	LIGHTING- HIGH TECH INDUST. TECH	277	1		3.1	20A.	1	2#12+GND	3/4"
5	LIGHTING-#125,122,121	277	1		3.3	20A.	1	2#12+GND	3/4"	C	C	6	LIGHTING-INDUST. TECH	277	1		2.0	20A.	1	2#12+GND	3/4"
7	LIGHTING- ART RM. #113 & RECYCLE RM. #110	277	1		3.0	20A.	1	2#12+GND	3/4"	A	A	8	LIGHTING-CORRIDOR	277	1		3.0	20A.	1	2#12+GND	3/4"
9	BOILER	480	3	1-1/2	2.2	20A.	3	3#12+GND	3/4"	B	B	10	AIR HANDLING UNIT #1	480	3	3/4	1.2	20A.	3	3#12+GND	3/4"
11												12									
13												14									
15	BOILER	480	3	1-1/2	9.0	20A.	3	3#12+GND	3/4"	B	B	16	AIR HANDLING UNIT #2	480	3	3/4	1.2	20A.	3	3#12+GND	3/4"
17												18									
19												20									
21	PUMP #P-1	480	3	10	9.0	30A	3	3#10+GND	3/4"	B	B	22	AIR HANDLING UNIT #3	480	3	3/4	1.2	20A.	3	3#12+GND	3/4"
23												24									
25												26									
27	PUMP #P-2	480	3	10	9.0	30A	3	3#10+GND	3/4"	B	B	28	AIR HANDLING UNIT #4	480	3	2.0	4.0	20A.	3	3#12+GND	3/4"
29												30									
31												32									
33	PUMP #P-3 (FUTURE)	480	3	7-1/2	9.0	30A	3	3#10+GND	3/4"	B	B	34	PUMP #P-4 (FUTURE)	480	3	7-1/2	9.0	30A.	3	3#10+GND	3/4"
35												36									
37												38									
39	SPARE	277	1			20A.	1			B	B	40	SPARE	277	1			20A.	1		
41	SPARE	277	1			20A.	1			C	C	42	SPARE	277	1			20A.	1		

ELECTRIC PANEL SCHEDULE

DESIGNATION: HVC | LOCATION: PLATFORM STOR. #129 | MOUNTING: SURFACE | PANEL TYPE: NEHB | MIN. A.I.C.: 14,000 | MAIN: M.L.O. | RATING: 225A.
VOLTAGE: 277/480 | PHASE: 3 | WIRE: 4 | CONNECTED LOAD: 79.0KW | FEEDER SIZE: 4#4/0 THWN + 1#2 GND., 2-1/2"C. | SOURCE: HV DIST. SECTION | FEEDER PROTECTION: 200A.-3P.

CIR. NO.	CIRCUIT DESCRIPTION	VOLTS	PH	LOAD HP	LOAD KW	CIR BRKR AMPS	CIR BRKR POLE	BRANCH CIRCUIT WIRE/CABLE	BRANCH CIRCUIT CONDUIT	PH CON	PH CON	CIR. NO.	CIRCUIT DESCRIPTION	VOLTS	PH	LOAD HP	LOAD KW	CIR BRKR AMPS	CIR BRKR POLE	BRANCH CIRCUIT WIRE/CABLE	BRANCH CIRCUIT CONDUIT
1	LIGHTING-STOR. #129	277	1		3.0	20A.	1	2#12+GND	3/4"	A	A	2	LIGHTING-GYM #130	277	1		2.6	20A.	1	2#12+GND	3/4"
3	LIGHTING-GYM #130	277	1		2.6	20A.	1	2#12+GND	3/4"	B	B	4	LIGHTING-GYM #130	277	1		2.6	20A.	1	2#12+GND	3/4"
5	LIGHTING-GYM #130	277	1		2.6	20A.	1	2#12+GND	3/4"	C	C	6	SPARE	277	1			20A	1		
7	SPARE	277	1			20A	1			A	A	8	SPARE	277	1			20A	1		
9	SPARE	277	1			20A	1			B	B	10	SPARE	277	1			20A	1		
11	SPARE	277	1			20A	1			C	C	12	SPARE	277	1			20A	1		
13	EXHAUST FAN #24	480	3	1-1/2	2.5	20A.	3	3#12+GND.	3/4"	A	A	14	EXHAUST FAN #25	480	3	1-1/2	2.5	20A.	3	3#12+GND.	3/4"
15										B	B	16									
17										C	C	18									
19	AIR HANDLING UNIT #12	480	3	5.0	6.4	20A.	3	3#12+GND.	3/4"	A	A	20	AIR HANDLING UNIT #13	480	3	5.0	6.4	20A.	3	3#12+GND.	3/4"
21										B	B	22									
23										C	C	24									
25	AIR HANDLING UNIT #11	480	3	2.0	2.8	20A.	3	3#12+GND.	3/4"	A	A	26	PLATFORM DIMMER CAB. (PDC)	480	3		45.0	70A.	3	3#4+1#8 GND.	1-1/2"
27										B	B	28									-
29										C	C	30									
31	SPACE & BUSSING	277	1				1			A	A	32	SPACE & BUSSING	277	1				1		
33	SPACE & BUSSING	277	1				1			B	B	34	SPACE & BUSSING	277	1				1		
35	SPACE & BUSSING	277	1				1			C	C	36	SPACE & BUSSING	277	1				1		
37	SPACE & BUSSING	277	1				1			A	A	38	SPACE & BUSSING	277	1				1		
39	SPACE & BUSSING	277	1				1			B	B	40	SPACE & BUSSING	277	1				1		
41	SPACE & BUSSING	277	1				1			C	C	42	SPACE & BUSSING	277	1				1		

ELECTRIC PANEL SCHEDULE

DESIGNATION: OLP | LOCATION: ELECTRICAL RM #111 | MOUNTING: SURFACE | PANEL TYPE: NEHB | MIN. A.I.C.: 14,000 | MAIN: M.L.O. | RATING: 225A.
VOLTAGE: 277/480V | PHASE: 3 | WIRE: 4 | CONNECTED LOAD: 10KW | FEEDER SIZE: 4#6&1-#8GND,1"C. | SOURCE: HV DIST. SECTION | FEEDER PROTECTION: 60A-3P

CIR. NO.	CIRCUIT DESCRIPTION	VOLTS	PH	LOAD HP	LOAD KW	CIR BRKR AMPS	CIR BRKR POLE	BRANCH CIRCUIT WIRE/CABLE	BRANCH CIRCUIT CONDUIT	PH CON	PH CON	CIR. NO.	CIRCUIT DESCRIPTION	VOLTS	PH	LOAD HP	LOAD KW	CIR BRKR AMPS	CIR BRKR POLE	BRANCH CIRCUIT WIRE/CABLE	BRANCH CIRCUIT CONDUIT
1	LIGHTING-COVERED WALKWAY	277	1		.80	20A.	1	2#12+GND	3/4"	A	A	2	LIGHTING-BLDG. EXTERIOR	277	1		1.50	20A.	1	2#12+GND	3/4"
3	SITE LIGHTING	277	1		2.64	20A.	1	2#8+1#10GND	3/4"	B	B	4	SITE LIGHTING	277	1		3.0	20A.	1	2#8,1-#10GND	3/4"
5	LIGHTING - BLDG. EXTERIOR	277	1		1.0	20A.	1	2#10+GND.	3/4"	C	C	5	LIGHTING-BLDG. EXTERIOR	277	1		1.0	20A.	1	2#10+GND	3/4"
7	SPARE	277	1			20A.	1			A	A	8	LIGHTING-BLDG. EXTERIOR	277	1		1.0	20A.	1	2#10+GND	3/4"
9	SPARE	277	1			20A.	1			B	B	10	SPARE	277	1			20A.	1		
11	SPARE	277	1			20A.	1			C	C	12	SPARE	277	1			20A.	1		
13	SPACE & BUSSING	277	1				1			A	A	14	SPACE & BUSSING	277	1				1		
15	SPACE & BUSSING	277	1				1			B	B	16	SPACE & BUSSING	277	1				1		
17	SPACE & BUSSING	277	1				1			C	C	18	SPACE & BUSSING	277	1				1		

COPYRIGHT OF DOCUMENTS
This document, and the ideas and designs incorporated herein, as an instrument of service, is the property of the architect and is not to be used in whole or in part for any purpose without the written authorization of the architect.

REVISIONS

NO	DATE	DESCRIPTION

COMPUTING ENGINEERS
MECHANICAL ELECTRICAL STRUCTURAL
TEL (203) 783-7979
FAX (203) 783-7978
TEN MILLSTONE CT
MILFORD, CT

LUCHINI MILFORD GOODELL & ASSOCIATES, INC.

THE LAWRENCE ASSOCIATES
ARCHITECTS / PLANNERS
1275 TOLLAND TURNPIKE MANCHESTER, CONNECTICUT 06040

PROJECT NUMBER 2155.01

PROJECT TITLE
ALTERATIONS AND ADDITIONS TO :
BOLTON ELEMENTARY SCHOOL
NOTCH ROAD
BOLTON, CONNECTICUT

DRAWING TITLE
ELECTRICAL PANELBOARD SCHEDULES

SCALE: AS NOTED | DATE: 8/17/92

E-11

DRAWING 84 OF 89

DOCUMENT OWNERSHIP
THESE DRAWINGS AND SPECIFICATIONS, THE DESIGNS DISCLOSED THEREIN AND THE TECHNICAL DATA AND ENGINEERING SERVICES REPRESENTED, THE EXCLUSIVE PROPERTY OF LUCHINI,MILFORT,GOODELL &ASSOC. INC WHETHER THE PROJECT FOR WHICH THEY ARE MADE IS EXCUTED OR NOT. THEY ARE NOT TO BE REPRODUCED IN WHOLE, OR IN PART, ORDISCLOSED ON OTHER PROJECTS, OR FOR DESIGN COMPLETION OF THIS PROJECT BY OTHERS, WITHOUT THE EXPRESS WRITTEN CONSENT OF THE ENGINEERS.