

## P&D Builders Job #1767



FLOOR PLAN NOTES

- 1. ALL DOORS SHALL BE 6" FROM ADJACENT WALL OR CENTERED IN WALL UNLESS NOTED OTHERWISE. 2. ALL INTERIOR STUD WALLS TO BE 2x4 STUDS @ 16" O.C.
- UNLESS NOTED OTHERWISE.
- 8. ALL DIMENSIONS TO INTERIOR WALLS ARE TO FACE OF STUD. ALL DIMENSIONS TO OUTSIDE FACE OF EXTERIOR WALLS ARE TO OUTSIDE FACE OF SHEATHING. ALL DIMENSIONS TO INSIDE FACE OF EXTERIOR WALL ARE TO FACE OF STUD.
- . ALL BEDROOM WINDOWS SHALL MEET CODE REQUIREMENTS FOR EGRESS. EGRESS CLEAR OPENINGS ON GRADE FLOOR SHALL BE A MINIMUM OF 5.0 SQUARE FEET. EGRESS CLEAR OPENINGS ON ALL OTHER FLOORS SHALL BE A MINIMUM OF 5.7 SQUARE FEET.
- . EGRESS WINDOWS TO HAVE A MINIMUM CLEAR HEIGHT OF 24" AND A MINIMUM CLEAR OPENING WIDTH OF 20". SILL HEIGHT SHALL NOT EXCEED 44" ABOVE THE FINISH FLOOR. ALL ANGLED WALLS ARE 45 DEGREES U.N.O.
- . ALL WORK SHALL BE PERFORMED IN ACCORDANCE WITH ALL APPLICABLE CODES AND REGULATIONS.
- CONTRACTOR SHALL VERIFY ALL CONDITIONS AND DIMENSIONS AT SITE BEFORE BEGINNING CONSTRUCTION. ANY DISCREPANCIES SHALL BE REPORTED IMMEDIATELY TO THE ARCHITECT IN WRITING FOR JUSTIFICATION AND / OR CORRECTION BEFORE PROCEEDING WITH WORK. CONTRACTORS SHALL ASSUME RESPONSIBILITY FOR ERRORS THAT ARE NOT REPORTED.
- 9. ALL DIMENSIONS SHALL BE READ OR CALCULATED AND NEVER
- 10. CONTRACTOR SHALL ENSURE COMPATIBILITY OF THE BUILDING WITH ALL SITE REQUIREMENTS.
- 11. ALL WOOD IN LOCATIONS SUBJECT TO TERMITE DECAY SHALL BE PRESSURE TREATED (CCA) OR BE OF AN APPROVED DECAY RESISTANT SPECIES. THIS INCLUDES, BUT NOT LIMITED TO, ALL EXTERIOR DECKS, SILLS AND SLEEPERS ON CONCRETE, MASONRY, OR IN DIRECT CONTACT WITH THE GROUND.

## DOOR LEGEND



## STRUCTURAL LEGEND

	- DIRECTION OF SPAN
\ <del>-</del>	EXTENTS OF STRUCTURE
<i>₹//////</i>	- SOLID BLOCKING
[	— STEEL BEAM (SEE PLAN FOR SIZE)
	- HEADER / BEAM (SEE PLAN FOR SIZE)
	- GIRDER TRUSS (SEE TRUSS MANF DWGS)
0-	- STEEL COLUMN (SEE PLAN FOR SIZE)
•	- POINT LOAD LOCATION
● <b>⋖</b>	- POINT LOAD FROM ABOVE

SEE SHEET A4-1 FOR GENERAL STRUCTURAL NOTES ALL LVL AND 2x WOOD BEAMS: (D) = DROPPED. (F) = FLUSH

TRUSS / JOIST / RAFTER INDICATOR

ALL HEADERS AND BEAMS TO BEAR ON MINIMUM (1) KING STUD (KS) & (1) JACK STUD (JS) EACH SIDE OF OPENING, U.N.O.

#	DATE	ISSUED WITH: CHANGE DESCRIPTION

BUILDERS




SCALE: 1/4" = 1'-0" SHEET # / DESCRIPTION

DATE: 10.24.2025



FIRST FLOOR PLAN 2,470 S.F.

## P&D Builders Job #1767



FOUNDATION NOTES

- 1. ALL 8" FOUNDATION WALLS SHALL HAVE A MINIMUM 16" x 8" CONTINUOUS POURED CONCRETE FOOTING, SEE WALL
- 2. CONTRACTOR TO VERIFY THAT ALL STRUCTURAL LOADS
- TRANSFER TO FOUNDATION
- . CEILING HEIGHTS IN BASEMENTS W/ITH HABITABLE SPACES OR HALLWAYS SHALL NOT BE LESS THAN 7'-0" CLEAR, EXCEPT UNDER BEAMS, DUCTS OR OTHER OBSTRUCTIONS WHERE THE CLEAR HEIGHT SHALL BE 6'-4" MINIMUM.
- ALL PREFABRICATED CONCRETE LINTELS AT FOOTING LEVEL CHANGES SHALL HAVE 8" MINIMUM BEARING AT EACH END. 5. REFER TO STRUCTURAL NOTES SHEET FOR GENERAL
- STRUCTURE INFORMATION.

STRUCTURAL LEGEND

TRUSS / JOIST / RAFTER INDICATOR - DIRECTION OF SPAN EXTENTS OF STRUCTURE

STEEL BEAM (SEE PLAN FOR SIZE) **───** HEADER / BEAM (SEE PLAN FOR SIZE) GIRDER TRUSS (SEE TRUSS MANF DWGS) STEEL COLUMN (SEE PLAN FOR SIZE)

POINT LOAD LOCATION ■ POINT LOAD FROM ABOVE SEE SHEET A4-1 FOR GENERAL STRUCTURAL NOTES

ALL LVL AND 2x WOOD BEAMS: (D) = DROPPED. (F) = FLUSH ALL HEADERS AND BEAMS TO BEAR ON MINIMUM (1) KING STUD (KS) & (1) JACK STUD (JS) EACH SIDE OF OPENING, U.N.O.

# DATE ISSUED WITH: CHANGE DESCRIPTION

BUILDERS



SCALE: 1/4" = 1'-0" SHEET # / DESCRIPTION

DATE: 10.24.2025




FINISHED BASEMENT PLAN 1,212 S.F. FINISHED BASEMENT



2 REAR ELEVATION



ELEVATION MATERIAL LEGEND




EXTERIOR FLASHING, CONDUITS, VENT PIPES, OR SIMILAR, TO COLOR MATCH ADJACENT MATERIALS, TYP. UNLESS PROHIBITED BY THE MANUFACTURER AND / OR CODE

#	DATE	ISSUED WITH: CHANGE DESCRIPTION

P&D
BUILDERS








RIGHT SIDE ELEVATION







# DATE ISSUED WITH: CHANGE DESCRIPTION

TO COLOR MATCH ADJACENT MATERIALS, TYP. UNLESS

PROHIBITED BY THE MANUFACTURER AND / OR CODE



SCALE: 1/4" = 1'-0" SHEET # / DESCRIPTION

DATE: 10.24.2025



LEFT SIDE ELEVATION