



12/7/2004

CLOSE OF FILE WITHOUT CERTIFICATION DUE TO DEFICIENCIES

MS. GINGER SHATTUCK
NORWALK LA MIRADA UNIFIED SCHOOL DISTRICT
12820 S. PIONEER BLVD.
NORWALK CA 90650

Project: Waite Middle School
Scope: Alteration to 4 - C.R. Bldgs (Relocation)(Stockpile # 66341); C.R. Bldg B (A 4631)(Toilet upgrade)
Application #: 03-105174
File #: 19-76

Dear MS. SHATTUCK:

The Department of General Services' records indicate that construction of the referenced project has been substantially completed in accordance with design documents approved by the Department. However, Verified Report documents and/or affidavits required to complete the file have not been received from the responsible entities, and the Division of the State Architect field engineer's final recommendations indicate potential deficiencies which are listed below:

1. DEFICIENCIES AS FOLLOWS:

- A) PARKING LOT SIGNAGE – INCOMPLETE
- B) RESTROOM SIGNAGE – INCOMPLETE
- C) GATE SIGN @ PATH OF TRAVEL – INCOMPLETE
- D) NEW FIRE HYDRANT INSTALLATION – INCOMPLETE
- E) ELECTRICAL ENGINEER SHALL VERIFY STROBE, SMOKE DETECTOR REQUIREMENT PER CBC
- F) FIRE ALARM TESTING REPORT

As these deficiencies remain uncorrected, the Department of General Services cannot certify this project. No further action by our office is anticipated on this project, and regretfully the file is being closed without issuance of the Department's certification of construction.

To reopen the project file, a submittal of outstanding documents along with **a warrant for \$150 is required** to recover our costs. If the listed documents cannot be obtained, an explanation regarding the attempts to secure them may be considered.

Sincerely,

Richard T. Conrad, FAIA
Acting State Architect

RTC:JEB:zsc

cc:
Mr. Marc Pange
File

Regional Office • 311 South Spring Street, Suite 1301 • Los Angeles, CA 90013 • (213) 897-3