



State of California • Arnold Schwarzenegger, Governor
State and Consumer Services Agency

DEPARTMENT OF GENERAL SERVICES
Division of the State Architect - Los Angeles Office

12/2/2005

CLOSE OF FILE WITHOUT CERTIFICATION DUE TO DEFICIENCIES

MR. BILL STUDDT
OXNARD UNION HIGH SCHOOL DISTRICT
309 S. K STREET
OXNARD CA 93030

Project: HUENEME HIGH SCHOOL
Scope: CONSTRUCTION OF LIGH POLE. (90 FEET HIGH)
Application #: 03-107175
File Id #: 56-H4

Dear Mr. Studt:

The Department of General Services' records indicate that construction of the referenced project has been substantially completed in accordance with design documents approved by the Department. However, Verified Report documents and/or affidavits required to complete the file have not been received from the responsible entities, and the Division of the State Architect field engineer's final recommendations indicate potential deficiencies which are listed below:

1. **DSA – 6A/E**
2. **DSA – 6 (Contractor)**
3. **DSA – 6 (Welding & In-Plant Inspectors)**
4. **Shop & Field Welding, Engineered Fill, Expansion & Epoxy Anchors, Caisson**
5. **DSA – 102 (Contract Information)**
6. **Notice of Completion**
7. **DEFICIENCIES: 1. The location change has no DSA approval. 2. A.O.R / Geotech has not address the soil failure during the drilling of the caisson.**

As these deficiencies remain uncorrected, the Department of General Services cannot certify this project. No further action by our office is anticipated on this project, and regretfully the file is being closed without issuance of the Department's certification of construction.

To reopen the project file, a submittal of outstanding documents along with **a warrant for \$150 is required** to recover our costs. If the listed documents cannot be obtained, an explanation regarding the attempts to secure them may be considered.

Sincerely,

David F. Thorman, AIA
State Architect

DFT: JEB:as

cc: Architect/Engineer
File