

ISO/IEC 17025 Certified Third Party Test Report

DATE: June 6, 2012

FILE: ROYSON.A053112C
PO #: 14395

CLIENT: Roysons
40 Vanderhoof Avenue
Rockaway, NJ 07866

ATTN: Mark Rain

SAMPLE IDENTIFIED BY CLIENT AS:


Vinyl Sample Submitted
Ref: Terralon Clear
Color Charcoal

TEST PROCEDURE:

TEST RESULTS:

WATER VAPOR TRANSMISSION
(ASTM E96), PROCEDURE B,
WATER METHOD, 70°F 50%Rh:
AIR GAP 3/4":

- PERMEANCE: 15.75 perms



Signed For The Company By

Adam R. Varley
Technical Director

JG/06/110



Stacy Sadovy
Stacy Sadovy
Quality Assurance Supervisor

