

Subject: Installation Clearances

WARNING: IT IS THE CUSTOMER'S RESPONSIBILITY TO MEET ALL STATE AND LOCAL CODES, AND INSURANCE REQUIREMENTS. IMPROPER INSTALLATION OF THE EQUIPMENT COULD CAUSE A FIRE THAT MAY RESULT IN EQUIPMENT DAMAGE, PERSONAL INJURY OR POSSIBLE DEATH. THE FOLLOWING INFORMATION IS A TYPICAL GUIDELINE ONLY!

We recommend you contact your local building inspection service or a qualified mechanical contractor for specific recommendations and/or requirements on your installation.

Equipment's Maximum Operating Temperature	Combustible Walls		Non-Combustible Walls	
	Ceiling	Walls	Ceiling	Walls
350°F to 650°F	18"	6"	12"	3"
651°F to 1000°F	24"	12"	18"	6"
1001°F to 1400°F	30"	18"	24"	12"

Access clearance in front of motors shall be 32".

Access clearance in front of the control cabinet/compartment shall be in compliance with NEC 1993, ARTICLE 110-32. Some typically examples:

- 36" in free air with no obstructions
- 48" from and brick, block or tile wall
- 60" from another panel or control cabinet/compartment with live parts.

We hope you will find this information useful. THANK YOU for contacting us and allowing us to be a service to you. Please contact us at 1-800-473-7373 if you have any questions.