

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20180801-E495867  
**Report Reference** E495867-20171227  
**Issue Date** 2018-AUGUST-01

**Issued to:** Igor, Inc.  
2700 Westown Pky, Suite 400  
West Des Moines IA 50266

**This is to certify that  
representative samples of**

**EMERGENCY LIGHTING AND POWER EQUIPMENT**  
PoE-powered, Model Series Nw50-60-x-y-z-EM, where w designates the node type and may be P for PoE Network Node, or D for Device Node, x is for LED drivers, C for Four Channel and W for One channel, y is the sensor I/O points, F for Full Sensor I/O and L for Limited Sensor I/O or N for None, z is for Wall switch points; 5 is for 5 button inputs and N is for none, and EM designates Emergency.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 924, Emergency Lighting and Power Equipment.  
CSA C.22.2 No. 141-15, Unit Equipment for Emergency Lighting.

**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

