



COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive
Marietta, GA 30060-3114
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions
Accounting
Communications & Education
Customer Service
Engineering & Records
Stormwater Management
System Maintenance
Water Protection

Press Release

Information on Sewer Overflow

Cobb County, GA - Oct 14, 2024

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: October 12, 2024
Location of overflow: 4874 CONDUCTOR WAY, MABLETON, GA 30126
This overflow resulted from: DEBRIS
Resulting in a wastewater discharge into: TRIBUTARY TO CLAY BRANCH
The volume of the overflow was estimated at: 360 Gallons
The Water System was notified at: Oct 12, 2024, 3:15 PM
The overflow was stopped at: Oct 12, 2024, 6:15 PM

Corrective action taken to reduce effects of the overflow include the following:

After using the jet machine to unstop the sewer line, the crew washed down the area.

Field Observation:

Upon arrival, the crew observed MH# 299-B279 and MH# 299-B305 spilling with secured lids. The sewage entered a storm drain connected to a nearby retention pond, which was released into a tributary of Clay Branch. During their time on-site, the crew did not observe any solids or fish kills.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

For Immediate Release