



## COBB COUNTY WATER SYSTEM

### System Maintenance Division

680 South Cobb Drive  
Marietta, GA 30060-3114  
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

**Divisions**  
Accounting  
Communications & Education  
Customer Service  
Engineering & Records  
Stormwater Management  
System Maintenance  
Water Protection

## Press Release

## Information on Sewer Overflow

Cobb County, GA - Oct 14, 2024

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: October 13, 2024  
Location of overflow: 484 STILLWATERS DR, MARIETTA, GA 30064  
This overflow resulted from: ROOTS  
Resulting in a wastewater discharge into: TRIBUTARY TO MUD CREEK  
The volume of the overflow was estimated at: 1000 Gallons  
The Water System was notified at: Oct 13, 2024, 1:26 PM  
The overflow was stopped at: Oct 13, 2024, 4:12 PM

Corrective action taken to reduce effects of the overflow include the following:

After using the jet machine to unstop the sewer line, the crew spread lime on the affected area.

Field Observation:

Upon arrival, the crew observed sewage exiting from the ground near an aerial pipe and entering a drainage ditch that empties into a tributary to Mud Creek. During their time onsite, the crew did not observe any fish kills.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

**For Immediate Release**