



COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive
Marietta, GA 30060-3114
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions
Accounting
Communications & Education
Customer Service
Engineering & Records
Stormwater Management
System Maintenance
Water Protection

Press Release

Information on Sewer Overflow

Cobb County, GA - Jan 3, 2025

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: January 3, 2025
Location of overflow: 1400 MARIETTA COUNTRY CLUB DR , KENNESAW,GA 30152
This overflow resulted from: GRAVEL
Resulting in a wastewater discharge into: NOONDAY CREEK
The volume of the overflow was estimated at: 120 Gallons
The Water System was notified at: Jan 3, 2025, 10:10 AM
The overflow was stopped at: Jan 3, 2025, 11:10 AM

Corrective action taken to reduce effects of the overflow include the following:

After using the jet machine to unstop the sewer line, the crew spread lime on the affected areas.

Field Observation:

Upon arrival, the crew observed MH# 306-0091 spilling with a secured lid. The escaping sewage left a 20-foot by 20-foot area around the manhole and a 5-foot by 60-foot trail, entering Noonday Creek. The crew also observed MH# 306-0088 spilling with a secured lid, leaving a 10-foot by 80-foot trail that entered Noonday Creek. During their time on-site, the crew did not observe any fish kills.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

For Immediate Release