



## COBB COUNTY WATER SYSTEM

### System Maintenance Division

680 South Cobb Drive  
Marietta, GA 30060-3114  
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

**Divisions**  
**Accounting**  
**Communications & Education**  
**Customer Service**  
**Engineering & Records**  
**Stormwater Management**  
**System Maintenance**  
**Water Protection**

# Press Release

## Information on Sewer Overflow

Cobb County, GA - Feb 10, 2025

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: February 8, 2025  
Location of overflow: 2890 SPRINGVIEW CT, ATLANTA, GA 30339  
This overflow resulted from: RAGS  
Resulting in a wastewater discharge into: TRIBUTARY TO GILMORE CREEK  
The volume of the overflow was estimated at: 230 Gallons  
The Water System was notified at: Feb 8, 2025, 5:51 PM  
The overflow was stopped at: Feb 8, 2025, 7:45 PM

Corrective action taken to reduce effects of the overflow include the following:

After using the jet machine to unstop the sewer line, the crew spread lime on the affected area.

Field Observation:

Upon arrival, the crew observed evidence of a spill around MH# 193-C027. Traces of a 10-foot by 5-foot trail entering a tributary to Gilmore Creek. After unstopping the line, the crew observed a light gray discoloration in the creek. During their time on-site, no fish kills were observed.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

**For Immediate Release**