



COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive
Marietta, GA 30060-3114
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions
Accounting
Communications & Education
Customer Service
Engineering & Records
Stormwater Management
System Maintenance
Water Protection

Press Release

Information on Sewer Overflow

Cobb County, GA - Feb 19, 2025

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: February 19, 2025
Location of overflow: 1400 MARIETTA COUNTRY CLUB DR, KENNESAW, GA 30152
This overflow resulted from: GRAVEL
Resulting in a wastewater discharge into: NOONDAY CREEK
The volume of the overflow was estimated at: 120 Gallons
The Water System was notified at: Feb 19, 2025, 11:40 AM
The overflow was stopped at: Feb 19, 2025, 12:00 PM

Corrective action taken to reduce effects of the overflow include the following:
Used jet machine to clear blockage from main line. Spread lime around spill area.

Field Observation:

While performing maintenance in the area, the crew found sewage seeping from manhole with lid secure. Sewage left a 7-foot by 20-foot trail leading down to light gray water along the creek bank in the waterway.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

For Immediate Release