



## COBB COUNTY WATER SYSTEM

### System Maintenance Division

680 South Cobb Drive  
Marietta, GA 30060-3114  
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

**Divisions**  
Accounting  
Communications & Education  
Customer Service  
Engineering & Records  
Stormwater Management  
System Maintenance  
Water Protection

## Press Release

## Information on Sewer Overflow

Cobb County, GA - Feb 24, 2025

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: February 22, 2025  
Location of overflow: 2404 MIRRABEAU CT, MARIETTA,GA,30066  
This overflow resulted from: DEBRIS  
Resulting in a wastewater discharge into: LITTLE NOONDAY CREEK  
The volume of the overflow was estimated at: 230 Gallons  
The Water System was notified at: Feb 22, 2025, 10:43 AM  
The overflow was stopped at: Feb 22, 2025, 12:38 PM

Corrective action taken to reduce effects of the overflow include the following:

After using the jet machine to unstop the sewer line, the crew spread lime on the affected area.

Field Observation:

Upon arrival, the crew observed MH# 309-0051 spilling with a secured lid. The escaping sewage left a 1-foot by 20-foot trail, entering Little Noonday Creek. During their time on-site, the crew did not observe any fish kills.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

**For Immediate Release**