



## COBB COUNTY WATER SYSTEM

### System Maintenance Division

680 South Cobb Drive  
Marietta, GA 30060-3114  
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

**Divisions**  
**Accounting**  
**Communications & Education**  
**Customer Service**  
**Engineering & Records**  
**Stormwater Management**  
**System Maintenance**  
**Water Protection**

## Press Release

### Information on Sewer Overflow

Cobb County, GA - Mar 13, 2025

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: March 12, 2025  
Location of overflow: 1218 SIX FLAGS RD, AUSTELL, GA 30168  
This overflow resulted from: GRAVEL  
Resulting in a wastewater discharge into: TRIBUTARY TO CHATTAHOOCHEE RIVER  
The volume of the overflow was estimated at: 590 Gallons  
The Water System was notified at: Mar 12, 2025, 12:22 PM  
The overflow was stopped at: Mar 12, 2025, 2:00 PM

Corrective action taken to reduce effects of the overflow include the following:

The crew used the jet machine to unstop the sewer line.

Field Observation:

Upon arrival, crews observed manhole #283-A035 actively spilling with a secured lid. The overflow created a 4-foot by 25-foot wet area, which entered a storm drain leading to a tributary of the Chattahoochee River. No solids or fish kills were observed during the inspection

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

**For Immediate Release**