



COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive
Marietta, GA 30060-3114
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions
Accounting
Communications & Education
Customer Service
Engineering & Records
Stormwater Management
System Maintenance
Water Protection

Press Release

Information on Sewer Overflow

Cobb County, GA - Mar 24, 2025

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: March 23, 2025
Location of overflow: 5011 WHITE BLVD, MABLETON GA 30126
This overflow resulted from: GREASE
Resulting in a wastewater discharge into: TRIBUTARY TO BUTLER CREEK
The volume of the overflow was estimated at: 690 Gallons
The Water System was notified at: Mar 23, 2025, 2:25 PM
The overflow was stopped at: Mar 23, 2025, 4:20 PM

Corrective action taken to reduce effects of the overflow include the following:

The crew used the jet machine to unstop the sewer line. Lime was applied to the affected area.

Field Observation:

Upon arrival, crews observed manhole on property actively spilling with a secured lid. The overflow created a pool of sewage that lead to the tributary of Butler Creek. No solids or fish kills were observed during the inspection

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

For Immediate Release