



## COBB COUNTY WATER SYSTEM

### System Maintenance Division

680 South Cobb Drive  
Marietta, GA 30060-3114  
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

**Divisions**  
**Accounting**  
**Communications & Education**  
**Customer Service**  
**Engineering & Records**  
**Stormwater Management**  
**System Maintenance**  
**Water Protection**

## Press Release

## Information on Sewer Overflow

Cobb County, GA - May 14, 2025

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: May 13, 2025  
Location of overflow: 1901 ROSS RD, MARIETTA, GA 30066  
This overflow resulted from: DEBRIS  
Resulting in a wastewater discharge into: LITTLE NOONDAY CREEK  
The volume of the overflow was estimated at: 100 Gallons  
The Water System was notified at: May 13, 2025, 11:30 AM  
The overflow was stopped at: May 13, 2025, 12:20 PM

Corrective action taken to reduce effects of the overflow include the following:

The crew removed the failed plug after using the jet machine to unstop the sewer line. Lime was spread on the affected area.

#### Field Observation:

Upon arrival, the crew observed MH# 309-0057A spilling with a secured lid. The escaping sewage left a 10-foot by 20-foot trail, entering Little Noonday Creek. The crew observed light discoloration in the waterway. No fish kills or solids were found during the time on-site.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

**For Immediate Release**