

COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive Marietta, GA 30060-3114 Phone: (770) 419-6351 Judy B. Jones, P.E. - Director

Divisions
Accounting
Communications & Education
Customer Service
Engineering & Records
Stormwater Management
System Maintenance
Water Protection

Press Release

Information on Sewer Overflow

Cobb County, GA - Jun 16, 2025

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: June 15, 2025

Location of overflow: 645 ERNEST BARRETT PKWY NW, KENNESAW, GA 30144

This overflow resulted from: GRAVEL

Resulting in a wastewater discharge into: TRIBUTARY TO NOONDAY CREEK

TRIBUTARY NO 6

The volume of the overflow was

estimated at:

430 Gallons

The Water System was notified at: Jun 15, 2025, 12:10 PM
The overflow was stopped at: Jun 15, 2025, 3:45 PM

Corrective action taken to reduce effects of the overflow include the following:

After setting up a sewer bypass, the crew used a jet machine to unstop the line and a vactor to clean the spill area.

Field Observation:

Upon arrival, the crew observed grey water seeping through the asphalt. Excavation of manhole #307-S200 confirmed active sewage overflow. The spill affected an area approximately 3 feet by 50 feet surrounding the manhole, with a 3-foot by 385-foot trail leading to nearby storm drains that discharge into tributary to Noonday Creek Tributary No 6. No solids or fish kills were observed during the on-site inspection.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

For Immediate Release