



## COBB COUNTY WATER SYSTEM

### System Maintenance Division

680 South Cobb Drive  
Marietta, GA 30060-3114  
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

**Divisions**  
**Accounting**  
**Communications & Education**  
**Customer Service**  
**Engineering & Records**  
**Stormwater Management**  
**System Maintenance**  
**Water Protection**

# Press Release

## Information on Sewer Overflow

Cobb County, GA - Jun 24, 2025

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: June 23, 2025  
Location of overflow: 4125 LAKESHORE WAY NE MARIETTA, GA 30067  
This overflow resulted from: RAGS  
Resulting in a wastewater discharge into: TRIBUTARY TO SOPE CREEK  
The volume of the overflow was estimated at: 400 Gallons  
The Water System was notified at: Jun 23, 2025, 11:16 AM  
The overflow was stopped at: Jun 23, 2025, 1:57 PM

Corrective action taken to reduce effects of the overflow include the following:

After using the jet machine to unstop the sewer line, the crew spread lime on the affected areas.

Field Observation:

Dispatch received a call for 193 Lakeshore Dr. Upon arrival, the crew observed sewage backing up into the residence. While inspecting the area, MH# 105-P119 seeping through the embankment wall, directly into a tributary to Sope Creek. During the time on-site, no solids or fish kills were observed.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

**For Immediate Release**