



COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive
Marietta, GA 30060-3114
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions
Accounting
Communications & Education
Customer Service
Engineering & Records
Stormwater Management
System Maintenance
Water Protection

Press Release

Information on Sewer Overflow

Cobb County, GA - Jun 25, 2025

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: June 24, 2025
Location of overflow: 1016 WOODWARD CIR SW, MABLETON, GA 30126
This overflow resulted from: RAGS
Resulting in a wastewater discharge into: CLAY BRANCH
The volume of the overflow was estimated at: 70 GALLONS
The Water System was notified at: Jun 24, 2025, 3:43 PM
The overflow was stopped at: Jun 24, 2025, 4:16 PM

Corrective action taken to reduce effects of the overflow include the following:

After manually removing debris and rags and using the jet machine to unstop the sewer line, the crew cleaned the affected area.

Field Observation:

Upon arrival, the crew observed MH# 299-B162 spilling with a secured lid. The escaping sewage left a 20-foot clear stream that entered a drainage ditch, which feeds into a tributary to Clay Branch. During the time on-site, no solids or fish kills were observed.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

For Immediate Release