



COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive
Marietta, GA 30060-3114
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions
Accounting
Communications & Education
Customer Service
Engineering & Records
Stormwater Management
System Maintenance
Water Protection

Press Release

Information on Sewer Overflow

Cobb County, GA - Jun 27, 2025

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: June 26, 2025
Location of overflow: 2718 LONG LAKE DR, ROSWELL, GA 30075
This overflow resulted from: ROOTS
Resulting in a wastewater discharge into: TRIBUTARY TO WILLEO CREEK
The volume of the overflow was estimated at: 90 Gallons
The Water System was notified at: Jun 26, 2025, 10:35 AM
The overflow was stopped at: Jun 26, 2025, 11:20 AM

Corrective action taken to reduce effects of the overflow include the following:

After using the jet machine to unstop the sewer line, the crew spread lime on the affected area.

Field Observation:

Dispatch received a call for 2724 Long Lake Dr. During a routine sewer line flush, crews observed sewage spilling from MH# 402-A012, which had a secured lid. The escaping sewage created a 1-foot by 35-foot trail that entered a pond feeding a tributary of Willeo Creek. No fish kills were observed during the on-site inspection.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

For Immediate Release