



COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive
Marietta, GA 30060-3114
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions
Accounting
Communications & Education
Customer Service
Engineering & Records
Stormwater Management
System Maintenance
Water Protection

Press Release

Information on Sewer Overflow

Cobb County, GA - Jun 27, 2025

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: June 27, 2025
Location of overflow: 6247 BENBROOKE DR ACWORTH, GA 30101
This overflow resulted from: ROOTS
Resulting in a wastewater discharge into: TRIBUTARY TO LITTLE ALLATOONA CREEK
The volume of the overflow was estimated at: 90 Gallons
The Water System was notified at: Jun 27, 2025, 12:05 PM
The overflow was stopped at: Jun 27, 2025, 12:50 PM

Corrective action taken to reduce effects of the overflow include the following:

After using the jet machine to unstop the sewer line, the crew spread lime on the affected area.

Field Observation:

Dispatch received a call for 6245 Benbrooke Dr. Upon arrival, the crew observed MH# 523-K044 spilling with a secured lid. The escaping sewage left a 20-foot by 30-foot spill area, entering a tributary to Little Allatoona Creek. No discoloration or fish kills were observed during the time onsite.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

For Immediate Release