



COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive
Marietta, GA 30060-3114
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions
Accounting
Communications & Education
Customer Service
Engineering & Records
Stormwater Management
System Maintenance
Water Protection

Press Release

Information on Sewer Overflow

Cobb County, GA - Jul 8, 2025

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: July 7, 2025
Location of overflow: 2350 MILSTEAD CIR NE MARIETTA, GA 30066
This overflow resulted from: ROOTS
Resulting in a wastewater discharge into: TRIBUTARY TO MORGAN LAKE TRIBUTARY
The volume of the overflow was estimated at: 330 Gallons
The Water System was notified at: Jul 7, 2025, 3:05 PM
The overflow was stopped at: Jul 7, 2025, 5:50 PM

Corrective action taken to reduce effects of the overflow include the following:

A jet machine was used to clear the blockage at MH# 309-B167A. Lime was applied to the affected area.

Field Observation:

Upon arrival, crews observed black water discharging from MH# 309-B167A, flowing onto the ground and into a tributary to Morgan Lake Tributary covering an area approximately 4 feet by 25 feet. The next downstream MH# 309-B148 was covered with sod but was holding. A debris basket was used to capture and remove solids. The blockage was cleared at MH# 309-B149 on Morgan Lake Road. No discoloration or debris was observed in the waterway or on the ground.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###
For Immediate Release